



VALVE BONNET BOLTING						
VALVE NO.	VALVE TYPE	NO. OF BOLTS	BOLT DIA.	BOLT TYPE	VALVE MANUFACTURER	MANUFACTURER DWG. NO.
898	G-642				ALOTCO	D-435 11

THIS REVISION IS CLASS 'A' PER 240-1, UPDATED DWG. AS PER RESPONSE TO IE BULLETIN 73-14 AS CONSTRUCTED. INSERVICE FIELD REVISION INFORMATION RELEASE FOR RECORD P.N. 69911-EI J.S.

**REVISIONS**

0 THIS ISSUE IS NON-CLASS 'A' PER CI 240-1. RELEASE FOR RECORD. P.N. 7076 11-3-78

1 THIS REVISION IS NON-CLASS 'A' PER CI-240-1. ADDED REF. DRAWINGS. ADDED LATEST REV. NO TO REF. DWG'S. RELEASE FOR RECORD. P.N. 7076 RT/AS EBASCO SERVICES, INC. 1-10-80

2 THIS REVISION IS NON-CLASS 'A' PER CI-240-1. UPDATED DWG. AS PER RESPONSE TO IE BULLETIN 73-14 AS CONSTRUCTED. INSERVICE FIELD REVISION INFORMATION RELEASE FOR RECORD P.N. 90051 V6/ 11-26-82

3 ADDED LATEST REV. NO. TO REF. DWGS. RELEASE FOR RECORD P.N. 21368 TREADWELL CORP. 11-12-82

4 THIS REV. IS NON CLASS PER CI 240-1. CHANGED DISCIPLINE CODE FROM MJ TO HL. RELEASE FOR RECORD. P.N. 69911-EI AG

**GENERAL NOTES**

1. WELDS IN 6" NPS, SCHEDULE 10S, PIPING ARE NOT REQUIRED TO BE EXAMINED PER TABLE IWC-2500-1. THE WELDS ARE INCLUDED IN THE COUNT TO WHICH THE SAMPLING RATES IS APPLIED.

TYPICAL WELD DETAIL DRAWINGS  
 6" CLASS 151, SCH 10S-D 208010

- REFERENCE DRAWINGS**
- FLOW DIAGRAM-SAFETY INJECTION SYSTEM — A235296
  - PRIMARY AUX. BLDG.-COMPOSITE PIPING ARR'G'T.-PLANS AT EL 15', EL 35', EL 42', EL 59' — 9321-F-2573
  - PRIMARY AUX. BLDG.-COMPOSITE PIPING ARR'G'T.-SECTIONS-SHEET No 3 — 9321-F-2588
  - PRIMARY AUX. BLDG.-COMPOSITE PIPING ARR'G'T.-SECTIONS-SHEET No 4 — 9321-F-2589
  - PRIMARY AUX. BLDG.-COMPOSITE PIPING ARR'G'T.-LOWER PLAN AT EL 68' AND SECTIONS SHEET No 2 — 9321-F-2587
  - PRIMARY AUX. BLDG.-COMPOSITE PIPING ARR'G'T.-PLAN AT EL 68'-0 — 9321-F-2570

- SYMBOL IDENTIFICATION**
- SUPPORT NUMBER
  - VALVE NUMBER
  - WELD NUMBER
  - QUALITY GROUP CLASSIFICATION
  - INTEGRAL SUPPORT WELD NUMBER

NOT FOR FABRICATION OR INSTALLATION

THIS DRAWING CONTAINS ITEMS WHICH MUST BE CONTROLLED WITHIN CON EDISON AS: "CLASS A" ITEMS PER CI-240-1

NOT FOR FABRICATION OR INSTALLATION

**B206911-4**

**CONSOLIDATED EDISON CO.**  
 OF NEW YORK, INC.

STATION LOCATION: INDIAN POINT No 2  
 INSERVICE INSPECTION  
 METRIC OF SAFETY INJECTION LINE  
 No 518- PRIMARY AUXILIARY BLDG

SCALE: NONE  
 DATE: 7/76  
 DRAWN BY: P. DENE  
 CHECKED BY: SIMONE

**APPROVALS**

DESIGNED BY: [Signature]  
 CHECKED BY: [Signature]  
 IN CHARGE: [Signature]  
 SUPERVISOR: [Signature]  
 OPERATOR: [Signature]  
 INSPECTOR: [Signature]  
 MAINTENANCE: [Signature]  
 PLANT ATTENDANT: [Signature]

Packet # 50-247  
 Session # 2023/01/17  
 to 2/27/74  
 Regulatory Docket File of Lir

ML