



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

August 6, 2010

LICENSEE: Omaha Public Power District
FACILITY: Fort Calhoun Station, Unit 1
SUBJECT: SUMMARY OF CONFERENCE CALL HELD ON JULY 16, 2010, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND OMAHA PUBLIC POWER DISTRICT CONCERNING GENERIC LETTER 2008-01 (TAC NO. MD7829)

On January 11, 2008, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2008-01, "Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML072910759). Omaha Public Power District (OPPD, the licensee) provided a response dated October 14, 2008 (ADAMS Accession No. ML082890096), regarding Fort Calhoun Station, Unit 1 (FCS).

The NRC staff and representatives of OPPD held a conference call on July 16, 2010, to discuss the licensee's response. The conference call was held in lieu of the NRC staff issuing a request for additional information. A list of participants is enclosed.

The licensee stated that it would provide a summary of the findings for items 2-8, 10, 14, 18, and 19 as listed in Section B, "Description of Necessary Corrective Actions," of its letter dated October 14, 2008. The licensee stated that it would also discuss the pump suction piping acceptance criteria.

In addition, the licensee subsequently stated that it would discuss the following:

- The surveillance intervals for the monitored locations, including justification for surveillance intervals greater than 31 days for emergency core cooling, decay heat removal, and containment spray systems.
- The training involved to ensure the compliance of emergency core cooling, decay heat removal, and containment spray systems with the NRC requirements as addressed in GL 2008-01. Although training was not identified in the GL 2008-01, it is considered to be a necessary part of applying procedures and other activities when addressing the issues identified in the GL 2008-01.

The licensee subsequently informed the NRC staff that it would submit a supplement by August 9, 2010.

- 2 -

If you have any questions concerning this matter, please contact me at (301) 415-1377 or via e-mail at Lynnea.Wilkins@nrc.gov.

A handwritten signature in black ink, appearing to read 'Lynnea Wilkins', written in a cursive style.

Lynnea Wilkins, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-285

Enclosure:
List of Participants

cc w/encl: Distribution via Listserv

LIST OF PARTICIPANTS
TELECONFERENCE ON JULY 16, 2010
BETWEEN U.S. NUCLEAR REGULATORY COMMISSION
AND OMAHA PUBLIC POWER DISTRICT (OPPD)
REGARDING GENERIC LETTER 2008-01
FORT CALHOUN STATION, UNIT 1
DOCKET NO. 50-285

Participants	Organization
Lynnea Wilkins	NRC
Kulin Desai	NRC
Bill Hansher	OPPD
Nicole Bretey	OPPD

Enclosure

If you have any questions concerning this matter, please contact me at (301) 415-1377 or via e-mail at Lynnea.Wilkins@nrc.gov.

/ra/

Lynnea Wilkins, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-285

Enclosure:
List of Participants

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC
LPLIV Reading
RidsAcrsAcnw_MailCTR Resource
RidsNrrDorlLpl4 Resource
RidsNrrDss Resource

RidsNrrPMFortCalhoun Resource
RidsNrrLAJBurkhardt Resource
RidsOgcRp Resource
RidsRgn4MailCenter Resource
KDesai, NRR/DSS

ADAMS Accession No. ML102110137

OFFICE	DORL/LPL4/PM	DORL/LPL4/LA	DORL/LPL4/BC	DORL/LPL4/PM
NAME	LWilkins	JBurkhardt	MMarkley (CFLyon for)	LWilkins
DATE	8/3/10	8/2/10	8/6/10	8/6/10

OFFICIAL RECORD COPY