

**Southern Nuclear
Operating Company, Inc.**
42 Inverness Center Parkway
Birmingham, Alabama 35242



JUL 30 2010

Docket Nos.: 52-025
52-026

ND-10-1473

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001

Southern Nuclear Operating Company
Vogtle Electric Generating Plant Units 3 and 4 Combined License Application
Voluntary Revision to Final Safety Analysis Report Chapter 6

Ladies and Gentlemen:

By letter dated March 28, 2008, Southern Nuclear Operating Company (SNC) submitted an application for combined licenses (COLs) for proposed Vogtle Electric Generating Plant (VEGP) Units 3 and 4 to the U.S. Nuclear Regulatory Commission (NRC) for two Westinghouse AP1000 reactor plants. SNC is supplementing the COL application by providing additional changes to Chapter 6 of the Final Safety Analysis Report (i.e., Part 2 of the COL application) to address recently identified revisions to the information provided in Westinghouse AP1000 Design Control Document (DCD) Chapters 2 and 6. The enclosure to this letter describes the changes to Chapter 6 of the Final Safety Analysis Report (FSAR).

If you have any questions regarding this letter, please contact Mr. Wes Sparkman at (205) 992-5061 or Ms. Amy Aughtman at (205) 992-5805.

AD53
NRQ

Mr. C. R. Pierce states he is the AP1000 Licensing Manager of Southern Nuclear Operating Company, is authorized to execute this oath on behalf of Southern Nuclear Operating Company and to the best of his knowledge and belief, the facts set forth in this letter are true.

Respectfully submitted,

SOUTHERN NUCLEAR OPERATING COMPANY

Charles R. Pierce

Charles R. Pierce

Sworn to and subscribed before me this 30th day of July, 2010

Notary Public: Dana Marie Williams

My commission expires: 12/29/2010

CRP/BJJ

Enclosure: VEGP Units 3 and 4 COL Application - Voluntary Revision to FSAR Chapter



cc: Southern Nuclear Operating Company

Mr. J. H. Miller, III, President and CEO (w/o enclosure)
Mr. J. A. Miller, Executive Vice President, Nuclear Development (w/o enclosure)
Mr. J. T. Gasser, Executive Vice President, Nuclear Operations (w/o enclosure)
Mr. B. L. Ivey, Vice President, Nuclear Development Support (w/o enclosure)
Mr. D. H. Jones, Site Vice President, Vogtle 3 & 4 (w/o enclosure)
Mr. T. E. Tynan, Vice President - Vogtle (w/o enclosure)
Mr. M. K. Smith, Technical Support Director (w/o enclosure)
Mr. D. M. Lloyd, Vogtle 3 & 4 Project Support Director (w/o enclosure)
Mr. M. J. Ajluni, Nuclear Licensing Manager
Mr. T. C. Moorner, Manager, Environmental Affairs, Chemistry and Rad. Services
Mr. J. D. Williams, Vogtle 3 & 4 Site Support Manager
Mr. J. T. Davis, Vogtle 3 & 4 Site Licensing Manager
Mr. W. A. Sparkman, COL Project Engineer
Ms. A. G. Aughtman, AP1000 Licensing Project Engineer
Document Services RTYPE: AR01.1053
File AR.01.02.06

Nuclear Regulatory Commission

Mr. L. A. Reyes, Region II Administrator
Mr. F. M. Akstulewicz, Deputy Director Div. of Safety Systems & Risk Assess. (w/o encl.)
Mr. R. G. Joshi, Lead Project Manager of New Reactors
Ms. T. E. Simms, Project Manager of New Reactors
Mr. B. C. Anderson, Project Manager of New Reactors
Mr. M. M. Comar, Project Manager of New Reactors
Ms. S. Goetz, Project Manager of New Reactors
Mr. J. M. Sebrosky, Project Manager of New Reactors
Mr. D. C. Habib, Project Manager of New Reactors
Ms. D. L. McGovern, Project Manager of New Reactors
Ms. T. L. Spicher, Project Manager of New Reactors
Ms. M. A. Sutton, Environmental Project Manager
Mr. M. D. Notich, Environmental Project Manager
Mr. L. M. Cain, Senior Resident Inspector of VEGP 1 & 2
Mr. J. D. Fuller, Senior Resident Inspector of VEGP 3 & 4

Georgia Power Company

Mr. T. W. Yelverton, Nuclear Development Director
Ms. A. N. Faulk, Nuclear Regulatory Affairs Manager

Oglethorpe Power Corporation

Mr. M. W. Price, Executive Vice President and Chief Operating Officer
Mr. K. T. Haynes, Director of Contracts and Regulatory Oversight

Municipal Electric Authority of Georgia

Mr. J. E. Fuller, Senior Vice President, Chief Financial Officer
Mr. S. M. Jackson, Vice President, Power Supply

Dalton Utilities

Mr. D. Cope, President and Chief Executive Officer

Bechtel Power Corporation

Mr. J. S. Prebula, Project Engineer (w/o enclosure)
Mr. R. W. Prunty, Licensing Engineer

Tetra Tech NUS, Inc.

Ms. K. K. Patterson, Project Manager

Shaw Stone & Webster, Inc.

Mr. C. A. Fonseca, Vogtle Project Manager (w/o enclosure)
Mr. J. M. Oddo, Licensing Manager
Mr. D. C. Shutt, Licensing Engineer

Westinghouse Electric Company, LLC

Mr. S. D. Rupprecht, Vice President of Regulatory Affairs & Strategy (w/o enclosure)
Mr. N. C. Boyter, Consortium Project Director Vogtle Units 3 & 4 (w/o enclosure)
Mr. S. A. Bradley, Vogtle Project Licensing Manager
Mr. M. A. Melton, Manager, Regulatory Interfaces
Mr. R. B. Sisk, Manager, AP1000 Licensing and Customer Interface
Mr. D. A. Lindgren, Principal Engineer, AP1000 Licensing and Customer Interface

NuStart Energy

Mr. R. J. Grumbir
Mr. E. R. Grant
Mr. P. S. Hastings
Mr. B. Hirmanpour
Mr. N. Haggerty
Ms. K. N. Slays

Other NuStart Energy Associates

Ms. M. C. Kray, NuStart
Mr. S. P. Frantz, Morgan Lewis
Mr. J. A. Bailey, TVA
Ms. A. L. Sterdis, TVA
Mr. J. P. Berger, EDF
Mr. W. Maher, FP&L
Mr. P. Hinnenkamp, Entergy
Mr. G. D. Miller, PG&N
Mr. N. T. Simms, Duke Energy
Mr. G. A. Zinke, NuStart & Entergy
Mr. R. H. Kitchen, PGN
Ms. A. M. Monroe, SCE&G
Mr. T. Beville, DOE/PM

Southern Nuclear Operating Company

ND-10-1473

Enclosure

VEGP Units 3 and 4 COL Application –

Voluntary Revision to FSAR Chapter 6

NuStart Qb Tracking No. 4162

STD COL 06.04-01

Westinghouse recently responded to RAI-SRP2.2-RSAC-01 Revision 1 via letter DCP_NRC_002897, as submitted May 28, 2010. The response to the Design Control Document (DCD) RAI included a revision to DCD information related to the COL information item identified in DCD Subsection 6.4.7 on control room habitability. In particular:

The subject letter revised DCD Table 6.4-1 to identify the hydrogen gas location as "Yard at turbine building" which is slightly different than the location identified by the Standard portion of the COL application FSAR Table 6.4-201 as revised by the response to BLN-RAI-COL-169. The FSAR table will be appropriately updated to conform to the DCD information, i.e., the "Corner of Auxiliary and Turbine buildings" will be revised to read "Yard at turbine building" in the "Evaluated Location" column.

The subject letter identified that Westinghouse considered two different volumes of liquid hydrogen with 1500 gallons being the primary evaluation and 2000 gallons being presented as a basis of comparison only. Thus, the Standard portion of the COL application FSAR Table 6.4-201 (as revised by the response to BLN-RAI-COL-169) will be appropriately updated to conform to the DCD information, i.e., the 2000 gal value will be revised to 1500 gal in the "Evaluated Maximum Quantity" column.

Additionally, the Staff has requested that the following additional comments be addressed:

- a) Provide a basis for not evaluating until a peak concentration is identified.
- b) Provide a basis for not evaluating wind speeds less than 1 m/sec.
- c) Provide an indication of which evaluations address wake effects.

Information to address these items will be provided in response to VEGP RAI Letter 061.

The proposed changes discussed in the COL Application Revisions section below will be included in a future COL application revision.

This response is expected to be STANDARD for each S-COLA.

Associated VEGP COL Application Revisions:

1. COLA Part 2, FSAR Chapter 6, Section 6.4, standard portion of table of toxic chemical evaluations (VEGP Table 6.4-201) as modified by the response to BLN-RAI-LTR-169 will be further revised in the Standard Onsite Toxic Chemicals listing for the Hydrogen Gas from "Corner of the Auxiliary and Turbine buildings" to read "Yard at turbine building" in the "Evaluated Location" column.
2. COLA Part 2, FSAR Chapter 6, Section 6.4, standard portion of table of toxic chemical evaluations (VEGP Table 6.4-201) as modified by the response to BLN-RAI-LTR-169 will be further revised in the Standard Onsite Toxic Chemicals listing for the Hydrogen Liquid from "2000 gal" to read "1500 gal" in the "Evaluated Maximum Quantity" column.