



FirstEnergy Nuclear Operating Company

Perry Nuclear Power Station
10 Center Road
Perry, Ohio 44081

Mark B. Bezilla
Vice President

440-280-5382
Fax: 440-280-8029

July 13, 2010
L-10-204

Mr. Robert Shelby, Mentor Waste Facility
Lake County Department of Utilities
P.O. Box 490
Painesville, Ohio 44077-0490

Subject:
Perry Nuclear Power Plant Semi-Annual Sewage Isotopic Report

Enclosed are the results of the isotopic analysis performed for industrial wastewater from the Perry Nuclear Power Plant. No radioactive material attributable to the Perry Nuclear Power Plant was detected.

For questions or if additional information is required, please contact Mr. Randall Killing at (440) 280-7370.

Sincerely,

Mark B. Bezilla

Enclosure

cc: NRC Region III
NRC Resident Inspector Office
NRR Project Manager
NRC Document Control Desk

A001
NRR

L-10-204
ENCLOSURE

200 Randall R. King Lab Manager Validate Entry by Sample

Note: ☐ **Validate by Sample Screen**

System Name:	ENVIRONMEN	Desc:	Environmental Sample
MPL Number:	SEWAGE	Desc:	Sewage Lift Station
Reason/Freq:	SA	Desc:	Semi-Annual
Mode Number:	6	Desc:	At All Times
Sample ID :	705094	Date Collected:	15:25:00 6/29/10
Validation Status: <input checked="" type="checkbox"/> (V/I)			

Isotopic by Gamma Spectroscopy

Status: ☒ PV

Limit: 0.00 to 0.00

MCA: 1002

Second MCA (if appl.):

NOTE: For OFFGAS PRE samples, the result is the Undecayed Release Rate.
NOTE: A numeric result of zero indicates 'None Detected'.

0.00E+00 uCi/ml
uCi/cc for N/G samples
uCi/sec for O/G pre and post samples
uCi/gm for resin samples