

Facility: <u>Indian Point Unit 2</u>		Date of Examination: <u>July 12, 2010</u>
Examination Level: RO <input type="checkbox"/> SRO <input checked="" type="checkbox"/>		Operating Test Number: _____

Administrative Topic (see Note)	Type Code*	Describe activity to be performed
Conduct of Operations	N, R	<b>Review WCR-1</b> 2.1.25 Ability to interpret reference materials, such as graphs, curves, tables, etc.
Conduct of Operations	N, R	<b>Determine Location for Spent Fuel Assembly</b> 2.1.42 Knowledge of new and spent fuel movement procedures.
Equipment Control	N, R	<b>Initiate a Temporary Procedure Change</b> 2.2.6 Knowledge of the process for making changes to procedures.
Radiation Control	M, R, P	<b>Review/Approve a Liquid Radiation Release Permit</b> 2.3.11 Ability to control radiation releases.
Emergency Procedures/Plan	D	<b>Classify Security Event</b> 2.4.28 Knowledge of procedures relating to a security event (non-safeguards information).

NOTE: All items (5 total) are required for SROs. RO applicants require only 4 items unless they are retaking only the administrative topics, when all 5 are required.

\* Type Codes & Criteria:

(C)ontrol room, (S)imulator, or Class(R)oom  
(D)irect from bank ( $\leq 3$  for ROs;  $\leq 4$  for SROs & RO retakes)  
(N)ew or (M)odified from bank ( $\geq 1$ )  
(P)revious 2 exams ( $\leq 1$ ; randomly selected)

*SLD*  
**INDIAN POINT UNIT 2 NRC RO EXAMINATION**

**CONDUCT OF OPERATIONS: Review WCR-1** The candidate will be given a copy of WCR-1, Reactivity Summary Sheet prepared by an RO for review. The candidate will review the calculation and find an error. The candidate should NOT sign Reviewed By and return the form.

- This is a New JPM
- SRO Only

**CONDUCT OF OPERATIONS: Determine Location for Spent Fuel Assembly** This JPM gives the candidate a spent fuel assembly with initial enrichment and burnup. The spent fuel assembly must be moved in the pit. The candidate must determine the spent fuel pit location zone.

- This is a New JPM
- The SRO Only

**EQUIPMENT CONTROL: Initiate a Temporary Procedure Change.** This JPM will initiate a Temporary Procedure Change for 2-AOP-ROD-1. The procedure is missing a step to place the P-A converter in Manual before depressing the UP-Down buttons. (Note this step does exist in other locations in the procedure)

- This is a New JPM
- SRO Only.

**RADIATION CONTROL: Review a Liquid Radiation Release Permit.** This JPM has modified values from the existing bank version. The permit will have inaccurate information.

- This is a Modified Bank JPM
- SRO Only.

**EMERGENCY PROCEDURES/PLAN: Respond to a Security Event.** The candidate will be notified that a security event is in progress. The candidate must respond in accordance with 0-AOP-SEC-1 and classify the event. Once the event is classified, the candidate will have 15 minutes to complete the NY State Part 1 form.

- This is a Modified Bank JPM.
- SRO Only.

# Review 2-WCR-1 Reactivity Summary Calculation

Page 1 of 12

SRO  
ADMIN

## ENTERGY (IP2) JOB PERFORMANCE MEASURE

Operator Name: \_\_\_\_\_

Employee ID #: \_\_\_\_\_

Evaluator: \_\_\_\_\_

Date: \_\_\_\_\_ SAT UNSAT

This JPM was administered for qualification? YES NO

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

## **Review 2-WCR-1 Reactivity Summary Calculation**

Page 2 of 12

### **DIRECTIONS TO OPERATOR:**

When I tell you to begin, you are to Review a Manual Reactivity Summary Calculation.

Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

### **INITIATING CUES:**

An Instant SRO Candidate has prepared a Manual Reactivity Summary Calculation in accordance with 2-WCR-1 for training evaluation qualification.

You are directed to Review the Manual Reactivity Summary Calculation.

Current Plant Conditions:

- Reactor Power – 100%
- Control bank D rods are at 223
- Boron Concentration – 970
- EFPD – 327
- MTC (NuPOP) – 14.3 pcm/°F
- ITC – 16.5 pcm/°F
- Estimated Shift Reactivity due to core burnup – 71 gallons primary water

### **TASK STANDARD:**

Manual Reactivity Summary Calculation Reviewed.

## Review 2-WCR-1 Reactivity Summary Calculation

Page 3 of 12

● Denotes Critical Step

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation		
2.	Obtain current revision of 2-WCR-1	Obtains Current Copy of Procedure	
3.	Check Given Data on the form	Check Data on Form Entered correctly	
4.	Check Graph RCS-4 HSD Boron Conc.	Checks 1255 Entered Correctly	
5.	Check A. Power Coefficient Value	Value Correct at 16.09 pcm/%	
6.	Check B Boron Worth	Value Correct at 7.86 pcm/ppm	
7.	Check C. Boration	Value Correct at 3.19 gal/ppm	
8.	Check D. Dilution	Value Correct at 66.9 gal/ppm	
9.	Check E. Rod Worth	Value Correct at 2.7 pcm/step	
10.	Check G. MWD/MTU	Value Correct at 12000 MWD/MTU	
11.	Check Boron for 1°F change	Value correct at 6 gal	
12.	Check Dilution for 1°F change	Value correct at 122 gal	
13.	Check Rod Step for 1°F change	Value Correct at 5 steps	
14.	Check Megawatts for 1°F change	Value Correct at 10	
16.	Check Desired Rod Position 10%	Value Correct at 203 steps	
● 17.	Check Boron Addition to compensate for 10% Note candidate may stop at this point because calculation is Unsatisfactory	Determines Value Incorrect. Correct value should be 54	
18.	Check Desired Rod Position 30%	Value Correct at 182	
19.	Check Boron Addition to compensate for 30%	Value Correct at 89	

## Review 2-WCR-1 Reactivity Summary Calculation

Page 4 of 12

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
20.	Check Desired Rod Position 50%	Value Correct at 172	
21.	Check Boron Addition to compensate for 50%	Value Correct at 188	
22.	Inform Preparer that Calculation is incorrect and that he has failed the JPM		
	JPM Complete		

# Review 2-WCR-1 Reactivity Summary Calculation

Page 5 of 12

Key

DATE: TODAY  
(Page 1 of 3)

## Reactivity Summary

1. Reactor Operator performs calculations during midnight shift Saturday night for Sunday.
2. The STA (Preferred) or CRS will independently verify the calculations (or inputs if computer generated)
3. On-coming Reactor Operators will present items 5 – 12 during the formal crew turnover meetings.
4. Linear interpolation between burnup values is permitted on RV-11.
5. Reactor power 100 %
6. RCS Boron Concentration 970 PPM
7. HSD Boron Concentration (RCS-4) 1255 PPM
8. Boron for 1°F change (C \* H/B) 6 Gal
9. Dilution for 1°F change (D \* H/B) 122 Gal
10. Rod Steps for 1°F change (H/E) 5 Steps
11. Megawatts for 1°F change 10 \* I/A 10 MW
12. Estimated Shift Reactivity additions due to core burn up  
Compute average PPM change per shift using change over several days and convert to required PW/Boron or Total Dilutions/Borations in X shifts divided by X. 71 Gal  
PW/Boron

RAPID POWER REDUCTION (NO XENON change)	DESIRED ROD POSITION STEPS (RV-11)	BORON ADDITION TO COMPENSATE PWR Defect less Rods
10%	203	54
30%	182	89
50%	172	188

Performed by / Date

Reviewed by

Reactivity Values	
A. Power coefficient (RV-2) (10% Range from current power)	16.09 pcm/%
B. Boron worth (RV-3)	7.86 pcm/ppm
C. Boration (Dilution/Boration Tables)	5.19 gal/ppm
D. Dilution (Dilution/Boration Tables)	66.9 gal/ppm
E. Rod Worth (RV-1) (10 Step Range)	2.7 pcm/step
F. EFPDs (obtained from previous 2-WCR-1 OR Reactor Engineering)	327.15 EFPD
G. MWD/MTU ( F X 36.68)	12000 MWD/MTU
H. Moderator Temperature Coefficient (Online NuPOP)	14.3 pcm/°F
I. Isothermal Temperature Coefficient (Online NuPOP)	16.5 pcm/°F

2-WCR-1  
Rev 8

PAGE 9 Indian Point Unit 2 Boration - Dilution Tables


PPM BORON CONC.	REQD GAL OF		REQD GAL OF		REQD GAL OF		REQD GAL OF		REQD GAL OF		REQD GAL OF	
	ACID TO BORATE 1 PPM	WATER TO DILUTE 1 PPM	ACID TO BORATE 2 PPM	WATER TO DILUTE 2 PPM	ACID TO BORATE 5 PPM	WATER TO DILUTE 5 PPM	ACID TO BORATE 10 PPM	WATER TO DILUTE 10 PPM	ACID TO BORATE 20 PPM	WATER TO DILUTE 20 PPM	ACID TO BORATE 50 PPM	WATER TO DILUTE 50 PPM
810	3.17	80.10	6.33	160.20	15.83	401.30	31.66	805.20	63.33	1620.50	158.44	4129.90
820	3.17	79.10	6.33	158.30	15.83	396.40	31.67	795.30	63.36	1600.50	158.52	4077.90
830	3.17	78.10	6.34	156.40	15.84	391.60	31.69	785.70	63.39	1581.00	158.60	4027.20
840	3.17	77.20	6.34	154.50	15.85	387.00	31.70	776.30	63.42	1561.90	158.68	3977.70
850	3.17	76.30	6.34	152.70	15.86	382.40	31.72	767.10	63.46	1543.30	158.76	3929.50
860	3.17	75.40	6.35	150.90	15.87	377.90	31.74	758.10	63.49	1525.20	158.84	3882.40
870	3.17	74.50	6.35	149.20	15.87	373.60	31.75	749.30	63.52	1507.40	158.92	3836.40
880	3.18	73.70	6.35	147.50	15.88	369.30	31.77	740.80	63.55	1490.10	159.00	3791.50
890	3.18	72.90	6.36	145.80	15.89	365.20	31.78	732.40	63.58	1473.20	159.08	3747.70
900	3.18	72.10	6.36	144.20	15.90	361.10	31.80	724.20	63.61	1456.60	159.15	3704.80
910	3.18	71.30	6.36	142.60	15.91	357.10	31.82	716.20	63.65	1440.40	159.23	3662.90
920	3.18	70.50	6.36	141.10	15.91	353.20	31.83	708.40	63.68	1424.60	159.31	3622.00
930	3.18	69.70	6.37	139.50	15.92	349.40	31.85	700.70	63.71	1409.10	159.39	3582.00
940	3.19	69.00	6.37	138.10	15.93	345.70	31.86	693.20	63.74	1394.00	159.47	3542.80
950	3.19	68.30	6.37	136.60	15.94	342.00	31.88	685.90	63.77	1379.10	159.55	3504.50
960	3.19	67.60	6.38	135.20	15.95	338.50	31.89	678.70	63.80	1364.60	159.63	3467.00
970	3.19	66.90	6.38	133.80	15.95	335.00	31.91	671.70	63.84	1350.40	159.71	3430.30
980	3.19	66.20	6.38	132.40	15.96	331.50	31.93	664.80	63.87	1336.50	159.79	3394.30
990	3.19	65.50	6.39	131.10	15.97	328.20	31.94	658.00	63.90	1322.80	159.87	3359.10
1000	3.20	64.80	6.39	129.80	15.98	324.90	31.96	651.40	63.93	1309.50	159.95	3324.70
1020	3.20	63.60	6.40	127.20	15.99	318.50	31.99	638.60	64.00	1283.50	160.11	3257.80
1040	3.20	62.40	6.40	124.80	16.01	312.40	32.02	626.30	64.06	1258.60	160.27	3193.60
1060	3.20	61.20	6.41	122.40	16.03	306.50	32.05	614.40	64.13	1234.60	160.43	3131.90
1080	3.21	60.00	6.42	120.10	16.04	300.80	32.09	603.00	64.19	1211.60	160.59	3072.50
1100	3.21	59.00	6.42	118.00	16.06	295.30	32.12	591.90	64.25	1189.30	160.76	3015.30
1120	3.21	57.90	6.43	115.80	16.07	290.00	32.15	581.30	64.32	1167.90	160.92	2960.20
1140	3.22	56.90	6.44	113.80	16.09	284.90	32.18	571.10	64.38	1147.20	161.08	2907.10
1160	3.22	55.90	6.44	111.80	16.11	280.00	32.22	561.20	64.45	1127.30	161.24	2855.80
1180	3.22	55.00	6.45	110.00	16.12	275.20	32.25	551.60	64.51	1108.00	161.41	2806.40
1200	3.23	54.00	6.45	108.10	16.14	270.60	32.28	542.40	64.58	1089.40	161.57	2758.60

SYSTEM TEMPERATURE = 547 DEGF

KEY

INDIAN POINT STATION UNIT NO.2 CYCLE 19  
MINIMUM SHUTDOWN BORON CONCENTRATION

**CONTROLLED**



Ref Cycle 19 NUPOP (WCAP-15915-P Rev 0)

O:\SITE\RXE\Cy 19 Graphs\U2\BOL\graphRCS\_4cy19.xls

2-GRAPH RCS 4 Rev 68  
Page 2 of 2

- GRAPH BASED ON THE FOLLOWING:**
- OF STUDY WITH 12 RODS INSERTED
  - NO CREDIT TAKEN FOR XENON
  - CREDIT TAKEN FOR 80% OF THE FULL POWER EQUILIBRIUM SODIUM WORTH AS A FUNCTION OF BURNUP
  - A 100 PPM SAFETY FACTOR IS USED
  - MINIMUM BORON VALUES FOR 300 PPM'S (1" AND BELOW) INCLUDE ADDITIONAL BORON TO ACCOUNT FOR AN UNOVERTAKEN RCS BORON DILUTION WHILE UNDER SYSTEM
  - INCLUDES EFFECT OF MAX THEORETICAL ROD DEPLETION AS A FUNCTION OF BURNUP
  - GRAPH INCLUDES SHUTDOWN MARGIN REQUIRED BY CERTAIN RNC'S
  - REQUIRED BORON CONCENTRATION IS ON OR ABOVE THE CURVE FOR THE EXISTING BURNUP AND TEMP RANGE
  - GRAPH IS VALID FOR AN BOL CURVE BURNUP OF 691 EFPD AND BELOW

- KEY**
- 1 80% - 200 PPM
  - 2 300P - 200P (IN SERVICE)
  - 3 300P - 200P (IN SERVICE)
  - 4 200P - 100P (IN SERVICE)
  - 5 100P - 50P
  - 6 50P - 25P
  - 7 25P - 10P
  - 8 10P - 5P
  - 9 5P - 1P

HE APPROVED: *[Signature]*  
EFFECTIVE DATE: 4/14/03

KEY

Time: 15 minutes  
Administrative

2-WCR-1

Indian Point Unit 2 Cycle 19  
TOTAL POWER DEFECT (pcm) AS A FUNCTION OF POWER AND BORON CONCENTRATION AT MOL/EOL (20000 MWD/MTU)

Boron Conc. (ppm)	POWER LEVEL (%)																				
	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100
0	0.0	153.5	297.6	433.4	562.3	685.2	803.3	917.4	1028.5	1137.1	1244.1	1349.9	1455.0	1559.8	1664.5	1769.4	1874.5	1979.8	2085.2	2190.6	2295.6
50	0.0	152.3	295.1	429.9	557.7	679.7	796.9	910.0	1020.1	1127.8	1233.6	1338.3	1442.2	1545.8	1649.2	1752.7	1856.3	1960.2	2064.1	2168.0	2271.5
100	0.0	151.0	292.7	426.5	553.3	674.4	790.6	902.8	1011.9	1118.6	1223.4	1327.0	1429.7	1532.0	1634.1	1736.3	1838.6	1941.0	2043.5	2145.9	2248.0
150	0.0	149.8	290.4	423.1	549.0	669.2	784.5	895.8	1003.9	1109.6	1213.4	1315.9	1417.5	1518.6	1619.5	1720.3	1821.2	1922.2	2023.3	2124.3	2224.9
200	0.0	148.6	288.2	419.9	544.9	664.1	778.5	888.9	996.1	1100.9	1203.7	1305.1	1405.6	1505.5	1605.1	1704.6	1804.2	1903.9	2003.5	2103.1	2202.4
250	0.0	147.4	286.0	416.7	540.8	659.1	772.6	882.2	988.5	1092.3	1194.1	1294.5	1393.9	1492.7	1591.1	1689.4	1787.6	1885.9	1984.2	2082.4	2180.3
300	0.0	146.3	283.8	413.6	536.8	654.3	766.9	875.6	981.0	1083.9	1184.8	1284.1	1382.5	1480.1	1577.4	1674.4	1771.4	1868.4	1965.3	2062.1	2158.7
350	0.0	145.2	281.7	410.6	532.9	649.5	761.3	869.2	973.8	1075.7	1175.6	1274.0	1371.3	1467.9	1564.0	1659.8	1755.5	1851.2	1946.8	2042.3	2137.5
400	0.0	144.2	279.7	407.7	529.1	644.9	755.9	862.9	966.6	1067.7	1166.7	1264.1	1360.4	1455.9	1550.8	1645.5	1740.0	1834.4	1928.8	2022.9	2116.8
450	0.0	143.1	277.7	404.8	525.4	640.4	750.6	856.8	959.7	1059.9	1158.0	1254.4	1349.7	1444.1	1538.0	1631.5	1724.8	1818.0	1911.1	2003.9	2096.5
500	0.0	142.1	275.8	402.0	521.8	636.0	745.4	850.8	952.8	1052.2	1149.4	1245.0	1339.3	1432.7	1525.4	1617.8	1710.0	1801.9	1893.7	1985.4	2076.6
550	0.0	141.2	273.9	399.3	518.3	631.7	740.3	844.9	946.2	1044.7	1141.0	1235.7	1329.0	1421.4	1513.2	1604.4	1695.4	1786.2	1876.8	1967.1	2057.2
600	0.0	140.2	272.1	396.7	514.8	627.5	735.3	839.2	939.6	1037.4	1132.9	1226.6	1319.0	1410.4	1501.1	1591.3	1681.2	1770.8	1860.2	1949.3	2038.1
650	0.0	139.3	270.3	394.1	511.5	623.3	730.5	833.5	933.3	1030.2	1124.9	1217.7	1309.2	1399.7	1489.3	1578.5	1667.2	1755.7	1843.9	1931.8	2019.4
700	0.0	138.4	268.5	391.5	508.2	619.3	725.7	828.1	927.0	1023.2	1117.0	1209.0	1299.6	1389.1	1477.8	1565.9	1653.6	1740.9	1828.0	1914.7	2001.0
750	0.0	137.5	266.8	389.0	504.9	615.4	721.0	822.7	920.9	1016.3	1109.3	1200.5	1290.2	1378.8	1466.5	1553.6	1640.2	1726.4	1812.3	1897.9	1983.0
800	0.0	136.6	265.2	386.6	501.8	611.5	716.5	817.4	914.9	1009.5	1101.8	1192.2	1281.0	1368.7	1455.4	1541.5	1627.1	1712.2	1797.0	1881.4	1965.4
850	0.0	135.7	263.5	384.2	498.7	607.7	712.0	812.3	909.0	1002.9	1094.4	1184.0	1272.0	1358.7	1444.6	1529.6	1614.2	1698.3	1782.0	1865.2	1948.1
900	0.0	134.9	261.9	381.9	495.7	604.0	707.6	807.2	903.3	996.5	1087.2	1176.0	1263.1	1349.0	1433.9	1518.0	1601.5	1684.6	1767.2	1849.4	1931.1
950	0.0	134.1	260.3	379.6	492.7	600.4	703.4	802.2	897.6	990.1	1080.1	1168.1	1254.4	1339.5	1423.4	1506.6	1589.1	1671.1	1752.7	1833.8	1914.4
1000	0.0	133.3	258.8	377.3	489.8	596.8	699.1	797.4	892.1	983.9	1073.2	1160.4	1245.9	1330.1	1413.2	1495.4	1577.0	1657.9	1738.4	1818.5	1898.0
970											1077.3				1419.3				1746.9		1907.9

*W. C. G. Jr.*  
RE - Approved  
10-27-09  
Effective Date

# Review 2-WCR-1 Reactivity Summary Calculation

Page 9 of 12

## INDIAN POINT ENERGY CENTER UNIT NO. 2 - CYCLE 19

KEY

Bank Overlap Remaining Rod Worth

D - Bank Steps	Worth PCM
223	0.0
213	27.4
203	89.4
193	180.8
183	271.1
173	365.9
163	459.4
153	532.9
143	596.8
133	652.1
123	699.6
113	739.9
100	784.3
93	810.9
83	870.0
73	952.2
63	1044.1
53	1136.1
43	1225.0
33	1309.1
23	1386.0
13	1452.4
3	1505.9
0	1519.6
C - Bank Steps	
113	1554.7
100	1592.4

$$\frac{27.4}{10} = 2.7$$

*W. J. Smith*  
RE APPROVED  
10-27-09  
EFFECTIVE DATE

KEY

Ref. Cycle 19 NuPOP HZP (MOL/EOL - 20000 MWD/MTU)  
Rev. 57

2 - Graph - RV-1

## Review 2-WCR-1 Reactivity Summary Calculation

Page 10 of 12

Any area of weakness observed?

YES

☐

NO

☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

\_\_\_\_\_  
Description of reviewed information:

**INITIATING CUES:**

*AN RO*  
~~An Instant SRO Candidate~~ has prepared a Manual Reactivity Summary Calculation in accordance with 2-WCR-1 for training evaluation qualification.

You are directed to Review the Manual Reactivity Summary Calculation.

**Current Plant Conditions:**

- Reactor Power – 100%
- Boron Concentration – 970
- EFPD – 327
- MTC (NuPOP) – 14.3 pcm/°F
- ITC – 16.5 pcm/°F
- Estimated Shift Reactivity due to core burnup – 71 gallons primary water

**TASK STANDARD:**

Manual Reactivity Summary Calculation Reviewed.

*→ Instant Core i*

DATE: TODAY  
(Page 1 of 3)**Reactivity Summary**

1. Reactor Operator performs calculations during midnight shift Saturday night for Sunday.
2. The STA (Preferred) or CRS will independently verify the calculations (or inputs if computer generated)
3. On-coming Reactor Operators will present items 5 – 12 during the formal crew turnover meetings.
4. Linear interpolation between burnup values is permitted on RV-11.
5. Reactor power 100 %
6. RCS Boron Concentration 970 PPM
7. HSD Boron Concentration (RCS-4) 1255 PPM
8. Boron for 1°F change ( $C * H/B$ ) 6 Gal
9. Dilution for 1°F change ( $D * H/B$ ) 122 Gal
10. Rod Steps for 1°F change ( $H/E$ ) 5 Steps
11. Megawatts for 1°F change  $10 * I/A$  10 MW
12. Estimated Shift Reactivity additions due to core burn up  
Compute average PPM change per shift using change over several days and convert to required PW/Boron or Total Dilutions/Borations in X shifts divided by X. 70 Gal  
PW/Boron

RAPID POWER REDUCTION (NO XENON change)	DESIRED ROD POSITION STEPS (RV-11)	BORON ADDITION TO COMPENSATE PWR Defect less Rods
10%	203	29
30%	182	89
50%	172	188

RD TODAY

Performed by / Date

Reviewed by

Reactivity Values	
A. Power coefficient (RV-2) (10% Range from current power)	<u>16.09</u> pcm/%
B. Boron worth (RV-3)	<u>7.86</u> pcm/ppm
C. Boration (Dilution/Boration Tables)	<u>3.9</u> gal/ppm
D. Dilution (Dilution/Boration Tables)	<u>66.9</u> gal/ppm
E. Rod Worth (RV-1) (10 Step Range)	<u>2.7</u> pcm/step
F. EFPDs (obtained from previous 2-WCR-1 OR Reactor Engineering)	<u>327.15</u> EFPD
G. MWD/MTU ( F X 36.68)	<u>12000</u> MWD/MTU
H. Moderator Temperature Coefficient (Online NuPOP)	<u>14.3</u> pcm/°F
I. Isothermal Temperature Coefficient (Online NuPOP)	<u>16.5</u> pcm/°F

2-WCR-1  
Rev 8File:  
Task Number:

# Identify the Location for Spent Fuel Assemblies

Page 1 of 5

SAL  
ADMIN

## ENTERGY (IP2) JOB PERFORMANCE MEASURE

Operator Name: \_\_\_\_\_

Employee ID #: \_\_\_\_\_

Evaluator: \_\_\_\_\_

Date: \_\_\_\_\_ SAT UNSAT

This JPM was administered for qualification? YES NO


The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

# Identify the Location for Spent Fuel Assemblies

Page 2 of 5

## DIRECTIONS TO OPERATOR:

When I tell you to begin, you are to determine Spent Fuel Pit Region(s) each fuel assembly can be moved to.



Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

## INITIATING CUES:

Three fuel assemblies in the spent fuel pit need to be moved to facilitate an inspection of the spent fuel racks in those areas.

### Fuel Assembly Data

#### Fuel Assembly 1

Initial Enrichment 4.5 W/o  
Burnup 52,000 MWD/MTU  
In Spent Fuel Pit since April 2005  
Number of IFBA Rods 0

#### Fuel Assembly 2

Initial Enrichment 4.6 W/o  
Burnup 32000 MWD/MTU  
In Spent Fuel Pit since March 2010  
Number of IFBA Rods 0

#### Fuel Assembly 3

Initial Enrichment 4.95 W/o  
Burnup 0 MWD/MTU (New Fuel Assembly)  
Ins Spent Fuel Pit since January 2010  
Number of IFBA Rods 24

You are directed to determine the Spent Fuel Pit Region(s) each fuel assembly can be moved to.

## TASK STANDARD:

Acceptable Storage Regions identified for each fuel assembly.

## Identify the Location for Spent Fuel Assemblies

Page 3 of 5



**Denotes Critical Step**

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation		
2.	Obtain Tech Spec Section 3.7.13 and Basis	Obtains TS	
● 3.	Candidate evaluates Fuel Assembly 1	Determines 1-1, 1-2, 2-1, 2-2	
● 4.	Candidate evaluates Fuel Assembly 2	Determines 1-2, 2-2 Peripheral Cells	
● 5.	Candidate evaluates Fuel Assembly 3	Determines 1-1 Checkerboard, 1-2 and 2-2 Peripheral Cells	
	JPM Complete		

### ANSWER KEY

	Region 1-1	Region 1-2	Region 2-1	Region 2-2
Assembly 1	YES	YES	YES	YES
Assembly 2	YES	YES	NO	PERIPHERAL
Assembly 3	CHECKERBOARD	YES	NO	PERIPHERAL

## Identify the Location for Spent Fuel Assemblies

Page 4 of 5

Any area of weakness observed?

YES

☐

NO

☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

\_\_\_\_\_  
Description of reviewed information:



**INITIATING CUES:**

Three fuel assemblies in the spent fuel pit need to be moved to facilitate an inspection of the spent fuel rack in that area.

**Fuel Assembly Data**

**Fuel Assembly 1**

Initial Enrichment 4.5 W/o  
Burnup 52,000 MWD/MTU  
In Spent Fuel Pit since April 2005  
Number of IFBA Rods 0

**Fuel Assembly 2**

Initial Enrichment 4.6 W/o  
Burnup 32000 MWD/MTU  
In Spent Fuel Pit since March 2010  
Number of IFBA Rods 0

**Fuel Assembly 3**

Initial Enrichment 4.95 W/o  
Burnup 0 MWD/MTU (New Fuel Assembly)  
In Spent Fuel Pit since January 2010  
Number of IFBA Rods 24

**TASK STANDARD:**

Acceptable Storage Regions identified for each fuel assembly.

**Prepare a TPC for 2-AOP-ROD-1 Rod Control and Indications  
Malfunctions**

Page 1 of 8

SRO.  
Admin

**ENTERGY (IP2)  
JOB PERFORMANCE MEASURE**

**Operator Name:** \_\_\_\_\_

**Employee ID #:** \_\_\_\_\_

**Evaluator:** \_\_\_\_\_

**Date:** \_\_\_\_\_ **SAT** **UNSAT**

This JPM was administered for qualification? **YES** **NO**

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

# **Prepare a TPC for 2-AOP-ROD-1 Rod Control and Indications Malfunctions**

Page 2 of 8

## **DIRECTIONS TO OPERATOR:**

When I tell you to begin, you are to write a TPC for 2-AOP-ROD-1.

Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

## **INITIATING CUES:**

During Simulator Training the crew observed that a step to place the P/A converter switch to manual before depressing the UP-DOWN pushbuttons was not included in the section for realigning a misaligned rod.

You are directed to prepare a TPC per IP-SMM-AD-102 step 6.5 for 2-AOP-ROD-1 to add a step for placing the P/A converter to Manual.

MERLIN is out of service for maintenance

## **TASK STANDARD:**

TPC is completed for 2-AOP-ROD-1.

# **Prepare a TPC for 2-AOP-ROD-1 Rod Control and Indications Malfunctions**

Page 3 of 8

✱ Denotes Critical Step

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation		
2.	Obtain Correct procedures	Obtains IP-SMM-AD-102 and 2-AOP-ROD-1	
3.	Observe NOTE before step 6.5.1	Observes Note	
✱4.	Determine change is NOT change of Intent	Review Definition 4.4	
✱5.	Determine the change is an Editorial TPC per step 4.23.3	Review step 4.23.3	
6.	Obtain DRN from MERLIN <b>CUE: Merlin is out of service</b>	Enter DRN number using 24 hour clock format "MMDDYYHHMM"	
7.	Review MERLIN to ensure new DRN will NOT conflict with existing DRNs/TPC against the procedure <b>CUE: MERLIN is out of service; no DRN/TPC exist for 2-AOP-ROD-1</b>	No action required	
✱8.	Enter new text as close as possible to the affected text.	Enter "Place and hold P/A converter toggle switch in MANUAL" after step 4.133	
✱9.	Place Revision Bars adjacent to change text	Manually enter Revision Bar	
✱10.	Place DRN number on Rev Bar	Enter DRN on Rev Bar	

# **Prepare a TPC for 2-AOP-ROD-1 Rod Control and Indications Malfunctions**

Page 4 of 8

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
●11.	<p>Enter the following information on Attachment 10.2:</p> <ul style="list-style-type: none"> <li>• Procedure Title</li> <li>• Procedure Number</li> <li>• Existing Revision Number</li> <li>• Procedure Activity</li> <li>• Revision Summary</li> <li>• RPO Department</li> <li>• Writer</li> </ul>	See Attached Key	
●12.	If issuing an Editorial TPC enter corresponding reason for Editorial Change in Revision Summary	<p>Enter "Step 4.6.11" in Revision Summary</p> <p>See Attached Key</p>	
●13.	<p>Mark all boxes NO in Implementation Requirements:</p> <ul style="list-style-type: none"> <li>• Implementation Plan</li> <li>• Formal Training</li> <li>• Special Handling Required</li> </ul>	<p>All NO boxes checked</p> <p>See Attached Key</p>	
●14.	<p>From Attachment 1 determine required reviews:</p> <ul style="list-style-type: none"> <li>• Technical Review <b>NO</b></li> <li>• Cross Disciplinary Review <b>NO</b></li> <li>• PAD <b>NO</b></li> <li>• CRS/SM <b>YES</b></li> <li>• User Validation <b>NO</b></li> <li>• RPO <b>YES</b></li> </ul>	<p>Correct boxes checked</p> <p>See Attached Key</p>	
●15.	Sign Writer Line of Attachment 10.2	Signs Writer Line	
	JPM Complete		

**Prepare a TPC for 2-AOP-ROD-1 Rod Control and Indications  
Malfunctions**

Page 5 of 8

Any area of weakness observed?      YES ☐ NO ☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

\_\_\_\_\_  
Description of reviewed information:

# Prepare a TPC for 2-AOP-ROD-1 Rod Control and Indications Malfunctions

Page 6 of 8

<b>IPEC IMPLEMENTING PROCEDURE PREPARATION, REVIEW, AND APPROVAL</b>	IP-SMM-AD-102    Rev: 6
Page 34 of 40	

## ATTACHMENT 10.2                      IPEC PROCEDURE REVIEW AND APPROVAL

(Page 1 of 1)

Procedure Title: Rod Control and Indication Malfunction

Procedure No: 2-AOP-ROD-1 Existing Rev: 6 New Rev: NA DRN No: MMDDYYHHMM

Procedure Activity (MARK Applicable)	Converted To IPEC, Replaces:	Temporary Procedure Change (MARK Applicable)
<input type="checkbox"/> NEW PROCEDURE	Unit 1 Procedure No: _____	<input checked="" type="checkbox"/> EDITORIAL Temporary Procedure Change (Enter Step Number in Revision Summary)
<input type="checkbox"/> GENERAL REVISION	Unit 2 Procedure No: _____	<input type="checkbox"/> ADVANCE Temporary Procedure Change
<input type="checkbox"/> PARTIAL REVISION	Unit 3 Procedure No: _____	<input type="checkbox"/> CONDITIONAL Temporary Procedure Change
<input checked="" type="checkbox"/> EDITORIAL REVISION		Terminating Condition: _____
<input type="checkbox"/> VOID PROCEDURE		
<input type="checkbox"/> SUPERSEDED		
<input type="checkbox"/> RAPID REVISION	Document in Microsoft Word: <input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> VOID DRN/TPC No(s): _____

**Revision Summary**    ☐ N/A - See Revision Summary page. \_\_\_\_\_

Add step to place PIA converter switch to Manual to allow operation of PIA converter for misaligned rod recovery per IP-SMM-AD-102 step 4.2.11

### Implementation Requirements

Implementation Plan? ☐ Yes ☒ No Formal Training? ☐ Yes ☒ No Special Handling? ☐ Yes ☒ No

RPO Dept: Operations Writer (Print Name/ Ext/ Sign): Name / Extension / Signature

### Review and Approval (Per Attachment 10.1, IPEC Review And Approval Requirements)

1. ☐ Technical Reviewer: \_\_\_\_\_ (Print Name/ Signature/ Date)

2. ☐ Cross-Disciplinary Reviewers:  
 Dept: \_\_\_\_\_ Reviewer: \_\_\_\_\_ (Print Name/ Signature/ Date)  
 Dept: \_\_\_\_\_ Reviewer: \_\_\_\_\_ (Print Name/ Signature/ Date)

3. RPO Responsibilities: \_\_\_\_\_ (Print Name/ Signature/ Date)

- ☐ PAD required and is complete (PAD Approver and Reviewer qualifications have been verified)
- ☐ Previous exclusion from further LI-100 Review is still valid
- ☒ PAD not required due to type of change

4. ☐ Non-Intent Determination Complete: \_\_\_\_\_ (Print Name/ Signature/ Date)

NO change of purpose or scope  
 NO reduction in the level of nuclear safety  
 NO voiding or canceling of a procedure, unless requirements are incorporated into another procedure or the need for the procedure was eliminated via an alternate process

NO change to less restrictive acceptance criteria  
 NO change to steps previously identified as commitment steps  
 NO deviation from the Quality Assurance Program Manual  
 NO change that may result in deviations from Technical Specifications, FSAR, plant design requirements, or previously made commitments

5. ☒ On-Shift Shift Manager/CRS: \_\_\_\_\_ (Print Name/ Signature/ Date)

6. ☐ User Validation: User: \_\_\_\_\_ Validator: \_\_\_\_\_

7. ☐ Special Handling Requirements Understood: \_\_\_\_\_ (Print Name/ Signature/ Date)

KEY

# Prepare a TPC for 2-AOP-ROD-1 Rod Control and Indications Malfunctions

Page 7 of 8

Rod Control and Indication Systems 2-AOP-ROD-1 Rev. 6  
Malfunctions

Page 51 of 71

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
--------------------------	-----------------------

## NOTE

- An urgent failure alarm will occur if the affected rod is in any bank except Shutdown Bank C or D when the rod is moved due to all lift coil disconnect switches being open in the unaffected group.
- If the rod fails to move, continuation through the procedure will reset the master cyclor and all appropriate switches.

4.126 \_\_ Insert affected rod while maintaining TAVE on program (as applicable) until group step counter matches that recorded in Step 4.111.

4.127 \_\_ Is affected rod in Shutdown Bank C or Shutdown Bank D?

\_\_ GO TO Step 4.129.

4.128 \_\_ GO TO Step 4.137.

4.129 \_\_ Is affected rod a group 2 rod?

1. \_\_ IF group 2 step counter reading is lower than group 1 step counter reading in affected bank, THEN GO TO Step 4.131.

2. \_\_ GO TO Step 4.133.

4.130 \_\_ Is group 2 step counter reading equal to group 1 step counter reading in affected bank?

4.131 \_\_ Insert affected rod one step.

## NOTE

If the master cyclor pulses past the group of concern, step sequencing will **NOT** be maintained. To prevent this, small "bumps" of the in-hold-out switch are necessary to only "pulse" the intended group.

4.132 \_\_ Withdraw affected rod one step.

4.133 \_\_ Is affected rod in a control bank?

\_\_ GO TO Step 4.137.

4.133.1  
P/A and  
hold P/A  
converter switch  
in MANUAL

4.134 \_\_ DEPRESS Up-Down pushbuttons to obtain bank position recorded in step 4.111.

4.135 \_\_ RELEASE P/A converter toggle switch.

DEJ  
MADYYH  
MM

KEY

**IPEC IMPLEMENTING PROCEDURE  
PREPARATION, REVIEW, AND APPROVAL**

IP-SMM-AD-102 Rev: 6

Page 34 of 40

**ATTACHMENT 10.2**

**IPEC PROCEDURE REVIEW AND APPROVAL**

(Page 1 of 1)

Procedure Title: \_\_\_\_\_

Procedure No: \_\_\_\_\_ Existing Rev: \_\_\_\_\_ New Rev: \_\_\_\_\_ DRN No: \_\_\_\_\_

<b>Procedure Activity</b> (MARK Applicable)	<input type="checkbox"/> Converted To IPEC, Replaces:	<b>Temporary Procedure Change</b> (MARK Applicable)
<input type="checkbox"/> NEW PROCEDURE	Unit 1 Procedure No: _____	<input type="checkbox"/> EDITORIAL Temporary Procedure Change (Enter Step Number in Revision Summary)
<input type="checkbox"/> GENERAL REVISION	Unit 2 Procedure No: _____	<input type="checkbox"/> ADVANCE Temporary Procedure Change
<input type="checkbox"/> PARTIAL REVISION	Unit 3 Procedure No: _____	<input type="checkbox"/> CONDITIONAL Temporary Procedure Change Terminating Condition: _____
<input type="checkbox"/> EDITORIAL REVISION		
<input type="checkbox"/> VOID PROCEDURE		
<input type="checkbox"/> SUPERSEDED		
<input type="checkbox"/> RAPID REVISION	Document in Microsoft Word: <input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> VOID DRN/TPC No(s): _____

**Revision Summary** ☐ N/A - See Revision Summary page. \_\_\_\_\_

**Implementation Requirements**

Implementation Plan? ☐ Yes ☐ No Formal Training? ☐ Yes ☐ No Special Handling? ☐ Yes ☐ No

RPO Dept: \_\_\_\_\_ Writer (Print Name/ Ext/ Sign): \_\_\_\_\_

**Review and Approval** (Per Attachment 10.1, IPEC Review And Approval Requirements)

1. ☐ Technical Reviewer: \_\_\_\_\_  
(Print Name/ Signature/ Date)

2. ☐ Cross-Disciplinary Reviewers:  
Dept: \_\_\_\_\_ Reviewer: \_\_\_\_\_  
(Print Name/ Signature/ Date)  
Dept: \_\_\_\_\_ Reviewer: \_\_\_\_\_  
(Print Name/ Signature/ Date)

3. RPO Responsibilities: \_\_\_\_\_  
(Print Name/ Signature/ Date)

- ☐ PAD required and is complete (PAD Approver and Reviewer qualifications have been verified)  
☐ Previous exclusion from further LI-100 Review is still valid  
☐ PAD not required due to type of change

4. ☐ Non-Intent Determination Complete: \_\_\_\_\_  
(Print Name/ Signature/ Date)

**NO** change of purpose or scope  
**NO** reduction in the level of nuclear safety  
**NO** voiding or canceling of a procedure, unless requirements  
are incorporated into another procedure or the need for the  
procedure was eliminated via an alternate process

**NO** change to less restrictive acceptance criteria  
**NO** change to steps previously identified as commitment steps  
**NO** deviation from the Quality Assurance Program Manual  
**NO** change that may result in deviations from Technical Specifications,  
FSAR, plant design requirements, or previously made commitments

5. ☐ On-Shift Shift Manager/CRS: \_\_\_\_\_  
(Print Name/ Signature/ Date)

6. ☐ User Validation: User: \_\_\_\_\_ Validator: \_\_\_\_\_

7. ☐ Special Handling Requirements Understood: \_\_\_\_\_  
(Print Name/ Signature/ Date)

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
--------------------------	-----------------------

**NOTE**

- An urgent failure alarm will occur if the affected rod is in any bank except Shutdown Bank C or D when the rod is moved due to all lift coil disconnect switches being open in the unaffected group.
- If the rod fails to move, continuation through the procedure will reset the master cyclor and all appropriate switches.

4.126__ Insert affected rod while maintaining TAVE on program (as applicable) until group step counter matches that recorded in Step 4.111.	
4.127__ Is affected rod in Shutdown Bank C or Shutdown Bank D?	__ GO TO Step 4.129.
4.128__ GO TO Step 4.137.	
4.129__ Is affected rod a group 2 rod?	1.__ IF group 2 step counter reading is lower than group 1 step counter reading in affected bank, THEN GO TO Step 4.131. 2.__ GO TO Step 4.133.
4.130__ Is group 2 step counter reading equal to group 1 step counter reading in affected bank?	
4.131__ Insert affected rod one step.	

**NOTE**

If the master cyclor pulses past the group of concern, step sequencing will **NOT** be maintained. To prevent this, small "bumps" of the in-hold-out switch are necessary to only "pulse" the intended group.

4.132__ Withdraw affected rod one step.	
4.133__ Is affected rod in a control bank?	__ GO TO Step 4.137.
4.134__ DEPRESS Up-Down pushbuttons to obtain bank position recorded in step 4.111.	
4.135__ RELEASE P/A converter toggle switch.	

**Review a Liquid Radioactive Release Permit for #14 Liquid  
Waste Distillate Storage Tank**

Page 1 of 10

*Silo  
Admin*

**ENTERGY (IP2)  
JOB PERFORMANCE MEASURE**

**Operator Name:** \_\_\_\_\_

**Employee ID #:** \_\_\_\_\_

**Evaluator:** \_\_\_\_\_

**Date:** \_\_\_\_\_ **SAT** **UNSAT**

This JPM was administered for qualification? **YES** **NO**

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

# Review a Liquid Radioactive Release Permit for #14 Liquid Waste Distillate Storage Tank

Page 2 of 10

## DIRECTIONS TO OPERATOR:

When I tell you to begin, you are to review a radioactive liquid release in accordance with SOP-5.1.5

Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

## INITIATING CUES:

1. The Unit is operating at 100% power.
2. All radiation monitors are operable.
3. Waste Distillate Storage Tank #14 is to be discharged, tank level, as reported by the NPO, is 71 inches.
4. WDST has been isolated and on recirc for the past 5 hours.
5. R-54 is aligned to #14 WDST.
6. A Manual Radioactive Liquid Release Permit was prepared by the FSS.
7. You are directed to review and approve the Liquid Release Permit in accordance with 2-SOP-5.1.5

### 8. Additional Data:

Permit Number	100300
Tank ID	14 WDST
Initial Tank Level	71
Pre-release volume	16,351
Recirculation Rate	150 gpm
Recirc Start-	Today 5 hours ago
Recirc Stop	Today Now
Chem Sample Number	3906
Sample Date/Time	Today 15 minutes ago
Total Gamma Activity	4.0E-5 → units?
ADC	5.31E-7
ppm Boron in tank	632
Pump Configuration	6 CWP's in Fast, 3 SWP's, 0 RWP's

File: 2000241602-3.doc  
Parent Task # 200\*024\*01\*02

Difficulty: 4  
2-SOP-5.1.5

Time: 25 minutes  
Admin


Task: You are to review the permit

## **Review a Liquid Radioactive Release Permit for #14 Liquid Waste Distillate Storage Tank**

Page 3 of 10

### **TASK STANDARD:**

Radioactive liquid waste release calculation reviewed and release permit  
(Attachment 1 to SOP-5.1.5) approved.




## Review a Liquid Radioactive Release Permit for #14 Liquid Waste Distillate Storage Tank

Page 4 of 10



**Denotes Critical Step**

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation <b>Time Commenced:</b> _____		
2.	Review Precautions and Limitations  CUE: When requested, inform operator all P&Ls are satisfied	Precautions and Limitations Reviewed	
3.	Determine required recirculation time for the tank to be released	Determine minimum recirculation time to be 218 minutes from Table 1	
 4.	Determine Total Dilution Flow CUE: 6 CWP Fast Speed 3 SWP 0 RWP	Sum flowrate based on current pump combinations. Calculate 855,000 gpm <b>Determines data correct on permit</b>	
5.	Assign Permit Number <b>CUE:</b> Permit Number 100300	Initial Conditions	

## Review a Liquid Radioactive Release Permit for #14 Liquid Waste Distillate Storage Tank

Page 5 of 10

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
6.	<p>Review data on Attachment 1</p> <p>CUE:</p> <p>Permit Number 100300</p> <p>Tank ID 14 WDST</p> <p>Initial Tank Level 71</p> <p>Pre-release volume 16,351</p> <p>Recirculation Rate 150 gpm</p> <p>Recirc Start- Today 5 hours ago</p> <p>Recirc Stop Today Now</p> <p>Chem Sample Number 3906</p> <p>Sample Date/Time Today 15 minutes ago</p> <p>Total Gamma Activity 4.0E-5</p> <p>ADC 5.31E-7</p> <p>ppm Boron in tank 632</p>	<p>Supplied with Initial condition.</p> <p>Check data on form</p>	
7.	<p>Verify from Chemistry total gamma activity without noble gas is less than 5.0E-5 <math>\mu\text{Ci/ml}</math>.</p> <p>CUE: Chemist reports total gamma activity &lt; 5.0E-5 <math>\mu\text{Ci/ml}</math>. If requested, R54 activity is 2.4E-5 <math>\mu\text{Ci/cc}</math></p>	<p>Simulate Contact Chemist</p> <p><i>Provide as part of summary</i></p>	
8.	Record Available Dilution Flowrate	Previously calculated 855,000 gpm	
9.	Calculate pounds of Boron in Tank and Maximum Allowable Chemical Release Rate	<p>Performs calculation determines 86 (<math>\pm 1</math>) pounds of boron and Chem release rate 1352 (<math>\pm 2</math>)</p> <p><b>Determines data correct on permit</b></p>	
10.	Calculate the Permissible Radioactive Release Rate	<p>Performs calculation determines rad. Release rate 11350 (<math>\pm 5</math>)</p> <p><b>Determines data NOT correct on permit</b></p>	

## Review a Liquid Radioactive Release Permit for #14 Liquid Waste Distillate Storage Tank

Page 6 of 10

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Candidate may terminate JPM at this time due to identified error		
11.	Determine most restrictive release rate	Identifies Pump Capacity 250 most restrictive <b>Determines data correct on permit</b>	
12.	Determine effluent rad monitor in service and calculate maximum alarm	Calculates Max Alarm Setpoint 1.816E-3 <b>Determines data correct on permit</b>	
13.	Determine permit improperly completed and <b>does not</b> sign Release Authorized By block	<b>Does Not Sign</b> Release Authorized By block	

## Review a Liquid Radioactive Release Permit for #14 Liquid Waste Distillate Storage Tank

Page 7 of 10

Any area of weakness observed?      YES ☐ NO ☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

---

Description of reviewed information:

# CALCULATION AND RECORDING OR RADIOACTIVE LIQUID RELEASES

No: 2-SOP-5.1.5 Rev: 36

Page 16 of 23

## ANSWER KEY EXAMPLE RADIOACTIVE LIQUID RELEASE PERMIT (Page 1 of 1)

PERMIT # <u>10300</u> TANK ID <u>14 WDST</u>		INITIAL Tank Level: <u>71</u> (Inches) <u>16351</u> Volume (V), gal	
RECIRC RATE : <u>150</u> gpm		Recirc Start: <u>7/14/10</u> (Date) <u>00:00</u> (Time)	
		Recirc Stop: <u>7/14/10</u> (Date) <u>05:00</u> (Time)	
Chemistry Sample No. <u>3906</u>		Sample Collection : <u>7/14/10</u> (Date) <u>04:30</u> (Time)	
Gamma Activity without Gas and Tritium is less than the admin limit of SMM-CY-001: <u>Yes</u> / No			
Total Gamma Activity <u>4.0E-5</u> µCi/ml		Allowed Diluted Concentration (ADC) <u>5.31E-7</u> µCi/ml	
TOTAL DILUTION FLOW (T) <u>855,000</u> (GPM)		From: <u>6</u> Unit 2 Circulators <u>0</u> Unit 3 Circulators <u>3</u> Service Water Pumps	
BORON:		$\frac{632}{\text{ppm B}} \times \frac{16351}{\text{tank vol (V), gal}} \times 8.33\text{E-6} = \underline{86}$	
Maximum Chemical Release Rate (Rc) = (		$\frac{855,000}{\text{Avail Dil Flow (B), gpm}} \times 1 \text{ ppm} + \frac{632}{\text{ppm B}} = \underline{1352}$	
Radioactive Release Rate: (Rr) = (		$\frac{855,000}{\text{Avail Dil Flow (B), gpm}} \times \frac{5.31\text{E-7}}{\text{ADC, uCi/ml}} + \frac{4.0\text{E-5}}{\text{Gamma Act (C), uCi/ml}} = \underline{11350} \text{ gpm}$	
Most Restrictive Release Rate (R) = <u>250</u> gpm (pump capacity most limiting)			
Rad Monitor # <u>54</u> SOURCE CHECKED <u>X</u> OPERABLE <u>X</u> YES <u>NO</u> (IF NO, COMPLETE ATT 3)			
Maximum Alarm Setpoint = (		$\frac{855,000}{\text{Avail Dil Flow (B), gpm}} \times \frac{5.31\text{E-7}}{\text{ADC, uCi/ml}} + \frac{250}{\text{Most Restrictive Release Rate (R), gpm}} = \underline{1.816\text{E-3}} \text{ uCi/ml}$	
Actual Alarm Setpoint = <u>4.0E-4</u> uCi/ml		Warn Setpoint = <u>3.0E-4</u> uCi/ml	
DISCHARGE FLOW METER & RECORDER OPERABLE <u>X</u> YES <u>NO</u> (IF NO, COMPLETE ATTACHMENT 3)			
Release Authorized By: _____ (Date)			
RELEASE INITIATED: _____ (Date) _____ (Time)			
RELEASE TERMINATED: _____ (Date) _____ (Time)			
FINAL TK LEVEL: _____ (Inches)		TOTAL VOLUME RELEASED _____ gal	
Remarks:			

Value on  
candidate copy  
is incorrect.  
These are the  
correct values

# CALCULATION AND RECORDING OR RADIOACTIVE LIQUID RELEASES

No: 2-SOP-5.1.5

Rev: 36

Page 16 of 23

*Handout put after the*  
*few*  
*of*  
*the*

## ATTACHMENT 1 EXAMPLE RADIOACTIVE LIQUID RELEASE PERMIT (Page 1 of 1)

PERMIT # 10300 TANK ID 14 WDST INITIAL  
Tank Level: 71 (Inches) 16351 Volume (V), gal

RECIRC  
RATE : 150 gpm

Recirc Start: 7/14/10 (Date) 00:00 (Time)

Recirc Stop: 7/14/10 (Date) 05:00 (Time)

Chemistry

Sample No. 3906 Sample Collection : 7/14/10 (Date) 04:30 (Time)

Gamma Activity without Gas and Tritium is less than the admin limit of SMM-CY-001: Yes / No

Total Gamma Activity 4.0E-5  $\mu$ Ci/ml Allowed Diluted Concentration (ADC) 5.31E-7  $\mu$ Ci/ml

TOTAL DILUTION FLOW (T) 855,000 (GPM) From: 6 Unit 2 Circulators  
0 Unit 3 Circulators  
3 Service Water Pumps

BORON:  $\frac{632}{\text{ppm B}} \times \frac{16351}{\text{tank vol (V), gal}} \times 8.33\text{E-6} = \underline{86}$  pounds

Maximum Chemical Release Rate (Rc) =  $\left( \frac{855,000}{\text{Avail Dil Flow (B), gpm}} \times 1 \text{ ppm} \right) + \frac{632}{\text{ppm B}} = \underline{1352}$  gpm

Radioactive  
Release Rate: (Rr) =  $\left( \frac{855,000}{\text{Avail Dil Flow (B), gpm}} \times \frac{5.31\text{E-7}}{\text{ADC, uCi/ml}} \right) \div \frac{5.0\text{E-4}}{\text{Gamma Act (C), uCi/ml}} = \underline{908}$  gpm

Most Restrictive Release Rate (R) = 250 gpm (pump capacity most limiting)

Rad Monitor # 54 SOURCE CHECKED X OPERABLE X YES NO (IF NO, COMPLETE ATT 3)

Maximum Alarm Setpoint =  $\left( \frac{855,000}{\text{Avail Dil Flow (B), gpm}} \times \frac{5.31\text{E-7}}{\text{ADC, uCi/ml}} \right) + \frac{250}{\text{Most Restrictive Release Rate (R), gpm}} = \underline{1.816\text{E-3}}$  uCi/ml

Actual Alarm Setpoint = 4.0E-4 uCi/ml Warn Setpoint = 3.0E-4 uCi/ml

DISCHARGE FLOW METER & RECORDER OPERABLE X YES NO (IF NO, COMPLETE ATTACHMENT 3)

Release Authorized By: \_\_\_\_\_ (Date)

RELEASE INITIATED: \_\_\_\_\_ (Date) \_\_\_\_\_ (Time)

RELEASE TERMINATED: \_\_\_\_\_ (Date) \_\_\_\_\_ (Time)

FINAL TK LEVEL: \_\_\_\_\_ (Inches) \_\_\_\_\_ gal TOTAL VOLUME RELEASED \_\_\_\_\_ gal

Remarks:

**INITIATING CUES:**

1. The Unit is operating at 100% power.
2. All radiation monitors are operable.
3. Waste Distillate Storage Tank #14 is to be discharged, tank level, as reported by the NPO, is 71 inches.
4. WDST has been isolated and on recirc for the past 5 hours.
5. R-54 is aligned to #14 WDST.
6. A Manual Radioactive Liquid Release Permit was prepared by the FSS.
7. You are *assigned the USA SAM* directed to review and approve the Liquid Release Permit in accordance with 2-SOP-5.1.5.
8. Additional Data:

Permit Number	100300
Tank ID	14 WDST
Initial Tank Level	71
Pre-release volume	16,351
Recirculation Rate	150 gpm
Recirc Start-	Today 5 hours ago
Recirc Stop	Today Now
Chem Sample Number	3906
Sample Date/Time	Today 15 minutes ago
Total Gamma Activity	4.0E-5
ADC	5.31E-7
ppm Boron in tank	632
Pump Configuration	6 CWP's in Fast, 3 SWP's, 0 RWP's

**TASK STANDARD:**

Radioactive liquid waste release calculation reviewed and release permit (Attachment 1 to SOP-5.1.5) approved.

*don't approve  
identify bad data*

*Confman*

**JPM No. 030EP-12**  
**Classify Emergency Events requiring Emergency Plan**  
**Implementation (Time Critical)**

Page 1 of 6

*SRO*  
*ADM, w*

**ENTERGY (IP2)**  
**JOB PERFORMANCE MEASURE**

**Operator Name:** \_\_\_\_\_

**Employee ID #:** \_\_\_\_\_

**Evaluator:** \_\_\_\_\_

**Date:** \_\_\_\_\_ **SAT** **UNSAT**

This JPM was administered for qualification?    YES    NO

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

**JPM No. 030EP-12**  
**Classify Emergency Events requiring Emergency Plan**  
**Implementation (Time Critical)**

Page 2 of 6

**DIRECTIONS TO OPERATOR:**

This is a Time Critical task. You have 15 MINUTES from the time you are told to begin until you classify the event. You have 15 MINUTES from the time you classify the event until you complete the radiological emergency data form.

When I tell you to begin, you are to classify the event and complete the Radiological Emergency Data Form as required by the Emergency Plan Implantation Procedures.

Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

**INITIATING CUES:**

Both Units are operating at 100% power. The CCR is notified of a credible threat via the NRC ENS line. The CCR is responding per AOP-SEC-1. During their response, Security CAS notifies the CCR that

- The security fences north of the dry cask storage area have been breached.
- The Aux Boiler Feed Pump Building door has been found open

**METEOROLOGICAL CONDITIONS:**

Wind Speed: 1.7 meters/second  
Wind Direction: 097 degrees @ 10 meters  
Stability Class: C

**TASK STANDARD:**

As the Shift Manager, classify the event. Complete and return to me the required Radiological Emergency Data Form as required by the Emergency Plan.

**JPM No. 030EP-12**  
**Classify Emergency Events requiring Emergency Plan**  
**Implementation (Time Critical)**

Page 3 of 6

● Denotes Critical Step

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Obtain correct procedure IP-EP-120 <b>Time Commenced:</b> _____		
●2.	The SM shall evaluate Plant Status Sheet to determine IF a GE, SAE, ALERT or NUE classification applies, AND IF so, determine the highest classification and declare it.  <b>Note: Declaration must be made within 15 minutes of start of JPM</b> <b>Time Declaration Made:</b> _____	<b>EAL (8.1.7)</b> <b>SAE</b>	
●3.	Complete and Approve "New York State Radiological Emergency Data Form, Part 1" <b>Note: MUST BE COMPLETED WITHIN 15 MINUTES OF DECLARATION</b>  Obtain filled out Radiological Emergency Data Form, Part "1" from MEANS and retain as part of JPM package. <b>Time IP-EP-115 Form 1 completed:</b> _____	Complete IP-EP-115 Form 1  Verify Data using Radiological Emergency Data Form Information, item #s 4, 5, 7, 8, 11, 12 & 13	
4.	Initiate County, State AND NRC notification in accordance with IP-EP-130  CUE: Acknowledge as communicator when requested to commence notifications.	Request for CCR communicator	

**JPM No. 030EP-12**  
**Classify Emergency Events requiring Emergency Plan**  
**Implementation (Time Critical)**

Page 4 of 6

Any area of weakness observed?      YES ☐ NO ☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

---

Description of reviewed information:

**JPM No. 030EP-12**  
**Classify Emergency Events requiring Emergency Plan**  
**Implementation (Time Critical)**

Page 5 of 6

**Radiological Emergency Data Form Information**

EAL# (8.1.7), Intrusion into a plant vital area by a hostile force.

Reactor Status:      Operational

Plant Status:        Stable

Release Status:      No Release

Wind Speed:          1.7 meters/second

Wind Direction:      097 degrees @ 10 meters

Stability Class:      C

**JPM No. 030EP-12**  
**Classify Emergency Events requiring Emergency Plan**  
**Implementation (Time Critical)**  
Page 6 of 6

New York State Indian Point Energy Center RADIOLOGICAL EMERGENCY DATA FORM - PART 1		Notification # <u>1</u>
This is the Indian Point Energy Center with a Part 1 Notification on: <u>TODAYS DATE</u>		
<b>1.</b>	Reactor Status: <u>EXERCISE</u> ACTUAL EMERGENCY at: UNIT 2 UNIT 3 <u>BOTH UNITS</u> This is an: <u>Unit 2 Operational</u> (Date) <u>TODAY</u> (Time) <u>CURRENT TIME</u> (24 hr clock) <u>Unit 3 Shutdown</u> (Date) <u>TODAY</u> (Time) <u>CURRENT TIME</u> (24 hr clock) <u>Unit 3 Operational</u> (Date) <u>TODAY</u> (Time) <u>CURRENT TIME</u> (24 hr clock) <u>Shutdown</u>	
<b>2.</b>	The Emergency Classification is: <u>C</u> A. Unusual Event B. Alert <u>C.</u> Site Area Emergency D. General Emergency E. Emergency Terminated This Emergency Classification declared on: <u>TODAY</u> at <u>TIME OF DECLARATION</u> (Date) (Time 24 hr clock)	
<b>3.</b>	EAL#: <u>B.1.7</u> <u>INTRUSION INTO A PLANT VITAL AREA BY A HOSTILE FORCE</u>	
<b>4.</b>	Release of Radioactive Materials due to the Classified Event: <u>A</u> <u>A.</u> No Release B. Release BELOW Federal limits To Atmosphere To Water C. Release ABOVE Federal limits To Atmosphere To Water D. Unmonitored release requiring evaluation	
<b>5.</b>	Wind Speed: <u>1.7</u> Meters/Sec at elevation 10 meters	
<b>6.</b>	Wind Direction: (From) <u>197</u> Degrees at elevation 10 meters	
<b>7.</b>	Stability Class: A B <u>C</u> D E F G	
<b>8.</b>	The following Protective Actions are recommended to be implemented as soon as practicable: <u>A</u> <u>A.</u> NO NEED for PROTECTIVE ACTIONS outside the site boundary B. EVACUATE and IMPLEMENT the KI PLAN for the following Sectors C. SHELTER-IN-PLACE and IMPLEMENT the KI PLAN for the following Sectors All remaining Areas MONITOR the EMERGENCY ALERT SYSTEM 2 miles around 5-miles downwind 5 miles around 10-miles downwind Entire EPZ In the following Sectors: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 NOTE: OFFSITE AUTHORITIES SHOULD CONSIDER SHELTER-IN-PLACE + TAKE KI IF EVACUATION IS NOT FEASIBLE	
<b>9.</b>	Reported by - Communicator: _____ Telephone # _____ (Communicator's Name)	
<b>10.</b>	Emergency Director Approval: <u>Signature</u> Date/Time: <u>TODAYS DATE/TIME</u> (Director's Name)	

**ANSWER KEY**

**JPM No. 030EP-12**  
**Classify Emergency Events requiring Emergency Plan**  
**Implementation (Time Critical)**

Page 7 of 6

**THIS IS A TIME CRITICAL JOB PERFORMANCE MEASURE**  
**15 minutes from instructions to begin to Classification**  
**15 minutes from Classification to starting Notification**

*to make  
declassification*  
*They should  
know  
this?*

**INITIATING CUES:**

Both Units are operating at 100% power. The CCR is notified of a credible threat via the NRC ENS line. The CCR is responding per AOP-SEC-1. During their response, Security CAS notifies the CCR that

- The security fences north of the dry cask storage area have been breached.
- The Aux Boiler Feed Pump Building door has been found open

**METEOROLOGICAL CONDITIONS:**

Wind Speed: 1.7 meters/second  
Wind Direction: 097 degrees @ 10 meters  
Stability Class: C

*How is this normally*

**TASK STANDARD:**

*or Fairly Cue*

As the Shift Manager, classify the event. Complete and return to me the required Radiological Emergency Data Form as required by the Emergency Plan.



## Notification # \_\_\_\_\_

1. Reactor Status:  
This is an:      EXERCISE      ACTUAL EMERGENCY      at:      UNIT 2      UNIT 3      BOTH UNITS  
                 Unit 2 Operational      (Date) \_\_\_\_\_ (Time) \_\_\_\_\_ (24 hr clock)  
                 Shutdown  
                 Unit 3 Operational      (Date) \_\_\_\_\_ (Time) \_\_\_\_\_ (24 hr clock)  
                 Shutdown

3. EAL#: \_\_\_\_\_

**5. Wind Speed:** \_\_\_\_\_ **Meters/Sec at elevation 10 meters**

7.	Stability Class:	A	B	C	D	E	F	G
----	------------------	---	---	---	---	---	---	---

**NOTE: OFFSITE AUTHORITIES SHOULD CONSIDER SHELTER-IN-PLACE + TAKE KI IF EVACUATION IS NOT FEASIBLE**

10. Emergency Director Approval: \_\_\_\_\_ Date/Time: \_\_\_\_\_  
(Director's Name)

New York State  
Indian Point Energy Center  
RADIOLOGICAL EMERGENCY DATA FORM - PART 1

Notification # 1

This is the Indian Point Energy Center with a Part 1 Notification on: TODAYS DATE

1.

Reactor Status:

This is an:

EXERCISE

ACTUAL EMERGENCY

at: UNIT 2

UNIT 3

BOTH UNITS

Unit 2 Operational

(Date) TODAY (Time) CURRENT TIME (24 hr clock)

Shutdown

Unit 3 Operational

(Date) TODAY (Time) CURRENT TIME (24 hr clock)

Shutdown

2.

The Emergency

Classification is: C

A. Unusual Event

B. Alert

C. Site Area Emergency

D. General Emergency

E. Emergency Terminated

This Emergency Classification declared on: TODAY at TIME OF DECLARATION  
(Date) (Time 24 hr clock)

3.

EAL#: B.1.7 INTRUSION INTO A PLANT VITAL AREA BY A HOSTILE FORCE

4.

Release of Radioactive Materials due to the Classified Event: A

A. No Release

B. Release BELOW Federal limits

To Atmosphere

To Water

C. Release ABOVE Federal limits

To Atmosphere

To Water

D. Unmonitored release requiring evaluation

5.

Wind Speed: 1.7 Meters/Sec at elevation 10 meters

6.

Wind Direction: (From) 197 Degrees at elevation 10 meters

7.

Stability Class: A B C D E F G

8.

The following Protective Actions are recommended to be implemented as soon as practicable: A

A. NO NEED for PROTECTIVE ACTIONS outside the site boundary

B. EVACUATE and IMPLEMENT the KI PLAN for the following Sectors

C. SHELTER-IN-PLACE and IMPLEMENT the KI PLAN for the following Sectors

All remaining Areas MONITOR the EMERGENCY ALERT SYSTEM

2 miles around 5-miles downwind

5 miles around 10-miles downwind

Entire EPZ

In the following Sectors: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16

NOTE: OFFSITE AUTHORITIES SHOULD CONSIDER SHELTER-IN-PLACE + TAKE KI IF EVACUATION IS NOT FEASIBLE

9.

Reported by - Communicator: \_\_\_\_\_ Telephone # \_\_\_\_\_

(Communicator's Name)

10.

Emergency Director Approval: Signature Date/Time: TODAYS DATE/TIME

(Director's Name)

## Notification # \_\_\_\_\_

1.

This is an: **EXERCISE** **ACTUAL EMERGENCY** at: **UNIT 2** **UNIT 3** **BOTH UNITS**  
Unit 2 Operational  
 (Date) \_\_\_\_\_ (Time) \_\_\_\_\_ (24 hr clock)  
 Shutdown  
Unit 3 Operational  
 (Date) \_\_\_\_\_ (Time) \_\_\_\_\_ (24 hr clock)  
 Shutdown

**2.**

**3.**

4.

<b>A. No Release</b>	<b>B. Release BELOW Federal limits</b>	<b>To Atmosphere</b>	<b>To Water</b>
<b>C. Release ABOVE Federal limits</b>	<b>To Atmosphere</b>	<b>To Water</b>	<b>D. Unmonitored release requiring evaluation</b>

**5.**

**6.**

**7.**

**8.**

**NOTE: OFFSITE AUTHORITIES SHOULD CONSIDER SHELTER-IN-PLACE + TAKE KI IF EVACUATION IS NOT FEASIBLE**

**9.**

**10.**

Form EP-1, Rev 3

Facility: <u>Indian Point Unit 2</u>		Date of Examination: <u>July 12, 2010</u>
Examination Level: <b>RO</b> <input checked="" type="checkbox"/> <b>SRO</b> <input type="checkbox"/>		Operating Test Number: _____
Administrative Topic (see Note)	Type Code*	Describe activity to be performed
Conduct of Operations	N, R	<b>Calculate Shutdown Margin <i>with UNTRI PPABLE</i></b> <i>ROA</i> 2.1.25 Ability to interpret reference materials such as graphs, curves, tables etc. 2.1.19 Ability to use plant computers to evaluate system or component status
Conduct of Operations	N, S	<b>Perform IR NIS COL (Control Room)</b> 2.1.29 Knowledge of how to conduct system lineups, such as valves, breakers, switches, etc.
Equipment Control	N, R	<b>Tagout 21 Safety Injection Pump</b> 2.2.13 Knowledge of tagging and clearance procedures.
Radiation Control	M, R, P	<b>Calculate a Liquid Radiation Release Permit</b> 2.3.11 Ability to control radiation releases.
Emergency Procedures/Plan		Not Applicable for RO
NOTE: All items (5 total) are required for SROs. RO applicants require only 4 items unless they are retaking only the administrative topics, when all 5 are required.		
* Type Codes & Criteria: (C)ontrol room, (S)imulator, or Class(R)oom (D)irect from bank ( $\leq 3$ for ROs; $\leq 4$ for SROs & RO retakes) (N)ew or (M)odified from bank ( $\geq 1$ ) (P)revious 2 exams ( $\leq 1$ ; randomly selected)		

(A)lternate path	4-6 / 4-6 / 2-3
(C)ontrol room	
(D)irect from bank	$\leq 9 / \leq 8 / \leq 4$
(E)mergency or abnormal in-plant	$\geq 1 / \geq 1 / \geq 1$
(EN)gineered safety feature	- / - / $\geq 1$ (control room system)
(L)ow-Power / Shutdown	$\geq 1 / \geq 1 / \geq 1$
(N)ew or (M)odified from bank including 1(A)	$\geq 2 / \geq 2 / \geq 1$
(P)revious 2 exams	$\leq 3 / \leq 3 / \leq 2$ (randomly selected)
(R)CA	$\geq 1 / \geq 1 / \geq 1$
(S)imulator	

ES-301

## Administrative Topics Outline

Form ES-301-1

### INDIAN POINT UNIT 2 NRC RO EXAMINATION

**CONDUCT OF OPERATIONS: Calculate Shutdown Margin** – The candidate will be given a set of conditions and asked to calculate Shutdown Margin. This is accomplished using any computer with access to the IPEC intranet to obtain current plant data from the On-Line NuPOP. The data is entered in the SDM calculation section of WRC-1.

- This is a New JPM
- RO Only

**CONDUCT OF OPERATIONS: Perform IR NIS COL (Control Room)** – The candidate is directed to perform the control room section of the IR NIS Check Off List. One switch will be out of position. The candidate must identify this switch and inform the CRS.

- This is a New JPM
- RO Only

**EQUIPMENT CONTROL: Tagout 21 Safety Injection Pump** – The candidate will be given plant prints and associated procedures and directed to prepare a manual tagout for the 21 Safety Injection Pump for seal replacement. NOTE: Manual tagout JPMs exist in the JPM Bank; however, this component (21 Safety Injection Pump) is new and has not been used before.

- This is a New JPM
- RO Only

**RADIATION CONTROL: Calculate a Liquid Radiation Release Permit.** This JPM has modified values from the existing bank version

- This is a Modified Bank JPM
- RO Only

# Calculate Shutdown Margin with Untrippable Rod

Page 1 of 7

## ENTERGY (IP2) JOB PERFORMANCE MEASURE

Operator Name: \_\_\_\_\_

Employee ID #: \_\_\_\_\_

Evaluator: \_\_\_\_\_

Date: \_\_\_\_\_ SAT UNSAT

This JPM was administered for qualification? YES NO

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

# **Calculate Shutdown Margin with Untrippable Rod**

Page 2 of 7

## **DIRECTIONS TO OPERATOR:**

When I tell you to begin, you are to Calculate Shutdown Margin with an Untrippable Rod.

Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

## **INITIATING CUES:**

During performance of 2-PT-Q089 Control Rod Exercise Test, Rod F-14 did not move. I&C has determined that the rod is mechanically bound in place (Untrippable).

The CRS has directed you to Calculate Shutdown Margin with an Untrippable Rod.

Current Plant Data:

Cycle Burnup 999 MWD/MTU

Current Boron concentration 1140 ppm

Relative Power 100%














## **TASK STANDARD:**

Shutdown Margin Calculation complete. CRS informed of results.

# Calculate Shutdown Margin with Untrippable Rod

Page 3 of 7

 Denotes Critical Step

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation	Record Time	
2.	Obtain Correct Procedure	Obtains current revision of 2-WCR-1	
 3.	Go to Indian Point Energy Center web page and select Operations Department	Log into a computer and open Operations web page.	
 4.	On the Operations Web Page select Unit 2 NuPOP	"Click" on Unit 2 NuPOP	
 5.	Select the "Run" button to Open File	"Click" on Run button	
 6.	Observe NOTE before step 4	Observes Note to leave spreadsheet open	
 7.	When Acrobat Reader is up, select Bookmarks on the left pane then select '+' box associated with "B Supporting Excel Files" to Open the files	"Click" '+' box	
 8.	Select Table B-1, Summary of Supporting Excel Files	Select Table B-1	
 9.	Scroll down and select TPD7 File Name.xls and Select open/enable Macros.	Select TPD7	
10.	Enter current data for the following:	See Below	
	Cycle Burnup	Enter 999	
	Enter specific boron concentration	Enter 1140	
	Enter Relative Power	Enter 100	
 11.	Record Total Power Defect on Line #1	Record 1509	
 12.	Go to Table B-1 Summary of Supporting Excel Files, Select Shutdown Margin and Open when prompted to open spreadsheet	Select Shutdown Margin and Click Open when prompted	
 13.	Select HZP SDM Rackup tab	Select correct tab	

# Calculate Shutdown Margin with Untrippable Rod

Page 4 of 7

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
14.	Multiply row 11 value by 1000 and record on Line 2	Records 5730	
15.	Enter 900 on Line 3 to account for Untrippable rod	Enter 900	
16.	Add lines 1 – 3 to record Shutdown Margin	Calculate 3221	
<del>17.</del>	Ensure Shutdown Margin is greater than value in COLR	Determines SDM is greater than COLR	
18.	Close Unit 2 NuPOP Excel Spreadsheets Do not save data	Close Spreadsheet does not save data	
19.	JPM is complete	NA	

adjust calculations  
such that  
SDM will  
be < COLR  
to step 17  
because  
critical

What is  
value in  
COLR?  
Is it  
less than  
greater  
than?

## Calculate Shutdown Margin with Untrippable Rod

Page 5 of 7

Any area of weakness observed?

YES

☐

NO

☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

\_\_\_\_\_  
Description of reviewed information:

# Calculate Shutdown Margin with Untrippable Rod

Page 6 of 7

(Page 2 of 3)

## CALCULATE SHUTDOWN MARGIN (SDM) AT POWER WITH AN UNTRIPPABLE ROD

1. Determine Power Defect (+) 1509 PCM
2. Determine control bank worth and shutdown bank worth with the most reactive rod cluster stuck out (-) 5730 PCM
3. In the event a rod is known to be untrippable, SDM verification must account for the worth of the untrippable rod as well as another rod of maximum worth Cycle 19: (BOL=900; EOL=780) (+) 900 PCM
4. Shutdown Margin (SR 3.1.1.1 bases) (total items 1 through 3) (-) 3121 PCM

- 1) IF desired to CALCULATE SDM at power with an untrippable rod, THEN GO TO the Indian Point Entergy Center web page AND select (click, using the mouse) Departments and select (click) Operations.
- 2) On the Operations page, SELECT (click) Unit 2 / Unit 2 NuPOP.
- 3) WAIT and when prompted, SELECT the 'Run' button to open the file.

see  
Step  
1b

### NOTE

Leave the coefficients spreadsheet (Coeffs.xls) open while using the NuPOP.

- 4) WHEN the Acrobat Reader is up, SELECT Bookmarks on the left pane THEN SELECT the '+' box associated with "B Supporting Excel Files" to OPEN the files.
- 5) SELECT Table B-1, Summary of Supporting Excel Files.
- 6) To OBTAIN Power Defect, scroll down (second page) to select the 'TPD7' File Name.xls AND select open / Enable Macros.
- 7) ENTER current data for the following (using the 'Tab' or 'I' or click the applicable box):
  - a. Cycle Burnup (MWD/MTU).
  - b. Specified Boron Concentration (pcm).
  - c. Relative Power (%).
  - d. WHEN all the values are submitted, THEN RECORD on line #1 above, the Total Power Defect for ECP (pcm).

# Answer Key

2-WCR-1  
Rev 8

--

*J. Condit*  
**INITIATING CUES:**

During performance of 2-PT-Q089 Control Rod Exercise Test, Rod F-14 did not move. I&C has determined that the rod is mechanically bound in place (Untrippable).

The CRS has directed you to Calculate Shutdown Margin with an Untrippable Rod.

Current Plant Data:  
Cycle Burnup 999 MWD/MTU  
Current Boron concentration 1140 ppm  
Relative Power 100%

**TASK STANDARD:**

Shutdown Margin Calculation complete. CRS informed of results.

*Initiating Cue*

*NOTE:  
Seems like it would be a better task  
to Calculate Manually SDM  
without Computer  
Task looks perhaps  
TOO EASY non discriminatory*

key?

**CALCULATE SHUTDOWN MARGIN (SDM) AT POWER WITH AN UNTRIPPABLE ROD**

- |   |                     |
|---|---------------------|
| 1. Determine Power Defect   | (+) <u>1509</u> PCM |
| 2. Determine control bank worth and shutdown bank worth with the most reactive rod cluster stuck out  | (-) <u>5730</u> PCM |
| 3. In the event a rod is known to be untrippable, SDM verification must account for the worth of the untrippable rod as well as another rod of maximum worth Cycle 19: (BOL=900; EOL=780) | (+) <u>900</u> PCM  |
| 4. Shutdown Margin {SR 3.1.1.1 bases} (total items 1 through 3)   | (-) <u>3121</u> PCM |

- 1) IF desired to CALCULATE SDM at power with an untrippable rod, THEN GO TO the Indian Point Entergy Center web page AND select (click, using the mouse) Departments and select (click) Operations.
- 2) On the Operations page, SELECT (click) Unit 2 / Unit 2 NuPOP.
- 3) WAIT and when prompted, SELECT the 'Run' button to open the file.

**NOTE**

Leave the coefficients spreadsheet (Coeffs.xls) open while using the NuPOP.

- 4) WHEN the Acrobat Reader is up, SELECT Bookmarks on the left pane THEN SELECT the '+' box associated with "B Supporting Excel Files" to OPEN the files.
- 5) SELECT Table B-1, Summary of Supporting Excel Files.
- 6) To OBTAIN Power Defect, scroll down (second page) to select the 'TPD7' File Name.xls AND select open / Enable Macros.
- 7) ENTER current data for the following (using the 'Tab' or '↓' or click the applicable box):
  - a. Cycle Burnup (MWD/MTU).
  - b. Specified Boron Concentration (pcm).
  - c. Relative Power (%).
  - d. WHEN all the values are submitted, THEN RECORD on line #1 above, the Total Power Defect for ECP (pcm).

# Perform CR portion of the IR NIS COL

Page 1 of 6

## ENTERGY (IP2) JOB PERFORMANCE MEASURE

Operator Name: \_\_\_\_\_

Employee ID #: \_\_\_\_\_

Evaluator: \_\_\_\_\_

Date: \_\_\_\_\_ SAT \_\_\_\_\_ UNSAT \_\_\_\_\_

This JPM was administered for qualification? YES NO

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

*Signature*  
*Replace*  
*Just with*  
*Complete lights &*  
*sent the*  
*Don't appear*  
*to*  
*discriminate*  
*No critical*  
*steps*

## Perform CR portion of the IR NIS COL

Page 2 of 6

### DIRECTIONS TO OPERATOR:

When I tell you to begin, you are to Perform the Control Room portion of the Intermediate Range NI Check Off List.

Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

### INITIATING CUES:

The plant is at 100% power. Intermediate Range Channel N-35 was removed from service due to erratic operations. All actions of 2-AOP-INST-1, Instrument or Controller Failures have been completed.

Repairs to Channel N-35 have been completed.

The CRS has directed you to perform the Intermediate Range Channel N35 portion of 2-COL-13.1 section 1.3

### TASK STANDARD:

Section 1.3 of 2-COL-13.1 complete.

*Initiating Cue*

# Perform CR portion of the IR NIS COL

Page 3 of 6

*perform Intermediate Range  
Check off List*

● Denotes Critical Step

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation		
2.	Obtain current copy of procedure	Obtains 2-COL-13.1	
3.	Level Trip Switch in Normal	Switch in Normal	
4.	Operation Selector Switch in Normal	Switch in Normal	
● 5.	Test Mode Switch in Fixed	Candidate Notes Switch in Variable	
● 6.	List Test Mode Switch position in Table on Page 4 of COL	Enters Test Mode Switch in Table	
7.	Instrument Power On Light Illuminated	Light ON	
8.	Control Power On Light Illuminated	Light ON	
9.	Loss of Comp. Detector Light Extinguished	Light OFF	
10.	Loss of Comp. Volt. Light Extinguished	Light OFF	
11.	Instrument Power Fuses (2) Installed	Fuses Installed	
12.	Control Power Fuses (2) Installed	Fuses Installed	
● 13.	Notify CRS that Test Mode Switch is out of COL Position <b>CUE: CRS Acknowledges</b>	<i>don't even install switch</i>	
14.	JPM is complete		

## Perform CR portion of the IR NIS COL

Page 4 of 6

Any area of weakness observed?

YES

☐

NO

☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

\_\_\_\_\_  
Description of reviewed information:

## **Perform CR portion of the IR NIS COL**

Page 5 of 6

Reset simulator to any IC

Place TEST MODE switch to VARIABLE

--

*Initial Conditions*  
**INITIATING CUES:**

The plant is at 100% power. Intermediate Range Channel N-35 was removed from service due to erratic operations. All actions of 2-AOP-INST-1, Instrument or Controller Failures have been completed.

Repairs to Channel N-35 have been completed.

The CRS has directed you to perform the Intermediate Range Channel N35 portion of 2-COL-13.1 section 1.3

**TASK STANDARD:**

Section 1.3 of 2-COL-13.1 complete.

*Initiating Cue*

## Prepare a Tagout

Page 1 of 10

### ENTERGY (IP2) JOB PERFORMANCE MEASURE

**Operator Name:** \_\_\_\_\_

**Employee ID #:** \_\_\_\_\_

**Evaluator:** \_\_\_\_\_

**Date:** \_\_\_\_\_ **SAT** **UNSAT**

This JPM was administered for qualification?    YES    NO

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

## Prepare a Tagout

Page 2 of 10

### DIRECTIONS TO OPERATOR:

When I tell you to begin, you are to prepare a manual tagout for 21 SI Pump for seal replacement.

Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

### INITIATING CUES:

- 1 The eSOMS Clearance Module is unavailable.
- 2 The Shift Manager has determined that 21 Safety Injection Pump must be tagged out for seal replacement.
- 3 Clearance Number is 2C20
- 4 Tagout Number is SI-001.
- 5 You are directed to prepare a manual tagout for 21 Safety Injection Pump using EN-OP-102 and EN-OP-102-01.

### TASK STANDARD:

Manual Tagout Complete and ready for review.

*Initiating Cue*

# Prepare a Tagout

Page 3 of 10



Denotes Critical Step

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation <b>Time Commenced:</b> _____		
2.	Obtain Correct Procedure	Obtains EN-OP-102 EN-OP-102-01	
3.	Ensure requirement of Attachments 9.1 and 9.2 of EN-OP-102 are followed	Review Attachment 9.1 and 9.2	
4.	Review Scope of Work	Tagout Required for emergent work	
5.	Review Tagging Requirements	Tagout Required for emergent work	
6.	Determine Safe Work Boundary for filter replacement	Review Plant Prints 208088 225134 208500 225134 241171 9321-2735	
7.	Boundary Valves should be reviewed for outstanding deficiencies CUE: No deficiencies exist on valves identified in tagout boundary	Determines no outstanding deficiencies	
8.	Complete Attachment 9.1 and 9.2 of EN-OP-102-01	See Attached Answer Key	

## Prepare a Tagout

Page 4 of 10

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
9.	<p>Utilizing the Isolation Boundaries, Prepare the tagout</p> <p>For each tag include:</p> <ul style="list-style-type: none"> <li>• Tag Serial Number</li> <li>• Tag Type</li> <li>• Equipment</li> <li>• Equipment Description (Not required)</li> <li>• Equipment Location</li> <li>• Placement Sequence</li> <li>• Placement Configuration</li> <li>• Restoration Configuration</li> </ul>	See attached Answer Key	
	JPM is complete		

✓ Should ~~list~~ list each component & required tag position & restoration each critical task?

## Prepare a Tagout

Page 5 of 10

Any area of weakness observed?

YES

☐

NO

☐


\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

\_\_\_\_\_  
Description of reviewed information:


	<b>NUCLEAR MANAGEMENT MANUAL</b>	NON-QUALITY RELATED	EN-OP-102-01	REV. 6
		INFORMATIONAL USE	PAGE 5 OF 25	
<b>Protective and Caution Tagging Forms &amp; Checklist</b>				

ATTACHMENT 9.1

MANUAL TAGOUT INDEX SHEET

CLEARANCE \_\_\_\_\_

TAGOUT #	COMPONENT TO BE WORKED	DATE HUNG	DATE REMOVED
<b>SI-001</b>	<b>21 Safety Injection Pump Seal</b>		
	Answer Key		

 <b>Entergy</b>	<b>NUCLEAR MANAGEMENT MANUAL</b>	NON-QUALITY RELATED	EN-OP-102-01	REV. 6
		INFORMATIONAL USE	PAGE 6 OF 25	
<b>Protective and Caution Tagging Forms &amp; Checklist</b>				

**ATTACHMENT 9.1****TAGOUT COVER SHEET**Clearance: MANUAL 123456Tagout: SI-001**Component to be worked:**21 SI Pump**Description**21 SI Pump has a seal leak. Tagout and drain pump for seal replacement**Placement Inst:**See Attached**Answer Key****Hazards:**See Attached**Restoration Inst:**See Attached

Attribute Description	Attribute Value

Work Order Number	Description

Status	Description	User	Verification Date
Prepared	Prepared		
Technical Reviewed	Reviewed		
Approved	Approved		
Tags Verified Hung	Tags Verified Hung		
Removal Approved	Removal Approved		
Tags Verified Removed	Tags Verified Removed		

Tag Serial No.	Tag Type	Equipment Description Equipment Location	Place Seq.	Placement Configuration	Place 1 <sup>st</sup> Verif Date/Time	Place 2nd Verif Date/Time	Rest Seq	Restoration Configuration	Rest 1 <sup>st</sup> Verif Date/Time	Place 2nd Verif Date/Time	Placement/Removal Tag Notes
1	Danger	21 Safety Injection Pump 480V Bus 5A Control Switch CCR Pnl SBF-2	1	Pullout				Auto			
2	Danger	21 Safety Injection Pump Breaker Control Fuses 480 V Room Bus 5A	2	Removed/Of f				Installed/On			
3	Danger	21 Safety Injection Pump breaker 480V room Bus 5A	3	Racked Out				Racked/In			
4	Danger	MOV-850A 21 SI Pump Discharge Valve 98' PAB MCC Room	4	Closed/ Neutral				Open/ Neutral			
5	Danger	MOV-850A 21 SI Pump Discharge Valve Breaker 98' PAB MCC Room	5	OFF				OFF/Locked			
6	Danger	MOV-850A Manual Operator PAB 59' SI Pump Cell	6	Do Not Operate				Do Not Operate/ Locked			
7	Danger	SI-1807A 21 SI Pump Recirc Test Line Stop PAB 59' SI Pump Cell	7	Closed				Backseated Open/ Locked			
8	Danger	SI848A 21 Safety Injection Pump Suction Stop PAB 59' SI Pump Cell	8	Closed				Backseated Open/ Locked			
9.	Danger	SI-1843A 21 SI Pump Thrust Balance Flow Line Stop PAB 59' SI Pump Cell	9	Closed				Backseated Open			
10	Danger	SI-4274-Cap Cap Downstream of drain valve 7306 PAB 59' SI Pump Cell	10	Cap Removed				Installed			
11	Danger	SI-7306 21 SI Pump Discharge Line Drain Stop PAB 59' SI Pump Cell	11	Open				Closed			

Answer Key

File:

Parent Task # Task Number

12	Danger	SI-4274-Cap Cap Downstream of vent valve 4274 PAB 59' SI Pump Cell	12	Cap Removed				Installed			
13	Danger	SI-4274 21 SI Pump Casing Vent Stop PAB 59' SI Pump Cell	13	Open				Closed			

Answer Key

*of conditions*  
**INITIATING CUES:**

- 1 The eSOMS Clearance Module is unavailable.
- 2 The Shift Manager has determined that 21 Safety Injection Pump must be tagged out for seal replacement.
- 3 Clearance Number is 2C20
- 4 Tagout Number is SI-001.
- 5 You are directed to prepare a manual tagout for 21 Safety Injection Pump using EN-OP-102 and EN-OP-102-01.

**TASK STANDARD:**

Manual Tagout Complete and ready for review.

*Final Review Cue*

# Calculate a Liquid Radioactive Release Permit for #14 Liquid Waste Distillate Storage Tank

Page 1 of 10

## ENTERGY (IP2) JOB PERFORMANCE MEASURE

Operator Name: \_\_\_\_\_

Employee ID #: \_\_\_\_\_

Evaluator: \_\_\_\_\_

Date: \_\_\_\_\_ SAT UNSAT

This JPM was administered for qualification? YES NO

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

# Calculate a Liquid Radioactive Release Permit for #14 Liquid Waste Distillate Storage Tank

Page 2 of 10

## DIRECTIONS TO OPERATOR:

When I tell you to begin, you are to calculate a radioactive liquid release in accordance with SOP-5.1.5

Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

## INITIATING CUES:

1. The Unit is operating at 100% power.
2. All radiation monitors are operable.
3. Waste Distillate Storage Tank #14 is to be discharged, tank level, as reported by the NPO, is 71 inches.
4. WDST has been isolated and on recirc for the past 5 hours.
5. R-54 is aligned to #14 WDST.
6. You are directed to calculate the Liquid Release Permit in accordance with 2-SOP-5.1.5. and submit to CRS for review
8. Additional Data:

Permit Number	100300
Tank ID	14 WDST
Initial Tank Level	71
Pre-release volume	16,351 gal
Recirculation Rate	150 gpm
Recirc Start-	Today 5 hours ago
Recirc Stop	Today Now
Chem Sample Number	3906
Sample Date/Time	Today 15 minutes ago
Total Gamma Activity	4.0E-5 uCi/ml
ADC	5.31E-7 uCi/ml
ppm Boron in tank	632
Pump Configuration	6 CWP's in Fast, 3 SWPs, 0 RWP's

→ *Finality Cue*

## **Calculate a Liquid Radioactive Release Permit for #14 Liquid Waste Distillate Storage Tank**

Page 3 of 10

### **TASK STANDARD:**

Radioactive liquid waste release calculation and release permit (Attachment 1 to SOP-5.1.5) complete.

# Calculate a Liquid Radioactive Release Permit for #14 Liquid Waste Distillate Storage Tank

Page 4 of 10

● Denotes Critical Step

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation <b>Time Commenced:</b> _____		
2.	Review Precautions and Limitations  CUE: When requested, inform operator all P&Ls are satisfied	Precautions and Limitations Reviewed	
3.	Determine required recirculation time for the tank to be released	Determine minimum recirculation time to be 218 minutes from Table 1	
●4.	Determine Total Dilution Flow CUE: 6 CWP Fast Speed 3 SWP 0 RWP	Sum flowrate based on current pump combinations. Calculate 855,000 gpm	
5.	Assign Permit Number <b>CUE:</b> Permit Number 100300	Initial Conditions	

# Calculate a Liquid Radioactive Release Permit for #14 Liquid Waste Distillate Storage Tank

Page 5 of 10

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
6.	<p>Enter data on Attachment 1</p> <p>CUE:</p> <p>Permit Number 100300</p> <p>Tank ID 14 WDST</p> <p>Initial Tank Level 71</p> <p>Pre-release volume 16,351</p> <p>Recirculation Rate 150 gpm</p> <p>Recirc Start- Today 5 hours ago</p> <p>Recirc Stop Today Now</p> <p>Chem Sample Number 3906</p> <p>Sample Date/Time Today 15 minutes ago</p> <p>Total Gamma Activity 4.0E-5</p> <p>ADC 5.31E-7</p> <p>ppm Boron in tank 632</p>	Supplied with Initial condition.	
7.	<p>Verify from Chemistry total gamma activity without noble gas is less than 5.0E-5 <math>\mu\text{Ci/ml}</math>.</p> <p>CUE: Chemist reports total gamma activity &lt; 5.0E-5 <math>\mu\text{Ci/ml}</math>. If requested, R54 activity is 2.4E-5 <math>\mu\text{Ci/cc}</math></p>	Simulate Contact Chemist	
8.	Record Available Dilution Flowrate	Previously calculated 855,000 gpm	
9.	Calculate pounds of Boron in Tank and Maximum Allowable Chemical Release Rate	Performs calculation determines 86 ( $\pm 1$ ) pounds of boron and Chem release rate 1352 ( $\pm 2$ )	
10.	Calculate the Permissible Radioactive Release Rate	Performs calculation determines rad. Release rate 11350 ( $\pm 5$ )	
11.	Determine most restrictive release rate	Identifies Pump Capacity 250 most restrictive	

# Calculate a Liquid Radioactive Release Permit for #14 Liquid Waste Distillate Storage Tank

Page 6 of 10

*My POT critical  
Should be*

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
* 12.	Determine effluent rad monitor in service and calculate maximum alarm	Calculates Max Alarm Setpoint 1.816E-3	
13.	Select an Alarm setpoint less than or equal to the calculated setpoint and record	Records a value less than the calculated value	?
14.	Set the alarm setpoint per 2-SOP-12.3.2 CUE: If asked another operator will adjust the radiation monitor setpoint		
15.	Select an Warn setpoint less than or equal to the Alarm setpoint and record	Records a value less than the Alarm value	
13.	Submit completed permit to CRS for review		
	JPM Complete		

# Calculate a Liquid Radioactive Release Permit for #14 Liquid Waste Distillate Storage Tank

Page 7 of 10

Any area of weakness observed? YES ☐ NO ☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

\_\_\_\_\_  
Description of reviewed information:

# CALCULATION AND RECORDING OR RADIOACTIVE LIQUID RELEASES

No: 2-SOP-5.1.5

Rev: 36

Page 16 of 23

## ANSWER KEY EXAMPLE RADIOACTIVE LIQUID RELEASE PERMIT (Page 1 of 1)

PERMIT # 10300 TANK ID 14 WDST INITIAL Tank Level: 71 (Inches) 16351 Volume (V), gal

RECIRC RATE: 150 gpm Recirc Start: 7/14/10 (Date) 00:00 (Time)  
Recirc Stop: 7/14/10 (Date) 05:00 (Time)

Chemistry Sample No. 3906 Sample Collection: 7/14/10 (Date) 04:30 (Time)

Gamma Activity without Gas and Tritium is less than the admin limit of SMM-CY-001: Yes / No

Total Gamma Activity 4.0E-5  $\mu$ Ci/ml Allowed Diluted Concentration (ADC) 5.31E-7  $\mu$ Ci/ml

TOTAL DILUTION FLOW (T) 855,000 (GPM) From: 6 Unit 2 Circulators  
0 Unit 3 Circulators  
3 Service Water Pumps

BORON:  $\frac{632}{\text{ppm B}} \times \frac{16351}{\text{tank vol (V), gal}} \times 8.33\text{E-6} = \underline{86}$  pounds

Maximum Chemical Release Rate (Rc) =  $(\frac{855,000}{\text{Avail Dil Flow (B), gpm}} \times 1 \text{ ppm}) + \frac{632}{\text{ppm B}} = \underline{1352}$  gpm

Radioactive Release Rate: (Rr) =  $(\frac{855,000}{\text{Avail Dil Flow (B), gpm}} \times \frac{5.31\text{E-7}}{\text{ADC, uCi/ml}}) \div \frac{4.0\text{E-5}}{\text{Gamma Act (C), uCi/ml}} = \underline{11350}$  gpm

Most Restrictive Release Rate (R) = 250 gpm (pump capacity most limiting)

Rad Monitor # 54 SOURCE CHECKED X OPERABLE X YES NO (IF NO, COMPLETE ATT 3)

Maximum Alarm Setpoint =  $(\frac{855,000}{\text{Avail Dil Flow (B), gpm}} \times \frac{5.31\text{E-7}}{\text{ADC, uCi/ml}}) \div \frac{250}{\text{Most Restrictive Release Rate (R), gpm}} = \underline{1.816\text{E-3}}$  uCi/ml

Actual Alarm Setpoint = 4.0E-4 uCi/ml Warn Setpoint = 3.0E-4 uCi/ml

DISCHARGE FLOW METER & RECORDER OPERABLE X YES NO (IF NO, COMPLETE ATTACHMENT 3)

Release Authorized By: \_\_\_\_\_ (Date)

RELEASE INITIATED: \_\_\_\_\_ (Date) \_\_\_\_\_ (Time)

RELEASE TERMINATED: \_\_\_\_\_ (Date) \_\_\_\_\_ (Time)

FINAL TK LEVEL: \_\_\_\_\_ (Inches) \_\_\_\_\_ gal TOTAL VOLUME RELEASED \_\_\_\_\_ gal

Remarks:

# CALCULATION AND RECORDING OR RADIOACTIVE LIQUID RELEASES

No: 2-SOP-5.1.5 Rev: 36

Page 16 of 23

## ATTACHMENT 1 EXAMPLE RADIOACTIVE LIQUID RELEASE PERMIT (Page 1 of 1)

PERMIT # \_\_\_\_\_ TANK ID \_\_\_\_\_ INITIAL \_\_\_\_\_  
Tank Level: \_\_\_\_\_ (Inches) \_\_\_\_\_ Volume (V), gal \_\_\_\_\_  
RECIRC RATE: \_\_\_\_\_ gpm Recirc Start: \_\_\_\_\_ (Date) \_\_\_\_\_ (Time)  
Recirc Stop: \_\_\_\_\_ (Date) \_\_\_\_\_ (Time)

Chemistry Sample No. \_\_\_\_\_ Sample Collection: \_\_\_\_\_ (Date) \_\_\_\_\_ (Time)

Gamma Activity without Gas and Tritium is less than the admin limit of SMM-CY-001: Yes / No

Total Gamma Activity \_\_\_\_\_  $\mu\text{Ci/ml}$  Allowed Diluted Concentration (ADC) \_\_\_\_\_  $\mu\text{Ci/ml}$

TOTAL DILUTION FLOW (T) \_\_\_\_\_ (GPM) From: \_\_\_\_\_ Unit 2 Circulators  
\_\_\_\_\_ Unit 3 Circulators  
\_\_\_\_\_ Service Water Pumps

BORON: \_\_\_\_\_ x \_\_\_\_\_ x  $8.33\text{E-6}$  = \_\_\_\_\_ pounds  
ppm B tank vol (V), gal

Maximum Chemical Release Rate (Rc) = ( \_\_\_\_\_ x 1 ppm ) + \_\_\_\_\_ = \_\_\_\_\_ gpm  
Avail Dil Flow (B), gpm ppm B

Radioactive Release Rate: (Rr) = ( \_\_\_\_\_ x \_\_\_\_\_ ) + \_\_\_\_\_ = \_\_\_\_\_ gpm  
Avail Dil Flow (B), gpm ADC,  $\mu\text{Ci/ml}$  Gamma Act (C),  $\mu\text{Ci/ml}$

Most Restrictive Release Rate (R) = \_\_\_\_\_ gpm (pump capacity most limiting)

Rad Monitor # \_\_\_\_\_ SOURCE CHECKED \_\_\_\_\_ OPERABLE YES NO (IF NO, COMPLETE ATT 3)

Maximum Alarm Setpoint = ( \_\_\_\_\_ x \_\_\_\_\_ ) + \_\_\_\_\_ = \_\_\_\_\_  $\mu\text{Ci/ml}$   
Avail Dil Flow (B), gpm ADC,  $\mu\text{Ci/ml}$  Most Restrictive Release Rate (R), gpm

Actual Alarm Setpoint = \_\_\_\_\_  $\mu\text{Ci/ml}$  Warn Setpoint = \_\_\_\_\_  $\mu\text{Ci/ml}$

DISCHARGE FLOW METER & RECORDER OPERABLE YES NO (IF NO, COMPLETE ATTACHMENT 3)

Release Authorized By: \_\_\_\_\_ (Date)

RELEASE INITIATED: \_\_\_\_\_ (Date) \_\_\_\_\_ (Time)

RELEASE TERMINATED: \_\_\_\_\_ (Date) \_\_\_\_\_ (Time)

FINAL TK LEVEL: \_\_\_\_\_ (Inches) \_\_\_\_\_ gal TOTAL VOLUME RELEASED \_\_\_\_\_ gal

Remarks:

*J. Carleton*  
**INITIATING CUES:**

1. The Unit is operating at 100% power.
2. All radiation monitors are operable.
3. Waste Distillate Storage Tank #14 is to be discharged, tank level, as reported by the NPO, is 71 inches.
4. WDST has been isolated and on recirc for the past 5 hours.
5. R-54 is aligned to #14 WDST.
6. You are directed to calculate the Liquid Release Permit in accordance with 2-SOP-5.1.5. and submit to CRS for review
7. Additional Data:

Permit Number	100300
Tank ID	14 WDST
Initial Tank Level	71
Pre-release volume	16,351 gal
Recirculation Rate	150 gpm
Recirc Start-	Today 5 hours ago
Recirc Stop	Today Now
Chem Sample Number	3906
Sample Date/Time	Today 15 minutes ago
Total Gamma Activity	4.0E-5 uci/ml
ADC	5.31E-7 uci/ml
ppm Boron in tank	632
Pump Configuration	6 CWP's in Fast, 3 SWP's, 0 RWP's

**TASK STANDARD:**

Radioactive liquid waste release calculation and release permit (Attachment 1 to SOP-5.1.5) complete.

*In. Entry Case:*

Facility: <u>Indian Point Unit 2</u>		Date of Examination: <u>July 12, 2010</u>
Exam Level: <b>RO</b> <input checked="" type="checkbox"/> <b>SRO-I</b> <input checked="" type="checkbox"/> <b>SRO-U</b> <input type="checkbox"/>		Operating Test No.: _____

Control Room Systems <sup>@</sup> (8 for RO); (7 for SRO-I); (2 or 3 for SRO-U, including 1 ESF)		
System / JPM Title	Type Code*	Safety Function
a. Realign a Misaligned Rod	M, A, S	1
b. Terminate Safety Injection after Main Steam Line Break	N, S, EN	2
c. Depressurize the RCS during SGTR using Aux Spray	D, A, S, EN	3
d. Transfer from AFW to Low Flow Bypass Feed.	M, L, P, S	4-S
e. Align Recirculation Spray	N, S, EN	5
f. Restore Power to Bus 2A using 22 EDG <i>RO only</i>	A, N, S	6
g. Perform Required Actions for 23 SG Pressure Channel (439B) Failing Low	D, A, S	7
h. Adjust the Alarm setpoints for R-44 in preparation for a gaseous release	N, S	9

In-Plant Systems <sup>@</sup> (3 for RO); (3 for SRO-I); (3 or 2 for SRO-U)		
i. Perform Required Actions to Dump Steam Locally Using the Atmospheric Steam Dump Valve for 21 SG	D, A, E	4-P
j. Start the Appendix R SBO EDG	N	6
k. Perform the Required Actions to Establish Backup Cooling to the Charging Pumps	D, R, E	8

<sup>@</sup> All RO and SRO-I control room (and in-plant) systems must be different and serve different safety functions; all 5 SRO-U systems must serve different safety functions; in-plant systems and functions may overlap those tested in the control room.		
---	--	--

* Type Codes	Criteria for RO / SRO-I / SRO-U
--------------	---------------------------------

- a. **Realign a Misaligned Control Bank Rod** in accordance with 2-AOP-ROD-1, *Rod Control Malfunctions*. One Control Bank Rod has become misaligned during power ascension with power level approximately 50%. When the candidate releases the IN-HOLD-OUT switch, the control rod will continue to withdraw. The candidate should re-enter 2-AOP-ROD-1, trip the reactor and perform the Immediate Operator Actions for a Reactor Trip.
- This is an Alternate Path JPM.
  - This is a Modified Bank JPM
  - Failure to properly perform this task will result in violation of TS and possible exceeding hot channel factors.
- b. **Terminate Safety Injection after Main Steam Line Break.** The plant experienced a steam break outside containment upstream of the MSIVs. Following the isolation of the faulted SG, the crew would transition to E-1; then, the crew would transition to ES-1.1, *SI Termination* using the foldout page criteria. This procedure flowpath does not have SI, or Phase A reset prior to entry. The candidate will be required to perform all actions to Reset SI and Phase A signals, then Terminate SI by securing the pumps.
- This is a new JPM.
  - Failure to properly perform this JPM will result in SI flow continuing and possible PTS condition.
- c. **Depressurize the RCS during a SGTR using Aux Spray.** A SGTR of adequate size to cause an SI has occurred. 6.9 KV Bus 3 tripped on fault resulting in a loss of 23 RCP. All actions up to depressurize to refill the pressurizer and minimize break flow will have been completed. The PORV Block Valves will be danger tagged shut and PCV-455A (Loop 24 Spray Valve) will not open. The candidate will continue in 2-E-3, *Steam Generator Tube Rupture* and perform depressurization using Aux Spray.
- This is an Alternate Path JPM.
  - This JPM directly from the JPM bank; however, it has not been used on the previous 2 NRC Exams.
  - Failure to properly perform this task will result in excessive loss of RCS inventory and possible SG overfill.
- d. **Transfer from AFW to Low Flow Bypass Feed.** The plant is at approximately 2-3% power. One MBFP has been started and is ready to provide flow to the SGs. In accordance with 2-SOP-21.1, *Main Feedwater System*, the candidate will transfer steam generator feedwater from the Auxiliary Feedwater System to the Main Feedwater Low Flow Bypass valves.
- A similar JPM was used on the last Unit 3 exam; however the method used was different from the method used in this JPM.
  - Failure to properly perform this task will result in possible reactor trip on SG level.
- e. **Align Recirculation Spray Flow.** The plant has experienced a Large Break LOCA. Transfer to recirculation has been accomplished. When the RWST has decreased to 2 feet the operating Containment Spray pump must be secured and transfer to recirculation spray flow must be accomplished in accordance with 2-ES-1.3 *Transfer to Cold Leg Recirculation*. This JPM requires the candidate to ensure proper core flow while Recirculation Spray flow is established since the Recirculation Pumps will be providing both core cooling flow and containment spray flow.
- This is a new JPM.
  - Failure to properly perform this task will result in failure to meet FSAR assumptions for Iodine removal.

- f. **Restore power to bus 2A using 22 EDG.** Bus 2A normal supply breaker will be tripped on overcurrent. The candidate will use 2-SOP-480V-1, *Loss Of Normal Power To Any 480v Bus*. All 3 EDGs will have automatically started and be running unloaded. All of the loads on the bus will be removed and a visual inspection of the bus performed (Local action). The bus will be re-energized from the control room using the EDG supply breaker.
- This is a New JPM.
  - This is an Alternate path JPM.
  - Failure to properly perform this task will result in reduction in redundant power supplies for safeguards equipment.
- g. **Perform Required Actions for 23 SG Pressure Channel (439B) Failing Low (alternate Path).** The affected Steam Pressure Transmitter provides density compensation for the steam flow channel used in the Steam Generator Water Level Control System. Steam Pressure failing Low will result in Steam Flow failing Low. The Immediate Operator actions will attempt to place the unaffected steam flow transmitter in service. The switch will not function (stuck contacts) requiring the candidate to take manual control of the feedwater regulating valve and controlling level. Additional actions include tripping bistables to remove the channel from service.
- This is a Bank JPM.
  - This JPM has never been used on an ILO NRC exam.
  - This is an Alternate path JPM.
  - Failure to properly perform this task will result in loss of control of SG level and possible Reactor Trip.
- h. **Adjust the Alarm setpoints for R-44 in preparation for a gaseous release.** In preparation for a gaseous waste release, the Warn and Alarm setpoint for Radiation Monitor 44, *Plant Vent Radio Gas*, must be changed. A Gaseous Waste Release Permit calculation indicates that the Alarm and Warn setpoint must be reset prior to the actual release. The candidate must change the Alarm and Warn setpoint to the values calculated on the Release Permit.
- This is a New JPM.
  - Failure to properly perform this task may result in excessive release of radioactive gas to the environment.
- i. **Perform Required Actions to Dump Steam Locally Using the Atmospheric Steam Dump Valve for 21 SG.** The JPM is part of the Appendix R actions. Instrument Air will not be available for the Atmospheric Steam Dump Valve. The candidate will be required to simulate connecting the alternate Nitrogen supply tank to the valve and control steam flow locally.
- In Plant JPM
  - This is a Bank JPM.
  - This JPM has not been used at Unit 2 for initial NRC exams. The Nitrogen Bottles were recently added and this JPM was written for annual requal operating exam.
  - Failure to properly perform this task will result in inability to control RCS temperature during a control room evacuation.
- j. **Start the Appendix R Emergency Diesel Generator.** Using 2-SOP-27.6, *Unit 2 Appendix R Diesel Generator Operation*, Start the Appendix R EDG Normal Engine Start (Parallel Mode). This is a relatively new piece of equipment. This EDG was not installed during the last NRC exam.
- In Plant JPM
  - This is a New JPM.
  - Failure to properly perform this task will result in not supplying electrical power during control room evacuation event.

- k. **Perform the Required Actions to Establish Backup Cooling to the Charging Pumps**
- This JPM is part of the Appendix R actions. The control room is evacuated and CCW is not available to the charging pumps. The candidate is directed to align backup city water cooling to the charging pumps.
  - In Plant JPM
  - This JPM is directly from existing bank.
  - This JPM has not been used on the previous last 2 Unit 2 Initial NRC examinations. A similar JPM was used on the last Unit 3 Initial exam; however, the methodology is significantly different between units.
  - Failure to properly perform this task will result in inability to maintain RCS inventory and possible core damage.

## Respond to a Misaligned Rod

Page 1 of 8

### ENTERGY (IP2) JOB PERFORMANCE MEASURE

**Operator Name:** \_\_\_\_\_

**Employee ID #:** \_\_\_\_\_

**Evaluator:** \_\_\_\_\_

**Date:** \_\_\_\_\_ **SAT** **UNSAT**

This JPM was administered for qualification?    YES    NO

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

## **Respond to a Misaligned Rod**

Page 2 of 8

### **DIRECTIONS TO OPERATOR:**

When I tell you to begin, you are to realign misaligned rod P-6.

Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

### **INITIATING CUES:**

The plant is at approximately 60% power during a startup. During rod withdrawal rod P-6 stepped in then stopped when the IN-HOLD-OUT switch was released. I&C identified a Moveable Gripper fuse blown. The fuse has been replaced.

The OM and Reactor Engineering have determined the rod should be realigned with the bank.

All necessary Briefs have been completed.

The Reactor Engineer has determined that the rod can be restored at normal rod speed.

You are directed to realign Rod P-6 with the bank in accordance with 2-AOP-ROD-1 starting with step 106.

### **TASK STANDARD:**

Control Bank D rod P-6 is realigned with the remainder of the bank.

## Respond to a Misaligned Rod

Page 3 of 8

✱ Denotes Critical Step

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation		
2.	Obtain procedure 2-AOP-ROD-1		
3.	Will rod be realigned with the group CUE: The rod will be aligned with the group.		
4.	Is the affected rod below remainder of rods in its group?	Observes rod below remainder of rods	
5.	Observes CAUTION before step 4.108 CUE: Reactor Engineer determined there are no limits on power and rod can be withdrawn at normal manual rod speed.	Contact Reactor Engineer for limitations	
✱6.	Open lift coil disconnect switches for all rods in Control bank D except rod P-6.	All lift coil disconnect switches opened	
✱7.	Place rod bank selector switch in CBD (Control Bank D) position	Selector Switch in CBD	
8.	Record group step counter reading for affected rod group	Records rod group position (approximately 194 steps)	
9.	Manually set step counter for group containing affected rod to actual position of misaligned rod <b>CUE: Rod is at 161 Steps</b>	Adjust step counter reading to affected rod height.	
10.	Is affected rod in a control bank	Determines P-6 is in CBD	
11.	Place P/A converter display selector switch in position for appropriate bank and record position	Select CBD on P/A converter and record position	
12.	Is affected rod below remainder of rods in its group	Determines rod is below remainder of rods	

## Respond to a Misaligned Rod

Page 4 of 8

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
13.	Is alarm NIS Power Range Overpower Rod Stop 106% clear?	Determines alarm is clear	
14.	Observe NOTE before step 4.118	Observes note	
15.	Withdraw affected rod at rate specified by Reactor Engineer (Normal manual rod speed) until group step counter matches that recorded above.  NOTE: Candidate may release IN_HOLD OUT switch when Urgent Failure Alarm annunciates.	Places IN-HOLD-OUT switch to OUT position	
16.	Observes rod continue to move when IN-HOLD-OUT switch is released.	Step counters continue and IRPI continues to increase	
17.	Candidate may trip the reactor at this time or may re-enter the procedure (steps below)		
18.	Was this procedure entered due to continuous unwarranted rod motion?	Determines procedure was entered due to continuous rod motion	
19.	Is rod control in manual	Determines rod control is in manual	
20.	Does continuous unwarranted rod motion still exist	Determines rod motion still exists	
20.	Trip the reactor and GO TO E-0	Depresses Reactor Trip Pushbutton	
21.	Enter E-0	Removes placard for Immediate Operator Actions	
22.	Verify Reactor Trip Observes: Reactor Trip Breakers Open Neutron flux lowering Rod bottom light lit Rod Position Indicators all < 2.5 inches	Observes the reactor is tripped	

## Respond to a Misaligned Rod

Page 5 of 8

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
23.	Verify Turbine Tripped Observes all stop valves closed	Observes turbine is tripped	
24.	JPM is complete		

## Respond to a Misaligned Rod

Page 6 of 8

Any area of weakness observed?

YES ☐ NO ☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

---

Description of reviewed information:

## Respond to a Misaligned Rod

Page 7 of 8

### Simulator Setup

Reset Simulator to IC-18

Enter Malfunction **MAL CRF002AV** (Dropped Rod), **Moving** (for moveable gripper).

Place Rod Control Mode Selector Switch in manual if necessary.

Insert rods one and withdraw one step to cause P-6 to become misaligned.

#### **REMOVE malfunction MAL CRF002AV**

Insert Malfunction **MAL CRF004A** (Uncontrolled Rod Motion Bank or Man) set STEP/MIN to **66**.

Take Snapshot if JPM is to be used more than once.



**INITIATING CUES:**

The plant is at approximately 60% power during a startup. During rod withdrawal rod P-6 stepped in then stopped when the IN-HOLD-OUT switch was released. I&C identified a Moveable Gripper fuse blown. The fuse has been replaced.

The OM and Reactor Engineering have determined the rod should be realigned with the bank.

All necessary Briefs have been completed.

The Reactor Engineer has determined that the rod can be restored at normal rod speed.

You are directed to realign Rod P-6 with the bank in accordance with 2-AOP-ROD-1 starting with step 106.

**TASK STANDARD:**

Control Bank D rod P-6 is realigned with the remainder of the bank.

## Terminate SI Per ES-1.1

Page 1 of 8

### ENTERGY (IP2) JOB PERFORMANCE MEASURE

Operator Name: \_\_\_\_\_

Employee ID #: \_\_\_\_\_

Evaluator: \_\_\_\_\_

Date: \_\_\_\_\_ SAT UNSAT

This JPM was administered for qualification? YES NO

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

## **Terminate SI Per ES-1.1**

Page 2 of 8

### **DIRECTIONS TO OPERATOR:**

When I tell you to begin, you are to Terminate Safety Injection in accordance with 2-ES-1.1

Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

### **INITIATING CUES:**

A large steam break occurred outside the VC upstream of the MSIV on 24 SG.

All actions of E-0 including Attachment 1 and E-2 have been completed. The crew transitioned to E-1 and determined that the Foldout Page SI Termination criteria was satisfied and transitioned to 2-ES-1.1.

You are directed to Terminate SI in accordance with 2-ES-1.1

### **TASK STANDARD:**





SI is terminated in accordance with ES-1.1 up to and including step 6.

# **Terminate SI Per ES-1.1**

Page 3 of 8



**Denotes Critical Step**

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation		
2.	Obtain correct procedure	ES-1.1	
3.	Review CAUTION before step 1	Reviews CAUTION	
4.	Reset SI	See Below	
	Check All CCW Pumps Running	Observes all CCW pumps running	
	Place Controls for Main and Bypass Feed Reg Valves to close	Place MFRV in Manual and lower setpoint to 0 Check Bypass FRV in close	
	Verify Automatic Safeguards Actuation key switches on Panel SB-2 in Defeat	Train A & Train B Key Switches placed in Defeat	
	One at a time depress SI Reset buttons	Reset Buttons depressed one at a time	
	Verify Train A & Train B Reset Note: The audible click of the relays resetting is acceptable. Candidate may go to the relays to visually observe them reset.	Audible Click heard when buttons depress	
5.	Reset Containment Isolation Phase A and B	See Below	
	Place IVSW switches to Open	Places switches to open for: 1410 1413 SOV-3518 SOV-3519	
	Place Containment Rad Mon WCPS Valves to OPEN	Switch to open	

## Terminate SI Per ES-1.1

Page 4 of 8

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Note: One Switch controls 4 Valves		
	Verify personnel and equipment hatch solenoid control switches to INCIDENT	Switches verified in incident	
	Place control switches for all remaining Phase A isolation valves to CLOSE	Switches placed to close	
	One at a time depress Phase A reset buttons Note: The audible click of the relays resetting is acceptable. Candidate may go to the relays to visually observe them reset.	Reset Buttons depressed one at a time	
	Verify Train A and B reset	Audible Click heard when buttons depress	
	Check Phase B actuated NO	Observes Phase B not actuated	
6.	Establish Instrument Air to containment – Open PCV-1228	Switch for 1228 to Open	
7.	Stop SI Pumps and Place in Auto	See Below	
	Stop SI Pumps and place in Auto	All 3 Switches to stop and returned to auto	
	Check any RHR Pumps running with suction aligned to RWST	Observes one RHR pump running aligned to RWST	
	Stop RHR pumps and place in Auto	Switch to stop and both switches returned to Auto	
8.	Review Caution and Note before step 5	Caution and Note reviewed	
9.	Check if charging flow has been established – YES	Observes one charging pump running	
10.	Establish charging flow as necessary NOTE: Candidate may reduce charging flow and adjust HVC-142 to maintain seal in jection	Adjust as necessary No adjustment is acceptable	

## Terminate SI Per ES-1.1

Page 5 of 8

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
11.	Verify SI Flow Not Required	Check Subcooling > 19° and Pressurizer Level > 14%	
	JPM is complete		

## Terminate SI Per ES-1.1

Page 6 of 8

Any area of weakness observed?

YES

☐

NO

☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

\_\_\_\_\_  
Description of reviewed information:

## **Terminate SI Per ES-1.1**

Page 7 of 8

### **Simulator Setup**

Initialize to any 100% power IC

Insert Malfunction MAL-SGN003D at 100%. Run the simulator and allow alarms to annunciate and automatic actions to occur.

Perform required actions of E-0 including attachment 1, and E-2.

Freeze the simulator. Take a snapshot if JPM is to be used more than once.

--

**INITIATING CUES:**

A large steam break occurred outside the VC upstream of the MSIV on 24 SG.

All actions of E-0 including Attachment 1 and E-2 have been completed. The crew transitioned to E-1 and determined that the Foldout Page SI Termination criteria was satisfied and transitioned to 2-ES-1.1.

You are directed to Terminate SI in accordance with 2-ES-1.1

**TASK STANDARD:**

SI is terminated in accordance with ES-1.1 up to and including step 6.

**Depressurize the RCS to Restore Inventory during a SGTR using  
Aux Spray**  
Page 1 of 7

**ENTERGY (IP2)  
JOB PERFORMANCE MEASURE**

**Operator Name:** \_\_\_\_\_

**Employee ID #:** \_\_\_\_\_

**Evaluator:** \_\_\_\_\_

**Date:** \_\_\_\_\_ **SAT** **UNSAT**

This JPM was administered for qualification?    **YES**    **NO**

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

# **Depressurize the RCS to Restore Inventory during a SGTR using Aux Spray**

Page 2 of 7

## **DIRECTIONS TO OPERATOR:**

When I tell you to begin, you are to depressurize the RCS to restore inventory during a SGTR.

Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

## **INITIATING CUES:**

1. PORV Block Valve 535 is Stop Tagged due to inoperable motor.
2. A Steam Generator Tube Rupture occurred 20 minutes ago
3. All actions of E-0 and E-3 have been completed up to and including the RCS cooldown.
4. Ruptured SG pressure has been verified increasing with adequate RCS Subcooling
5. Bus 6 is tripped on a fault at the completion of the cooldown.
6. All necessary safeguards equipment was restarted after bus fault.
7. The CRS has directed you to depressurize the RCS in accordance with E-3 commencing with step 16.



## **TASK STANDARD:**

The RCS has been depressurized to meet the requirements of E-3.

# Depressurize the RCS to Restore Inventory during a SGTR using Aux Spray

Page 3 of 7

 Denotes Critical Step

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation		
2.	Obtain Procedure	E-3	
3.	Check subcooling > 39°F	Observe Saturation Monitors Subcooling SAT	
4.	Check normal spray available	Identifies normal spray is available;	
5.	Spray Pressurizer with Maximum Spray	Identifies Spray Valve does not open Transitions to Step 18	
6.	Observe Note before Step 18	Observes the NOTE	
7.	Check at least one PORV available	Determines PORV available	
8.	Open one PORV	Determines PORV does not open	
	ESTABLISH AUX SPRAY		
9.	Maintain RCP Seal Injection 6 – 12 gpm	Observe Seal Injection flow meters	
10.	Secure all but one charging pump and reduce speed to minimum	Observes two charging pumps running; secures one pump and reduces speed to minimum	
 11.	Close charging line flow control valve HCV-142	Adjusts potentiometer to 0% output	
 12.	Close charging stop valves 204A and 205B	Place switch for 204A to Close (204B should is closed)	

# Depressurize the RCS to Restore Inventory during a SGTR using Aux Spray

Page 4 of 7

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
13.	Close the Pressurizer Spray Valves	May Place PCV-455A controller to close	
14.	Open Aux Spray Valve 212	Place switch for 212 to Open	
15.	Initiate Aux Spray by slowly opening HCV-142	Rotate potentiometer to open valve	
16.	Adjust charging pump speed to increase spray flow	Adjust potentiometer for operating charging pump	
17.	Verify Aux Spray is established and return to step 17b	Verify pressure decreasing	
18.	Secure depressurization when criteria met RCS Pressure < Ruptured SG pressure AND PRZR level > 14% OR PRZR level > 71% OR Subcooling < value in table for current RCS pressure	Close Aux Spray valve 212	
	Cue candidate that JPM is complete		

**Depressurize the RCS to Restore Inventory during a SGTR using  
Aux Spray**

Page 5 of 7

Any area of weakness observed?      YES ☐      NO ☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

\_\_\_\_\_  
Description of reviewed information:

**Depressurize the RCS to Restore Inventory during a SGTR using  
Aux Spray**  
Page 6 of 7  
**Simulator Setup**

Initialize Simulator to any 100% power IC.

MAL-RCS014A at 3.5 will cause a SGTR of approximately 200 gpm in 21 SG

Allow approximately 1 minute for alarms to annunciate. Trip the reactor and perform the actions of E-0 (including Attachment 1)

Perform actions of E-3 up to and including step 15.

After Cooldown insert Malfunction MAL EPS006F (Fault on Bus 6)

*Insert Malfunctions SWI PCS044E OFF (Blown fuse in controller for PCV-455A)*

**The above malfunction must be re-entered after each IC reset**

Insert Malfunction SWI-RCS006A CLOSE POS Pressurizer Relief Valve PCV-456 Control Switch

Place Red Hold Tag on Pressurizer Block Valve 535 in Close Pull to Lock Close position.

Freeze simulator.

Take a snapshot if JPM is to be used more than once.

# **Depressurize the RCS to Restore Inventory during a SGTR using Aux Spray**

Page 7 of 7

## **INITIATING CUES:**

1. PORV Block Valve 535 is Stop Tagged due to inoperable motor.
2. A Steam Generator Tube Rupture occurred 20 minutes ago
3. All actions of E-0 and E-3 have been completed up to and including the RCS cooldown.
4. Ruptured SG pressure has been verified increasing with adequate RCS Subcooling
5. Bus 6 is tripped on a fault at the completion of the cooldown.
6. All necessary safeguards equipment was restarted after bus fault.
7. The CRS has directed you to depressurize the RCS in accordance with E-3 commencing with step 16.

## **TASK STANDARD:**

The RCS has been depressurized to meet the requirements of E-3.

# Transfer from AFW Feed to Low Flow Bypass Valves

Page 1 of 6

## ENTERGY (IP2) JOB PERFORMANCE MEASURE

Operator Name: \_\_\_\_\_

Employee ID #: \_\_\_\_\_

Evaluator: \_\_\_\_\_

Date: \_\_\_\_\_ SAT UNSAT

This JPM was administered for qualification? YES NO

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

# **Transfer from AFW Feed to Low Flow Bypass Valves**

Page 2 of 6

## **DIRECTIONS TO OPERATOR:**

When I tell you to begin, you are to transfer feedwater from Aux Feed to the Low Flow Bypass Feed Regulating Valves.

Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

## **INITIATING CUES:**

The unit is approximately 3% power with a normal startup in progress. 21 MBFP is running. Feed flow to the SGs is being supplied by the AFW system. All chemistry parameters are in specification. The CRS is in POP-1.3 at step 4.22.4 and had directed you Transfer from AFW feed to Low Flow Bypass Feed using 2-SOP-21.1 section 4.1.9.

All requirements for entering MODE 1 have been met.

## **TASK STANDARD:**

Feed flow is being supplied by the low flow bypass valves and AFW system has been shutdown and restored to auto-standby operation.

## Transfer from AFW Feed to Low Flow Bypass Valves

Page 3 of 6

● Denotes Critical Step

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation		
2.	Obtain Procedure 2-SOP-21.1	Obtains procedure	
3.	Place HI/LO Steam Flow and Feedwater Flow Chart Scale to LO mode	Ensures switches are in LO	
4.	Adjust MBFP Speed so its discharge pressure is 50 – 100 psig LESS than SG pressure	Adjust 21 MBFP Foxboro Controller to achieve desired $\Delta P$	
●5.	Open all four feedwater bypass valves to 50%	Rotate LFBV potentiometers to 50%	
●6.	Slowly raise MBFP speed to raise discharge pressure to just above SG pressure and establish flow	Adjust 21 MBFP Foxboro controller to achieve desired $\Delta P$	
●7.	When increase in SG level or feedwater flow is observed, throttle AFW flow	Move manual switch (Left-Right) to adjust AFW flow	
8.	When all 4 Aux Feed Reg Valves are fully closed, Shutdown the AFW system  CUE: A spare operator will shutdown the AFW system	No Action necessary	
●9.	Maintain SG levels 35 – 60% using LFBV setpoint dials.	Adjust Setpoint dials as necessary	
	JPM is Complete		

## Transfer from AFW Feed to Low Flow Bypass Valves

Page 4 of 6

Any area of weakness observed?

YES ☐ NO ☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

---

Description of reviewed information:

# **Transfer from AFW Feed to Low Flow Bypass Valves**

Page 5 of 6

## **Simulator Setup**

Select IC with Power approximately 3 – 6%.

Ensure MBFP is running. Adjust discharge pressure to approximately 150 or more LESS than SG pressure. Ensure LFBVs closed and AFW supplying SGs  
Stabilize SG Level

Take a snapshot if JPM is to be used more than once.

--

**INITIATING CUES:**

The unit is approximately 3% power with a normal startup in progress. 21 MBFP is running. Feed flow to the SGs is being supplied by the AFW system. All chemistry parameters are in specification. The CRS is in POP-1.3 at step 4.22.4 and had directed you Transfer from AFW feed to Low Flow Bypass Feed using 2-SOP-21.1 section 4.1.9.

**TASK STANDARD:**

Feed flow is being supplied by the low flow bypass valves and AFW system has been shutdown and restored to auto-standby operation.

# Align Containment Spray System for Recirculation

Page 1 of 6

## ENTERGY (IP2) JOB PERFORMANCE MEASURE

Operator Name: \_\_\_\_\_

Employee ID #: \_\_\_\_\_

Evaluator: \_\_\_\_\_

Date: \_\_\_\_\_ SAT UNSAT

This JPM was administered for qualification? YES NO

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

# **Align Containment Spray System for Recirculation**

Page 2 of 6

## **DIRECTIONS TO OPERATOR:**

When I tell you to begin, you are to Align Containment Spray for Recirculation Beginning at step 21 of 2-ES-1.3

Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

## **INITIATING CUES:**

1. A large break LOCA has occurred.
2. Safety Injection and Containment Spray have been RESET in accordance with E-1, Loss of Reactor or Secondary coolant.
3. The RWST level has decreased to 2 feet and the CRS has directed you to transfer to Containment Spray recirculation in accordance with ES-1.3
4. All steps up through and including step 18 of E-1 have been completed.
5. The Service Water System is aligned for two header operation.
6. You are directed to align Containment Spray for Recirculation Spray Flow

## **TASK STANDARD:**

Containment Spray is aligned for Recirculation.

# Align Containment Spray System for Recirculation

Page 3 of 6



Denotes Critical Step

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation		
2.	Obtain Procedure	2-ES-1.3	
3.	Check any Containment Spray pumps running	Observe 22 Spray Pump Running	
4.	Check RWST level LESS THAN 2 feet	Observe RWST level approximately 2 feet	
● 5.	Stop Containment Spray Pumps	Place control switch to stop	
● 6.	Close Containment Spray Pump Discharge Valves	Place Switches for MOV 866A-D in close	
7.	Determine 21 RHR Heat Exchanger is in service	Observes valve alignment for 21 RHR HX	
● 8.	Open Spray Header Valve for In Service RHR heat exchanger	Place switch for 899B to Open	
9.	Check Minimum Flow to core and containment spray	Observe indicators 946A-D	
	Candidate observes indicator 946D is reading 0 and uses Right Column and 2 <sup>nd</sup> row.	Use table in ES-1.3 to verify adequate core flow	
	Check Minimum Spray flow > 960 gpm	Candidate observes recirc spray flow approximately 1800 gpm	
	JPM is complete		

# Align Containment Spray System for Recirculation

Page 4 of 6

Any area of weakness observed?

YES ☐ NO ☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

\_\_\_\_\_  
Description of reviewed information:

# **Align Containment Spray System for Recirculation**

Page 5 of 6

## **Simulator Setup**

Initialize to any 100% power IC.

Insert Malfunction MAL-RCS005A (B, C, or D)

Insert Override IND-RHR004 FI-946D Meter Signal Loop 1 "0 gpm"

Perform actions of E-0 up to step 15 including Attachment 1.

Perform actions of E-1 up to step 18.

Perform actions of ES-1.3 up to and including step 20.

Take a snapshot if JPM is to be used more than once.

--

**INITIATING CUES:**

6. A large break LOCA has occurred.
7. Safety Injection and Containment Spray have been RESET in accordance with E-1, Loss of Reactor or Secondary coolant.
8. The RWST level has decreased to 2 feet and the CRS has directed you to transfer to Containment Spray recirculation in accordance with ES-1.3
9. All steps up through and including step 18 of E-1 have been completed.
10. The Service Water System is aligned for two header operation.

**TASK STANDARD:**

Containment Spray is aligned for Recirculation.

# Restore Power to Bus 2A using 22 EDG

Page 1 of 7

## ENTERGY (IP2) JOB PERFORMANCE MEASURE

*NO only*

Operator Name: \_\_\_\_\_

Employee ID #: \_\_\_\_\_

Evaluator: \_\_\_\_\_

Date: \_\_\_\_\_ SAT UNSAT

This JPM was administered for qualification? YES NO

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

## Restore Power to Bus 2A using 22 EDG

Page 2 of 7

### DIRECTIONS TO OPERATOR:

When I tell you to begin, you are to restore power to bus 2A using 22 EDG

Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

### INITIATING CUES:

The plant is operating at 100% power.

Bus 2A normal feed breaker tripped open on overcurrent.

All actions of 2-AOP-480V-1, Loss of Normal Power to Any 480V bus have been completed up to Attachment 2 step 2.1.

The CRS has directed you to restore power to bus 2A using 2-AOP-480V-1 Attachment 2.

### TASK STANDARD:

Bus 2A is Re-energized from 22 EDG.

*Initiating Cue:*

# Restore Power to Bus 2A using 22 EDG

Page 3 of 7

Denotes Critical Step

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to BEGIN after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation. Time Commenced: _____		
2.	Obtain procedure	AOP-480V-1	
3.	Is bus 2A energized by 22 EDG	Determines bus 2A is not energized	
4.	Is 22 EDG running YES	Observes EDGs all running	
5.	Is white supervisory light for relay 86/2A extinguished	Determines light is extinguished	
6.	Dispatch an operator to open breakers for: MCC21 MCC23 MCC24/24A MCC28 MCC210 and Perform visual inspection of 2A CUE: Inform candidate that all breakers are opened	Contacts NPO and directs opening breakers	
7.	Place control switches for 480V bus 2A in TPO 22 SIP 23 FCU 22 CCW Pump 22 SW Pump 25 SW Pump 22 BU Heaters	Places all control switches in TPO	
	CUE: NPO reports visual inspection of bus 2A reveal no observable damage and no smoke or unusual smell.		

*TPO spell out ?  
Trip Position ?*

*goes with Step  
#8 move*

## Restore Power to Bus 2A using 22 EDG

Page 4 of 7

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
8.	Is there any other indication of damage on bus 2A?	Determines no other damage to bus 2A	
9.	Green flag BKR 52 EG-2A Note: Breaker will be green flagged	Observes breaker switch green flagged	
10.	Green flag breaker 52-2A	Places BKR control switch to trip and back to auto	
11.	Reset 480V Bus 2A lockout relay	Depress reset pushbutton observe white supervisory light for relay 86/2A illuminated	
12.	Place 480V bus 2A BKR EDG-2A in close and release	Switch in close and released to auto	
13.	Is bus 2A energized Yes	Observes bus 2A is energized	
	JPM is Complete		

## Restore Power to Bus 2A using 22 EDG

Page 5 of 7

Any area of weakness observed?

YES

☐

NO

☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

\_\_\_\_\_  
Description of reviewed information:

## **Restore Power to Bus 2A using 22 EDG**

Page 6 of 7

### **Simulator Setup**

Insert malfunction EPS007A 480V Bus 2A Fault.

Run Simulator.

Perform actions in 2-AOP-480V-1 up to step 2.1 of Attachment 2.

### **Remove Malfunction EPS007A 480V Bus 2A Fault.**

Take a snapshot if JPM is to be used more than once.

--

*al Conditions*  
**INITIATING CUES:**

The plant is operating at 100% power.

Bus 2A normal feed breaker tripped open on overcurrent.

All actions of 2-AOP-480V-1, Loss of Normal Power to Any 480V bus have been completed up to Attachment 2 step 2.1.

The CRS has directed you to restore power to bus 2A using 2-AOP-480V-1 Attachment 2.

**TASK STANDARD:**

Bus 2A is Re-energized from 22 EDG.

*Inserting Cue ?*

**Perform the Required Actions for #23 S/G Steam Pressure  
Channel (439B) Failing Low (Alternate Path)**

Page 1 of 8

**ENTERGY (IP2)  
JOB PERFORMANCE MEASURE**

**Operator Name:** \_\_\_\_\_

**Employee ID #:** \_\_\_\_\_

**Evaluator:** \_\_\_\_\_

**Date:** \_\_\_\_\_ **SAT** **UNSAT**

This JPM was administered for qualification? **YES** **NO**

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

# **Perform the Required Actions for #23 S/G Steam Pressure Channel (439B) Failing Low (Alternate Path)**

Page 2 of 8

## **DIRECTIONS TO OPERATOR:**

When I tell you to begin, you are to take the appropriate actions to stabilize the plant in response to indications and annunciators.

I will describe the general system conditions. Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

## **INITIATING CUES:**

1. Reactor at indicated power.
2. Steady State, equilibrium Xenon.
3. No equipment out of service.

## **TASK STANDARD:**


Plant stabilized with appropriate failed equipment removed from service per the applicable procedure.

# **Perform the Required Actions for #23 S/G Steam Pressure Channel (439B) Failing Low (Alternate Path)**

Page 3 of 8



**Denotes Critical Step**

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	<p><b>NOTE:</b> Take simulator out of Freeze, initiate malfunction at direction of evaluator.</p>		
	<p><b>CUE:</b> Evaluator, inform operator as the CRS to implement immediate actions of 2-AOP-INST-1, Instrument/Controller Failures</p>		
<p> 1.</p>	<p>Operator takes Immediate Actions from memory</p> <p><b>NOTE:</b> Immediate actions of 2-AOP-INST-1</p> <p><b>NOTE:</b> Placing Steam Flow selector switch to operable channel WILL NOT transfer control. Operator must take manually control of Feed Reg Valve and control SG Level. Manual control of SG level is Critical.</p> <p><b>CUE:</b> Following Operator's implementation of Immediate Actions, as CRS, inform operator that an instrument failure has occurred and to implement 2-AOP-INST-1.</p> <p><b>NOTE:</b> Candidate may take MBFP Speed control to manual due to failure of steam flow to transfer.</p>	<ol style="list-style-type: none"> <li>1. Checks parameters listed and determines that 23 S/G Pressure Channel (439B) is failed low.</li> <li>2. Verify 23 S/G level control is affected</li> <li>3. Select both SG transfer switches to non-affected channel</li> <li>4. Take manual control of 23 Feed Reg Valve to control parameters and stabilize the plant.</li> <li>5. Assures all control systems listed in step 3.1 are checked.</li> </ol>	


# **Perform the Required Actions for #23 S/G Steam Pressure Channel (439B) Failing Low (Alternate Path)**

Page 4 of 8

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
2.	Operator determines that an instrument failure has occurred	Operator identifies 23 S/G Steam Pressure Channel (439B)	
3.	Using table in 2-AOP-INST-1, operator transitions to the procedure step for Steam Pressure.	Operator identifies and transitions to procedure step for failed Steam Pressure Channel.	
4.	Check status of Channel C instrument.	Verify 23 Steam Pressure Channel C has not failed and transitions to step 4.47	
5.	Refer to appropriate Tech Spec as described in the AOP.  <b>CUE:</b> Inform operator as CRS that the proper Tech Spec Tables have been referred to.	N/A	
NOTE	Review notes prior to step 4.48	Notes reviewed	
6.	Verify placing Steam Line Pressure Comparison Bistable Trip Switches for the failed channel in trip will not cause a safety injection and trip the appropriate Bistable Trip Switches for the failed channel.  <b>CUE:</b> Inform operator as CRS that ALL bistables associated with failed channel are to be tripped. A spare operator will maintain SG levels.	IAW Attachment 3 of 2-AOP-INST-1, Loop 1B Steam Line Comparison, $P3 < P1$ and $P1 < P3$ , in White rack A-11 are placed in trip position.	

# **Perform the Required Actions for #23 S/G Steam Pressure Channel (439B) Failing Low (Alternate Path)**

Page 5 of 8

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
NOTE	Review notes prior to step 4.49	Notes reviewed	
	<p>Verify placing Steam Flow Mismatch Bistable Trip Switch for the failed channel in trip will not cause a Rx Trip or Safety Injection and trip the appropriate Steam Flow Mismatch Bistable Trip Switch for the failed channel.</p> <p><b>CUE:</b> Inform operator as CRS that ALL bistables associated with failed channel are to be tripped. A spare operator will maintain SG levels.</p>	IAW Attachment 4 of 2-AOP-INST-1, Loop 3B SF>FWF in White rack A-11 is placed in trip position.	
8.	<p>Return controls used to stabilize the plant to desired position</p> <p><b>CUE:</b></p> <p>If required, inform operator that failed channel will not be repaired at this time.</p>	Determine that 23 Feed Reg Valve should remain in Manual	

**Perform the Required Actions for #23 S/G Steam Pressure  
Channel (439B) Failing Low (Alternate Path)**

Page 6 of 8

Any area of weakness observed?

YES ☐ NO ☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

---

Description of reviewed information:

**Perform the Required Actions for #23 S/G Steam Pressure  
Channel (439B) Failing Low (Alternate Path)**

Page 7 of 8

**SIMULATOR SET-UP**

**Any 100% Power IC**

**Insert Malfunction/Override**

**SWI-PCS077 B position Steam Flow Transfer Switch  
(failure to transfer)**

**Ensure 23 SG Steam Flow Channel B in Control**

**23 Steam Pressure Channel B Fails Low**

**Insert Malfunction:**

**XMT-SGN042A FIXED OUTPUT:  
PT-439B S/G 23 PRESSURE CH 2  
SEVERITY 0**

**Take Snapshot if JPM is to be used more than once.**

**INITIATING CUES:**

1. Reactor at indicated power.
2. Steady State, equilibrium Xenon.
3. No equipment out of service.

**TASK STANDARD:**

Plant stabilized with appropriate failed equipment removed from service per the applicable procedure.

**RETURN THIS TO INSTRUCTOR WHEN YOU HAVE COMPLETED**

## Change Radiation Monitor 44 Setpoint

Page 1 of 7

### ENTERGY (IP2) JOB PERFORMANCE MEASURE

Operator Name: \_\_\_\_\_

Employee ID #: \_\_\_\_\_

Evaluator: \_\_\_\_\_

Date: \_\_\_\_\_ SAT UNSAT

This JPM was administered for qualification? YES NO

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

## **Change Radiation Monitor 44 Setpoint**

Page 2 of 7

### **DIRECTIONS TO OPERATOR:**

When I tell you to begin, you are to adjust the alarm setpoint for radiation monitor 44 in preparation for LGDT release

Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

### **INITIATING CUES:**

1. Preparations are being made to release 23 LGDT.
2. The release permit has been prepared and requires R-44 alarm setpoint to be set at  $9.00 \times 10^{-3} \mu\text{Ci/cc}$
3. The CRS has directed you to reset R-44 Actual Alarm setpoint to  $9.00 \times 10^{-3} \mu\text{Ci/cc}$  in accordance with 2-SOP-12.3.2, Digital Radiation Monitor System Operation (Local or SRD)

### **TASK STANDARD:**



R-44 Alarm setpoint changed.

# Change Radiation Monitor 44 Setpoint

Page 3 of 7



Denotes Critical Step

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation <b>Time Commenced:</b> _____		
2.	Obtain correct procedure	Obtains 2-SOP-12.3.2	
3.	Review Precautions and Limitations	P&Ls reviewed	
 4.	Prepare SRD for data entry	Verifies remote light is lit at SRD Set Program mode key switch to ENTER DATA	
5.	Observe NOTE before step 4.9.1.2	Observes Note	
6.	Display the current setpoint: Press "CH" key Enter Channel Number "4" Press "FUNC" key Enter "0" Press "DISP" key	CH key depressed "4" entered for Channel Number FUNC key depressed "0" entered DISP key depressed	
7.	Observe Note before step 4.9.1.3	Observes Note	
 8.	Enter New Setpoint Press "CH" key Enter Channel Number "4" Press "FUNC" key Enter "0" Press "DATA" key Enter new value (three digits) without decimal point "900" Press the "EXP" key Press "DISP OP" key Enter exponent (two digits) "03" Press "ENTER" key	CH key depressed "4" entered for Channel Number FUNC key depressed "0" entered DATA key depressed 900 entered for setpoint EXP key depressed DISP OP key depressed "03" Exponent	

## Change Radiation Monitor 44 Setpoint

Page 4 of 7

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
		entered ENTER key depressed	
9.	Set program mode key switch to RUN position CUE: NPO reports all remaining local actions complete	Key switch to RUN	
10.	Inform CRS that R-44 Setpoint has been set to $9.00 \times 10^{-3} \mu\text{Ci/cc}$ CUE: CRS Acknowledges		
	JPM is Complete		

## Change Radiation Monitor 44 Setpoint

Page 5 of 7

Any area of weakness observed?

YES

☐

NO

☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

\_\_\_\_\_  
Description of reviewed information:

## Change Radiation Monitor 44 Setpoint

Page 6 of 7

### SIMULATOR SETUP

Reset Simulator to any At Power IC

Ensure R-44 Setpoint is not  $9.00 \times 10^{-3} \mu\text{Ci/cc}$

--

**INITIATING CUES:**

1. Preparations are being made to release 23 LGDT.
2. The release permit has been prepared and requires R-44 alarm setpoint to be set at  $9.00 \times 10^{-3} \mu\text{Ci/cc}$
3. The CRS has directed you to reset R-44 Actual Alarm setpoint to  $9.00 \times 10^{-3} \mu\text{Ci/cc}$  in accordance with 2-SOP-12.3.2, Digital Radiation Monitor System Operation (Local or SRD)

**TASK STANDARD:**

R-44 Alarm setpoint changed.

**Perform the Required Actions to Dump Steam Locally Using the  
Atmospheric Steam Dump Valve for 21 S/G (PCV-1134)**

Page 1 of 6

**ENTERGY (IP2)  
JOB PERFORMANCE MEASURE**

**Operator Name:** \_\_\_\_\_

**Employee ID #:** \_\_\_\_\_

**Evaluator:** \_\_\_\_\_

**Date:** \_\_\_\_\_ **SAT** **UNSAT**

This JPM was administered for qualification? **YES** **NO**

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

# **Perform the Required Actions to Dump Steam Locally Using the Atmospheric Steam Dump Valve for 21 S/G (PCV-1134)**

Page 2 of 6

## **DIRECTIONS TO OPERATOR:**

When I tell you to begin, you are to *simulate* locally dumping steam from 21 Steam Generator using the Atmospheric Steam Dump Valve

I will describe the general system conditions. Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

## **INITIATING CUES:**

1. The CCR has been evacuated due to a fire and AOP-SSD-1, Control Room Inaccessibility Safe Shutdown Control, has been implemented.
2. The CRS has directed you to align the 21 Steam Generator Atmospheric Dump Valves PCV-1134 for local operation per 2-AOP-SSD-1, Attachment 3, commencing with step 3.8.
3. When directed by the CRS, you are to commence dumping steam from the Steam Generator using its atmospheric steam dump valve locally
4. Radio communications have been established.




## **TASK STANDARD:**

Instrument Air isolated and Atmos Steam Dump Valve throttled open

# **Perform the Required Actions to Dump Steam Locally Using the Atmospheric Steam Dump Valve for 21 S/G (PCV-1134)**

Page 3 of 6

 **Denotes Critical Step**

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	NOTE: Remind operator to NOT change any switch or valve positions		
1	Obtains correct procedure and step	2-AOP-SSD-1, Attachment 3, Step 3.8	
2	Review Note prior to step 3.8	Note Reviewed	
 3	Close the normal Instrument Air supply stop from the positioner to the diaphragm, Valve F (V-1)  <b>CUE:</b> After valve is located and simulated movement, cue that valve is CLOSED	Locates and indicates proper direction to CLOSE IA-1202 for PCV-1134	
4	Ensure the N2 pressure regulating valve H is backed out  <b>CUE:</b> After valve is located and simulated movement, cue that valve is backed out	Locates and indicates proper direction to CLOSE PRV-5608 for PCV-1134	
 5	OPEN SGN-500 the N2 Inlet Stop valve C (V-4)  <b>CUE:</b> After valve is located and simulated movement, cue that valve is OPEN	Locates and indicates proper direction to OPEN SGN-500 for PCV-1134	
 6	OPEN SGN-508 the N2 to the Diaphragm Stop valve D (V-2)  <b>CUE:</b> After valve is located and simulated movement, cue that valve is OPENING	Locates valve and indicates proper direction to OPEN SGN-508 for PCV-1134	
7	CLOSE IA-1008 the vent valve E (V-3)  <b>CUE:</b> After valve is located and simulated movement, cue that valve is CLOSED	Locates valve and indicates proper direction to CLOSE IA-1008 for PCV-1134	

# **Perform the Required Actions to Dump Steam Locally Using the Atmospheric Steam Dump Valve for 21 S/G (PCV-1134)**

Page 4 of 6

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	<b>CUE:</b> Inform operator, when each step ( 3.9, 3.10,& 3.11) is addressed for alignment, that 22, 23 and 24 SG Atmospheric Steam Dump Valves are aligned for steaming and operators are standing by at each of those stations for operation of those valves	Student advances to step 3.12	
8	Notify CRS and operator at ABFPs that Atmos Steam Dumps are manned and ready for steaming  <b>CUE:</b> Acknowledge as CRS and ABFP operator	Inform CRS and ABFP operator that Atmos Stm dumps are manned and ready	
	<b>CUE:</b> Inform operator to commence steaming 21 SG per step 3.13		
9	Throttle OPEN PRV-5608 Nitrogen Regulator valve H  <b>NOTE:</b> Only provide the following cue if the above critical steps have been perform correctly.  <b>CUE:</b> After indicator and valve is located and proper movement simulated, cue that steam can be heard from Atmos Dump  <b>NOTE:</b> Only throttling of PRV-5608 is critical	Locates indicator and valve and indicates proper movement to throttle OPEN PRV-5608 for PCV-1134	

**Perform the Required Actions to Dump Steam Locally Using the  
Atmospheric Steam Dump Valve for 21 S/G (PCV-1134)**

Page 5 of 6

Any area of weakness observed? YES ☐ NO ☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

\_\_\_\_\_  
Description of reviewed information:

# **Perform the Required Actions to Dump Steam Locally Using the Atmospheric Steam Dump Valve for 21 S/G (PCV-1134)**

Page 6 of 6

## **INITIATING CUES:**

3. The CCR has been evacuated due to a fire and AOP-SSD-1, Control Room Inaccessibility Safe Shutdown Control, has been implemented.
4. The CRS has directed you to align the 21 Steam Generator Atmospheric Dump Valves PCV-1134 for local operation per 2-AOP-SSD-1, Attachment 3, commencing with step 3.8.
3. When directed by the CRS, you are to commence dumping steam from the Steam Generator using its atmospheric steam dump valve locally
4. Radio communications have been established.

## **TASK STANDARD:**

Instrument Air isolated and Atmos Steam Dump Valve throttled open.

**RETURN THIS TO INSTRUCTOR WHEN YOU HAVE COMPLETED**

# **Perform a Startup of the Unit 2 Appendix R Diesel Generator - Supplying Appendix R Loads**

Page 1 of 7

## **ENTERGY (IP2) JOB PERFORMANCE MEASURE**

**Operator Name:** \_\_\_\_\_

**Employee ID #:** \_\_\_\_\_

**Evaluator:** \_\_\_\_\_

**Date:** \_\_\_\_\_ **SAT** **UNSAT**

This JPM was administered for qualification? **YES** **NO**

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

# Perform a Startup of the Unit 2 Appendix R Diesel Generator - Supplying Appendix R Loads

Page 2 of 7

## DIRECTIONS TO OPERATOR:

When I tell you to begin, you are to perform a startup of the Unit 2 Appendix R Diesel Generator supplying Unit 2 Appendix R loads.

Before you start, I will state the ~~Task Standard~~ *Initial Conditions* and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

*Initial Conditions:*  
**INITIATING CUES:**

1. CCR has been evacuated due to a fire.
2. Normal Unit 2 Offsite power and EDGs are unavailable.
3. The 480V Switchgear room is inaccessible.
- Initiating Cue:*  
4. You are directed to Start the Unit 2 Appendix R Diesel Generator Supplying Appendix R Loads in accordance with 2-SOP-27.6 up to and including closing the SBO/ASS breaker.

## TASK STANDARD:

The Appendix R Diesel Generator is running and breaker SBO/ASS is closed.

# **Perform a Startup of the Unit 2 Appendix R Diesel Generator - Supplying Appendix R Loads**

Page 3 of 7



**Denotes Critical Step**

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
	Inform operator to <b>BEGIN</b> after his completion of review of the Initiating Cues and log time below		
1.	Commence evaluation		
2.	Obtain Correct Procedure and section	2-SOP-27.6 section 4.3	
3.	Observe NOTES before step 4.3.1	Reviews Notes	
4.	Initiate having District Operator Open Breaker F3-1 CUE: Breaker is Open	Simulates radio contact with SM	
5.	Request Unit 3 CCR to Open 52GT/2F CUE: 52GT/2F is Open	Simulates radio contact with Unit 3 CCR	
6.	Observe NOTES before step 4.3.3	Reviews Notes	
7.	Verify Delay Gate is closed	Verifies Gate Closed	
8.	Verify at least one of the following is open: Maintenance Loading Bay overhead door Tool Room Roll-up door	Observes Doors Open	
9.	Initiate Opening the 3 damper set directly west of Appendix R DG	Rotate the handwheel on the west wall	
10.	Verify the Appendix R diesel Generator Fuel Oil Day Tank indications are illuminated: System Ready Yellow LED Flashing Power Available Green LED Illuminated CUE Yellow LED is Flashing and Green LED is illuminated	Observes Yellow LED flashing and green LED illuminated	
11.	Check NO abnormal conditions exist as indicated by a LED flashin ON state and horn sounding. CUE NO LED is flashing and horn is silent	Observes App. R Day Tank Control Panel	

# **Perform a Startup of the Unit 2 Appendix R Diesel Generator - Supplying Appendix R Loads**

Page 4 of 7

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
12.	Verify breaker SBOH is Open	Observes breaker is open	
13.	Verify breaker SBO/ASS is Open	Observes Breaker is Open	
14.	Close Breaker ASS	Depress button on APP R Diesel Control Panel	
15.	Place Unit-Parallel switch to UNIT	Places switch to UNIT	
16.	Verify: Shutdown Status Indicator – Extinguished Warning Status Indicator - Extinguished	Observes indicators extinguished at Control Panel	
17.	If City Water will be the cooling source (YES)	See below	
	Open UW-854, Backflow preventor inlet isolation	Simulates Opening Valve	
	Open UW-855, Backflow Preventor Outlet Isolation	Simulates Opening Valve	
	Observe NOTE before step 4.3.11.2	Reviews NOTE	
	Throttle UW-840 to achieve 87 gpm on FI-7980 CUE: After candidate locates valve and indicator, state flow is 87 gpm.	Simulate throttling open valve and observes indicator	
	Throttle UW-836 to achieve approximately 118 gpm as indicated by FI-7979, Jacket Water Flow	Simulate throttling open valve and observes indicator	
18.	IF Conventional Service Water is available CUE: Conventional Service Water is NOT available	No Action Required	
19.	Verify the following breakers open: F3-1 52GT/2F SB1-3 CUE: All Breakers are OPEN	No Action Required	

# **Perform a Startup of the Unit 2 Appendix R Diesel Generator - Supplying Appendix R Loads**

Page 5 of 7

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
20.	Observe NOTE before step 4.3.14	Reviews Note	
21.	Verify GT-2 is Out of Service CUE: GT-2 is out of service	No Action Required	
22.	Verify breaker B3-3 is closed	Observes Breaker Closed	
23.	Verify 3 damper set west of App R diesel are open. CUE: Dampers are open	Observes Damper position	
24.	Observe NOTES before step 4.3.17	Reviews NOTES	
25.	Turn O/Manual/Auto switch to MANUAL	Simulate rotating switch to MANUAL	
26.	Press and Hold the Manual Run/Stop Button for a minimum of 3 seconds CUE: Diesel Engine starts	Simulates Pressing button	
27.	Observe NOTES before step 4.3.19	Reviews NOTES	
28.	Close breaker SBO/ASS CUE: symbol indicates _- _	Press and Hold _\_ pushbutton until symbol indicates _- _	
29.	JPM is complete		

**Perform a Startup of the Unit 2 Appendix R Diesel Generator -  
Supplying Appendix R Loads**

Page 6 of 7

Any area of weakness observed? YES ☐ NO ☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness  
discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

\_\_\_\_\_  
Description of reviewed information:

# Perform a Startup of the Unit 2 Appendix R Diesel Generator - Supplying Appendix R Loads

Page 7 of 7

--

*AD. Centitors*  
**INITIATING CUES:**

1. CCR has been evacuated due to a fire.
2. Normal Unit 2 Offsite power and EDGs are unavailable.
3. The 480V Switchgear room is inaccessible.
4. You are directed to Start the Unit 2 Appendix R Diesel Generator Supplying Appendix R Loads in accordance with 2-SOP-27.6 up to and including closing the SBO/ASS breaker.

**TASK STANDARD:**

The Appendix R Diesel Generator is running and breaker SBO/ASS is closed.

*Initiating Cue:*

# Perform the Required Actions to Establish Backup Cooling to the Charging Pumps

Page 1 of 5

## ENTERGY (IP2) JOB PERFORMANCE MEASURE

Operator Name: \_\_\_\_\_

Employee ID #: \_\_\_\_\_

Evaluator: \_\_\_\_\_

Date: \_\_\_\_\_ SAT UNSAT

This JPM was administered for qualification? YES NO

The Training Department developed this material for the Entergy training programs. Text materials and figures contained in this document are developed for the purpose of instruction and should not be used in connection with either plant maintenance or plant operation. This material may not be reproduced without the authorization of the Manager, Nuclear Training.

# **Perform the Required Actions to Establish Backup Cooling to the Charging Pumps**

Page 2 of 5

## **DIRECTIONS TO OPERATOR:**

When I tell you to begin, you are to *simulate* establish backup cooling to the Charging Pumps

I will describe the general system conditions. Before you start, I will state the Task Standard and Initiating Cues, and answer any questions. Utilize all reference material appropriate for this task.

## **INITIATING CUES:**

1. The CCR has been evacuated due to a fire and 2-AOP-SSD-1, Control Room Inaccessibility Safe Shutdown Control, has been implemented.
2. CCW cooling to the Charging pumps is not available.
3. The CRS has directed you to establish backup cooling to the Charging Pumps per 2-AOP-SSD-1, Attachment 10.








## **TASK STANDARD:**

Backup cooling has been established to the Charging Pumps.

# **Perform the Required Actions to Establish Backup Cooling to the Charging Pumps**

Page 3 of 5

 **Denotes Critical Step**

STEP	DESCRIPTIONS / CUES & NOTES	STANDARD	S/U
1	Obtain correct procedure	2-AOP-SSD-1, Attachment 10, Step 10.1	
10.1	Connect hose to Charging Pumps City Water Backup Header Stop, route hose to drainage  <b>CUE:</b> Hose connected	Locate hose and 1873D connection and simulate routing hose to suitable drainage	
 10.2	Close Charging Pumps City Water Backup Telltale Stop  <b>CUE:</b> Valve Closed	1874 to Clockwise direction	
 10.3	Close Charging Pumps Oil and Fluid Drive Heat Exchanger Outlet Stop	756B to Clockwise direction	
 10.4	Close Charging Pumps Oil and Fluid Drive Coolers Inlet Stop  <b>CUE:</b> Valve Closed	756A to Clockwise direction	
 10.5	Open Charging Pumps City Water Backup Outlet Header Stop  <b>CUE:</b> Valve Open	1873C to counter-clockwise direction	
 10.6	Open Charging Pumps City Water Backup Outlet Header Stop  <b>CUE:</b> Valve Open	1873D to counter-clockwise direction	
 10.7	Open charging Pumps City Water Inlet Header Stops  <b>CUE:</b> Valve Open	1873A to the counter-clockwise direction	
 10.8	Open charging Pumps City Water Inlet Header Stops  <b>CUE:</b> Valve Open	1873B to the counter-clockwise direction	

# Perform the Required Actions to Establish Backup Cooling to the Charging Pumps

Page 4 of 5

Any area of weakness observed? YES ☐ NO ☐

\_\_\_\_\_  
Examinee Signature

All areas of observed weakness discussed

\_\_\_\_\_  
Evaluator Initials

Description of problem area:

\_\_\_\_\_  
Description of reviewed information:

# **Perform the Required Actions to Establish Backup Cooling to the Charging Pumps**

Page 5 of 5

## **INITIATING CUES**

1. The CCR has been evacuated due to a fire and 2-AOP-SSD-1, Control Room Inaccessibility Safe Shutdown Control, has been implemented.
2. CCW cooling to the Charging pumps is not available.
3. The CRS has directed you to establish backup cooling to the Charging Pumps per 2-AOP-SSD-1, Attachment 10.

## **TASK STANDARD:**

Backup cooling has been established to the Charging Pumps.

**RETURN THIS TO INSTRUCTOR WHEN YOU HAVE COMPLETED**

Control Room Inaccessibility  
Safe Shutdown Control  
Attachment 10  
Backup Cooling Water Supply to  
Charging Pumps  
Page 1 of 1

2-AOP-SSD-1 Rev. 16

Page 221 of 327

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p style="text-align: center;"><b>NOTE</b></p> <ul style="list-style-type: none"> <li>• The hose to connect valve 1873D to floor drain is staged outside 22CHP cell.</li> <li>• Valves 756A&amp;B and 1873A-D are located in overhead pipe chase outside 22CHP cell. A ladder to access overhead is staged adjacent to local control panel between 22CHP and 23CHP cells.</li> </ul>	
10.1 __ Connect hose to 1873D (CHARGING PUMPS CITY WATER BACKUP OUTLET HEADER STOP) and route to <u>any</u> drain.	
10.2 __ Close 1874 (CHARGING PUMPS CITY WATER BACKUP TELLTALE STOP).	
10.3 __ Close 756B (CHARGING PUMPS OIL AND FLUID DRIVE COOLERS OUTLET STOP).	
10.4 __ Close 756A (CHARGING PUMPS OIL AND FLUID DRIVE COOLERS INLET STOP).	
10.5 __ Open 1873C (CHARGING PUMPS CITY WATER BACKUP OUTLET HEADER STOP).	
10.6 __ Open 1873D (CHARGING PUMPS CITY WATER BACKUP OUTLET HEADER STOP).	
10.7 __ Open 1873A (CHARGING PUMPS CITY WATER BACKUP INLET HEADER STOP).	
10.8 __ Open 1873B (CHARGING PUMPS CITY WATER BACKUP INLET HEADER STOP).	
10.9 __ EXIT this attachment.	

... END ...

Facility: Indian Point 2 Scenario No.: 1

Op-Test No.: 1

Examiners: \_\_\_\_\_ Operators: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Initial Conditions:**

Reset simulator to IC-118 Load Simulator Schedule-Scenario1

The Plant is in a 100% normal full power lineup.

PORV PCV-456 and associated block valve are tagged out due to PCV-456 blowing fuses.

**Turnover:**

Maintain 100% Power

**Critical Tasks:**

1. Establish greater than 400 gpm AFW flow to the SGs before transition out of E-0 or tripping the RCPs in the FR-H.1. (E-0--F)
2. Isolate Feedwater flow to and steam flow from the ruptured SG before transition to ECA-3.1 occurs. (E-3--A)
3. Establish/Maintain RCS temperature to ensure transition out of E-3 does not occur due to either of the following:
  - RCS temperature too high to maintain required subcooling
  - RCS temperature too low resulting in severe challenge to the subcriticality or integrity CSF. (E-3--B)
4. When SI termination criteria are met, stop SI pumps before completion of ECA-3.3 step 9. (ECA-3.3--A)

Event No.	Mal. No.	Event Type*	Event Description
1	CNH-PCS008D	C(ATC) C(CRS)	23 MFRV fails closed in auto with manual available ramped over 10 minutes.
2	XMT-CVC019 A	I(ALL)	VCT level instrument fails low causing automatic makeup and charging pump suction to swap to the RWST.
3	MAL-RCS014 C	R(ATC) N(CRS) N(BOP)	SGTL on 23 SG 900 gpd. This will require a downpower and eventual shutdown. <i>Tech Spec action for CRS S/D plus TS for failure of B/D isol valve</i>
4	MAL-RCS014 C	M(ALL)	SGTR on 23 SG grows to 280 gpm. This will lead to team performing a manual reactor trip and SI.
5	MAL-EPS007D	C(CRS)	Fault on 480 V Bus 6A during the SI loading sequence. This will require tripping RCPs.
6	MOC-AFW001	C(CRS) C(BOP)	21 AFW pump will not auto start (inserted at setup). This along with loss of 6A will result in inadequate heat sink until addressed by team.

\* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

## **Session Outline:**

The evaluation begins with the plant at 100% power steady state operation.

Shortly after the team takes the watch, 23 MFRV will slowly fail closed. The team should recognize the failure and the ATC should transfer control of the valve to manual per administrative guidance of EN-OP-115, Conduct of Operations. The team will enter 2-AOP-FW-1, Loss of Main Feedwater, but no equipment manipulations will be required since 23 MFRV was already placed in manual.

While the team is progressing through 2-AOP-FW-1 (or after exit), VCT level instrument LC-112 will fail low. This will cause an automatic makeup and charging pump suction to swap to the RWST. The team will respond per 2-AOP-CVCS-1, CVCS Malfunctions.

After the team has stabilized charging pump suction, a 900 gpd steam generator tube leak will develop on 23 SG. The team will implement 2-AOP-SG-1, Steam Generator Tube Leak, and begin a shutdown. SGBD Valve 1216 will not close automatically and will only close if failed in the field.

While progressing with the shutdown, the tube leakage in 23 SG will increase to 280 gpm. The team will diagnose the increase in leak rate and trip the reactor and actuate SI. The manual reactor trip pushbutton on the flight panel will not work, however the supervisory panel button will function. When SI is actuated, 480V Bus 6A will fault, which will lead to the SI Blackout logic being made up causing all CCW Pumps to be off.

Following the reactor trip and SI, the team will have to establish AFW flow because 23 AFW Pump does not have power and 21 AFW Pump will not auto start (malfunction). 22 AFW pump must be placed in service to feed 23 and 24 SGs. 21 AFW may be manually started to feed 21 and 22 SGs or 22 AFW pump may be used to feed all four SGs. The team will progress through E-0, Reactor Trip or Safety Injection and transition to E-3, Steam Generator Tube Rupture. 23 SG will be isolated and the team will cool down the RCS in preparation to depressurize. The team will be unable to depressurize the RCS using E-3. Normal spray cannot be used because no RCPs are in service. Auxiliary spray will not be available because instrument air to containment will not be available (PCV-1228 will not open). Neither PORV will be available; one is tagged out, and the other's closed block valve does not have power. The team will transition to 2-ECA-3.3, SGTR without Pressurizer Pressure Control.

The scenario will be terminated when SI pumps have been stopped after RCS depressurization in ECA-3.3.

Procedural flow path: 2-AOP-FW-1, 2-AOP-CVCS-1, 2-AOP-SG-1, (2-POP-2.1, 2-AOP-RSD-1, or 2-AOP-RLR-1), E-0, E-3, ECA-3.3

## Scenario Critical Task and Malfunction Analyses

### Critical Tasks:

#### CT-1

Establish greater than 400 gpm AFW flow to the SGs before transition out of E-0 or tripping the RCPs in the FR-H.1.

**Safety Significance:** Failure to establish AFW flow will lead to going to FR-H.1 would lead to bleed and feed and hamper efforts to stop RCS leakage. This would lead to a significant reduction of safety margin beyond that irreparably introduced by the scenario.

**Cue:** The operating team will have indication of AFW flow and a procedural step in E-0 to establish flow.

**Measurable Performance Indicators:** If flow is not established, the team will transition to FR-H.1 and not satisfactorily meet the complete the critical task.

**Performance Feedback:** The team will be able to establish AFW flow by initiating flow with 22 AFW pump for 23 and 24 SGs (and possibly 21 and 22 SGs) and starting 21 AFW pump to feed 21 and 22 SGs (unless fed using 22 AFW pump).

#### CT-2

Isolate Feedwater flow to and steam flow from the ruptured SG before transition to ECA-3.1 occurs.

**Safety Significance:** Failure to isolate Feedwater flow would lead to a high SG level and hamper efforts to stop RCS leakage. This would lead to a significant reduction of safety margin beyond that irreparably introduced by the scenario.

**Cue:** The operating team will have SG NR level indications and steps in E-3 to isolate Feedwater flow.

**Measurable Performance Indicators:** If Feedwater is not secured, the ruptured SG pressure will lower and transition to ECA-3.1 will be made. This will constitute not meeting critical task.

**Performance Feedback:** The team will have indications of AFW flow and SG pressure to indicate success.

### CT-3

Establish/Maintain RCS temperature to ensure transition out of E-3 does not occur due to either of the following:

- RCS temperature too high to maintain required subcooling
- RCS temperature too low resulting in severe challenge to the subcriticality or integrity CSF.

**Safety Significance:** Overcooling could lead to a challenge to the integrity status CSF and/or lose subcooling. In an extreme overcooling subcriticality could be challenged. All of these events would hampers events to stop RCS leakage, so this would lead to a significant reduction of safety margin beyond that irreparably introduced by the scenario.

**Cue:** The operating team will have guidance in E-3 to control cooldown and indications of RCS temperature and pressure to aid in complying with this guidance.

**Measurable Performance Indicators:** If an overcooling event occurs, the team will transition out of E-3 to FR-P.1. This will constitute not meeting critical task.

**Performance Feedback:** The team will have indications from CETs, subcooling, and SG pressures.

### CT-4

When SI termination criteria are met, stop SI pumps before completion of ECA-3.3 step 9.

**Safety Significance:** Failure to terminate SI could lead to lifting a SG safety and releasing radioactivity to the environment. This would constitute a degradation of any barrier to fission product release.

**Cue:** The operating team will have guidance in ECA-3.3 to terminate SI along with indication that 23 SG level is increasing in an uncontrolled manner.

**Measurable Performance Indicators:** The team progresses beyond step 9 of ECA-3.3 without terminating SI will constitute not meeting critical task.

**Performance Feedback:** The team will have indications SG NR and wide range level and indication of SI pumps status.

### Credited Malfunctions:

1. 23 MFRV will fail in auto (C for ATC/CRS). The ATC will have to take action to control Feedwater flow or a reactor trip will occur. The CRS is given credit for supervising actions. The BOP operator will acknowledge alarms and may aid in diagnosis and control of Feedwater flow, however we are not taking credit for his actions.
2. VCT level instrument failure low (I for ALL). The ATC and BOP both have control board indications that will be used to diagnose failure. The BOP will acknowledge alarms and take action to restore Charging Pump suction to the VCT. The ATC will have to monitor for reactivity effects when the Charging Pump is taking suction from RWST. Additionally, the ATC will secure makeup at the proper time. The CRS will coordinate and supervise activities.
3. 23 SG Tube Leak. The BOP and ATC will have to diagnose event. The BOP will take actions to isolate leakage. A load reduction will occur which will be a reactivity manipulation for the ATC and normal plant operation for the BOP and CRS. This malfunction also requires evaluation of Tech Specs by the CRS.
4. 23 SG Tube Rupture. This is a major malfunction for all operators. Complicating the event are setup malfunctions of one PORV being tagged out, another PORV being unavailable due to Bus 6A fault and instrument air to containment not being available.
5. 480 Bus 6A fault. This will lead to SI with Blackout logic being made up which will cause no CCW pumps to be available. Operators will have to recognize this and secure RCPs. The scenario is more complicated if do not do this in a timely manner because when they trip on their own 6.9KV busses are lost which means the condenser is not available for cooldown. Only the CRS is given credit for this because either board operator may perform this action.
6. 21 AFW auto-start failure. This along with the 480 Bus 6A failure will result in no AFW flow. Manual action by the BOP will be required to restore feed. The CRS and BOP are given credit for this action, but there is a reasonable chance that the ATC will actually perform the action.


Simulator Setup and Instructor Directions		
Setup/Event	INSTRUCTOR ACTIONS	EXPECTED RESPONSE/INSTRUCTOR CUES
IC Reset		Reset Simulator to 100% power IC
SES Setup Batch File	Run setup schedule and verify malfunctions and over-rides have been entered.	Loads 21 ABFP autostart malfunction. Loads tagout of PORV 456 and block valve 536. Loads failure of PCV 1216. Loads failure of flight panel Rx Trip pushbutton Loads MFRV Failure on Trigger 1. Loads VCT Level Failure on Trigger 2. Loads SGTR 900 gpd on Trigger 3. Sets trigger 4 to increase SGTR to 280 gpm. Sets trigger 30 to auto actuate on reactor trip. Sets trigger 29 to actuate on SI initiation. Loads 1228 fails closed on Trigger 30. Loads Bus 6A fault on trigger 29.
Floor Setup	<b>Perform setup checklist.</b>  Update the Protected Equipment PC. <i>Risk is Yellow</i>	<b>HANG PROTECTED EQUIPMENT</b> tags for: 455C PORV and block. Place 536 in TPO and PORV 456 in Close and hang danger tags. Crew walks the panels and assumes the watch.
Event 1	<b>Click the Trigger 1 button at lead evaluator direction.</b>	23 MFRV fails closed in auto (manual available) Ramped over 10 min IMF CNH-PCS008D to 35 ramped over 600s.
Role Play	<b>If NPO sent to investigate 23 MFRV:</b>	NPO reports no obvious problems.
Event 2	<b>Click the Trigger 2 button at lead evaluator direction.</b>	VCT level transmitter fails to zero. IMF XMT-CVC019A to 0 with no ramp
Role Play	<b>If NPO sent to investigate VCT level instrumentation:</b>	NPO reports no obvious problems.
Event 3	<b>Click the Trigger 3 button at lead evaluator direction.</b>	SGTL on 23 S/G 900gpd IMF MAL-RCS014C to 0.01 with no ramp
Role Play	<b>If NPO sent to N16 panel:</b>	Acknowledge the local alarm and report 900 gpd on 23 main steam line.  Team will start a shutdown based on SGTL
Role Play	<b>If NPO sent to fail 1216</b>	Delete malfunction AOV-SGB013A. Fail to closed if needed.

Simulator Setup and Instructor Directions		
Setup/Event	INSTRUCTOR ACTIONS	EXPECTED RESPONSE/INSTRUCTOR CUES
<b>Event 4</b>	<b>Click the Trigger 4 button at lead evaluator direction</b>	SGTR on 23 SG grows to 280 gpm MAL-RCS014C modified from 0.01 to 4.0 no ramp
<b>Role Play</b>	<b>If asked to investigate PCV-1228 failure</b>	NPO reports no obvious problem. MTC reports valve appears to be mechanically bound.

**Event 1 Description:** Feedwater Regulating valve for 23 SG fails closed in auto control. RO takes manual control and restores FW flow to 23 SG. Team responds with AOP-FW-1, Loss of Feedwater or AOP-INST-1, Instrument/Controller Failures.

<b>Time</b>	<b>Position</b>	<b>Examinee's Actions or Behavior</b>
	ATC	<p>Diagnose FRV malfunction by observing 23 SG NR level trending down. The SG Level Deviation Alarm may actuate.</p> <ul style="list-style-type: none"> <li>Place 23 SG FRV in manual and match FF with SF.</li> </ul>
	CRS	<p>Supervise the crew during AOP-FW-1 or AOP-INST-1.</p> <ul style="list-style-type: none"> <li>Direct RO to perform immediate actions of AOP-FW-1 or INST-1.</li> <li>Implement AOP-FW-1 or INST-1.</li> <li>Verify 23 SG FW control is in manual and 23 SG level is under control.</li> <li>Ensure notifications are made and troubleshooting is requested.</li> </ul>
Lead Evaluator		<p>At the discretion of the lead evaluator, direct the Booth Instructor to actuate trigger 2.</p> <p>When crew diagnoses VCT level failure, proceed to next event.</p>

Event 2 Description: VCT Level transmitter fails low, VCT auto makeup starts and Charging Pump suction swaps to the RWST. Team responds per 2-AOP-CVCS-1, Charging and Volume Control Malfunctions		
Time	Position	Examinee's Actions or Behavior
	BOP	Diagnose VCT level failure based on Auto-Makeup and lowering VCT Level without lowering pressure.
	CRS	<p>Supervise the crew during 2-AOP-CVCS-1.</p> <ul style="list-style-type: none"> <li>• BOP will align charging Pump Suction to the VCT.</li> <li>• ATC will place make up controls to stop.</li> <li>• Team should respond prior to significant temperature/power effect has occurred. Turbine load will be adjusted if temperature/power effect occurs.</li> <li>• Maintain VCT pressure 2-5 psig above previous value.</li> </ul>
	Lead Evaluator	<p>At the discretion of the lead evaluator, direct the Booth Instructor to actuate trigger 3.</p> <p>When crew diagnoses SGTL, proceed to next event.</p>

Event 3 Description: 900 gallon per day Steam Generator Tube Leak on 23 SG. Team responds per 2-AOP-SG-1, Steam Generator Tube Leak.		
Time	Position	Examinee's Actions or Behavior
	BOP	Perform ARPs for alarms associated with SGTL. Dispatch NPO to N-16 panel.
	ATC/BOP	Observe R-45 and R-49 in alarm and diagnose that leak rate is therefore greater than 75 gpd. Diagnose failure of PCV-1216 23 SG BD Isol valve to auto close. May have valve failed locally. 
	CRS	Enters 2-AOP-SG-1, Steam Generator Tube Leak. <ul style="list-style-type: none"> <li>Directs crew actions to estimate the size of the leak and minimize secondary contamination.</li> <li>Directs Chemistry to calculate leak rate.</li> <li>Notifies HP of SGTL.</li> <li>Determines shutdown must be made.</li> </ul>
	ALL	Diagnose leak rate is approximately 0.7 GPM (900 gpd).
	CRS	Evaluate Technical Specification 3.4.13 RCS Operational Leakage. <ul style="list-style-type: none"> <li>Determine Condition B applies because primary to secondary exceeds limit – be in Mode 3 in 6 hours and Mode 5 in 36 hrs.</li> </ul>
	ATC	Monitors Pressurizer Level and Pressure for abnormal trends due to SGTL. If level is lowering: <ul style="list-style-type: none"> <li>If desired, reduces letdown flow to 45 gpm.</li> <li>If desired, starts a second charging pump.</li> </ul>
	BOP	Coordinates with RO to reduce letdown to 45 GPM, if desired. <ul style="list-style-type: none"> <li>Open 200A.</li> <li>Close 200B and 200C.</li> <li>Verify PCV-135 controlling between 225 and 275 psig.</li> </ul>
	ALL	Perform load reduction as per Tech Spec/AOP

chat do,  
 significant  
 1 mis  
 failure?  
 what  
 actions  
 for  
 manually  
 control  
 B/D?

Event 3 Description: 900 gallon per day Steam Generator Tube Leak on 23 SG. Team responds per 2-AOP-SG-1, Steam Generator Tube Leak.

Time	Position	Examinee's Actions or Behavior
	Lead Evaluator	<p>When Lead Evaluator is satisfied with amount of load reduction observed, direct the Booth Instructor to manually actuate trigger 4 to increase tube leakage.</p> <p>When crew diagnoses SG tube leakage has dramatically increased, proceed to next event.</p>

Event 4 Description: SGTL increases in size to 280 gpm rupture. Team manually trips, actuates SI and implements E-0.

Time	Position	Examinee's Actions or Behavior
	ATC	<p>Diagnose increase rate of leakage.</p> <ul style="list-style-type: none"> <li>Determine leak rate is greater than the capacity of two charging pumps and 45 gpm letdown.</li> </ul>
	CRS	<p>Directs team to evaluate IAAT Step 4.1.</p> <ul style="list-style-type: none"> <li>Directs RO to trip reactor.</li> <li>Directs RO/BOP to manually actuate SI.</li> </ul>
	ATC	Attempts to trip reactor. Flight panel button not working properly
	BOP/ATC	<p>Trips reactor from supervisory panel.</p> <p>Manually actuates SI.</p>
	CRS	Directs team to perform immediate actions of E-0, Reactor Trip or Safety Injection.
	ATC	<p>Performs E-0 immediate actions:</p> <ul style="list-style-type: none"> <li>Verifies Reactor tripped.</li> <li>Verifies Turbine tripped.</li> <li>Verifies SI actuated.</li> </ul> <p><i>LIST E-0 Actions reqd.</i></p>
	BOP	Verifies all 480V buses energized except 6A.
	CRS	<p>Verify immediate actions using the procedure.</p> <ul style="list-style-type: none"> <li>Direct RO and BOP actions during use of EOPS.</li> </ul>

*General Comment* → *list CT first before actions should list all reqd operator actions for safety @T*

Event 4 Description: SGTL increases in size to 280 gpm rupture. Team manually trips, actuates SI and implements E-0.		
Time	Position	Examinee's Actions or Behavior
	CRS/ATC	Verify AFW pumps. <ul style="list-style-type: none"> <li>No AFW pumps are providing flow to SGs.</li> <li>21 AFW may be started manually to feed 21 and 22 SGs.</li> <li>22 AFW must be placed in service to feed 23 and 24 SGs, and may be used to feed 21 and 22 SGs</li> <li>May establish 400 gpm AFW flow and have BOP align remaining SGs in Attachment 1.</li> </ul>
	<b>Critical Task</b>	WOG CT: E-0--F Establish greater than 400 gpm AFW flow to the SGs before transition out of E-0 or tripping RCPs in FR-H.1.
	BOP	Perform Attachment 1, Automatic Action Verification. <ul style="list-style-type: none"> <li>Start a charging pump.</li> <li>Dispatch NPO to reset lighting and MCCS 24A, 27A, and 29A.</li> <li>Stop condensate pumps.</li> <li>Use 22 AFWP to align AFW flow to 23 and 24 SGs if not already done.</li> </ul>
	ALL	Monitor 23 SG level. <ul style="list-style-type: none"> <li>When NR level &gt; 10%, takes prudent operator action to isolate AFW flow to 23 SG and adjust atmo to 1030 psig. (Note this is part of critical task E-0 -- F).</li> <li>Ensures total AFW flow to intact SGs remains &gt;400gpm.</li> </ul>

*Red all CT actions*

Event 4 Description: SGTL increases in size to 280 gpm rupture. Team manually trips, actuates SI and implements E-0.

Time	Position	Examinee's Actions or Behavior
	CRS/ATC	<ul style="list-style-type: none"> <li>• Verify SI Flow. Place one RHR pump CS in pullout.</li> <li>• RCPs are tripped because of black out logic which keeps CCW pumps from running.</li> </ul> <p><b>Note: This may be performed prior to reaching this step. If this action is delayed, the RCPs will eventually trip on their own and 6.9KV<sup>a</sup> busses may be lost. This will effect scenario by losing Circulating Water Pumps, which will make Condenser not available for cooldown.</b></p> <ul style="list-style-type: none"> <li>• Check Seal Cooling.</li> <li>• Check RCS temperatures trending to 547.</li> <li>• Check PRZR PORVS, Spray valves and aux spray closed.</li> <li>• Check if RCPs should be stopped.</li> <li>• Check for faulted SG.</li> <li>• Check for ruptured SG. <ul style="list-style-type: none"> <li>○ Determine 23 SG is ruptured.</li> </ul> </li> </ul>
	CRS	Transition to E-3, Steam Generator Tube Rupture.
Lead Evaluator		Proceed to the next event when the crew transitions to E-3, Steam Generator Tube Rupture.

*Link  
Criteria for Stopping RCPs*

Event Description: 23 SG is ruptured. Team performs actions of E-3 Steam Generator Tube Rupture. 23 SG is isolated and RCS is cooldown is performed in preparation to depressurize. Team will diagnose that depressurization cannot be performed per E-3.		
Time	Position	Examinee's Actions or Behavior
	CRS	<p>Transition to E-3, Steam Generator Tube Rupture.</p> <ul style="list-style-type: none"> <li>Direct actions of the team during implementation of E-3.</li> </ul>
	CRS/ATC	<p>Determine if RCPs should be stopped.</p> <p>Identify ruptured SG.</p> <ul style="list-style-type: none"> <li>Determines 23 SG is ruptured.</li> </ul> <p>Isolate Flow from Ruptured SG.</p> <ul style="list-style-type: none"> <li>Check 23 SG atmospheric steam dump controller set at 1030 psig</li> <li>Check 23 SG atmospheric steam dump closed. <i>LIST valve #</i></li> <li>Check 22 and 23 SG intact. <ul style="list-style-type: none"> <li>Dispatch NPO to close MS-42.</li> </ul> </li> <li>Verify 23 SG blowdown isolation valves are closed. <i>list valves</i></li> <li>Dispatch NPO to locally isolate 23 SG upstream traps and MSIV bypass.</li> <li>Close 23 SG MSIV.</li> <li>Check 23 SG level &gt; 10%. <ul style="list-style-type: none"> <li>When &gt; 10%, stop feed flow to 23 SG.</li> </ul> </li> </ul> <p><i>LIST ALL affected S/G valves</i></p>
<div> <div>Critical Task</div> <div> WOG CT: E-3--A  Isolate feedwater flow to and steam flow from the ruptured SG before a transition to ECA-3.1 occurs. </div> </div>		

Event Description: 23 SG is ruptured. Team performs actions of E-3 Steam Generator Tube Rupture. 23 SG is isolated and RCS is cooldown is performed in preparation to depressurize. Team will diagnose that depressurization cannot be performed per E-3.

Time	Position	Examinee's Actions or Behavior
	CRS/ATC	<p>Check 23 SG &gt; 440 psig.</p> <p>Initiate RCS Cooldown.</p> <ul style="list-style-type: none"> <li>• Determine required CET temperature.</li> <li>• Dump steam from 21, 22, and 24 SGs to the condenser.</li> <li>• When CETs are &lt; target temperature, stop dumping steam and control temperature at value less than target temperature..</li> </ul> <p>Check intact SGs.</p> <p>Check PORVs and Block Valves.</p> <ul style="list-style-type: none"> <li>• Check power available to block valves.</li> <li>• Check PORVs closed.</li> <li>• Cannot open any block valves.</li> </ul> <p>Reset SI. <i>list all affected coils &amp; pumps</i></p> <p>Reset Phase A.</p> <p>Establish IA to containment. <i>list valves</i></p> <ul style="list-style-type: none"> <li>• Determine PCV-1228 will not open.</li> </ul> <p>Stop RHR pumps and place in auto.</p>
<b>Critical Task</b>		<p>WOG CT: E-3--B</p> <p>Establish/maintain RCS temperature such that transition from E-3 does not occur due to</p> <ul style="list-style-type: none"> <li>○ RCS temperature too high – unable to maintain required subcooling.</li> <li>○ RCS temperature too low – severe challenge occurs to sub criticality or integrity status trees.</li> </ul>

**Event Description:** 23 SG is ruptured. Team performs actions of E-3 Steam Generator Tube Rupture. 23 SG is isolated and RCS is cooldown is performed in preparation to depressurize. Team will diagnose that depressurization cannot be performed per E-3.

<b>Time</b>	<b>Position</b>	<b>Examinee's Actions or Behavior</b>
	ATC/CRS	<p>Establish maximum Charging Flow with suction aligned to RWST.</p> <ul style="list-style-type: none"> <li>• Check ruptured SG pressure stable or increasing.</li> <li>• Check Subcooling based on CETs &gt; than value from table.</li> <li>• Depressurize the RCS. <ul style="list-style-type: none"> <li>○ Determine spray not available due to no RCPs and no instrument air.</li> <li>○ Diagnose PORVs not available.</li> <li>○ Determine auxiliary spray cannot be aligned due to no instrument air.</li> </ul> </li> </ul>
	CRS	Transition to ECA-3.3, SGTR without Pressurizer Pressure Control.
Lead Evaluator		Proceed to the next event when transition to ECA-3.3 is made.

**Event Description:** Instrument Air to Containment PCV-1228 will not open and both PORV block valves cannot be opened. Team performs ECA-3.3, SGTR with out pressurizer pressure control.

<b>Time</b>	<b>Position</b>	<b>Examinee's Actions or Behavior</b>
	RO/CRS	<p>Check status of 480V buses.</p> <ul style="list-style-type: none"> <li>Dispatch NPO to manually load equipment onto buses.</li> </ul> <p>Check 23 SG NR level less than 73%.</p> <p>Try to establish normal spray.</p> <p>Try to restore a PORV.</p> <p>Try to establish auxiliary spray.</p> <p>Check intact SG levels.</p> <p>Check PRZR Level &gt; 14%.</p> <p>Determine if SI can be terminated.</p> <ul style="list-style-type: none"> <li>Check subcooling &gt; value from table.</li> <li>Check secondary heat sink.</li> <li>Check RVLIS &gt; 60%.</li> <li>Check 23 SG NR level increasing in an uncontrolled manner.</li> </ul> <p>Stop SI pumps and place in AUTO.</p>
	<b>Critical Task</b>	<p>WOG CT: ECA-3.3--A</p> <p>Stop all SI Pumps when termination criteria are met.</p>
	<b>Lead Evaluator</b>	<p>Terminate scenario any time after SI pumps are stopped, or at the discretion of the Lead Evaluator.</p>

Facility: Indian Point 2 Scenario No.: 4

Op-Test No.: 1

Examiners: \_\_\_\_\_

Operators: \_\_\_\_\_

**Initial Conditions:**

Reset simulator to IC-287 Load Simulator Schedule-Scenario4

The Plant is in Mode 1 just above 5% power preparing to come on line.

**Turnover:**

Raise power to approximately 8-10% to place MTG in service.

*Prepare Turnover Sheet with Plant Initial Conditions*

**Critical Tasks:**

1. Insert negative reactivity into the core by at least one of the following methods before completing FR-S.1 step 4: (FR-S.1--C)
  - De-energize the control rod drive MG sets
  - Place rod control in manual and insert RCCAs
  - Establish emergency boration flow to the RCS
2. Establish at least 800 gpm AFW flow to the SGs before completion of FR-S.1 step 3. (E-0 -- F)
3. Manually actuate at least one train of SIS actuated safeguards before completion of E-0 step 4. (E-0 -- D)

Event No.	Malf. No.	Event Type*	Event Description
1	N/A	R(ATC) N(CRS) N(BOP)	Power escalation.
2	MOC-SWS007	C(CRS) C(BOP)	22 Service Water Pump trip. <b>Tech Spec for CRS</b>
3	XMT-RCS028 A	I(ALL)	Controlling PZR Pressure transmitter fails high. <b>Tech Spec for CRS</b>
4	MOV-CCW008	C(CRS) C(BOP)	FCV-625 spurious closure.
5	MAL-SGN005	<del>N</del> (CRS) C(ATC)	Steam leak in the Turbine Building leading to plant trip. <i>Means BE MT?</i>
6	BKR-PPL003/4	<del>M</del> (ALL) <del>C</del>	Entered at setup, Reactor Trip Breakers will not open causing team to enter 2-FR-S.1.
7	RLY-PPL487/8	C(CRS) C(BOP)	Entered at setup, SI does not automatically actuate. Manual actuation will be required.
* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor			

## Session Outline:

The scenario begins with the plant at 5% power with no equipment is out of service. The team has been instructed to raise power to 8-10% and place MTG in service.

*Cont 1* After taking the watch, the crew will commence raising power. *Cont 2* After the power escalation has progressed, 22 SWP will trip. The team will start another pump per 2-ARP-SJF.

*Cont 3* Following the restoration of SW, a failure high of PT-455 will occur. The team will respond using 2-AOP-INST-1 "Instrument or Controller Failures." The channel will be removed from service.

After the channel is removed from service, FCV-625 will go closed with no apparent reason. The team should respond per 2-ARP-SGF and re-open the valve. If the team elects to not re-open the valve, the scenario can continue.

Prior to completion of the Subsequent Actions of 2-AOP-CCW-1, a steam break will occur in the Turbine Building. The team will attempt to manually trip the plant but the reactor trip breakers will not open.

The reactor will not trip from the Control Room and the team will respond per 2-FR-S.1, "Response to Nuclear Power Generation / ATWS," and will shutdown the reactor by manually inserting control rods and initiating Emergency Boration. The reactor trip breakers will not be locally opened after an NPO is dispatched, until after emergency Boration has been aligned. One MSIV will fail to close from the control switches. The team will proceed through 2-FR-S.1 until transition to 2-E-0, "Reactor Trip or Safety Injection."

After the transition to 2-E-0 is made, the team will determine that three SGs are intact and 23 SG is faulted. The Team will also determine that SI did not automatically actuate and must manually actuate SI. The team will transition to 2-E-2, Faulted Steam Generator Isolation and isolate 23 SG. The scenario is terminated after the actions of 2-E-2 are complete and a transition to 2-E-1, Loss of Reactor or Secondary Coolant is announced or at the discretion of the lead examiner.

Procedure flow path: 2-POP-1.3, 2-ARP-SJF, 2-AOP-INST-1, 2-ARP-SGF, 2-AOP-UC-1, 2-E-0, 2-FR-S.1, 2-E-0, 2-E-2

## Scenario Critical Task and Malfunction Analyses

### Critical Tasks:

#### CT-1

Insert negative reactivity into the core by at least one of the following methods before completing FR-S.1 step 4:

- De-energize the control rod drive MG sets
- Place rod control in manual and insert RCCAs
- Establish emergency boration flow to the RCS.

Safety Significance: Failure to insert negative reactivity would result in a significant reduction of safety margin beyond that irreparably introduced by the scenario.

Cue: There will be numerous indications that the reactor did not trip. E-0 and FR-S.1 will provide guidance for tripping the reactor.

Measurable Performance Indicators: All three methods will be demonstrated by the team until the reactor is tripped. Failure to continue attempts to insert negative reactivity while reactor power is above 5% will constitute failure to complete the critical task.

Performance Feedback: Numerous indications of reactor power, charging flow, and trip breaker indications.

#### CT-2

Establish at least 800 gpm AFW flow to the SGs before completion of FR-S.1 step 3.

Safety Significance: Failure to establish required AFW flow could limit heat removal with power above 5%. This would lead to a significant reduction of safety margin beyond that irreparably introduced by the scenario.

Cue: FR-S.1 will direct establishing 800 gpm AFW flow.

Measurable Performance Indicators: If step 3 of FR-S.1 is completed without establishing proper AFW flow this will constitute a failure to complete the critical task.

Performance Feedback: The team will have indications of AFW flow.

### CT-3

Manually actuate at least one train of SIS actuated safeguards before completion of E-0 step 4.

Safety Significance: Failure to initiate safety injection would lead to a degraded emergency core cooling system (ECCS).

Cue: The team will have indication of a faulted SG and alarms indicating that a delta-P SI should have occurred. E-0 will direct initiating SI.

Measurable Performance Indicators: Failure to initiate SI by the completion of E-0 step 4 will constitute a failure to complete the critical task.

Performance Feedback: The team will have indications of pumps and valves to show that SI actuated.

#### Credited Malfunctions:

1. 22 SW Pump trip. The BOP will diagnose the pump trip. Another essential header SW pump should be started per the ARP. The CRS will coordinate and supervise activities. The CRS will evaluate Tech Specs for the pump trip.
2. PT-455 failing high. The ATC and BOP will diagnose the failure based on PZR Hi Press alarm and open spray valve. The ATC will take manual control of PZR pressure. The BOP will remove the channel from service and may trip bistables. The CRS will coordinate and supervise activities. The CRS will evaluate Tech Specs.
3. FCV-625 goes closed. The BOP will diagnose that the valve has gone closed after acknowledging CCW Thermal Barrier Low Flow Alarm. Per the ARP, the valve can be re-opened and flow checked locally. The scenario may proceed without re-opening the valve.
4. Steam Line Rupture. The ATC and BOP will diagnose a steam line breaker by changes in power along with audio indications. The ATC and CRS will determine that reactor needs to be tripped and MSIVs closed. The ATC will attempt to trip the reactor.
5. ATWAS/Failure of 21 MSIV. This is major malfunction set for the whole team. FR-S.1 will be entered and Emergency Boration will be initiated prior to the reactor being tripped locally. 21 MSIV failure will cause 21 SG to blow down requiring the team to secure feeding it.
6. Failure of automatic SI. The BOP with concurrence of the CRS will actuate SI when it is determined that an automatic SI is warranted but did not occur..

Simulator Setup and Instructor Directions		
Setup/Event	INSTRUCTOR ACTIONS	EXPECTED RESPONSE/INSTRUCTOR CUES
<b>IC Reset</b>	<b>Use IC for NRC Scenario 4 5% Power Starting Up</b>	Reset Simulator to 5% power IC
<b>SES Setup Schedule</b>	<b>Run Schedule</b> and verify malfunctions and over-rides have been entered	Loads Reactor Trip Breaker malfunction Loads Auto SI Failure Loads MS Isolation failure Loads PT-455 failure on Trigger 1 Loads FCV-625 failure on Trigger 2 Loads Turbine Hall Steam Leak on Trigger 3
<b>Floor Setup</b>	Perform setup checklist	
<b>Event 1</b>	Actuate Trigger 1  <b>At lead evaluator direction</b>	When directed by the Lead Evaluator, activate Trigger 1 to cause 22 SWP to trip.
<b>Role Play</b>	If called to check 22 SWP	Pump Motor has slight acrid odor. Breaker tripped on over-current. The pump that was started is operating with no issues.
<b>Event 2</b>	Actuate Trigger 2  <b>At lead evaluator direction</b>	When directed by the Lead Evaluator, activate Trigger 2 to cause PT-455 to fail high with a 10 second ramp. XMT-RCS028A to 2500 with 10s ramp
<b>Role Play</b>	If I&C is contacted about PT-455 failure	Report back that a troubleshooting package will be prepared
<b>Event 3</b>	Actuate Trigger 3  <b>At lead evaluator direction</b>	When directed by the Lead Evaluator, activate Trigger 3 to FCV-625 to fail closed.  MOV-CCW008 to close  <b>AS SOON AS VALVE GOES CLOSED REMOVE MALFUNCTION (valve will not re-open when malfunction is removed)</b>
<b>Role Play</b>	When Nuclear NPO dispatched	Nuke NPO reports that flow at FIC-625 is normal after valve is re-opened.
<b>Event 4</b>	Actuate Trigger 4  <b>At lead evaluator direction</b>	When directed by the Lead Evaluator, activate Trigger 4: Insert MAL-SGN005 to value 60 with no ramp or delay.

Simulator Setup and Instructor Directions		
Setup/Event	INSTRUCTOR ACTIONS	EXPECTED RESPONSE/INSTRUCTOR CUES
<b>Role Play</b>	If NPO dispatched to look for steam leak	If NPOs are dispatched to look for steam, report back that a large steam leak exists at the north end of the turbine hall.
<b>Role Play</b>	NPO cannot locally trip reactor until Emergency Boration is commenced.  Actuate Trigger 5 to trip reactor.	If trigger does not work, remove overrides preventing reactor trip. May have to insert manual reactor trip

Event # 1

Event Description: Power ascension using POP-1.3 in preparation for Main Turbine Startup and Synchronization.		
Time	Position	Examinee's Actions or Behavior
	CRS	Supervise the actions of the team during power ascension <ul style="list-style-type: none"> <li>Refers to POP-1.3 Refers to Reactivity Summary Sheet</li> <li>Develops and implements a startup plan</li> <li>Develops and implements a reactivity plan</li> <li>Directs the RO to make reactivity additions</li> <li>Directs the BOP to make turbine load changes</li> </ul>
	ATC	Performs reactivity manipulations to support power increase <ul style="list-style-type: none"> <li>Withdraw control rods if desired</li> <li>Perform Dilutions if desired</li> </ul>
	BOP	Performs peer checks for reactivity manipulations
Lead Evaluator		When sufficient power ascension activities have been observed, direct Booth Operator to activate trigger 1 <ul style="list-style-type: none"> <li>Proceed to next event.</li> </ul>

*Details How many Rods? which Rods?*  
*details Is a deletion Reg'd if so how much?*

Event Description: 22 Service Water Pump Trip.		
Time	Position	Examinee's Actions or Behavior
	BOP	<ul style="list-style-type: none"> <li>Observes Alarm for SW 1,2,3 Header Low pressure and 22 SWP not running.</li> <li>Refers to 2-ARP-SJF</li> <li>Recommends starting another 1,2,3 header pump</li> <li>Starts pump when CRS concurs</li> </ul>
	CRS	<ul style="list-style-type: none"> <li>Concurs with start of additional SW pump</li> <li>Refers to Tech Spec LCO 3.7.8 and determines that Condition A applies and the plant is in a 72 hour AOT</li> </ul>
Lead Evaluator		<p>After SW has been restored and time is allowed for CRS to evaluate Tech Specs, direct Booth Operator to activate trigger 2</p> <ul style="list-style-type: none"> <li>Proceed to next event.</li> </ul>

*which pump is he expecting to start?*

Event Description:PT-455 fails high. PZR Master Pressure Controller place in manual. 2-AOP-INST-1 entered. Channel removed from service and automatic pressure control restored.		
Time	Position	Examinee's Actions or Behavior
	BOP	Notes alarms associated with PZR Pressure
	ATC	Diagnose PT-455 failure and place PZR Pressure Master Controller to manual and control pressure.
	CRS	Implement 2-AOP-INST-1 Verify no other failures Verify pressure control in manual Remove PT-455 from service <b>NOTE: Lead Evaluator determine if bistables are to be tripped. May be necessary to allow BOP to take action for failure.</b> Return pressure control to automatic
Lead Evaluator		When pressure control has been returned to automatic (or at lead examiner's discretion), instruct booth operator to activate Trigger 2 to cause FCV-625 to close.

Event Description:FCV-625 spuriously closes and can be re-opened per 2-ARP-SGF.		
Time	Position	Examinee's Actions or Behavior
	BOP	Notes alarm for CCW Thermal Barrier Return low flow.
	CRS BOP	Use 2-ARP-SGF as guidance for re-opening FCV-625 If valve is re-opened, Nuke NPO should be sent to check flow is normal at FIC-625
Lead Evaluator		When the valve has been re-opened, or at the discretion of the lead evaluator, direct the Booth Instructor to activate Trigger 3 to cause a rupture on the Main Steam East Header in the Turbine Building.

Event Description: Main Steam Line piping rupture in the Turbine Hall. Team identifies steam leak and enters 2-AOP-UC-1, Uncontrolled Cooldown and determines reactor trip is required		
Time	Position	Examinee's Actions or Behavior
	RO	Diagnose Main Steam Leak from the following indications: <ul style="list-style-type: none"> <li>• rising steam flow</li> <li>• rising reactor power</li> <li>• lowering Tave</li> </ul>
	CRS	Implements AOP-UC-1, Uncontrolled Cooldown <ul style="list-style-type: none"> <li>• Determine an unisolable steam leak exists</li> <li>• Direct the crew to trip the reactor, close MSIVs and go to E-0</li> </ul>
Lead Evaluator		Proceed to the next event when the team determines reactor trip is required.

Event Description: Manual and Auto reactor trips do not open the Reactor Trip Breakers. Team Transitions to FR-S.1. All MSIVs are failed open but three will eventually be locally closed. Auto Safety Injection will not occur due to malfunction; but manual SI will function when actuated.

Time	Position	Examinee's Actions or Behavior
	RO	Manually Trip the Reactor Diagnose reactor did not trip
	RO/BOP	Attempt to trip the reactor using the Reactor Trip Pushbutton on panel SB-2
	RO	Attempt to trip the reactor <ul style="list-style-type: none"> <li>Determine reactor did not trip</li> <li>Inform team reactor is not tripped and go to FR-S.1</li> </ul>
	CRS	Direct team to perform actions of FR-S.1, Response to Nuclear Power Generation/ATWS <ul style="list-style-type: none"> <li>Dispatch NPO to locally trip the reactor using posted operator aid</li> </ul>
	RO	Perform FR-S.1 Immediate Actions: <ul style="list-style-type: none"> <li>Attempt to manually trip the reactor</li> <li>Verify NPO is dispatched to locally trip reactor</li> <li>Manually actuate turbine trip</li> </ul>
	BOP	Manually start motor driven AFW pumps and verify > 800 gpm flow to SGs
<b>Critical Task</b>		WOG CT E-0--F Establish at least 800 gpm AFW flow to the SGs before completion of FR-S.1 step 3.



Event Description: Manual and Auto reactor trips do not open the Reactor Trip Breakers. Team Transitions to FR-S.1. All MSIVs are failed open but three will eventually be locally closed. Auto Safety Injection will not occur due to malfunction; but manual SI will function when actuated.

Time	Position	Examinee's Actions or Behavior
	CRS/RO	<p>Verify dilution paths isolated</p> <ul style="list-style-type: none"> <li>• Close FCV-111A</li> </ul> <p>Check for reactivity insertion from uncontrolled Cooldown</p> <p>Check MSIVs closed</p> <ul style="list-style-type: none"> <li>• Close all MSIVS</li> <li>• Determine one MSIV will not close from the control room</li> <li>• Dispatch NPO to locally close MSIV</li> </ul> <p>Identify Faulted SGs</p> <p>Check SG pressures – decreasing in uncontrolled manner or completely depressurized</p>
Lead Evaluator		The scenario is terminated after the actions of 2-E-2 are complete and a transition to 2-E-1, Loss of Reactor or Secondary Coolant is announced or at the discretion of the lead examiner.

*Classify  
Event*

Facility: Indian Point 2 Scenario No.: ~~5 (spare)~~

Op-Test No.: 1

# 3

Examiners: \_\_\_\_\_ Operators: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Initial Conditions:**

Reset simulator to IC-118 Load Simulator Schedule-Scenario3

The Plant is in a 100% normal full power lineup.

22 AFW Pump has been OOS for 4 hours due to bearing oil line repair.

**Turnover:**

Maintain 100% Power

**Critical Tasks:**

1. Establish RCS bleed and feed when the average of the three lowest S/G levels reach 41% WR. (FR-H.1—F)
2. Open all reactor vessel head vent valves before resetting SI in FR-H.1 (non-WOG)
3. Close all reactor vessel head vent valves before exiting 2-FR-H.1. (FR-H.1—G)

Event No.	Malf. No.	Event Type*	Event Description
1	XMT-SGN002 A	I(ALL)	21 SG B Channel of Steam Flow Fails high. Team will place Channel <del>B</del> in service and enter 2-AOP-INST-1. <b>Tech Spec Evaluation for CRS</b>
2	MAL-EPS007B	C(ALL) R(ATC) N(CRS) N(BOP)	Loss of 480V Bus 3A. Team will enter 2-AOP-480V-1 and diagnose that a T.S. shutdown is required due to having 2 inoperable AFW pumps. <b>Tech Spec Evaluation for CRS</b> <i>After a Aux Booster feed pumps?</i>
3	MAL-CVC002 A	C(CRS) C(ATC)	21 RCP Number 1 Seal leak. Team will have to enter 2-AOP-RCP-1. Continued operation is allowed with existing leakage. 21 RCP seal leakage will increase until tripping the pump and reactor is required.
<del>4</del> 4	<del>MOC-AFW002</del> MOC-AFW002	<del>M(ALL)</del>	<del>23 AFW pump will not start. This will lead the team to a loss of heat sink.</del> <i>operator left Stop &amp; Control valve fail to close MSIVs maybe block to turbine</i>
<del>5</del> 5	<del>AOV-RCS002 A</del> AOV-RCS002 A	<del>C(ALL)</del>	<del>PORV PCV-455C will not open. This will require the team to open the reactor head vent valves to perform bleed and feed.</del>
* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor			

## Session Outline:

The evaluation begins with the plant at 100% power steady state operation. The following equipment is out of service:

- 22 AFW pump has been out-of-service for bearing oil line repair for 4 hours. It is expected back within the next 6 hours (ITS 3.7.5 – 72 hr AOT). 21 and 23 AFW pumps are protected equipment.

After taking the watch, 21 SG Steam Flow Channel B transmitter will fail high. The ATC will switch to the A channel and the team will enter 2-AOP-INST-1. The CRS will refer to Tech Spec Table 3.3.2-1 and bistables will be tripped.

After bistables are tripped, a fault will occur on 480V Bus 3A. The team will take actions in accordance with AOP-480V-1, “Loss of Normal Power to any Safeguards 480V Bus.” Due to the fault on Bus 3A, 22 EDG cannot re-energize the bus. TS require plant shutdown due to 2 trains of AFW inoperable (TS 3.7.5 condition C).

After team has begun shutdown, 21 RCP will experience #1 seal degradation. The team will perform actions of AOP-RCP-1, Reactor Coolant Pump Malfunctions.” The #1 seal degradation severity will then increase requiring reactor trip.

When the reactor is tripped, the turbine upper left stop and control valve pair fail to close. MSIV's must be manually closed to trip the turbine.

*LIST  
on D-1*

23 ABFP will not auto start and will not be able to be manually started from the Control Room due to 480V circuit breaker failure. (21 ABFP is de-energized due to fault on bus 3A, and 22 ABFP is out of service.)

The team will subsequently transition to FR-H.1, “Loss of Secondary Heat Sink” due to a loss of AFW flow. SG WR levels will lower until bleed and feed is required.

One PRZR PORV will not open when required. The crew will open the Reactor Head Vent valves. 21 AFW pump will then be successfully started from its ASSS supply, or 23 AFW pump from its normal supply after swapping 480V breakers with the spare breaker. The scenario can be terminated after the head vent valves have been closed, or at the discretion of the lead evaluator.

Procedure flow path: 2-AOP-INST-1, 2-AOP-480V-1, 2-POP-2.1 or 2-AOP-RSD-1, 2-AOP-RCP-1, 2-E-0, 2-FR-H.1

## Scenario Critical Task and Malfunction Analyses

### Critical Tasks:

#### CT-1

Establish RCS bleed and feed when the average of the three lowest S/G levels reach 41% WR.

Safety Significance: Failure to establish bleed and feed prior to SG dryout could lead to a challenge the fuel and RCS barrier. This would lead to a degradation of any barrier to fission product release.

Cue: The team will have WR SG level indication and FR-H.1 foldout page guidance to establish bleed and feed..

Measurable Performance Indicators: If <sup>bleed</sup>bled and feed is not established prior to SG WR reaching 14%, this will cause the team to not satisfactorily complete the critical task.

Performance Feedback: The team will have indications of SI flow and CETs.

#### CT-2

Open all reactor vessel head vent valves before resetting SI in FR-H.1.

Safety Significance: Failure to open reactor vessel head vent valves when one PORV does not open will result in a bleed path less than assume in accident analyses. This could lead to a degradation of any barrier to fission product release.

Cue: The operating team will have indications that one PORV will not open. FR-H.1 will direct opening the reactor vessel head vent valves.

Measurable Performance Indicators: If the team proceeds in FR-H.1 to reset SI without opening the reactor vessel head vent valves, this will constitute not meeting critical task.

Performance Feedback: The team will have indications of CETs and SI flow.

### CT-3

Close all reactor vessel head vent valves before exiting 2-FR-H.1.

**Safety Significance:** Failure to close the reactor vessel head vent valves before exiting FR-H.1 would violate the procedure and lead to having an RCS breach at a point in the EOP flowpath where this is not expected. This would cause a significant reduction of safety margin beyond that irreparably introduced by the scenario.

**Cue:** The operating team will have guidance in FR-H.1 to remain in the procedure until the reactor vessel head vent valves are closed.

**Measurable Performance Indicators:** If the team exits FR-H.1 with the reactor vessel head vent valves still open, this will constitute not meeting critical task.

**Performance Feedback:** The team will have indications of valve position along with RCS pressure.

### Credited Malfunctions:

1. 21 SG Steam Flow Instrument Failure. The ATC will diagnose the failure and switch to the operable channel. The BOP will trip bistables, and the CRS will coordinate and supervise activities. The CRS will evaluate Tech Specs for the failure.
2. Loss of 480V Bus 3A. All operators will diagnose the failure. The ATC will have to start a charging pump. The BOP will have to start a SW pump. The CRS will coordinate and supervise activities. The CRS will evaluate Tech Specs for the failure and determine that the plant is in a six hour shutdown statement.
3. 21 RCP No.1 Seal leak and rupture. The ATC and BOP will diagnose the initial failure. No credit is taken for the initial leak since there are no equipment operations. When leakage is increased, the team will have to recognize that trip criteria are met and trip the reactor.
4. 23 AFW Pump Failure. This failure along with Bus 3A and 22 AFW OOS will lead to a loss of heat sink which is a major malfunction for all operators.
5. PORV 455C Failure. This failure will cause the team to use the reactor head vent valves. The BOP and ATC should both perform control board manipulations to complete this task. The CRS will coordinate and supervise activities.

*failure*  
← *Stop & Control Valve*  
*as Close Close MSIVs*  
*to trip*  
*turbine*

Simulator Setup and Instructor Directions		
Setup/Event	INSTRUCTOR ACTIONS	EXPECTED RESPONSE/INSTRUCTOR CUES
IC Reset	10, 11, 12	Reset Simulator to 100% power IC
SES Setup Schedule	Load schedule and verify malfunctions and over-rides have been entered	Isolates steam supply to 22 ABFP Removes 22 ABFP from service Loads 23 ABFP failure Fails Upper Left Stop Valve Loads PORV 455C failure Loads bus 3A fault on trigger 1 Loads 21 RCP #1 Seal Failure (5.1 gpm) on trigger 2 Increases Seal Failure to > 6 gpm on trigger 3 Sets trigger 30 to actuate on reactor trip Fails Upper Left Control Valve partially open
Floor Setup	<b>Ensure that 22 Charging Pump is in service.</b>  Perform setup checklist Distribute Turn over sheets	<i>Update the Protected Equipment Computer display. Risk is yellow.</i>  Ensure that 22 Charging Pump is running and all others are secured  Place PCV-1139 (22 ABFP) in Trip and apply Danger Tag  Hang PROTECTED EQUIPMENT tags for: 21 & 23 ABFP's  Watch team walks the panels and assumes the watch.
Event 1	Actuate Trigger 1 <b>At lead evaluator direction</b>	Insert XMT-SGN002A to high value with no ramp or delay.
Role Play	If I&C called to investigate failure:	Inform the team that a troubleshooting package is being developed.
Event 2	Actuate Trigger 2 <b>At lead evaluator direction</b>	Insert MAL-EPS007B 480V BUS 3A FAULT without delay or ramp

Simulator Setup and Instructor Directions		
Setup/Event	INSTRUCTOR ACTIONS	EXPECTED RESPONSE/INSTRUCTOR CUES
Role Play	<p>If NPO sent to investigate Bus 3A Trip</p> <p>Acknowledge requests for I&amp;C to troubleshoot</p>	<p>NPO reports no obvious damage, but bus supply breaker tripped on over current and strong odor of ozone.</p> <p>I&amp;C will develop a troubleshooting plan</p>
Event 3	<p>Actuate Trigger 3</p> <p><b>At lead evaluator direction</b></p>	<p>Insert MAL-CVC002A RCP 21 #1 SEAL FAILURE (NR) to value of 4 with 120 second ramp and no delay</p>
Event 4	<p>Actuate Trigger 4</p> <p><b>At lead evaluator direction</b></p>	<p>Increase MAL-CVC002A to value 120 with no ramp or delay.</p>
NOTE:	When Rx is tripped	Upper left stop and control valve do not close.
Role Play	<p><del>ABFP</del> Status:</p> <p><i>AFW pump 2,</i></p>	<p>21 de-energized</p> <p>22 bearing oil is drained</p> <p>23 pump appears normal. Breaker appears normal</p>
Role Play	When NPO dispatched to energize head vent valves at MCC 26A/B	<p>Close breaker for HCV-3100</p> <ul style="list-style-type: none"> <li>o MCC 26A Sheet 2 (EPS 18) LOA-EPS431</li> </ul> <p>Close breaker for HCV-3101</p> <ul style="list-style-type: none"> <li>o MCC 26B Sheet 2 (EPS 22) LOA-EPS523</li> </ul>
	<p><b>After head vent valves have been opened:</b></p> <p>Depending upon previous requests from the CCR, perform one of the following: fix the 23 ABFP 480V breaker or align ASSS power to 21 ABFP</p>	<p>Do one of the following to restore a motor driven ABFP:</p> <ol style="list-style-type: none"> <li>1. Fix 23 ABFP 480V brkr: Call CCR and request 23 ABFP control switch be placed in pullout to support breaker swap. From the Instructor Station Summary - Delete MOC-AFW002. NPO reports that the 480V breaker for 23 ABFP has been swapped with the spare breaker. Request CCR to attempt to start 23 ABFP.</li> <li>2. Align ASSS 440V power (SOP-ESP-1, section 4.11) to 21 ABFP: Place EDC5 in "ALT" (Bus 3A P&amp;ID EPS7). Notify CCR. When directed by CCR, close breaker at 12FD3 to start ABFP. (P&amp;ID SWD4 breaker 12FD3-1B)</li> </ol>

Event Description: 21 SG Steam Flow Channel B Fails High.		
Time	Position	Examinee's Actions or Behavior
	BOP/ATC	Diagnose failed instrument
	BOP	Refers to ARPs for alarms
	ATC	Places Channel A in service for 21 SG Steam Flow (will probably switch to the A Channel for Feed Flow as well)
	CRS	<p>Implements 2-AOP-INST-1</p> <ul style="list-style-type: none"> <li>• Verifies no other instrument failures</li> <li>• Ensures actions have been taken to stabilize the plant</li> <li>• Refers to Tech Spec Table 3.3.2-1</li> </ul> <p><b>Evaluator Note: If the CRS asks SM if tripping bistables will be performed, inform him that I&amp;C request that bistables be tripped.</b></p> <ul style="list-style-type: none"> <li>• Directs tripping of bistables</li> </ul>
Lead Evaluator		<p>When bistables have been tripped, direct the Booth Instructor to actuate trigger 2.</p> <p>Proceed to the next event when the team diagnoses increased RCP Seal Return Flow.</p>

Event Description: 480V Bus 3A faults. Team responds per AOP-480V-1 to stabilize the plant.		
Time	Position	Examinee's Actions or Behavior
	BOP/ATC	<p>Diagnose bus 3A de-energized</p> <p>Perform ARPs for associated alarms</p>
	CRS	<p>Implement AOP-480V-1</p> <ul style="list-style-type: none"> <li>○ Direct actions of RO and BOP</li> <li>○ Initiate Attachment 2</li> <li>○ Direct STA to evaluate TS</li> <li>○ Determine shutdown is required</li> <li>○ Ensure notifications are initiated (OM, WWM, NRC, Power Marketing, etc).</li> </ul>
	ATC	<p>Start 21 or 23 Charging pump and adjust speed to match 22 prior to trip.</p> <p>If flashing in letdown line occurs, then first close LCV-459, start a charging pump and re-establish letdown per 2-SOP-3.1</p>
	BOP	<p>Check CCW pumps running and 625 open</p> <p>Check SW pumps</p> <p>Dispatch NPO to monitor EDGs</p>
	CRS	<p>Initiate review of the following TS to determine required actions based on plant conditions:</p> <p style="padding-left: 40px;">3.8.1 AC Sources – Operating, Condition H</p> <p style="padding-left: 40px;">3.8.9 Distribution Systems – Operating</p> <p>Determine that bus 3A is inoperable, 22 EDG cannot power bus 3A, and 138KV and 13.8KV offsite sources also cannot power bus 3A. 3.8.1 Condition H requires immediate entry into LCO 3.0.3 which requires actions to be initiated within 1 hour to place the unit in mode 3 within 7 hours.</p> <p>Determine 21 ABFP is inoperable and since 22 ABFP pump is also inoperable, per LCO 3.7.5 Condition C:</p> <ul style="list-style-type: none"> <li>○ Be in mode 3 in next six hours</li> </ul> <p><b><i>If desired, CRS can be prompted by Lead Evaluator that the OM has requested that the unit be brought to Mode 3 in 3 hours.</i></b></p>

Event Description: 480V Bus 3A faults. Team responds per AOP-480V-1 to stabilize the plant.		
Time	Position	Examinee's Actions or Behavior
	CRS	Enter Attachment 3 of 2-POP-2.1 Reactor Power Reduction Checklist or Enter 2-AOP-RSD-1 Supervise load reduction
	ATC	Determine shutdown reactivity plan Perform Boration to support load reduction <b>Note: BAST will have to be swapped prior to Boration</b> Lower Turbine load using the governor
	BOP	Perform actions and peer checks in support of Boration and Turbine load reduction
Lead Evaluator		When load reduction has been performed enough to observe reactivity additions and normal plant evolutions, direct the Booth Instructor to actuate trigger 2.  Proceed to the next event when the team diagnoses increased RCP Seal Return Flow.

Event Description: 21 RCP Seal #1 degrades. Rising seal return to about 5.1 gpm. Alarm annunciates at 5 gpm. Team implements AOP-RCP-1. Subsequently, leak rate increases to > 6 gpm requiring trip.		
Time	Position	Examinee's Actions or Behavior
	ATC/BOP	Diagnose rising #1 Seal Return on 21 RCP Perform ARPs for associated alarms <ul style="list-style-type: none"> <li>ARP-SF, 1-5, RCP No. 1 SEAL RETURN HIGH LOW FLOW</li> </ul> Perform actions as directed by the CRS
	CRS	Implement AOP-RCP-1, Reactor Coolant Pump Malfunction <ul style="list-style-type: none"> <li>Direct the actions of the crew</li> <li>Evaluate RCP trip criteria</li> <li>Determine a seal malfunction exists</li> <li>Notify SM that 8 hour shutdown is required</li> <li>Direct BOP to initiate data collection per Attachment 1</li> </ul>
Lead Evaluator		Directs Booth Operator to increase seal leakage to > 6 gpm
	ATC/BOP	Observe rising seal return flow Inform CRS when > 6 gpm
	CRS	Determine IAAT step 4.1 applies with seal return > 6 gpm <ul style="list-style-type: none"> <li>Provide team update on plan to trip reactor, stop 21 RCP and close 261A</li> <li>Direct RO/BOP to trip reactor, stop 21 RCP and close 261A</li> </ul> Implement E-0, Reactor Trip or Safety Injection
	ATC/BOP	Trip Reactor Verify Reactor trip Stop 21 RCP When 21 RCP has stopped, Close 261A
Lead Evaluator		Proceed to the next event when the team implements E-0

Event Description: Turbine upper left stop and control valve don't close requiring MSIVs manually closed. AFW flow cannot be established. Team implements E-0 and transitions to ES-0.1 and then to FR-H.1 and establishes Bleed and Feed.		
Time	Position	Examinee's Actions or Behavior
	CRS	Direct the actions of the crew Direct team to perform immediate actions of E-0 Transition to FR-H.1
	ATC	Checks Reactor tripped Checks Turbine Tripped <ul style="list-style-type: none"> <li>Attempts to manually trip turbine</li> <li>Manually closes all MSIVs</li> </ul> Checks SI actuated Attempts to start 23 ABFP <div style="position: absolute; top: 20px; right: 20px; transform: rotate(-15deg); font-family: cursive;">       - Turbine        Stop valves        that don't close        Stop &amp; Purge     </div>
	BOP	Checks 480V busses 2A, 5A, and 6A energized
EVALUATOR NOTE:		The RO may close MSIVs before Safety Injection occurs. If so, the team will transition to ES-0.1 and then FR-H.1. If auto SI occurs, then the team will go to FR-H.1 from E-0 step 7
	ALL	Determine AFW flow cannot be established and transition to FR-H.1 is required.
	CRS	Implement FR-H.1 Direct the actions of the crew Review Caution Criteria for Bleed and Feed
	ATC/RO	Check RCS pressure > than the highest SG Pressure and RCS temperature > 350 degrees F. Check the average of the three lowest WR SG Levels < 41% <ul style="list-style-type: none"> <li>Inform CRS when Bleed and Feed criteria met</li> </ul> <div style="position: absolute; right: 20px; top: 50px; font-family: cursive;">       Bleed     </div>

Event Description: Turbine upper left stop and control valve don't close requiring MSIVs manually closed. AFW flow cannot be established. Team implements E-0 and transitions to ES-0.1 and then to FR-H.1 and establishes Bleed and Feed.		
Time	Position	Examinee's Actions or Behavior
	<b>Critical Task</b>	WOG CT: FR-H.1--F <b>Establish RCS bleed and feed when the average of the three lowest SG Levels reach 41% WR</b>
	CRS	Immediately proceed to step 9 to establish bleed and feed
	BOP/RO	Stop all running RCPs Actuate SI if required
	ATC/BOP	Verify RCS Feed Path <ul style="list-style-type: none"> <li>• Check SI pumps running</li> <li>• Check SI Valve alignment</li> <li>• Reset SI</li> <li>• Reset Phase A and open 1228</li> </ul>
	ATC/BOP	Establish RCS Bleed Path <ul style="list-style-type: none"> <li>• Check power available to both PORV Block valves</li> <li>• Check both PORV Block Valves open</li> <li>• OPEN both PRZR PORVS (455C will not open)</li> <li>• Dispatch NPO to energize Rx Head Vent Valves at MCC 26A and 26B</li> <li>• Open both Reactor Head Vent Valves</li> </ul>
	<b>Critical Task</b>	<b>SITE SPECIFIC CT</b> <b>Open all reactor vessel head vent valves when less than both PORVs are available for RCS bleed path before resetting SI.</b>

Event Description: Turbine upper left stop and control valve don't close requiring MSIVs manually closed. AFW flow cannot be established. Team implements E-0 and transitions to ES-0.1 and then to FR-H.1 and establishes Bleed and Feed.		
Time	Position	Examinee's Actions or Behavior
	CRS	Check for available low pressure water source for S/Gs Direct BOP to perform E-0 steps 1-9 Continue attempts to establish secondary heat sink
Booth Instructor After the head vents are open		Depending upon previous requests from the CCR, perform one of the following: fix 23 ABFP 480V breaker or align ASSS power to 21 ABFP 1. Fix 23 ABFP 480V bkr: Request CCR place 23 ABFP control switch to pullout to allow breaker change out. From the Instructor Station Summary - Delete MOC-AFW002. NPO reports that the 480V breaker for 23 ABFP has been swapped with the spare breaker. Request CCR to attempt to start 23 ABFP 2. Align ASSS 440V power to 21 ABFP: Refer to SOP-ESP-1 section 4.11. Place EDC5 in "ALT" (Bus 3A P&ID EPS7). Notify CCR. When directed by CCR, close breaker at 12FD3 to start ABFP. (P&ID SWD4 breaker 12FD3-1B)
	CRS/ATC	Establish AFW flow from 21 or 23 ABFP Observe foldout page criteria for flow restoration Restore NR level in at least one SG to > 10% (27% if adverse VC) Check RCS temperature lowering Close Head Vent Valves
Evaluator Note:		At the lead evaluator's discretion, if the third critical task is required to complete the scenario set, continue until reactor head vent valves are closed. If the third critical task is not required or desired, then the lead evaluator may terminate the scenario after AFW flow is established.
Critical Task		WOG CT: FR-H.1--G  <b>Close all reactor vessel head vent valves before the end of the scenario</b>

Event Description: Turbine upper left stop and control valve don't close requiring MSIVs manually closed. AFW flow cannot be established. Team implements E-0 and transitions to ES-0.1 and then to FR-H.1 and establishes Bleed and Feed.		
<b>Time</b>	<b>Position</b>	<b>Examinee's Actions or Behavior</b>
	CRS ATC	<p>Determine if SI pumps can be stopped. When sub-cooling requirements are met:</p> <ul style="list-style-type: none"> <li>○ Close PORV</li> <li>○ Stop SI pump(s)</li> </ul>
Lead Evaluator		Terminate the scenario at the discretion of the Lead Evaluator when the appropriate number of critical tasks has been evaluated.