South Texas Project Electric Generating Station P.O. Box 289 Wadsworth, Texas 77483

August 2, 2010 NOC-AE-10002585 File No: G25, T07.03 10 CFR 50.55a

U. S. Nuclear Regulatory Commission Attention: Document Control Desk One White Flint North 11555 Rockville Pike Rockville, MD 20852-2738

South Texas Project
Unit 2
Docket No. STN 50-499
Inservice Inspection Summary Report – 2RE14

Attached are four copies of the South Texas Project Unit 2 summary report for inservice inspections performed prior to and during refueling outage 2RE14 completed in May 2010. This summary report satisfies the reporting requirements of ASME Code Section XI, Article IWA-6230.

There are no commitments in this report.

If there are any questions, please contact either Philip L. Walker at  $(361)\ 972-8392$  or me at  $(361)\ 972-7904$ 

Marco Ruyalcaba

Manager,

Testing/Programs

mk

Attachment: Summary Report for 2RE14 Inservice Inspection of Unit 2 South Texas Project

Electric Generating Station (4 copies)

STI No: 32718273

CC:

(paper copy) \*

Regional Administrator, Region IV U. S. Nuclear Regulatory Commission 612 East Lamar Blvd, Suite 400 Arlington, Texas 76011-4125

Mohan C. Thadani Senior Project Manager U.S. Nuclear Regulatory Commission One White Flint North (MS 8B1A) 11555 Rockville Pike Rockville, MD 20852

Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 289, Mail Code: MN116
Wadsworth, TX 77483

C. M. Canady
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

(electronic copy)

A. H. Gutterman, Esquire Morgan, Lewis & Bockius LLP

Mohan C. Thadani U. S. Nuclear Regulatory Commission

John Ragan Catherine Callaway Jim von Suskil NRG South Texas LP

Ed Alarcon Kevin Pollo Richard Pena City Public Service

Jon C. Wood Cox Smith Matthews

C. Mele City of Austin


Richard A. Ratliff Texas Department of State Health Services

Alice Rogers Texas Department of State Health Services

<sup>\*</sup> One copy of the attachment is provided.

Attachment NOC-AE-10002585 Page 1 of 8

# SUMMARY REPORT for the 2RE14 INSERVICE INSPECTION of UNIT 2 SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION



## STP NUCLEAR OPERATING COMPANY April 2010

#### **COVER SHEET**

#### **2RE14 INSERVICE INSPECTION SUMMARY REPORT**

#### SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION, UNIT 2

P.O. BOX 289

WADSWORTH, TEXAS 77483

**USNRC DOCKET NO: 50-499** 

**OPERATING LICENSE NO: NPF-80** 

**COMMERCIAL OPERATION DATE: JUNE 19, 1989** 

J. Williams Engineer

Reviewed by:

L. Spiess, Supervising Engineer

AN BOJAIN

#### **SCOPE**

## COMPONENT SUPPORTS, REPAIR AND REPLACEMENT, SYSTEM PRESSURE TESTS AND WELD INSPECTION PROGRAMS (IWB, IWC, IWD, IWL)

The examinations summarized in this report were performed in accordance with the 1989 Edition with no Addenda of the ASME Code, Section XI that is applicable to the South Texas Project, Unit 2, second tenyear interval (10/19/2000-10/18/2010), third period (10/19/2007-10/18/2010). This report covers selected ASME Code Class 1, 2 & 3 Systems/Components. This report is documented in accordance with the requirements of ASME Section XI Code Case N-532-4.

Examinations and tests required by the Code are scheduled in accordance with "Inspection Program B" as defined in IWB-2412 for ASME Code Class 1 Systems/Components, IWC-2412 for ASME Code Class 2 Systems/Components and IWD-2412 for ASME Code Class 3 Systems/Components.

The ASME Code Class 1 components were examined as prescribed by Table IWB-2500-1, and the applicable Examination Categories, which established the examination frequency at each refueling outage. The ASME Code Class 2 Systems/Components were examined in accordance with Table IWC-2500-1, Examination Categories. The ASME Code Class 3 Systems/Components were examined in accordance with Table IWD-2500-1, Examination Categories. Component Supports were examined in accordance with Table 2500-1 of Code Case N-491-2.

The ASME Code Class CC components were examined as prescribed by Table IWL-2500-1; ASME 2004 Edition No addenda subsection IWL. 20<sup>th</sup> Year examinations were completed under Surveillance ST: 88000349, (0PSP09-TD-001 Containment Tendon Test/End Anchorage and Adjustment Concrete Inspection.)

AN 3/2/2),0

Plant South Texas Project Electric Generating Station  Unit No. 2 Commercial service date JUNE 19, 1989 Refueling outage no. 2RE14  (If applicable)  Current inspection interval IWB, IWC, IWD, IWF - 2 <sup>rd</sup> : IWE - 2 <sup>rd</sup> , IWL-20 <sup>th</sup> Year  (1 <sup>th</sup> , 2 <sup>rd</sup> , 3 <sup>rd</sup> , 4 <sup>th</sup> , other)  Current inspection period IWB, IWC, IWD, IWF - 3 <sup>rd</sup> ; IWE - 1 <sup>th</sup> Edition and Addenda of Section XI applicable to the inspection plan 1989 No Addenda, IWE & IWL-2004 Edition and Addenda of Section XI applicable to repairs/replacement activities, if different than the inspection plan Code Cases used: N-722, N-729-1  CERTIFICATE OF CONFORMANCE  I certify that (a) the statements made in this report are correct; (b) the examinations and tests meet the Inspection P by the ASME Code, Section XI, and (c) the repair/replacement activities and evaluations supporting the completion 2RE14 conform to the requirements of Section XI.  (Refueling outage number)  Signed Testing/Programs Engineer Date 8/02/2010  CERTIFICATE OF INSERVICE INSPECTION	
Current inspection interval	
Current inspection period	
Edition and Addenda of Section XI applicable to the inspection plan 1989 No Addenda, IWE & IWL-2004 Edition and Addenda of Section XI applicable to repairs/replacement activities, if different than the inspection plan Code Cases used: N-722, N-729-1  CERTIFICATE OF CONFORMANCE  I certify that (a) the statements made in this report are correct; (b) the examinations and tests meet the Inspection Plan 2RE14 conform to the requirements of Section XI. (Refueling outage number)  Signed Testing/Programs Engineer Date 8/02/2010  CERTIFICATE OF INSERVICE INSPECTION	
Date and revision of inspection plan  September 2009/ Revision 5, Supplement 2  Edition and Addenda of Section XI applicable to repairs/replacement activities, if different than the inspection plan Code Cases used:  N-722, N-729-1  CERTIFICATE OF CONFORMANCE  I certify that (a) the statements made in this report are correct; (b) the examinations and tests meet the Inspection P by the ASME Code, Section XI; and (c) the repair/replacement activities and evaluations supporting the completion 2RE14  conform to the requirements of Section XI.  (Refueling outage number)  Signed  Testing/Programs Engineer  Date  8/02/2010  CERTIFICATE OF INSERVICE INSPECTION	on No Addenda
Certify that (a) the statements made in this report are correct; (b) the examinations and tests meet the Inspection Plan  Code Cases used:  CERTIFICATE OF CONFORMANCE  I certify that (a) the statements made in this report are correct; (b) the examinations and tests meet the Inspection P  by the ASME Code, Section XI; and (c) the repair/replacement activities and evaluations supporting the completion  2RE14  Conform to the requirements of Section XI.  (Refueling outage number)  Signed  Testing/Programs Engineer  Date 8/02/2010  CERTIFICATE OF INSERVICE INSPECTION	
CERTIFICATE OF CONFORMANCE  I certify that (a) the statements made in this report are correct; (b) the examinations and tests meet the Inspection P by the ASME Code, Section XI; and (c) the repair/replacement activities and evaluations supporting the completio 2RE14 conform to the requirements of Section XI.  (Refueling outage number)  Signed Testing/Programs Engineer Date 8/02/2010    (Owner or Owner's Designee, Title)	
CERTIFICATE OF CONFORMANCE  I certify that (a) the statements made in this report are correct; (b) the examinations and tests meet the Inspection P by the ASME Code, Section XI; and (c) the repair/replacement activities and evaluations supporting the completion 2RE14 conform to the requirements of Section XI.  (Refueling outage number)  Signed Testing/Programs Engineer Date 8/02/2010  (Owner or Owner's Designee, Title)	<del></del>
I certify that (a) the statements made in this report arc correct; (b) the examinations and tests meet the Inspection P by the ASME Code, Section XI; and (c) the repair/replacement activities and evaluations supporting the completion 2RE14 conform to the requirements of Section XI.  (Refueling outage number)  Signed Testing/Programs Engineer Date 8/02/2010  (Owner or Owner's Designee, Title)	
I certify that (a) the statements made in this report arc correct; (b) the examinations and tests meet the Inspection P by the ASME Code, Section XI; and (c) the repair/replacement activities and evaluations supporting the completion 2RE14 conform to the requirements of Section XI.  (Refueling outage number)  Signed Testing/Programs Engineer Date 8/02/2010  (Owner or Owner's Designee, Title)	
	<del>.</del>
1, the undersigned, holding a valid commission issued by the National Board of Boiler and pressure Vessel Inspectors and the Sta	te or Province of
Texas and employed by ABS Boiler & Marine Insurance Co. of Houston, Texas have inspected the it this Owner's Activity Report, and state that, to the best of my knowledge and belief, the Owner has performed all activities report in accordance with the requirements of Section XI.  By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning activities and evaluation described this report. Furthermore, neither the inspector nor his employer shall be liable for any personal injury or property damage or a loss of any kind arising from the connected with this inspection.	presented by this  ng the repairs/
Market Commissions 13 - 756	
Inspector's Signature P. W. E. M. F. M. F. M. F. Mational Board, State, Province, and Endorsements	Pitting and the state of the st

ANI! / B/2/20

#### TABLE I

### ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRE EVALUATION FOR CONTINUED SERVICE

#### 2RE14. April 2010

Examination Category	Items Number	Item Description	Evaluation description
		See Note #1	

#### NOTES:

- 1. No items found with flaws or relevant conditions that required evaluation for continued service.
- 2. Surveillance procedure OPSP11-RC-0015, ASME Section XI Inservice Inspection, documents Inservice Inspection Activities during 2RE14.

TABLE 2

#### ABSTRACT OF <u>REPAIRS/REPLACEMENT</u> ACTIVITIES REQUIRED FOR CONTINUED SERVICE 2RE14 April 2010

Code	Repair, Replacement, or Corrective			Date completed	Répair/Replacement
Class	Measure	Item Description	Description of Work	•	Plan Number
3	Replacement	Valve	Replaced valve	01/20/2009	2-8-022
-3	Replacement	Valve	Replaced valve	04/21/2009	2-8-041
2	Replacement	Valve	Replaced valve clamp cap screws	12/04/2008	2-8-042
3	Replacement	Pump	Replaced Seal and Bearings	01/21/2009	2-8-055
3	Replacement	Valve	Replaced valve.	01/20/2009	2-8-057
3	Repair	Valve	Machined Check Valve Plates	11/13/2009	2-8-060
3	Replacement	Strainer	Replace Cover bolting	01/22/2009	2-9-004
3	Replacement	Flange	Replaced flange	04/24/2009	2-9-005
3	Replacement	Valve	Replaced Hinge Pin Bushings & Stop Pin Bushings	06/15/2009	2-9-007
-3	Replacement	Flange	Replaced Blind Flange	04/24/2009	2-9-009
3	Replacement	Pump	Replaced Pump with Product Lubricated Pump	04/24/2010	2-9-010
3	Replacement	Seismic Supports	Modification of Seismic Supports	04/24/2010	2-9-011
3	Replacement	Pipe	Replaced partial piping spool	04/24/2009	2-9-013
3	Replacement	Valve	Replaced valve	04/22/2009	2-9-014
2	Repair	Door Seal	Repair seal with Helicoil repair	09/20/2009	2-9-015
<b>'2</b> '	Repair	Door Seal	Repair seal with Helicoil repair	07/09/2009	2-9-016
3	Replacement	Valve	Replaced damage Valve parts/ Machined Valve Body	07/02/2009	2-9-017 R-1
3	Replacement	Pump	Replaced gland seals and plates	07/10/2009	2-9-018
-2	Replacement	Valve	Replaced Pilot Poppet	04/16/2010	2-9-027
2	Replacement	Valve	Replaced Pilot Poppet	04/13/2010	2-9-028
2.	Replacement	Valve	Replaced Pilot Poppet	04/15/2010	2-9-029
1	Replacement	Pump	Replaced Seal Housing bolts	09/22/2009	2-9-030
2	Replacement	Valve	Replaced Valve Plug, Seat Ring and Bonnet Seal Ring	04/23/2010	2-9-033
2	Replacement	Gaskets/Fasteners	Replaced inner & outer HX gaskets, Bonnet Flange	04/09/2010	2-9-037
			fastener, inlet & outlet Fasteners and gaskets		
3	Replacement	Pump	Replaced leaking drain plug	12/07/2009	2-9-038
ì	Replacement	Spring Can	Replaced Spring Can RC-2123-SH0002	04/22/2010	2-9-039
1	Repair	Spring Can	Weld Build Up of Can housing and indicator	04/17/2010	2-9-041
. 2	Replacement.	Valve	Replaced code parts during valve internals inspection	04/13/2010	2-9-043



# TABLE 2. ABSTRACT OF <u>REPAIRS/REPLACEMENT</u> ACTIVITIES REQUIRED FOR CONTINUED SERVICE 2RE14 April 2010

Code Class	Repair, Replacement, or Corrective Measure	Item Description	Description of Work	Date completed	Repair/Replacement Plan Number
1	Repair	Valve	Seal Weld Repair	04/15/2010	2-9-044
1	Replacement	Valve	Replaced PSV with rebuilt tested PSV	04/24/2010	2-9-045
1	Replacement	Valve	Replaced PSV with rebuilt tested PSV	04/24/2010	2-9-046
1	Replacement	Valve	Replaced PSV with rebuilt tested PSV	04/22/2010	2-9-047
1	Replacement	Valve	Replaced Valve	04/12/2010	2-9-048
1	Replacement	Valve	Replaced Seals	04/26/2009	2-9-053
2	Replacement	Pump	Replaced Seal Glands	02/24/2010	2-9-054
2	Replacement	Valve	Replaced Valve Disc	04/20/2010	2-9-055
2	Replacement	Pump	Replaced Inboard & Outboard Seals	03/04/2010	2-9-057
3	Repair	Pipe	Repair ECW 30" pipe	12/25/2009	2-9-059
2	Replacement	Valve	Replaced Valve	04/10/2010	2-10-002
1	Replacement	Strut Support	Replaced Rigid Sway Strut RC-2002-HL5004	04/13/2010	2-10-003
1	Replacement	Strut Support	Replaced Rigid Sway Strut RC	04/13/2010	2-10-004
3.	Replacement	Valve	Replaced PSV with new tested PSV	02/02/2010	2-10-005
3	Replacement	Pump	Replaced Upper Bearing oil cooler & Motor Air Coolers	04/22/2010	2-10-006
1	Replacement	Pump	Replaced #1 Seal Housing Bolting/ #2C RCP	04/07/2010	2-10-008
1	Replacement	RRVH	Install CETNA Housing Nozzles 75,76,77 & 78	04/20/2010	2-10-009
1	Replacement	RRVH	Harvesting of code materials from old RVH for installation on RRVH	04/23/2010	2-10-011
1	Replacement	RRVH	Traveler with admin work order to document replacement of Unit-2 Reactor Closure Head & Appurtenances	04/23/2010	2-10-012
1	Replacement	RRVH	Remove and store ORVH ASME Code Nameplate	04/26/2010	2-10-013 R-1
1	Replacement	RŖVĦ	Harvesting fo previously installed CENTA Compression Collars for use during CENTA reassembly on RRVH in 2RE14	04/29/2010	2-10-014
ī	Replacement	RRVH	Installation of RRVH CETNA Seal Assemblies	04/24/2010	2-10-015



# ABSTRACT OF REPAIRS/REPLACEMENT ACTIVITIES REQUIRED FOR CONTINUED SERVICE 2RE14 April:2010


Attachment NOC-AE-10002585 Page 8 of 8

Code Class	Repair, Replacement, or Corrective Measure	Item Description	Description of Work	Date completed	Repair/Replacement Plan Number
ì	Replacement.	RRVH	Install new design IDD Housing Seal Plug & Nut assembly	04/25/2010	2-10-016
1	Replacement	Snubber	Replaced Mech Snubber	04/13/2010	2-10-021
`2	Replacement	Valve	Replaced Valve	04/22/2010	2-10-022
2	Replacement	Valve	Replaced lower body thread plug and seal welded plug	04/25/2010	2-10-027

AN/1 / 1/2/10

Attachment NOC-AE-10002585 Page 1 of 8

# SUMMARY REPORT for the 2RE14 INSERVICE INSPECTION of UNIT 2 SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION



## STP NUCLEAR OPERATING COMPANY April 2010

#### **COVER SHEET**

#### **2RE14 INSERVICE INSPECTION SUMMARY REPORT**

#### SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION, UNIT 2

P.O. BOX 289

WADSWORTH, TEXAS 77483

**USNRC DOCKET NO: 50-499** 

**OPERATING LICENSE NO: NPF-80** 

**COMMERCIAL OPERATION DATE: JUNE 19, 1989** 

Prepared by: \_\_\_\_\_

J. Williams/Engineer

Reviewed hy-

Spiess, Supervising Engineer

AN Byzlx

#### **SCOPE**

## COMPONENT SUPPORTS, REPAIR AND REPLACEMENT, SYSTEM PRESSURE TESTS AND WELD INSPECTION PROGRAMS (IWB, IWC, IWD, IWL)

The examinations summarized in this report were performed in accordance with the 1989 Edition with no Addenda of the ASME Code, Section XI that is applicable to the South Texas Project, Unit 2, second tenyear interval (10/19/2000-10/18/2010), third period (10/19/2007-10/18/2010). This report covers selected ASME Code Class 1, 2 & 3 Systems/Components. This report is documented in accordance with the requirements of ASME Section XI Code Case N-532-4.

Examinations and tests required by the Code are scheduled in accordance with "Inspection Program B" as defined in IWB-2412 for ASME Code Class 1 Systems/Components, IWC-2412 for ASME Code Class 2 Systems/Components and IWD-2412 for ASME Code Class 3 Systems/Components.

The ASME Code Class 1 components were examined as prescribed by Table IWB-2500-1, and the applicable Examination Categories, which established the examination frequency at each refueling outage. The ASME Code Class 2 Systems/Components were examined in accordance with Table IWC-2500-1, Examination Categories. The ASME Code Class 3 Systems/Components were examined in accordance with Table IWD-2500-1, Examination Categories. Component Supports were examined in accordance with Table 2500-1 of Code Case N-491-2.

The ASME Code Class CC components were examined as prescribed by Table IWL-2500-1; ASME 2004 Edition No addenda subsection IWL. 20<sup>th</sup> Year examinations were completed under Surveillance ST: 88000349, (0PSP09-TD-001 Containment Tendon Test/End Anchorage and Adjustment Concrete Inspection.)

AN 3/2/10

FORM OAR-1 OWNER'S ACTIVITY REPORT (Code Case N-532-4)
Report Nunmber OAR-2RE14
Plant South Texas Project Electric Generating Station
Unit No. 2 Commercial service date JUNE 19, 1989 Refueling outage no. 2RE14 (If applicable)
Current inspection interval IWB, IWC, IWD, IWF - 2 <sup>nd</sup> ; IWE -2 <sup>nd</sup> , IWL-20 <sup>th</sup> Year
(1 <sup>st</sup> , 2 <sup>nd</sup> , 3 <sup>rd</sup> ) [IWB, IWC, IWD, IWF - 3 <sup>rd</sup> ]; IWE -1 <sup>st</sup> ]  (1 <sup>st</sup> , 2 <sup>nd</sup> , 3 <sup>rd</sup> )
Edition and Addenda of Section XI applicable to the inspection plan 1989 No Addenda, IWE & IWL-2004 Edition No Addenda
Date and revision of inspection plan September 2009/ Revision 5, Supplement 2
Edition and Addenda of Section XI applicable to repairs/replacement activities, if different than the inspection plan  Code Cases used:  N-722, N-729-1
N-122, N-127-1
I certify that (a) the statements made in this report are correct; (b) the examinations and tests meet the Inspection Plan as required by the ASME Code, Section XI; and (c) the repair/replacement activities and evaluations supporting the completion of   2RE14
CERTIFICATE OF INSERVICE INSPECTION
I, the undersigned, holding a valid commission issued by the National Board of Boiler and pressure Vessel Inspectors and the State or Province of Texas and employed by ABS Boiler & Marine Insurance Co. of Houston, Texas have inspected the items described in this Owner's Activity Report, and state that, to the best of my knowledge and belief, the Owner has performed all activities represented by this report in accordance with the requirements of Section XI.  By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repairs/ replacements activities and evaluation described this report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from the connected with this inspection.  Commissions  Inspector's Signature R. M.E. M. A. W. M.

8/1/2/20

### ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRE EVALUATION FOR CONTINUED SERVICE

#### 2RE14 April 2010

Examination Category	Items Number	Item Description	Evaluation description
		See Note #1	
	·		

#### NOTES:

- 1. No items found with flaws or relevant conditions that required evaluation for continued service.
- 2. Surveillance procedure OPSP11-RC-0015, ASME Section XI Inservice Inspection, documents Inservice Inspection Activities during 2RE14.

## ABSTRACT OF <u>REPAIRS/REPLACEMENT</u> ACTIVITIES REQUIRED FOR CONTINUED SERVICE 2RE14 April 2010

Code	Repair, Replacement, or Corrective			Date completed	Repair/Replacement
Class	Measure	Item Description	Description of Work		Plan Number
3	Replacement	Valve	Replaced valve	01/20/2009	2-8-022
3	Replacement	Valve	Replaced valve	04/21/2009	2-8-041
2	Replacement	Valve	Replaced valve clamp cap screws	12/04/2008	2-8-042
3	Replacement	Pump	Replaced Seal and Bearings	01/21/2009	2-8-055
3	Replacement	Valve	Replaced valve	01/20/2009	2-8-057
3	Repair	Valve	Machined Check Valve Plates	11/13/2009	2-8-060
3	Replacement	Strainer	Replace Cover bolting	01/22/2009	2-9-004
3	Replacement	Flange	Replaced flange	04/24/2009	2-9-005
3	Replacement	Valve	Replaced Hinge Pin Bushings & Stop Pin Bushings	06/15/2009	2-9-007
3	Replacement	Flange	Replaced Blind Flange	04/24/2009	2-9-009
3	Replacement	Pump	Replaced Pump with Product Lubricated Pump	04/24/2010	2-9-010
3	Replacement	Seismic Supports	Modification of Seismic Supports	04/24/2010	2-9-011
3	Replacement	Pipe	Replaced partial piping spool	04/24/2009	2-9-013
3	Replacement	Valve	Replaced valve	04/22/2009	2-9-014
2	Repair	Door Seal	Repair seal with Helicoil repair	09/20/2009	2-9-015
2	Repair	Door Seal	Repair seal with Helicoil repair	07/09/2009	2-9-016
3	Replacement	Valve	Replaced damage Valve parts/ Machined Valve Body	07/02/2009	2-9-017 R-1
3	Replacement	Pump	Replaced gland seals and plates	07/10/2009	2-9-018
2	Replacement	Valve	Replaced Pilot Poppet	04/16/2010	2-9-027
2	Replacement	Valve	Replaced Pilot Poppet	04/13/2010	2-9-028
2	Replacement	Valve	Replaced Pilot Poppet	04/15/2010	2-9-029
1	Replacement	Pump	Replaced Seal Housing bolts	09/22/2009	2-9-030
2	Replacement	Valve	Replaced Valve Plug, Seat Ring and Bonnet Seal Ring	04/23/2010	2-9-033
2	Replacement	Gaskets/Fasteners	Replaced inner & outer HX gaskets, Bonnet Flange	04/09/2010	2-9-037
			fastener, inlet & outlet Fasteners and gaskets		
3	Replacement	Pump	Replaced leaking drain plug	12/07/2009	2-9-038
1	Replacement	Spring Can	Replaced Spring Can RC-2123-SH0002	04/22/2010	2-9-039
1	Repair	Spring Can	Weld Build Up of Can housing and indicator	04/17/2010	2-9-041
2	Replacement	Valve	Replaced code parts during valve internals inspection	04/13/2010	2-9-043



# TABLE 2 ABSTRACT OF REPAIRS/REPLACEMENT ACTIVITIES REQUIRED FOR CONTINUED SERVICE 2RE14 April 2010

Code Class	Repair, Replacement, or Corrective Measure	Item Description	Description of Work	Date completed	Repair/Replacement Plan Number
1	Repair	Valve	Seal Weld Repair	04/15/2010	2-9-044
1	Replacement	Valve	Replaced PSV with rebuilt tested PSV	04/24/2010	2-9-045
1	Replacement	Valve	Replaced PSV with rebuilt tested PSV	04/24/2010	2-9-046
i	Replacement	Valve	Replaced PSV with rebuilt tested PSV	04/22/2010	2-9-047
1	Replacement	Valve	Replaced Valve	04/12/2010	2-9-048
1	Replacement	Valve	Replaced Seals	04/26/2009	2-9-053
2	Replacement	Pump	Replaced Seal Glands	02/24/2010	2-9-054
2	Replacement	Valve	Replaced Valve Disc	04/20/2010	2-9-055
2	Replacement	Pump	Replaced Inboard & Outboard Seals	03/04/2010	2-9-057
3	Repair	Pipe	Repair ECW 30" pipe	12/25/2009	2-9-059
2	Replacement	Valve	Replaced Valve	04/10/2010	2-10-002
1	Replacement	Strut Support	Replaced Rigid Sway Strut RC-2002-HL5004	04/13/2010	2-10-003
1	Replacement	Strut Support	Replaced Rigid Sway Strut RC	04/13/2010	2-10-004
3	Replacement	Valve	Replaced PSV with new tested PSV	02/02/2010	2-10-005
3	Replacement	Pump	Replaced Upper Bearing oil cooler & Motor Air Coolers	04/22/2010	2-10-006
1	Replacement	Pump	Replaced #1 Seal Housing Bolting/ #2C RCP	04/07/2010	2-10-008
1	Replacement	RRVH	Install CETNA Housing Nozzles 75,76,77 & 78	04/20/2010	2-10-009
1	Replacement	RRVH	Harvesting of code materials from old RVH for installation on RRVH	04/23/2010	2-10-011
1	Replacement	RRVH	Traveler with admin work order to document replacement of Unit-2 Reactor Closure Head & Appurtenances	04/23/2010	2-10-012
1	Replacement	RRVH	Remove and store ORVH ASME Code Nameplate	04/26/2010	2-10-013 R-1
1	Replacement	RRVH	Harvesting fo previously installed CENTA Compression Collars for use during CENTA reassembly on RRVH in 2RE14	04/29/2010	2-10-014
1	Replacement	RRVH	Installation of RRVH CETNA Seal Assemblies	04/24/2010	2-10-015



#### ABSTRACT OF <u>REPAIRS/REPLACEMENT</u> ACTIVITIES REQUIRED FOR CONTINUED SERVICE 2RE14 April 2010


Attachment NOC-AE-10002585 Page 8 of 8

Code Class	Repair, Replacement, or Corrective Measure	Item Description	Description of Work	Date completed	Repair/Replacement Plan Number
1	Replacement	RRVH	Install new design IDD Housing Seal Plug & Nut assembly	04/25/2010	2-10-016
1	Replacement	Snubber	Replaced Mech Snubber	04/13/2010	2-10-021
2_	Replacement	Valve	Replaced Valve	04/22/2010	2-10-022
2	Replacement	Valve	Replaced lower body thread plug and seal welded plug	04/25/2010	2-10-027

AN/ A/ 2/10

Attachment NOC-AE-10002585 Page 1 of 8

# SUMMARY REPORT for the 2RE14 INSERVICE INSPECTION of UNIT 2 SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION



## STP NUCLEAR OPERATING COMPANY April 2010

#### **COVER SHEET**

#### **2RE14 INSERVICE INSPECTION SUMMARY REPORT**

#### SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION, UNIT 2

P.O. BOX 289

**WADSWORTH, TEXAS 77483** 

USNRC DOCKET NO: 50-499

**OPERATING LICENSE NO: NPF-80** 

**COMMERCIAL OPERATION DATE: JUNE 19, 1989** 

Prepared by: \_

J. Williams/Engineer

Reviewed by:

Spiess, Supervising Engineer

AN Blair

#### **SCOPE**

## COMPONENT SUPPORTS, REPAIR AND REPLACEMENT, SYSTEM PRESSURE TESTS AND WELD INSPECTION PROGRAMS (IWB, IWC, IWD, IWL)

The examinations summarized in this report were performed in accordance with the 1989 Edition with no Addenda of the ASME Code, Section XI that is applicable to the South Texas Project, Unit 2, second tenyear interval (10/19/2000-10/18/2010), third period (10/19/2007-10/18/2010). This report covers selected ASME Code Class 1, 2 & 3 Systems/Components. This report is documented in accordance with the requirements of ASME Section XI Code Case N-532-4.

Examinations and tests required by the Code are scheduled in accordance with "Inspection Program B" as defined in IWB-2412 for ASME Code Class 1 Systems/Components, IWC-2412 for ASME Code Class 2 Systems/Components and IWD-2412 for ASME Code Class 3 Systems/Components.

The ASME Code Class 1 components were examined as prescribed by Table IWB-2500-1, and the applicable Examination Categories, which established the examination frequency at each refueling outage. The ASME Code Class 2 Systems/Components were examined in accordance with Table IWC-2500-1, Examination Categories. The ASME Code Class 3 Systems/Components were examined in accordance with Table IWD-2500-1, Examination Categories. Component Supports were examined in accordance with Table 2500-1 of Code Case N-491-2.

The ASME Code Class CC components were examined as prescribed by Table IWL-2500-1; ASME 2004 Edition No addenda subsection IWL. 20<sup>th</sup> Year examinations were completed under Surveillance ST: 88000349, (0PSP09-TD-001 Containment Tendon Test/End Anchorage and Adjustment Concrete Inspection.)

AN 3/2),0

FORM OAR-1 OWNER'S ACTIVITY REPORT (Code Case N-532-4)
Report Nunmber OAR-2RE14
Plant South Texas Project Electric Generating Station
Unit No. 2 Commercial service date JUNE 19, 1989 Refueling outage no. 2RE14 (If applicable)
Current inspection interval IWB, IWC, IWD, IWF - 2 <sup>nd</sup> ; IWE -2 <sup>nd</sup> , IWL-20 <sup>th</sup> Year  (1 <sup>st</sup> , 2 <sup>nd</sup> , 3 <sup>rd</sup> , 4 <sup>th</sup> , other)
Current inspection period IWB, IWC, IWD, IWF - 3 <sup>rd</sup> ; IWE -1 <sup>st</sup> ; IWE -1 <sup>st</sup>
Edition and Addenda of Section XI applicable to the inspection plan 1989 No Addenda, IWE & IWL-2004 Edition No Addenda
Date and revision of inspection plan September 2009/ Revision 5, Supplement 2
Edition and Addenda of Section XI applicable to repairs/replacement activities, if different than the inspection plan
Code Cases used: N-722, N-729-1
I certify that (a) the statements made in this report are correct; (b) the examinations and tests meet the Inspection Plan as required by the ASME Code, Section XI; and (c) the repair/replacement activities and evaluations supporting the completion of   2RE14
CERTIFICATE OF INSERVICE INSPECTION
I, the undersigned, holding a valid commission issued by the National Board of Boiler and pressure Vessel Inspectors and the State or Province of Texas and employed by ABS Boiler & Marine Insurance Co. of Houston, Texas have inspected the items described in this Owner's Activity Report, and state that, to the best of my knowledge and belief, the Owner has performed all activities represented by this report in accordance with the requirements of Section XI.  By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repairs/ replacements activities and evaluation described this report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from the connected with this inspection.  Commissions  National Board, State, Province, and Endorsements
Date 08/02/2010

AN/1/2/20

### ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRE EVALUATION FOR CONTINUED SERVICE

#### 2RE14 April 2010

Examination Category	Items Number	Item Description	Evaluation description
		See Note #1	
<u>.</u> .			

#### NOTES:

- 1. No items found with flaws or relevant conditions that required evaluation for continued service.
- 2. Surveillance procedure OPSP11-RC-0015, ASME Section XI Inservice Inspection, documents Inservice Inspection Activities during 2RE14.

1911/1 16/2/10

## ABSTRACT OF <u>REPAIRS/REPLACEMENT</u> ACTIVITIES REQUIRED FOR CONTINUED SERVICE 2RE14 April 2010

Code Class	Repair, Replacement, or Corrective Measure	Item Description	Description of Work	Date completed	Repair/Replacement Plan Number
3		Valve	Replaced valve	01/20/2009	2-8-022
	Replacement	Valve	_ ^ · · _ · _ · _ · _ · _ · _ · _ · _	04/21/2009	2-8-041
3	Replacement	<del> </del>	Replaced valve		
2	Replacement	Valve	Replaced valve clamp cap screws	12/04/2008	2-8-042
3	Replacement	Pump	Replaced Seal and Bearings	01/21/2009	2-8-055
3	Replacement	Valve	Replaced valve	01/20/2009	2-8-057
3	Repair	Valve	Machined Check Valve Plates	11/13/2009	2-8-060
3	Replacement	Strainer	Replace Cover bolting	01/22/2009	2-9-004
3	Replacement	Flange	Replaced flange	04/24/2009	2-9-005
3	Replacement	Valve	Replaced Hinge Pin Bushings & Stop Pin Bushings	06/15/2009	2-9-007
3	Replacement	Flange	Replaced Blind Flange	04/24/2009	2-9-009
3	Replacement	Pump	Replaced Pump with Product Lubricated Pump	04/24/2010	2-9-010
3	Replacement	Seismic Supports	Modification of Seismic Supports	04/24/2010	2-9-011
3	Replacement	Pipe	Replaced partial piping spool	04/24/2009	2-9-013
3	Replacement	Valve	Replaced valve	04/22/2009	2-9-014
2	Repair	Door Seal	Repair seal with Helicoil repair	09/20/2009	2-9-015
2	Repair	Door Seal	Repair seal with Helicoil repair	07/09/2009	2-9-016
3	Replacement	Valve	Replaced damage Valve parts/ Machined Valve Body	07/02/2009	2-9-017 R-1
3	Replacement	Pump	Replaced gland seals and plates	07/10/2009	2-9-018
2	Replacement	Valve	Replaced Pilot Poppet	04/16/2010	2-9-027
2	Replacement	Valve	Replaced Pilot Poppet	04/13/2010	2-9-028
2	Replacement	Valve	Replaced Pilot Poppet	04/15/2010	2-9-029
1	Replacement	Pump	Replaced Seal Housing bolts	09/22/2009	2-9-030
2	Replacement	Valve	Replaced Valve Plug, Seat Ring and Bonnet Seal Ring	04/23/2010	2-9-033
2	Replacement	Gaskets/Fasteners	Replaced inner & outer HX gaskets, Bonnet Flange	04/09/2010	2-9-037
_			fastener, inlet & outlet Fasteners and gaskets	* ****	
3	Replacement	Pump	Replaced leaking drain plug	12/07/2009	2-9-038
1	Replacement	Spring Can	Replaced Spring Can RC-2123-SH0002	04/22/2010	2-9-039
1	Repair	Spring Can	Weld Build Up of Can housing and indicator	04/17/2010	2-9-041
2	Replacement	Valve	Replaced code parts during valve internals inspection	04/13/2010	2-9-043



Attachment NOC-AE-10002585 Page 7 of 8

# TABLE 2 ABSTRACT OF REPAIRS/REPLACEMENT ACTIVITIES REQUIRED FOR CONTINUED SERVICE 2RE14 April 2010

Code Class	Repair, Replacement, or Corrective Measure	Item Description	Description of Work	Date completed	Repair/Replacement Plan Number
1	Repair	Valve	Seal Weld Repair	04/15/2010	2-9-044
ı	Replacement	Valve	Replaced PSV with rebuilt tested PSV	04/24/2010	2-9-045
i	Replacement	Valve	Replaced PSV with rebuilt tested PSV	04/24/2010	2-9-046
1	Replacement	Valve	Replaced PSV with rebuilt tested PSV	04/22/2010	2-9-047
1	Replacement	Valve	Replaced Valve	04/12/2010	2-9-048
1	Replacement	Valve	Replaced Seals	04/26/2009	2-9-053
2	Replacement	Pump	Replaced Seal Glands	02/24/2010	2-9-054
2	Replacement	Valve	Replaced Valve Disc	04/20/2010	2-9-055
2	Replacement	Pump	Replaced Inboard & Outboard Seals	03/04/2010	2-9-057
3	Repair	Pipe	Repair ECW 30" pipe	12/25/2009	2-9-059
2	Replacement	Valve	Replaced Valve	04/10/2010	2-10-002
1	Replacement	Strut Support	Replaced Rigid Sway Strut RC-2002-HL5004	04/13/2010	2-10-003
1	Replacement	Strut Support	Replaced Rigid Sway Strut RC	04/13/2010	2-10-004
3	Replacement	Valve	Replaced PSV with new tested PSV	02/02/2010	2-10-005
3	Replacement	Pump	Replaced Upper Bearing oil cooler & Motor Air Coolers	04/22/2010	2-10-006
1	Replacement	Pump	Replaced #1 Seal Housing Bolting/ #2C RCP	04/07/2010	2-10-008
l	Replacement	RRVH	Install CETNA Housing Nozzles 75,76,77 & 78	04/20/2010	2-10-009
1	Replacement	RRVH	Harvesting of code materials from old RVH for installation on RRVH	04/23/2010	2-10-011
1	Replacement	RRVH	Traveler with admin work order to document replacement of Unit-2 Reactor Closure Head & Appurtenances	04/23/2010	2-10-012
1	Replacement	RRVH	Remove and store ORVH ASME Code Nameplate	04/26/2010	2-10-013 R-1
1	Replacement	RRVH	Harvesting fo previously installed CENTA Compression Collars for use during CENTA reassembly on RRVH in 2RE14	04/29/2010	2-10-014
1	Replacement	RRVH	Installation of RRVH CETNA Seal Assemblies	04/24/2010	2-10-015



# ABSTRACT OF REPAIRS/REPLACEMENT ACTIVITIES REQUIRED FOR CONTINUED SERVICE 2RE14 April 2010


Attachment NOC-AE-10002585 Page 8 of 8

Code Class	Repair, Replacement, or Corrective Measure	Item Description	Description of Work	Date completed	Repair/Replacement Plan Number
1	Replacement	RRVH	Install new design IDD Housing Seal Plug & Nut assembly	04/25/2010	2-10-016
1	Replacement	Snubber	Replaced Mech Snubber	04/13/2010	2-10-021
2	Replacement	Valve	Replaced Valve	04/22/2010	2-10-022
2	Replacement	Valve	Replaced lower body thread plug and seal welded plug	04/25/2010	2-10-027

AN/ A/2/10

Attachment NOC-AE-10002585 Page 1 of 8

# SUMMARY REPORT for the 2RE14 INSERVICE INSPECTION of UNIT 2 SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION



## STP NUCLEAR OPERATING COMPANY April 2010

#### **COVER SHEET**

#### **2RE14 INSERVICE INSPECTION SUMMARY REPORT**

#### SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION, UNIT 2

P.O. BOX 289

**WADSWORTH, TEXAS 77483** 

**USNRC DOCKET NO: 50-499** 

**OPERATING LICENSE NO: NPF-80** 

**COMMERCIAL OPERATION DATE: JUNE 19, 1989** 

J. Williams Engineer

O'TIV

.. Spiess, Supervising Engineer

AN Byala

#### **SCOPE**

## COMPONENT SUPPORTS, REPAIR AND REPLACEMENT, SYSTEM PRESSURE TESTS AND WELD INSPECTION PROGRAMS (IWB, IWC, IWD, IWL)

The examinations summarized in this report were performed in accordance with the 1989 Edition with no Addenda of the ASME Code, Section XI that is applicable to the South Texas Project, Unit 2, second tenyear interval (10/19/2000-10/18/2010), third period (10/19/2007-10/18/2010). This report covers selected ASME Code Class 1, 2 & 3 Systems/Components. This report is documented in accordance with the requirements of ASME Section XI Code Case N-532-4.

Examinations and tests required by the Code are scheduled in accordance with "Inspection Program B" as defined in IWB-2412 for ASME Code Class 1 Systems/Components, IWC-2412 for ASME Code Class 2 Systems/Components and IWD-2412 for ASME Code Class 3 Systems/Components.

The ASME Code Class 1 components were examined as prescribed by Table IWB-2500-1, and the applicable Examination Categories, which established the examination frequency at each refueling outage. The ASME Code Class 2 Systems/Components were examined in accordance with Table IWC-2500-1, Examination Categories. The ASME Code Class 3 Systems/Components were examined in accordance with Table IWD-2500-1, Examination Categories. Component Supports were examined in accordance with Table 2500-1 of Code Case N-491-2.

The ASME Code Class CC components were examined as prescribed by Table IWL-2500-1; ASME 2004 Edition No addenda subsection IWL. 20<sup>th</sup> Year examinations were completed under Surveillance ST: 88000349, (0PSP09-TD-001 Containment Tendon Test/End Anchorage and Adjustment Concrete Inspection.)

AN 1/2/2),0

FORM OAR-1 OWNER'S ACTIVITY REPORT (Code Case N-532-4)
Report Number OAR-2RE14
Plant South Texas Project Electric Generating Station
Unit No. 2 Commercial service date JUNE 19, 1989 Refueling outage no. 2RE14 (If applicable)
Current inspection interval IWB, IWC, IWD, IWF - 2 <sup>nd</sup> ; IWE -2 <sup>nd</sup> , IWL-20 <sup>th</sup> Year (1 <sup>st</sup> , 2 <sup>nd</sup> , 3 <sup>rd</sup> , 4 <sup>th</sup> , other)
Current inspection period IWB, IWC, IWD, IWF - 3 <sup>rd</sup> ; IWE -1 <sup>st</sup> ; IWE -1 <sup>st</sup>
Edition and Addenda of Section XI applicable to the inspection plan 1989 No Addenda, IWE & IWL-2004 Edition No Addenda
Date and revision of inspection plan September 2009/ Revision 5, Supplement 2
Edition and Addenda of Section XI applicable to repairs/replacement activities, if different than the inspection plan
Code Cases used: N-722, N-729-1
I certify that (a) the statements made in this report are correct; (b) the examinations and tests meet the Inspection Plan as required by the ASME Code, Section XI; and (c) the repair/replacement activities and evaluations supporting the completion of   2RE14
CERTIFICATE OF INSERVICE INSPECTION
I, the undersigned, holding a valid commission issued by the National Board of Boiler and pressure Vessel Inspectors and the State or Province of Texas and employed by ABS Boiler & Marine Insurance Co. of Houston, Texas have inspected the items described in this Owner's Activity Report, and state that, to the best of my knowledge and belief, the Owner has performed all activities represented by this report in accordance with the requirements of Section XI.  By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repairs/ replacements activities and evaluation described this report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from the connected with this inspection.
Inspector's Signature P. N.E. MANN Mational Board, State, Province, and Endorsements  Date 08/02/2010

ANI! / A/2/20

### ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRE EVALUATION FOR CONTINUED SERVICE

#### 2RE14 April 2010

Examination Category	Items Number	Item Description	Evaluation description
		See Note #1	

#### NOTES:

- 1. No items found with flaws or relevant conditions that required evaluation for continued service.
- 2. Surveillance procedure OPSP11-RC-0015, ASME Section XI Inservice Inspection, documents Inservice Inspection Activities during 2RE14.

PM 1 0/2/10

TABLE 2

# ABSTRACT OF <u>REPAIRS/REPLACEMENT</u> ACTIVITIES REQUIRED FOR CONTINUED SERVICE 2RE14 April 2010

Code	Repair, Replacement, or Corrective		· · :	Date completed	Repair/Replacement
Class	Measure	Item Description	Description of Work		Plan Number
3	Replacement	Valve	Replaced valve	01/20/2009	2-8-022
3	Replacement	Valve	Replaced valve	04/21/2009	2-8-041
2	Replacement	Valve	Replaced valve clamp cap screws	12/04/2008	2-8-042
3	Replacement	Pump	Replaced Seal and Bearings	01/21/2009	2-8-055
3	Replacement	Valve	Replaced valve	01/20/2009	2-8-057
3	Repair	Valve	Machined Check Valve Plates	11/13/2009	2-8-060
3	Replacement	Strainer	Replace Cover bolting	01/22/2009	2-9-004
3	Replacement	Flange	Replaced flange	04/24/2009	2-9-005
3	Replacement	Valve	Replaced Hinge Pin Bushings & Stop Pin Bushings	06/15/2009	2-9-007
3	Replacement	Flange	Replaced Blind Flange	04/24/2009	2-9-009
3	Replacement	Pump	Replaced Pump with Product Lubricated Pump	04/24/2010	2-9-010
3	Replacement	Seismic Supports	Modification of Seismic Supports	04/24/2010	2-9-011
3	Replacement	Pipe	Replaced partial piping spool	04/24/2009	2-9-013
3	Replacement	Valve	Replaced valve	04/22/2009	2-9-014
2	Repair	Door Seal	Repair seal with Helicoil repair	09/20/2009	2-9-015
2	Repair	Door Seal	Repair seal with Helicoil repair	07/09/2009	2-9-016
3	Replacement	Valve	Replaced damage Valve parts/ Machined Valve Body	07/02/2009	2-9-017 R-1
3	Replacement	Pump	Replaced gland seals and plates	07/10/2009	2-9-018
2	Replacement	Valve	Replaced Pilot Poppet	04/16/2010	2-9-027
2	Replacement	Valve	Replaced Pilot Poppet	04/13/2010	2-9-028
2	Replacement	Valve	Replaced Pilot Poppet	04/15/2010	2-9-029
1	Replacement	Pump	Replaced Seal Housing bolts	09/22/2009	2-9-030
2	Replacement	Valve	Replaced Valve Plug, Seat Ring and Bonnet Seal Ring	04/23/2010	2-9-033
2	Replacement	Gaskets/Fasteners	Replaced inner & outer HX gaskets, Bonnet Flange	04/09/2010	2-9-037
			fastener, inlet & outlet Fasteners and gaskets		
3	Replacement	Pump	Replaced leaking drain plug	12/07/2009	2-9-038
1	Replacement	Spring Can	Replaced Spring Can RC-2123-SH0002	04/22/2010	2-9-039
1	Repair	Spring Can	Weld Build Up of Can housing and indicator	04/17/2010	2-9-041
2	Replacement	Valve	Replaced code parts during valve internals inspection	04/13/2010	2-9-043



Attachment NOC-AE-10002585 Page 7 of 8

# TABLE 2 ABSTRACT OF REPAIRS/REPLACEMENT ACTIVITIES REQUIRED FOR CONTINUED SERVICE 2RE14 April 2010

Code Class	Repair, Replacement, or Corrective Measure	Item Description	Description of Work	Date completed	Repair/Replacement Plan Number
1	Repair	Valve	Seal Weld Repair	04/15/2010	2-9-044
1	Replacement	Valve	Replaced PSV with rebuilt tested PSV	04/24/2010	2-9-045
1	Replacement	Valve	Replaced PSV with rebuilt tested PSV	04/24/2010	2-9-046
1	Replacement	Valve	Replaced PSV with rebuilt tested PSV	04/22/2010	2-9-047
1	Replacement	Valve	Replaced Valve	04/12/2010	2-9-048
1	Replacement	Valve	Replaced Seals	04/26/2009	2-9-053
2	Replacement	Pump	Replaced Seal Glands	02/24/2010	2-9-054
2	Replacement	Valve	Replaced Valve Disc	04/20/2010	2-9-055
2	Replacement	Pump	Replaced Inboard & Outboard Seals	03/04/2010	2-9-057
3	Repair	Pipe	Repair ECW 30" pipe	12/25/2009	2-9-059
2	Replacement	Valve	Replaced Valve	04/10/2010	2-10-002
1	Replacement	Strut Support	Replaced Rigid Sway Strut RC-2002-HL5004	04/13/2010	2-10-003
1	Replacement	Strut Support	Replaced Rigid Sway Strut RC	04/13/2010	2-10-004
3	Replacement	Valve	Replaced PSV with new tested PSV	02/02/2010	2-10-005
3	Replacement	Pump	Replaced Upper Bearing oil cooler & Motor Air Coolers	04/22/2010	2-10-006
1	Replacement	Pump	Replaced #1 Seal Housing Bolting/ #2C RCP	04/07/2010	2-10-008
1	Replacement	RRVH	Install CETNA Housing Nozzles 75,76,77 & 78	04/20/2010	2-10-009
1	Replacement	RRVH	Harvesting of code materials from old RVH for installation on RRVH	04/23/2010	2-10-011
1	Replacement	RRVH	Traveler with admin work order to document replacement of Unit-2 Reactor Closure Head & Appurtenances	04/23/2010	2-10-012
1	Replacement	RRVH	Remove and store ORVH ASME Code Nameplate	04/26/2010	2-10-013 R-1
1	Replacement	RRVH	Harvesting fo previously installed CENTA Compression Collars for use during CENTA reassembly on RRVH in 2RE14	04/29/2010	2-10-014
1	Replacement	RRVH	Installation of RRVH CETNA Seal Assemblies	04/24/2010	2-10-015



# TABLE 2 ABSTRACT OF REPAIRS/REPLACEMENT ACTIVITIES REQUIRED FOR CONTINUED SERVICE 2RE14 April 2010

Attachment NOC-AE-10002585 Page 8 of 8

Code Class	Repair, Replacement, or Corrective Measure	Item Description	Description of Work	Date completed	Repair/Replacement Plan Number
1	Replacement	RRVH	Install new design IDD Housing Seal Plug & Nut assembly	04/25/2010	2-10-016
1	Replacement	Snubber	Replaced Mech Snubber	04/13/2010	2-10-021
2	Replacement	Valve	Replaced Valve	04/22/2010	2-10-022
2	Replacement	Valve	Replaced lower body thread plug and seal welded plug	04/25/2010	2-10-027

AN/ / /2/10