



- PRIMARY SEAL WATER RETURN (CRS) 5178120DE (C-12) → CRS-802B-1/2"-EG1
- DEMIN WATER SUPPLY FROM UNIT 2 5178222DE (F-4) → AFW-17835-6"-JN
- OUT OF SERVICE / IN SERVICE
- TO REFUELING WATER STORAGE TANK CRS-D-1 (CRS) 5178120DE (A-1) → PMU-821-3"-HP
- TO SPENT FUEL PIT PUMP SFP-G-5 (SFP) 5178300DE (E-12) → PMU-9469-1/2"-HP
- TO REFUELING WATER PUMPS (DISCONNECTED) (CRS) 5178120DE (D-12) → PMU-807-1/2"-HP
- TO SPENT FUEL PIT MAKE-UP (SFP) 5178300DE (D-12) → PMU-882-2"-HP
- TO COW SURGE TANK (COW) 5178310DE (E-1) → PMU-717-3"-HP
- TO RAD WASTE ION EXCHANGERS (RWL) 5178167DE (G-12) → PMU-8017-1-1/2"-HP
- TO REFUELING WATER TANK (CRS) 5178120DE (C-1) → PMU-881-1"-HP
- TO DECONTAMINATION DRAIN TANK RLC-D-26 (BAS) 5178145DE (H-1) → PMU-8010-1"-HP
- TO RE-1218 (RWL) 5178165DE (C-12) → PMU-857-3/4"-HP
- TO RESIN SLURRY TANK RWL-C-11 (RWL) 5178167DE (B-12) → PMU-895-2"-HP
- TO RESIN SLURRY TANK RWL-C-11 (RWL) 5178167DE (C-12) → PMU-9467-2"-HP
- TO BATCHING TANK BAS-D-8 (BAS) 5178145DE (D-12) → PMU-9470-2"-HP
- TO BORIC ACID TRANSFER PUMPS BAS-G-9A & G-9B (BAS) 5178145DE (E-12) → PMU-885-2"-HP

NOTE:
1. POWER AND AIR HAVE BEEN DISABLED AND VALVES BLOCKED OPEN.

<p>RECEIVED CDMS APR 29 2003 SITE FILE COPY</p>	<p>ENGINEERING CHANGE NOTICE CP 030202057-1 REV. 0 IF SUPERSEDED, ARE THE ORIGINAL ECP ASSESSMENTS IMPROVED BY THIS ECH?</p> <p>DATE: 4/24/03 BY: [Signature] CHECKED: [Signature] DATE: 4/24/03 BY: [Signature] DATE: 4/24/03 BY: [Signature]</p>	<p>QC NSR UNIT 1 SAN ONOFRE NUCLEAR GENERATING STATION DECOMMISSIONING P & I DIAGRAM PRIMARY PLANT MAKE-UP WATER SYSTEM</p> <p>SOUTHERN CALIFORNIA EDISON Scale: NONE DRAWN BY: HOULTON, J.</p>
<p>W. REVIEW CDMS STATUS = APRV APRIL 24, 2003 08:53</p> <p style="text-align: center;">ENGINEERING CHANGE (ECN) A17411</p>		

5178370DE REV 2