

NOTES:

1. FOR ADDITIONAL INFORMATION SEE MANUFACTURER'S DRAWINGS. TVA CONTRACT NUMBERS 74C63-83090 AND P92NJB-451658.
2. DIESEL GENERATORS 1A-A & 2A-A AND ASSOCIATED EQUIPMENT ARE TRAIN A. DIESEL GENERATORS 1B-B & 2B-B AND ASSOCIATED EQUIPMENT ARE TRAIN B. ALL EQUIPMENT IS SAFETY RELATED.
3. ALL THE EQUIPMENT IS LOCATED ON THE ENGINE CONTROL PANEL UNLESS OTHERWISE NOTED.
4. THE TYPICAL ANNUNCIATOR CIRCUIT FOR LED'S IS AS SHOWN BELOW:



5. ALL ANNUNCIATION APPEARS ON DRAWINGS 1-45W760-82-7C & -8C.
6. FUSE NUMBERS SHOWN IN TABLES SHOULD BE COMBINED WITH THE APPLICABLE BOARD PREFIX LISTED BELOW TO FORMULATE COMPLETE UNIQUE FUSE IDENTIFICATION NUMBER:
   6.9KV DIESEL GENERATOR ENGINE CONTROL PANEL 1-PNL-82-
   EXAMPLE:
   1-FU-82-A4/E1
   THIS NUMBER WILL CHANGE TO 2 FOR UNIT 2 BOARDS.
7.
8. THE FUSE INFORMATION FOR CLASS IE FUSES OR FUSES USED TO PROTECT ELECTRICAL PENETRATIONS SHOWN IN THIS DRAWING SERIES, OR AS GIVEN FOR THESE CIRCUITS IN VENDOR CONTRACT DRAWINGS REFERENCED IN THIS DRAWING SERIES, IS FOR INFORMATION ONLY. REFER TO THE MASTER FUSE REPORT, DRAWING SERIES 45B6000, FOR CONFIGURATION CONTROLLED FUSE INFORMATION. OTHERWISE, FOR THOSE FUSES NOT LISTED IN THE MASTER FUSE REPORT, THESE DRAWINGS WILL REMAIN THE CONTROLLING DOCUMENT.
9. THE TERMINAL NUMBERS SHOWN FOR MCC-INTERNAL COMPONENTS ARE THE MCC-TERMINAL BLOCK/INTERNAL WIRE NUMBERS RATHER THAN THE ACTUAL DEVICE TERMINAL NUMBERS.
10. FOR GENERAL NOTES, INCLUDING TECHNICAL INFORMATION ABOUT CIRCUIT DESIGN, SEE DRAWING 1-45W760-0-1.
11. DRAWING AS SHOWN IS FOR DIESEL GENERATOR UNIT 2B-B. SEE THE FOLLOWING FOR THE OTHER UNITS:

DIESEL GENERATOR	DRAWING
1A-A	1-45W760-82-1
1B-B	1-45W760-82-1A
2A-A	1-45W760-82-1B
OC-S	1-45W760-82-11

12. MIN-MAX EXCITATION LIMITER DISCONNECTED & ABANDONED IN PLACE.
13. DISCONNECT PLUGS P1 THRU P13 (2-CDPL-82-B) AND P1 THRU P3 (2-ADPL-82-B) ARE UNIT 1 / UNIT 2 INTERFACE POINTS FOR DG 2B-B & DG C-S.
14. WIRING SHALL BE NO. 16 AWG MULTICONDUCTOR, INSULATED, SHIELDED MARK #WVA-50, OR THE USE OF EXISTING SHIELDED NO. 16 AWG PANEL WIRING.
15. NEW INTERNAL PANEL WIRING SHALL BE #14 AWG MARK #WJG-6 UNLESS OTHERWISE INDICATED.

SYMBOLS:
(SEE NOTE 3)

- DIESEL GENERATOR ENGINES
- DIESEL GENERATOR PROTECTIVE RELAYS PANEL
- DIESEL GENERATOR BATTERY DISTRIBUTION PANEL
- DIESEL GENERATOR ENGINE CONTROL PANEL
- C1 — LOCATED ON CONTROL DISTRIBUTION PANEL, DG BLDG
- 1 2 — DENOTES UNIT 1 / UNIT 2 INTERFACE POINT (SAFETY RELATED)

REFERENCE DRAWINGS:
SINGLE LINES:
6900V DIESEL GEN. SINGLE LINES----------45W727
CONNECTION DIAGRAMS:
DIESEL GEN MISC. CONN. DIAGRAMS---------- 45W2781-SERIES

RO ISSUE CONT
DCN M-16145-A
DCA M16145-24-0
DCN M-16531-A
DCA M16531-81-0
DCN W-22706-A
DCA W22706-39-0, -42-0
DCN W-24966-A
DCA W24966-13-0

COMPANION DRAWINGS:
1-45W760-82-2 THRU 22

FSAR FIG. 8.3-14E

ISSUED BY:
W.L. ELLIOTT/D.E. ROOT

REV	CHANGE REF	PREPARER	CHECKER	APPROVED	DATE
8	52642	ESJ	JEW	JKQ	7-7-08

REVISED PER DCA 52642-04-0.

SCALE: NTS — EXCEPT AS NOTED

PROJECT FACILITY
DIESEL GENERATOR BLDG
UNIT 1

TITLE
WIRING DIAGRAM 6900V STANDBY DIESEL GENERATOR 2B-B SCHEMATIC DIAGRAMS

1 — WATTS BAR NUCLEAR PLANT, TENNESSEE VALLEY AUTHORITY — Q

DESIGN		INITIAL ISSUE	ENGINEERING APPROVAL
DRAFTER: L.C.BRYAN	CHECKER: P.D.HARTIGAN	RO ISSUE PER	1 NR
DESIGNER: M.L. CHAPMAN/DLO	REVIEWER: NR	DCN S-30422-A, DCA S304222-29-0, DCN M-02671-A, DCN M02671-52-0	2 NR, 3 C.C. LYKE FOR MCB

DATE 4-26-94 | 85 | E | 1-45W760-82-1C | R8

PRINTS REQ'D R ____ PRINT SIZE F — BR OR PROJ | AB CE EE ME NE FE HE SE TE BL BF WB SQ

PRINT SIZE W — BR OR PROJ | AB CE EE ME NE FE HE SE TE BL BF WB SQ

CAD MAINTAINED DRAWING

CONFIGURATION CONTROL DRAWING