

Entergy Nuclear Operations, Inc. Palisades Nuclear Plant 27780 Blue Star Memorial Highway Covert, MI 49043 Tel 269 764 2000

Paula K. Anderson Licensing Manager

August 16, 2010

RG 1.21

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

Subject: Corrections to Palisades Nuclear Plant 2007 and 2009 Radioactive Effluent Release and Waste Disposal Reports

Palisades Nuclear Plant Docket 50-255 License No. DPR-20

- References: 1. Letter dated April 29, 2008, "2007 Annual Radioactive Effluent Release and Waste Disposal Report"
 - 2. Letter dated April 30, 2010, "2009 Annual Radioactive Effluent Release and Waste Disposal Report"

Dear Sir or Madam:

Entergy Nuclear Operations, Inc. (ENO) submitted reference 1 on April 29, 2008. It was recently discovered that the second page of Attachment 2 titled, "Radioactive Effluent Release Report, Gaseous Effluents – Summation of Releases, January – December 2007," was inadvertently omitted from the submittal. The correct tables are provided in Enclosure 1.

ENO submitted reference 2 on April 30, 2010. It was subsequently discovered that incorrect gaseous and liquid Sr-89, Sr-90 and alpha values were listed in Attachment 1 to that report, and used for effluent calculations. Additionally, when the correct values were used for liquid effluent dose calculations, doses comparable to doses from previous years were obtained. Therefore, the last paragraph in Section 9 of the Supplemental Information titled, "Sr-89, Sr-90 and Liquid Doses," is no longer valid and has been deleted. These corrections are provided in Enclosure 2.

In accordance with Regulatory Guide 1.21, "Measuring, Evaluating, and Reporting Radioactive Material in Liquid and Gaseous Effluents and Solid Waste," the corrected attachments have been provided in their entirety, and revision bars have been used to indicate the locations of the changes.

Document Control Desk Page 2

This letter contains no new commitments and no revisions to existing commitments.

Sincerely,

pka/bed

22

Enclosure 1: Correction to 2007 Annual Radioactive Effluent and Waste Disposal Report

Enclosure 2: Correction to 2009 Annual Radioactive Effluent and Waste Disposal Report

CC Administrator, Region III, USNRC Project Manager, Palisades, USNRC Resident Inspector, Palisades, USNRC

ENCLOSURE 1

Correction to 2007 Annual Radioactive Effluent and Waste Disposal Report

ATTACHMENT 2 RADIOACTIVE EFFLUENT RELEASE REPORT GASEOUS EFFLUENTS – SUMMATION OF RELEASES JANUARY – DECEMBER 2007

								Est
	Fission and Activation							Error
a.	Gases *	Units	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Year	%
(1)	Quarterly sum of total curies	Ci	1.24E+02	6.86E+01	1.14E+02	3.45E+01	3.41E+02	4.7
(2)	Average release rate	µCi/sec	1.60E+01	8.73E+00	1.43E+01	4.34E+00		
(3)	Percent of limit	%	7.10E-03	3.67E-03	6.21E-03	1.80E-03		,
	Ar-41	Ci	< LLD	< LLD	5.51E-02	< LLD		
	Kr-85	Ci	1.59E+00	1.42E+00	1.27E+00	2.01E+00		
	Kr-85m	Ci	7.39E-03	5.83E-04	1.31E-04	< LLD		
	Kr-87	Ci	4.12E-04	6.34E-04	< LLD .	< LLD		,
	Kr-88	Ci	< LLD	< LLD	< LLD	< LLD		
(4)	Xe-131m	Ci	1.11E+00	6.33E-01	2.46E-01	5.15E-01		
	Xe-133	Ci	1.20E+02	6.63E+01	1.12E+02	3.20E+01		
	Xe-133m	Ci	4.23E-01	2.60E-01	1.18E-02	1.88E-05		
	Xe-135	Ci	1.10E+00	1.40E-02	2.80E-02	1.56E-03		
	Xe-135m	Ci	3.29E-03	3.67E-03	1.84E-03	2.51E-03		
	Xe-138	Ci	< LLD	< LLD	< LLD	< LLD		
h	Indines]						

υ.	Iodines							
(1)	Total lodine	Ci	2.27E-03	2.44E-03	3.03E-02	7.52E-04	3.57E-02	10.0
(2)	Average release rate	µCi/sec	2.91E-04	3.10E-04	3.81E-03	9.47E-05		
(3)	% of limit for lodine 131/133	%	2.46E-04	2.12E-04	3.91E-03	9.17E-05		
	I-131	Ci	1.68E-03	1.35E-03	2.89E-02	6.68E-04		
(4)	I-133	Ci	5.86E-04	1.09E-03	1.39E-03	8.44E-05		
	l-135	Ci	< LLD	< LĽD	< LLD	< LLD		

С	Particulates half-life > 8 days							
(1)	Total Release	Ci	1.41E-05	2.74E-05	8.41E-05	1.77E-05	1.43E-04	21.9
	Average release rate for							
(2)	period	µCi/sec	1.81E-06	3.48E-06	1.06E-05	2.23E-06		
(3)	% of limit	%	6.43E-05	1.24E-04	3.75E-04	7.67E-05		
	Mn-54	Ci	< LLD	< LLD	< LLD	< LLD		
	Co-58	Ci	< LLD	< LLD	< LLD	< LLD		
	Fe-59	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td></td><td></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td></td><td></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td></td><td></td></lld<></td></lld<>	<lld< td=""><td></td><td></td></lld<>		
	Co-60	Ci	< LLD	< LLD	< LLD	< LLD		
	Zn-65	Ci	< LLD	< LLD	< LLD	< LLD		
	Y-88	Ci	< LLD	< LLD	< LLD	< LLD		
(4)	Nb-95	Ci	< LLD	< LLD	< LLD	3.46E-07		
	Sr-89	Ci	< LLD	< LLD	< LLD	< LLD		
	Sr-90	Ci	< LLD	< LLD	< LLD	< LLD		
	Cs-134	Ci	< LLD	< LLD	< LLD	< LLD		
	Cs-137	Ci	< LLD	< LLD	< LLD	< LLD		
	Ce-141	Ci	< LLD	< LLD	< LLD	1.67E-07		
	Ce-144	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td></td><td></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td></td><td></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td></td><td></td></lld<></td></lld<>	<lld< td=""><td></td><td></td></lld<>		
	Total For Period	Ci	0.00E+00	0.00E+00	0.00E+00	5.13E-07		
(5)	Gross alpha radioactivity	Ci	1.69E-06	2.44E-06	7.17E-06	3.36E-06		

ATTACHMENT 2 RADIOACTIVE EFFLUENT RELEASE REPORT GASEOUS EFFLUENTS – SUMMATION OF RELEASES JANUARY – DECEMBER 2007

d. Tritium]				
1. Total Release	Ci	1.56E+01	1.64E+01	1.80E+01	1.68E+01
2. Average release rate for period	µCi/sec	2.01E+00	2.09E+00	2.26E+00	2.11E+00
3. Percent of limit	%	4.27E-03	4.44E-03	4.82E-03	4.50E-03
	-				
e. Whole Body Dose					
1. Beta airdose at site boundary due to noble gases (ODCM App A					•
III.C)	mrads	1.06E-02	5.84E-03	9.58E-03	6.25E-04
2. Percent limit	%	1.06E-01	5.84E-02	9.58E-02	6.25E-03
3. Gamma Airdose at Site boundary due to noble gasses		0 505 00			
	mrads	3.56E-03	1.88E-03	3.19E-03	9.94E-05
4. Percent Limit	%	7.12E-02	3.76E-02	6.38E-02	1.99E-03
f. Organ Dose					
1. Maximum organ dose to public based on critical receptors (ODCM App A III.D)	mrem	2.00E-02	1.62E-02	3.27E-01	8.26E-03
2. Percent of Limit	%	2.67E-01	2.16E-01	4.36E+00	1.10E-01
L		L	•	ı	L
Net Unidentified beta	Ci	1.41E-05	2.74E-05	8.41E-05	1.72E-05
Un ID Beta % of Release		4.19E-05			

ENCLOSURE 2

Correction to 2009 Annual Radioactive Effluent and Waste Disposal Report

-

ATTACHMENT 1 PALISADES NUCLEAR PLANT 2009 RADIOACTIVE EFFLUENT RELEASE REPORT

2009 Plant Operating History

Palisades Nuclear Plant (PNP) was on line on January 1, 2009. PNP was taken off line on February 17, 2009, due to excessive control rod drive mechanism leakage. The plant was returned to service on February 21, 2009. PNP was taken off line on March 22, 2009, for a refueling outage, and was returned to service on May 2, 2009. PNP remained on line for the remainder of 2009.

A. Gaseous Effluents

Tables A-1, "Gaseous Effluents – Summation of All Discharges," A-1A, "Gaseous Effluents – Ground-Level Release – Batch Mode," and A-1B, "Gaseous Effluents – Ground-Level Release – Continuous Mode," list and summarize gaseous effluents released during this reporting period.

B. Liquid Effluents

Tables A-2, "Liquid Effluents – Summation of All Discharges," A-2A, "Liquid Effluents – Batch Mode," and A-2B, "Liquid Effluents – Continuous Mode," list and summarize liquid effluents released during this reporting period.

C. Solid Waste Storage and Shipments

Table A-3, "Low-Level Waste for Waste Classification A, B and C, summarizes solid radioactive waste shipped for processing or burial in 2009 for the following waste streams: resins, filters and evaporator bottoms, dry active waste, irradiated components, other waste, and sum of all waste.

D. <u>Dose Assessments</u>

Tables A-4, "Dose Assessments, 10 CFR Part 50, Appendix I," and A-5, "EPA 40 CFR Part 190, Individual in the Unrestricted Area," lists annual dose to the members of the public.

E. Supplemental Information

1. Abnormal Discharges

In December 2007, tritium was detected in a groundwater monitoring well at a level of 22,000 pCi/L. The source of the activity is leakage associated with T-91, the utility water storage tank, and associated piping. T-91 is used to store processed liquid waste prior to discharge. No radionuclides other than tritium have been detected in the groundwater. Tritium is still being released to the environment (Lake Michigan) via an unmonitored pathway, as demonstrated by the continued detection of monitoring well sample activity. A definitive release rate or total activity released cannot be determined. Conservatively, the same upper limit of 1% estimate of total tritium activity released via batch releases that was used in 2007 and 2008 will be used for 2009 effluent calculations.

Date and Duration – Tritium was first detected in a monitoring well in December 2007 and release to the environment is still occurring.

Location – The location is between the northwest corner of the auxiliary building and Lake Michigan; the plume roughly paralleling piping associated with T-91.

Volume – The volume release is conservatively estimated at 1% of liquid radioactive waste discharge volume – 7698 gallons.

Estimated Activity of Each Radionuclide - 2.943 curies of tritium

Effluent Monitoring Results – N/A

On-site Monitoring Results – Monitoring well sample results are from 755 PCi/L to 217,351 pCi/L for the most affected well.

Depth to Local Water Table – The depth is approximately eight to nine feet.

Classification of Subsurface Aquifers – Not used for drinking water.

Size and Extent of Any Groundwater Plume – Fifteen yards wide by fifty yards long.

Expected Movement/Mobility of Groundwater Plume – Westerly direction down-gradient toward Lake Michigan at approximately two feet per day.

Land Use Characteristics – Palisades site property, water not used for drinking or irrigation.

Remedial Actions Considered or Taken - None

Calculated Member of Public Dose Attributable to the Release – Total body and organ dose are both 3.93E-4 mrem.

Calculated Member of Public Dose Attributable to the Discharge – Total body and organ dose are both 3.93E-4 mrem.

Actions Taken to Prevent Recurrence – T-91 has been repaired and piping has been replaced.

NRC Notification, Date and contact Organization – The NRC was notified on December 10, 2007, by PNP.

2. Non-Routine Planned Discharges

During excavation to replace suspect piping, 5569 gallons of tritiated groundwater were pumped out and discharged to the mixing basin.

3. Radioactive Waste Treatment System Changes

None.

4. Annual Land Use Census Changes

There are no longer any beef cattle within five miles of the plant. Beef cattle were previously located in the southeast sector at 4.3 miles from the plant. The garden previously located in the southeast sector at 1.49 miles from the plant is no longer there. The garden critical receptor is now located in the northeast sector at 1.67 miles. The residence critical receptor is unchanged. Also unchanged is that there are no dairy cows or goats located within five miles of the plant.

5. Effluent Monitoring System Inoperability

No effluent monitor was out of service for more than 30 days.

6. Offsite Dose Calculation Manual (ODCM) Changes

The ODCM was revised on December 21, 2009, and issued on January 12, 2010. Table 1.3, "Palisades XOQDOQ," was updated to show the results of the XOQDOQ computer program run using 2009 land use census information and 2004 to 2008 meteorological data. Table 1.4, "Land Use Census," was updated to show the results of the 2009 land use census. Table 1.4a, "Critical Receptors," was updated to show the critical receptors and their revised XOQ and DOQ values. Enclosure 1 contains the ODCM, Revision 23, per the requirements of Technical Specification 5.5.1.c.3.

7. Process Control Program Changes

None.

8. Errata/Corrections to Previous Reports

None.

9. Other

Groundwater Monitoring

PNP installed five groundwater monitoring wells in 2007, and added an additional nine wells in 2008. These wells were strategically placed within the owner controlled area, both inside and outside the protected area to allow detection of radioactive contamination of ground water due to leaks or spills from plant systems. Monitoring well 3-07 is most indicative of the leak described above. Tritium levels ranged from a low of 755 pCi/L to a high of 217,351 pCi/L. Monitoring wells 2-07 and 11-08 had tritium level highs of 1493 and 2854 pCi/L, respectively, and both showed lows of less than the minimum detectable activity. The remaining wells showed no activity throughout the year. Well locations are depicted in Figure 1.

Sr-89, Sr-90 and Liquid Doses

In 2009, PNP used a new vendor to analyze effluent samples for hard-to-detect radionuclides. This vendor has the ability to detect a lower concentration for Sr-89 and Sr-90. These radionuclides were detected in service water and turbine sump samples at low level concentrations. The maximum value was 2.66E-8 µCi/ml. Consequently, due to the high yearly service water volume (1.05 E10 gallons), this resulted in high Sr-89 and Sr-90 release activities. This in turn, resulted in higher calculated liquid organ doses to the public. (In 2008, the organ dose was 2.13E-3 mrem. In 2009, the organ dose was 3.70E-1 mrem). It is strongly believed that the Sr-89 and Sr-90 values are due to background radioactivity. Currently, PNP does not have a technical paper documenting background radioactivity, so the calculated values will remain. FIGURE 1 GROUNDWATER MONITORING WELL LOCATIONS



ATTACHMENT 1 Palisades - Table A-1 Gaseous Effluents – Sum of All Releases

Summation of All Releases	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total	Uncertainty
Fission and Activation	Ci	0.000 - 0.1			1 0775.00	0.4005.01	0.0449/
Average		2.922E+01	1.941E+00	1.140E+00	1.977E+00	3.428E+01	8.344%
Release Rate	µCi/s	3.757E+00	2.469E-01	1.442E-01	2.488E-01	1.087E+00	
% of Limit	%	1.978E-03	1.195E-04	7.259E-05	8.736E-04	7.559E-04	
lodines (Halogens)	Ci	8.425E-04	3.555E-04	3.595E-04	2.296E-04	1.787E-03	1.965E+01%
Average Release Rate	µCi/s	1.083E-04	4.522E-05	4.523E-05	2.888E-05	5.667E-05	
% of Limit	%	3.199E-05	3.558E-05	2.063E-05	1.401E-05	2.549E-05	
Particulates	Ci	1.414E-07	1.782E-07	8.490E-08	0.000E+00	4.045E-07	30.96%
Average Release Rate	µCi/s	1.818E-08	2.266E-08	1.068E-08	0.000E+00	1.283E-08	
% of Limit	%	1.772E-08	5.977E-08	2.691E-08	0.000E+00	2.605E-08	
Tritium	Ci	2.013E+01	9.187E+00	5.881E+00	5.921E+00	4.112E+01	4.02%
Average							
Release Rate	µCi/s	2.588E+00	1.168E+00	7.399E-01	7.449E-01	1.304E+00	
% of Limit	%	6.290E-03	2.839E-03	1.798E-03	1.810E-03	3.168E-03	
Gross Alpha	Ci	1.885E-07	5.695E-07	2.630E-07	1.907E-07	1.212E-06	3.398E-15

ATTACHMENT 1 Palisades - Table A-1A Gaseous Effluents – Ground Level Release, Batch Mode

Fission and Activation Gases	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total
Ar-41	Ci	ND	ND	ND	ND	0.000E+00
Kr-85	Ci	1.890E-03	ND	ND	ND	1.890E-03
Kr-85m	Ci	5.830E-04	ND	ND	ND	5.830E-04
Kr-87	Ci	ND	ND	ND	ND	0.000E+00
Kr-88	Ci	ND	ND	ND	ND	0.000E+00
Xe-131m	Ci	3.636E-02	1.737E-02	ND	ND	5.373E-02
Xe-133	Ci	5.790E+00	1.053E+00	4.793E-03	4.057E-04	6.847E+00
Xe-133m	Ci	8.768E-02	4.420E-04	ND .	ND	8.812E-02
Xe-135	Ci	3.916E-01	ND	ND	7.700E-06	3.916E-01
Xe-135m	Ci	ND	ND	ND	ND	0.000E+00
Xe-138	Ci	ND	ND	ND	ND	0.000E+00
(List Others)	Ci	ND	ND	ND	ND	0.000E+00
Total	Ci	6.308E+00	1.070E+00	4.793E-03	4.134E-04	7.383E+00

Iodines/Halogens	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total
I-131	Ci	1.832E-06	3.342E-07	ND	ND	2.166E-06
I-132	Ci	1.020E-06	ND	ND	ND	1.020E-06
I-133	Ci	2.244E-06	ND	ND	ND	2.244E-06
I-134	Ci	ND	ND	ND	ND	0.000E+00
I-135	Ci	ND	ND	ND	ND	0.000E+00
Total	Ci	5.096E-06	3.342E-07	0.000E+00	0.000E+00	5.430E-06

Particulates	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total
Co-58	Ci ND		ND	ND	ND	0.000E+00
Co-60	Ci	ND	ND	ND	ND	0.000E+00
Sr-89	Ci	NR	NR	NR	NR	0.000E+00
Sr-90	Ci	NR	NR	NR	NR	0.000E+00
Cs-134	Ci	ND	ND	ND	ND	0.000E+00
Cs-137	Ci	ND	ND	ND	ND	0.000E+00
Total	Ci	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
		.		1		<u></u>
Tritium	Ci	1.316E+01	NR	NR	NR	1.316E+01
	<u> </u>	<u>., , , , , , , </u>	<u>.</u>	<u></u>		<u> </u>
Gross Alpha	Ci	NR	NR	NR	NR	0.000E+00

Gross Alpha Ci NR NR NR I

ND = Measurements performed but no activity detected.

NR = Analysis not required & not performed

ATTACHMENT 1 Palisades - Table A-1B Gaseous Effluents – Ground Level Release, Continuous Mode

Fission and Activation	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total
Gases						
Ar-41	Ci	ND	ND	ND	3.358E-02	3.358E-02
Kr-85	Ci	ND	ND	ND	ND	0.000E+00
Kr-85m	Ci	ND	ND	ND	1.812E-02	1.812E-02
Kr-87	Ci	ND	ND	7.500E-04	4.724E-02	4.799E-02
Kr-88	Ci	ND	ND	ND	5.014E-02	5.014E-02
Xe-131m	Ci	ND	ND	ND	ND	0.000E+00
Xe-133	Ci	2.290E+01	8.703E-01	1.138E+00	1.344E+00	2.626E+01
Xe-133m	Ci	ND	ND	ND	ND	0.000E+00
Xe-135	Ci	1.952E-03	6.920E-04	1.658E-03	2.072E-01	2.115E-01
Xe-135m	Ci	3.920E-03	ND	1.140E-03	9.600E-02	1.011E-01
Xe-138	Ci	ND	ND	ND	1.811E-01	1.811E-01
(List Others)	Ci	ND	ND	ND	ND	0.000E+00
Total	Ci	2.291E+01	8.710E-01	1.141E+00	1.977E+00	2.690E+01
			•		<u>.</u>	Luusees, e.e.,
Iodines/Halogens	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total
I-131	Ci	1.402E-04	1.986E-04	7.881E-05	5.714E-05	4.747E-04
I-132	Ci	4.060E-04	ND	ND	ND	4.060E-04
I-133	Ci	2.912E-04	1.566E-04	2.807E-04	1.724E-04	9.009E-04
I-134	Ci	ND	ND	ND	ND	0.000E+00
I-135	Ci	ND	ND	ND	ND	0.000E+00
Total	Ci	8.374E-04	3.552E-04	3.595E-04	2.296E-04	1.782E-03
			*	· · · · · · · · · · · · · · · · · · ·	••••••	L
Particulates	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total

Particulates Units Quarter 1		Quarter 2	Quarter 3	Quarter 4	Total	
Co-58 Ci 1.190E-0		1.190E-07	8.580E-08	3.270E-08	ND	2.375E-07
Co-60	Ci	2.240E-08	9.240E-08	3.910E-08	ND	1.539E-07
Sr-89	Ci	ND	ND	ND	ND	0.000E+00
Sr-90	Ci	ND	ND	ND	ND	0.000E+00
Cs-134	Ci	ND	ND	ND	ND	0.000E+00
Cs-137	Ci	ND	ND	1.310E-08	ND	1.310E-08
Total	Ci	1.414E-07	1.782E-07	8.490E-08	0.000E+00	4.045E-07
Tritium	Ci	6.967E+00	9.187E+00	5.881E+00	5.921E+00	2.796E+01
Gross Alpha	Ci	ND	ND	ND	ND	0.000E+00

ND = Measurements performed but no activity detected.

ATTACHMENT 1 Palisades - Table A-2 Liquid Effluents – Sum of All Releases

Summation of All Liquid							
Releases	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total	Uncertainty
Fission and Activation							
Products (excluding							
tritium, gases, and gross							
	Ci	1.294E-02	5.022E-04	3.328E-04	9.190E-05	1.387E-02	15.438%
Average Concentration							
	µCi/ml	3.905E-10	1.745E-11	8.297E-12	2.355E-12	9.832E-11	
% of Limit	%	9.526E-03	3.812E-04	2.625E-04	5.973E-05	2.407E-03	
Tritium	Ci	1.924E+02	4.561E+01	3.718E+01	2.219E+01	2.974E+02	4.02%
Average Concentration	:						
	µCi/ml	5.806E-06	1.585E-06	9.268E-07	5.685E-07	2.108E-06	
% of Limit	%	5.749E-01	1.569E-01	9.154E-02	5.614E-02	2.086E-01	
Dissolved and Entrained							
Gases	Ci	9.957E-03	1.760E+00	0.000E+00	0.000E+00	1.770E+00	27.99%
Average Concentration							
	µCi/ml	3.005E-10	6.116E-08	0.000E+00	0.000E+00	1.255E-08	
% Of Limit	%	1.502E-04	3.058E-02	0.000E+00	0.000E+00	6.274E-03	
Gross Alpha	Ci	9.767E-05	1.588E-05	2.557E-06	0.000E+00	1.161E-04	2.826E-08
Average Concentration							
	µCi/ml	2.947E-12	5.519E-13	6.373E-14	0.000E+00	8.232E-13	
Volume of Primary							
(Befere Dilution)							and the second
	Liters	1.756E+06	6.959E+05	3.226E+05	1.390E+05	2.914E+06	
Dilution Water Used for							
Above	Liters	3.314E+10	2.878E+10	4.011E+10	3.902E+10	1.411E+11	
Volume of Secondary or							
Effluent (e.g. low-							and the second second
activity or unprocessed)							
(Before Dilution)							
,							
	Liters	8.058E+09	1.507E+10	8.621E+09	8.012E+09	3.976E+10	and the second
Average Stream Flow	m³/s	4.262E+00	3.660E+00	5.047E+00	4.910E+00	4.470E+00	

Dilution flow rate (gal/qtr) = # of Dilution pumps running x days running/qtr x 4000 gpm/pump x min/day

ATTACHMENT 1 Palisades - Table A-2A Liquid Effluents – Batch Mode

Fission and Activation Products	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total
Cr-51	Ci	ND	ND	ND	ND	0.000E+00
Mn-54	Ci	3.793E-04	ND	ND	ND	3.793E-04
Fe-55	Ci	0.000E+00	0.000E+00	0.000E+00	9.274E-06	9.274E-06
Fe-59	Ci	1.854E-04	ND	ND	ND	1.854E-04
Co-57	Ci	ND	ND	ND	ND	0.000E+00
Co-58	Ci	3.156E-03	2.369E-04	8.421E-05	1.207E-05	3.489E-03
Co-60	Ci	8.538E-03	2.230E-04	2.179E-04	5.649E-05	9.036E-03
Sr-89	Ci	1.838E-05	ND	3.276E-06	ND ·	2.166E-05
Sr-90	Ci	6.014E-07	ND	6.172E-07	ND	1.219E-06
Nb-95	Ci	2.280E-05	ND	ND	ND	2.280E-05
Ag-110m	Ci	4.589E-04	2.260E-05	ND	4.600E-06	4.861E-04
Sn-113	Ci	ND	ND	ND	ND	0.000E+00
Sb-124	Ci	ND	ND	ND	ND	0.000E+00
Sb-125	Ci	ND	ND	ND	ND	0.000E+00
1-131	Ci	2.670E-06	ND	ND	ND	2.670E-06
I-133	Ci	ND	ND	ND	ND	0.000E+00
I-135	Ci	ND	ND	ND	ND	0.000E+00
Cs-134	Ci	ND	ND	ND	ND	0.000E+00
Cs-137	Ci	ND	1.976E-05	2.683E-05	2.950E-06	4.954E-05
Ni-63	Ci	0.000E+00	0.000E+00	0.000E+00	6.518E-06	6.518E-06
Zn-65	Ci	1.320E-05	ND	ND	ND	1.320E-05
Zr-95	Ci	9.300E-06	ND	ND	ND	9.300E-06
La-140	Ci	1.414E-04	ND	ND	ND	1.414E-04
Totals	Ci	1.293E-02	5.022E-04	3.328E-04	9.190E-05	1.385E-02

Dissolved and Entrained Gases	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total
Kr-85	Ci	ND	ND	ND	ND	0.000E+00
Kr-85m	Ci	ND	ND	ND	ND	0.000E+00
Kr-88	Ci	ND	ND	ND	ND	0.000E+00
Xe-131m	Ci	ND	ND	ND	ND	0.000E+00
Xe-133	Ci	9.957E-03	ND	ND	ND	9.957E-03
Xe-133m	Ci	ND	ND	ND	ND	0.000E+00
Xe-135	Ci	ND	ND	ND	ND	0.000E+00
Xe-135m	Ci	ND	ND	ND	ND	0.000E+00
Totals		9.957E-03	0.000E+00	0.000E+00	0.000E+00	9.957E-03
Tritium	Ci	1.905E+02	4.515E+01	3.672E+01	2.191E+01	2.943E+02
Gross Alpha	Ci	2.861E-05	ND	2.557E-06	ND	3.116E-05

ND = None Detected

|

·200

ATTACHMENT 1 Palisades - Table A-2B Liquid Effluents – Continuous Mode

Fission and Activation Products	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total
Cr-51	Ci	ND	ND	ND	ND	0.000E+00
Mn-54	Ci	ND	ND	ND	ND	0.000E+00
Fe-55	Ci	ND	ND	ND	ND	0.000E+00
Fe-59	Ci	ND	ND	ND	ND	0.000E+00
Co-57	Ci	ND	ND	ND	ND	0.000E+00
Co-58	Ci	ND	ND	ND	ND	0.000E+00
Co-60	Ci	ND	ND	ND	ND	0.000E+00
Sr-89	Ci	ND	ND	ND	·ND	0.000E+00
Sr-90	Ci	1.528E-05	ND	ND	ND	1.528E-05
Nb-95	Ci	ND	ND	ND	ND	0.000E+00
Ag-110m	Ci	ND	ND	ND	ND	0.000E+00
Sn-113	Ci	ND	ND	ND	ND	0.000E+00
Sb-124	Ci	ND	ND	ND	ND	0.000E+00
Sb-125	Ci	ND	ND	ND	ND	0.000E+00
I-131	Ci	ND	ND	ND	ND	0.000E+00
I-133	Ci	ND	ND	ND	ND	0.000E+00
I-135	Ci	ND	ND	ND	ND	0.000E+00
Cs-134	Ci	ND	ND	ND	ND	0.000E+00
Cs-137	Ci	ND	ND	ND	ND	0.000E+00
Ni-63	Ci	ND	ND	ND	ND	0.000E+00
Zn-65	Ci	ND	ND	ND	ND	0.000E+00
Zr-95	Ci	ND	ND	ND	ND	0.000E+00
La-140	Ci	ND	ND	ND	ND	0.000E+00
Totals	Ci	1.528E-05	0.000E+00	0.000E+00	0.000E+00	1.528E-05

1

|

I

Dissolved and Entrained Gases	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total
Kr-85	Ci	ND	1.760E+00	ND	ND	1.760E+00
Kr-85m	Ci	ND	ND	ND	ND	0.000E+00
Kr-88	Ci	ND	ND	ND	ND	0.000E+00
Xe-131m	Ci	ND	ND	ND	ND	0.000E+00
Xe-133	Ci	ND	ND	ND	ND	0.000E+00
Xe-133m	Ci	ND	ND	ND	ND	0.000E+00
Xe-135	Ci	ND	ND	ND	ND	0.000E+00
Xe-135m	Ci	ND	ND	ND	ND	0.000E+00
Totals		0.000E+00	1.760E+00	0.000E+00	0.000E+00	1.760E+00
Lease	1			<u>.</u>	1	•
Tritium	Ci	1.912E+00	4.573E-01	4.586E-01	2.761E-01	3.104E+00
		l		±	*	

Gross Alpha	Ci	6.907E-05	1.588E-05	ND	ND	8.495E-05
ND = None Detected						

ATTACHMENT 1 Palisades - Table A-3 Low Level Waste

Resins, Filters, and Evaporator Bottoms	Vol	Curies Shipped	
Waste Class	ft ³	m ³	Curies
A	1.40E+02	3.96E+00	1.45E-05
В	0.00E+00	0.00E+00	0.00E+00
С	0.00E+00	0.00E+00	0.00E+00
ALL	1.40E+02	3.96E+00	1.45E-05

Major Nuclides for the Above Table:

H-3, Fe-55, Co-58, Co-60, Sr-90, Tc-99, Cs-134, Cs-137, Ce-144, Pu-241

Dry Active Waste	Vol	Curies Shipped	
Waste Class	ft ³	m ³	Curies
A	3.29E+04	9.33E+02	5.98E+00
В	0.00E+00	0.00E+00	0.00E+00
С	0.00E+00	0.00E+00	0.00E+00
ALL	3.29E+04	9.33E+02	5.98E+00

Major Nuclides for the Above Table:

H-3, Cr-51, Mn-54, Fe-55, Fe-59, Co-58, Co-60, Ni-63, Zr-95, Nb-95, Ag-110m, I-131

Irradiated Components	Vol	ume	Curies Shipped
Waste Class	ft ³	m³	Curies
A	0.00E+00	0.00E+00	0.00E+00
В	0.00E+00	0.00E+00	0.00E+00
С	0.00E+00	0.00E+00	0.00E+00
ALL	0.00E+00	0.00E+00	0.00E+00

Other Waste	Vol	Curies Shipped	
Waste Class	ft ³	ft ³ m ³	
A	1.86E+03	5.27E+01	8.72E-01
В	0.00E+00	0.00E+00	0.00E+00
С	0.00E+00	0.00E+00	0.00E+00
ALL	1.86E+03	5.27E+01	8.72E-01

Major Nuclides for the Above Table: H-3, Mn-54, Co-58, Co-60, Ni-63, Cs-137

Sum of All Low-Level Waste Shipped from Site	Vc	Curies Shipped	
Waste Class	ft ³	m³	Curies
A	3.49E+04	9.90E+02	6.85E+00
В	0.00E+00	0.00E+00	0.00E+00
С	0.00E+00	0.00E+00	0.00E+00
ALL	3.49E+04	9.90E+02	6.85E+00

Major Nuclides for the Above Table:

H-3, Cr-51, Mn-54, Fe-55, Fe-59, Co-58, Co-60, Ni-63, Zr-95, Nb-95, Ag-110m, I-131, Cs-137

ATTACHMENT 1 Palisades - Table A-4 Dose Assessments, 10 CFR Part 50, Appendix I

	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Yearly
Liquid Effluent Dose Limit, Total Body	1.5 mrem	1.5 mrem	1.5 mrem	1.5 mrem	3 mrem
Total Body Dose	4.11E-03	1.83E-04	1.30E-04	3.83E-05	4.46E-03
% Of Limit	0.27%	0.01%	0.01%	0.00%	0.15%
Liquid Effluent Dose Limit, Any Organ	5 mrem	5 mrem	5 mrem	5 mrem	10 mrem
Organ Dose	4.36E-03	2.21E-04	1.65E-04	4.22E-05	4.79E-03
% of Limit	0.09%	0.00%	0.00%	0.00%	0.05%
Gaseous Effluent Dose Limit, Gamma Air	5 mrad	5 mrad	5 mrad	5 mrad	10 mrad
Gamma Air Dose	8.42E-04	5.26E-05	3.19E-05	3.27E-04	1.25E-03
% of Limit	0.02%	0.00%	0.00%	0.01%	0.01%
Gaseous Effluent Dose Limit, Beta Air	10 mrad	10 mrad	10 mrad	10 mrad	20 mrad
Beta Air Dose	2.41E-03	1.57E-04	9.33E-05	2.80E-04	2.94E-03
% of Limit	0.024%	0.002%	0.001%	0.003%	0.015%
Gaseous Effluent Dose Limit, Any Organ (Iodine, Tritium, Particulates with >8 day half-life)	7.5 mrem	7.5 mrem	7.5 mrem	7.5 mrem	15 mrem
Gaseous Effluent Organ Dose (Iodine, Tritium, Particulates with >8-Day half-life)	3.53E-03	2.46E-03	1.27E-03	1.14E-03	8.39E-03
% of Limit	0.05%	0.03%	0.02%	0.02%	0.06%

Palisades - Table A-5 EPA 40 CFR Part 190, Individual in the Unrestricted Area

	Whole Body	Thyroid	Any Other Organ
Dose Limit	25 mrem	75 mrem	25 mrem
Dose	4.46E-03	8.39E-03	4.79E-03
% of Limit	0.02%	0.01%	0.02%