## Written Exam Before Facility Validation (pages 1 to 210)

Examination Outline Cross-Reference	Level	RO
Knowledge of the physical connections and/or cause-effect	Tier #	2
relationships between the RCPS (reactor Coolant Pump System)	Group #	1
and the following: CVCS	K/A #	003 K1.04
	Rating	2.6

Question 1

Which of the following are symptoms that the #1 seal for RCP 1-2 has failed:

- A #1 seal leakoff low, VCT pressure high
- B #1 seal leakoff high, VCT pressure high
- C #1 seal leakoff low, VCT pressure low
- D #1 seal leakoff high, VCT pressure low

#### Proposed Answer: B

#### **Explanation:**

- A. Incorrect RCDT level high is indicative of No 2 seal failure
- B. Correct No 1 seal failure cause high flow to VCT increasing pressure. PK 05-01 sends the operator to section B for number 1 seal failure if leakoff flow is high. Per AP-28, the following are listed as plant indications of a number 1 seal failure: High VCT Pressure
- C. Incorrect PRT level high is indicative of RV-8121 lifting
- D. Incorrect VCT pressure Low is inconsistent with excessive No 1 seal leak off going into the VCT

**Technical References:** A-6, Chemical and Volume Control System, Section 2.2 OIM 6-1, Rev. 28. AR PK05-02, RCP No. 11. OP AP-28, Section B, RCP No.1 Seal Failure, section 2, Plant Indications **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis 55.41 (2 to 9)	Х
10CFR Part 55 Content:	55.41 (2 to 9)	

**Comment [g1]:** (6/10/ 09)(PRE)Minor editorial changes made by GWA to make this plant specific. This is memory, not comprehension. PREVALID

Examination Outline Cross-Reference	Level	RO
Knowledge of bus power supplies to the following: Charging	Tier #	2
Pumps.	Group #	1
	K/A #	004 K 2.03
	Rating	3.3

#### GIVEN:

- Unit 1 is at 100% power
- DG 1-2 is cleared for maintenance
- ECCS CCP 1-1 is off
- ECCS CCP 1-2 is running
- Normal CCP 1-3 is off

If 500 kV is lost to Auxiliary Transformer 1-2, ECCS CCP 1-2 will \_\_\_\_\_\_

- A. trip. ECCS CCP 1-1 will auto start, powered from its emergency diesel generator
- B. trip. ECCS CCP 1-1 will auto start, powered from Startup Transformer 1-2
- C. remain running, powered from Startup Transformer 1-2. ECCS CCP 1-1 remains off
- D. remain running, powered from Startup Transformer 1-2. ECCS CCP 1-1 will auto start being powered from Startup Transformer 1-2

### Answer: C

#### **Explanation:**

- A. Incorrect Automatic transfer to Startup Transformer keeps running pump powered.
- B. Incorrect Automatic transfer to Startup Transformer running pump powered
- C. Correct Automatic transfer to Startup Transformer running pump powered and no auto start signal for standby pump is generated
- D. Incorrect -No auto start signal for standby pump is generated.

**Technical References:** B-1A, Chemical and Volume Control System, Page 2.2-6 OIM Page J-1-1, Rev. 28

References to be provided to applicants during exam: None

Learning Objective: To be determined

Question Source: (note changes; attach Bank # Modified Bank # Comment [g2]: (6/10/ 09)(PRE) Minor editorial changes made to stem. This memory not comprehension. GWA PREVALID

parent)	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	Х
10CFR Part 55 Content:	55.41 (7)	

Examination Outline Cross-Reference	Level	RO
Knowledge of the effect that a loss or malfunction of the RHRS	Tier #	2
will have on the following: RCS	Group #	1
	K/A #	005 K 3.01
	Rating	3.9
Question 3		

GIVEN:

- The Residual Heat Removal (RHR) System has been placed in service to continue a cooldown to MODE 5
- CCW is aligned to both RHR heat exchangers
- RHR heat exchanger bypass valve, HCV-670 is 30% open to establish a 20°F/hour RCS cooldown rate

Which of the following events could reduce the cooldown rate?

A. Instrument air to RHR heat exchanger bypass valve, HCV-670, is lost.

\_\_\_\_\_

- B. Instrument air to RHR flow control valve, HCV-637, is lost.
- C. Flow controller to RHR pump recirculation valve FCV-641A, fails high.
- D. Suction Line Relief valve, RV-8707, lifts.

#### Answer: A

#### **Explanation:**

- A. Correct HCV-670 fails open. Opening the bypass valve will divert coolant away from the HX's resulting is less cooling
- B. Incorrect HCV-670 fails open. This increases RHR flow and forces more flow through the HX's and increase the cooldown rate
- C. Incorrect FCV-641A closes if flow is high(>1398 gpm)
- D. Incorrect? Lifting of RV-8707 will divert RHR suction flow to the PRT resulting in a reduction in RCS cooldown

Technical References: OP B-2:V Rev. 25, section 6; LB2-RHRS, Rev. 13, page 6 of 40; OP AP-9, Loss of IA, Rev. 23, page 17 (for failure condition of HCV-637

#### References to be provided to applicants during exam: None

Learning Objective: To be determined

**Question Source:** Bank #

Comment [g3]: (6/10/ 09)(PRE) Added Unit 2 to the stem. GWA. PREVALID

parent)	(note changes; attach	Modified Bank #	Х
		New	
Question	History:	Last NRC Exam	No
Question	Cognitive Level:	Memory/Fundamental	Y
10CFR Pa	rt 55 Content:	55.41 (7)	~

## November 2007 exam Question 31 ML 081006050

**Residual Heat Removal System:** Ability to predict and/or monitor changes in parameters (to prevent exceeding design limits) associated with operating the RHRS controls including: Heatup/cooldown rates.

Level RO SRO Tier # \_2\_\_\_ Group # \_1\_\_\_ K/A # 005 A1.01 Importance rating 3.5

Question: 31

The Residual Heat Removal (RHR) System has been placed in service to continue a cooldown to mode 5. CCW is aligned to both RHR heat exchangers. RHR heat exchanger bypass valve, HCV-670 is 30% open to establish a 20°F/hour RCS cooldown rate.

Which of the following actions or events could reduce the RCS cooldown rate?

A. HCV-670 is throttled open from 30% to 50%.

B. RHR heat exchanger bypass valve, HCV-670 is throttled closed from 30% to 10% open.

C. RHR heat exchanger #1 outlet flow control valve, HCV-638 is opened from 70% to 90%

D. Instrument air to HCV-637 is isolated.

Answer: <u>A</u>

Explanation: A is correct. Opening the bypass valve will divert coolant away from the HX's resulting is less cooling. B is incorrect since throttling closed the bypass valve will force more flow through the HX's and increase the cooldown rate. C is incorrect since opening the HX outlet valve promotes more flow through the HX. D is incorrect since loss of air to HCV-637 will cause the pneumatic valve to fail open which will promote more flow through the HX which

will increase the cooldown rate.

#### Technical Reference(s): <u>OP B-2:V Rev. 25, section 6; LB2-RHRS, Rev. 13, page 6 of 40;</u> <u>OP AP-9, Loss of IA, Rev. 23, page 17 (for failure condition of HCV-637)</u>

Proposed references to be provided to applicants during examination: STG B-2, Fig. RHR-04\_

Learning Objective: <u>STG B2-RHR (Section 3, Normal Ops.) obj 12, 15, & 16</u>

Question Source Bank # \_\_\_\_\_ Modified Bank # \_\_\_\_\_ (Note changes or attach parent) New \_\_\_\_\_XX

Question Cognitive Level: Memory or Fundamental Knowledge \_\_\_\_ Comprehension or Analysis \_\_\_X\_\_

Comments: OPEN REFERENCE : Examination Outline Cross-reference: Level RO SRO

Examination Outline Cross-Reference	Level	RO
Knowledge of the ECCS design feature(s) and/or interlocks	Tier #	2
which provide for the following: Reset of containment isolation.	Group #	1
	K/A #	006 K4.13
	Rating	3.8

GIVEN:

- Unit 1 was at 100% power with all systems in normal alignment
- An inadvertent Reactor Trip and Safety Injection has occurred

Resetting both trains of Phase A Containment Isolation (CIA) is desired.

Which of the following describes how both trains of CIA can be reset?

- A. The Safety Injection Signal is required to be reset first, and then EITHER CIA reset switch can be used to reset both trains.
- B. The Safety Injection Signal is required to be reset first, and then EACH CIA reset switch can be used to reset its respective train.
- C. The Safety Injection Signal is NOT required to be reset first. EITHER CIA reset switch can be used to reset both trains.
- D. The Safety Injection Signal is NOT required to be reset first. EACH CIA reset switch can be used to reset its respective train.

#### Answer: D

#### Explanation:

- A. Incorrect SIS need not be reset to permit CIA reset. Credible distracter since SIS initiated CIA. Second part also false
- B. Incorrect SIS need not be reset to permit CIA reset. Credible distracter since SIS initiated CIA. Second part is true
- C. Incorrect First Part True. Each CIA reset switch only resets its respective train
- D. Correct –. SIS need not be reset to permit CIA reset. Each CIA reset switch only resets its respective train

**Technical References:** B-6A, Reactor Protection System Page 2.2-18 OIM Pages B-6-5 and B-6-5-7 **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

**Question Source:** 

Bank #

Comment [g4]: (6/10/ 09)(PRE) Minor edits to the stem. This is fundamental / memory, not comprehension. GWA. PREVALID

(note c	(note changes; attach	Modified Bank #	
parent)		New	х
Question	History:	Last NRC Exam	No
Question	Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Pa	rt 55 Content:	55.41 (7)	

Examination Outline Cross-Reference	Level	RO
Knowledge of PRTS design feature(s) and/or interlock(s) which	Tier #	2
provide for the following: Quench Tank Cooling	Group #	1
	K/A #	007 K4.01
	Rating	2.6
Question 5		

GIVEN:

- A Pressurizer PORV is leaking
- PK05-25, PRT PRESS LVL/TEMP is in alarm due to high PRT temperature
- PRT pressure is slowly rising

In accordance with AR PK05-25, PRT temperature is lowered by \_\_\_\_\_.

- A. Isolating the leaking PORV
- B. Filling the PRT using primary water
- C. Draining the PRT to the RCDT
- D. Verifying RCS-1-PCV-472, PRT Vent to Vent Header, closes

#### Answer: B

#### **Explanation:**

- A. Incorrect Plausible. The temperature is lowered by adding primary water to the PRT. Isolating the leaking PORV would prevent a further increase in the temperature.
- B. Correct In accordance with the AR PK step 2.1.6, primary water introduction is used to cool the quench volume.
- C. Incorrect This is done after the quench volume has been cooled, and this does not lower temperature.
- D. This is an automatic action that occurs at 10psig.

#### Technical References: References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenti	New	Х
Question History:	Last NRC Exam	NO
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х

**Comment [g5]:** Resa mpled the KA. PREVALID **10CFR Part 55 Content:** 55.41 (7)

Examination Outline Cross-Reference	Level	RO
Ability to predict and/or monitor changes in parameters (to	Tier #	2
prevent exceeding design limits) associated with operating the	Group #	1
CCWS controls including: CCW flow rate.	K/A #	008 A1.01
	Rating	2.8

GIVEN:

- Unit 1 is at 100% steady-state power.
- All systems and equipment are operable and in the proper full power alignment

Which of the following is a potential consequence of placing a second ASW/CCW train in service?

- A. The colder letdown water exiting the letdown heat exchanger could result in a positive reactivity addition
- B. Spent fuel pool over-cooling could result in a positive reactivity addition large enough to challenge the minimum Keff requirement
- C. RCP thermal barrier return CCW flow could isolate on high flow, which will necessitate prompt action to trip the reactor and all RCPs
- D. The Seal Water Heat Exchanger, by over-cooling the RCP seal injection water, could change seal tolerances enough to affect the amount of seal leakage

#### Answer: A

#### Explanation:

- A. Correct Cooler water tends to deposit boron atoms in the demineralizers especially at BOL (high Cb). This could cause power to go above the license limit
- B. Incorrect SFP boron concentration satisfies minimum SDM requirement
- C. Incorrect The Thermal Barrier return valve may close is correct, but the requirement to trip the Rx and RCPs would only apply if seal injection was lost also
- D. Incorrect SWHX function is to cool seal leak-off flow, not injection flow. The amount of seal leak-off flow that may be over-cooled is insignificant compared to the volume in the VCT, thus seal injection temperature should not change significantly

Technical References: STG F2-CCW Rev 16 Obj 13, 17. References to be provided to applicants during exam: None Learning Objective: To be determined

**Question Source:** 

(note changes; attach

Bank # Modified Bank # Х

Comment [g6]: (6/10/ 09)(PRE) No comments. GWA. PREVALID parent)

	New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х
10CFR Part 55 Content:	55.41 (7)	

## BANKED - from November 2007 exam Question 34 ML 081006050

Level RO SRO Tier # \_2\_\_\_ Group # \_1\_\_ K/A # <u>008 A1.01</u> Importance rating <u>2.8</u>

**Component Cooling Water:** Ability to predict and/or monitor changes in parameters (to prevent exceeding design limits) associated with operating the CCWS controls including: CCW flow rate.

Question: 34

Unit 1 is at 100% steady-state power, with all systems and equipment operable and in the proper full power alignment.

Which of the following is a potential consequence of placing a second ASW/CCW train in service?

- A. The colder letdown water exiting the letdown heat exchanger could result in a positive reactivity addition.
- B. Spent fuel pool over-cooling could result in a positive reactivity addition large enough to challenge the minimum Keff requirement.
- C. RCP thermal barrier return CCW flow could isolate on high flow, which will necessitate prompt action to trip the reactor and all RCPs.
- D. The Seal Water Heat Exchanger, by over-cooling the RCP seal injection water, could change seal tolerances enough to affect the amount of seal leakage.

### Answer: <u>A</u>

Explanation: A is correct because cooler water tends to deposit boron atoms in the demineralizers, especially at BOL (high Cb). This could cause power to go above the license limit. B is incorrect as SFP boron concentration satisfies minimum SDM requirement. The statement in answer C that TB return valve may close is correct, but the requirement to tip the Rx and RCPs would only apply if seal injection was lost also. D is incorrect since the SWHX function is to cool seal leakoff flow, not injection flow. The amount of seal leak-off flow that may be over-cooled is insignificant compared to the volume in the VCT, thus seal injection temperature should not change significantly.

Technical Reference(s): <u>Reactor Theory; Components (demineralizers) GFE program; STG B1A, Rev.</u> <u>15, page 3-2</u>

Proposed references to be provided to applicants during examination: <u>None</u>

Learning Objective: STG F2-CCW, Rev 15 Obj. 13, 17

Question Source Bank # \_\_\_\_\_ Modified Bank # \_\_\_\_\_ (Note changes or attach parent) New \_\_\_\_\_XX\_\_\_\_

Question Cognitive Level: Memory or Fundamental Knowledge \_\_\_\_ Comprehension or Analysis \_\_\_X

Examination Outline Cross-Reference	Level	RO
Knowledge of the effect of a loss or malfunction of the following	Tier #	2
will have on the PZR PCS: PZR Sprays and Heaters.	Group #	1
	K/A #	010 K6.03
	Rating	3.2

#### Question 7

GIVEN:

- Unit 1 is at 100% power
- One of the backup heater groups was manually placed in the "ON" position one hour ago for RCS mixing

Spray valve PCV-455A fails full open.

Which of the following sequences of events will occur?

- A. PCV-455B spray valve closes, pressurizer heaters energize, PORV interlock removed, Reactor trips.
- B. PCV-455B spray valve closes, PORV interlock removed, pressurizer heaters energize, Reactor trips.
- C. No change in position of the spray valve PCV-455B, pressurizer heaters energize, Reactor trips, PORV interlock removed.
- D. No change in position of the spray valve PCV-455B, pressurizer heaters energize, PORV interlock removed, Reactor trips.

#### Answer: A

#### Explanation:

- A. Correct Both spray valves should initially be open. Due to the integral nature of the PZR pressure master controller, a short time after the backup heater group was energized, the spray valves should have opened and will be the first pressure control component to respond (valve close) as PZR pressure decreases. (Per procedure
- B. Incorrect heaters energize before the PORV interlock is removed
- C. Incorrect the spray valve functioning spray valve is not addressed
- D. Correct the spray valve functioning spray valve is not addressed

Technical References:STG A4A, Rev. 14, page 22-8, OIM A-4-6, Rev. 26References to be provided to applicants during exam:NoneLearning Objective:To be determinedSTG A4A-PP&LCS, Rev. 14, Obj 13, 22

Question Source:

Bank #

Comment [g7]: (6/10/09) Removed "with no operator action" from the stem. This is assumed unless stated otherwise. Removed SIS from all answers since it was in the same sequence – no discriminatory value. GWA. PREVALID

(note changes; attach parent)	Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7)	

## MODIFIED - from November 2007 exam Question 31 ML 081006050

RO SRO Tier # \_2\_\_ Pressurizer Pressure Control: Ability to monitor automatic operation of the PZR PCS, including: PZR pressure.

Group # \_ 1\_\_\_ K/A # 010 A3.02 Importance rating \_ 3.6\_

Question: 36

Unit 1 is at stable 22% power with all RCS control circuits in automatic except for one of the backup heater groups, which was manually placed in the "ON" position one hour ago for RCS mixing. A small leak develops in the RCS causing pressurizer pressure to slowly decrease.

Which of the following sequences of actions will occur as RCS pressure decreases with no operator actions?

- A. The open spray valves close, pressurizer heaters energize, PORV interlock removed, Reactor trips, SIS.
- B. The open spray valves close, PORV interlock removed, pressurizer heaters energize, Reactor trips, SIS.
- C. No change in position of the spray valves, pressurizer heaters energize, Reactor trips, PORV interlock removed, SIS.
- D. No change in position of the spray valves, pressurizer heaters energize, PORV interlock removed, Reactor trips, SIS.

Answer: <u>A</u>

Explanation: One spray valve should initially be open. Due to the integral nature of the PZR pressure master controller, a short time after the backup heater group was turned on, a spray valve should have opened and will be the first pressure control component to respond (valve close) as PZR pressure decreases. Answer A is correct. B is incorrect since the heaters energize before the PORV interlock is removed. Answers C and D are incorrect since neither addresses the spray valve.

Technical Reference(s): STG A4A, Rev. 14, page 22-8, OIM A-4-6, Rev. 26

Proposed references to be provided to applicants during examination: <u>None</u>

Learning Objective: \_\_\_ STG A4A-PP&LCS, Rev. 14, Obj 13, 22

Question Source Bank # \_\_\_\_\_ Modified Bank # \_\_\_\_\_ (Note changes or attach parent) New \_\_\_\_\_XX\_\_\_

Question Cognitive Level: Memory or Fundamental Knowledge \_\_ Comprehension or Analysis X

Comments

Examination Outline Cross-Reference	Level	RO
Knowledge of the operational impact of the following concepts	Tier #	2
as they apply to the PZR PCS: Determination of condition of	Group #	1
fluid in PZR, using steam tables.	K/A #	010 K5.01
	Rating	3.5
Question 8		

\_\_\_\_\_

Given the following conditions:

- Unit 1 is in MODE 5
- RHR is in service with RCS loop temperatures at 95°F
- Pressurizer level is 70% cold cal
- Pressurizer pressure is 3.5 psia
- Vacuum refill skid pump is shut down
- Pressurizer heaters are energized •

At what pressurizer liquid temperature will bubble formation start in the pressurizer?

- A. 140°F
- B. 144°F
- C. 148°F
- D. 152°F

Answer: C

Step 6.1.1.a.3 of OP A-2:IX has RCS temp at 95F. **Explanation:** 

- A. Incorrect -
- B. Incorrect -
- C. Correct Tsat for 3.5 psia is 148°F
- D. Incorrect.

#### **Technical References:** References to be provided to applicants during exam: Steam Tables Learning Objective: To be determined

Questio	n Source:	Bank #
	(note changes; attach	Modified Bank #
parent)		

Comment [g8]: (6/11/ 09) Minor edit to stem. This fundamental, not comprehension. PREVALID

New

Х

Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (5)	

## BANK- from October 2002 exam Question 31 ML 023220665

Proposed Question # 11:

Unit 1 is in mode 5 with the following plant conditions:

RHR in service with RCS loop temperatures at 115 F.

Pressurizer level at 70% cold cal.

\_\_Pressurizer pressure at 3.5 psia.

Vacuum refill skid pump shut down. Pressurizer heaters energized.

What will be the pressurizer liquid temperature when the bubble starts forming in the pressurizer?

A 140\_F

B 144\_F

C 148 F

D 152\_F

Proposed Answer: C

Explanation:

Technical Reference(s): OP A-2:IX page 19 Steam Tables

Proposed references to be provided to applicants during examination: Steam Tables

Learning Objective: 4551 Explain operational characteristics of Pressurizer.

Question Source: Bank # Modified Bank # New X

Examination Outline Cross-Reference	Level	RO
Ability to (a) predict the impacts of the following malfunctions	Tier #	1
or operations on the RPS; and (b) based on those predictions,	Group #	1
use procedures to correct, control or mitigate the	K/A #	012 A2.06
consequences of those malfunctions or operations: Failure of	Rating	4.4
RPS to trip the reactor.		

Given the following conditions:

- Unit 2 was at 100% power.
- A Spurious Safety Injection occurs.
- The reactor <u>fails</u> to trip.

Which of the following describes the impact on the Reactor Protection system and the Function Restoration Procedure that should be used to mitigate the consequences?

- A. RPS generates P-4 and the main turbine is tripped. FR-S.1 is used to establish an effective heat sink.
- B. RPS does NOT generate P-4 and the main turbine is NOT tripped. FR-C.1 is used to establish effective core cooling.
- C. RPS does NOT generate P-4 and the main turbine is tripped. FR-S.1 is used to insert negative reactivity.
- D. RPS generates P-4 and the main turbine is NOT tripped. FR-C.1 is used to establish effective core cooling.

#### Answer: C

#### Explanation:

- A. Incorrect The turbine is tripped by SI, but P-4 is not generated. FR-S.1 is used.
- B. Incorrect the turbine is tripped, and FR-C.1 is not used.
- C. Correct ECCS systems are designed to remove decay heat. FR-S.1 is the highest priority RED Path. The turbine is tripped by the SI signal, but P-4 is not generated.
- D. Incorrect The turbine is tripped, and P-4 is not generated. FR-C.1 is not used.

Technical References: OPS-Lesson Plan LMCDFRS Obj 4 OIM C-3-5 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: Bank # (note changes; attach Modified Bank # Comment [g9]: (6/11/ 09)Changed stem to read better. Rearranged answers to 2 of 2 format. Fundamental not comprehension. PREVALID

parent)	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	Х
10CFR Part 55 Content:	55.41 (5)	

Examination Outline Cross-Reference	Level	RO
Knowledge of the effect that a loss or malfunction of the ESFAS	Tier #	2
will have on the following: Fuel.	Group #	1
	K/A #	013 K3.01
	Rating	4.4
Question 10		

#### GIVEN:

- Unit 1 was at 100% power
- A reactor trip occurs due to a loss of all feedwater
- Auxiliary Feedwater (AFW) fails to actuate

Which of the following is the likely consequence of the AFW failure if no action is taken?

- A. Core uncovery and overheating.
- B. RCS pressure exceeding design pressure.
- C. Return to criticality.
- D. Multiple Steam Generator U-tube failures.

#### Answer: A

#### **Explanation:**

- A. Correct From FR-H.1 background, without operator action, once the secondary is lost as a heat sink, the RCS will heat up to saturation, boil off and result in core uncovery and damage.
- B. Incorrect Plausible if assuming the temperature increase would cause a large enough pressure increase to threaten RCS integrity
- C. Incorrect Core boil off is correct.
- D. Incorrect Steam generator dryout is possible

#### Technical References: FR-H.1, background References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	
Question History:	Last NRC Exam	No

Comment [g10]: (6/1 1/09) Minor changes to stem. Added explanations for the distracters. PREVALID Question Cognitive Level:

10CFR Part 55 Content:

Memory/Fundamental Comprehensive/Analysis 55.41 (7)

Х

## BANK April 2007 Draft ML 072400068

## **RO Question 39**

The plant trips from full power due to a loss of feedwater. AFW fails to actuate. Without operator action, which of the following is the likely consequence of the AFW failure?

- A. Core uncovery and overheating.
- B. RCS pressure exceeding design pressure.
- C. Return to criticality due to core boil off causing a loss of boron inventory.
- D. Steam Generator dryout and tube damage from excessive steam generator pressure.

Proposed Answer:

A. Core uncovery and overheating.

Explanation:

A correct. From FR-H.1 background, without operator action, once the secondary is lost as a heat sink, the RCS will heat up to saturation, boil off and result in core

uncovery and damage.

Technical Reference(s): FR-H.1, background

Proposed references to be provided to applicants during examination: None

Learning Objective: 11319 Describe the loss of feedwater event leading to core damage. Question Source:

Bank modified M-0068

Question History: N/A

Question Cognitive Level:

Memory or Fundamental Knowledge X

Comprehension or Analysis

10 CFR Part 55 Content: 55.41.7 - Design, components, and function of control and safety systems, including instrumentation, signals, interlocks, failure modes, and automatic and manual features.

Comments: No changes from initial submittal.

K/A: 013 K3.01 - Knowledge of the effect that a loss or malfunction of the ESFAS will have on the following: Fuel (4.4/4.7)

Examination Outline Cross-Reference	Level	RO
Ability to monitor automatic operation of the ESFAS including:	Tier #	2
Inputs and logic.	Group #	1
	K/A #	013 A3.01
	Rating	3.7

Given the following conditions:

- A plant shutdown in accordance with OP L-5, Plant Shutdown From Minimum Load to Cold Shutdown, is in progress
- Unit 1 is at 7% reactor power
- The Main Turbine has been MANUALLY tripped as part of the normal shutdown

What will be the status of the following permissive alarms?

- PK08-02, Low Power Permissive P-7
- PK08-05, Power Range at Power Permissive P-10
- PK08-08, Turbine Low Power Permissive P-13
- A. Only PK08-02 is clear
- B. Only PK08-05 is clear
- C. Only PK08-08 is clear
- D. Both PK08-08 and PK08-02 are clear

#### Answer: A

## DCPP VERIFY A IS CORRECT

#### Explanation:

A. Correct – Only -02 will be clear based on logic. 02 is inverse of P-7 status, and 08 is inverse of P-13 status. In this case P-13 is not met, P-10 is met so that P-7 = [P-13 OR P-10]. P-7 is met.

- B. Incorrect 05 will be lit
- C. Incorrect 08 will be lit
- D. Incorrect 08 will be lit

#### Technical References: STG B6a Page 2.3-6 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	Х
Question History:	Last NRC Exam	No

Comment [g11]: (6/1 1/09) Revised stem to read clearer. Running through the logic, PK-0802 will be clear, and the other two will be lit. There is no correct answer. Verify this revision to the question is correct. PREVALID Question Cognitive Level:

10CFR Part 55 Content:

Memory/Fundamental Comprehensive/Analysis 55.41 (7)

Х

Examination Outline Cross-Reference	Level	RO
Ability to manually operate and/or monitor in the control room:	Tier #	2
Containment reading of temperature, pressure, and humidity	Group #	1
system.	K/A #	022 A4.05
	Rating	3.1

GIVEN:

• Containment average temperature is reading abnormally high due to one of the selected containment area temperature elements failing high

Containment average temperature can be read in the Control Room at \_\_\_\_\_; and the faulty temperature element can be removed from the average calculation \_\_\_\_\_.

- A. TI-26 (Containment Area TM Panel); on the Plant Process Computer
- B. YR-26 (Containment Average Temperature); on the Plant Process Computer
- C. TI-26 (Containment Area TM Panel); at TI-26
- D. YR-26 (Containment Average Temperature); at TI-26

#### Answer: D

#### Explanation:

- A. Incorrect. Both parts incorrect.
- B. Incorrect. First part is correct.
- C. Incorrect. Second part is correct
- D. Correct. YR-26 is located in the control room. The elements can be deselected locally at TI-26 which is outside the control room.

#### Technical References: LH-11 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 (7)	х

Comment [g12]: (6/1 1/09) E-1.2 does not support the correct answer. Used LI-2. Removed status of Phase B and CS alarms since applicants should be able to determine that they should be in based off given information. Edited stem for better focus... rising containment pressure vs. high pressure. (8/4/09) DCPP commented that this may not meet the KA. Replaced question. PREVALID

Examination Outline Cross-Reference	Level	RO
Knowledge of CSS design features and/or interlocks which	Tier #	2
provide for the following: lodine scavenging via the CSS	Group #	1
	K/A #	026 K4.06
	Rating	2.8
Question 13		

Which of the following describes how the sufficient amount of Sodium Hydroxide (NaOH) is assumed to be delivered to the Containment Sump?

- A. Only CS-8994A OR CS-8994B (NaOH to CCS Pump Eductor Valves) needs to open. Proper NaOH volume is assured by stopping the containment spray pumps on Low-Low RWST level (4%).
- B. Both CS-8994A AND CS-8994B (NaOH to CCS Pump Eductor Valves) need to open. Proper NaOH volume is assured by stopping the containment spray pumps on Low-Low RWST level (4%).
- C. Only CS-8994A OR CS-8994B (NaOH to CCS Pump Eductor Valves) needs to open. Proper NaOH volume is assured by stopping the containment spray pumps on Low RWST level (33%).
- D. Both CS-8994A AND CS-8994B (NaOH to CCS Pump Eductor Valves) need to open. Proper NaOH volume is assured by closing both CS-899B AND CS-8994B on Low-Low RWST level (33%).

Proposed Answer: A

Explanation:

- A Correct: Either train is 100% capacity. Pumps run until the Low Level (4%) is reached.
- B Incorrect: Either train is 100% capacity.
- C Incorrect: Pumps continue to at RWST low levI (33%) until the Low Level (4%) is reached.

D Incorrect: Pumps are secured at RWST Low-Low (4%). Valves are not closed.
Technical References STG I-2 page 1-4 and 3-10.
References to be provided to applicants during exam: None
Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	Х

Comment [g1]: (6/16/ 09) No Comments. PREVALID 10CFR Part 55 Content:

Comprehensive/Analysis 55.41 (7)

Examination Outline Cross-Reference	Level	RO
Ability to determine operability and/or availability of safety	Tier #	2
related equipment	Group #	1
	K/A #	026 G2.2.37
	Rating	3.6

Which of the following is the required line up for a properly filled and OPERABLE Containment Spray System?

- A. SI-246 (RWST to CS Outlet Valve) closed; CS-9001A and B (Spray Pump Discharge Vales) open with power removed.
- B. SI-246 (RWST to CS Outlet Valve) sealed open; CS-9001A and B (Spray Pump Discharge Vales) closed and ready to auto open.
- C. SI-246 (RWST to CS Outlet Valve) closed; CS-9001A and B (Spray Pump Discharge Vales) closed and ready to auto open.
- D. SI-246 (RWST to CS Outlet Valve) sealed open; CS-9001A and B (Spray Pump Discharge Vales) open with power removed.

#### Proposed Answer: B Explanation:

- A Incorrect: This prevents filling the discharge header downstream of 9001A/B, but system will not automatically perform it function.
- B Correct: Discharge valve are closed to prevent filling the discharge header while valve SI-246 is sealed open.
- C Incorrect: System will not automatically perform it function.
- D Incorrect: The discharge will be filled.

Technical References: STG I-2 page 3-1 Procedure OP I-2:I "Containment Spray System -Make Available" . References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	х

Comment [g2]: (6/16/ 09) Changed stem. Removed the word acceptable. PREVALID 10CFR Part 55 Content:

Comprehensive/Analysis 55.41 (7)

Examination Outline Cross-Reference	Level	RO
Knowledge of the purpose and function of major system	Tier #	2
components and controls	Group #	1
	K/A #	039 G2.1.28
	Rating	4.1

What is the function of the Turbine Overspeed Protection Circuit?

- A. Closes the reheat stop valves and extraction non-return valves <u>permanently</u> to prevent turbine overspeed following a turbine trip.
- B. Closes the reheat stop valves and extraction non-return valves <u>momentarily</u> to prevent a turbine trip.
- C. Closes the governor valves and intercept valves <u>permanently</u> to prevent turbine overspeed following a turbine trip.
- D. Closes the governor valves and intercept valves momentarily to prevent a turbine trip.

#### Proposed Answer: D Explanation:

- A Incorrect: These valves do close on a turbine trip but due to either low PCV-23 or SV-40.
- B Incorrect: the OPC does not control these valves.
- C Incorrect: See D below.
- D Correct: The OPC circuit momentarily closed the governor and intercept valve at 103% but allows reopening at 101%.

#### Technical References: STG C-3b page 2.1-28 References to be provided to applicants during exam: None Learning Objective: To be determined

Bank # Modified Bank #	
Х	
Exam No	
undamental X nsive/Analysis	
E	

Comment [g3]: (6/16/ 09) No Comments. PREVALID

Examination Outline Cross-Reference	Level	RO
Knowledge of the physical connections and/or cause effect	Tier #	2
relationships between the MRSS and the following systems: S/G	Group #	1
	K/A #	039 K1.01
	Rating	3.1
Question 16		

GIVEN:

- Unit 1 is at 100% power
- Reheat Steam to one Moisture Separator Reheater (MSR) is isolated
- All systems operating normally in automatic control

\_\_\_\_\_

The SFM has directed you to lower Unit Load to 98% in preparation for restoring HP reheat steam. What is the reason for this power reduction?

- A. Avoid lifting the MSR relief valves.
- B. Avoid water hammer.
- C. Avoid an overpower condition.
- D. Avoid excessive thermal stress.

#### Proposed Answer: С **Explanation:**

A Incorrect: Pressure changes are minimized by the RAMP open feature (modulate open at 75°/hour rate)

B Incorrect: Procedure has been written to limit or prevent water hammer (discussion item 2.2

C Correct: Increasing Main Steam flow will drop S/G pressure and cause a RCS cooldown. With a negative MTC, power will increase.

D Incorrect: Thermal stresses are minimized by the RAMP open feature (modulate open at 75% hour rate)

Technical References: STG C5 OP-C-5:II step 6.5.2 and precaution & limitation 5.8.1 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	Х
Question History:	Last NRC Exam	No

Comment [g4]: (6/16/ 09) KA Mismatch. Rewrite to address S/G relationship to Main and Reheat steam system.

(8/17/09) Question rewritten PREVALID

**Question Cognitive Level:** 

10CFR Part 55 Content:

Memory/Fundamental Comprehensive/Analysis 55.41 (2 to 9)

Х

Examination Outline Cross-Reference	Level	RO
Ability to manually operate and monitor in the control room:	Tier #	2
Recovery from automatic feedwater isolation	Group #	1
	K/A #	059 A4.11
	Rating	3.1

GIVEN:

- Unit 1 was at 8% power
- A secondary transient causes a Feedwater Isolation (FWI)
- The reactor is tripped
- Normal Steam Generator Levels are restored while on Auxiliary Feedwater

What is required to reset the FWI signal and establish a Main Feedwater flow path?

- A. Manually Reset BOTH Trains of FWI. Manually open FW isolation valves. The Main Feed Regulating and Bypass Feed Regulating Valves will function automatically.
- B. Close the Reactor Trip breakers. Manually Reset BOTH Trains of FWI. Manually open FW isolation valves and bypass feed regulating valves.
- C. Reset Low Tavg. Manually Reset BOTH Trains of FWI. Manually open FW isolation valves and bypass feed regulating valves.
- D. Reset Low Tavg. Manually Reset BOTH Trains of FWI. Manually open FW isolation valves. The Main Feed Regulating and Bypass Feed Regulating valves will function automatically.

Proposed Answer: B

#### Explanation:

- A. Answer A is incorrect. Reactor trip breakers must be closed to remove the Reactor trip with low Tave signal.
- B. Answer B is correct. Reactor trip breakers must be closed to remove the Reactor trip with low Tave signal.
- C. Answer C is incorrect.
- D. Answer D is incorrect.

**Technical References** OIM, Feedwater Isolation Signals, Page B-6-12, Rev. 28 **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Questio	on Source:	Bank #
	(note changes; attach	Modified Bank #
parent)		

Comment [g5]: (6/16/ 09) Minor edits made to stem. PREVALID

	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	х
10CFR Part 55 Content:	55.41 (7)	

Examination Outline Cross-Reference	Level	RO
Knowledge of the effect of a loss or malfunction of the following	Tier #	2
will have on AFW components: Pumps	Group #	1
	K/A #	061 K6.02
	Rating	2.6

GIVEN:

- Unit 2 was at 100% power when a Reactor Trip occurred
- Motor Driven AFW Pump 2-3 immediately trips

How will LCV-115 and LCV-113, AFW supply valves to Steam generators 2-3 and 2-4, respond?

The LCVs will:

- A. Close and remain closed due to runout protection circuitry.
- B. Open but then close as Turbine Driven AFW pump restores level.
- C. Open and remain open due to the AFW Pump 2-3 trip.
- D. Throttle and remain throttled due to the pump trip cutout signal.

# Proposed Answer: C

#### Explanation:

- A. Incorrect. Upon the pump trip, the EH pump loses power, the solenoid relief valves fail open, and the loss of EH pressure causes the valves to fail open.
- B. Incorrect. Valve will close as level rises if MDAFWP not tripped.
- C. Correct.
- D. Incorrect. There is not a cutout signal.

#### Technical References LD-1, Page 2-44, Rev. 15 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank #	Х
parony	New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х

Comment [g6]: (6/16/ 09) Minor change to stem format. PREVALID
10CFR Part 55 Content:

# 55.41 (7)

# MODIFIED from RO Question 46 ML082830427

# **RO Question 46**

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #	2	
Group #	1	
K/A #	061/K3.02	
Importance Rating	4.2	4.4

K/A: **Auxiliary / Emergency Feedwater (AFW) System** - Knowledge of the effect that a loss or malfunction of the AFW System will have on the following: S/G.

Proposed Question:

Given the following conditions:

Unit 2 was at 100% power when a Reactor Trip occurred.

PT-434, AFW pump 2-3 discharge pressure transmitter has failed to zero.

What effect will this failure have on LCV-115 and LCV-113, AFW supply valves to Steam generators 2-3 and 2-4?

The LCVs will fail:

- A. Closed, and must be taken to manual to restore control.
- B. Open, and must be taken to manual to restore control.
- C. Open, AFW pump 2-3 must be secured to stop flow.
- D. As is, and must be locally operated.

Proposed Answer: A

Explanation:

Answer A is correct. This input is used as run-out protection. Discharge pressure transmitter failing to zero will cause the LCVs to go closed on low pump discharge pressure. Manual control is available from the controller.

Answer B is incorrect. Valves will not fail open, they will fail closed.

Answer C is incorrect. Valves will not fail open, they will fail closed. There is no requirement to stop the pumps.

Answer D is incorrect. Valves will not fail as is; this is true of the turbine driven AFW pump LCVs.

Technical Reference(s): LD-1, Auxiliary Feedwater System, Page 29 & 30, Rev11.

Proposed references to be provided to applicants during examination: NONE

Learning Objective:	37635- Describe controls, indications, and alarms associated with the Auxiliary Feedwater System.		
Question Source:	Bank # Modified Bank # New	A-0692 (Note changes or attach parent)	
Question History:	Last NRC Exam	N/A	

Question Cognitive Level: Memory or Fundamental Knowledge Comprehension or Analysis Х

10 CFR Part 55 Content: 55.41 7 55.43

10 CFR Part 55 Content: Design, components, and function of control and safety systems, including instrumentation, signals, interlocks, failure modes and automatic and manual features.

Examination Outline Cross-Reference	Level	RO
Ability to monitor automatic operation of the AFW including:	Tier #	2
AFW startup and flow.	Group #	1
	K/A #	061 A3.01
	Rating	

GIVEN:

• A Unit 1 plant startup is in progress per OP L-3.

\_\_\_\_\_

- The reactor is at 9% power with a Main Feedwater Pump in service.
- While rolling the Main Turbine, S/G level control malfunctions result in S/G 2-2 level exceeding 75%.

Which of the following automatic actions would occur?

- A. Both motor driven AFW pumps will start following a time delay.
- B. Both motor driven AFW pumps will immediately start.
- C. All AFW pumps will immediately start.
- D. All AFW pumps will start following a time delay.

# **Explanation:**

- A. Incorrect. A time delay is only associated with the low-low steam generator start signal below 50% power.
- B. Correct. Steam Generator Level > 75% is P-14. This Trips both Main feed Pumps resulting in an immediate start signal to Motor Driven pumps only.
- C. Incorrect. Only the Motor Driven AFW pumps start on Trip of Main Feed Pumps.

New

D. Incorrect. Only the Motor Driven AFW pumps start on Trip of Main Feed Pumps. A time delay is only associated with the low-low steam generator start signal below 50% power

Technical References OIM B-6-2, STG-D1 page 2-9 & 27 References to be provided to applicants during exam: None Learning Objective: STG-D.1 Obj 16

Questio	n Source:	Bank #
	(note changes; attach	Modified Bank #
parent)		

Requal A-0687

Comment [g7]: PRE

Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 (7)	Х
Diablo 20 ES-401 RO & SRO Question Worksheet Examination Outline Cross-reference: Level	002 Exam ML 023220665 Written Examination Form ES-40 RO SRO	01-6 Tier # 2 Group # 1
System: 061 Auxiliary / Emergency Feedwat A3 Ability to monitor automatic operation of t A3.01 AFW startup and flows. Proposed Question # 46 A plant startup is in progress per OP The reactor is at 9% power with Mai While rolling the Main Turbine, S/G I 75%.	er (AFW) System he AFW, including: ' L-3. n Feedwater Pump in service. evel control malfunctions result ir	K/A # 061. <b>A3.01</b> Importance Rating 4.2/ 4.2
Which of the following automatic act	ions would occur?	
A Both motor driven AFW pumps wil	I start following a time delay.	
B Both motor driven AFW pumps wil	l immediately start.	
C All AFW pumps will immediately s	tart.	
D All AFW pumps will start following	a time delay.	
Proposed Answer: B Explanation: Technical Reference(s): OIM page B-6-2 STG D-1 page 2-9 Proposed references to be provided to applie Learning Objective: 8432 Analyze AFW pum Question Source: Bank # A-0687 Modified Bank # New Question History: Last NRC Exam Question Cognitive Level: Memory or Funda Comprehension or Analysis X 10 CFR Part 55 Content: 55.41 7 55.43	cants during examination: NONE p control logic. mental Knowledge	

	-	
Examination Outline Cross-Reference	Level	RO
Ability to (a) predict the impacts of the following malfunctions	Tier #	2
or operations on the ac distribution system; and (b) based on	Group #	1
those predictions, use procedures to correct, control or mitigate	K/A #	062 A2.09
the consequences of those malfunctions or operations:	Rating	2.7
Consequences of exceeding current limitations.		

Given the following conditions:

- Unit 1 is at 100% power
- Unit 2 is in Mode 5 with D/G 2-2 out of service for maintenance
- A line fault occurs on 230kV Switchyard causing a loss of both 230kV Bus 1 and Bus 2

What is the impact on each Unit's 4kV vital system and what procedure would be used to mitigate the consequences?

- A. No effect on Unit 1. Unit 2 Vital 4kV Bus G is de-energized causing entry into OP-SD-0, "Loss of, or Inadequate Decay heat Removal".
- B. No effect on Unit 1. Unit 2 Vital 4kV Bus H is de-energized causing entry into OP-SD-1, "Loss of AC Power".
- C. Unit 1 Vital 4kV buses are energized from their respective Diesel Generators. Unit 2 Vital 4kV Bus H is de-energized causing entry into OP-SD-0, "Loss of, or Inadequate Decay Heat Removal".
- D. Unit 1 Vital 4kV buses are energized from their respective Diesel Generators. Unit 2 Vital 4kV Bus G is de-energized causing entry into OP-SD-1, "Loss of AC Power".

# Proposed Answer: B **Explanation:**

- A. Incorrect. Normal power to Unit 1 4kV buses is the Auxiliary Transformer, but OP-SD-0 will direct operator to OP-SD-1 Loss of Power. Restoring power will restore decay heat removal.
- B. Correct. Normal power to Unit 1 4kV buses is the Auxiliary Transformer. OP-SD-1 Loss of Power is highest priority. Restoring power will restore decay heat removal.
- C. Incorrect. Normal power to Unit 1 4kV buses is the Auxiliary Transformer. OP-SD-0 will direct operator to OP-SD-1 Loss of Power. Restoring power will restore decay heat removal.

Comment [g8]: (6/16/ 09) Changed EDG designation to Unit 2 instead of Unit 1. Changed info for Unit 2 in all the answers since the correct bus for EDG 2-2 is H, not G. PREVALID D. Incorrect. . Normal power to Unit 1 4kV buses is the Auxiliary Transformer, but OP-SD-1 is correct.

**Technical References:** OIM, Electrical Distribution Overview, Page J-1-1, Rev. 28, LER 2007-001-00

STG J-6A & 6B References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 (5)	Х

Examination Outline Cross-Reference	Level	RO
Ability to predict and/or monitor change in parameters	Tier #	2
associated with operating the DC electrical system controls	Group #	1
including: Battery capacity as it is affected by discharge rate	K/A #	063 A1.01
	Rating	2.5

A vital 125 VDC battery is supplying its distribution bus, and it is heavily DC loaded.

Which of the following describes battery parameter response over time?

- A. Battery current, electrolyte level, and specific gravity increase.
- B. Battery current increases, electrolyte level, and specific gravity decrease.
- C. Cell voltage decreases, electrolyte level and specific gravity increase.
- D. Cell voltage decreases, electrolyte level increases, and specific gravity decreases.

# Answer: B **Explanation:**

- A. Incorrect. Specific Gravity Drops
- B. Correct. As a battery discharges, Voltages drops(STG-J9 obj 26 page 5-12), Specific Gravity drops(STG-J9 obj 26,27 page 5-13), Electrolyte Level drops (STG-J9 obj 29 page 5-19), Charging current increases to carry load T/S 3.8.6 verifies float current < 2.0 amps</li>
- C. Incorrect. Electrolyte level drops
- D. Incorrect. Electrolyte level drops

#### Technical References: STG-J9 and T/S 3.8.6 basis References to be provided to applicants during exam: None Learning Objective: STG-J9 Obj 26,27 &29

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 (5)	х

**Comment [g9]:** (6/16/ 09) Minor edits made. PREVALID

Examination Outline Cross-Reference	Level	RO
Knowledge of the effect of a loss or malfunction of the following	Tier #	2
will have on the EDG system: Air Receivers	Group #	1
	K/A #	K6.07
	Rating	2.7

\_\_\_\_\_

Question 22

GIVEN:

- Unit 1 is at 100%
- A relief valve has failed open on Diesel Generator (DG) 1-1 Starting Air Receiver 1-1A
- The leakage exceeds the capacity of the starting air compressor.

Which of the following describes the affect of this failure on DG 1-1, if a start signal occurs prior to any operator action?

- A. Start in the normal allowed time from the 1-1B Starting Air Receiver via all four starting air solenoids.
- B. Will start but, starting time will exceed the surveillance required response time.
- C. Start in the normal allowed time via the 2 starting air solenoids associated with the Starting Air Receiver.
- D. Will not start because the starting air system will be depressurized.

Proposed Answer: C

Explanation:

- Incorrect. Diesel will start in normal time, but the start will be with only 2 of the 4 starting motors.
- B. Incorrect. Diesel will start, but will not exceed the surveillance time as the starting air systems are redundant.
- C. Correct. Start will occur in normal time via 2 starting air solenoids associated with the 1-1B starting air system

Х

D. Incorrect. The EDG will start.

**Technical References** STG 6B, Section 5 and T/S 3.8.8 Bases **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question	Source:	Bank #	4
	(note changes; attach	Modifi	ed Bank #
parent)			
		New	

Comment [g10]: (6/1 6/09) No Comments. PREVALID

Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7)	

#### BANKED ML082830427

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #	2	
Group #	1	
K/A #	064/K6.07	
Importance Rating	2.7	2.9

K/A: **Emergency Diesel Generator (ED/G) System** - Knowledge of the effect of a loss or malfunction of the following will have on the ED/G System: Air receivers.

Proposed Question:

Unit 1 is at 100%.

A relief valve has failed open on Diesel Generator (DG) 1-1 Starting Air Receiver 1-1A.

The leakage exceeds the capacity of the starting air compressor.

Which of the following describes the affect of this failure on DG 1-1, if a start signal occurs prior to any operator action?

- A. Start in the normal allowed time, from the 1-1B Starting Air Receiver via all four starting air solenoids.
- B. Will start but, starting time will exceed the surveillance required response time.
- C. Start in the normal allowed time via the 2 starting air solenoids associated with the 1-1B Starting Air Receiver.
- D. Will not start because the starting air system will be depressurized.

Proposed Answer: C

Explanation:

Answer A is incorrect. Diesel will start in normal time, but the start will be with only 2 of the 4 starting motors.

Answer B is incorrect. Diesel will start, but will not exceed the surveillance time as the starting air systems are redundant.

Answer C is correct. Start will occur in normal time via 2 starting air solenoids associated with the 1-1B starting air system.

Answer D is incorrect. Air systems are separate but redundant, one system failing will not affect the others operation.

Technical Reference(s):LJ-6B, Diesel Generator System, Pages 54-60, Rev. 12.Tech Spec 3.8.8 Bases, Page 39, Rev. 4.

Proposed references to be provided to applicants during examination: NONE

Learning Objective:	37728 - Decribe Die	37728 - Decribe Diesel Generator System components.			
Question Source:	Bank # Modified Bank # New	INPO - 23185 (Note changes or attach parent)			
Question History:	Last NRC Exam	N/A			
Question Cognitive Let	vel: Memory or Fu Comprehensio	ndamental Knowledge			
10 CFR Part 55 Conte	nt: 55.41 <u>7</u> 55.43	_			
10 CFR Part 55 Conte	nt: Design, compor systems, includ failure modes a	nents, and function of control and safety ing instrumentation, signals, interlocks, nd automatic and manual features.			

Examination Outline Cross-Reference	Level	RO
Knowledge of the operational implications as they apply to	Tier #	2
concepts as to the PM system: Radiation theory, including	Group #	1
sources, types, units, and effects.		073K5.01
	Rating	2.5
Question 23		

Unit 1 is at full power.

A small steam generator tube leak is causing steam line radiation monitor RM-73 to read 1000 cpm above background.

If the monitor is functioning properly, what should happen to the indication if power is reduced to 50%?

- A. Indication should decrease due to the decrease in N-16 production.
- B. Indication should decrease due to the decrease in iodine production.
- C. Indication should remain the same due to the continued tube leakage.
- D. Indication should increase because there is less steam flow but the same amount of radiation.

Answer A

Explanation:

- A Correct.
- B Incorrect.
- C Incorrect
- D Incorrect Technical References: OIM G-3-1, STG G-4a page 2.3-59. References to be provided to applicants during exam: None Learning Objective: 37877

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7)	

Comment [g1]: (6/16/ 09) No Comments. Question changed per DCPP recommendations. PREVALID

Examination Outline Cross-Reference	Level	RO
Knowledge of SWS design feature(s) and/or interlock(s) which	Tier #	2
provide for the following: Service water train separation.	Group #	1
Note: SWS is analogous to Auxiliary Salt Water	K/A #	076 K4.06
	Rating	2.8

Which of the following is the normal alignment of Auxiliary Salt Water Pump Crosstie Valves, FCV-495 and FCV-496, and what does this alignment ensure?

- A. They are both open. This ensures that a water hammer event resulting form an SWS pump trip and restart will not affect both trains.
- B. They are both closed. This ensures that a water hammer event resulting form an SWS pump trip and restart will not affect both trains.
- C. They are both open. This ensures that a single active failure that will not result in a significant reduction in heat removal capability.
- D. They are both closed. This ensures that train separation will not be compromised.

# Proposed Answer: C

#### Explanation:

- A. Incorrect. With FCV-495 and 49 both open, the headers are tied together. This will allow a water hammer event to affect both trains. Vacuum reliefs perform this function.
- B. Incorrect. With FCVV-495 and 496 both closed, a water hammer event will not affect both trains. This alignment is required by ECG 17.4 but only if both vacuum relief valves in one train are inoperable. This is NOT the normal arrangement
- C. Correct. FCV-495 and 496 are both open. This ensure that a single active failure that will not result in a significant reduction in heat removal capability
- D. Incorrect. If both FCV-495 and 496 are both closed this would ensure that train separation will not be compromised but this is NOT the normal arrangement.

# Technical References: STG-E5. T/S 3.7.8 basis ECG 17.4 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	Х
Question History:	Last NRC Exam	No

**Comment [g2]:** (6/16/ 09) Edited stem and answers. Added to explanation for A. PREVALID Question Cognitive Level:

10CFR Part 55 Content:

Memory/Fundamental Comprehensive/Analysis 55.41 (7)

Х

Examination Outline Cross-Reference	Level	RO
Knowledge of bus power supplies to the following: service	Tier #	2
water	Group #	1
	K/A #	076 K2.01
	Rating	3.1

What are the power supplies for the Unit 2 Auxiliary Saltwater Pumps, 2-1 and 2-2?

- A. Pump 2-1 is powered from Bus F; Pump 2-2 is powered from Bus G
- B. Pump 2-1 is powered from Bus G; Pump 2-2 is powered from Bus H
- C. Pump 2-1 is powered from Bus F; Pump 2-2 is powered from Bus H
- D. Pump 2-1 is powered from Bus G; Pump 2-2 is powered from Bus F

#### Proposed Answer: A

# Explanation:

Question 25

- A Correct: provide an explanation.
- B Incorrect.
- C Incorrect:
- D Incorrect:

**Technical References:** STG E-5, OIM J-1-1. **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7)	

Comment [g3]: (6/16/ 09) No Comments. PREVALID

Taken from April 2007 Draft Exam ML 072400068 RO Question 53 R1 Examination Outline Cross-Reference: Level RO SRO Tier: 2 Group: \_1\_\_ K/A: 076 K2.01 Importance Rating: 2.7 2.7 Proposed Question: What are the power supplies for the Unit 2 Auxiliary Saltwater Pumps, 2-1 and 2-2? Pump 2-1 Pump 2-2 A. Bus F Bus G B. Bus G Bus H C. Bus F Bus H D. Bus G Bus F Proposed Answer: A. Bus F Bus G Explanation: A correct. Pumps 1 and 2 are powered from Bus F and G respectively for both units. B incorrect. Pump 2-1 is powered from F, 2-2 powered from G. C incorrect. Pump 2-2 powered from G. D incorrect. Pump 2-1 powered from F. Technical Reference(s): STG E5, ASW Proposed references to be provided to applicants during examination: None Learning Objective: 5339 - State the power supply to the ASW Pumps. Question Source: New Question History: Last NRC Exam: N/A Question Cognitive Level: Memory or Fundamental Knowledge X Comprehension or Analysis 10 CFR Part 55 Content: 55.41.7 - Design, components, and function of control and safety systems, including instrumentation, signals, interlocks, failure modes, and automatic and manual features. Comments: Expanded justification. No other changes. K/A: 076 K2.01 - Knowledge of bus power supplies to the following: Service water (2.7/2.7)

Examination Outline Cross-Reference	Level	RO
Knowledge of bus power supplies to the following: Emergency	Tier #	2
air compressor	Group #	1
	K/A #	078K2.02
We don't have an "emergency" air compressor.	Rating	3.3

A loss of power to which of the following buses / load centers would have the most significant impact on Unit 2's ability to maintain normal instrument air header pressure (100 psig – 108 psig)?

- A. Unit 2, vital 4KV bus H
- B. Unit 1, vital 480V bus/load center G
- C. Unit 2, non-vital 480V bus/load center 22J
- D. Unit 1, non-vital 480V bus/load center 15E

#### Proposed Answer: D

#### Explanation:

- A. Incorrect. Compressors at both units are powered from non-vital sources.
- B. Incorrect. Compressors at both units are powered from non-vital sources
- C. Incorrect: Non-vital bus/load center 15D supplies only one reciprocating (normal) compressor and it is a Unit 1 MCC.
- D. Correct: Bus/load center 15E supplies power to one reciprocating and one rotary compressor.

#### Technical References: STG K-1 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	Х
parenty	New	
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 (7)	Х

# DCPP REACTOR OPERATOR NRC LICENSE EXAM, Dec. 2007 ML081006050

**Comment [g4]:** (6/16/ 09) Changed explanation for C. 15D is a Unit 1 Load Center. PREVALID Question 58 Examination Outline Cross-reference: Level RO SRO Tier # \_ 2\_\_\_\_ Group # 1 K/A # 078 K2.01 Importance rating \_ 2.7 \_ Instrument Air: Knowledge of the bus power supplies to the following: Instrument air compressors. **Ouestion: 54** A loss of power to which of the following busses/load centers would have the most significant impact on Unit 2's ability to maintain normal instrument air header pressure (100 psig - 108 psig)? A. Unit 2, vital 4KV bus H B. Unit 1, vital 480V bus/load center G C. Unit 2, non-vital 480V bus/load center 22J D. Unit 1, non-vital 480V bus/load center 15E Answer: \_\_ D\_\_ Explanation: A and B are incorrect since all compressors at both units are powered from non-vital sources. C is incorrect; non-vital bus/load center "J" is located in the Aux. Bldg and does not supply power to any compressor D is correct. Bus/load center 15E supplies power to one reciprocating and one rotary compressor.

Technical Reference(s): OIM J-1-1, Rev.27; STG K1, Rev. 12, pages 2.1-3,12; STG J7, Rev. 11, page 2-16

Proposed references to be provided to applicants during examination: None

Learning Objective: STG K1, Compressed Air System, Rev 12 obj 23

Question Source	Bank #		_		
	Modifi	ed Bank # _		(Note chang	ses or attach parent)
	New _	<u>X</u>			
Question Cognitive Le	vel:	Memory of Comprehe	r Fundamer nsion or Ar	ntal Knowle nalysis	dge <u>X</u>
		-		-	

Comments:

Examination Outline Cross-Reference	Level	RO
Knowledge of the effect that a loss or malfunction of the IAS will	Tier #	2
have on the following: Containment air system.	Group #	1
	K/A #	078 K3.01
	Rating	3.1

GIVEN:

- Unit 1 was at 100% power with all systems in automatic control
- Instrument Air pressure is 80 psig and lowering
- The SFM has directed entry to OP-AP-9, Loss of Instrument Air
- Immediately after entering OP-AP-9, the reactor trips

Which of the following describes the effect on air-operated valves inside containment and how the plant will be stabilized (post-trip)?

- A. No effect. All air operated valves were designed to fail to the safe position.
- B. No effect. Letdown and charging valves modulate properly on N2 backup with no additional operator is required.
- C. Pressurizer spray valves fail closed. Operator must manually control pressure by cycling proportional heaters on/off.
- D. PORVs 474, 455C and 456 fail closed and letdown isolates. Operator must restore letdown to avoid lifting a Pressurizer safety valve.

# Proposed Answer: C

# Explanation:

- A. Incorrect. All air operated valves are fail safe, but with no operate action the prssurizer will over fill as letdown is isolated and charging flow continues. Since Pzr sprays fail shut, a PORV lift will occur.
- B. Incorrect. Letdown must be restored by <u>manually</u> opening MS 1-902(sealed valve) and N2-1-34. (Appendix A page 17)
- C. Correct. See Op AP-9 step 5b
- D. Incorrect. PORV 455C and 456 will operate on backup N2.

Technical References STG K1 page 3-13, STG B1A pages 2.1-3&10, STG 4A page 2.1-46 and Procedure OP AOP-9 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source:

(note changes; attach

Bank # Modified Bank # **Comment [g5]**: (6/16/ 09) Edited Stem and answers for clarity. PREVALID

parent)	New	х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	x
10CFR Part 55 Content:	55.41 (7)	Λ

Examination Outline Cross-Reference	Level	RO
Knowledge of the physical connections and/or cause effect	Tier #	2
relationships between the containment system and the	Group #	1
following: SIS, including action of safety injection reset	K/A #	103 K1.08
	Rating	3.6

GIVEN:

- The reactor has tripped
- RCS pressure is 1300 psig and slowly lowering
- Pressurizer level is 5% and stable
- Containment pressure is 5 psig and lowering

The crew has transitioned to E-1 and is at Step 6, CHECK If Containment Spray Should Be Stopped

Which of the following describes the action that Operators should take to stop the containment spray pumps for the given conditions?

- A. Wait until containment pressure falls below Containment Hi Press Safety Injection setpoint. Reset Safety Injection. Reset Containment Spray. Stop Spray Pumps.
- B. Wait until containment pressure is below Containment Hi-Hi Press. Reset Containment Spray. Stop Spray Pumps.
- C. Check containment pressure is below Containment Hi Press Safety Injection setpoint. Reset Safety Injection. Reset Containment Spray. Stop Spray Pumps.
- D. Check containment pressure is below Containment Hi-Hi Press. Reset Containment Spray. Stop Spray Pumps.

#### Proposed Answer: D

Explanation:

- A Incorrect. SIS need not be reset to stop spray pumps. Credible distracter since SIS and Hi-Hi Containment Pressure starts pumps.
- B Incorrect. Containment pressure is already below the Hi-Hi Reset pressure setpoint 20 psig. The action of waiting is done in step 6.c, RNO.
- C Incorrect. See E-1 step 7 resetting <u>either</u> S/I or Hi-Hi Cnmt Spray
- D Correct. See E-1 step 6 resetting <u>either</u> S/I or Hi-Hi Cnmt Spray

**Technical References:** OIM B-6-8 E-1 Step 7 STG I2 page 2-10. **References to be provided to applicants during exam:** None **Learning Objective:** To be determined Comment [g6]: (6/16/ 09) Minor edits and added to explanation for B, to ensure nobody can argue that it may be correct. Modifications per DCPP input. PREVALID

Question Source: (note changes; attach	Bank # Modified Bank #	
pulony	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 (2 - 9)	х

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Knowledge of bus power supplies to the following: One-line	Group #	2
diagram of power supply to trip breakers.	K/A #	001 K2.02
	Rating	3.6
Question 29		

Which of the following sequence of power supplies describes the source of power for a Reactor Trip Breaker Under Voltage Coil?

- A. 480VAC Bus  $F \rightarrow PY-11 \rightarrow SSPS 48VDC$
- B. 480VAC Bus  $G \rightarrow PY-12 \rightarrow Eagle 21 \ 48VDC$
- C. 125VDC Bus  $\rightarrow$  SSPS 48VDC
- D. 125VDC Bus  $\rightarrow$  Reactor Trip Breaker Control Power

# Answer: A

#### Explanation:

- A. Correct Bus F supplies PY-11 which then supplies Train A 48VDC in SSPS
- B. Incorrect Bus G and PY-12 are correct, but Eagle 21 does not supply power; however, it does supply inputs to SSPS to trip the reactor.
- C. Incorrect Plausible if the applicant thinks 48VDC power supply for reactor trip breaker UV coils comes from 125VDC. SSPS is correct.
- D. Incorrect This is the sequence for the shunt trip coils

Technical References: B-6B (Eagle 21 and Solid State Protection System), J-10 (Instrument AC system) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41(7)	Х

**Comment [g1]:** (6/17/ 09) Rewrote question because C and D were not plausible since Vital and Non-Vital buses were mixed. RED is original.

(8/3/09) Top version accepted by facility. PREVALID.

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Knowledge of annunciator alarms, indications, or response	Group #	2
procedures.	K/A #	002 G2.4.31
	Rating	4.2

GIVEN:

- Unit 1 is in MODE 5
- LTOP is in service

RCS pressure rises to 440psig and PK02-16, RHR SYSTEM, alarms.

Based on this, PORV PCV-455C should be \_\_\_\_\_; and, RHR-8702, RHR suction valve, is

- A. Closed; Open
- B. Closed; Closed and blocked from opening
- C. Open; Open
- D. Open; Closed and blocked from opening

#### Answer: C

#### **Explanation:**

- A. Incorrect PORV should be open
- B. Incorrect The PORV should be open
- C. Correct
- D. Incorrect PK02-16 alarming means suction valve is open

Technical References: System Training Guide A-1, Reactor Coolant System References to be provided to applicants during exam: None Learning Objective: To be determined

tuestion Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	Х
Question History:	Last NRC Exam	No

Comment [g2]: (6/17/ 09) KA Mismatch. Question rewritten so that applicant has to know what causes PK02-16 to annunciate.

(8/3/09) DCPP commented that the valve would not automatically close, and that C was correct. Revised stem. PREVALID. **Question Cognitive Level:** 

10CFR Part 55 Content:

Memory/Fundamental Comprehensive/Analysis 55.41 (3, 5, 7)

Х

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Ability to manually operate and/or monitor in the control room:	Group #	2
NIS indicators	K/A #	015 A4.02
	Rating	3.9

GIVEN:

- A reactor startup is in progress on Unit 1
- SR Channel N-31 indicates 6 x 10<sup>3</sup> cps
- SR Channel N-32 indicates 8 x 10<sup>3</sup> cps
- IR Channel N-35 indicates 2 x 10<sup>-9</sup> amps
- IR Channel N-36 indicates 3 x 10<sup>-11</sup> amps

Which of the following describes the response of the Intermediate Range Excore Nuclear Instruments?

- A. IR Channel N-35 is reading abnormally high; P-6 permissive is NOT enabled.
- B. IR Channel N-36 is reading abnormally low; P-6 permissive is enabled.
- C. IR Channel N-35 is reading abnormally high; P-6 permissive is enabled.
- D. IR Channel N-36 is reading abnormally low; P-6 permissive is NOT enabled.

# Answer: C

# **Explanation:**

- A. Incorrect. IR N-35 is high, but the logic for P-6 is satisified w/1 of 2 IR above the setpoint of 1 x  $10^{-10}$  ICA.
- B. Incorrect. N-36 is reading approximately what it should be for the current source range counts.
- C. Correct Based SR/IR overlap criteria, IR Channel N-35 is reading abnormally high for existing conditions; P-6 permissive is enabled when ONE IR channel > 10<sup>-10</sup> amps. Manual action is required to de-energize SRHV.
- D. Incorrect. N-36 reading is correct, and P-6 permissive is enabled.

Technical References: System Lesson Guide B-4, Excore Nuclear Instrumentation OIM page B-4-1 References to be provided to applicants during exam: None Learning Objective: To be determined Comment [g3]: (6/17/ 09) Removed ONE from the stem. Edited NIS indications. Removed "for existing conditions" from answers B, C and D.

(8/3/09) Incorporated DCPP recommendations. PREVALID.

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 ( 2, 6 )	

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Ability to monitor automatic operation of the NNIS, including: Automatic selection of NNIS inputs to control systems	Group #	2
	K/A #	016 A3.01
	Rating	2.9

GIVEN:

- Unit 1 is operating at 100%
- PK05-21 PZR LEVEL HI/LO is alarming
- PK05-22 PZR LEVEL HI/LO CONTROL is alarming
- PZR level is rising
- PZR heaters are de-energized

The Controlling Pressurizer level has failed

- A. HIGH; actual PZR level will stabilize at a new higher level.
- B. LOW; actual PZR level will stabilize at a new higher level.
- C. HIGH; actual PZR level will increase until a high level reactor trip occurs.
- D. LOW; actual PZR level will increase until a high level reactor trip occurs.

# Answer: D

#### **Explanation:**

- A. Incorrect Controlling PZR level has failed LOW; Letdown will isolate, and without operator action to switch to a non-faulted controlling channel, pressurizer level will increase until a high level reactor trip occurs.
- B. Incorrect PZR level will not stabilize at a new higher level.
- C. Incorrect Controlling PZR level has failed LOW.
- D. Correct Initial indications of a failed PZR level controller failing LOW are heaters DE-ENERGIZING and pressurizer level INCREASING. Although pressurizer level will ultimately increase on a failed level controller failing HIGH, due to letdown isolation, the initial indications of a failed PZR channel HIGH are Backup heaters ENERGIZING and pressurizer level DECREASING. Letdown will isolate in both conditions and ultimately lead to a high level reactor trip without operator action.

Technical References: Operator Information Manual, A-4-2a (Pressurizer Level

**Comment [g4]:** (6/17/ 09) Weak tie to KA; however, since Automatic Selection is a feature of B&W, the operators should know they do NOT have this at Westinghouse. Dressed up the stem. Changed cognitive level to comp.

(8/3/09) Revised stem according to DCPP recommendations. Will leave the question as-is even though auto selection is not made. PREVALID.

# Control), A-4-2b (Pressurizer Level Channel Failures) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
pulonty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 ( 3, 7 )	х

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Ability to (a) predict the impacts of the following malfunctions	Group #	2
or operations on the ITM system; and (b) based on those	K/A #	017 A2.02
predictions, use procedures to correct, control or mitigate the	Rating	3.6
consequences of those malfunctions or operations: Core		
damage		

GIVEN:

- A small break LOCA has occurred
- No ECCS CCPs or SI pumps are running
- All RCPs are secured
- In-core thermocouples indicate 1210°F

Which of the following describes the status of core cooling and the preferred mitigation strategy to restore core cooling?

- A. Core cooling is degraded. RCPs should be restarted.
- B. Core cooling is inadequate. RCPs should be restarted.
- C. Core cooling is degraded. Restore ECCS flow.
- D. Core cooling is inadequate. Restore ECCS flow.

#### Answer: D

#### **Explanation:**

A incorrect. Incores above 1200°F indicate inadequate core cooling. Restart of RCPs is the least preferred method.

B incorrect. Incores above 1200°F indicate inadequate core cooling. However, restoring ECCS flow is the preferred method, RCP restart is the least preferred.

C incorrect. Core cooling is inadequate.

D correct. Core cooling is inadequate and the preferred method of addressing the situation is to restore ECCS flow.

Technical References: FR-C.1 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source:		Bank #
	(note changes; attach	Modified Bank #
parent)		

New

Comment [g5]: (6/17/ 09) KA mismatch. The question needs to address both parts of the KA. First, the impact on ITM from core damage or the indications on ITM that core damage is imminent Second use an EOP to address this. In this case, we don't want to reach core damage. (8/4/09) Used question suggested by DCPP as replacement. PREVALID

Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 ( 2, 7 )	

Examination Outline Cross-Reference	Level	RO
Ability to predict and/or monitor changes in parameter (to	Tier #	2
	Group #	2
prevent exceeding design limits) associated with operating the		028 A1.01
HRPS controls including: Hydrogen concentration	Rating	3.4

GIVEN:

- Large Break LOCA is in progress
- Core damage is occurring
- #1 Electric Hydrogen Recombiner is in service
- #2 Electric Hydrogen Recombiner is ready to be placed in service
- Containment Hydrogen concentration is 3.2%

Which of the following describes the minimum equipment that is needed in operation in order to maintain hydrogen at or below the current concentration?

- A. ONE Combiner and the Containment Purge System in service.
- B. ONE Combiner ONLY in service.
- C. ONE Combiner and Containment Spray System in service.
- D. BOTH Combiners in service.

#### Answer: B

#### **Explanation:**

- A. Incorrect Each Containment Hydrogen Recombiner has 100% capacity. The Containment Purge System is to be used as a back up to the CHRs once hydrogen concentration reaches 3.5% by volume.
- B. Correct Only one Recombiner is needed to maintain hydrogen concentration in Containment below 4% by volume.
- C. Incorrect Containment Spray is only placed in service once Containment reaches 22 psig, well above the pressure when the Recombiners would be placed in service.
- D. Incorrect Only one Recombiner is needed to maintain hydrogen concentration in Containment below 4% by volume.

Technical References: System Lesson Guide H-8 (Containment Hydrogen Purge System), SLG H-9 (Containment Hydrogen Recombiners), SLG I-2 (Containment Spray System) **Comment [g6]:** (6/17/ 09) This is a true/false style question, and is unsat. You don't need any information in the stem to answer this question. Rewrite.

(8/4/09) Question revised. PREVALID.

# References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 ( 7, 9 )	

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Knowledge of the effect of a loss or malfunction on the		2
following will have on the SDS: Controller and positioners,	K/A #	041 K6.03
including <mark>ICS</mark> , S/G, CRDS		2.7

GIVEN:

- Unit 1 has tripped from 100% power
- Reactor Trip Breaker 'A' is open
- Reactor Trip Breaker 'B' is closed
- Steam Dump Mode Select Switch is selected to Tavg

What is the status of the Steam Dump System?

- A. Groups 1 and 2 steam dump valves will actuate on the Load Rejection Controller; Groups 3 and 4 will NOT actuate.
- B. Groups 1 and 2 steam dump valves will actuate on the Reactor Trip Controller; Groups 3 and 4 will NOT actuate.
- C. Groups 1, 2, 3, and 4 steam dump valves will actuate on the Load Rejection Controller.
- D. Groups 1, 2, and 3 steam dump valves will actuate on the Reactor Trip Controller; Group 4 will NOT actuate.

# Answer: A

Explanation:

- A. Correct Groups 1 and 2 will actuate on the Load Rejection Controller, which modulates due to Reactor Trip Breaker 'B' remaining closed. Groups 3 and 4 will not actuate due to a lack of arming signal with Reactor Trip Breaker 'A' opening.
- B. Incorrect Groups 1 and 2 will not actuate on the Reactor Trip Controller due to Reactor Trip Breaker 'B' remaining closed on the trip.
- C. Incorrect Groups 1 and 2 will actuate on the Load Rejection Controller, but Groups 3 and 4 will not.
- D. Incorrect Groups 1 and 2 will actuate on the Load Rejection Controller, not the Reactor Trip Controller. Group 3 is not controlled by the Reactor Trip Controller.

Technical References: System Lesson Guide C-2B, Steam Dump System References to be provided to applicants during exam: None Comment [g7]: B&W

**Comment [g8]:** (6/17/ 09) Edited the stem for clarity and focus. The training material labels the groups in Roman Numerals. Is this necessary? (8/4/09) No Comments. PREVALID. Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	'A' Bank #58
parent)	New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х
10CFR Part 55 Content:	55.41 (7)	

Examination Outline Cross-Reference	Level	RO
Knowledge of the operational implications of the following concepts as they apply to the MT/B System: Purpose of low-power reactor trips (limited to 25% power)	Tier #	2
	Group #	2
	K/A #	045 K5.18
	Rating	2.7

GIVEN:

- Unit 1 is at 19% power and paralleled to the grid
- The crew is operating in accordance with OP L-3, Secondary Plant Startup
- The Main Unit Turbine EHC malfunctions, and turbine loading increases uncontrollably

If no operator action is taken, \_\_\_\_\_

- A. only the reactor will trip at 25% reactor power. The reactor trip protects the core from the positive reactivity excursion.
- B. both the reactor and turbine will trip at 25% reactor power. The reactor trip protects the core from the positive reactivity excursion
- C. both the reactor and turbine will trip on OP∆T. The reactor trip protects the core against operating with a power density greater than 21.1 kW/foot
- D. only the reactor will trip on OP∆T to protect the core against operating with a power density greater than 21.1 kW/foot.

# Answer: C

# **Explanation:**

- A. Incorrect Both the reactor and turbine will trip, but not at 25% reactor power
- B. Incorrect -
- C. Correct With the plant at 19%, the high flux low setpoint has been bypassed in accordance with OP L-3. Therefore, the applicant must know the purpose of the 25% power trip to know that it is not in effect.
- D. Incorrect

Technical References: System Lesson Guide B-6A (Reactor Protection System), Tech Spec Bases B 3.3.1 (Instrumentation) References to be provided to applicants during exam: None Learning Objective: To be determined **Comment [g9]:** (6/17/ 09) P4 permissive (RTBs open) is a turbine trip signal, so answer D would be correct. The explanations are incorrect. Rewritten. Choose one of them.

DCPP Verify this is correct.

Question Source: (note changes; attach	Bank # Modified Bank #	
pulonty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 ( 5, 6, 7 )	х
Examination Outline Cross-Reference	Level	RO
---	---------	-----------
	Tier #	2
Knowledge of ARM system design feature(s) and/or interlock(s)	Group #	2
which provide for the following: Containment Ventilation	K/A #	072 K4.01
Isolation	Rating	3.3

Which of the following radiation monitors, if in high alarm, will cause Containment Purge Exhaust valves (RCV-11 and RCV-12) to automatically close?

- A. RM-13, RHR Exhaust Duct Air Particulate monitor
- B. RM-44A, Containment Radiation Monitor
- C. RM-29, Plant Vent Gross Gamma monitor
- D. RM-34, Plant Vent ALARA monitor

#### Answer: B

#### **Explanation:**

- A. Incorrect
- B. Correct RM-44A/B in high alarm initiates a containment isolation signal. The containment isolation signal will close RCV-11 and -12.
- C. Incorrect
- D. Incorrect

#### Technical References: LH-4 Containment Purge System References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х

Comment [g10]: (6/1 7/09) Rewrite. This is a repeat and almost exact same question Sean wrote. Resample KA. (8/4/09) Rewritten question was again the same as Sean's question. Picked K4.01 and rewrote the question. PREVALID. **10CFR Part 55 Content:** 55.41 (7, 11)

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Knowledge of the physical connections and/or cause-effect relationships between the circulating water system and the following systems: Emergency/essential SWS	Group #	2
	K/A #	075 K1.08
	Rating	3.2

In accordance with OP AP-10 (Loss of Auxiliary Saltwater), when is it appropriate to cross-tie the Auxiliary Saltwater (ASW) and the Circulation Water bays?

- A. If one unit loses its ASW pumps and the other unit's ASW pumps are not available.
- B. If the Circulation Water screens are severely clogged and the ASW screens are not available.
- C. If Chlorine injection into the ASW system is necessary.
- D. If the ASW pumps are losing suction

#### Answer: D

#### Explanation:

- A. Incorrect The correct action would be to enter OP AP-11, Loss of CCW.
- B. Incorrect This would require isolating the two trains for the affected unit.
- C. Incorrect This would require operating with the opposite unit supplying.
- D. Correct If the bay level is low and the pumps are losing suction (or cavitating), cross-tying would be appropriate if the Circulation Water screens are less affected.

Technical References: AR PK01-03 (Auxiliary Saltwater Pumps), AP-10 (Loss of Auxiliary Salt Water) References to be provided to applicants during exam: None Learning Objective: To be determined

Questio	n Source:	Bank #	X #65 February 2005 Exam
	(note changes; attach	Modified Bank #	
parent)			
pa. e ,		New	

**Question History:** 

Last NRC Exam

No

Comment [g11]: (6/1 9/09) Rewrote question to focus on OP AP-10. You want to make sure that the questions are backed by procedure steps. Changed cognitive level. Changed to Modified Bank. The red question is the bank question. This is still very close to a backwards logic question. We will see how this plays out after NRC review.

(8/3/09) DCPP recommended keeping the original question. May be too close to backward logic. PREVALID Question Cognitive Level:

10CFR Part 55 Content:

Memory/Fundamental Comprehensive/Analysis 55.41 (10)

Х

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the operational implications of the following	Group #	1
concepts as they apply to a Pressurizer Vapor Space Accident:	K/A #	008 AK 1.02
Change in leak rate with change in pressure.	Rating	3.1

## Rewrite Given the following conditions:

- The reactor has tripped
- PCV-474 (PORV) has opened and subsequently failed to close
- Block Valve 8000 A failed to close
- RCS pressure is 1200 psig and lowering.
- Pressurizer level is 17% and stable
- Containment pressure is 2 psig
- RCS subcooling requirements are met

Which ONE of the following describes the next action that operators should take for the given conditions?

- A. Throttle flow from both ECCS SI pumps.
- B. Maintain maximum ECCS flow until RHR cooling can be established.
- C. Secure both ECCS CCPs.
- D. Secure one ECCS CCP and both SI pumps.

#### Answer: D

#### **Explanation:**

- A. Incorrect Both SI pumps will be stopped (E-1.2 step 17) in order to re-establish normal charging
- B. Incorrect One ECCS CCP and both SI pumps will be stopped prior to establishing RHR cooling
- C. Incorrect Only one ECCS CCP is stopped
- D. Correct One ECCS CCP and both SI pumps are stopped, per E-1.2 step 17 prior to establishing RHR cooling in step 32.

Technical References: E-1.2 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source:

Bank #

**Comment [g1]:** (6/19/ 09) Replace this question. A similar one has been written be Sean Currie.

(note parent)	(note changes; attach	Modified Bank #	
		New	Х
Question	History:	Last NRC Exam	No
Question	Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х
10CFR Pa	rt 55 Content:	55.41 (5 and 10)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the interrelations between the small break LOCA and the following: S/Gs	Group #	1
	K/A #	009 EK 2.03
	Rating	3.0

GIVEN:

- A small break LOCA has occurred in containment
- The LOCA is within the capacity of one SI pump
- RCS pressure is 1900 psig and slowly lowering
- MSIVs are shut
- All steam generators are available

Is a secondary heat sink necessary in order to maintain adequate core cooling?

- A. No, because ECCS flow is providing adequate core cooling.
- B. Yes, because this will allow ECCS flow to equal break flow.
- C. Yes, because secondary pressure must be maintained below primary pressure during all LOCA events.
- D. No, because ECCS recirculation flow will provide adequate cooling.

#### Answer: B

#### Explanation:

- A. Incorrect Secondary heat sink is required in order for the RCS to reach equilibrium pressure, allowing high pressure SI flow to equal break flow, and thus guarantee that core cooling and decay heat removal are adequate.
- B. Correct
- C. Incorrect When secondary pressure is greater than primary pressure, the secondary becomes a heat source vice a heat sink.
- D. Incorrect Secondary heat sink is required for a small break LOCA and not for a large break LOCA, when the RCS will completely depressurize.

Technical References: WOG, Background Information E-1, pages 5 and 52 References to be provided to applicants during exam: None Learning Objective: To be determined

Bank #

Question Source:

**Comment [g2]:** (6/19/ 09) Changed stem and answers.

(note changes; att parent)	(note changes; attach	Modified Bank #	
		New	х
Question	History:	Last NRC Exam	No
Question	Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Pa	rt 55 Content:	55.41 (7)	

Examination Outline Cross-Reference	Level	RO
Knowledge of the reasons for the following responses as they apply to the Large Break LOCA: RCP tripping requirement	Tier #	1
	Group #	1
	K/A #	011 EK 3.14
	Rating	4.1

GIVEN:

- Unit 1 was at 100% power
- A large break LOCA occurred
- SI actuated and all required systems operated normally
- RCS pressure is 1200 psig and lowering
- SG 1-2 NR level is 17% and rising
- All other SG NR levels are 14% and rising
- Total AFW flow is 400GPM
- Containment pressure is 10 psig and rising
- The crew has transitioned to E-1, Loss of Reactor or Secondary Coolant

What is the next action that the crew should take?

- A. Maintain total AFW flow greater than 435GPM to maintain an adequate heat sink.
- B. Trip all RCPs because they have little or no effect on mitigating a large break LOCA.
- C. Trip all RCPs to prevent excessive depletion of RCS inventory.
- D. Maintain AFW flow to each SG greater than 435GPM to enable RCS cooldown.

#### Answer: B

#### **Explanation:**

- A. Incorrect SG levels are at the correct level for the given AFW flow
- B. Correct For large break LOCAs, the operation of the RCPs has little if any effect during mitigation and recovery.
- C. Incorrect This is the design basis for a small break LOCA, not a large break LOCA
- D. Incorrect Should be total AFW flow.

## Technical References: Background Information WOG, Generic Issue, RCP Trip/Restart, pages 7-10

References to be provided to applicants during exam: None Learning Objective: To be determined

**Comment [g3]:** (6/19/ 09) Changed question to make it more operationally valid. The answer is still the same.

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (10)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to operate and/or monitor the following as they apply to	Group #	1
the Reactor Coolant Pump Malfunctions (Loss of RC Flow): RCP	K/A #	015/17
vibrations.		AA1.23
	Rating	3.1

GIVEN:

- Unit 1 is at 100% Power
- PK05-03, RCP 3 UP BRG L/O RESVR LVL HI/LO, is ON
- RCP 3 motor bearing temperature is 202°F
- PK05-05, RCP HIGH VIBRATION, is ON
- Vibration Monitoring System is indicating 25 mils on the Pump Shaft of RCP 3

In accordance with OP AP-28, RCP Malfunctions, what action should the operators take?

- A. Stop RCP 3 and then perform E-0 immediate actions.
- B. Shutdown the reactor per OP AP-25, Rapid Load Reduction, and then stop RCP 3.
- C. Trip the reactor, enter E-0, and then immediately stop RCP 3.
- D. Initiate trending on RCP 3, monitor CCW surge tank levels and prepare to make containment entry to determine oil levels on RCP 3.

#### Answer: C

#### **Explanation:**

- A. Incorrect This has to be done in conjunction with tripping the reactor.
- B. Incorrect This would be the appropriate action if the #1 seal on RCP 3 had a leak rate of .8 GPM and bearing/motor temperatures were stable. The #1 seal on RCP 3 is intact.
- C. Correct Tripping the reactor and the RCP are the immediate actions per OP AP-28 for any RCP that has any bearing temperature alarm concurrent with a vibration alarm.
- D. Incorrect This would be the appropriate action if the bearing temperature were less than 190°F with no concurrent vibration alarm.

Technical References: OP AP-28, Reactor Coolant Pump Malfunction References to be provided to applicants during exam: None Learning Objective: To be determined **Comment [g4]:** (6/19/ 09) Changed stem to tie this to a procedure. Minor edits to the answers.

Question Source: (note changes; attach	Bank # Modified Bank #		
parenty	New	Х	
Question History:	Last NRC Exam	No	
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х	
TUCFR Part 55 Content:	55.41 (3 and 5)		

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to determine and interpret the following as they apply to the Loss of Reactor Coolant Makeup: Whether charging line leak exists.	Group #	1
	K/A #	022 AA2.01
	Rating	3.2

GIVEN:

- Unit 1 is at 100% power
- Pressurizer level is slowly lowering
- RCS pressure is slowly lowering
- FI-128 (charging flow) is lowering
- PI-142 (charging header pressure) is lowering
- PK11-21, HIGH RADIATION, is ON due to an Aux Bldg area radiation monitor
- The crew has entered OP AP-17, Loss of Charging

Based on this, the most likely location of the leak is \_\_\_\_\_.

- A. between the CCP discharge valves and FCV-128, CCP flow control valve
- B. on the charging return line, downstream of the regenerative heat exchanger
- C. downstream of HCV-142, RCP Seal flow control valve
- D. on one of the ECCS cold leg injection lines

#### Answer: A

#### Explanation:

- A. Correct since the leak is between the CCP discharge valve and FCV-128 isolation valve, FT-128 will see decreased flow, and thus pressure on the charging header will drop (PT-142 correctly indicating lower pressure).
- B. Incorrect If the leak were downstream of the RHX, the pressure on the header would increase (due to increase charging demand from the Pressurizer which is seeing reduced flow) and FT-128 would see increased flow. Also there is no high radiation alarm coming from containment, where the RHX is located, but from the Auxiliary Building, where the CCPs and FCV-128 are located.
- C. Incorrect HCV-142 is downstream of FT-128. FT-128 would indicate an increase flow due to the demand from a leak downstream of HCV-142 and FT-128.
- D. Incorrect Leak location is incorrect.

#### Technical References: OP AP-17, Loss of Charging

Comment [g5]: (6/19/ 09) Edited stem and answers.

# References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 ( 5 and 10)	Х

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Emergency Procedures/Plan: Knowledge of how abnormal operating procedures are used in conjunction with EOPs.	Group #	1
	K/A #	025 G 2.4.8
	Rating	3.8

#### Given the following:

- Reactor is shutdown with all head closure bolts fully tensioned
- RCS and Secondary system intact
- RCS pressure at 165#
- Loss of AC power has occurred, OP AP SD-1 has been entered, and restoration of 4kV and 480V buses will not occur for at least two hours
- Reactor core outlet temperature at 140°F and increasing steadily

What is the correct operator action that needs to be taken?

- A. Enter OP AP SD-5 (Loss of RHR) until temperature decreases.
- B. Enter OP AP-16 (Malfunction of RHR System) and verify temperature decreasing.
- C. Enter OP AP SD-0 (Loss of or inadequate decay heat removal) and commence decay heat removal using Steam Generators.
- D. Enter OP AP SD-0 and commence decay heat removal using Feed and Bleed.

#### Answer: C

#### Explanation:

- A. Incorrect Per OP AP SD-1 (Loss of AC Power) step 20, due to the loss of the 480V and 4kV buses, the procedure directs the Operator to OP AP SD-0, step 7, to verify Steam Generators available and commence decay heat removal with RCS pressure greater than 150#.
- B. Incorrect This procedure is applicable in Mode 4, not Mode 5, which is the current condition. Also, this procedure does not assume a loss of AC power.
- C. Correct
- D. Incorrect OP AP SD-1 directs the Operator to OP AP SD-0, step 7, in order to use the Steam Generators as a method of decay heat removal and then back to the procedure for Loss of AC Power once temperature is stabilized.

Technical References: OP AP SD-0 (Loss of or inadequate decay heat removal), OP AP SD-1 (Loss of AC Power)

**Comment [g6]:** (6/19/ 09) KA mismatch. Replace question.

# References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 ( 5 and 10)	х

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to determine and interpret the following as they apply to	Group #	1
the Loss of Component Cooling Water: The cause of possible	K/A #	026 AA2.02
CCW loss.	Rating	2.9

GIVEN:

- Reactor tripped
- CCW SURGE TANK (PK01-07) Annunciator alarm alarming
- CCW VITAL HDR A/B (PK01-06) Annunciator alarm alarming
- Unit 1 CCW Surge Tank level decreasing
- RCPs tripped
- Simultaneously entered into EP E-0 (Reactor Trip) and OP AP-11 (Malfunction of Component Cooling Water System)
- Unit 2 CCW cross-connected to Unit 1

What is the source of the Component Cooling Water malfunction?

- A. Un-isolable out-leakage from Unit 1 CCW Surge Tank.
- B. Loss of CCW flow to the Let Down Heat Exchanger in Unit 1.
- C. Out-leakage from CCW Header 'A', necessitating isolation of the entire header.
- D. Loss of CCW flow in Unit 1.

#### Answer: A

#### **Explanation:**

- A. Correct Per OP AP-11, Section F, if the Surge Tank leak is un-isolable the system is cross-connected to the other Unit.
- B. Incorrect CCW is not cross-connected from the other unit on loss of CCW flow to the Let Down Heat Exchanger.
- C. Incorrect Isolation of the header would occur per OP AP-11, Section A, and then loads would be switched to equipment that can be supplied by another header. Cross-connection to the other Unit does not occur.
- D. Incorrect If no CCW pump can be placed in service, then Per OP AP-11, Appendix C (Backup Cooling to ECCS CCP) is performed in conjunction with Appendix B (CCW Heat Load Isolation).

## Technical References: OP AP-11, Malfunction of Component Cooling Water References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 ( 5 and 10)	Х

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to operate and monitor the following as they apply to an	Group #	1
ATWS: Reactor trip switch pushbutton.	K/A #	029 EA1.08
	Rating	4.5

With the reactor at 100%, an operator at the turbine EHC system station inadvertently repositions the valve position limiter rapidly from 100% to 10%, with the following conditions as a result:

- Steam dumps opened
- Indicated nuclear power presently at 96% and slowly decreasing
- Pressurizer Pressure Channel 'A' and 'B' indicate 2386# and 2388#, respectively
- Pressurizer level is increasing
- AUCT HI TAVG is 592°F and slowly increasing

Which ONE of the following describes the required condition of the reactor and the correct subsequent operator action?

- A. The reactor is responding correctly to the transient with the operator ensuring that Pressurizer spray has initiated in order to reduce pressure.
- B. Reactor power should be decreasing steadily as Bank 'D' rods move in due to Tref < Tavg necessitating the operator take manual control of the rods to lower Tavg.
- C. The reactor should have tripped and so the operator must continuously insert controls rods to ensure subcriticality.
- D. The reactor should have tripped and so the operator must depress the reactor trip switch pushbutton on his panel.

#### Answer: D

#### **Explanation:**

- A. Incorrect The reactor should have tripped on two out of four pressurizer pressure channels indicating more than the 2385# high pressure setpoint. The first operator action per EOP FR-S.1 (Response to Nuclear Power Generation/ATWS) in step one, is to verify the reactor tripped, with the 'Response Not Obtained' column specifically directing the operator to manually trip the reactor and only continuously inserting rods if the reactor will not trip manually.
- **B.** Incorrect
- C. Incorrect

#### D. Correct

Technical References: EOP E-0 (Reactor Trip or Safety Injection), EOP FR-S.1 (Response to Nuclear Power Generation/ATWS), Primary Systems A-4A (Pressurizer, Pressure and Level Control) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
paronty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 ( 5 and 10)	Х

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the reasons for the following responses as they	Group #	1
apply to the SGTR: Equalizing pressure on primary and	K/A #	038 EK3.01
secondary sides of ruptured S/G.	Rating	4.1

A Steam Generator Tube Rupture has occurred and EOP E-3, "Steam Generator Tube Rupture", has been entered. Depressurization of the RCS is in progress.

What is the PRIMARY goal of depressurizing the RCS to match the pressure of the faulted Steam Generator?

- A. Equalizing the pressure of the faulted Steam Generator with RCS pressure will preclude the possibility of an unmonitored atmospheric release and possible exposure to the public.
- B. Equalizing pressure of the faulted Steam Generator with RCS pressure will aid Safety Injection in replenishing RCS inventory and prevent uncovering of Pressurizer heaters.
- C. Depressurizing the RCS to match the faulted Steam Generator and maximize subcooling to help prevent the transition of primary coolant to the secondary system.
- D. Depressurizing the RCS to match the faulted Steam Generator and minimize subcooling to help prevent the transition of primary coolant to the secondary system.

#### Answer: D

#### Explanation:

- A. Incorrect Per the Caution of EOP E-3, step 35, "An UNMONITORED atmospheric release MAY occur IF RCS <u>or</u> Ruptured S/Gs Pressures EXCEED 1040 PSIG".
- B. Incorrect The PRIMARY concern of equalizing RCS pressure and faulted Steam Generator pressure, with the addition of MINIMIZING sub-cooling, is to stop the leak and prevent further primary coolant from entering the secondary system.
- C. Incorrect
- D. Correct

Technical References: EOP E-3 (Steam Generator Tube Rupture), AOP AP-3 (Steam Generator Tube Failure), EOP E-3 Bases, References to be provided to applicants during exam: None Learning Objective: To be determined

Bank # Modified Bank #	
New	Х
Last NRC Exam	No
Memory/Fundamental Comprehensive/Analysis 55.41 ( 5 and 10)	х
	Bank # Modified Bank # New Last NRC Exam Memory/Fundamental Comprehensive/Analysis 55.41 ( 5 and 10)

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the interrelations between the Steam Line Rupture and the following: Sensors and detectors.	Group #	1
	K/A #	040 AK2.02
	Rating	2.6

The plant is at normal operating temperature and pressure.

Which of the following would satisfy the MINIMUM coincidence necessary to cause Main Steam Isolation Valve actuation on High-High Containment pressure?

- A. 1 of 4 Containment pressure channels sensing greater than or equal to 22 psig coincident with Phase 'A' CI signal.
- B. 1 of 4 Containment pressure channels sensing greater than or equal to 22 psig coincident with Phase 'B' CI signal.
- C. 2 of 4 Containment pressure channels sensing greater than or equal to 22 psig coincident with Phase 'A' CI signal.
- D. 2 of 4 Containment pressure channels sensing greater than or equal to 22 psig coincident with Phase 'B' CI signal.

#### Answer: D

#### **Explanation:**

- A. Incorrect
- **B.** Incorrect
- C. Incorrect
- D. Correct Main Steam Line Isolation Actuation signal is generated by two of four Containment pressure channels reading greater than or equal to 22 psig. Containment Phase 'B' CI signal is generated by this same logic.

Technical References: LB-6A, Reactor Protection System References to be provided to applicants during exam: None Learning Objective: To be determined

Question	Source:	Bank #
	(note changes; attach	Modified Bank #
parent)		
		New

Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the operational implications of the following	Group #	1
concepts as they apply to the Station Blackout: Effect of battery	K/A #	055 EK1.01
discharge rates on capacity.	Rating	3.3
Question 49		

The site is in a station blackout condition and the operators have entered ECA-0.0 (Loss of All Vital AC Power). Step 15 directs the operators to begin shedding non-essential DC loads.

What is the basis for the capacity of the batteries for the vital and non-vital DC buses and the primary concerns with not reducing their discharge rates?

- A. Two hours battery capacity Concerns are breaking Main Turbine vacuum at 150 rpm or greater in order to reduce the time in service of the DC Bearing Oil pump, and the potential for excessive battery hydrogen build-up.
- B. Two hours battery capacity Concerns are loss of emergency lighting and irreversible damage to the battery as it approaches its end voltage.
- C. Three hours battery capacity Concerns are loss of emergency lighting and potentially excessive hydrogen build-up.
- D. Three hours battery capacity Concerns are breaking Main Turbine vacuum at 150 rpm or greater in order to reduce the time in service of the DC Bearing Oil pump, and the potential for irreversible damage to the battery as it approaches its end voltage.

#### Answer: B

#### **Explanation:**

- A. Incorrect A concern is breaking Main Turbine vacuum, but at 200 rpm or greater, not 150 rpm. Excessive hydrogen build-up is not the primary concern in step 15.
- B. Correct Emergency lighting may be lost after 90 minutes if DC discharge rates are not reduced on the 250 VDC bus. Also, batteries may be irreversibly damaged and supplied loads may not function as battery voltages approach their end voltage.
- C. Incorrect Battery capacity is two hours, not three hours and is based on a design basis accident where the batteries must provide needed loads during emergency core cooling until power can be returned to the battery chargers.
- D. Incorrect

**Comment [g7]:** This seems familiar to one that Sean wrote. This question may need to be replaced.

## Technical References: ECA-0.0 (Loss of All Vital AC Power), J-9 (DC Power) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 ( 7 and 8 )	Х

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the operational implications of the following	Group #	1
concepts as they apply to Loss of Offsite Power: Definition of	K/A #	056 AK1.04
saturation conditions, implication for the systems.	Rating	3.1

The reactor has tripped from 100% power and safety injection is in progress when the following occurred ....

- Seismic event in the Buttonwillow area causing loss of offsite power
- PZV-474 has lifted and stuck open
- Isolation Valve 8000 A has failed open on the loss of power
- Pressurizer level at 66% and increasing
- RCS temperature at 550° F
- RCS pressure at 1015 psig

What is the condition of the RCS and the primary concern associated with this condition?

- A. 25° F sub-cooled, which is insufficient as a prerequisite to re-starting a RCP.
- B. Saturated, boiling is now occurring in the RCS which may bind RCPs.
- C. Saturated, boiling is now occurring in the core which could uncover the fuel.
- D. 25° F sub-cooled, boiling is now occurring in the core with the potential to uncover fuel.

#### Answer: C

#### Explanation:

- A. Incorrect The core is at saturation conditions, therefore sub-cooling do not exist. The primary concern is uncovering fuel as the coolant boils away, not restarting a RCP.
- B. Incorrect Core is at saturation, but uncovering the fuel is the primary concern, not binding the RCPs.
- C. Correct
- D. Incorrect Sub-cooling does not exist when the RCS is at saturation.

Technical References: LA-4A (Pressurizer, Pressure and Level Control) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (5)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the reasons for the following responses as they	Group #	1
apply to the Loss of Vital AC Instrument Bus: Actions contained	K/A #	057 AK3.01
in EOP for loss of vital AC electrical instrument bus.	Rating	4.1

GIVEN:

- Unit 1 operating at 100% power
- PK19-19 (VITAL UPS FAILURE) Alarming
- Channel I bistable status lights lit
- Channel II and IV bistable status lights off
- Rods are moving in at normal speed

Which of the following identifies the correct failure and the appropriate operator follow-up action?

- A. Loss of Vital Bus PY-11, PT-505 (Tref) failed low, take manual control of rods
- B. Loss of Vital Bus PY-12, PT-505 (Tref) failed low, take manual control of rods
- C. Loss of Vital Bus PY-11, Power Range N-41 fails, take manual control of rods
- D. Loss of Vital Bus PY-14, Power Range N-44 fails, take manual control of rods

#### Answer: A

#### Explanation:

- A. Correct PT-505 (Tref) powered from PY-11 has failed low on a loss of power to PY-11, causing rods to move in to bring Tave back to Tref. Operator should take manual control of rods per AP-4 once it is recognized that rods are moving in due to the loss of PY-11.
- B. Incorrect If power were lost to PY-12, the Channel II bistable lights would be lit, not Channel I.
- C. Incorrect Power Range N-41 does fail on the loss of PY-11, but the failure of one PR NI does not affect rod control. Rods are moving in due to the failure of PT-505.
- D. Incorrect If power were lost to PY-14, the Channel IV bistable lights would be lit and not Channel I.

Technical References: AP-4 (Loss of Vital or Non-Vital Instrument AC), LPA-4 (Loss of

### Vital or Non-Vital Instrument AC), J10 (Instrument AC System) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 ( 5 and 7 )	х

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to operate and/or monitor the following as they apply to	Group #	1
the Loss of Nuclear Service Water (SWS): Loads on the SWS in	K/A #	062 AA1.02
the control room.	Rating	3.2

GIVEN:

- Unit 1 is operating at 100%
- ASW Pp 1-1 is running and supply CCW HX 1-1
- ASW Pp 1-2 is in standby
- PK01-01, ASW SYS HX △P/HDR PRESS, alarming
- PK01-03, AUX SALTWATER PUMPS, alarming
- ASW Pp 1-2 has auto started

Which of the following describes the correct subsequent operator action?

- A. Enter OP AP-10, Loss of Auxiliary Salt Water; start the standby ASW pump on Unit 2 and cross-connect ASW from Unit 2 to Unit 1.
- B. Enter OP AP-10, Loss of Auxiliary Salt Water; place the idle ASW train of Unit 1 in service.
- C. Enter OP AP-10, Loss of Auxiliary Salt Water; verify CCW temperatures are normal or decreasing.
- D. Enter OP AP-11, Malfunction of Component Cooling Water System; verify at least two CCW pumps running.

#### Answer: B

#### **Explanation:**

- A. Incorrect Per AP-10, cross-connecting units occurs on the total loss of flow in units. One pump is still available and running in Unit 1.
- B. Correct Per AP-10 step 3, place idle ASW train in service with a pump in that train that has not lost suction.
- C. Incorrect
- D. Incorrect

Technical References: OP AP-10 (Loss of Auxiliary Salt Water), LPA-10 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank #	X – LPA-10 (9)
parony	New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 ( 5 and 7 )	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to determine and interpret the following as they apply to	Group #	1
the Loss of Instrument Air: When to trip reactor if instrument air	K/A #	065 AA2.06
pressure is decreasing.	Rating	3.6

GIVEN:

- Steam Generator levels 58% and decreasing
- Instrument Air pressure is 69# and decreasing
- Letdown has isolated
- RCS pressure is 2295# and increasing
- PK13-16 (PLANT INSTRUMENT AIR) alarming

After entering OP AP-9 (Loss of Instrument Air), which of the following describes the correct operator action?

- A. Take manual control to maintain PZR level at program.
- B. Bypass the in-service Instrument Air Dryer.
- C. Take manual control of Digital Feedwater Control System.
- D. Trip the reactor and enter EOP E-0 (Reactor Trip or Safety Injection).

#### Answer: D

#### Explanation:

- A. Incorrect OP AP-9 (Loss of Instrument Air), step 1, directs the operator to trip the reactor and enter EOP E-0 if S/G levels, PZR levels, PZR pressure can not be maintained within their normal band.
- B. Incorrect
- C. Incorrect
- D. Correct

Technical References: OP AP-9 (Loss of Instrument Air), LPA-9 (OP AP-9, Loss of Instrument Air) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: Bank # (note changes; attach Modified Bank #

parent)		
	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х
10CFR Part 55 Content:	55.41 ( 5 and 7 )	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Conduct of Operations: Ability to locate and operate	Group #	1
components, including local controls.	K/A #	W/E11 G
		2.1.30
	Rating	4.4

#### A large break LOCA has occurred.

The following conditions exists:

- Both RHR pumps FAILED TO START on SI signal
- RHR valves have operated as designed
- Vital buses are energized
- Containment Recirc Sump level is 93.5 ft
- Containment Recirc Sumps are clear of blockage
- Operators have entered ECA-1.1 (Loss of Emergency Coolant Recirculation)

What operator action should be taken next?

- A. Check RWST level is GREATER THAN 4%.
- B. Immediately start TWO Containment Spray Pumps.
- C. Reset Safety Injection and restart RHR pumps with remote switch.
- D. Manually Close RHR Pump Breakers.

#### Answer: D

#### **Explanation:**

- A. Incorrect Operators are currently in ECA-1.1 (Loss of Emergency Coolant Recirculation), step 2c, Manually Close RHR Pp Breakers. Step 1 was to ensure Recirc Sumps were clear of blockage followed in step 2 of ensuring power to RHR pumps (vital buses energized) and checking that Recirc Sump level was GREATER than 92 feet.
- **B.** Incorrect
- C. Incorrect
- D. Correct

### Technical References: EOP ECA-1.1 (Loss of Emergency Coolant Recirculation) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
pulony	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 ( 5 and 7 )	Х
Examination Outline Cross-Reference	Level	RO
---	---------	-------
	Tier #	1
Ability to determine and interpret the following as they apply to	Group #	1
the (Loss of Secondary Heat Sink): Facility conditions and	K/A #	W/E05
selection of appropriate procedures during abnormal and		EA2.1
emergency operations.	Rating	3.4

GIVEN:

- Reactor tripped with safety injection
- RCS press 1400#
- RCS Th is 425°F
- All S/G NR levels are low off scale
- Intact S/G press is 915#
- Crew has left EOP E.0 (Reactor Trip or Safety Injection) and entered EOP FR-H.1 (Response to Loss of Secondary Heat Sink)

Which of the following correctly describes the requirement of the Steam Generators and the correct operator action?

- A. Required for RCS heat removal. Establish AFW flow and continue with EOP FR-H.1
- B. Not Required for RCS heat removal. Trip RCPs and return to EOP E-0.
- C. Required for RCS heat removal. Trip RCPs and continue with EOP FR-H.1
- D. Not Required for RCS heat removal. Trip RCPs and enter EOP E-2 (Faulted Steam Generator Isolation)

### Answer: C

#### **Explanation:**

- A. Incorrect Steam Generators ARE required for RCS heat removal. Once AFW flow is established the next step will return you to the procedure and step in effect.
- B. Incorrect Steam Generators ARE required for RCS heat removal. In FR-H.1 after RCPs are tripped you will continue in this procedure in order to establish Bleed and Feed.
- C. Correct Steam Generators ARE required for RCS heat removal. Once RCPs are tripped in step 5, the procedure continues to establish Bleed and Feed in order to remove decay heat.
- D. Incorrect Steam Generators ARE required for heat removal. Once RCPs are

tripped in step 5, the procedure continues to establish Bleed and Feed in order to remove decay heat.

Technical References: EOP E.0 (Reactor Trip or Safety Injection0, EOP FR-H.1 (Response to Loss of Secondary Heat Sink) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #		
parenty	New	х	
Question History:	Last NRC Exam	No	
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 ( 5 and 7 )	х	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to operate and/or monitor the following as they apply to	Group #	1
Generator Voltage and Electric Grid Disturbances:	K/A #	077 AA1.02
Turbine/generator controls.	Rating	3.8

GIVEN:

- Reactor at 42% due to turbine run back
- PK12-06 (TURBINE) alarming
- Input 692 (Bearing Oil Pressure Low) locked in
- Bearing Oil Pressure on VB-4 at 7 psig and stable

Which of the following correctly describes the required operator action?

- A. Trip the turbine and enter E-0 (Reactor Trip or Safety Injection) based on the subsequent reactor trip.
- B. Trip the turbine and continue in AP-29 (Main Turbine Malfunction).
- C. Immediately start the AC and/or DC bearing oil pump and monitor pressure per AP-29.
- D. Immediately start the AC and/or DC bearing oil pump and trip the turbine if bearing oil pressure falls below 6 psig.

#### Answer: B

#### **Explanation:**

- A. Incorrect Tripping the turbine is correct, but with reactor power at less than 50% (P-9 Permissive) the reactor will not automatically trip upon a turbine trip, thus negating the need to transition to E-0.
- B. Correct An immediate trip for the turbine, per AP-29, is necessary when bearing oil pressure falls below 8 psig. AP-29 is the guiding procedure, not E-0, as the reactor will not have tripped since power is below the P-9 setpoint.
- C. Incorrect This is the correct action for a 719 Input (PPC Lube Oil Pressure Alarm), but not for Input 692 (Bearing Oil Low Pressure), which directs you to trip the turbine with bearing oil pressure on VB-4 at less than 8 psig.
- D. Incorrect Starting the bearing oil pump is an immediate action for the 719 Input, but tripping the turbine occurs when bearing oil pressure falls below 8 psig, not

# Technical References: AP-29 (Main Turbine Malfunction) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
paronty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41(5 and 7)	х

6.

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Conduct of operations: Ability to interpret and execute	Group #	2
procedures.	K/A #	028 G
		2.1.20
	Rating	4.6

The plant was stable at full power with all systems operating normally in automatic control when the following occurs:

- Pressurizer level is 60% and begins to rise
- Pressurizer pressure is 2235 psig and stable
- Letdown flow isolates.
- Charging flow decreases.
- Pzr Level Hi/Lo alarms
- All other parameters are normal
- Annunciator Typewritter prints out "PZR Lo Lvl Letdn Iso All Htrs Off

Alarm response procedure PK05-22 was entered and the US directs you to monitor the above parameters. Which of the following has occurred?

- A. Excessive Reactor Coolant System Leakage has occurred"
- B. Pressurizer level channel has failed has occurred.
- C. Loss of Charging has occurred.
- D. Letdown Line Failure has occurred

# Answer: B

## Explanation:

- A. Incorrect Rising pressurizer level is inconsistent with a RCS leak
- B. Correct The backup pressurizer level control channel has failed low.
- C. Incorrect Charging flow is decreasing as expected in the response to the operable primary controlling level channel.
- D. Incorrect Letdown has isolated as expected due to the backup pressurizer level control channel failing low.

**Technical References:** AR PK05-22 steps 5.1 and 5.7, STG A4A, OIM A-4-2b **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach	Bank # Modified Bank #		
parent)	New	Х	
Question History:	Last NRC Exam	No	
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х	
10CFR Part 55 Content:	55.41(10)		

Examination Outline Cross-Reference	Level	RO
Ability to determine and interpret the following as they apply to the Fuel Handling incidents: ARM system indications.	Tier #	1
	Group #	2
	K/A #	036 AA2.01
	Rating	3.2

Refer to the figure of RM-58 Fuel Handling Building (FHB) Radiation Control Module for the question that follows:



Given the following indications:

- Red Light is ON for Trip 2
- Amber Light is ON for Trip 1
- Green Operate Light is ON

Based on the indications, what automatic actions should have occurred?

- A. FHB Evacuation Alarm only.
- B. FHB Ventilation swapped to Iodine removal Mode and FHB Evacuation Alarm
- C. Both Auxiliary Building and FHB Ventilation swapped to Iodine Removal Mode.
- D. Only Auxiliary Building Ventilation swapped to lodine removal mode.

# Answer: B

# Explanation:

- A. Incorrect. This condition would also cause the FHB ventilation system to swap to the lodine removal mode.
- B. Correct. Red light ON indicates a HI Alarm set point has been exceeded and the FHB evacuation alarm should be sounding and lodine removal ventilation should be in service.
- C. Incorrect. Auxiliary Building Ventilation is not swapped to lodine Removal mode based on RM-58 input signal, only FHB Ventilation is shifted to lodine Mode.
- D. Incorrect. Auxiliary Building Ventilation is not swapped to Iodine Removal mode based on RM-58 input signal.

**Technical References:** STG G4A, Radiation Monitoring, Pages 2.2-18-23, Rev. 9. **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	Х
parenty	New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х
10CFR Part 55 Content:	55.43(5) 55.45(13)	

## BANK from *ML 082830427* June 2008 DCPP Exam

## **RO Question 22**

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #	1	
Group #	2	
K/A #	036/AA2.01	
Importance Rating	3.2	3.9

K/A: **Fuel Handling Incidents** - Ability to determine and interpret the following as they apply to the Fuel Handling Incidents: ARM system indications.

Refer to the figure of RM-58 Fuel Handling Building (FHB) Radiation Control Module for the question that follows:



Given the following indications:

- Red Light is ON for Trip 2
- Amber Light is ON for Trip 1
- Green Operate Light is ON

Based on the indications, what automatic actions should have occurred?

- A. FHB Evacuation Alarm only.
- B. FHB ventilation swapped to lodine removal Mode and FHB Evacuation Alarm.
- C. Auxiliary Building and FHB Ventilation swapped to Iodine Removal Mode.
- D. Auxiliary Building Ventilation swapped to lodine removal mode only.

Proposed Answer: B

Explanation:

Answer A is incorrect. This condition would also cause the FHB ventilation system to swap to the lodine removal mode.

Answer B is correct. Red light ON indicates a HI Alarm set point has been exceeded and the FHB evacuation alarm should be sounding and lodine removal ventilation should be in service.

Answer C is incorrect. Auxiliary Building Ventilation is not swapped to lodine Removal mode based on RM-58 input signal, only FHB Ventilation is shifted to lodine Mode.

Answer D is incorrect. Auxiliary Building Ventilation is not swapped to lodine Removal mode based on RM-58 input signal.

Technical Reference(s):	STG G4A, Radiation Monitoring, Pages 2-18-23, Rev. 9.
	LPA-21 Irradiated Fuel Damage, Page 9, Rev. 8.
	AR PK11-10, FHB High Radiation, RE 58 and 59, Rev. 11.
	OP AP-21 Irradiated Fuel Damage, Pages 1 & 3, Rev. 10.

Proposed references to	o be p	provided to applie	cants during	examination:	NONE
Learning Objective:	65 ha	73 – Explain the ndling building ra	automatic a	actions that occu m.	r due to a fuel
Question Source:	Ban Moc New	k # lified Bank # /	X	(Note changes	or attach parent)
Question History:	Last	NRC Exam	N/	Ά	
Question Cognitive Level:       Memory or Fundamental Knowledge       X         Comprehension or Analysis					
10 CFR Part 55 Content: 55.41 7 55.43					
10 CFR Part 55 Content: Design, components, and function of control and safety systems, including instrumentation, signals, interlocks, failure modes and automatic and manual features.					
Comments:					

Examination Outline Cross-Reference	Level	RO
Ability to operate and/or monitor the following as they apply to	Tier #	1
the Loss of Condenser Vacuum: Rod position.	Group #	2
	K/A #	051 AA1.04
	Rating	2.5

Given the following conditions:

- The unit is at 90% and ramping up with "MW Feedback In"
- Control Bank D rods are at 210 steps
- All equipment is operable and in the proper alignment for power operations

Due to condenser seal degradation and subsequent air in-leakage, condenser vacuum begins to slowly degrade.

How is this event expected to affect control rod position?

- A. Control rods will slowly step in due to T-avg vs. T-ref and/or power mismatch.
- B. Control rods will slowly step out due to T-avg vs. T-ref and/or power mismatch.
- C. A demand will exist for control rods to step out, but due to C-11, rods will remain at 210 steps.
- D. Control rods remain at 210 steps as degraded condenser vacuum will not affect power or T-avg.

# Answer: B

# Explanation:

- A. Incorrect As vacuum degrades, efficiency is reduced, but DEHC will attempt to maintain the same load. This means that more MW's will be required from the RCS resulting in a reduced T-avg which results in a *"rods-out"* demand to restore T-avg
- B. Correct As vacuum degrades, efficiency is reduced, but DEHC will attempt to maintain the same load. This means that more MW's will be required from the RCS resulting in a reduced T-avg which results in a "rods-out" demand to restore T-avg
- C. Incorrect C-11 does not stop control bank D withdrawal until its position is 220 steps
- D. Incorrect turbine efficiency will affect reactor power and/or T-avg resulting in auto rod withdrawl.

Technical References: OP-AP-7, Rev. 34, page 2

References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	Х
parent)	New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х
10CFR Part 55 Content:	55.41(7)	

# BANK from *ML 081006050* Nov 2007 DCPP Exam

RO SRO Tier # \_ 1\_\_\_\_ Group # \_ 2\_\_\_ K/A \_051 AA1.04 Importance rating \_2.5 \_

**Loss of Condenser Vacuum:** Ability to operate and/or monitor the following as they apply to the loss of condenser vacuum: rod position

Question: 21

The unit is at 90% and ramping up with "MW Feedback In." Control Bank D rods are at 210 steps. All equipment is operable and in the proper alignment for power operations. Due to condenser seal degradation and subsequent air in-leakage, condenser vacuum begins to slowly degrade.

How is this event expected to affect control rod position?

A. Control rods will slowly step in due to T-avg vs. T-ref and/or power mismatch.

B. Control rods will slowly step out due to T-avg vs. T-ref and/or power mismatch.

C. A demand will exist for control rods to step out, but due to C-11, rods will remain at 210 steps.

D. Control rods remain at 210 steps as degraded condenser vacuum will not affect power or T-avg.

Answer: <u>B</u>\_\_\_\_

Explanation: Answer A is incorrect, B is correct. As vacuum degrades, efficiency is reduced, but DEHC will attempt to maintain the same load. This means that more MW's will be required from the RCS resulting in a reduced T-avg which results in a "rods-out" demand to restore T-avg. C is incorrect since C-11 does not stop control bank D withdrawal until its position is 220 steps. D

is incorrect since turbine efficiency will affect reactor power and/or T-avg resulting in auto rod withdrawal.

Technical Reference(s): OP-AP-7, Rev. 34, page 2

Proposed references to be provided to applicants during examination: <u>None</u>

Learning Objective: \_\_\_ STG C7A, Rev. 15, obj 22 \_\_\_\_\_ (As available)

Question Source Bank # \_\_\_\_\_ Modified Bank # \_\_\_\_\_ (Note changes or attach parent) New \_\_\_\_\_XX\_\_\_\_

Question Cognitive Level: Memory or Fundamental Knowledge \_\_\_\_ Comprehension or Analysis\_\_\_X\_\_\_

Examination Outline Cross-Reference	Level	RO
Knowledge of the reasons for the following responses as they	Tier #	1
apply to the Area Radiation Monitoring system: Guidance	Group #	2
contained in alarm response for ARM system.	K/A #	061 AK3.02
	Rating	3.4

Annunciator Response Procedure AR PK11-17, S.G. Blowdown Hi Rad, directs the operator to verify automatic blowdown isolation.

It then directs the operator to override this signal by placing the RE 19, 23 Hi Rad S/G Blowdown and Sample Valves (O.C.) isolation defeat cutout switch to the "cut in" position.

What is the reason for this guidance?

- A. Allow flushing the Radiation Monitor to eliminate nuisance alarms.
- B. Allow repositioning the HASP#1/HASP#2 switch to be placed in HASP#2 (Leak based setpoint) position.
- C. Allow re-flash capability for subsequent alarms.
- D. Allow sampling to identify a ruptured Steam Generator.

## Answer: D

## **Explanation:**

- A. Incorrect nuisance alarms are eliminated by taking the HASP toggle to HASP#1 (effluent) setpoint position.
- B. Incorrect HASP#1/HASP#2 toggles is normally in HASP#2
- C. Incorrect this switch allows blowdown sample isolation valve to be re-opened
- D. Correct this switch allows blowdown sample isolation valve to be re-opened for chemisty sampling.

**Technical References: Procedure** AR PK11-17, STG G4a page 2.3-38 **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source:		Bank #	
	(note changes; attach	Modified Bank #	
parent)			
		New	

Х

Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	Х
10CFR Part 55 Content:	55.41(5 and 10)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the interrelations between the Control Room evacuation and the following: Reactor trip system.	Group #	2
	K/A #	068 AK2.02
	Rating	3.7

An explosion and lots of smoke caused an immediate control room evacuation.

Which ONE of the following is the *highest* priority action that operators should take before evacuating the control room?

- A. Manually close MSIVs and bypass valves.
- B. Trip the main turbine.
- C. Trip the main unit generator.
- D. Trip the reactor.

# Answer: D

# **Explanation:**

- A. Incorrect True, but this is step 5 of AP-8A. RNO can be done locally.
- B. Incorrect True, but this is step 3 of AP-8A. RNO can be done locally.
- C. Incorrect True, but this is step 4 of AP-8A. RNO can be done locally.
- D. Correct Tripping reactor is highest priority. The RNO of steps of 3- 5 can be done locally. See background of AP-8A for basis for performing only the RNO's.

## Technical References: AP-8A background References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х
10CFR Part 55 Content:	55.41(7)	

Examination Outline Cross-Reference	Level	RO
Knowledge of the operational implications of the following	Tier #	1
concepts as they apply to the (Reactor Trip or Safety	Group #	2
Injection/Rediagnosis): components, capacity, and function of	K/A #	W/E01& 02
emergency systems.		EK1.1
	Rating	3.1

The following plant conditions exist after stabilizing from a small break LOCA:

- RCS Pressure = 1750 psig
- Pressurizer Level = 20% stable
- Subcooling = 45°F
- AFW flow = 500 gpm
- 1 CCP running
- 2 SI pumps running

How will pressurizer level respond if both SI pumps are shut down?

- A. Increase
- B. Decrease
- C. No change
- D. Initial sharp decrease, then slowly stabilize

# Answer: C

# **Explanation:**

- A. Incorrect. Turning off the SI pumps will not result in more flow and subsequent repressurization.
- B. Incorrect. RCS pressure is greater than shutoff head. Pressure should not change.
- C. Correct. RCS pressure is above SI pump shutoff head. When the SI pumps are secured, there will not be an RCS pressure response or temperature response.
- D. Incorrect. This is a typical response when pumps are secured during ECCS reduction sequence

## **Technical References:** STG B3 **References to be provided to applicants during exam:** None **Learning Objective:** 6743 Explain PZR response during ECCS reduction sequence

# **Question Source:**

parent)	(note changes; attach	Modified Bank #	
		New	
Question	History:	Last NRC Exam	No
Question	Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х
10CFR Pa	art 55 Content:	55.41(8 & 10)	

# Banked from ML 072400068 April 2007 (draft) DCPP Exam

# **RO** Question 26 R1

Examination Outline Cross-Reference: Level RO SRO	Tier:	1
K/A: EPE E02 EK1.1	Group:	<u>2</u>
Importance Rating: 3.2 3.8	_	

# **Proposed Question**:

The following plant conditions exist after stabilizing from a small break LOCA:

- •RCS Pressure = 1750 psig
- •Pressurizer Level = 20% stable
- •Subcooling =  $45^{\circ}$ F
- •AFW flow = 500 gpm
- •1 CCP running
- •2 SI pumps running

How will Pressurizer level be affected if both SI pumps are shut down?

- A. Increase
- B. Decrease
- C. No change
- D. Initial sharp decrease, then slowly stabilize

# Proposed Answer: C. No change

Explanation:

- A. A incorrect. Turning off the SI pumps will not result in more flow and subsequent repressurization.
- B. B incorrect. RCS pressure is greater than shutoff head. Pressure should not change.
- C. C correct. RCS pressure is above SI pump shutoff head. When the SI pumps are secured, there will not be an RCS pressure response or temperature response.
- D. D incorrect. This is a typical response when pumps are secured during ECCS reduction sequence.

Technical Reference(s): STG B3 Proposed references to be provided to applicants during examination: None Learning Objective: 6743 Explain PZR response during ECCS reduction sequence Question Source: <u>Bank P-6157</u> Question History: Last NRC Exam

Question Cognitive Level:

Memory or Fundamental Knowledge \_\_\_\_\_ Comprehension or Analysis X 10 CFR Part 55 Content: 55.41.8 - Components, capacity, and functions of emergency systems.

Comments: Expanded justification. No change to question from initial submittal.

K/A: EPE E02 EK1.1 – Knowledge of the operational implications of the following concepts as they apply to the (SI Termination) Components, capacity, and function of emergency systems. (3.2/3.8)

Examination Outline Cross-Reference	Level	RO
Knowledge of the interrelations between the (Steam generator	Tier #	1
Overpressure) and the following: Components, and functions of	Group #	2
control and safety systems, including instrumentation, signals,	K/A #	W/E13
interlocks, failure modes, and automatic and manual features.		EK2.1
	Rating	3.0

Unit 1 experienced a Steam Generator Tube Rupture (SGTR).

The crew is at the step in E-3, Steam Generator Tube Rupture, which checks to see if ECCS flow should be terminated.

Which of the following would be the effect on the plant, if Safety Injection Termination is delayed beyond the time assumed in the FSAR analysis for a SGTR?

- A. RWST inventory depletion
- B. Pressurized Thermal Shock
- C. Steam Generator Overfill
- D. Pressurizer Water Solid Conditions

## Answer: C

## Explanation:

- A. Incorrect This is an ECA 1.1, Loss of Emergency Coolant Recirculation, concern.
- B. Incorrect This is a red or orange path FR-P.1, "Response to Imminent Pressurized Thermal Shock" concern.
- C. Correct If SI Flow is not terminated in a timely fashion, leakage into the steam generator will eventually fill the SG with water and potentially lift the SG Safety valves which greatly increases off-site dose
- D. Incorrect This is a yellow path FR-I.1 concern only implemented after SI is terminated.

**Technical References:** WOG E-3 Background Information **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Questio	n Source:	Bank #
	(note changes; attach	Modified Bank #
parent)		

	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41(7)	

# Modified from ML 082830427 June 2008 DCPP Exam RO Question 25

Examination Outline Cross-Reference:

RO	SRO
1	
2	
E02/EK1.1	
3.2	3.8
	RO 1 2 E02/EK1.1 3.2

K/A: **SI Termination** - Knowledge of the operational implications of the following concepts as they apply to the SI Termination: Components, capacity, and function of emergency systems.

Proposed Question:

Unit 1 experienced a Steam Generator Tube Rupture (SGTR).

The crew is at the step in E-3 "Steam Generator Tube Rupture", that checks to see if "ECCS Flow Should Be Terminated."

Which of the following would be the effect on the plant, if Safety Injection Termination is delayed beyond the time assumed in the FSAR analysis for a SGTR?

- A. Steam Generator overfill.
- B. Loss of Subcooling Margin.
- C. Loss of Secondary Heat Sink.
- D. Reactor Vessel Head bubble formation.

Proposed Answer: A

Explanation:

Answer A is correct. If SI Flow is not terminated in a timely fashion, leakage into the steam generator will eventually fill the SG with water and potentially lift the SG Safety valves.

Answer B is incorrect. Loss of subcooling is not a concern at this step in the procedure.

Answer C is incorrect. Loss of Heat Sink will not occur, even if the ruptured generator is needed for cooldown, as level will be increasing.

Answer D is incorrect. Voiding may occur in the upper head region, but is not a significant safety concern; SI is terminated even if a void exists.

Technical Reference(s):	LTAA-9, Steam Generator Tube Ruptures, Page 16, Rev. 8.
	LPE-3, EOP E-3 SGTR Response, Page 25, Rev. 10.
	EOP E-3, Steam Generator Tube Rupture, Page 23, Rev.
	28A.
	E-3 Background Document, Page 120, Rev. 2.

Proposed references to be provided to applicants during examination: NONE

Learning Objective:	6855 -Explain the effect of SI termination and/or re-initiation on _ control of the plant.		
Question Source:	Bank #	P-0796	

Modified Bank #	(Note changes or attach pare	ent)
New		

 Question History:
 Last NRC Exam
 N/A

Comments:

Examination Outline Cross-Reference	Level	RO
Knowledge of the reasons for the following responses as they	Tier #	1
apply to the (Containment Flooding): RO or SRO function as a	Group #	2
team as appropriate to the assigned position, in such a way that	K/A #	W/E 15
procedures are adhered to and the limitations in the facility		EK3.4
license and amendments are not violated.	Rating	2.9

A reactor trip and SI have occurred as a result of a large break LOCA.

E-1.3, Transfer to Cold Leg Recirculation, has just been completed.

The STA reports the following conditions associated with the Containment critical safety function:

- Containment pressure 2.0 psig.
- Containment radiation 1400 R/hr.
- Containment sump level 98 ft.

Which one of the following is an immediate containment concern?

- A. Containment structural integrity. Go to FR-Z.1, Response to High Containment Pressure.
- B. Flooding vital equipment in containment. Go to FR-Z.2, Response to High Containment Flooding.
- C. Erroneous instrumentation readings. Go to FR-Z.3, Response to High Containment Radiation.
- D. Inadequate suction to the RHR pumps. Go to ECA-1.3, Sump Blockage Guideline.

## Answer: B

THIS IS NOT SRO-ONLY BECAUSE THE APPLICANT IS NOT ASKED TO CHOOSE A PROCEDURE AFTER ASSESSING PLANT CONDITIONS.

Explanation:

- A. Incorrect FR-Z.3 is a RED path but containment pressure is <22 psig. Entry condition not met</p>
- B. Correct FR-Z.2 entry condition met and is MAGENTA Path
- C. Incorrect FR-Z.3 is a YELLOW path
- D. Incorrect ECA-1.3 entry condition not met E-1.3 step 13 ACTION/EXPECTED RESPONSE met

# Technical References:

**References to be provided to applicants during exam:** EOP F-0.5 / EOP FR-Z.2 background

Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41(5 and 10)	

# Modified from ML 0023220665 October 2002 DCPP Exam

Proposed Question # 94:

A reactor trip and Si have occurred as a result of a large break LOCA. E-1.3, "Transfer to Cold Leg Recirculation" has just been completed.

The STA reports the following conditions associated with the Containment critical safety function:

- Containment pressure 2.0 psig.
- Containment sump level 98 ft.
- Containment radiation 1400 R/hr.

Which one of the following is an immediate containment concern?

- A. Inadequate suction to the RHR pumps.
- B. Flooding vital equipment in containment.
- C. Erroneous instrumentation readings.
- D. Containment structural integrity.

## Proposed Answer: B

Explanation:

Technical Reference(s): EOP F-0 Attachment 6 DCPP Step Description/Deviation for FR-Z.2 step 1

Proposed references to be provided to applicants during examination: NONE

Learning Objective: 6819 Explain the effect of high water levels in containment.

Question Source: Bank # B-0002 Modified Bank # New

Question History: Last NRC Exam

Question Cognitive Level: Memory or Fundamental Knowledge Comprehension or Analysis X

10 CFR Part 55 Content: 55.41 7

Examination Outline Cross-Reference	Level	RO
Ability to verify system alarm setpoints and operate controls	Tier #	1
identified in the alarm response manual.	Group #	2
	K/A #	W/E16
		G2.4.50
	Rating	4.2

While observing the containment purge radiation monitor (RM44A) radiation display unit (RDU), you notice that the HIGH ALARM and CVI BYP status lights on the panel are both ON.

Based solely on the indications on the RDU, which one of the following is true regarding the containment purge CVI status?

- A. Status is normal; high radiation on R-44A will cause a CVI.
- B. A CVI signal has been sensed and a CVI has occurred.
- C. A CVI signal has NOT been sensed, but the CVI actions will occur when it is sensed.
- D. A CVI signal is sensed, but the CVI function is bypassed and it will NOT occur.

# Answer: D

# Explanation:

- A. Incorrect This a true but inconsistent with the CVI BYP status
- B. Incorrect The CVI will NOT actuate
- C. Incorrect The HIGH ALARM status light means the signal is sensed
- D. Correct CVI BYP is light when key-switch is in Bypass The CVI will NOT actuate

# **Technical References:** STG G-4B pages 2-43 and 2-44 **References to be provided to applicants during exam:** None

**Learning Objective:** 3281 Explain the conditions that effect Digital Radiation Monitoring system radiation monitor indications

Question Source: (note changes; attach	Bank # Modified Bank #	Х
parenty	New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х

## 10CFR Part 55 Content:

55.41(10)

## Modified from ML 0023220665 October 2002 DCPP Exam

Proposed Question # 28 :

While observing the containment purge radiation monitor (RM44A) radiation display unit (RDU), you notice that the HIGH ALARM and CVI BYP status lights on the panel are both ON.

Based solely on the indications on the RDU, which one of the following is true regarding the containment purge CVI status?

A. A CVI signal has been sensed and a CVI has occurred.

B. The status is normal; high radiation on R-44A will cause a CVI.

C. A CVI has NOT been sensed, but the CVI actions will occur when it is sensed.

D. A CVI signal is sensed, but the CVI function is bypassed and it will NOT occur.

Proposed Answer: D

Explanation:

Technical Reference(s): STG G-4B pages 2-43 and 2-44

Proposed references to be provided to applicants during examination: NONE

Learning Objective: 3281 Explain the conditions that effect Digital Radiation Monitoring system radiation monitor indications.

Question Source: Bank # A-0673

Question History: Last NRC Exam

Question Cognitive Level: Comprehension or Analysis X

10 CFR Part 55 Content: 55.41 7 55.43

Comments:

Examination Outline Cross-Reference	Level	RO
	Tier #	3
Ability to locate control room switches, controls, and indications, and to determine that they correctly reflect the	Group #	1
	K/A #	2.1.31
desired plant lineup.	Rating	4.6

Given the following:

- A plant heatup is in progress
- The plant is in Mode 3
- PZR pressure is 1975 psig
- RCS temperature is 525° F

Which of the following describes the status of the indication related to the P-11 permissive on the VB1 panel?

- A. P-11 light ON; PZR Low Pressure SI is enabled.
- B. P-11 light ON; PZR Low Pressure SI is blocked.
- C. P-11 light OFF; PZR Low Pressure SI is enabled.
- D. P-11 light OFF; PZR Low Pressure SI is blocked.

## Answer: C

## Explanation:

- A. Incorrect
- **B.** Incorrect
- C. Correct Pressurizer pressure is above the 1915 psig setpoint, therefore P-11 light on VB1 is OFF and Low Pressure SI is enabled.
- D. Incorrect

Technical References: System Lesson Guide B-6A (Reactor Protection System) References to be provided to applicants during exam: None Learning Objective: To be determined

Question	Source:	Bank #
	(note changes; attach	Modified Bank #
parent)		
		New

Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 ( 5, 7, 8 )	

Examination Outline Cross-Reference	Level	RO
	Tier #	3
Knowledge of conduct of operations requirements.	Group #	1
	K/A #	2.1.1
	Rating	3.8

An event has occurred that will cause a safety injection actuation (SI) setpoint to be exceeded, and automatic actuation is deemed unavoidable.

In accordance with OP1.DC10, Conduct of Operations, operators should \_\_\_\_\_\_.

- A. initiate a reactor trip and SI before automatic actuation
- B. monitor the plant and verify that the reactor trips and SI actuates automatically
- C. inform the Shift Foreman and wait for direction to trip the reactor and initiate SI
- D. initiate SI and verify the reactor automatically trips

## Answer: A

# Explanation:

- A. Correct
- **B.** Incorrect
- C. Incorrect
- **D.** Incorrect

## Technical References: OP1. DC10 page 4 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	#70 2002 Exam
parent)	New	
Question History:	Last NRC Exam	No

**Question Cognitive Level:** 

10CFR Part 55 Content:

Memory/Fundamental Comprehensive/Analysis 55.41 (10)

Examination Outline Cross-Reference	Level	RO
	Tier #	3
Knowledge of the process for making changes to procedures.	Group #	2
	K/A #	2.2.6
	Rating	3.0

A Nuclear Operator reports in to you that during a pre-startup valve lineup, a critical valve that needs to be repositioned is not documented in the current revision of the procedure.

In accordance with OP1.DC10, Conduct of Operations, a \_\_\_\_\_\_ is used to document decision to revise the procedure, and this decision is made by the \_\_\_\_\_?

- A. Procedure Feedback Request; Shift Manager
- B. Action Request; Shift Foreman
- C. Action Request; Shift Manager
- D. Procedure Feedback Request; Shift Foreman

## Answer: C

# Explanation:

- A. Incorrect
- B. Incorrect
- C. Correct Per OP1.DC10, the Shift Foreman will consult with the Shift Manager, with the Shift Manager making the decision to proceed or not with the procedure. An Action Request is then utilized to document the decision and the change needed in the procedure.
- D. Incorrect

Technical References: OP1.DC10, Conduct of Operations References to be provided to applicants during exam: None Learning Objective: To be determined

Question	n Source:	Bank #
	(note changes; attach	Modified Bank #
parent)		Now
		INEW

Х

Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	Х
10CFR Part 55 Content:	55.41 ( 10 )	

Examination Outling Cross Poteronce		PO
Examination Outline Cross-Reference	Level	KU
	Tier #	3
Knowledge of tagging and clearance procedures.	Group #	2
	K/A #	2.2.13
	Rating	4.1

GIVEN:

- A turbine building sump pump has been cleared for routine maintenance.
- The clearance has been reported on, and a maintenance red tag has been hung.
- No work has been done to the pump.
- A problem has developed with the other sump pump, making it desirable to place the cleared pump back in service.
- The Sub-clearance requestor can NOT be located.

Which of the following individuals may remove this red tag?

- A. Any Maintenance Foreman familiar with the clearance.
- B. The Senior Control Operator
- C. The Nuclear Operator removing the clearance with the concurrence of the Senior Control Operator.
- D. The Unit Shift Foreman

# Answer: D

Explanation:

- A. Incorrect
- B. Incorrect
- C. Incorrect
- D. Correct

Technical References: OP2. ID2, Clearances References to be provided to applicants during exam: None Learning Objective: To be determined

**Question Source:** 

parent)	(note changes; attach	Modified Bank #	
		New	
Question	History:	Last NRC Exam	No
Question Cognitive Level:		Memory/Fundamental	Х
10CFR Part 55 Content:		55.41 ( 10 )	

Examination Outline Cross-Reference	Level	RO
	Tier #	3
Knowledge of the process for managing troubleshooting	Group #	2
activities.	K/A #	2.2.20
	Rating	2.6

During the shift turnover you have been informed that troubleshooting will occur on the Intermediate Range Nuclear Instrumentation System. Who must approve this troubleshooting activity to occur on your shift AND who must approve any deviation in pre-approved test equipment should that become necessary?

- A. Shift Foreman; Shift Foreman
- B. Shift Foreman; Shift Manager
- C. Shift Manager; Shift Manager
- D. Shift Manager; Shift Foreman

## Answer: A

# Explanation:

- A. Correct
- **B.** Incorrect
- C. Incorrect
- **D.** Incorrect

Technical References: B-16, Operations Troubleshooting Activities References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	Х
10CFR Part 55 Content:

Comprehensive/Analysis 55.41 (10)

Examination Outline Cross-Reference	Level	RO
Knowledge of radiation exposure limits under normal or	Tier #	3
emergency conditions.	Group #	3
	K/A #	G2.3.4
	Rating	3.2
		41.12

Which of the following describes the 10CFR20 Limits and the Diablo Canyon Administrative Limit for radiation exposure for a calendar year?

	10CFR20 Limit	DCPP Admin Limit
Α.	4500 mREM	2000 mREM
B.	4500 mREM	4000 mREM
C.	5000 mREM	2000 mREM
D.	5000 mREM	4500 MREM

## Answer: D

## Explanation:

- A. Incorrect –10CFR20 limit is 5000 mREM and <u>not</u> 4500 mREM. 2000 mREM is the DCPP Admin *Guideline*. 4500 mREM is the Admin **Limit**.
- B. Incorrect –.10CFR20 limit is 5000 MREM and <u>not</u> 4500 mREM. 4000 mREM is 90% of DCPP Admin Limit (4500 mREM).
- C. Incorrect 10CFR20 limit is 5000 mREM <u>but</u> 2000mREM is the DCPP Admin *Guideline* <u>not</u> the Admin **Limit**.
- D. Correct –10CFR20 limit is 5000 mREM and the DCPP Admin Limit is 4500 mREM.

**Technical References:** RP1.ID6, Personnel Dose Limits and Monitoring **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Questio	n Source: (note changes; attach	Bank # Modified Bank #	Х
parent)		New	
Questic	on History:	Last NRC Exam	No
Questio	n Cognitive Level:	Memory/Fundamental	

#### 10CFR Part 55 Content:

Comprehensive/Analysis 55.41.12

Х

NRC Form ES-401-5 Written Examination Question Worksheet

June 2008 DCPP

ML 091270008

**RO** Question 71

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #	3	
Group #	N/A	
K/A #	G 2.3.4	
Importance	3.2 3.7	
Rating		

K/A: Generic - Radiation Control: Knowledge of radiation exposure limits under normal or emergency conditions.

Proposed Question:

Which of the following describes the 10CFR20 Limits and the Diablo Canyon Administrative Limit for radiation exposure for a calendar year?

	10CFR20	Limit DCPP Admin Limit
Α.	4500 mREM	2000 mREM
В.	4500 mREM	4000 mREM
С.	5000 mREM	2000 mREM
D.	5000 mREM	4500 MREM

Proposed Answer: D

Explanation:

Answer A is incorrect. 10CFR20 limit is 5000 mREM and not 4500 mREM, 4500 mREM is the Admin limit, DCPP Admin Guideline is 2000 mREM.

Answer B is incorrect. 10CFR20 limit is 5000 MREM and not 4500 mREM , 4500 mREM is the Admin limit, 4000 mREM is 90% of 4500 mREM.

Answer C is incorrect. 10CFR20 limit is 5000 mREM and the DCPP Admin Guideline is 2000 mREM.

Answer D is correct. 10CFR20 limit is 5000 mREM and the DCPP Admin limit is 4500 mREM.

ES-401 June 2008 DCPP NRC Form ES-401-5 Written Examination Question Worksheet Technical Reference(s): RP1.ID6, Personnel Dose Limits and Monitoring Requirements, Attachment 8.1, Rev. 8. OIM Administrative Radiation Exposure Limits, Page S-1-1, Rev. 20. Proposed references to be provided to applicants during examination: NONE Learning Objective: STATE the DCPP administrative exposure guidelines. Bank # Modified Bank # INPO -30401 (Note changes or attach parent) Question Source: New Question History: Last NRC Exam N/A Question Cognitive Level: Memory or Fundamental Knowledge X Comprehension or Analysis 10 CFR Part 55 Content: 55.41 12 55.43 10 CFR Part 55 Content: Radiological safety principles and procedures. Comments:

Examination Outline Cross-Reference	Level	RO
Ability to control radiation releases.	Tier #	3
	Group #	3
	K/A #	G2.3.11.
	Rating	3.8
		41.11

Several Auxiliary Building radiation alarms are received. It is confirmed that Liquid Hold-Up Tank 1-1 has ruptured, and is leaking in the Auxiliary Building.

What action must be taken to prevent the offsite release of radioactive particulate and iodine?

- A. Select "S" signal test, secure one Aux Bldg Ventilation train, and energize charcoal heaters.
- B. Push "Status Reset" at POV1 and POV2, and reset the "S" signal.
- C. Stop all Aux Bldg supply and exhaust fans, and energize charcoal heaters.
- D. Locally close dampers that isolate the Waste Gas Decay Tank rooms.

## Answer: A

## Explanation:

- A. Correct. AP-14, step 2 provides direction for placing ABVS in SFGDS Only. This isolates ventilation to general aux Bldg and ensures all other exhaust is filter by the lodine Removal filter prior to exhaust to atmosphere.
- B. Incorrect. This will reset ventilation logic. System will be reposition to normal based on selected mode and selected equipment. This does not minimize release to environment.
- C. Incorrect. This will not provide for Iodine removal. Exhaust Fan E-1 needs to be running.
- D. Incorrect. This will isolate ventilation supply to Liquid Hold up tanks but will not provide for lodine removal.

Х

**Technical References:** OP-AP-14, LPA-14 page 6, STG H-1 **References to be provided to applicants during exam:** None **Learning Objective:** 

Question	Source: (note changes; attach	Bank # Modified Bank #
parent)		New
Question	History:	Last NRC Exam

Question Cognitive Level:	Memory/Fundamental
	Comprehensive/Analysis
10CFR Part 55 Content:	55.41.11

## DCPP REACTOR OPERATOR NRC LICENSE EXAM, Dec. 2007 ML

ML 0801006050

Examination Outline Cross-reference:	Level	RO
Ability to control radiation releases.	Tier #	1
	Group #	2
	K/A #	059 G
		2.3.11
	Importance rating	2.7

Question: 22

Several Auxiliary Building radiation alarms are received. It is confirmed that Liquid Hold-Up Tank 1-1 has ruptured, and is leaking in the Auxiliary Building.

What action must be taken to prevent the offsite release of radioactive particulate and iodine?

A. Select "S" signal test, secure one Aux Bldg Ventilation train, and energize charcoal heaters.

B. Push "Status Reset" at POV1 and POV2, and reset the "S" signal.

C. Stop all Aux Bldg supply and exhaust fans, and energize charcoal heaters.

D. Locally close dampers that isolate the Waste Gas Decay Tank rooms.

Answer: <u>A</u>

Explanation: AP-14, step 2 provides direction for placing 100% of the ABVS exhaust through the charcoal filters for both units. This sequence is provided in answer A. The actions and sequences in B, C, & D will not accomplish the intent of the step.

Technical Reference(s): <u>OP-AP-14, rev. 12, step 2, page 2</u> Proposed references to be provided

to applicants during examination: <u>None</u> Learning Objective: 3477

\_\_\_\_\_ (As available) Question Source Bank # <u>B-0367</u>

Modified Bank # \_\_\_\_\_\_ (Note changes or attach parent) New \_\_\_\_\_\_ Question

Cognitive Level: Memory or Fundamental Knowledge <u>X</u> Comprehension or Analysis \_\_\_\_

\_\_ Comments:

Examination Outline Cross-Reference	Level	RO
	Tier #	3
Ability to comply with radiation work permit requirements during normal or abnormal conditions.	Group #	3
	K/A #	2.3.7
	Rating	3.5

Which of the following would meet the minimum requirement for entry into a High Radiation Area (dose rates do not exceed 1.0 REM/hour at 30 centimeters) per Technical Specification, Section 5.7, High Radiation Area?

Individual is entered on a valid Radiation Work Permit and...

- A. is continuously under the surveillance of a Radiation Protection Technician equipped with a self-reading dosimeter.
- B. has a monitoring device which continuously displays area radiation dose rate.
- C. has a monitoring device which updates individual dose record program.
- D. is accompanied by a Radiation Protection Technician with a neutron radiation monitoring instrument.

## Answer: B

## Explanation:

- A. Incorrect Radiation Protection Technician can monitor an individual in a High Radiation Area, but both MUST be wearing a radiation monitoring device that continuously displays area dose rate.
- B. Correct
- C. Incorrect Dose is being continuously updated, but the individual may not be aware of the cumulative dose.
- D. Incorrect Both individuals must be wearing a radiation monitoring device that continuously displays area dose rate.

Technical References: Technical Specification 5.7 References to be provided to applicants during exam: None Learning Objective: To be determined

**Question Source:** 

Bank #

Comanche Peak 2009 Exam #70

poront)	(note changes; attach	Modified Bank #	
parent)		New	
Question	History:	Last NRC Exam	No
Question	Cognitive Level:	Memory/Fundamental	Х
10CFR Pa	art 55 Content:	55.41 ( 12 )	

Examination Outline Cross-Reference	Level	RO
	Tier #	3
Ability to identify post accident instrumentation.	Group #	4
	K/A #	2.4.3
	Rating	3.7

Which of the following is considered Post Accident Instrumentation?

- A. Narrow Range Containment Sump Water Level
- B. Pressurizer Level
- C. Wide Range Neutron Flux
- D. Auxiliary Feedwater Flow

## Answer: C

## Explanation:

- A. Incorrect Wide Range Containment Sump Water Level is monitored by PAM1
- B. Incorrect Not monitored by PAMS
- C. Correct Monitored by PAM1
- D. Incorrect Not monitored by PAMS

## Technical References: System Training Guide, B-10, Post-Accident Monitoring System References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х

10CFR Part 55 Content:

Examination Outline Cross-Reference	Level	RO
	Tier #	3
Knowledge of EOP layout, symbols, and icons.	Group #	4
	K/A #	2.4.19
	Rating	3.4

When proceeding through Emergency Operating Procedures, if the reader comes across a step that is bordered within a box (e.g. 1), this denotes to the reader...

- A. Continuous Action Step
- B. Refer to Foldout Page
- C. Refer to the Note/Caution of that step
- D. Immediate Action Step

## Answer: D

Explanation:

- A. Incorrect Continuous Action Steps are bordered by a box around the entire step.
- B. Incorrect Instructions within the step will refer the reader to the Foldout Page.
- C. Incorrect Notes and Cautions are identified by their descriptors, NOTE or CAUTION, with the text extending across the entire page.
- D. Correct

Technical References: LPE-Rule (EOP Rules of Usage) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank #	
	New	х
Question History:	Last NRC Exam	No

**Question Cognitive Level:** 

10CFR Part 55 Content:

Memory/Fundamental Comprehensive/Analysis 55.41 (10)

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Ability to Interpret and execute procedure steps.	Group #	1
	K/A #	009 G2.1.20
	Rating	4.6
Question 76		

Following a small break LOCA on Unit 2 the following conditions exist:

- RCS temperature 525° F
- RWST level 32%
- RHR flow 150 GPM before RHR pumps stopped by the operator
- RCS pressure 290 PSIG
- Hydrogen Concentration .4%

Which ONE of the following procedures provides the required actions that mitigate these plant conditions?

- A. EOP E-1.4, Transfer to hot Leg Recirculation
- B. EOP E-1.2, Post LOCA Cooldown and Depressurization
- C. OP H-9, Inside Containment Hydrogen Recombination System
- D. EOP E-1.3, Transfer to Cold Leg Recirculation

#### Answer: D

#### **Explanation:**

- A. Incorrect Transfer to Hot Leg Recirculation occurs at step 20 of EOP E-1, but due to the current conditions, this procedure is exited at step 13 to Cold Leg Recirculation with RWST level less than 33% and RHR flow initially greater than 100 GPM before being stopped by the operator.
- B. Incorrect Entrance into E-1.2, Post LOCA Cooldown and Depressurization, does not occur due to RCS pressure being less than 300 PSIG in step 12 of E-1.
- C. Incorrect Entrance into OP H-9 would occur if Hydrogen concentration was greater than .5%.
- D. Correct Transfer to Cold Leg Recirculation occurs in step 13 of EOP E-1 with RWST level less than 33% and RHR flow greater than 100 GPM before being stopped by the operator.

**Comment [g1]:** Need s to be reworded to state what procedure the crew is operating in?

## Technical References: EOP E-1, Loss of Reactor or Secondary Coolant References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.43 ( 5 )	Х

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Ability to determine and interpret the following as they apply to	Group #	1
the Loss of Residual Heat Removal System: Leakage of reactor	K/A #	025 AA2.02
coolant from RHR into closed cooling water system or into	Rating	3.8
reactor building atmosphere.		

GIVEN:

- Unit 1 is in MODE 5
- RHR pump 1-1 is in service

PK11-21, High Radiation alarms. A few minutes later, PK02-16, RHR System and PK02-17, RHR Pumps, also goes into alarm.

Which of the following procedures should the SFM utilize to address the current plant conditions?

- A. AP-1, Excessive Reactor Coolant System Leakage
- B. AP SD-2, Loss of RCS Inventory
- C. AP-16, Malfunction of the RHR System
- D. AP-24, Shutdown LOCA

#### Answer: B

#### **Explanation:**

- A. Incorrect Only appropriate in MODES 1-4
- B. Correct
- C. Incorrect Not applicable in MODE 5 or if there is a loss of RCS inventory
- D. Incorrect Not applicable in MODE 5

Technical References: OP AP-24, OP AP SD-2, OP AP-1, OP AP-16, PK02-16, PK02-17, PK11-21 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: Bank # (note changes; attach Modifie

Bank # Modified Bank # #78 2005 Exam

parent)

	New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х
10CFR Part 55 Content:	55.43 ( 5 )	

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Knowledge of the purpose and function of major system	Group #	1
components and controls.	K/A #	026 G2.1.28
	Rating	4.1

Given the following conditions:

- Unit 1 reactor is at 100% power in Mode 1
- CCW Header 'C' is isolated due to excessive header leakage
- CCW Surge Tank is operable
- CCW Pump #2 is de-energized due to high motor temperatures

Which ONE of the following correctly describes the minimum time the surge tank is capable of system make-up based on 200 gpm non-mechanistic leakage rate AND whether the CCW system meets the operability requirement of Technical Specification 3.7.7

- A. 30 minutes; Operable
- B. 20 minutes; Operable
- C. 30 minutes; Inoperable
- D. 20 minutes; Inoperable

#### Answer: D

**Explanation:** 

- A. Incorrect
- **B.** Incorrect
- C. Incorrect
- D. Correct Tech Spec Bases 3.7.7 states that 20 minutes is the minimum time the Surge Tank can provide system makeup for leakage based on a 200 gpm nonmechanistic leakage rate. Tech Spec 3.7.7 states that TWO vital CCW loops shall be operable in Modes 1, 2, 3 and 4. The Bases for 3.7.7 describes two vital operable CCW loops to include headers 'A' and 'B', both CCW heat exchangers, the surge tank, and all THREE CCW pumps must be operable.

## Technical References: T.S. 3.7.7, Bases 3.7.7, System Lesson Guide LF-1 (Component Cooling Water) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank #	
	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.43 ( 2 )	х

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Ability to determine or interpret the following as they apply to a	Group #	1
Station Blackout: Actions necessary to restore power	K/A #	055 EA2.03
	Rating	4.7

A seismic event has occurred which has tripped both units and temporarily removed off site power. Both emergency diesels have failed to start and the plant is now in a station blackout condition. You have transitioned to ECA-0.0 (Loss of all Vital AC Power) from E-0 in conjunction with EOP ECA-0.3 (Restore 4kV Buses) in order to restore 4kV vital buses.

Given the following:

- No ECCS pumps are running
- No RCPs are running
- RCS subcooling is 19°F as indicated by core exit thermocouples
- PZR level is 14% and slowly decreasing
- RCS pressure is 2050 psig and slowly decreasing

Which of the following procedures should you utilize in order to restore power and stabilize the plant?

- A. Transition to EOP ECA-0.1 (Loss of All AC Power Without SI Required).
- B. Continue in EOP ECA-0.0 and EOP ECA-0.3 without transitioning.
- C. Transition to EOP ECA-0.2 (Loss of All AC Power With SI Required).
- D. Return to E-0 (Reactor Trip or Safety Injection).

#### Answer: C

#### Explanation:

- A. Incorrect Transitioning to ECA-0.1 would occur in step 28 of ECA-0.0 if RCS subcooling were greater than 20°F, Pressurizer level were greater than 12% and no ECCS pumps were running. As current conditions indicate that RCS subcooling is less than 20°F, the correct transition would be to ECA-0.2
- **B.** Incorrect
- C. Correct Transition to ECA-0.2 from step 28 in ECA-0.0 with RCS subcooling less than 20°F.

D. Incorrect

## Technical References: ECA-0.0, ECA-0.1, ECA-0.2, ECA-0.3, EOP E-0 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.43 ( 5 )	х

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Knowledge of abnormal condition procedures.	Group #	1
	K/A #	056 2.4.11
	Rating	4.2

A loss of offsite power has occurred while in MODE 1. You have just entered into OP AP-26 (Loss of Offsite Power).

Given the following:

- RCS temperature is 572° F
- 12 kV buses have been re-energized
- 480V vital and non-vital buses remain de-energized
- RCS pressure is 2175 psig

Which of the following correctly describes your next appropriate action?

- A. Implement OP L-5 to cool plant < 392° F (Plant Cooldown from Minimum to Cold Shutdown)
- B. Implement OP AP-7, Attachment 6.1 (Hot Condenser Cooldown)
- C. Implement OP C-7:I to fill and vent the Condensate System
- D. Immediately restart RCP-2 in order to restore core cooling and normal Pressurizer Spray

#### Answer: A

#### **Explanation:**

- A. Correct Step 1 (f) of OP AP-26 directs operators to ensure at least one CRDM fan in service. CRDM fans are powered from 12I and 12J of the non-vital buses which are currently de-energized. The 'NO' response to this step is to cool the RCS less than 392° F in order to minimize heating of CRDMs.
- B. Incorrect This occurs in Step 1 (i) of OP AP-26, only AFTER directing the cooldown per OP L-5.
- C. Incorrect This is not the next priority step, but occurs in Step 3 of Section B of OP AP-26 in order to help restore the secondary plant.
- D. Incorrect RCPs are not restarted until Step 1 of Section B of OP AP-26, and only

# AFTER performing an RCP Seal Status Evaluation to ensure seals are intact and capable of performing their intended function.

Technical References: OP AP-26 (Loss of Offsite Power) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.43 ( 5 )	х

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Ability to determine and interpret the following as they apply to	Group #	1
the Loss of vital AC Instrument Bus: That substitute power sources have come on line on a loss of initial AC.	K/A #	057 AA2.14
	Rating	3.6

Unit 1 is at full power.

AR PK19-19, UPS Failure is now alarming. The CO reports inputs 1503 and 1505 are locked in.

Which of the following describes the status of inverter 1-4 and the vital AC instrument bus 14?

- A. Both the inverter and the vital AC instrument bus are OPERABLE.
- B. The inverter is OPERABLE; the vital AC instrument bus is inoperable.
- C. The inverter is inoperable; the vital AC instrument bus is OPERABLE.
- D. Both the inverter and the vital AC instrument bus are inoperable; the vital AC instrument bus will be OPERABLE if the inverter can be transferred to its backup.

#### Answer: C

#### **Explanation:**

- A. Incorrect The inverter will be OPERABLE when it is powered from its normal source or from the DC source.
- B. Incorrect The inverter has transferred to its backup supply (input 1505), therefore the vital AC instrument bus is OPERABLE.
- C. Correct The vital instrument bus is powered from a class 1E CVT (backup supply) and OPERABLE. The inverter is inoperable.
- D. Incorrect The vital AC bus is currently energized.

Technical References: T.S. 3.8.7 and T.S. Bases 3.8.7, AR PK19-19 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: B (note changes; attach M

Bank # Modified Bank # #81 2005 Exam

**Comment [g2]:** RO question. Needs to be rewritten.

parent)

	New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х
10CFR Part 55 Content:	55.43 ( 2 )	

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Ability to determine and interrupt the following as they apply to	Group #	2
the Pressurizer Control Malfunctions: leak in PZR.	K/A #	028
		A2.11
	Rating	3.6

The plant was stable at full power with all systems operating normally in automatic control when the following occurs:

- Pressurizer level increased slightly but is now decreasing.
- Pressurizer pressure is 2220 psig and decreasing
- Pressurizer backup heaters energized
- Charging flow is increasing.
- Annunciator Containment Environment P250 actuates
- Containment Temperature rising

Which ONE of the following describes the correct procedure that Operators should take for the given conditions?

- A. GO TO OP AP-1 "Excessive Reactor Coolant System Leakage."
- B. GO TO OP AP-5 "Malfunction of Protection or Control Channel."
- C. GO TO OP AP-17 "Loss of Charging."
- D. GO TO OP AP-11 "Malfunction of Component Cooling."

## Answer: B

## **Explanation:**

- A. Correct Pressure Vapor Space leak has occured
- B. Incorrect Elevated Containment Temperature is inconsistent with a Pzr instrument level or pressure instrument failure.
- C. Incorrect Charging flow is increasing as expected in the response to the loss of RCS inventory.
- D. Incorrect Temperature rise is due to steam leak not High CCW temperature.

**Technical References:** ARP 01-16, Simulator Malfunction MALFPZR, OIM-A-4-2B **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source:	Bank #
(note changes; attach	Modified Bank #

parony
--------

	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	x
10CFR Part 55 Content:	55.43(5 and 13)	Λ

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Ability to evaluate plant performance and make operational	Group #	2
judgments based on operating characteristics, reactor behavior,	K/A #	051 G 2.1.7
and instrument interpretation.	Rating	4.7

A turbine load increase is in progress with all systems operating normally in automatic control when the following occurs:

- Turbine Load is 200 MWE.
- Pressurizer pressure is 2235 psig and stable
- Tave/Tref is matched.
- Condenser Pressure PI-44 reads 4.0"Hg Abs.
- Condenser Pressure Recorder PR-11A and B both show condenser pressure is slowly rising.
- Annunciator PK10-11 COND PRESS/LEVEL is in ALARM

Which ONE of the following describes the correct procedure that Operators should take for the given conditions?

- A. Immediately trip the reactor.
- B. Immediately trip the turbine.
- C. Reduce load increase necessary to restore condenser pressure to within operating limits.
- D. Reduce load as necessary to remove CWP from operation.

## Answer: C

#### Explanation:

- A. Incorrect. Power is below P-9Immediately trip the reactor.
- B. Incorrect. Condenser pressure is within acceptable operating region of Op AP-7 Attachment 6.2.
- C. Correct. Normal condenser parameter should re be restored..
- D. Incorrect. There are abnormal CWP indications or indications of tube fouling.

Technical References: OP-L-3 PK10-11 OP-AP-7 References to be provided to applicants during exam: None

## Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #
parenty	New X
Question History:	Last NRC Exam
Question Cognitive Level:	Memory/Fundamental
10CFR Part 55 Content:	55.41(7)

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Ability to operate and/or monitor the following as they apply to	Group #	2
the dropped rod: Rod position indication to actual rod position	K/A #	003 AA2.01
	Rating	3.9

GIVEN:

- A load increase is in progress with all systems operating normally in automatic control.
- Reactor power is 90% and increasing under operator control.
- Control Bank D group demand counters at 200 steps.
- Individual Digital Rod Position Indications for all Bank D rods read 204 steps.
- Bank Overlap Unit reads 584 steps.
- Pressurizer pressure is 2235 psig and stable
- Tave/Tref is matched.
- Annunciator PK03-15 Bank D Rod Stop C-11 is in ALARM.

Which of the following describes the cause of the alarm and the correct procedure that Operators should take for the given conditions?

- A. Loss of power to the P/A converter. Initiate work request to troubleshoot and repair.
- B. Bank D Rod Position Indication malfunctions. Refer to Technical Specification 3.1.7 "Rod Position Indication."
- C. Bank D Inappropriate Rod motion. Refer to OP-AP-12A, "Continuous Withdraw or Insertion of a Control Rod Bank."
- D. Bank D Rod misalignment. Refer to OP-AP-12B, "Control Rod Misalignment."

## Answer: A

## Explanation:

- A. Correct. Loss of power to the P/A converter generates fail safe actuation of C-11.
- B. Incorrect. Bank overlap unit, group demand and DRPI are all consistent,
- C. Incorrect. Tave/Tref remains matched. No inappropriate rod motion has occurred.
- D. Incorrect. Group demand and DRPI for all rod within Bank D agree within accuracy range band.

**Technical References:** OP-L-4, STG-A3a Page 2-47, AR PK03-15 OIM B-6-3 **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

## **Question Source:**

(note changes; attach parent)

Bank # Modified Bank #

New

**Question History:** 

Last NRC Exam

**Question Cognitive Level:** 

10CFR Part 55 Content:

Memory/Fundamental Comprehensive/Analysis 55.43(5 and 13) Х

Examination Outline Cross-Reference	Level	SRO
Knowledge of the limiting conditions for operation and safety	Tier #	1
limits	Group #	2
	K/A #	WE08
		G2.2.22
	Rating	4.7

Given the following:

- Unit 2 was at 100% power.
- All systems were operating normally in automatic
- Automatic Main Steam Line Isolation failed to occur
- An uncontrolled cooldown of all steam generators **has occurred** resulting in a RCS cold leg temperature reaching 235°F.

The crew is in E-0 Rector Trip or Safety Injection and has successfully closed all MSIVs and Bypass Valves manually per step 8 RNO. **Now** the following conditions exist:

- RCS pressure 1750 psig and rising
- Pressurizer level 15% and rising
- Steam Geneartor pressures:

S/G 2-1	820 psig, rising
S/G 2-2	0 psig, stable
S/G 2-3	900 psig, rising
S/G 2-4	890 psig, rising

Which ONE of the following describes the next procedure that the crew should take for the given conditions?

- A. E-1.1 Safety Injection Termination to prevent over-pressurizing the RCS.
- B. E-2 Faulted Steam Generator Isolation
- C. ECA-2.1 Uncontrolled Depressurization of All Steam Generators
- D. FR-P.1 Response to Imminent Pressurized Thermal Shock Condition

## Answer: B

## **Explanation:**

- A. Incorrect. Transition to E-1.1 will occur at E-2 Step 8.
- B. Correct. Transition to E-2 is required at E-0 step 11
- C. Incorrect. Transition to ECA-2.1 could occur at E-2 step 2 but condition is not met.
- D. Incorrect. Magenta FR-P.1 condition met but is only temporary. Per EOP F-0 section 4.1.1, operator is not required to perform action of FR-P.1 since adequate

time was not allowed for thermal stresses to affect the integrity of the vessel wall. **Technical References: References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41(5) 43(2) and 45(2)	Х

ML0508904472 Feb 2005

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #		1
Group #		2
K/A #	W/E02 EA2.1	
Importance		4.2

## Proposed Question: SRO Question 83

A steam break occurs inside containment on Steam Generator 2-2. The crew is performing the steps of E-0, Reactor Trip or Safety Injection.

Current plant conditions:

•Containment pressure – 14 psig (peak at 25 psig)

•Steam Generator 2-2 early isolation performed

•Total AFW throttled to 500 gpm

•RCS pressure – 1850 and increasing

•Steam Generator pressures:

 $\circ$  2-1 – 900 psig, stable

 $\circ$  2-2 – 0 psig, stable

o 2-3 and 2-4 – 1000 psig, stable

 $\bullet$ Pressurizer Level – 35%, increasing

•RCS Subcooling 50°F

The procedural flowpath should be E-0 to ....

A. E-1.1

B. E-2 to E-1.1

C. FR-Z.1 to E-1.1

D. FR-Z.1 to E-2 to E-1.1

Proposed Answer:

B. E-2 to E-1.1

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Ability to interpret control room indications to verify the status		1
and operation of a system, and understand how operator	K/A #	007 G2.2.44
actions and directives affect plant and system conditions.	Rating	4.2

GIVEN:

- Unit 1 was at 100% power.
- A Pressurizer PORV inadvertently opened.
- The reactor has tripped.
- The PORV is now isolated.
- PK 05-25, PZR Relief Tank Press, Lvl, Temp is in alarm
- PRT Press is 12 psig
- PRT Level is 92%
- PRT Temperature is 140F

Which of the following is the correct order of priority to restore PRT parameters?

- A. Pressure, Level, Temperature.
- B. Temperature, Pressure, Level.
- C. Level, Temperature, Pressure.
- D. Pressure, Temperature, Level.

## Answer: C

## **Explanation:**

- A. Incorrect the PRT cannot be vented with pressure > 10 psig. Lowering Level and temperature first will lower pressure then venting can occur.
- B. Incorrect PRT temperature is lowered by opening RCS-8030 primary water supply valve. Level is already high.
- C. Correct Lowering level first helps lower pressure and temperature. This is the order in Alarm response AR PK05-25.
- D. Incorrect Level, Temperature then pressure is the order in AR PK05-25.

## Technical References: AR PK05-25 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source:	Bank #	X
(note changes; attach	Modified Bank #	

parent)

New

Question History:Last NRC ExamQuestion Cognitive Level:Memory/Fundamental<br/>Comprehensive/Analysis10CFR Part 55 Content:55.41(5), 43(3) and 45(2)

## BVPS 2LOT4 NRC Written Exam ML 030230046

Examination Outline Cross-reference:

Level	RO	SRO
Tier #	2	2
Group #	3	3
K/A #	007 A1.02	
Importance Rating	2.7	2.9

Ability to predict and/or monitor changes in parameters (to prevent exceeding design limits) associated with operating the PRTS controls including: Maintaining quench tank pressure.

Question: 25

Given the following:

- "\* The Unit is at 100% power when a Pressurizer PORV inadvertently opens.
- "\* The reactor was tripped and the PORV is now isolated.
- "\* PRZR Relief Tank (PRT) pressure, temperature and level are now elevated above normal values.

In accordance with 20M-6.4.AAY, Pressurizer Relief Tank Trouble, PRT parameters are to be restored to normal values by establishing appropriate PRT.

- A. level, then temperature, then pressure.
- B. pressure, then temperature, then level.
- C. level, then pressure, then temperature.
- D. pressure, then level, then temperature.

Proposed Answer: A

Explanation:

- A. Correct.
- B. Incorrect. Pressure must be established last because temperature and level both affect pressure.

- C. Incorrect. See above.
- D. Incorrect. See above.

Technical Reference(s): Attach if not previously provided) 20M-6.4.AAY 20M-6.2.A **20M-6.1.C** Proposed References to be provided to applicants during examination: NONE

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Ability to (a) predict the impacts of the following malfunctions	Group #	1
or operations on the CSS; and (b) based on those predictions,	K/A #	026 A2.04
use procedures to correct, control or mitigate the	Rating	4.2
consequences of those malfunctions or operation: Failure of		
spray pump		
Question 87		

A large break LOCA occurred, resulting in a reactor trip and safety injection.

EOP E-1, "Loss of Reactor Coolant or Secondary Coolant" is in progress.

The following conditions exist:

- RCS Pressure is 60 psig and trending down slowly
- RCS Temperature is 300F and trending down slowly
- RWST level is 50% and trending down slowly
- RHR flow is 150 gpm
- Containment pressure is 32 psig and trending down slowly
- PK01-18 Containment Spray Actuation is ON
- Containment Spray Pump 1-1 failed to auto-start and cannot be manually started.

Based on the above, the Shift Forman should:

- A. Continue in E-1, "Loss of Reactor Coolant or Secondary Coolant."
- B. GO TO E-1.3, "Transfer to Cold Leg Recirculation."
- C. GO TO ECA-1.1, "Loss of Emergency Coolant Recirculation."
- D. GO TO FR-Z.1, "Response to High containment Pressure."

## Answer: D

## **Explanation:**

- A. Incorrect. Crew has transitioned out of E-O to E-1 already. Status Monitoring is in effect per EOP F-0 background document. MAGENTA PATH on Containment should be implemented per EOP F-0 rule of Usage 3.3.
- B. Incorrect. E-1.3 would be implemented if RWST level is < 33%. RWST level is above this transition criteria.
- C. Incorrect. ECA-1.1 Entry condition from E-1 Step 11 NOT met since RHR is available and running.
- D. Correct. MAGENTA PATH on Containment should be implemented per EOP F-0 rule of Usage 3.3.
Technical References: References to be provided to applicants during exam: None Learning Objective:

Question Source: (note changes; attach	Bank # Modified Bank #	Х
parony	New	
Question History:	Last NRC Exam	
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	
10CFR Part 55 Content:	55.41(5) 43(5) 55.45(3 & 13)	

#### Modified from June 2008 Exam ML 09127008 June 2008 DCPP Written Examination Question Worksheet SRO Question 2

NRC Form ES-401-5

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #		1
Group #		1
K/A #		011/2.4.4
Importance Rating	4.7	

K/A: Large Break LOCA - Emergency Procedures/Plan: Ability to recognize abnormal indications for system operating parameters that are entry-level conditions for emergency and abnormal operating procedures.

Proposed Question:

ES-401

A Large Break LOCA has occurred, resulting in a reactor trip and safety injection.

EOP E-1, "Loss of Reactor or Secondary Coolant" is in progress.

The following conditions currently exist:

- RCS Pressure is 40 PSIG and stable.
- RHR system flow is at 0 gpm.
- RWST Level is 32% and TRENDING DOWN SLOWLY.
- Containment Recirculation Sump level is 94 feet and TRENDING UP SLOWLY.

Based on the above parameters the Shift Foreman should:

- A. Continue in E-1, "Loss of Reactor or Secondary Coolant."
- B. GO TO E-1.3, "Transfer to Cold Leg Recirculation."
- C. GO TO FR-Z.2, "Response to Containment Flooding."
- D. GO TO ECA-1.2, "LOCA Outside Containment."

Proposed Answer: B

Explanation:

Answer A is incorrect. E-1 foldout page directs the operator to transition to E-1.3 when RWST level reaches 33%.

Answer B is correct. E-1 Foldout page item is met for transition to E-1.3 based on the RWST level being below 33%, RHR flow is zero because the RHR pumps tripped off automatically on low RWST level of 33%. 92 ft is the expected level for the Containment Recirculation Sump following a DBA LOCA.

Answer C is incorrect. Containment flooding is only a concern if Recirc sump level is greater than 95.75 ft..

Answer D is incorrect. LOCA outside containment has not occurred; level in containment and the RWST are at the expected values. E-1.3 will check for this condition.

Technical Reference(s): LPE-1A, Loss of Coolant Response, Page 25, Rev. 10. EOP E-1, Loss of Reactor or Secondary Coolant, Step 13, page 14 and Foldout Page, Rev. 24. EOP E-1.3, Transfer to Cold Leg Recirculation, Step 6, Page 4, Rev. 25.

Proposed references to be provided to applicants during examination: NONE

Learning Objective: 3552 - Given initial conditions, assumptions, and symptoms, determine the correct Emergency Operating Procedure to be used to mitigate an operational event.

Question Source:

	Bank # Modified New	l Bank # B-0101 (	(Note changes or attach parent)
Question History:	Last NR	C Exam	N/A
Question Cognitive Level	:	Memory or Fund Comprehension	damental Knowledge or Analysis X
10 CFR Part 55 Content:	55.41 55.43	5	
10 CFR Part 55 Content:	Assessi normal,	ment of facility co abnormal, and er	onditions and selection of appropriate procedures during mergency situations.

Comments:

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Ability to prioritize and interpret the significance of each	Group #	1
annunciator or alarm.	K/A #	005G2.4.45
	Rating	4.3

GIVEN:

- Unit 1 is cooling down in Mode 5.
- Both trains of RHR cooling (supported by 2 ASW Pumps and 3 CCW pumps) are in service.
- The following Annunciators go into alarm:

PK01-06	CCW Vital HDR A/B
PK01-09	CCW PUMPS
PK01-16	RHR SYSTEM
PK01-17	RHR PUMPS
PK16-22	480 V BUS 1H
PK16-24	480 BUS 1H GROUND

• RCS Cooldown rate decays.

Which ONE of the following describes the correct procedure that Operators should take for the given conditions?

- A. GO TO OP AP-SD-0 "Loss of, or Inadequate Decay Heat Removal."
- B. GO TO OP AP-SD-1 "Loss of AC Power."
- C. GO TO OP AP-SD-4 "Loss of Component Cooling Water."
- D. GO TO OP AP-SD-5 "Loss of Residual Heat Removal."

# Answer: A

# **Explanation:**

- A. Correct AP-SD-0 is used to diagnose cause of degraded decay heat removal and identify appropriate procedure.
- B. Incorrect Plausible because AP-SD-1 is used when BOTH trains of RHR/ASP/CCW is lost.
- C. Incorrect CCW is functioning SAT. CCW anunciators will result on CCW pump 1-2 trip and auto-start of CCW pump 1-3.
- D. Incorrect AP-SD-5 verifies ONE RHR train restored (step 3). If one train is inadequate procedure directs crew to AP- SD-0 (step 8 RNO)

# Technical References: Lesson Plan LPA-SD References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach		Bank # Modified Bank #	
parenty		New	
Question Hist	ory:	Last NRC Exam	
Question Cog	nitive Level:	Memory/Fundamental Comprehensive/Analysis	
10CFR Part 5	5 Content:	55.41(10), 43(5) and 55.45(3)	

Х

Examination Outline Cross-Reference	Level	SRO
Ability to (a) predict the impacts of the following malfunctions	Tier #	2
or operations on the DC electrical systems; and (b) based on	Group #	1
those predictions, use procedures to correct, control or mitigate	K/A #	063 A2.02
the consequences of those malfunctions or operation: Loss of	Rating	3.1
ventilation during battery charging.		

Unit 1 is at 100% power

Maintenance Service requests to work on both Auxiliary Building Switchgear Ventilation System supply and exhaust fans (2-27 and E-27)

What are the operational concerns and the correct response the SFM should take?

- A. Reduced Battery Capacity; Implement compensatory measures for blocked open doors per ECG80.1, Doors Required for HELB, HVAC ECCS Function or Flood Protection.
- B. Reduced Battery Capacity; Declare Batteries Inoperable per Tech Spec 3.8.4, DC Sources Operating
- C. Elevated Hydrogen concentration in the Vital Battery Rooms; Implement compensatory measures for blocked open doors per ECG80.1, Doors Required for HELB, HVAC ECCS Function or Flood Protection.
- D. Elevated Hydrogen concentration in the Vital Battery Rooms; Declare Batteries Inoperable per Tech Spec 3.8.4, DC Sources - Operating

# Answer: C

#### Explanation:

- A. Incorrect Battery Capacity will not be diminished but ECG is correct.
- B. Incorrect Battery Capacity will not be diminished, T/S is incorrect
- C. Correct Hydrogen concentration will increase in battery rooms without adequate ventilation, blocked open doors are controlled by ECG 80.1.
- D. Incorrect Hydrogen concentration will increase in battery rooms without adequate ventilation, but T/S is incorrect.

Х

#### Technical References: References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source:	Bank #	
(note changes; attach	Modified Bank #	

parent)

New

Question History:	Last NRC Exam
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis
10CFR Part 55 Content:	55.41(5), 55.43(5) and 55.45(3 & 13)

### Banked From June 2008 Exam ML -8280427

### SRO Question 14

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #		2
Group #		1
K/A #		063/A2.02
Importance Rating		3.1

K/A: **D.C. Electrical Distribution System** - Ability to (a) predict the impacts of the following malfunctions or operations on the D.C. Electrical System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those malfunctions or operations: Loss of ventilation during battery charging.

Proposed Question:

Unit 1 is at 100% power.

Maintenance Services requests to work on both Auxiliary Building Switchgear Ventilation system supply and Exhaust fans (S-27 and E-27).

What are the operational concerns and the response by the SFM?

- A. Elevated H<sub>2</sub> (Hydrogen) concentration in the Vital Battery Rooms; Implement compensatory measures for blocked open doors per ECG 80.1, Doors required for HELB, HVAC, ECCS Function or Flood Protection.
- B. Reduced Battery Capacity, Implement compensatory measures for blocked open doors per ECG 80.1, Doors required for HELB, HVAC, ECCS Function or Flood Protection.
- C. Reduced Battery Capacity, Declare the batteries inoperable per Tech Spec 3.8.4, DC Sources Operating.
- D. Elevated H<sub>2</sub> (Hydrogen) concentration in the Vital Battery Rooms; Declare the batteries inoperable per tech Spec 3.8.4, DC Sources Operating.

Proposed Answer: A

Explanation:

Answer A is correct.  $H_2$  concentration will increase in the battery rooms without sufficient ventilation, compensatory action would be to open doors to provide ventilation from other systems. Blocked open doors are controlled by ECG 80.1.

Answer B is incorrect. Capacity of the battery will not be diminished, ECG is correct.

Answer C is incorrect. Capacity of the battery will not be diminished, TS is incorrect.

Answer D is incorrect. H<sub>2</sub> concentration will increase in the battery rooms without sufficient ventilation; Batteries do not have to be declared inoperable until operational limits are exceeded, there are no limits for high temperature.

Technical Reference	e(s): LH-10 Miscella & 22, Rev. 4.	neous Building Ventilation System, Pages 11	
	ECG 80.1, Doc	ors required for HELB, HVAC, ECCS Function,	
	or Flood Protect	ction, Rev. 5.	
Proposed references	s to be provided to app	Dicants during examination: NONE	
Learning Objective:	65936 - Discuss :	significant Technical Specifications and	
	Equipment Control	ol Guidelines associated with the	
	Miscellaneous Bu	uilding Ventilation System.	
Question Source:	Bank #		
	Modified Bank #	(Note changes or attach parent)	
	New	X	
Question History:	Last NRC Exam	N/A	
Question Cognitive Level: Memory or Fundamental Knowledge			
Comprehension or Analysis X			
10 CFR Part 55 Content: 55.41			
55.43 2			
10 CFR Part 55 Content: Facility operating limitations in the technical specifications			
	and their base	es.	

Comments:

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Ability to interpret control room indications to verify the status		1
and operations of a system, and understand how operator	K/A #	003 G2.2.44
actions and directives affect plant and system conditions.	Rating	4.4

Unit 1 is carrying out actions in FR-C.1, and all RCPs are off.

The crew is making preparations to start a RCP using Attachment B in FR-C.1. Seal cooling was lost to RCP No. 2 but is now restored.

The following RCP conditions exist:

	RCP No. 1	RCP No. 2	RCP No. 3	RCP No. 4
Seal D/P	Slightly low	SAT	SAT	SAT
Seal Injection Flow	SAT	Slightly high	Slightly low	SAT
Seal Leak-off	SAT	SAT	SAT	Slightly high

What direction would give to the operator that is starting the RCP?

- A. Start RCP No. 1 after lowering VCT pressure to restore Seal D/P.
- B. Start RCP No. 2 after lowering VCT pressure to restore Seal Injection Flow.
- C. Start RCP No. 3 after lowering to VCT pressure to restore Seal Injection Flow.
- D. Start RCP No. 4 after lowering to VCT pressure to restore Seal Leak-off.

### Answer: A

#### Explanation:

- A. Correct Pump is second in order of preference for normal PZR Spray.
- B. Incorrect Preferred pump but RCP seal cooling was lost and should not be started WITHOUT an RCP Seal Status Evaluation.
- C. Incorrect Pump is behind RCP No 1 and No.2 in starting preference.
- D. Incorrect lowering VCT pressure will raise (not lower) seal leak off flow to normal.

Х

**Technical References:** EOP FR-C.1 Appendix B **References to be provided to applicants during exam:** None **Learning Objective:** 

Question Source:	Bank #
(note changes; attach	Modified Bank #

parent)

New

xam
ndamental sive/Analysis .43(5) and

### Modified from FEB 2005 - ML 050890447

### **Question Worksheet**

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #		2
Group #		1
K/A #	003 A2.05	
Importance		2.8

### Proposed Question: SRO 86

The crew is making preparations to start a RCP using Attachment B in E-0.2, "Natural Circulation Cooldown". The CO reports Seal Leakoff flow is low. All other conditions for starting the RCP are met.

Which of the following actions should the SFM direct the operator to perform?

A. Start the RCP.

B. Increase VCT level.

C. Increase charging flow.

D. Decrease VCT pressure.

#### Proposed Answer:

D. Decrease VCT pressure.

Explanation:

A incorrect, this is not a procedure in which RCPs are started if normal conditions are not met.

B incorrect, increasing VCT level will increase VCT pressure, which will further decrease seal leakoff flow.

C incorrect, increasing charging will not affect appreciably affect seal leakoff.

D correct, decreasing VCT pressure will decrease the DP and increase seal leakoff flow.

Technical Reference(s):

E-0.2, Natural Circulation Cooldown, attachment B, Restart of Reactor Coolant Pump Proposed references to be provided to applicants during examination: none Learning Objective: 4892 - State the cause/effect relationship between VCT and RCPs sro tier 2 group 1\_86.doc Question Source: New X Question History: Last NRC Exam N/A Question Cognitive Level: Memory or Fundamental Knowledge \_\_\_\_\_ Comprehension or Analysis X 10 CFR Part 55 Content: 55.41 41.5 55.43 43.5 Comments:

K/A: 003 A2.05 – Reactor Coolant Pump - Ability to (a) predict the impacts of the following malfunctions or operations on the RCPS; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those malfunctions or operations: Effects of VCT pressure on RCP seal leakoff flows

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Ability to (a) predict the impacts of the following malfunctions	Group #	2
or operations on the NIS: and (b) based on those predictions,	K/A #	015 A2.01
use procedures to correct, control, or mitigate the	Rating	3.9
consequences of those malfunctions or operations: Power		
supply loss or erratic operation.		

GIVEN:

- Unit 1 is at full power
- PT 505 has failed low rods are driving in
- PR NI-41 has de-energized
- SR NI-32 has energized
- Pressure Control Hagan controller has switched to MANUAL
- Pressurizer Level Hagan controller has switched to AUTO HOLD
- Auto Makeup is initiating

Which of the following initial and subsequent procedures addresses the required immediate actions and the necessary follow up actions to restore the plant?

OP AP-4 (Loss of Vital or Nonvital Instrument AC) OP AP-5 (Malfunction of Protection or Control Channel) OP J-10:I (Instrument AC System – Make Available and Energize) OP J-10:IV (Instrument AC System – Transfer of Panel Power Supply)

- A. OP AP-4; OP J-10:I
- B. OP AP-5; OP J-10:IV
- C. OP AP-4; OP J-10:IV
- D. OP AP-5; OP J-10:I

#### Answer: A

#### Explanation:

A. Correct – Loss of Instrument AC has occurred which has de-energized PY-11, resulting in Loss of PR NI-41 and the energizing of SR NI-32. Tref has fallen below Tave due to the loss of PT-505, causing rods to drive in. Various Hagan controllers will switch to Manual or AUTO HOLD. OP AP-4 (Loss of Vital or Nonvital Instrument AC) is the appropriate procedure to enter and combat this casualty. Step 3 of AP-4 will direct the operators to OP J-10:I in order to reenergize vital instrument buses.

- B. Incorrect
- C. Incorrect
- D. Incorrect

Technical References: OP AP-4, OP AP-5, OP J-10:I, OP J-10:IV References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х
ioor in r art 55 content.	33.43 ( 3 )	

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Malfunctions or operations on the HRPS; and (b) based on	Group #	2
those predictions, use procedures to correct, control or mitigate	K/A #	028 A2.02
the consequences of those malfunctions or operations: LOCA	Rating	3.9
condition and related concern over hydrogen		

GIVEN:

- A large break LOCA has occurred
- Hydrogen concentration inside Containment as measured on PAM 1 is 1.6%
- EOP E-1 has been entered

Which of the following supplemental procedures to E-1 correctly place the Containment Hydrogen Recombination System in service and WHO is responsible to order this system placed in service?

- A. OP H-8; Shift Foreman
- B. OP H-9; Site Emergency Coordinator
- C. OP H-8; Site Emergency Coordinator
- D. OP H-9; Shift Foreman

OP H-8 (Containment Hydrogen Purge System) OP H-9 (Inside Containment Hydrogen Recombination System)

#### Answer: B

#### **Explanation:**

- A. Incorrect
- B. Correct EOP E-1 step 19 directs operators to OP H-9 if hydrogen concentration is more than .5%. OP H-9 states that the IHRS is ONLY placed in service upon direction of the TSC and the Site Emergency Coordinator.
- C. Incorrect
- D. Incorrect

Technical References: EOP E-1 (Loss of Reactor or Secondary Coolant), OP H-9 (Inside Containment H2 Recombination System) References to be provided to applicants during exam: None

# Learning Objective: To be determined

Question Source: (note changes; attach		Bank # Modified Bank #		
parent)		New	Х	
Question I	History:	Last NRC Exam	No	
Question (	Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х	
10CFR Par	rt 55 Content:	55.43 ( 5 )		

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Ability to analyze the effect of maintenance activities, such as	Group #	2
degraded power sources, on the status of limiting conditions	K/A #	068 2.2.36
for operations.	Rating	4.2

A liquid Radwaste Discharge Permit and Checklist have been completed in accordance with OP G-1 in preparation for overboard discharge of an Equipment Drain Receiver.

Checklist status is as follows:

- One Circulating Water pump is RUNNING.
- One Auxiliary Salt Water Pump is RUNNING.
- RE-18, Radwaste Effluent Radiation Monitor, is OOS.
- FR-20, Radwaste effluent Recorder, is OOS.

Based on the information given, could the Shift Foreman authorize the discharge and why?

- A. NO; both the discharge radiation monitor and the flow recorder are OOS.
- B. NO; there is insufficient dilution flow.
- C. YES; the alternate radiation monitor and flow recorder could be used.
- D. YES; samples can be analyzed and flow rate can be estimated.

### Answer: D

Explanation:

- A. Incorrect
- B. Incorrect
- C. Incorrect
- D. Correct

Technical References: ECG 39.3 pages 1 and 4 References to be provided to applicants during exam: None Learning Objective: To be determined

**Question Source:** 

parant)	(note changes; attach	Modified Bank #	
parent)		New	
Question	History:	Last NRC Exam	No
Question	Cognitive Level:	Memory/Fundamental	x
10CFR Pa	art 55 Content:	55.43 ( 2 )	Λ

Examination Outline Cross-Reference	Level	SRO
	Tier #	3
Ability to use procedures related to shift staffing, such as	Group #	1
minimum crew complement, overtime limitations, etc.	K/A #	2.1.5
	Rating	3.9

Unit 2 is in MODE 6 with the last head closure bolt in the process of being removed for refueling.

You have been tasked as the Shift Foreman to develop the list of qualified personnel for your upcoming shift. Are you required to include a Health Physics Technician and Shift Technical Advisor to your shift complement under the current plant conditions?

Health Physics Technician		Shift Technical Advisor
A.	No	Yes
В.	Yes	No
C.	Yes	Yes
D.	No	No

# Answer: B

# Explanation:

- A. Incorrect
- B. Correct T.S. 5.2.2 (Unit Staff) requires a Health Physics Technician any time that fuel is in the core, which meets the current plant condition. A Shift Technical Advisor is required in MODES 1, 2, 3, and 4 only.
- C. Incorrect
- D. Incorrect

Technical References: T.S. 5.2.2 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source:		Bank #
	(note changes; attach	Modified Bank #
parent)		

	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х
10CFR Part 55 Content:	55.43 ( 2 )	

Examination Outline Cross-Reference	Level	SRO
	Tier #	3
Ability to make accurate, clear, and concise verbal reports.	Group #	1
	K/A #	2.1.17
	Rating	4.0

If, as the Shift Foreman, you have deviated from a license condition or technical specification in order to protect public health and safety in the event of an emergency, what would be the time requirement to report such a deviation to the NRC?

- A. 15 minutes
- B. 30 minutes
- C. 1 hour
- D. 4 hours

### Answer: C

#### Explanation:

- A. Incorrect
- B. Incorrect
- C. Correct 10CFR50.72(5)(b) directs a licensee to report within one hour if that licensee has departed from a license condition or technical specification pursuant to 10CFR50.54(x).
- D. Incorrect

Technical References: 10CFR50.72(5)(b) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	

10CFR Part 55 Content:

Comprehensive/Analysis 55.43 ( 5 )

Examination Outline Cross-Reference	Level	SRO
	Tier #	3
Knowledge of the process for controlling equipment	Group #	2
configuration or status.	K/A #	2.2.14
	Rating	4.3

Which situation would require a Temporary Modification (TMOD)?

- A. Leaving a pump suction strainer installed following flushing.
- B. Installing a temporary hose to drain a pump cleared for maintenance.
- C. Lifting a lead as part of a surveillance test.
- D. Installing a jumper on cleared equipment using an approved work order.

#### Answer: A

#### **Explanation:**

- A. Correct
- **B.** Incorrect
- C. Incorrect
- **D.** Incorrect

#### Technical References: CF4.ID7 pages 2 and 6 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	#94 20	02 Exam
parenty	New		
Question History:	Last NRC Exam	I	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis		Х
Examination Outline Cross-Reference		l evel	SRO
	~	Tier #	3

Knowledge of the bases in Technical Specifications for limiting	Group #	2
conditions for operations and safety limits.	K/A #	2.2.25
	Rating	4.2

Technical Specification 3.5.1, Accumulators, applies until the plant is in MODE 3, less than 1000 psig.

In accordance with TS 3.5.1 basis, why are the accumulators allowed to be removed from service below 1000 psig?

- A. ECCS injection is sufficient to ensure peak clad temperature remains below 2200°F.
- B. Nitrogen injection is a larger risk.
- C. The probability of a large LOCA with a blowdown phase is sufficiently low.
- D. Accumulator boron concentration is typically less than required shutdown boron concentration.

#### Answer: A

#### Explanation:

- A. Correct Below 1000 psig, ECCS injection is sufficient to maintain core cooling.
- B. Incorrect This is why Accumulators are isolated in many EOPs.
- C. Incorrect A large LOCA will still have a blowndown phase.
- D. Incorrect Required boron concentration in an accumulator is higher than any required shutdown boron concentration.

Technical References: T.S. 3.5.1, B 3.5.1 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	#76 2005 Exam
parent)	New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х

10CFR Part 55 Content:

Examination Outline Cross-Reference	Level	SRO
	Tier #	3
Ability to approve release permits.	Group #	3
	K/A #	2.3.6
	Rating	3.8

A discharge of Gas Decay Tank 1-2 is planned.

Given these conditions:

- Current time and date 2200, 17 July
- RE-22 declared inoperable at 0100 on 3 July
- The planned discharge will take 4 hours
- 2 samples have been independently drawn and analyzed
- Release rate calculations have been independently verified

Which of the following describes whether the planned discharge may or may not occur?

- A. The planned discharge may proceed in its entirety.
- B. The discharge may occur, but only for 3 hours, then it must be terminated.
- C. The planned discharge may not occur until RE-22 is restored to OPERABLE status.
- D. The discharge may not proceed because during the discharge, the allowable time RE-22 may be inoperable will expire.

# Answer: C

#### Explanation:

- A. Incorrect Discharge not allowed by OP-G-2:V step 6.17
- B. Incorrect The allowable outage time (14 days) has ALREADY expired. This is a credible distracter because <u>if</u> RE-22 was declared inoperable at 0100 on <u>4</u> July, OP G-2:V step 6.1.6 would allow 3 hours of discharge.
- C. Correct as of 0100 on 17 July, the 14 days allowed by ECG (and procedure OP G-2:V step 6.1.7) has been exceeded. A discharge is not allowed.
- D. Incorrect The allowable outage time (14 days) has ALREADY expired.

**Technical References:** ECG 39.4 , OP G-2:V, Gaseous Radwaste System – Gas Decay Tank Discharge

**References to be provided to applicants during exam:** OP G-2:V ECG 39.4 **Learning Objective:** To be determined

**Question Source:** 

parent)	(note changes; attach	Modified Bank #
		New
Question	History:	Last NRC Exam
Question Cognitive Level:		Memory/Fundamental Comprehensive/Analysis
10CFR Part 55 Content:		55.41(13), 43(4), 45(10)

# SRO Question 98 ML050890447 02/2005 Exam Question Worksheet

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #		3
Group #		3
K/A #		G2.3.8
Importance		3.2

No

#### **Proposed Question**:

A discharge of Gas Decay Tank 1-2 is planned.

The current conditions exist:

- Current time and date 2200, 17 July
- RE-22 declared inoperable at 0100 on 3 July
- The planned discharge will take 4 hours
- 2 samples have been independently drawn and analyzed

Which of the following describes whether the planned discharge may or may not occur?

- A. The planned discharge may not occur until RE-22 is restored to OPERABLE status.
- B. The planned discharge may proceed in its entirety.
- C. The discharge may occur, but only for 3 hours, then it must be terminated.
- D. The discharge may not proceed because during the discharge the allowable time RE-22 may be inoperable will expire.

Proposed Answer: A. The planned discharge may not occur until RE-22 is restored to OPERABLE status.

Explanation:

- A. Correct, as of 0100 on 17 July, the 14 days allowed by ECG (and procedure OP G- 2:V) has been exceeded. A discharge is not allowed.
- B. Incorrect, 14 days exceeded.
- C. Incorrect, 14 days already exceeded.
- D. Incorrect, if there is time available, the discharge could have continued for a short period of time.

Technical Reference(s): ECG 39.4

OP G-2:V, Gaseous Radwaste System – Gas Decay Tank Discharge

Proposed references to be provided to applicants during examination: OP G-2:V ECG 39.4 Learning Objective: 7428 - State gaseous radwaste system administrative controls 66068 - Discuss the requirements of System 39 ECGs. Question Source: New X Question History: Last NRC Exam N/A

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Knowledge of EOP terms and definitions.	Group #	4
	K/A #	2.4.17
	Rating	4.3

What is meant by the term HOT DRY STEAM GENERATOR?

- A. Primary Side Temperature >543F. No secondary side liquid inventory.
- B. Primary Side Temperature >550F. No secondary side liquid inventory.
- C. Primary Side Temperature >581F. Secondary side liquid inventory <23% Wide Range.
- D. Primary Side Temperature >635F. Secondary side liquid inventory < 23% Wide Range.

### Answer: B

#### Explanation:

- A. Incorrect. This is Lo Tave. Second part correct.
- B. Correct. Section 2.4 EOP background for FR-H.1.
- C. Correct. This is DNB limit (T/S 3.4.1/COLR) temperature and Feed & Bleed initiation criteria for level.
- D. Incorrect. This 100% Tave Safety Limit and Feed & Bleed initiation criteria for level.

#### Technical References: FR-H.1 Background References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	
10CFR Part 55 Content:	55.41(10) 43(13)	

Examination Outline Cross-Reference	Level	SRO
	Tier #	3
Knowledge of the basis for prioritizing safety functions during	Group #	4
abnormal/emergency operations.	K/A #	2.4.22
	Rating	4.4

The control room operators have entered EOP FR-H.1 "Response to Loss of Secondary Heat Sink," due to red path on the Heat Sink Critical Safety Function Status Tree. The Emergency Evaluation Coordinator (EEC) identifies a red path on the "Integrity" Critical Safety Function Status Tree.

The Shift Foreman should:

- A. NOTE FR-P.1 Response to Imminent Pressurized Thermal Shock Condition. Continue with FR-H.1, Fuel/Cladding Integrity is a higher priority than RCS Integrity.
- B. GO TO FR-P.1, RCS Integrity is a higher priority than Fuel/Clad Integrity.
- C. Implement FR-P.1 while continuing in FR-H.1; to minimize cooldown caused by FR-H.1 actions.
- D. Immediately return to Step 1 of FR-H.1, to reassess secondary conditions.

# Answer: A

# Explanation:

- A. Correct. FR H.1 is a higher priority than FR-P.1, higher priority CSFSTs are always continued unless a higher priority challenge is identified. Fuel and Cladding Integrity are a higher priority for protection against radiation releases..
- B. Incorrect. FR P.1 is not a higher priority FRG, it is lower. FR-P.1 actions will be addressed when FR-H.1 actions are completed.
- C. Incorrect. FR-P.1 actions are not done in parallel with FR-H.1 actions; this is not allowed per rules of usage.
- D. Incorrect. Returning to step 1 is not required when FR-P.1 conditions are met.

Х

**Technical References:** F-0 Critical Safety Functions Background Section 1.2 **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source:	Bank #
(note changes; attach	Modified Bank #

parent)

	INEW	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	
10CFR Part 55 Content:	55.41(7 and 10), 43(5) and 45(12)	

Now

NRC Form ES-401-5	June 2008 DCPP	ML091270008
Written Examination Question	Worksheet	
	SRO Question 24	
ination Outling Cross-Potoronco		

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #		3
Group #		N/A
K/A #		G 2.4.23
Importance Rating		4.4

K/A: **Generic** - Emergency Procedures/Plan: Knowledge of the bases for prioritizing emergency procedure implementation during emergency operations.

Proposed Question:

The control room operators have entered EOP FR-H.1 "Response to Loss of Secondary Heat Sink," due to red path on the Heat Sink Critical Safety Function Status Tree. The Emergency Evaluation Coordinator (EEC) identifies a red path on the "Integrity" Critical Safety Function Status Tree.

The Shift Foreman should:

- A. NOTE FR-P.1 Response to Imminent Pressurized Thermal Shock Condition. Continue with FR-H.1, Fuel/Cladding Integrity is a higher priority than RCS Integrity.
- B. GO TO FR-P.1, RCS Integrity is a higher priority than Fuel/Clad Integrity.
- C. Implement FR-P.1 while continuing in FR-H.1; to minimize cooldown caused by FR-H.1 actions.
- D. Immediately return to Step 1 of FR-H.1, to reassess secondary conditions.

Proposed Answer: A

Explanation:

- A. Answer A is correct. FR H.1 is a higher priority than FR-P.1, higher priority CSFSTs are always continued unless a higher priority challenge is identified. Fuel and Cladding Integrity are a higher priority for protection against radiation releases.
- B. Answer B is incorrect. FR P.1 is not a higher priority FRG, it is lower. FR-P.1 actions will be addressed when FR-H.1 actions are completed.
- C. Answer C is incorrect. FR-P.1 actions are not done in parallel with FR-H.1 actions; this is not allowed per rules of usage.

D. Answer D is incorrect. Returning to step 1 is not required when FR-P.1 conditions are met.

Technical Reference(s): LPE-FR, Functional Restoration Guidelines, Page 5, Rev. 8. EOP F-0, Critical Safety Function Status Trees, Page 2 & 3, Rev. 14.

Proposed references to be provided to applicants during examination: NONE

Learning Objective: 38107 - Apply the Rules of Usage in EOPs for the CSFSTs and FRGs, including: the priority of use of the six CSFSTs

Question Source: New Bank # Modified Bank # INPO - 20219 (Note changes or attach parent)

Question History: Last NRC Exam N/A Question Cognitive Level: Memory or Fundamental Knowledge Comprehension or Analysis X 10 CFR Part 55 Content: 55.41 55.43 5

10 CFR Part 55 Content: Assessment of facility conditions and selection of appropriate procedures during normal, abnormal, and emergency situations.

Comments:

After Facility Validation (pages 211 to 427) Official DRAFT Exam before formal NRC review.

Examination Outline Cross-Reference	Level	RO
Knowledge of the physical connections and/or cause-effect	Tier #	2
relationships between the RCPS (reactor Coolant Pump System)	Group #	1
and the following: CVCS	K/A #	003 K1.04
	Rating	2.6

# Question 1

Which of the following are symptoms that the #1 seal for RCP 1-4 has failed?

- A Lower #1 seal leakoff; higher VCT pressure
- B Higher #1 seal leakoff; higher VCT pressure
- C Lower #1 seal leakoff; lower VCT pressure
- D Higher #1 seal leakoff; lower VCT pressure

Proposed Answer: B (fixed justification)

# **Explanation:**

- A. Incorrect Seal leakoff flow would be high
- B. Correct No 1 seal failure cause high flow to VCT increasing pressure. PK 05-01 sends the operator to section B for number 1 seal failure if leakoff flow is high. Per AP-28, the following are listed as plant indications of a number 1 seal failure: High VCT Pressure
- C. Incorrect Both seal leakoff flow and VCT pressure would increase
- D. Incorrect VCT pressure Low is inconsistent with excessive No 1 seal leak off going into the VCT

**Technical References:** A-6, Chemical and Volume Control System, Section 2.2

OIM 6-1, Rev. 28. AR PK05-02, RCP No. 11. OP AP-28, Section B, RCP No.1 Seal Failure, section 2, Plant Indications **References to be provided to applicants during exam:** None **Learning Objective:** 35754 - Describe system interrelationships between the CVCS and other plant systems

Question Source:	Bank #	
(note changes; attach parent)	Modified Bank #	
	New	Х

<b>Question History:</b>	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (2 to 9)	

Examination Outline Cross-Reference	Level	RO
Knowledge of bus power supplies to the following: Charging	Tier #	2
Pumps.	Group #	1
	K/A #	004 K 2.03
	Rating	3.3

GIVEN:

- Unit 1 is at 100% power
- DG 1-2 is cleared for maintenance
- ECCS CCP 1-1 is off
- ECCS CCP 1-2 is running
- Normal CCP 1-3 is off

If 500 kV is lost to Auxiliary Transformer 1-2, ECCS CCP 1-2 will \_\_\_\_\_.

- A. trip. ECCS CCP 1-1 will auto start, powered from its emergency diesel generator
- B. trip. ECCS CCP 1-1 will auto start, powered from Startup Transformer 1-2.
- C. remain running, powered from Startup Transformer 1-2. ECCS CCP 1-1 remains off.
- D. remain running, powered from Startup Transformer 1-2. ECCS CCP 1-1 will auto start being powered from Startup Transformer 1-2.

# Answer: C

# **Explanation:**

- A. Incorrect Automatic transfer to Startup Transformer keeps running pump powered.
- B. Incorrect Automatic transfer to Startup Transformer running pump powered
- C. Correct Automatic transfer to Startup Transformer running pump powered and no auto start signal for standby pump is generated
- D. Incorrect –No auto start signal for standby pump is generated.

**Technical References:** B-1A, Chemical and Volume Control System, Page 2.2-6 OIM Page J-1-1, J-5-1c Rev. 28

# References to be provided to applicants during exam: None

**Learning Objective:** 4295 - Analyze automatic features and interlocks associated with the Electric Power Transfer System

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	X
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7)	

Examination Outline Cross-Reference	Level	RO
Knowledge of the effect that a loss or malfunction of the RHRS	Tier #	2
will have on the following: RCS	Group #	1
	K/A #	005 K 3.01
	Rating	3.9

GIVEN:

- The Residual Heat Removal (RHR) System has been placed in service
- 40% Steam dumps are open in MANUAL and STEAM PRESSURE mode
- CCW is aligned to both RHR heat exchangers
- RHR heat exchanger bypass valve, HCV-670 is 30% open to establish a 20°F/hour RCS cooldown rate

Which of the following events would reduce the RCS cooldown rate?

- A. Instrument air is lost to RHR heat exchanger bypass valve, HCV-670.
- B. Instrument air is lost to RHR flow control valve, HCV-637.
- C. Flow controller to RHR pump recirculation valve FCV-641A, fails high.
- D. Main Steam header pressure transmitter, PT-507, fails low.

# Answer: A

# **Explanation:**

- A. Correct HCV-670 fails open. Opening the bypass valve will divert coolant away from the HX's resulting is less cooling
- B. Incorrect HCV-637 fails open. This increases RHR flow and forces more flow through the HX's and increase the cooldown rate
- C. Incorrect FCV-641A closes if flow is high(>1398 gpm)
- D. Incorrect in Manual, steam dumps will not respond to a failure of PT-507

**Technical References:** OP B-2:V Rev. 25, section 6; LB2-RHRS, Rev. 13, page 6 of 40; OP AP-9, Loss of IA, Rev. 23, page 17 (for failure condition of HCV-637 and 670)

# References to be provided to applicants during exam: None

Learning Objective: 7050 - Discuss abnormal conditions associated with the RHR system

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
<b>IUCER Part 55 Content:</b>	<b>33.41</b> ( <i>1</i> )	

# November 2007 exam Question 31 ML 081006050

**Residual Heat Removal System:** Ability to predict and/or monitor changes in parameters (to prevent exceeding design limits) associated with operating the RHRS controls including: Heatup/cooldown rates.

Level RO SRO Tier # \_2\_\_\_ Group # \_1\_\_\_ K/A # 005 A1.01 Importance rating 3.5

Question: 31

The Residual Heat Removal (RHR) System has been placed in service to continue a cooldown to mode 5. CCW is aligned to both RHR heat exchangers. RHR heat exchanger bypass valve, HCV-670 is 30% open to establish a 20°F/hour RCS cooldown rate.

Which of the following actions or events could reduce the RCS cooldown rate?

A. HCV-670 is throttled open from 30% to 50%.

B. RHR heat exchanger bypass valve, HCV-670 is throttled closed from 30% to 10% open.

C. RHR heat exchanger #1 outlet flow control valve, HCV-638 is opened from 70% to 90%

D. Instrument air to HCV-637 is isolated.

Answer: <u>A</u>

Explanation: A is correct. Opening the bypass valve will divert coolant away from the HX's resulting is less cooling. B is incorrect since throttling closed the bypass valve will force more flow through the HX's and increase the cooldown rate. C is incorrect since opening the HX outlet valve promotes more flow through the HX. D is incorrect since loss of air to HCV-637 will cause the pneumatic valve to fail open which will promote more flow through the HX which will increase the cooldown rate.

Technical Reference(s): <u>OP B-2:V Rev. 25</u>, section 6; <u>LB2-RHRS</u>, <u>Rev. 13</u>, page 6 of 40; <u>OP AP-9</u>, Loss of IA, Rev. 23, page 17 (for failure condition of HCV-637)

Proposed references to be provided to applicants during examination: STG B-2, Fig. RHR-04\_

Learning Objective: \_\_STG B2-RHR (Section 3, Normal Ops.) obj 12, 15, & 16

Question Source Bank # \_\_\_\_\_ Modified Bank # \_\_\_\_\_ (Note changes or attach parent) New \_\_\_\_\_ XX\_\_\_\_

Question Cognitive Level: Memory or Fundamental Knowledge \_\_\_\_ Comprehension or Analysis \_\_X\_\_\_

Comments: OPEN REFERENCE : Examination Outline Cross-reference: Level RO SRO
Examination Outline Cross-Reference	Level	RO
Knowledge of the ECCS design feature(s) and/or interlocks	Tier #	2
which provide for the following: Reset of containment isolation.	Group #	1
	K/A #	006 K4.13
	Rating	3.8

Which of the following describes the minimum actions required to reset both trains of Phase A?

- A. Either Phase A reset pushbutton taken to RESET.
- B. Both Phase A reset pushbuttons taken to RESET.
- C. Both Trains of SI reset and either Phase A reset switch taken to RESET.
- D. Both Trains of P-4 actuated, both Trains of SI reset and both Phase A reset switches taken to RESET.

#### **Answer:** B **Explanation:**

- A. Incorrect Requires both trains
- B. Correct Both trains required, however, no other action is required.
- C. Incorrect SI reset is not required.

D. Incorrect –. P-4 and SI not part of the reset circuitry.

**Technical References:** B-6A, Reactor Protection System Page 2.2-18

OIM Pages B-6-5 and B-6-5-7

References to be provided to applicants during exam: None

**Learning Objective:** 37048 - Analyze automatic features and interlocks associated with the RPS

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
<b>10CFR Part 55 Content:</b>	55.41 (7)	

Examination Outline Cross-Reference	Level	RO
Knowledge of PRTS design feature(s) and/or interlock(s) which	Tier #	2
provide for the following: Quench Tank Cooling	Group #	1
	K/A #	007 K4.01
	Rating	2.6

GIVEN:

- A leaking Pressurizer PORV has been isolated by the crew
- PK05-25, PRT PRESS LVL/TEMP is in alarm due to high PRT temperature (140°F)
- PRT level (62%) and pressure (7 psig) are slowly rising

In accordance with AR PK05-25, PRT Press/Lvl/Temp, PRT temperature is lowered by

- A. Venting the PRT to the Vent Header.
- B. Filling the PRT using primary water, then draining, if required, to the RCDT.
- C. Draining the PRT to the RCDT, filling with primary water to the high level alarm, and draining again.
- D. Verifying RCS-1-PCV-472, PRT Vent to Vent Header, closes.

# Answer: B

# **Explanation:**

- A. Incorrect Plausible. The temperature is lowered by adding primary water to the PRT. Isolating the leaking PORV would prevent a further increase in the temperature.
- B. Correct In accordance with the AR PK step 2.1.6, primary water introduction is used to cool the quench volume, once quenched, the PRT is drained if level is high.
- C. Incorrect The volume is cooled first with primary water and then drained, not vice versa.
- D. This is an automatic action that occurs at 10 psig and has no effect on cooling the PRT.

Х

# Technical References: AR PK05-25

# References to be provided to applicants during exam: None

Learning Objective: 40576 - Discuss abnormal conditions associated with the PRT system

Question Source:	Bank #
(note changes; attach parent)	Modified Bank #
	New

Question History:	Last NRC Exam	NO
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7)	

Examination Outline Cross-Reference	Level	RO
Ability to predict and/or monitor changes in parameters (to	Tier #	2
prevent exceeding design limits) associated with operating the	Group #	1
CCWS controls including: CCW flow rate.	K/A #	008 A1.01
	Rating	2.8

## GIVEN:

- Unit 1 is at 100% steady-state power
- TCV-130, Letdown Heat Exchanger CCW Temperature Control valve is in Manual

Which of the following is a potential consequence of opening TCV-130 and causing a significant change in letdown temperature?

- A. A positive reactivity addition
- B. Flashing of letdown
- C. Automatic isolation of letdown to the demineralizers
- D. A negative reactivity addition

## Answer: A

## **Explanation:**

- A. Correct Cooler water tends to deposit boron atoms in the demineralizers especially at BOL (high Cb). This could cause power to go above the license limit
- B. Incorrect Letdown flashing occurs at the outlet of the Regen heat exchanger as a result of letdown flow much higher than charging flow.
- C. Incorrect demin bypass occurs at high temperature, this would not be the case if TCV-130 was opened (temperature would decrease).
- D. Incorrect Lower temperature causes positive, not negative reactivity addition, higher temperature could cause negative reactivity.

**Technical References:** OP B-1ALXII, precautions and limitations, step 6.1. OP1.ID3 step 5.2.4 rev 5

## References to be provided to applicants during exam: None

**Learning Objective:** 5346 - Discuss significant precautions and limitations associated with the ASW system

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7)	

BANKED - from November 2007 exam Question 34 ML 081006050

Level RO SRO Tier # \_2\_\_\_ Group # \_1\_\_ K/A # <u>008 A1.01</u> Importance rating <u>2.8</u>

**Component Cooling Water:** Ability to predict and/or monitor changes in parameters (to prevent exceeding design limits) associated with operating the CCWS controls including: CCW flow rate.

Question: 34

Unit 1 is at 100% steady-state power, with all systems and equipment operable and in the proper full power alignment.

Which of the following is a potential consequence of placing a second ASW/CCW train in service?

- A. The colder letdown water exiting the letdown heat exchanger could result in a positive reactivity addition.
- B. Spent fuel pool over-cooling could result in a positive reactivity addition large enough to challenge the minimum Keff requirement.
- C. RCP thermal barrier return CCW flow could isolate on high flow, which will necessitate prompt action to trip the reactor and all RCPs.
- D. The Seal Water Heat Exchanger, by over-cooling the RCP seal injection water, could change seal tolerances enough to affect the amount of seal leakage.

Answer: <u>A</u>

Explanation: A is correct because cooler water tends to deposit boron atoms in the demineralizers, especially at BOL (high Cb). This could cause power to go above the license limit. B is incorrect as SFP boron concentration satisfies minimum SDM requirement. The statement in answer C that TB return valve may close is correct, but the requirement to tip the Rx and RCPs would only apply if seal injection was lost also. D is incorrect since the SWHX

function is to cool seal leakoff flow, not injection flow. The amount of seal leak-off flow that may be over-cooled is insignificant compared to the volume in the VCT, thus seal injection temperature should not change significantly.

## Technical Reference(s): <u>Reactor Theory; Components (demineralizers) GFE program; STG B1A, Rev.</u> <u>15, page 3-2</u>

Proposed references to be provided to applicants during examination: <u>None</u>

Learning Objective: STG F2-CCW, Rev 15 Obj. 13, 17

Question Source Bank # \_\_\_\_\_ Modified Bank # \_\_\_\_\_ (Note changes or attach parent) New \_\_\_\_\_XX\_\_\_

Question Cognitive Level: Memory or Fundamental Knowledge \_\_\_\_ Comprehension or Analysis \_\_X\_\_

Examination Outline Cross-Reference	Level	RO
Knowledge of the effect of a loss or malfunction of the following	Tier #	2
will have on the PZR PCS: PZR Sprays and Heaters.	Group #	1
	K/A #	010 K6.03
	Rating	3.2

GIVEN:

- Unit 1 is at 100% power
- Two of the backup heater groups were manually placed in the "ON" position one hour ago for RCS mixing

Spray valve PCV-455A fails full open.

Which of the following sequences of events will occur?

- A. PCV-455B spray valve closes, pressurizer heaters energize, pressure lowers below PORV low pressure interlock setpoint, Reactor trips.
- B. PCV-455B spray valve closes, pressure lowers below PORV low pressure interlock setpoint, pressurizer heaters energize, Reactor trips.
- C. No change in position of the spray valve PCV-455B, pressurizer heaters energize, Reactor trips, pressure lowers below PORV low pressure interlock setpoint.
- D. No change in position of the spray valve PCV-455B, pressurizer heaters energize, pressure lowers below PORV low pressure interlock setpoint, Reactor trips.

# Answer: A

# **Explanation:**

- A. Correct Both spray valves should initially be open. Due to the integral nature of the PZR pressure master controller, a short time after the backup heater group was energized, the spray valves should have opened and will be the first pressure control component to respond (valve close) as PZR pressure decreases.
- B. Incorrect heaters energize before the PORV interlock is reached
- C. Incorrect the spray valve functioning spray valve is not addressed
- D. Correct the spray valve functioning spray valve is not addressed

Technical References: STG A4A, Rev. 14, page 22-8, OIM A-4-6, Rev. 26

#### References to be provided to applicants during exam: None

**Learning Objective:** 36926 - Discuss abnormal conditions associated with the Pzr, Pzr Pressure and Level Control System

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7)	

MODIFIED - from November 2007 exam Question 31 ML 081006050

RO SRO Tier # \_2\_\_\_ **Pressurizer Pressure Control:** Ability to monitor automatic operation of the PZR PCS, including: PZR pressure.

Group # \_1\_\_\_ K/A # <u>010 A3.02</u> Importance rating <u>3.6</u>\_

Question: 36

Unit 1 is at stable 22% power with all RCS control circuits in automatic except for one of the backup heater groups, which was manually placed in the "ON" position one hour ago for RCS mixing. A small leak develops in the RCS causing pressurizer pressure to slowly decrease.

Which of the following sequences of actions will occur as RCS pressure decreases with no operator actions?

- A. The open spray valves close, pressurizer heaters energize, PORV interlock removed, Reactor trips, SIS.
- B. The open spray valves close, PORV interlock removed, pressurizer heaters energize, Reactor trips, SIS.
- C. No change in position of the spray valves, pressurizer heaters energize, Reactor trips, PORV interlock removed, SIS.
- D. No change in position of the spray valves, pressurizer heaters energize, PORV interlock removed, Reactor trips, SIS.

Answer: <u>A</u>

Explanation: One spray valve should initially be open. Due to the integral nature of the PZR pressure master controller, a short time after the backup heater group was turned on, a spray valve should have opened and will be the first pressure control component to respond (valve close) as PZR pressure decreases. Answer A is correct. B is incorrect since the heaters energize before the PORV interlock is removed. Answers C and D are incorrect since neither addresses the spray valve.

Technical Reference(s): STG A4A, Rev. 14, page 22-8, OIM A-4-6, Rev. 26

Proposed references to be provided to applicants during examination: <u>None</u>

Learning Objective: \_\_ STG A4A-PP&LCS, Rev. 14, Obj 13, 22

Question Source Bank # \_\_\_\_\_ Modified Bank # \_\_\_\_\_ (Note changes or attach parent) New \_\_\_\_\_XX\_\_\_

Question Cognitive Level: Memory or Fundamental Knowledge \_\_ Comprehension or Analysis X

Comments

Examination Outline Cross-Reference	Level	RO
Knowledge of the operational impact of the following concepts as	Tier #	2
they apply to the PZR PCS: Determination of condition of fluid	Group #	1
in PZR, using steam tables.	K/A #	010 K5.01
	Rating	3.5

GIVEN:

- Unit 1 is in MODE 5
- RHR is in service with RCS loop temperatures at 95°F
- Pressurizer level is 70% cold cal
- Pressurizer pressure is 3.5 psia
- Vacuum refill skid pump is shut down
- Pressurizer heaters are energized

At what pressurizer liquid temperature will bubble formation start in the pressurizer?

- A. 140°F
- B. 144°F
- C. 148°F
- D. 152°F

Answer: C Step 6.1.1.a.3 of OP A-2:IX has RCS temp at 95F.

# Explanation:

- A. Incorrect –
- B. Incorrect -
- C. Correct Tsat for 3.5 psia is 148°F
- D. Incorrect.

**Technical References: steam tables References to be provided to applicants during exam:** Steam Tables **Learning Objective:** 40738 - Apply fundamentals topics associated with the Pzr, Pzr Pressure and Level Control System

**Question Source:** 

(note changes; attach parent)	Modified Bank # New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (5)	

BANK- from October 2002 exam Question 31 ML 023220665

Proposed Question # 11 :

Unit 1 is in mode 5 with the following plant conditions:

RHR in service with RCS loop temperatures at 115 F.

\_\_Pressurizer level at 70% cold cal.

Pressurizer pressure at 3.5 psia.

Vacuum refill skid pump shut down.

Pressurizer heaters energized.

What will be the pressurizer liquid temperature when the bubble starts forming in the pressurizer?

A 140\_F

B 144\_F

C 148\_F

D 152\_F

Proposed Answer: C

Explanation:

Technical Reference(s): OP A-2:IX page 19 Steam Tables

Proposed references to be provided to applicants during examination: Steam Tables

Learning Objective: 4551 Explain operational characteristics of Pressurizer.

Question Source: Bank # New X

Examination Outline Cross-Reference	Level	RO
Ability to (a) predict the impacts of the following malfunctions or	Tier #	1
operations on the RPS; and (b) based on those predictions, use	Group #	1
procedures to correct, control or mitigate the consequences of	K/A #	012 A2.06
those malfunctions or operations: Failure of RPS to trip the	Rating	4.4
reactor.		

GIVEN:

- Unit 2 was at 100% power.
- A Spurious Safety Injection occurs.
- The reactor <u>fails</u> to trip.

Which of the following describes the response of the Reactor Protection System and the Function Restoration Procedure that should be used to mitigate the consequences?

- A. RPS will not automatically trip the main turbine. FR-S.1 is used to insert negative reactivity.
- B. RPS will not automatically trip the main turbine. FR-C.1 is used to establish effective core cooling.
- C. RPS will automatically trip the main turbine. FR-S.1 is used to insert negative reactivity.
- D. RPS will automatically trip the main turbine.FR-C.1 is used to establish effective core cooling.

## Answer: C

## **Explanation:**

- A. Incorrect The turbine is tripped by SI, but P-4 is not generated. FR-S.1 is used.
- B. Incorrect the turbine is tripped, and FR-C.1 is not used.
- C. Correct ECCS systems are designed to remove decay heat. FR-S.1 is the highest priority RED Path. The turbine is tripped by the SI signal, but P-4 is not generated.
- D. Incorrect The turbine is tripped, and P-4 is not generated. FR-C.1 is not used.

**Technical References:** OPS-Lesson Plan LMCDFRS Obj 4 OIM C-3-5 **References to be provided to applicants during exam:** None **Learning Objective:** 37048 - Analyze automatic features and interlocks associated with the RPS 9704 - Identify entry conditions for the FRPs

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (5)	

Examination Outline Cross-Reference	Level	RO
Knowledge of the effect that a loss or malfunction of the ESFAS	Tier #	2
will have on the following: Fuel.	Group #	1
	K/A #	013 K3.01
	Rating	4.4

GIVEN:

- Unit 1 was at 100% power
- A reactor trip occurs due to a loss of all feedwater
- Auxiliary Feedwater (AFW) fails to actuate

Which of the following is the likely consequence of the AFW failure if no action is taken?

- A. Core uncovery and overheating.
- B. RCS pressure exceeding design pressure.
- C. Return to criticality.
- D. Multiple Steam Generator U-tube failures.

# Answer: A

# **Explanation:**

- A. Correct From FR-H.1 background, without operator action, once the secondary is lost as a heat sink, the RCS will heat up to saturation, boil off and result in core uncovery and damage.
- B. Incorrect Plausible if assuming the temperature increase would cause a large enough pressure increase to threaten RCS integrity
- C. Incorrect Core boil off is correct.
- D. Incorrect Steam generator dryout is possible

**Technical References:** FR-H.1, background **References to be provided to applicants during exam:** None **Learning Objective:** 11319 - Describe the loss of feedwater event leading to core damage.

Х

Question Source:	Bank #
(note changes; attach parent)	Modified Bank #

Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	x
10CFR Part 55 Content:	55.41 (7)	

## BANK April 2007 Draft ML 072400068

#### **RO** Question 39

The plant trips from full power due to a loss of feedwater. AFW fails to actuate. Without operator action, which of the following is the likely consequence of the AFW failure?

A. Core uncovery and overheating.

B. RCS pressure exceeding design pressure.

C. Return to criticality due to core boil off causing a loss of boron inventory.

D. Steam Generator dryout and tube damage from excessive steam generator pressure.

Proposed Answer:

A. Core uncovery and overheating.

Explanation:

A correct. From FR-H.1 background, without operator action, once the secondary is lost as a heat sink, the RCS will heat up to saturation, boil off and result in core uncovery and damage.

Technical Reference(s): FR-H.1, background

Proposed references to be provided to applicants during examination: None

Learning Objective: 11319 Describe the loss of feedwater event leading to core damage. Question Source:

Bank modified M-0068

Question History: N/A

Question Cognitive Level:

Memory or Fundamental Knowledge X

Comprehension or Analysis

10 CFR Part 55 Content: 55.41.7 - Design, components, and function of control and safety systems, including instrumentation, signals, interlocks, failure modes, and automatic and manual features.

Comments: No changes from initial submittal.

K/A: 013 K3.01 - Knowledge of the effect that a loss or malfunction of the ESFAS will have on the following: Fuel (4.4/4.7)

Examination Outline Cross-Reference	Level	RO
Ability to monitor automatic operation of the ESFAS including:	Tier #	2
Inputs and logic.	Group #	1
	K/A #	013 A3.01
	Rating	3.7

GIVEN:

- A plant shutdown in accordance with OP L-5, Plant Shutdown From Minimum Load to Cold Shutdown, is in progress
- Unit 1 is at 7% reactor power
- The Main Turbine has been MANUALLY tripped as part of the normal shutdown

What will be the status of the following permissive alarms?

- PK08-02, Low Power Permissive P-7 (white)
- PK08-05, Power Range at Power Permissive P-10 (yellow)
- PK08-08, Turbine Low Power Permissive P-13 (white)
- A. PK08-02 is clear, PK08-05 and PK08-08 are lit.
- B. PK08-05 is clear, PK08-02 and PK08-08 are lit.
- C. PK08-08 is clear, PK08-02 and PK08-05 are lit.
- D. Both PK08-08 and PK08-02 are clear, PK08-05 is lit.

## Answer: B Detailed knowledge of PK's

B is the correct answer

## **Explanation:**

- A. Incorrect Below 10%, PK08-02 and PK08-08 are on (off at power).
- B. Correct -05 will be out.
- C. Incorrect -08 will be lit
- D. Incorrect -08 and 02 will be lit

## **Technical References OIM B-6-2**

## References to be provided to applicants during exam: None

**Learning Objective:** 37049 - Describe controls, indications, and alarms associated with the RPS

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	X
Question History:	Last NRC Exam	No

Question Cognitive Level:	
10CFR Part 55 Content:	

Memory/Fundamental Comprehensive/Analysis 55.41 (7)

Examination Outline Cross-Reference	Level	RO
Ability to manually operate and/or monitor in the control room:	Tier #	2
Containment reading of temperature, pressure, and humidity	Group #	1
system.	K/A #	022 A4.05
	Rating	3.1

#### Question 12

Containment average temperature is reading abnormally high due to one of the selected containment area temperature elements failing high

Containment average temperature can be read in the Control Room at \_\_\_\_\_; and the faulty temperature element can be removed from the average calculation \_\_\_\_\_.

- A. TI-26 (Containment Area TM Panel); on the Plant Process Computer
- B. YR-26 (Containment Average Temperature); on the Plant Process Computer
- C. TI-26 (Containment Area TM Panel); at TI-26
- D. YR-26 (Containment Average Temperature); at TI-26

## Answer: D

#### **Explanation:**

- A. Incorrect. Both parts incorrect.
- B. Incorrect. First part is correct.
- C. Incorrect. Second part is correct
- D. Correct. YR-26 is located in the control room. The elements can be deselected locally at TI-26 which is outside the control room.

## **Technical References: LH-11**

#### References to be provided to applicants during exam: None

**Learning Objective:** 37589 - Describe controls, indications, and alarms associated with the Containment Structure

Question Source:	Bank #	
(note changes; attach parent)	Modified Bank #	
	New	Х

Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	X
10CFR Part 55 Content:	55.41 (7)	

Examination Outline Cross-Reference	Level	RO
Knowledge of CSS design features and/or interlocks which	Tier #	2
provide for the following: Iodine scavenging via the CSS	Group #	1
	K/A #	026 K4.06
	Rating	2.8

Which of the following describes how the sufficient amount of Sodium Hydroxide (NaOH) is assumed to be delivered to the Containment Sump?

NOTE: CS-8994A and CS-8994B are Spray Additive Tank Outlet to Eductor valves

- A. Either CS-8994A OR CS-8994B must open to provide sufficient flow of NAOH to the suction of the Containment Spray pumps. Proper NaOH volume is assured by running the Containment Spray pumps until Low-Low RWST level (4%).
- B. Both CS-8994A AND CS-8994B must open to provide sufficient flow of NAOH to the suction of the Containment Spray pumps. Proper NaOH volume is assured by running the Containment Spray pumps until Low-Low RWST level (4%).
- C. Either CS-8994A OR CS-8994B must open to provide sufficient flow of NAOH to the suction of the Containment Spray pumps. Proper NaOH volume is assured by running the Containment Spray pumps until Low RWST level (33%).
- D. Both CS-8994A AND CS-8994B must open to provide sufficient flow of NAOH to the suction of the Containment Spray pumps. Proper NaOH volume is assured by running the Containment Spray pumps until Low RWST level (33%).

Proposed Answer: A

Explanation:

- A Correct: Either train is 100% capacity. Pumps run until the Low-Low Level (4%) is reached.
- B Incorrect: Either train is 100% capacity.
- C Incorrect: Pumps continue to at RWST low level (33%) until the Low-Low Level (4%) is reached.

D Incorrect: Pumps are secured at RWST Low-Low (4%), either train is 100% capacity. **Technical References** STG I-2 page 1-4 and 3-10.

## References to be provided to applicants during exam: None

**Learning Objective:** 40802 - Explain significant CSS design features and the importance to nuclear safety

Question Source: (note changes; attach parent)	Bank # Modified Bank #	
attach parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	Х
10CFR Part 55 Content.	Comprehensive/Analysis	

**10CFR Part 55 Content:** 55.41 (7) Note, modified distractor D for balance, modified second part of answers to inidicate pumps run until an RWST level is reached (not tripped...) rnf5, 9/8/09

Examination Outline Cross-Reference	Level	RO
Ability to determine operability and/or availability of safety	Tier #	2
related equipment	Group #	1
	K/A #	026 G2.2.37
	Rating	3.6

Which of the following is the required line up for a properly filled and OPERABLE Containment Spray System?

- A. SI-246 (RWST Supply to Containment Spray) closed; CS-9001A and B (Spray Pump Discharge Valves) open with power removed.
- B. SI-246 RWST Supply to Containment Spray) sealed open; CS-9001A and B (Spray Pump Discharge Valves) closed and ready to auto open.
- C. SI-246 (RWST Supply to Containment Spray) closed; CS-9001A and B (Spray Pump Discharge Valves) closed and ready to auto open.
- D. SI-246 (RWST Supply to Containment Spray) sealed open; CS-9001A and B (Spray Pump Discharge Valves) open with power removed.

Proposed Answer: B Explanation:

- A Incorrect: This prevents filling the discharge header downstream of 9001A/B, but system will not automatically perform it function.
- B Correct: Discharge valve are closed to prevent filling the discharge header while valve SI-246 is sealed open.
- C Incorrect: System will not automatically perform it function.
- D Incorrect: The discharge will be filled.

**Technical References:** STG I-2 page 3-1 Procedure OP I-2:I "Containment Spray System -Make Available". **References to be provided to applicants during exam:** None **Learning Objective:** 40805 - Describe the operation of the CSS

Question Source:	Bank #	
(note changes; attach parent)	Modified Bank #	
	New	Х
Question History:	Last NRC Exam	No

Question Cognitive Level:	Memory/Fundamental
	Comprehensive/Analysis
10CFR Part 55 Content:	55.41 (7)

Examination Outline Cross-Reference	Level	RO
Knowledge of the purpose and function of major system	Tier #	2
components and controls	Group #	1
	K/A #	039 G2.1.28
This is a main steam ka, are you ok with the question dealing	Rating	4.1
with a turbine (045) subject?		

What is the function of the Turbine Overspeed Protection Circuit (OPC)?

- A. Closes the reheat stop valves and extraction non-return valves <u>permanently</u> to prevent turbine overspeed following a turbine trip.
- B. Closes the reheat stop valves and extraction non-return valves <u>momentarily</u> to prevent turbine overspeed following a turbine trip.
- C. Closes the governor valves and intercept valves <u>permanently</u> to prevent turbine overspeed following a complete loss of electrical load.
- D. Closes the governor valves and intercept valves <u>momentarily</u> to prevent turbine overspeed following a complete loss of electrical load.

## Proposed Answer: D

#### **Explanation:**

- A Incorrect: These valves do close on a turbine trip but due to either low PCV-23 or SV-40.
- B Incorrect: the OPC does not control these valves.
- C Incorrect: Valve close momentarily.
- D Correct: The OPC circuit momentarily closes the governor and intercept valve at 103% but allows reopening when speed is less than 101% following a complete loss of electrical load.

Technical References: STG C-3b page 2.1-28, C3C, page 2-44. OIM C-3-4 References to be provided to applicants during exam: None Learning Objective: 41077 - Discuss abnormal conditions associated with the Turbine Control Oil System Question Source: Bank #

lestion Source:	Bank #
(note changes; attach parent)	Modified Bank #

	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	Х
10CED Part 55 Contant:	Comprehensive/Analysis	
IUCFK Fart 55 Content:	33.41(7)	

Note: added overspeed to B and D, and OPC to question. Rnf5, 9/8/09

Examination Outline Cross-Reference	Level	RO
Knowledge of the physical connections and/or cause effect	Tier #	2
relationships between the MRSS and the following systems: S/G	Group #	1
	K/A #	039 K1.01
	Rating	3.1

## **Question 16**

GIVEN:

- Unit 1 is at 100% power
- Reheat Steam to one Moisture Separator Reheater (MSR) is isolated
- All systems operating normally in automatic control

The SFM has directed the CO to lower Unit Load to 98% in preparation for restoring HP reheat steam.

The reason for this power reduction is to avoid which of the following as HP Reheat is restored?

- A. Lifting the MSR relief valves.
- B. Water hammer.
- C. An overpower condition.
- D. Excessive thermal stress.

#### Proposed Answer: C Explanation:

A Incorrect: Pressure changes are minimized by the RAMP open feature (modulate open at 75°/hour rate)

B Incorrect: Procedure has been written to limit or prevent water hammer (discussion item 2.2

C Correct: Increasing Main Steam flow will drop S/G pressure and cause a RCS

cooldown. With a negative MTC, power will increase.

D Incorrect: Thermal stresses are minimized by the RAMP open feature (modulate open at 75°/hour rate)

**Technical References:** STG C5 OP-C-5:II step 6.5.2 and precaution & limitation 5.8.1 **References to be provided to applicants during exam:** None

**Learning Objective:** 3409 - Discuss significant precautions and limitations associated with the MSRs

Question Source: (note changes: attach parent)	Bank # Modified Bank #	
(	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (2 to 9)	
Removed redundant wording (avoid) from	m each answer and moved	
it into the avertion Morred avertion to a	tand along from the astron	

it into the question. Moved question to stand alone from the setup. Rnf5, 9/8/09

Examination Outline Cross-Reference	Level	RO
Ability to manually operate and monitor in the control room:	Tier #	2
<b>Recovery from automatic feedwater isolation</b>	Group #	1
	K/A #	059 A4.11
	Rating	3.1

The plant experienced a reactor trip and Safety Injection (SI) from 100% power.

What actions must be taken before the Main Feedwater Regulating and Bypass valves can be opened?

- A. Reset SI signal, cycle the Reactor trip breakers, reset Feedwater Isolation.
- B. Reset SI signal, cycle the Reactor trip breakers only.
- C. Cycle the Reactor trip breakers, reset Feedwater Isolation only.
- D. Reset Feedwater Isolation only.

# Proposed Answer: A **Explanation:**

- A. Correct. The sealin for P-4 and SI must be removed, then FWI reset.
- B. In correct. Feedwater Isolation must be reset.
- C. Incorrect. SI must be reset.
- D. Incorrect. Both the P-4 and SI seal-in must be removed.

**Technical References** OIM, Feedwater Isolation Signals, Page B-6-12, Rev. 28 **References to be provided to applicants during exam:** None **Learning Objective:** 37048 - Analyze automatic features and interlocks associated with the RPS

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	X A-0730
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	

#### **10CFR Part 55 Content:**

The plant experienced a reactor trip and SI from 100% power. All systems responded as expected for the transient. What actions must be taken before the feedwater control valves can be opened?

- A. Reset SI signal, cycle the Reactor trip breakers, reset Feedwater Isolation.
- B. Reset SI, heat up RCS above low Tavg setpoint, reset Feedwater Isolation.
- C. Cycle the Reactor trip breakers, reset Feedwater Isolation.
- D. Reset Feedwater Isolation.

Answer: A

## ASSOCIATED INFORMATION:

#### Associated objective(s):

37614	Analyze automatic features and interlocks associated with the
	MFW system

Reference Id: A-0730

Examination Outline Cross-Reference	Level	RO
Knowledge of the effect of a loss or malfunction of the following	Tier #	2
will have on AFW components: Pumps	Group #	1
	K/A #	061 K6.02
	Rating	2.6

Unit 2 was at 100% power when a Reactor Trip occurred.

Motor Driven AFW Pump 2-3 immediately trips.

As a result of the pump trip, Steam Generator AFW Supply Valves, LCV-115 and LCV-113 will:

- A. Close but then reopen to provide runout protection.
- B. Open but then close as Turbine Driven AFW pump restores level.
- C. Open and remain open due to the pump trip.
- D. Throttle and remain throttled due to loss of flow input to the circuitry.

## Proposed Answer: C Explanation:

- A. Incorrect. Upon the pump trip, the EH pump loses power, the solenoid relief valves fail open, and the loss of EH pressure causes the valves to fail open.
- B. Incorrect. Valve will close as level rises if MDAFWP not tripped.
- C. Correct. Removal of the pump breaker signal causes the valves to fail open.
- D. Incorrect. The valves fail open.

**Technical References** Ops lesson LD-1, Page 29 of 39, Rev. 12 **References to be provided to applicants during exam:** None **Learning Objective:** 37635- Describe controls, indications, and alarms associated with the Auxiliary Feedwater System.

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No

**Question Cognitive Level:** 

**10CFR Part 55 Content:** 

#### MODIFIED from RO Question 46 ML082830427

#### **RO** Question 46

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #	2	
Group #	1	
K/A #	061/K3.02	
Importance Rating	4.2	4.4

K/A: **Auxiliary / Emergency Feedwater (AFW) System -** Knowledge of the effect that a loss or malfunction of the AFW System will have on the following: S/G.

Proposed Question:

Given the following conditions:

Unit 2 was at 100% power when a Reactor Trip occurred.

PT-434, AFW pump 2-3 discharge pressure transmitter has failed to zero.

What effect will this failure have on LCV-115 and LCV-113, AFW supply valves to Steam generators 2-3 and 2-4?

The LCVs will fail:

- A. Closed, and must be taken to manual to restore control.
- B. Open, and must be taken to manual to restore control.
- C. Open, AFW pump 2-3 must be secured to stop flow.
- D. As is, and must be locally operated.

Proposed Answer: A

Х

Explanation:

Answer A is correct. This input is used as run-out protection. Discharge pressure transmitter failing to zero will cause the LCVs to go closed on low pump discharge pressure. Manual control is available from the controller.

Answer B is incorrect. Valves will not fail open, they will fail closed.

Answer C is incorrect. Valves will not fail open, they will fail closed. There is no requirement to stop the pumps.

Answer D is incorrect. Valves will not fail as is; this is true of the turbine driven AFW pump LCVs.

Technical Reference(s)	ED-1, Auxiliary Feedwater System, Page 29 & 30, Rev11.
Proposed references to	be provided to applicants during examination: <u>NONE</u>
Learning Objective:	37635- Describe controls, indications, and alarms associated with the Auxiliary Feedwater System.
Question Source:	Bank # Modified Bank # A-0692 (Note changes or attach parent) New
Question History:	Last NRC Exam N/A
Question Cognitive Le	vel: Memory or Fundamental Knowledge Comprehension or Analysis X
10 CFR Part 55 Conter	t: $55.41   7   55.43     7$
10 CFR Part 55 Conter	nt: Design, components, and function of control and safety systems, including instrumentation, signals, interlocks, failure modes and automatic and manual features.

Examination Outline Cross-Reference	Level	RO
Ability to monitor automatic operation of the AFW including:	Tier #	2
AFW startup and flow.	Group #	1
	K/A #	061 A3.01
	Rating	

GIVEN:

- A Unit 1 plant startup is in progress per OP L-3, Secondary Plant Startup
- The reactor is at 9% power with a Main Feedwater Pump in service

While rolling the Main Turbine, S/G level control malfunctions which results in S/G 1-2 level exceeding 90%. All other steam generator levels are on program.

Which of the following automatic AFW pump starts, if any, will occur?

- A. None.
- B. Both motor driven AFW pumps will immediately start.
- C. All AFW pumps will immediately start.
- D. All AFW pumps will start following a time delay.

## Answer: B Explanation:

- A. Incorrect. Although steam generator levels are not low, the AFW pumps (MDAFW) will start due to the trip of the MFW pumps.
- B. Correct. Steam Generator Level > 90% is P-14. This Trips both Main feed Pumps resulting in an immediate start signal to Motor Driven pumps only.
- C. Incorrect. Only the Motor Driven AFW pumps start on Trip of Main Feed Pumps.
- D. Incorrect. Only the Motor Driven AFW pumps start on Trip of Main Feed Pumps. A time delay is only associated with the low-low steam generator start signal below 50% power

**Technical References** OIM B-6-2, STG-D1 page 2-9 & 27 **References to be provided to applicants during exam:** None **Learning Objective:** 37637 - Analyze automatic features and interlocks associated with the AFW system

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Requal A-0687
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7)	
Note: Broke out question from setup, cha occur, added procedure name. Change to generator to match initial conditions. Rnf.	nged "should" to "will" 1-2 from 2-2 steam 5 09/08/09	

#### Diablo 2002 Exam ML 023220665 ES-401 RO & SRO Written Examination Form ES-401-6

<u>Question Worksheet</u> Examination Outline Cross-reference: Level RO SRO

> Tier # 2 Group # 1 K/A # 061.**A3.01** Importance Rating 4.2/ 4.2

System: 061 Auxiliary / Emergency Feedwater (AFW) System A3 Ability to monitor automatic operation of the AFW, including: A3.01 AFW startup and flows. Proposed Question # 46 A plant startup is in progress per OP L-3.

The reactor is at 9% power with Main Feedwater Pump in service. While rolling the Main Turbine, S/G level control malfunctions result in S/G 2-2 level exceeding 75%.

Which of the following automatic actions would occur?

A Both motor driven AFW pumps will start following a time delay.

B Both motor driven AFW pumps will immediately start.

C All AFW pumps will immediately start.

D All AFW pumps will start following a time delay.

Proposed Answer: B Explanation: Technical Reference(s): OIM page B-6-2 STG D-1 page 2-9 Proposed references to be provided to applicants during examination: NONE Learning Objective: 8432 Analyze AFW pump control logic. Question Source: Bank # A-0687 Modified Bank # New Question History: Last NRC Exam Question Cognitive Level: Memory or Fundamental Knowledge Comprehension or Analysis X 10 CFR Part 55 Content: 55.41 7 55.43

Examination Outline Cross-Reference	Level	RO
Ability to (a) predict the impacts of the following malfunctions or	Tier #	2
operations on the ac distribution system; and (b) based on those	Group #	1
predictions, use procedures to correct, control or mitigate the	K/A #	062 A2.09
consequences of those malfunctions or operations: Consequences	Rating	2.7
of exceeding current limitations.		

GIVEN:

- Unit 1 is at 100% power
- Unit 2 is in MODE 5 on Startup power
- D/G 2-2 is out of service for maintenance

A line fault occurs on 230kV Switchyard causing a loss of power to Startup Transformers 1-1 and 2-1.

What is the impact on each Unit's 4kV vital system and what procedure would be used to mitigate the consequences?

- A. No effect on Unit 1. Unit 2 Vital 4kV Bus G is de-energized causing entry into OP-SD-0, "Loss of, or Inadequate Decay heat Removal".
- B. No effect on Unit 1. Unit 2 Vital 4kV Bus H is de-energized causing entry into OP-SD-1, "Loss of AC Power".
- C. Unit 1 Vital 4kV buses are energized from their respective Diesel Generators. Unit 2 Vital 4kV Bus H is de-energized causing entry into OP-SD-0, "Loss of, or Inadequate Decay Heat Removal".
- D. Unit 1 Vital 4kV buses are energized from their respective Diesel Generators. Unit 2 Vital 4kV Bus G is de-energized causing entry into OP-SD-1, "Loss of AC Power".

## Proposed Answer: B Explanation:

- A. Incorrect. Normal power to Unit 1 4kV buses is the Auxiliary Transformer, but OP-SD-0 will direct operator to OP-SD-1 Loss of Power. Restoring power will restore decay heat removal.
- B. Correct. Normal power to Unit 1 4kV buses is the Auxiliary Transformer. OP-SD-1 Loss of Power is highest priority. Restoring power will restore decay heat removal.

- C. Incorrect. Normal power to Unit 1 4kV buses is the Auxiliary Transformer. OP-SD-0 will direct operator to OP-SD-1 Loss of Power. Restoring power will restore decay heat removal.
- D. Incorrect. . Normal power to Unit 1 4kV buses is the Auxiliary Transformer, but OP-SD-1 is correct.

**Technical References:** OIM, Electrical Distribution Overview, Page J-1-1, Rev. 28, LER 2007-001-00 STG J-6A & 6B

**References to be provided to applicants during exam:** None **Learning Objective:** 41081 Discuss abnormal conditions associated with the 4VV System

Learning Objective: 41081 - Discuss abnormal conditions associated with the 4KV System

Question Source: (note changes; attach parent)	Bank # Modified Bank #	
	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	
	Comprehensive/Analysis	Х
<b>10CFR Part 55 Content:</b>	55.41 (5)	
Note: separated problem from setup. Rnf.	5 09/08/09	

Examination Outline Cross-Reference	Level	RO
Ability to predict and/or monitor change in parameters	Tier #	2
associated with operating the DC electrical system controls	Group #	1
including: Battery capacity as it is affected by discharge rate	K/A #	063 A1.01
	Rating	2.5

A battery is supplying its Vital DC bus.

Which of the following would be an indication in the Control Room that there is a heavy load on the Vital 125 VDC battery?

- A. No initial change in voltage but a decrease over time.
- B. An initial drop in voltage with a slow return to normal.
- C. An initial drop in voltage with a gradual decrease over time.
- D. An initial increase in voltage with a gradual decrease over time.

# Answer: C

## **Explanation:**

- A. Incorrect. the large load will initially cause voltage to drop.
- B. Incorrect. Voltage will drop, if load is removed, voltage may recover, but not if it continues to be applied.
- C. Correct. As a cell discharges, lead sulfate precipitates out of solution onto both positive and negative plates. This causes the plates to clog. As the plates clog, the effective surface area of the plates is rapidly reduced. Since the effective surface area of the plates determines the maximum reaction rate, it will be limited and the total battery voltage will begin to drop. On a loss of all AC power, when the battery has a high load, the voltage drops at a rapid rate immediately, then at a slower rate as time progresses. Voltage, then, is a fair estimate of a battery's condition at any one time under load, and the Control Room Operators may use voltage as a good approximation of battery capacity.
- D. Incorrect. Voltage initially decreases

# Technical References: STG-J9 and T/S 3.8.6 basis

References to be provided to applicants during exam: None

**Learning Objective:** 10975 - STATE what happens to the lead terminals and the sulfuric acid during battery use under load.

10976 - STATE how each of the following may be used as an indicator of battery condition during battery loading:

- a. Specific gravity of the electrolyte
- b. Battery voltage

c. Battery capacity

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	X (F-2879)
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х
<b>10CFR Part 55 Content:</b>	55.41 (5)	

Which of the following would be an indication of a heavy load being placed on a lead-acid battery?

- A. An initial drop in voltage with a gradual decrease over time.
- B. An initial drop in voltage with a slow return to normal.
- C. An initial increase in voltage with a gradual decrease over time.
- D. No initial change in voltage but a decrease over time.
- Answer: A

#### ASSOCIATED INFORMATION:

#### Associated objective(s):

10975	STATE what happens to the lead terminals and the sulfuric acid
	during battery use under load.
10976	STATE how each of the following may be used as an indicator of
	battery condition during battery loading:
	a. Specific gravity of the electrolyte
	b. Battery voltage
	c. Battery capacity

Reference Id: F-2879
Examination Outline Cross-Reference	Level	RO
Knowledge of the effect of a loss or malfunction of the following	Tier #	2
will have on the EDG system: Air Receivers	Group #	1
	K/A #	K6.07
	Rating	2.7

GIVEN:

- Unit 1 is at 100%
- A relief valve has failed open on Diesel Generator (DG) 1-1 Starting Air Receiver 1-1A
- The leakage exceeds the capacity of the starting air compressor and the 1-1A Starting Air Receiver is depressurized

Which of the following describes the affect of this failure on DG 1-1, if a start signal occurs prior to any operator action?

- A. Start in the normal allowed time with air from the 1-1B Starting Air Receiver via all four starting air solenoids.
- B. Will start, however, starting time will exceed the surveillance required response time.
- C. Start in the normal allowed time with air from the 1-1B Starting Air ReceiverReceiver via the two starting air solenoids associated with the 1-1B Starting Air Receiver.
- D. Will not start because the starting air system will be depressurized.

# Proposed Answer: C

# Explanation:

- A. Incorrect. Diesel will start in normal time, but the start will be with only 2 of the 4 starting motors.
- B. Incorrect. Diesel will start, but will not exceed the surveillance time as the starting air systems are redundant.
- C. Correct. Start will occur in normal time via 2 starting air solenoids associated with the 1-1B starting air system
- D. Incorrect. The EDG will start.

**Technical References** STG 6B, Section 5 and T/S 3.8.8 Bases **References to be provided to applicants during exam:** None **Learning Objective:** 37728 - Decribe Diesel Generator System components

**Question Source:** 

	(note changes; attach parent)	Modified Bank # New	
Question	History:	Last NRC Exam	No
Question	Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR P	art 55 Content:	55.41 (7)	

# **BANKED ML082830427**

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #	2	
Group #	1	
K/A #	064/K6.07	
Importance Rating	2.7	2.9

K/A: **Emergency Diesel Generator (ED/G) System -** Knowledge of the effect of a loss or malfunction of the following will have on the ED/G System: Air receivers.

Proposed Question:

Unit 1 is at 100%.

A relief valve has failed open on Diesel Generator (DG) 1-1 Starting Air Receiver 1-1A.

The leakage exceeds the capacity of the starting air compressor.

Which of the following describes the affect of this failure on DG 1-1, if a start signal occurs prior to any operator action?

- A. Start in the normal allowed time, from the 1-1B Starting Air Receiver via all four starting air solenoids.
- B. Will start but, starting time will exceed the surveillance required response time.
- C. Start in the normal allowed time via the 2 starting air solenoids associated with the 1-1B Starting Air Receiver.
- D. Will not start because the starting air system will be depressurized.

Proposed Answer: C

Explanation:

Answer A is incorrect. Diesel will start in normal time, but the start will be with only 2 of the 4 starting motors.

Answer B is incorrect. Diesel will start, but will not exceed the surveillance time as the starting air systems are redundant.

Answer C is correct. Start will occur in normal time via 2 starting air solenoids associated with the 1-1B starting air system.

Answer D is incorrect. Air systems are separate but redundant, one system failing will not affect the others operation.

Technical Reference(s):	LJ-6B, Diesel Generator System, Pages 54-60, Rev. 12.
	Tech Spec 3.8.8 Bases, Page 39, Rev. 4.

Proposed references to	o be pr	ovided to applic	ants during	examination:	NONE
Learning Objective:	37	728 - Decribe Di	esel Genera	ator System com	ponents.
Question Source:	Ban	k #	INPO -		
	Moc New	lified Bank #		(Note changes	or attach parent)
Question History:	Last	NRC Exam	N	/A	
Question Cognitive Le	evel:	Memory or Fu Comprehensio	indamental on or Analy	Knowledge sis	X
10 CFR Part 55 Conte	ent:	55.41     7       55.43	_		
10 CFR Part 55 Conte	ent:	Design, compor systems, includ failure modes a	nents, and f ing instrum nd automat	unction of contro entation, signals ic and manual fe	ol and safety , interlocks, atures.

Examination Outline Cross-Reference	Level	RO
Knowledge of the operational implications as they apply to	Tier #	2
concepts as to the PM system: Radiation theory, including	Group #	1
sources, types, units, and effects.	K/A #	073K5.01
	Rating	2.5

Unit 1 is at full power.

A small steam generator tube leak is causing steam line radiation monitor RM-73 to read 1000 cpm above background.

If the monitor is functioning properly, what should happen to the indication if power is reduced to 50%?

- A. Indication should decrease due to the decrease in N-16 production.
- B. Indication should decrease due to the decrease in iodine production.
- C. Indication should remain the same due to the continued tube leakage.
- D. Indication should increase because there is less steam flow but the same amount of radioactivity.

Answer A

Explanation:

- A Correct.
- B Incorrect.
- C Incorrect

D Incorrect

**Technical References:** OIM G-3-1, STG G-4a page 2.3-59. **References to be provided to applicants during exam:** None **Learning Objective:** 37877 - Describe the operation of the Radiation Monitoring system.

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No

Memory/Fundamental Comprehensive/Analysis 55.41 (7)

#### **10CFR Part 55 Content:**

Note Changed to Bank question – from DCPP 2005 NRC exam. Rnf5 – 09/08/09

#### 51 – 2005 DCPP Exam

Examination Outline Cross-Reference:	Level	RO	SRO
	Tier #	1	
	Group #	2	
	K/A #	073 K	1.01
	Importance	3.6	3.9

Unit 2 is at full power. A small steam generator tube leak is causing steam line radiation monitor RM-73 to read 1000 cpm.

If the monitor is functioning properly, what should happen to the indication if power is reduced to 50%?

- A. Indication should decrease due to the decrease in N-16 production.
- B. Indication should decrease due to the decrease in iodine production.
- C. Indication should remain the same due to the continued tube leakage.
- D. Indication should increase because there is less steam flow but the same amount of radiation.

Proposed Answer:

A. Indication should decrease due to the decrease in N-16 production.

Explanation:

The steam line radiation monitors detect N-16 from the tube leakage. Once the unit is shutdown, N-16 production ceases and the indication will decrease.

Technical Reference(s): G4A – Radiation Monitoring, SOE-93-001

Proposed references to be provided to applicants during examination: None.

Learning Objective: 8485 Explain the conditions that effect Radiation Monitoring system radiation monitor indications

Question Source: Bank # Modified Bank # S-1207 New

Question History:Last NRC ExamN/AQuestion Cognitive Level:Memory or Fundamental Knowledge X

Comprehension or Analysis

 10 CFR Part 55 Content:
 55.41
 41.11

 55.43
 \_\_\_\_\_\_

Comments: K/A: 073 K1.01 - Knowledge of the physical connections and/or cause effect relationships between the PRM system and the following systems: Those systems served by PRMs

Examination Outline Cross-Reference	Level	RO
Knowledge of SWS design feature(s) and/or interlock(s) which	Tier #	2
provide for the following: Service water train separation.	Group #	1
Note: SWS is analogous to Auxiliary Salt Water	K/A #	076 K4.06
	Rating	2.8

Which of the following is the normal alignment of Auxiliary Salt Water Pump Crosstie Valves, FCV-495 and FCV-496, and what does this alignment ensure?

- A. Both valves are open. This ensures that a water hammer event resulting from an ASW pump trip and restart will not affect both trains.
- B. Both valves are closed. This ensures that a water hammer event resulting from an ASW pump trip and restart will not affect both trains.
- C. Both valves are open. This ensures that a single active failure will not result in a significant reduction in heat removal capability.
- D. Both valves are closed. This ensures that train separation will not be compromised.

#### Proposed Answer: C Explanation:

- A. Incorrect. With FCV-495 and 496 both open, the headers are tied together. This will allow a water hammer event to affect both trains. Vacuum reliefs perform this function.
  - B. Incorrect. With FCVV-495 and 496 both closed, a water hammer event will not affect both trains. This alignment is required by ECG 17.4 but only if both vacuum relief valves in one train are inoperable. This is NOT the normal arrangement
  - C. Correct. FCV-495 and 496 are both open. This ensure that a single active failure that will not result in a significant reduction in heat removal capability
  - D. Incorrect. If both FCV-495 and 496 are both closed this would ensure that train separation will not be compromised but this is NOT the normal arrangement.

# **Technical References: STG-E5. T/S 3.7.8 basis ECG 17.4 References to be provided to applicants during exam:** None **Learning Objective:** 37011 - State the purpose of the ASW system components

Question Source: Bank # (note changes; attach parent) Modified Bank #

	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
<b>10CFR Part 55 Content:</b> Changed SWS to ASW for A and B. rnf5	55.41 (7) 09/08/09	

Examination Outline Cross-Reference	Level	RO
Knowledge of bus power supplies to the following: service water	Tier #	2
	Group #	1
	K/A #	076 K2.01
	Rating	3.1

What are the power supplies for the Unit 1 Auxiliary Saltwater Pumps, 1-1 and 1-2?

- A. Pump 1-1 is powered from Bus F; Pump 1-2 is powered from Bus G
- B. Pump 1-1 is powered from Bus G; Pump 1-2 is powered from Bus H
- C. Pump 1-1 is powered from Bus F; Pump 1-2 is powered from Bus H
- D. Pump 1-1 is powered from Bus H; Pump 1-2 is powered from Bus G

#### Proposed Answer:

#### Explanation:

- A Correct: Per OIM J-1, ASW pumps 21 and 22 are powered from buses F and G.
- B Incorrect. G and H provide power to Unit 1 ASW pumps.
- C Incorrect: Correct supply for 2-1 but 22 is G.

А

D Incorrect: Correct supply for 2-2 but 21 is F.

#### Technical References: STG E-5, OIM J-1-1.

**References to be provided to applicants during exam:** None **Learning Objective:** 5339 - State the power supplies to ASW system components

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7)	

Taken from April 2007 Draft Exam ML 072400068 RO Ouestion 53 R1 Examination Outline Cross-Reference: Level RO SRO Tier: 2 Group: 1 K/A: 076 K2.01 Importance Rating: 2.7 2.7 Proposed Question: What are the power supplies for the Unit 2 Auxiliary Saltwater Pumps, 2-1 and 2-2? Pump 2-1 Pump 2-2 A. Bus F Bus G B. Bus G Bus H C. Bus F Bus H D. Bus G Bus F Proposed Answer: A. Bus F Bus G Explanation: A correct. Pumps 1 and 2 are powered from Bus F and G respectively for both units. B incorrect. Pump 2-1 is powered from F, 2-2 powered from G. C incorrect. Pump 2-2 powered from G. D incorrect. Pump 2-1 powered from F. Technical Reference(s): STG E5, ASW Proposed references to be provided to applicants during examination: None Learning Objective: 5339 - State the power supply to the ASW Pumps. Question Source: New Question History: Last NRC Exam: N/A Question Cognitive Level: Memory or Fundamental Knowledge X Comprehension or Analysis 10 CFR Part 55 Content: 55.41.7 - Design, components, and function of control and safety systems, including instrumentation, signals, interlocks, failure modes, and automatic and manual features. Comments: Expanded justification. No other changes. K/A: 076 K2.01 - Knowledge of bus power supplies to the following: Service water

(2.7/2.7)

Examination Outline Cross-Reference	Level	RO
Knowledge of bus power supplies to the following: Emergency air	Tier #	2
compressor	Group #	1
	K/A #	078K2.02
We don't have an "emergency" air compressor.	Rating	3.3

A loss of power to which of the following buses / load centers would have the most significant impact on Unit 2's ability to maintain normal instrument air header pressure (100 psig - 108 psig)?

- A. Unit 2, vital 4KV bus H
- B. Unit 1, vital 480V bus/load center G
- C. Unit 2, non-vital 480V bus/load center 22J
- D. Unit 1, non-vital 480V bus/load center 15E

#### Proposed Answer: D

#### **Explanation:**

- A. Incorrect. Compressors at both units are powered from non-vital sources.
- B. Incorrect. Compressors at both units are powered from non-vital sources
- C. Incorrect: 22J is non-vital 480VAC but does not power any air compressors.
- D. Correct: Bus/load center 15E supplies power to one reciprocating and one rotary compressor.

**Technical References: STG K-1** 

#### References to be provided to applicants during exam: None

Learning Objective: 7225 - State the power supplies to Compressed Air System components

Question Source: (note changes; attach)	Bank # parent) Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7)	

#### DCPP REACTOR OPERATOR NRC LICENSE EXAM, Dec. 2007 ML081006050

Question 58

Examination Outline Cross-reference: Level RO SRO

Tier # \_ 2\_

Group # \_ 1\_

K/A # 078 K2.01

Importance rating 2.7

**Instrument Air:** Knowledge of the bus power supplies to the following: Instrument air compressors.

Question: 54

A loss of power to which of the following busses/load centers would have the most significant impact on

Unit 2's ability to maintain normal instrument air header pressure (100 psig – 108 psig)?

A. Unit 2, vital 4KV bus H

B. Unit 1, vital 480V bus/load center G

C. Unit 2, non-vital 480V bus/load center 22J

D. Unit 1, non-vital 480V bus/load center 15E

Answer: \_\_\_ D\_\_\_\_

Explanation:

A and B are incorrect since all compressors at both units are powered from non-vital sources.

C is incorrect; non-vital bus/load center "J" is located in the Aux. Bldg and does not supply power to any compressor

D is correct. Bus/load center 15E supplies power to one reciprocating and one rotary compressor.

Technical Reference(s): OIM J-1-1, Rev.27; STG K1, Rev. 12, pages 2.1-3,12; STG J7, Rev. 11, page 2-16

Proposed references to be provided to applicants during examination: None

Learning Objective: STG K1, Compressed Air System, Rev 12 obj 23

Question Source	Bank ;	4	
-	Modif	ied Bank #	(Note changes or attach parent)
	New	<u>X</u>	
Question Cognitive	Level:	Memory or	r Fundamental Knowledge <u>X</u>
Commontes		Comprehen	nsion or Analysis

Comments:

Examination Outline Cross-Reference	Level	RO
Knowledge of the effect that a loss or malfunction of the IAS will	Tier #	2
have on the following: Containment air system.	Group #	1
	K/A #	078 K3.01
	Rating	3.1

GIVEN:

- Unit 1 was at 100% power with all systems in automatic control
- Instrument Air pressure is 80 psig and lowering
- The SFM has directed entry to OP-AP-9, Loss of Instrument Air
- Immediately after entering OP-AP-9, the reactor trips

Which of the following describes the effect on air-operated valves inside containment and how the plant will be stabilized (post-trip)?

- A. No effect. All air operated valves were designed to fail to the safe position.
- B. No effect. Letdown and charging valves modulate properly on N2 backup; no additional operator action is required.
- C. Pressurizer spray valves fail closed. Operator must manually control pressure by cycling proportional heaters on/off.
- D. PORVs 474, 455C and 456 fail closed and letdown isolates. Operator must restore letdown to avoid lifting a Pressurizer safety valve.

# Proposed Answer: C

# Explanation:

- A. Incorrect. All air operated valves are fail safe, but with no operate action the pressurizer will over fill as letdown is isolated and charging flow continues. Since Pzr sprays fail shut, a PORV lift will occur.
- B. Incorrect. Letdown must be restored by <u>manually</u> opening MS 1-902(sealed valve) and N2-1-34. (Appendix A page 17)
- C. Correct. See Op AP-9 step 5b
- D. Incorrect. PORV 455C and 456 will operate on backup N2.

**Technical References** STG K1 page 3-13, STG B1A pages 2.1-3&10, STG 4A page 2.1-46 and Procedure OP AOP-9

References to be provided to applicants during exam: None

Learning Objective: 7209 - Discuss abnormal conditions associated with the Compressed Air

System

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7)	

Examination Outline Cross-Reference	Level	RO
Knowledge of the physical connections and/or cause effect	Tier #	2
relationships between the containment system and the following:	Group #	1
SIS, including action of safety injection reset	K/A #	103 K1.08
	Rating	3.6
ka mismatch?? replacement. #32 from 2005 exam		
Ouestion 28		

Possibly a better fit to the KA: 32 DCPP 2005 exam

Examination Outline Cross-Reference:	Level	RO	SRO
	Tier #	2	
	Group #	1	
	K/A #	006 K	1.02
	Importance	4.3	4.6

Some time after an accident, containment pressure rises and indicates the following on VB1:

- PI-934 = 20 psig
- PI-935 = 23 psig
- PI-936 = 20 psig
- PI-937 = 24 psig

Containment spray does not actuate.

Which of the following would explain why spray did not actuate?

- A. Safety Injection signal has been reset.
- B. RWST is below the low level alarm setpoint.
- C. Containment Isolation Phase A has failed to actuate.
- D. Not enough channels of containment pressure are at/above the nominal setpoint.

Proposed Answer:

A. Safety Injection signal has been reset.

Explanation: A correct, an SI signal must be present B incorrect, RWST level would not interfere with actuation and pumps trip at lo-lo level. C incorrect, no interface. D incorrect, setpoint is 2/4 at 22 psig Technical Reference(s): Drawings 4014233, SSPS Functional Diagram and 498006 Containment Pressure STG I2, Containment Spray System, page 2-9

Proposed references to be provided to applicants during examination: None

Learning Objective: 5422 Explain the consequences of SSPS failures on plant operation

Question Source: M No	Bank # odified Bank # ew		P-49415		
Question History	: La	st N	RC Exam	DCPP RO Exa	ım 1995
Question Cogniti	ve Level: M Co	emor ompre	y or Fundan ehension or	nental Knowledge Analysis	X
10 CFR Part 55 C	Content: 55 55	.41 .43	41.7		

Comments: K/A: 006 K1.02 - Knowledge of the physical connections and/or cause effect relationships between the ECCS and the following: ESFAS

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Knowledge of bus power supplies to the following: One-line	Group #	2
diagram of power supply to trip breakers.	K/A #	001 K2.02
	Rating	3.6

Which of the following sequence of power supplies describes the source of power for a Reactor Trip Breaker Under Voltage Coil?

- A. 480 VAC Bus  $F \rightarrow PY-11 \rightarrow SSPS$  48VDC
- B. 480 VAC Bus  $G \rightarrow PY-12 \rightarrow Eagle 21 \ 48VDC$
- C. 125 VDC Bus ED-11  $\rightarrow$  SSPS 15 VDC
- D. 125 VDC Bus ED-12  $\rightarrow$  Reactor Trip Breaker Control Power

#### Answer: A

#### **Explanation:**

- A. Correct Bus F supplies PY-11 which then supplies Train A 48VDC in SSPS
- **B.** Incorrect Bus G and PY-12 are correct, but Eagle 21 does not supply power; however, it does supply inputs to SSPS to trip the reactor.
- C. Incorrect Plausible if the applicant thinks 15 VDC power supply for reactor trip breaker UV coils comes from 125VDC. SSPS is correct, however, 15 VDC supplies circuit cards and test slave relays.
- **D.** Incorrect This is the sequence for the shunt trip coils

# Technical References: B-6B (Eagle 21 and Solid State Protection System), J-10 (Instrument AC system)

**References to be provided to applicants during exam:** None

Learning Objective: 3291 - State the power supplies to the Eagle-21/SSPS components

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	Х

**10CFR Part 55 Content:** 

Comprehensive/Analysis 55.41 (7)

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Knowledge of annunciator alarms, indications, or response	Group #	2
procedures.	K/A #	002 G2.4.31
	Rating	4.2

# GIVEN:

- Unit 1 is in MODE 5
- LTOP is in service

RCS pressure rises to 445 psig and PK02-16, RHR System, alarms.

Based on this, PORV PCV-455C should be \_\_\_\_; and, RHR-8702, RHR suction valve, is

- A. Closed; Open
- B. Closed; Closed and blocked from opening
- C. Open; Open
- D. Open; Closed and blocked from opening

Answer: C Removed alarm, it would be in alarm with 8702 open. Explanation:

- A. Incorrect PORV should be open
- **B.** Incorrect The PORV should be open
- C. Correct the PORV should be open and the alarm means that RCS pressure is high and the suction valve is open.
- D. Incorrect PK02-16 alarming means suction valve is open

**Technical References: System Training Guide A-1, Reactor Coolant System References to be provided to applicants during exam:** None **Learning Objective:** 36923 - Analyze automatic features and interlocks associated with the Pzr, Pzr Pressure and Level Control System 35317 - Analyze automatic features and interlocks associated with the RHR system

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (3, 5, 7)	

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Ability to manually operate and/or monitor in the control room:	Group #	2
NIS indicators	K/A #	015 A4.02
	Rating	3.9

GIVEN:

- A reactor startup is in progress on Unit 1
- SR Channel N-31 indicates  $2 \times 10^3$  cps
- SR Channel N-32 indicates  $2 \times 10^3$  cps
- IR Channel N-35 indicates 2 x 10<sup>-9</sup> amps
- IR Channel N-36 indicates 2 x 10<sup>-11</sup> amps



Which of the following describes the

response of the Intermediate Range Excore Nuclear Instruments?

- A. IR Channel N-35 is reading abnormally high; P-6 permissive is NOT enabled.
- B. IR Channel N-36 is reading abnormally low; P-6 permissive is enabled.
- C. IR Channel N-35 is reading abnormally high; P-6 permissive is enabled.
- D. IR Channel N-36 is reading abnormally low; P-6 permissive is NOT enabled.

#### Answer: C

#### **Explanation:**

- A. Incorrect. IR N-35 is high, but the logic for P-6 is satisified w/1 of 2 IR above the setpoint of 1 x  $10^{-10}$  ICA.
- **B.** Incorrect. N-36 is reading approximately what it should be for the current source range counts.
- C. Correct Based SR/IR overlap criteria, IR Channel N-35 is reading abnormally high for existing conditions; P-6 permissive is enabled when ONE IR channel > 10<sup>-10</sup> amps. Manual action is required to de-energize SRHV.

# D. Incorrect. N-36 reading is correct, and P-6 permissive is enabled.

Technical References: System Lesson Guide B-4, Excore Nuclear Instrumentation OIM page B-4-1 References to be provided to applicants during exam: None Learning Objective: 5992 - Discuss abnormal conditions associated with the NIS

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (2, 6)	

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Ability to monitor automatic operation of the NNIS, including:	Group #	2
Automatic selection of NNIS inputs to control systems	K/A #	016 A3.01
	Rating	2.9

GIVEN:

- Unit 1 is operating at 100%
- PK05-21 PZR LEVEL HI/LO is alarming
- PK05-22 PZR LEVEL HI/LO CONTROL is alarming
- PZR level is rising
- PZR heaters are de-energized

The Controlling Pressurizer level has failed

- A. HIGH; actual PZR level will stabilize at a new higher level.
- B. LOW; actual PZR level will stabilize at a new higher level.
- C. HIGH; actual PZR level will increase until a high level reactor trip occurs.
- D. LOW; actual PZR level will increase until a high level reactor trip occurs.

# Answer: D

# **Explanation:**

- A. Incorrect Controlling PZR level has failed LOW; Letdown will isolate, and without operator action to switch to a non-faulted controlling channel, pressurizer level will increase until a high level reactor trip occurs.
- **B.** Incorrect PZR level will not stabilize at a new higher level.
- C. Incorrect Controlling PZR level has failed LOW.
- D. Correct Initial indications of a failed PZR level controller failing LOW are heaters DE-ENERGIZING and pressurizer level INCREASING. Although pressurizer level will ultimately increase on a failed level controller failing HIGH, due to letdown isolation, the initial indications of a failed PZR channel HIGH are Backup heaters ENERGIZING and pressurizer level DECREASING. Letdown will isolate in both conditions and ultimately lead to a high level reactor trip without operator action.

Technical References: Operator Information Manual , A-4-2a (Pressurizer Level Control), A-4-2b (Pressurizer Level Channel Failures) References to be provided to applicants during exam: None

**Learning Objective:** 36926 - Discuss abnormal conditions associated with the Pzr, Pzr Pressure and Level Control System

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	X
<b>10CFR Part 55 Content:</b>	55.41 ( 3, 7 )	

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Ability to (a) predict the impacts of the following malfunctions or	Group #	2
operations on the ITM system; and (b) based on those	K/A #	017 A2.02
predictions, use procedures to correct, control or mitigate the	Rating	3.6
consequences of those malfunctions or operations: Core damage		

GIVEN:

- A small break LOCA has occurred
- In-core thermocouples indicate 1210°F

Which of the following describes the status of the Core Cooling Critical Safety Function (CSF) and the preferred mitigation strategy to restore core cooling?

- A. The CSF is MAGENTA. RCPs should be restarted.
- B. The CSF is RED. RCPs should be restarted.
- C. The CSF is MAGENTA. Restore ECCS flow.
- D. The CSF is RED. Restore ECCS flow.

#### Answer: D

#### **Explanation:**

A incorrect. Incores above 1200°F indicate inadequate core cooling. Restart of RCPs is the least preferred method.

B incorrect. Incores above 1200°F indicate inadequate core cooling. However, restoring ECCS flow is the preferred method, RCP restart is the least preferred.

C incorrect. Core cooling is inadequate.

D correct. Core cooling is inadequate and the preferred method of addressing the situation is to restore ECCS flow.

#### **Technical References: FR-C.1**

#### References to be provided to applicants during exam: None

**Learning Objective:** 6811 - Explain the most effective method to restore adequate core cooling 11307 - Define inadequate core cooling.

Question Source:	Bank #
(note changes; attach parent)	Modified Bank #
	New

Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (2,7)	

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Ability to predict and/or monitor changes in parameter (to	Group #	2
prevent exceeding design limits) associated with operating the	K/A #	028 A1.01
HRPS controls including: Hydrogen concentration	Rating	3.4

GIVEN:

- Large Break LOCA is in progress
- Core damage is occurring
- Containment Hydrogen concentration is 3.2%

Which of the following describes the <u>minimum</u> equipment that is needed in operation in order to maintain hydrogen at or below the current concentration?

- A. ONE Recombiner and the Containment Purge System in service.
- B. ONE Recombiner ONLY in service.
- C. ONE Recombiner and Containment Spray System in service.
- D. BOTH Recombiners in service.

#### Answer: B

#### **Explanation:**

- A. Incorrect Each Containment Hydrogen Recombiner has 100% capacity. The Containment Purge System is to be used as a back up to the CHRs once hydrogen concentration reaches 3.5% by volume.
- B. Correct Only one Recombiner is needed to maintain hydrogen concentration in Containment below 4% by volume.
- C. Incorrect Containment Spray is only placed in service once Containment reaches 22 psig, well above the pressure when the Recombiners would be placed in service.
- D. Incorrect Only one Recombiner is needed to maintain hydrogen concentration in Containment below 4% by volume.

Technical References: System Lesson Guide H-8 (Containment Hydrogen Purge System), SLG H-9 (Containment Hydrogen Recombiners), SLG I-2 (Containment Spray System) References to be provided to applicants during exam: None **Learning Objective: 40834 -** Explain significant CHPS design features and the importance to nuclear safety

Question Source:	Bank #	
(note changes; attach parent)	Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7,9)	
Note: deleted reference to recombiners in	service and about to be	
inservice. Confuses what the question is t	trying to test. Rnf5,	
9/10/09		

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Knowledge of the effect of a loss or malfunction on the following	Group #	2
will have on the SDS: Controller and positioners, including ICS,	K/A #	041 K6.03
S/G, CRDS	Rating	2.7

#### GIVEN:

- Unit 1 has tripped from 100% power
- Reactor Trip Breaker 'A' is open
- Reactor Trip Breaker 'B' is closed
- Steam Dump Mode Select Switch is selected to Tavg

What is the status of the Steam Dump System?

- A. Groups 1 and 2 steam dump valves will actuate on the Load Rejection Controller; Groups 3 and 4 will NOT actuate.
- B. Groups 1, 2, 3, and 4 steam dump valves will actuate on the Reactor Trip Controller.
- C. Groups 1, 2, 3, and 4 steam dump valves will actuate on the Load Rejection Controller.
- D. Groups 1, 2, and 3 steam dump valves will actuate on the Reactor Trip Controller; Group 4 will NOT actuate.

#### Answer: A

#### **Explanation:**

- A. Correct Groups 1 and 2 will actuate on the Load Rejection Controller, which modulates due to Reactor Trip Breaker 'B' remaining closed. Groups 3 and 4 will not actuate due to a lack of arming signal with Reactor Trip Breaker 'A' opening.
- B. Incorrect Groups 1 and 2 will not actuate on the Reactor Trip Controller due to Reactor Trip Breaker 'B' remaining closed on the trip but will open due to the load rejection controller. Groups 3 and 4 blocked by P-4 train A.
- C. Incorrect Groups 1 and 2 will actuate on the Load Rejection Controller, but Groups 3 and 4 will not.
- D. Incorrect Groups 1 and 2 will actuate on the Load Rejection Controller, not the Reactor Trip Controller. Group 3 is not controlled by the Reactor Trip Controller.

# Technical References: OIM C-2-3References to be provided to applicants during exam: NoneLearning Objective: To be determined<br/>associated with the Steam Dump System8004 - Analyze automatic features and interlocks

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	'A' Bank #58
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41(7)	

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Knowledge of the operational implications of the following	Group #	2
concepts as they apply to the MT/B System: Purpose of low-	K/A #	045 K5.18
power reactor trips (limited to 25% power)	Rating	2.7

GIVEN:

- Unit 1 is at 7% power
- The crew is shutting down the plant in accordance with OP L-5, Plant Cooldown From Minimum Load to Cold Shutdown

The Main Unit Turbine EHC malfunctions, and turbine load begins increases uncontrollably at approximately 50 MW/minute.

If no operator action is taken, the reactor will trip \_\_\_\_\_.

- A. at 25% reactor power, but it will not cause a turbine trip. The reactor trip protects the core from the positive reactivity excursion.
- B. at 25% reactor power and cause a turbine trip. The reactor trip protects the core from the positive reactivity excursion.
- C. on Power Range Rate trip and cause a turbine trip. The reactor trip protects the core against violating the DNBR limit.
- D. on Power Range Rate trip, but it will not cause a turbine trip. The reactor trip protects the core against violating the DNBR limit.

#### Answer: B

#### **Explanation:**

on a plant shutdown, the turbine is taken off line with power below 10%. The at power trips are blocked and low power trips are enabled. Any reactor trip causes a turbine trip regardless of power level.

- A. Incorrect Both the reactor and turbine will trip.
- **B.** Correct both reactor and turbine will trip on the unblocked high flux (low) to protect against positive reactivity excursion from low power.
- C. Incorrect PR rate is +5%/2 sec. 50 MW/min is approximately 5%/minute, reason for trip is correct.

#### D. Incorrect – PR rate is +5%/2 sec. 50 MW/min is approximately 5%/minute. Reason for trip is correct.

Technical References: System Lesson Guide B-6A (Reactor Protection System). OIM B-6-4a and B-6-4b References to be provided to applicants during exam: None Learning Objective: 41316 - Explain significant RPS design features and the importance to nuclear safety 37048 - Analyze automatic features and interlocks associated with the RPS

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	X
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	X
<b>10CFR Part 55 Content:</b>	55.41 ( 5, 6, 7 )	

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Knowledge of ARM system design feature(s) and/or interlock(s)	Group #	2
which provide for the following: Containment Ventilation	K/A #	072 K4.01
Isolation	Rating	3.3

Which of the following radiation monitors, if in high alarm, will cause Containment Purge Exhaust valves (RCV-11 and RCV-12) to automatically close?

- A. RM-13, RHR Exhaust Duct Air Particulate monitor
- B. RM-44A, Containment Radiation Monitor
- C. RM-29, Plant Vent Gross Gamma monitor
- D. RM-34, Plant Vent ALARA monitor

#### Answer: B

#### **Explanation:**

- A. Incorrect
- B. Correct RM-44A/B in high alarm initiates a containment isolation signal. The containment isolation signal will close RCV-11 and -12.
- C. Incorrect
- **D.** Incorrect

# **Technical References: LH-4 Containment Purge System References to be provided to applicants during exam:** None **Learning Objective:** 5119 - Analyze automatic features and interlocks associated with the Containment Purge System

Question Source: (note changes; attach parent)	Bank #	
	Modified Bank #	
	New	Х
Question History.	Last NRC Exam	No
Question mistory.	Last NIC Liam	110

**Question Cognitive Level:** 

**10CFR Part 55 Content:** 

Memory/Fundamental Comprehensive/Analysis 55.41 (7, 11)

Examination Outline Cross-Reference	Level	RO
	Tier #	2
Knowledge of the physical connections and/or cause-effect relationships between the circulating water system and the following systems: Emergency/essential SWS	Group #	2
	K/A #	075 K1.08
	Rating	3.2

In accordance with OP AP-10, Loss of Auxiliary Saltwater, when is it appropriate to cross-tie the Auxiliary Saltwater (ASW) and the Circulation Water bays?

- A. If one unit loses its ASW pumps and the other unit's ASW pumps are not available.
- B. If the Circulation Water screens are severely clogged and the ASW screens are not available.
- C. If Chlorine injection into the ASW system is necessary.
- D. If bay level is low and the ASW pumps are losing suction.

#### Answer: D

#### **Explanation:**

- A. Incorrect The correct action would be to enter OP AP-11, Loss of CCW.
- **B.** Incorrect This would require isolating the two trains for the affected unit.
- C. Incorrect This would require operating with the opposite unit supplying.
- **D.** Correct If the bay level is low and the pumps are losing suction (or cavitating), cross-tying would be appropriate if the Circulation Water screens are less affected.

**Technical References:** AR PK01-03 (Auxiliary Saltwater Pumps), AP-10 (Loss of Auxiliary Salt Water) **References to be provided to applicants during exam:** None **Learning Objective:** 5354 - State the purpose of actions when restoring ASW after malfunctions

**Question Source:** 

Bank #

X #65 February 2005 Exam
	(note changes; attach parent)	Modified Bank # New	
Question 1	History:	Last NRC Exam	No
Question	Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	X
10CFR Pa	art 55 Content:	55.41 (10)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the operational implications of the following	Group #	1
concepts as they apply to a Pressurizer Vapor Space Accident:	K/A #	008 AK
Change in leak rate with change in pressure.		1.02
	Rating	3.1

Question 39 original not an RO question, especially closed book

# Replaced with 39 from DCPP June 2008 exam

GIVEN:

- A Pressurizer PORV fails open and cannot be isolated
- The plant trips and SI actuates
- 30 minutes after the reactor trip the crew enters E-1.2, Post LOCA Cooldown and Depressurization

Which of the following describes the expected plant conditions as the crew enters E-1.2?

- A. Break flow is unchanged from its original value; Pressurizer level off-scale high.
- B. Break flow has decreased from its original value; Pressurizer level on scale and decreasing.
- C. Break flow is unchanged from its original value; Pressurizer level on scale and decreasing.
- D. Break flow has decreased from its original value; Pressurizer level off-scale high.

```
Proposed Answer: D. Break flow has decreased from its original value; Pressurizer level is off-scale high.
```

Explanation:

Answer A incorrect – RCS pressure will be less than NOP as a result break flow will be reduced.

Answer B incorrect – Pressurizer level will be off scale high (even if still on scale, it would be increasing due to increased SI flow and the open PORV).

Answer C incorrect – Break flow will be reduced.

Answer D correct – lower RCS pressure will result in lower break flow and due to vapor space break, level will be off scale high.

Fechnical Reference(s):LMCD-FRC page 17 and page 37				
Proposed references to b	be provided to applicants during examination: <u>NONE</u>			
Learning Objective:	<ul><li>41697 - Describe the plant response to a loss of reactor coolant including:</li><li>Vapor Space LOCAs</li></ul>			
Question Source:	Bank #  X    Modified Bank #  (Note changes or attach parent)    New			
Question History:	Last NRC Exam DCPP 2008			
Question Cognitive Lev	el: Memory or Fundamental Knowledge Comprehension or Analysis X			
10 CFR Part 55 Content	55.41  5    55.43			
10 CFR Part 55 Content: Facility operating characteristics during steady state and transient conditions, including coolant chemistry, causes and effects of temperature, pressure and reactivity changes, effects of load changes, and operating limitations and reasons for these operating characteristics.				

Comments:

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the interrelations between the small break LOCA	Group #	1
and the following: S/Gs	K/A #	009 EK 2.03
	Rating	3.0

# GIVEN:

- A small break LOCA has just occurred in containment
- RCS pressure is 1600 psig and slowly lowering
- One train of ECCS has actuated
- MSIVs are shut
- All steam generators are available
- All RCPs are running

Is a secondary heat sink necessary in order to maintain adequate core cooling?

- A. No, because RCS decay heat removal is through the break.
- B. Yes, because this will allow ECCS flow to equal break flow.
- C. Yes, because secondary pressure must be maintained below primary pressure during all LOCA events.
- D. No, because the RCPs provide core cooling.

### Answer: B

Lowered pressure, 1900 is above SI pump shutoff head. Changed D. **Explanation:** 

- A. Incorrect Secondary heat sink is required in order for the RCS to reach equilibrium pressure, allowing high pressure SI flow to equal break flow, and thus guarantee that core cooling and decay heat removal are adequate.
- B. Correct
- C. Incorrect Secondary heat sink is required for a small break LOCA and not for a large break LOCA, when the RCS will completely depressurize.
- D. Incorrect RCPs transport heat to the steam generators for removal.

**Technical References: WOG, Background Information E-1, pages 5 and 52 References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the reasons for the following responses as they	Group #	1
apply to the Large Break LOCA: RCP tripping requirement	K/A #	011 EK 3.14
	Rating	4.1

GIVEN:

- Unit 1 was at 100% power
- A large break LOCA occurred
- Containment pressure is 25 psig and rising
- The crew has transitioned to E-1, Loss of Reactor or Secondary Coolant

Why will the crew trip the RCPs?

- A. Loss of cooling to the motor bearing oil coolers.
- B. To preserve them in case they are needed for core cooling later in the event.
- C. To prevent severe core uncovery if the RCPs trip later in the event.
- D. To maximize the time the steam generators are available as a heat sink.

### Answer: A

Lowered question to memory, modified question to directly address KA **Explanation:** 

- A. Correct loss of cooling occurs when Phase B occurs (22 psig). RCPs are stopped to prevent damage to the motors due to overheating.
- B. Incorrect this is the reason in C.1.
- C. Incorrect This is the design basis for a small break LOCA, not a large break LOCA
- D. Incorrect This is why RCPs are tripped for loss of secondary heat sink.

# **Technical References: Background Information WOG, Generic Issue, RCP Trip/Restart, pages 7-10**

**References to be provided to applicants during exam:** None **Learning Objective:** 5442 - Explain the conditions affecting RCP trip criteria

Question Source: Bank # (note changes; attach parent) Modified Bank #

	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (10)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to operate and/or monitor the following as they apply to	Group #	1
the Reactor Coolant Pump Malfunctions (Loss of RC Flow): RCP	K/A #	015/17
vibrations.		AA1.23
	Rating	3.1

GIVEN:

- Unit 1 is at 20% Power
- PK05-03, RCP 3 UP BRG L/O RESVR LVL HI/LO, is ON
- RCP 1-3 motor bearing temperature is 222°F
- PK05-05, RCP HIGH VIBRATION, is ON
- Vibration Monitoring System is indicating 25 mils on the Pump Shaft of RCP 1-3

In accordance with OP AP-28, RCP Malfunctions, what action should the operators take?

- A. Stop RCP 1-3 and then perform the immediate actions of E-0, Reactor Trip or Safety Injection.
- B. Shutdown the reactor per OP AP-25, Rapid Load Reduction, and then stop RCP 1-3.
- C. Trip the reactor, enter E-0, Reactor Trip or Safety Injection, and then stop RCP 1-3.
- D. Continue to monitor RCP 1-3 conditions, no stopping of the RCP is required at this time.

### Answer: C

Lowered power level to make a shutdown more plausible (below one loop loss of flow reactor trip setpoint)

### **Explanation:**

- A. Incorrect This has to be done in conjunction with tripping the reactor.
- B. Incorrect This would be the appropriate action if the #1 seal on RCP 3 had a leak rate of .8 GPM and bearing/motor temperatures were stable. The #1 seal on RCP 3 is intact.
- C. Correct Tripping the reactor and the RCP are the immediate actions per OP AP-28 for any RCP that has any bearing temperature alarm concurrent with a vibration alarm.
- D. Incorrect Foldout page 4.0, RCP trip requirements met.

### Technical References: OP AP-28, Reactor Coolant Pump Malfunction, foldout page

# References to be provided to applicants during exam: None

**Learning Objective:** 3477 Given an abnormal condition, summarize the major actions of the abnormal operating procedure to mitigate an event in progress.

Question Source: (note chan	nges; attach parent)	Bank # Modified Bank # New	X
Question History:		Last NRC Exam	No
Question Cognitive	Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Cont	tent:	55.41 (3 and 5)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to determine and interpret the following as they apply to	Group #	1
the Loss of Reactor Coolant Makeup: Whether charging line leak	K/A #	022 AA2.01
exists.	Rating	3.2

# GIVEN:

- Unit 1 is at 100% power
- Pressurizer level is slowly lowering
- RCS pressure is slowly lowering
- FI-128 (charging flow) is lowering
- PI-142 (charging header pressure) is lowering
- PK11-21, HIGH RADIATION, is ON due to an Aux Bldg area radiation monitor
- The crew has entered OP AP-17, Loss of Charging

Based on this, the most likely location of the leak is \_\_\_\_\_.

- A. between the CCP discharge valves and FCV-128, CCP flow control valve
- B. on the charging return line, downstream of the regenerative heat exchanger
- C. downstream of HCV-142, RCP Seal flow control valve
- D. on one of the ECCS cold leg injection lines

### Answer: A

### **Explanation:**

- A. Correct since the leak is between the CCP discharge valve and FCV-128 isolation valve, FT-128 will see decreased flow, and thus pressure on the charging header will drop (PT-142 correctly indicating lower pressure).
- B. Incorrect If the leak were downstream of the RHX, the pressure on the header would increase (due to increase charging demand from the Pressurizer which is seeing reduced flow) and FT-128 would see increased flow. Also there is no high radiation alarm coming from containment, where the RHX is located, but from the Auxiliary Building, where the CCPs and FCV-128 are located.
- C. Incorrect HCV-142 is downstream of FT-128. FT-128 would indicate an increase flow due to the demand from a leak downstream of HCV-142 and FT-128.
- D. Incorrect Leak location is incorrect.

**Technical References: OP AP-17, Loss of Charging References to be provided to applicants during exam:** None **Learning Objective:** 3465 - Identify and discuss RCS leakage paths, including means used to detect and identify leaks.

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 ( 5 and 10)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Loss of RHR: Knowledge of how abnormal operating procedures	Group #	1
are used in conjunction with EOPs.	K/A #	025 G 2.4.8
	Rating	3.8
This really appears to be an SRO question.		

Unit 1 is in MODE 5.

A break on the RHR suction line occurs. The RHR pumps begin to cavitate and are secured by the crew.

As a result of the loss of RCS inventory and RHR cooling the crew will...

- A. Go to OP AP SD-2, Loss of RCS Inventory and implement E-1, Loss of Reactor or Secondary Coolant.
- B. Go to OP AP SD-2, Loss of RCS Inventory and refer to E-1, Loss of Reactor or Secondary Coolant.
- C. Go to OP AP SD-2, Loss of RCS Inventory only.
- D. Go to E-1, Loss of Reactor or Secondary Coolant only.

### Answer: C (RO ??)

### **Explanation:**

- A. Incorrect EOPs do not apply in MODE 5. E-1 is not used at this time.
- B. Incorrect EOPs do not apply in MODE 5. E-1 is not used at this time.
- C. Correct. Only AP SD-2 would be used.
- D. Incorrect E-1 does not apply in MODE 5.

# Technical References: OP AP SD-0 (Loss of or inadequate decay heat removal), OP AP SD-1 (Loss of AC Power)

### References to be provided to applicants during exam: None

**Learning Objective:** 3478 - Given initial conditions, assumptions, and symptoms, determine the correct abnormal operating procedure to be used to mitigate an operational event

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 ( 5 and 10)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to determine and interpret the following as they apply to	Group #	1
the Loss of Component Cooling Water: The cause of possible	K/A #	026 AA2.02
CCW loss.	Rating	2.9

# GIVEN:

- Unit 1 is at full power
- CCW A header flow has increased
- CCW flow on headers B and C has decreased
- Unit 1 CCW Surge Tank level is decreasing
- Containment Structure sump level is rising

Which of the following is a possible location of the Component Cooling Water leak?

- A. CFCU 1-4
- B. RCP 1-3 thermal barrier return line
- C. Seal Water Heat exchanger inlet line
- D. RHR Heat Exchanger 1-2 inlet line

### Answer: A

### **Explanation:**

- A. Correct Vital header alarm due to low flow. Because containment sump level is increasing, and only one side of the surge tank is decreasing, the leak must be on a vital CCW header load in containment (ie CFCU).
- B. Incorrect Inside Containment but not a vital header load. No Header C alarm.
- C. Incorrect Not vital or located inside Containment, but could be at a lower pressure than CCW pressure and a source of outleakage.
- D. Incorrect Vital load and could cause the vital header alarm, but not inside Containment.

**Technical References:** AR PK01-06, AR PK01-07 **References to be provided to applicants during exam:** None **Learning Objective:** 3466 - Discuss the effects and actions associated with a loss of CCW.

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	X
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 ( 5 and 10)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to operate and monitor the following as they apply to an	Group #	1
ATWS: Reactor trip switch pushbutton.	K/A #	029 EA1.08
	Rating	4.5

RCS pressure begins to rapidly decrease. The operator takes the Reactor Trip Switch to "TRIP" and PK04-14, Reactor Trip Actuated, alarms.

Which of the following has occurred?

- A. There is a demand for a reactor trip but the trip breakers are still closed.
- B. A manual reactor trip demand signal has been generated by the Reactor Protection System.
- C. RCS pressure has decreased below the Low Pressure Trip setpoint generating an automatic reactor trip demand.
- D. The manual trip was successful in opening at least one or both reactor trip breakers.

### Answer: D

Removed window dressing and changed question. **Explanation:** 

- A. Incorrect –
- **B.** Incorrect –
- C. Incorrect –
- **D.** Correct. Alarm actuates when both trains actuate. Does not differentiate between manual or auto trip.

**Technical References: AR PK04-14 References to be provided to applicants during exam:** None **Learning Objective:** 37049 - Describe controls, indications, and alarms associated with the RPS

Question Source:	Bank #
(note changes; attach parent)	Modified Bank #
	New

Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	X
10CFR Part 55 Content:	55.41 ( 5 and 10)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the reasons for the following responses as they	Group #	1
apply to the SGTR: Equalizing pressure on primary and	K/A #	038 EK3.01
secondary sides of ruptured S/G.	Rating	4.1

A Steam Generator Tube Rupture has occurred and EOP E-3, "Steam Generator Tube Rupture", has been entered. Depressurization of the RCS is in progress.

The PRIMARY goal of depressurizing the RCS to match the pressure of the ruptured Steam Generator is for which of the following reasons?

- A. To refill the Pressurizer and allow the restoration of Letdown and normal pressure control.
- B. To refill the RCS and collapse any voids in the reactor vessel head.
- C. To maximize sub-cooling to help prevent the transfer of primary coolant to the secondary system.
- D. To minimize sub-cooling to help prevent the transfer of primary coolant to the secondary system.

### Answer: D

Replaced with Ruptured, not faulted **Explanation:** 

- A. Incorrect Per the Caution of EOP E-3, step 35, "An UNMONITORED atmospheric release MAY occur IF RCS <u>or</u> Ruptured S/Gs Pressures EXCEED 1040 PSIG".
- **B.** Incorrect The PRIMARY concern of equalizing RCS pressure and faulted Steam Generator pressure, with the addition of MINIMIZING sub-cooling, is to stop the leak and prevent further primary coolant from entering the secondary system.
- C. Incorrect
- **D.** Correct

Technical References: EOP E-3 (Steam Generator Tube Rupture), AOP AP-3 (Steam Generator Tube Failure), EOP E-3 Bases, References to be provided to applicants during exam: None Learning Objective: 7920 - Explain basis of emergency procedure steps

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 ( 5 and 10)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the interrelations between the Steam Line Rupture	Group #	1
and the following: Sensors and detectors.	K/A #	040 AK2.02
	Rating	2.6

The plant is at normal operating temperature and pressure.

Which of the following would satisfy the MINIMUM coincidence necessary to cause Main Steam Isolation actuation?

A. 1 of 4 Containment pressure channels sensing greater than or equal to 3 psig.

B. 2 of 4 Containment pressure channels sensing greater than or equal to 3 psig.

C. 1 of 4 Containment pressure channels sensing greater than or equal to 22 psig.

D. 2 of 4 Containment pressure channels sensing greater than or equal to 22 psig.

#### Answer: D

### **Explanation:**

- A. Incorrect
- **B.** Incorrect
- C. Incorrect
- D. Correct Main Steam Line Isolation Actuation signal is generated by two of four Containment pressure channels reading greater than or equal to 22 psig. Containment Phase 'B' CI signal is generated by this same logic.

**Technical References: LB-6A, Reactor Protection System References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No

**Question Cognitive Level:** 

**10CFR Part 55 Content:** 

Memory/Fundamental Comprehensive/Analysis 55.41 (7)

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the operational implications of the following	Group #	1
concepts as they apply to the Station Blackout: <u>Effect of battery</u>	K/A #	055 EK1.01
discharge rates on capacity.	Rating	3.3
Not sure this ties to KA, and I believe this is the second time this		
has been sampled. We had recommended resampling.		

The site is in a station blackout condition and the operators have entered ECA-0.0 (Loss of All Vital AC Power). Step 15 directs the operators to begin shedding non-essential DC loads.

What is the design capacity of the vital DC batteries and the primary reason for the load shed?

- A. Two hours battery capacity To prevent a potentially explosive hydrogen build-up in the battery rooms due to high discharge.
- B. Two hours battery capacity To conserve the battery for monitoring and control of the plant until power can be restored.
- C. Three hours battery capacity To prevent a potentially explosive hydrogen build-up in the battery rooms due to high discharge.
- D. Three hours battery capacity To conserve the battery for monitoring and control of the plant until power can be restored.

#### Answer: B

#### **Explanation:**

- A. Incorrect design is 2 hours, load shed is to conserve the battery.
- **B.** Correct 2 hour design and conserve the battery (step 15 basis).
- C. Incorrect Battery capacity is two hours, not three hours.
- **D.** Incorrect Battery capacity is two hours, not three hours.

**Technical References: ECA-0.0 (Loss of All Vital AC Power), J-9 (DC Power) References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	X
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (7 and 8)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the operational implications of the following	Group #	1
concepts as they apply to Loss of Offsite Power: Definition of	K/A #	056 AK1.04
saturation conditions, implication for the systems.	Rating	3.1

The reactor has tripped from 100% power and Safety Injection is in progress when the following events occur:

- Seismic event in the Buttonwillow area causing loss of offsite power
- PORV-474 has lifted and stuck open
- Isolation Valve 8000 A has failed open on the loss of power
- Pressurizer level at 66% and increasing
- RCS temperature at 550° F
- RCS pressure at 1015 psig

What is the condition of the RCS and the primary concern associated with this condition?

- A. 25° F sub-cooled, which is insufficient as a prerequisite to re-starting a RCP.
- B. Saturated, boiling is now occurring in the RCS which may bind RCPs.
- C. Saturated, boiling is now occurring in the core which could uncover the fuel.
- D. 25° F sub-cooled, boiling is now occurring in the core with the potential to uncover fuel.

### Answer: C

### **Explanation:**

- A. Incorrect The core is at saturation conditions, therefore sub-cooling do not exist. The primary concern is uncovering fuel as the coolant boils away, not re-starting a RCP.
- **B.** Incorrect Core is at saturation, but uncovering the fuel is the primary concern, not binding the RCPs.
- C. Correct
- D. Incorrect Sub-cooling does not exist when the RCS is at saturation.

Technical References: LA-4A (Pressurizer, Pressure and Level Control)

# **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
<b>10CFR Part 55 Content:</b>	55.41 ( 5 )	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the reasons for the following responses as they	Group #	1
apply to the Loss of Vital AC Instrument Bus: Actions contained	K/A #	057 AK3.01
in EOP for loss of vital AC electrical instrument bus.	Rating	4.1

GIVEN:

- Unit 1 operating at 100% power
- Channel I bistable status lights lit
- Rods are moving in prior to the operator placing them in MANUAL
- PK19-19 (VITAL UPS FAILURE) Alarming

Which of the following identifies the failure that occurred and what caused rods to begin to insert?

- A. Loss of Vital Bus PY-11 causing PT-505 (Tref) to fail low.
- B. Loss of Vital Bus PY-12 causing PT-505 (Tref) to fail low.
- C. Loss of Vital Bus PY-11 causing Power Range N-41 to fail low.
- D. Loss of Vital Bus PY-12 causing Power Range N-42 to fail low.

Answer: A (check 91 for double jeopardy) Removed redundant action in all answers and moved to question. Explanation:

- A. Correct PT-505 (Tref) powered from PY-11 has failed low on a loss of power to PY-11, causing rods to move in to bring Tave back to Tref. Operator should take manual control of rods per AP-4 once it is recognized that rods are moving in due to the loss of PY-11.
- B. Incorrect If power were lost to PY-12, the Channel II bistable lights would be lit, not Channel I. PT-505 modules would fail low, also causing rods to insert.
- C. Incorrect Power Range N-41 does fail on the loss of PY-11, but the failure of one PR NI does not affect rod control. Rods are moving in due to the failure of PT-505.
- D. Incorrect PY-11 has failed, PR failure would not cause rods to insert.

Technical References: AP-4 (Loss of Vital or Non-Vital Instrument AC), LPA-4 (Loss of

# Vital or Non-Vital Instrument AC), J10 (Instrument AC System) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41 (5 and 7)	Х

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to operate and/or monitor the following as they apply to	Group #	1
the Loss of Nuclear Service Water (SWS): Loads on the SWS in	K/A #	062 AA1.02
the control room.	Rating	3.2

Which of the following two ASW parameters would indicate a fouling of an in service CCW heat exchanger?

- A. Low header pressure and high pump amps
- B. High header pressure and low pump amps
- C. High CCW heat exchanger differential pressure and low pump amps
- D. High CCW heat exchanger differential pressure and high pump amps

#### Answer: C SRO question Explanation:

- A. Incorrect this is indication of system rupture
- **B.** Incorrect variation of system rupture and there is low amps with fouled heat exchanger
- C. Correct. Fouling causes dp to increase, and amps will decrease.
- **D.** Incorrect. Pump amps will be low.

# Technical References: OP AP-10, Loss of Aux Saltwater

References to be provided to applicants during exam: None

**Learning Objective:** 3477 - Given an abnormal condition, summarize the major actions of the abnormal operating procedure to mitigate an event in progress.

Question Source: (note changes: attach parent)	Bank # Modified Bank #	
(note changes, attach parent)	New	Х
Question History:	Last NRC Exam	No

**Question Cognitive Level:** 

**10CFR Part 55 Content:** 

Memory/Fundamental Comprehensive/Analysis 55.41 ( 5 and 7 )

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to determine and interpret the following as they apply to	Group #	1
the Loss of Instrument Air: When to trip reactor if instrument	K/A #	065 AA2.06
air pressure is decreasing.	Rating	3.6

GIVEN:

- Steam Generator levels 58% and decreasing
- Instrument Air pressure is 69 psig and decreasing
- Letdown has automatically isolated
- RCS pressure is 2295 psig and increasing
- PK13-16, PLANT INSTRUMENT AIR is alarming

After entering OP AP-9 (Loss of Instrument Air), which of the following describes the operator action?

- A. Take manual control to maintain Pressurizer level at program.
- B. Bypass the in-service Instrument Air Dryer.
- C. Take manual control of Digital Feedwater Control System.
- D. Trip the reactor and enter EOP E-0, Reactor Trip or Safety Injection.

# Answer: D

# **Explanation:**

- A. Incorrect OP AP-9 (Loss of Instrument Air), step 1, directs the operator to trip the reactor and enter EOP E-0 if S/G levels, PZR levels, PZR pressure can not be maintained within their normal band.
- **B.** Incorrect
- C. Incorrect
- **D.** Correct

Technical References: OP AP-9 (Loss of Instrument Air), LPA-9 (OP AP-9, Loss of Instrument Air)

References to be provided to applicants during exam: None

**Learning Objective:** 7927 - Given initial conditions and assumptions, determine if a reactor trip or safety injection actuation is required

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	x
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	v
10CFR Part 55 Content:	55.41 ( 5 and 7 )	Λ

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Loss of ECR: Ability to locate and operate components,	Group #	1
including local controls.	K/A #	W/E11 G
		2.1.30
	Rating	4.4

GIVEN:

- Operators have entered ECA-1.1, Loss of Emergency Coolant Recirculation
- The crew is using Appendix M to makeup to the RWST from the Spent Fuel Pit
- Step 1 is verify Spent Fuel Pit pumps are OFF

Where will the operator go to stop the running 1-1 Spent Fuel Pool pump by pushing the STOP pushbutton?

- A. At a panel in the AFW motor driven pump room
- B. At the breaker on the appropriate Vital 480 V MCC
- C. At a local panel near the Spent Fuel Pit
- D. At the breaker on the appropriate Non-Vital 480 V MCC

### Answer: A

Original could not be answered as closed reference. replaced **Explanation:** 

- A. Correct controls are on a panel just outside the SFP pump room
- **B.** Incorrect only the breaker control there.
- C. Incorrect this has the indications for heat exchanger pressure (for adjusting dp)
- D. Incorrect power supply is vital G and H.

Technical References: EOP ECA-1.1 (Loss of Emergency Coolant Recirculation), Appendix M References to be provided to applicants during exam: None Learning Objective: 5275 - Identify the location of components associated with the SFP cooling system

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 ( 5 and 7 )	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to determine and interpret the following as they apply to	Group #	1
the (Loss of Secondary Heat Sink): Facility conditions and	K/A #	W/E05
selection of appropriate procedures during abnormal and		EA2.1
emergency operations.	Rating	3.4

GIVEN:

- Reactor tripped and safety injection has actuated
- RCS press 1400 psig
- RCS Th is 425°F
- Steam Generator 1-1 pressure is 0 psig
- Steam Generator 1-1 Wide Range level is off scale low
- Intact steam generator Wide Range levels are 15%
- Intact steam generator pressures are 915 psig
- Crew has exited EOP E.0, Reactor Trip or Safety Injection, and entered EOP FR-H.1, Response to Loss of Secondary Heat Sink

Which of the following describes the requirement of the Steam Generators and the operator action?

- A. Required for RCS heat removal. Continue attempts to establish AFW flow in accordance with EOP FR-H.1.
- B. Not Required for RCS heat removal. Trip RCPs and return to EOP E-0.
- C. Required for RCS heat removal. Trip RCPs and initiate Bleed and Feed.
- D. Not Required for RCS heat removal. Trip RCPs and enter EOP E-2, Faulted Steam Generator Isolation.

### Answer: C

#### **Explanation:**

- A. Incorrect Steam Generators ARE required for RCS heat removal. Once AFW flow is established the next step will return you to the procedure and step in effect.
- B. Incorrect Steam Generators ARE required for RCS heat removal. In FR-H.1 after RCPs are tripped you will continue in this procedure in order to establish Bleed and Feed.
- C. Correct Steam Generators ARE required for RCS heat removal. Once RCPs are

tripped in step 5, the procedure continues to establish Bleed and Feed in order to remove decay heat.

D. Incorrect – Steam Generators ARE required for heat removal. Once RCPs are tripped in step 5, the procedure continues to establish Bleed and Feed in order to remove decay heat.

Technical References: EOP E.0 (Reactor Trip or Safety Injection0, EOP FR-H.1 (Response to Loss of Secondary Heat Sink) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	X
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	X
<b>10CFR Part 55 Content:</b>	55.41 ( 5 and 7 )	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to operate and/or monitor the following as they apply to	Group #	1
Generator Voltage and Electric Grid Disturbances:	K/A #	077 AA1.02
Turbine/generator controls.	Rating	3.8

GIVEN:

- Reactor power has been lowered to 42% due to grid stability problems
- PK12-06, TURBINE, alarms (Input 692, Bearing Oil Pressure Low)
- Bearing Oil Pressure on VB-4 at 5 psig and decreasing slowly
- Standby bearing oil pump is running
- The crew has entered OP AP-29, Main Turbine Malfunction

Which of the following describes the required operator action?

- A. Trip the turbine and enter E-0, Reactor Trip or Safety Injection, based on the subsequent reactor trip.
- B. Trip the turbine.
- C. Trip the reactor and enter E-0, Reactor Trip or Safety Injection.
- D. Continue to reduce turbine load.

# Answer: B

Changed initial condition to better match KA **Explanation:** 

- A. Incorrect Tripping the turbine is correct, but with reactor power at less than 50% (P-9 Permissive) the reactor will not automatically trip upon a turbine trip, thus negating the need to transition to E-0.
- B. Correct An immediate trip for the turbine, per AP-29 foldout page, is necessary when bearing oil pressure falls below 8 psig. AP-29 is the guiding procedure, not E-0, as the reactor will not have tripped since power is below the P-9 setpoint.
- C. Incorrect This is the correct action for a 719 Input (PPC Lube Oil Pressure Alarm), but not for Input 692 (Bearing Oil Low Pressure), which directs you to trip the turbine with bearing oil pressure on VB-4 at less than 8 psig.
- D. Incorrect reducing turbine load will not address the lowering oil pressure
# **Technical References: AP-29 (Main Turbine Malfunction) References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	X
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 ( 5 and 7 )	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Conduct of operations: Ability to interpret and execute	Group #	2
procedures.	K/A #	028 G
		2.1.20
	Rating	4.6

The plant was stable at full power with all systems operating normally in automatic control when the following occurs:

- Pressurizer level is 60% and begins to rise
- Pressurizer pressure is 2235 psig and stable
- Letdown flow isolates.
- Charging flow decreases.
- PK 05-22, Pzr Level Hi/Lo Control alarms (input 544, PZR Lo Lvl Letdn Iso All Htrs Off)
- All other parameters are normal

Which of the following has occurred?

- A. Excessive Reactor Coolant System Leakage
- B. Pressurizer level channel failure
- C. Loss of Charging
- D. Letdown Line Failure

**Answer:** B similar to 32 Reference to alarm typewriter is n/a **Explanation:** 

- A. Incorrect Rising pressurizer level is inconsistent with a RCS leak
- B. Correct The backup pressurizer level control channel has failed low.
- C. Incorrect Charging flow is decreasing as expected in the response to the operable primary controlling level channel.
- D. Incorrect Letdown has isolated as expected due to the backup pressurizer level control channel failing low.

Technical References: AR PK05-22 steps 5.1 and 5.7, STG A4A, OIM A-4-2b

# **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41(10)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Ability to determine and interpret the following as they apply to		2
the Fuel Handling incidents: ARM system indications.	K/A #	036 AA2.01
	Rating	3.2

Refer to the figure of RM-58 Fuel Handling Building (FHB) Radiation Control Module for the question that follows:

Given the following indications:

- Red Light is ON for Trip 2
- Amber Light is ON for Trip 1
- Green Operate Light is ON

Based on the indications, what automatic actions should have occurred?

- A. FHB Evacuation Alarm only.
- B. FHB Ventilation swapped to Iodine removal Mode and FHB
  Evacuation Alarm
- C. Both Auxiliary Building and FHB Ventilation swapped to Iodine Removal Mode.
- D. Only Auxiliary Building Ventilation swapped to Iodine removal mode.

# Answer: B

# **Explanation:**

- A. Incorrect. This condition would also cause the FHB ventilation system to swap to the Iodine removal mode.
- B. Correct. Red light ON indicates a HI Alarm set point has been exceeded and the FHB evacuation alarm should be sounding and Iodine removal ventilation should be in service.
- C. Incorrect. Auxiliary Building Ventilation is not swapped to Iodine Removal mode based on RM-58 input signal, only FHB Ventilation is shifted to Iodine Mode.
- D. Incorrect. Auxiliary Building Ventilation is not swapped to Iodine Removal mode based



on RM-58 input signal.

**Technical References:** STG G4A, Radiation Monitoring, Pages 2.2-18-23, Rev. 9. **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.43(5) 55.45(13)	

#### BANK from *ML 082830427* June 2008 DCPP Exam

#### **RO** Question 22

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #	1	
Group #	2	
K/A #	036/AA2.0	)1
Importance Rating	3.2	3.9

K/A: **Fuel Handling Incidents** - Ability to determine and interpret the following as they apply to the Fuel Handling Incidents: ARM system indications.

Refer to the figure of RM-58 Fuel Handling Building (FHB) Radiation Control Module for the question that follows:



Given the following indications:

- Red Light is ON for Trip 2
- Amber Light is ON for Trip 1
- Green Operate Light is ON

Based on the indications, what automatic actions should have occurred?

- A. FHB Evacuation Alarm only.
- B. FHB ventilation swapped to Iodine removal Mode and FHB Evacuation Alarm.
- C. Auxiliary Building and FHB Ventilation swapped to Iodine Removal Mode.

D. Auxiliary Building Ventilation swapped to Iodine removal mode only.

Proposed Answer: B

Explanation:

Answer A is incorrect. This condition would also cause the FHB ventilation system to swap to the Iodine removal mode.

Answer B is correct. Red light ON indicates a HI Alarm set point has been exceeded and the FHB evacuation alarm should be sounding and Iodine removal ventilation should be in service.

Answer C is incorrect. Auxiliary Building Ventilation is not swapped to Iodine Removal mode based on RM-58 input signal, only FHB Ventilation is shifted to Iodine Mode.

Answer D is incorrect. Auxiliary Building Ventilation is not swapped to Iodine Removal mode based on RM-58 input signal.

Technical Reference(s):	STG G4A, Radiation Monitoring, Pages 2-18-23, Rev. 9.
	LPA-21 Irradiated Fuel Damage, Page 9, Rev. 8.
	AR PK11-10, FHB High Radiation, RE 58 and 59, Rev. 11.
	OP AP-21 Irradiated Fuel Damage, Pages 1 & 3, Rev. 10.

Proposed references to be provided to applicants during examination: NONE

Learning Objective:	6573 – Explain the automatic actions that occur due to a fuel
	handling building radiation alarm.

Question Source:	Bank # Modified Bank # New	(Note changes or attach parent)
Question History:	Last NRC Exam	N/A
Question Cognitive Le	vel: Memory or Fu Comprehension	undamental Knowledge X on or Analysis
10 CFR Part 55 Conter	nt: 55.41 <u>7</u> 55.43	
10 CFR Part 55 Conter	R Part 55 Content: Design, components, and function of control and safety systems, including instrumentation, signals, interlocks, failure modes and automatic and manual features.	
Comments:		

Examination Outline Cross-Reference	Level	RO
Ability to operate and/or monitor the following as they apply to	Tier #	1
the Loss of Condenser Vacuum: Rod position.		2
	K/A #	051 AA1.04
	Rating	2.5

Given the following conditions:

- The unit is at 90% and ramping up with "MW Feedback In"
- Control Bank D rods are at 210 steps
- All equipment is operable and in the proper alignment for power operations

Due to condenser seal degradation and subsequent air in-leakage, condenser vacuum begins to slowly degrade.

How is this event expected to affect control rod position?

- A. Control rods will slowly step in due to T-avg vs. T-ref and/or power mismatch.
- B. Control rods will slowly step out due to T-avg vs. T-ref and/or power mismatch.
- C. A demand will exist for control rods to step out, but due to C-11, rods will remain at 210 steps.
- D. Control rods remain at 210 steps as degraded condenser vacuum will not affect power or T-avg.

Answer: B

# Explanation:

- A. Incorrect As vacuum degrades, efficiency is reduced, but DEHC will attempt to maintain the same load. This means that more MW's will be required from the RCS resulting in a reduced T-avg which results in a "*rods-out*" demand to restore T-avg
- B. Correct As vacuum degrades, efficiency is reduced, but DEHC will attempt to maintain the same load. This means that more MW's will be required from the RCS resulting in a reduced T-avg which results in a "rods-out" demand to restore T-avg
- C. Incorrect C-11 does not stop control bank D withdrawal until its position is 220 steps
- D. Incorrect turbine efficiency will affect reactor power and/or T-avg resulting in auto rod withdrawl.

#### **Technical References:** OP-AP-7, Rev. 34, page 2 **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	X
<b>10CFR Part 55 Content:</b>	55.41(7)	

#### BANK from *ML 081006050* Nov 2007 DCPP Exam

RO SRO Tier # 1 Group # 2 K/A 051 AA1.04 Importance rating 2.5

**Loss of Condenser Vacuum:** Ability to operate and/or monitor the following as they apply to the loss of condenser vacuum: rod position

Question: 21

The unit is at 90% and ramping up with "MW Feedback In." Control Bank D rods are at 210 steps. All equipment is operable and in the proper alignment for power operations. Due to condenser seal degradation and subsequent air in-leakage, condenser vacuum begins to slowly degrade.

How is this event expected to affect control rod position?

A. Control rods will slowly step in due to T-avg vs. T-ref and/or power mismatch.

B. Control rods will slowly step out due to T-avg vs. T-ref and/or power mismatch.

C. A demand will exist for control rods to step out, but due to C-11, rods will remain at 210 steps.

D. Control rods remain at 210 steps as degraded condenser vacuum will not affect power or T-avg.

Answer: <u>B</u>

Explanation: Answer A is incorrect, B is correct. As vacuum degrades, efficiency is reduced, but DEHC will attempt to maintain the same load. This means that more MW's will be required from the RCS resulting in a reduced T-avg which results in a "rods-out" demand to restore T-avg. C is incorrect since C-11 does not stop control bank D withdrawal until its position is 220 steps. D is incorrect since turbine efficiency will affect reactor power and/or T-avg resulting in auto rod withdrawal.

Technical Reference(s): OP-AP-7, Rev. 34, page 2

Proposed references to be provided to applicants during examination: <u>None</u>

Learning Objective: \_\_ STG C7A, Rev. 15, obj 22 \_\_\_\_\_ (As available)

Question Source Bank # \_\_\_\_\_ Modified Bank # \_\_\_\_\_ (Note changes or attach parent) New \_\_\_\_\_ XX\_\_\_\_

Question Cognitive Level: Memory or Fundamental Knowledge \_\_\_\_ Comprehension or Analysis \_\_X\_\_

Examination Outline Cross-Reference	Level	RO
Knowledge of the reasons for the following responses as they	Tier #	1
apply to the Area Radiation Monitoring system: Guidance	Group #	2
contained in alarm response for ARM system.	K/A #	061 AK3.02
	Rating	3.4

Annunciator Response Procedure AR PK11-17, S.G. Blowdown Hi Rad, directs the operator to verify automatic blowdown isolation.

It then directs the operator to override this signal by placing the RE 19, 23 Hi Rad S/G Blowdown and Sample Valves (O.C.) isolation defeat cutout switch to the "CUT IN" position.

What is the reason for placing the defeat cutout switch in "CUT IN"?

- A. Allow flushing the Radiation Monitor to eliminate nuisance alarms.
- B. Allow repositioning the HASP#1/HASP#2 switch to be placed in HASP#2 (Leak based setpoint) position.
- C. Allow re-flash capability for subsequent alarms.
- D. Allow sampling to identify a ruptured Steam Generator.

# Answer: D

# **Explanation:**

- A. Incorrect nuisance alarms are eliminated by taking the HASP toggle to HASP#1 (effluent) setpoint position.
- B. Incorrect HASP#1/HASP#2 toggles is normally in HASP#2
- C. Incorrect this switch allows blowdown sample isolation valve to be re-opened
- D. Correct this switch allows blowdown sample isolation valve to be re-opened for chemisty sampling.

**Technical References: Procedure** AR PK11-17, STG G4a page 2.3-38 **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: Bank # (note changes; attach parent) Modified Bank #

	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41(5 and 10)	

Examination Outline Cross-Reference	Level	RO
	Tier #	1
Knowledge of the interrelations between the Control Room	Group #	2
evacuation and the following: Reactor trip system.	K/A #	068 AK2.02
	Rating	3.7

An explosion and lots of smoke caused an immediate control room evacuation.

Which of the following is the *highest* priority action that operators should take before evacuating the control room?

- A. Manually close MSIVs and bypass valves.
- B. Trip the main turbine.
- C. Trip the main unit generator.
- D. Trip the reactor.

#### Answer: D

#### **Explanation:**

- A. Incorrect True, but this is step 5 of AP-8A. RNO can be done locally.
- B. Incorrect True, but this is step 3 of AP-8A. RNO can be done locally.
- C. Incorrect True, but this is step 4 of AP-8A. RNO can be done locally.
- D. Correct Tripping reactor is highest priority. The RNO of steps of 3- 5 can be done locally. See background of AP-8A for basis for performing only the RNO's.

**Technical References:** AP-8A background **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	

**10CFR Part 55 Content:** 

Comprehensive/Analysis 55.41(7)

Examination Outline Cross-Reference	Level	RO
Knowledge of the operational implications of the following	Tier #	1
concepts as they apply to the (Reactor Trip or Safety	Group #	2
Injection/Rediagnosis): components, capacity, and function of	K/A #	W/E01& 02
emergency systems.		EK1.1
	Rating	3.1

The following plant conditions exist after stabilizing from a small break LOCA:

- RCS Pressure = 1750 psig
- Pressurizer Level = 20% stable
- Subcooling =  $45^{\circ}$ F
- AFW flow = 500 gpm
- 1 CCP running
- 2 SI pumps running

How will pressurizer level respond if both SI pumps are shut down?

- A. Increase
- B. Decrease
- C. No change
- D. Initial sharp decrease, then slowly stabilize

# Answer: C

# **Explanation:**

- A. Incorrect. Turning off the SI pumps will not result in more flow and subsequent repressurization.
- B. Incorrect. RCS pressure is greater than shutoff head. Pressure should not change.
- C. Correct. RCS pressure is above SI pump shutoff head. When the SI pumps are secured, there will not be an RCS pressure response or temperature response.
- D. Incorrect. This is a typical response when pumps are secured during ECCS reduction sequence

# **Technical References:** STG B3 **References to be provided to applicants during exam:** None

Learning Objective: 6743 Explain PZR response during ECCS reduction sequence

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41(8 & 10)	

#### Banked from ML 072400068 April 2007 (draft) DCPP Exam

#### **RO** Question 26 R1

Examination Outline Cross-Reference: Level RO SRO	Tier:	1
K/A: EPE E02 EK1.1	Group: <u>2</u>	
Importance Rating: 3.2 3.8	-	

# **Proposed Question**:

The following plant conditions exist after stabilizing from a small break LOCA:

- •RCS Pressure = 1750 psig
- •Pressurizer Level = 20% stable
- •Subcooling =  $45^{\circ}$ F
- •AFW flow = 500 gpm
- •1 CCP running
- •2 SI pumps running

How will Pressurizer level be affected if both SI pumps are shut down?

- A. Increase
- B. Decrease
- C. No change
- D. Initial sharp decrease, then slowly stabilize

Proposed Answer: C. No change

Explanation:

- A. A incorrect. Turning off the SI pumps will not result in more flow and subsequent repressurization.
- B. B incorrect. RCS pressure is greater than shutoff head. Pressure should not change.
- C. C correct. RCS pressure is above SI pump shutoff head. When the SI pumps are secured, there will not be an RCS pressure response or temperature response.
- D. D incorrect. This is a typical response when pumps are secured during ECCS reduction sequence.

Technical Reference(s): STG B3

Proposed references to be provided to applicants during examination: None Learning Objective: 6743 Explain PZR response during ECCS reduction sequence Question Source: <u>Bank P-6157</u> Question History: Last NRC Exam

Question Cognitive Level: Memory or Fundamental Knowledge \_\_\_\_\_ Comprehension or Analysis X 10 CFR Part 55 Content: 55.41.8 - Components, capacity, and functions of emergency systems.

Comments: Expanded justification. No change to question from initial submittal.

K/A: EPE E02 EK1.1 – Knowledge of the operational implications of the following concepts as they apply to the (SI Termination) Components, capacity, and function of emergency systems. (3.2/3.8)

Examination Outline Cross-Reference	Level	RO
Knowledge of the interrelations between the (Steam generator	Tier #	1
Overpressure) and the following: Components, and functions of	Group #	2
control and safety systems, including instrumentation, signals,	K/A #	W/E13
interlocks, failure modes, and automatic and manual features.		EK2.1
	Rating	3.0

Unit 1 experienced a Steam Generator Tube Rupture (SGTR).

The crew is at the step in E-3, Steam Generator Tube Rupture, which checks to see if ECCS flow should be terminated.

Which of the following would be the effect on the plant, if Safety Injection Termination is delayed beyond the time assumed in the FSAR analysis for a SGTR?

- A. RWST inventory depletion
- B. Pressurized Thermal Shock
- C. Steam Generator Overfill
- D. Reactor Vessel Head bubble formation

# Answer: C

I don't believe this meets the criteria for a modified question. Explanation:

- A. Incorrect This is an ECA 1.1, Loss of Emergency Coolant Recirculation, concern.
- B. Incorrect This is a red or orange path FR-P.1, "Response to Imminent Pressurized Thermal Shock" concern.
- C. Correct If SI Flow is not terminated in a timely fashion, leakage into the steam generator will eventually fill the SG with water and potentially lift the SG Safety valves which greatly increases off-site dose
- D. Incorrect This is a yellow path FR-I.1 concern only implemented after SI is terminated.

**Technical References:** WOG E-3 Background Information **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	X
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41(7)	

# Modified from ML 082830427 June 2008 DCPP Exam RO Question 25

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #	1	
Group #	2	
K/A #	E02/EK1.1	
Importance Rating	3.2	3.8

K/A: **SI Termination** - Knowledge of the operational implications of the following concepts as they apply to the SI Termination: Components, capacity, and function of emergency systems.

Proposed Question:

Unit 1 experienced a Steam Generator Tube Rupture (SGTR).

The crew is at the step in E-3 "Steam Generator Tube Rupture", that checks to see if "ECCS Flow Should Be Terminated."

Which of the following would be the effect on the plant, if Safety Injection Termination is delayed beyond the time assumed in the FSAR analysis for a SGTR?

- A. Steam Generator overfill.
- B. Loss of Subcooling Margin.
- C. Loss of Secondary Heat Sink.
- D. Reactor Vessel Head bubble formation.

Proposed Answer: A

Explanation:

Answer A is correct. If SI Flow is not terminated in a timely fashion, leakage into the steam generator will eventually fill the SG with water and potentially lift the SG Safety valves.

Answer B is incorrect. Loss of subcooling is not a concern at this step in the procedure.

Answer C is incorrect. Loss of Heat Sink will not occur, even if the ruptured generator is needed for cooldown, as level will be increasing.

Answer D is incorrect. Voiding may occur in the upper head region, but is not a significant safety concern; SI is terminated even if a void exists.

Technical Reference(s):	LTAA-9, Steam Generator Tube Ruptures, Page 16, Rev. 8.
	LPE-3, EOP E-3 SGTR Response, Page 25, Rev. 10.
	EOP E-3, Steam Generator Tube Rupture, Page 23, Rev. 28A.
	E-3 Background Document, Page 120, Rev. 2.

Proposed references to be provided to applicants during examination: NONE

Learning Objective:	6855 -Explain the e control of the plant.	effect of SI termination and/or re-initiation on
Question Source:	Bank # Modified Bank # New	P-0796 (Note changes or attach parent)
Question History:	Last NRC Exam	N/A

Comments:

Examination Outline Cross-Reference	Level	RO
Knowledge of the reasons for the following responses as they	Tier #	1
apply to the (Containment Flooding): RO or SRO function as a	Group #	2
team as appropriate to the assigned position, in such a way that	K/A #	W/E 15
procedures are adhered to and the limitations in the facility		EK3.4
license and amendments are not violated.	Rating	2.9

A reactor trip and SI have occurred as a result of a large break LOCA.

E-1.3, Transfer to Cold Leg Recirculation, has just been completed.

The WCSFM reports the following conditions associated with the Containment critical safety function:

- Containment pressure 2.0 psig.
- Containment radiation 1400 R/hr.
- Containment sump level 98 ft.

Which of the following is an immediate containment concern?

- A. Containment structural integrity. Go to FR-Z.1, Response to High Containment Pressure.
- B. Flooding vital equipment in containment. Go to FR-Z.2, Response to High Containment Flooding.
- C. Erroneous instrumentation readings. Go to FR-Z.3, Response to High Containment Radiation.
- D. Inadequate suction to the RHR pumps. Go to ECA-1.3, Sump Blockage Guideline.

#### Answer: B

#### **Explanation:**

- A. Incorrect FR-Z.3 is a RED path but containment pressure is <22 psig. Entry condition not met
- B. Correct FR-Z.2 entry condition met and is MAGENTA Path
- C. Incorrect FR-Z.3 is a YELLOW path
- D. Incorrect ECA-1.3 entry condition not met E-1.3 step 13 ACTION/EXPECTED RESPONSE met

#### **Technical References: References to be provided to applicants during exam:** EOP F-0.5 **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	X
<b>10CFR Part 55 Content:</b>	55.41(5 and 10)	

#### Modified from ML 0023220665 October 2002 DCPP Exam

#### Proposed Question # 94:

A reactor trip and Si have occurred as a result of a large break LOCA. E-1.3, "Transfer to Cold Leg Recirculation" has just been completed.

The STA reports the following conditions associated with the Containment critical safety function:

- Containment pressure 2.0 psig.
- Containment sump level 98 ft.
- Containment radiation 1400 R/hr.

Which one of the following is an immediate containment concern?

- A. Inadequate suction to the RHR pumps.
- B. Flooding vital equipment in containment.
- C. Erroneous instrumentation readings.
- D. Containment structural integrity.

#### Proposed Answer: B

Explanation:

Technical Reference(s): EOP F-0 Attachment 6 DCPP Step Description/Deviation for FR-Z.2 step 1 Proposed references to be provided to applicants during examination: NONE

Learning Objective: 6819 Explain the effect of high water levels in containment.

Question Source: Bank # B-0002 Modified Bank # New

Question History: Last NRC Exam

Question Cognitive Level: Memory or Fundamental Knowledge Comprehension or Analysis X

10 CFR Part 55 Content: 55.41 7

Examination Outline Cross-Reference	Level	RO
Ability to verify system alarm setpoints and operate controls	Tier #	1
identified in the alarm response manual.	Group #	2
	K/A #	W/E16
		G2.4.50
	Rating	4.2

While observing the containment purge radiation monitor (RM44A) radiation display unit (RDU), you notice that the HIGH ALARM and CVI BYP status lights on the panel are both ON.

Based solely on the indications on the RDU, which of the following describes the containment purge CVI status?

- A. Status is normal; high radiation on R-44A will cause a CVI.
- B. A CVI signal has been sensed and a CVI has occurred.
- C. A CVI signal has NOT been sensed, but the CVI actions will occur when it is sensed.
- D. A CVI signal is sensed, but the CVI function is bypassed and it will NOT occur.

# Answer: D

# **Explanation:**

- A. Incorrect This a true but inconsistent with the CVI BYP status
- B. Incorrect The CVI will NOT actuate
- C. Incorrect The HIGH ALARM status light means the signal is sensed
- D. Correct CVI BYP is light when key-switch is in Bypass The CVI will NOT actuate

# Technical References: STG G-4B pages 2-43 and 2-44

**References to be provided to applicants during exam:** None **Learning Objective:** 3281 Explain the conditions that effect Digital Radiation Monitoring system radiation monitor indications

Question Source:	Bank #	Х
(note changes; attach parent)	Modified Bank #	
	New	

Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	X
10CFR Part 55 Content:	55.41(10)	

#### Modified from ML 0023220665 October 2002 DCPP Exam

Proposed Question # 28 :

While observing the containment purge radiation monitor (RM44A) radiation display unit (RDU), you notice that the HIGH ALARM and CVI BYP status lights on the panel are both ON.

Based solely on the indications on the RDU, which one of the following is true regarding the containment purge CVI status?

A. A CVI signal has been sensed and a CVI has occurred.

B. The status is normal; high radiation on R-44A will cause a CVI.

C. A CVI has NOT been sensed, but the CVI actions will occur when it is sensed.

D. A CVI signal is sensed, but the CVI function is bypassed and it will NOT occur.

Proposed Answer: D

Explanation:

Technical Reference(s): STG G-4B pages 2-43 and 2-44

Proposed references to be provided to applicants during examination: NONE

Learning Objective: 3281 Explain the conditions that effect Digital Radiation Monitoring system radiation monitor indications.

Question Source: Bank # A-0673

Question History: Last NRC Exam

Question Cognitive Level: Comprehension or Analysis X

10 CFR Part 55 Content: 55.41 7 55.43

Comments:

Examination Outline Cross-Reference	Level	RO
	Tier #	3
Ability to locate control room switches, controls, and indications,	Group #	1
and to determine that they correctly reflect the desired plant	K/A #	2.1.31
lineup.	Rating	4.6

Given the following:

- A plant heatup is in progress
- The plant is in MODE 3
- PZR pressure is 1975 psig
- RCS temperature is 525° F

Which of the following describes the status of PK08-06, P-11 Pressurizer SI Permissive?

- A. PK ON; PZR Low Pressure SI is enabled.
- B. PK ON; PZR Low Pressure SI is blocked.
- C. PK OFF; PZR Low Pressure SI is enabled.
- D. PK OFF; PZR Low Pressure SI is blocked.

# Answer: C

# **Explanation:**

- A. Incorrect
- **B.** Incorrect
- C. Correct Pressurizer pressure is above the 1915 psig setpoint, therefore P-11 light on VB1 is OFF and Low Pressure SI is enabled.
- **D. Incorrect**

**Technical References: System Lesson Guide B-6A (Reactor Protection System) References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source:

(note changes; attach parent)	Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (5, 7, 8)	

Examination Outline Cross-Reference	Level	RO
	Tier #	3
Knowledge of conduct of operations requirements.	Group #	1
	K/A #	2.1.1
	Rating	3.8

An event has occurred that will cause a safety injection actuation (SI) setpoint to be exceeded, and automatic actuation is deemed to be unavoidable.

In accordance with OP1.DC10, Conduct of Operations, operators should \_\_\_\_\_\_.

- A. initiate a reactor trip and at step 4 of E-0, Reactor Trip or Safety Injection, verify SI actuation
- B. monitor the plant and verify that the reactor trips and SI actuates automatically
- C. inform the Shift Foreman and wait for direction to trip the reactor and initiate SI
- D. initiate SI and verify the reactor automatically trips

Answer: D Per AP1 (step 1) SI is actuated. Explanation:

- A. Incorrect the operator should actuate the ESF signal.
- B. Incorrect operator should actuate the ESF signal.
- C. Incorrect operator should actuate the ESF signal.
- D. Correct Per OP1.DC10, step 4.6.2 Licensed Operators are expected to <u>manually</u> <u>initiate Engineered Safety Feature (ESF) actions</u>, (Reactor Trips and Safety Injections), under the following circumstances:T35692
  - When directed by procedure.
  - <u>When a plant parameter is approaching an automatic set point, such that the automatic actuation is judged to be unavoidable</u>.

• When in the judgment of the Operator or supervisor, initiation of the ESF signal, and use of the EOP set, will better allow for stabilization of the plant and diagnosis of the situation

# Technical References: OP1. DC10 page 4 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	#70 2002 Exam
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (10)	

Examination Outline Cross-Reference	Level	RO
	Tier #	3
Knowledge of the process for making changes to procedures.	Group #	2
	K/A #	2.2.6
Recommended replacement	Rating	3.0

While performing a procedure, it is noted that a minor typographical change is required. The change will not change the intent of the procedure and nuclear safety is <u>NOT</u> affected.

Which of the following is the correct procedure revision process?

- A. Editorial correction
- B. On the spot change
- C. Expedited procedure revision
- D. Normal revision

Answer: A

# ASSOCIATED INFORMATION:

Associated objective(s):

1 Isboeratea objeeti ve(s	<i>.</i>	
9735	Ex	xplain procedure for making on the spot changes (OTSC)

Reference Id: P-1551

# Answer: A

# **Explanation:**

- **A. Correct -** per AD2.ID1, R19, page 20. EC is used to update or correct editorial information that is obviously wrong.
- **B.** Incorrect
- C. Incorrect
- **D. Incorrect**

# **Technical References: OP1.DC10, Conduct of Operations**

# **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes: attach parent)	Bank # Modified Bank #	P-1551
(note enanges, attaen parent)	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (10)	

Examination Outline Cross-Reference	Level	RO
	Tier #	3
Knowledge of tagging and clearance procedures.	Group #	2
	K/A #	2.2.13
	Rating	4.1

GIVEN:

- A turbine building sump pump has been cleared for routine maintenance.
- The clearance has been reported on, and a maintenance red tag has been hung.
- No work has been done to the pump.
- A problem has developed with the other sump pump, making it desirable to place the cleared pump back in service.
- The Sub-clearance requestor can NOT be located.

Which of the following individuals may remove this red tag?

- A. Any Maintenance Foreman familiar with the clearance
- B. The Senior Control Operator
- C. The Nuclear Operator removing the clearance with the concurrence of the Senior Control Operator
- D. The Unit Shift Foreman

# Answer: D

# **Explanation:**

- A. Incorrect
- **B.** Incorrect
- C. Incorrect
- **D.** Correct

**Technical References: OP2. ID2, Clearances References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	#95 2002 Exam
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (10)	

Examination Outline Cross-Reference	Level	RO
	Tier #	3
Knowledge of the process for managing troubleshooting	Group #	2
activities.	K/A #	2.2.20
	Rating	2.6

In accordance with Operations Policy, B-16, Operations Troubleshooting Activities, whose approval is needed prior to any troubleshooting activities commencing on a unit?

- A. Shift Foreman
- B. Shift Manager
- C. Work Control Lead
- D. Operations Manager

#### Answer: A

#### **Explanation:**

- A. Correct per B-16, The SFM must approve any preplanned troubleshooting activities.
- **B.** Incorrect
- C. Incorrect
- **D. Incorrect**

## **Technical References: B-16, Operations Troubleshooting Activities References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank # New X	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	Х

**10CFR Part 55 Content:** 

Comprehensive/Analysis 55.41 (10)

Examination Outline Cross-Reference	Level	RO
Knowledge of radiation exposure limits under normal or	Tier #	3
emergency conditions.	Group #	3
	K/A #	G2.3.4
	Rating	3.2
		41.12

Which of the following describes the 10CFR20 Limits and the Diablo Canyon Administrative Limit for radiation exposure for a calendar year?

	10CFR20 Limit	DCPP Admin Limit
A.	4500 mREM	2000 mREM
B.	4500 mREM	4000 mREM
C.	5000 mREM	2000 mREM
D.	5000 mREM	4500 MREM

#### Answer: D

#### **Explanation:**

- A. Incorrect –10CFR20 limit is 5000 mREM and <u>not</u> 4500 mREM. 2000 mREM is the DCPP Admin *Guideline*. 4500 mREM is the Admin **Limit**.
- B. Incorrect –.10CFR20 limit is 5000 MREM and <u>not</u> 4500 mREM. 4000 mREM is 90% of DCPP Admin Limit (4500 mREM).
- C. Incorrect 10CFR20 limit is 5000 mREM <u>but</u> 2000mREM is the DCPP Admin *Guideline* <u>not</u> the Admin **Limit**.
- D. Correct –10CFR20 limit is 5000 mREM and the DCPP Admin Limit is 4500 mREM.

**Technical References:** RP1.ID6, Personnel Dose Limits and Monitoring **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach par	ent) Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental	
---------------------------	------------------------	
	Comprehensive/Analysis	
10CFR Part 55 Content:	55.41.12	

NRC Form ES-401-5 June 2008 DCPP M

ML 091270008

Written Examination Question Worksheet

# **RO Question 71**

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #	3	
Group #	N/A	
K/A #	G 2.3.4	
Importance	3.2 3.7	
Rating		

Х

K/A: **Generic** – Radiation Control: Knowledge of radiation exposure limits under normal or emergency conditions.

Proposed Question:

Which of the following describes the 10CFR20 Limits and the Diablo Canyon Administrative Limit for radiation exposure for a calendar year?

	10CFR20	Limit DCPP Admin Limit
А.	4500 mREM	2000 mREM
В.	4500 mREM	4000 mREM
С.	5000 mREM	2000 mREM
D.	5000 mREM	4500 MREM

Proposed Answer: D

Explanation:

Answer A is incorrect. 10CFR20 limit is 5000 mREM and not 4500 mREM, 4500 mREM is the Admin limit, DCPP Admin Guideline is 2000 mREM.

Answer B is incorrect. 10CFR20 limit is 5000 MREM and not 4500 mREM, 4500 mREM is the Admin limit, 4000 mREM is 90% of 4500 mREM.

Answer C is incorrect. 10CFR20 limit is 5000 mREM and the DCPP Admin Guideline is 2000 mREM.

Answer D is correct. 10CFR20 limit is 5000 mREM and the DCPP Admin limit is 4500 mREM.

ES-401 June 2008 DCPP NRC Form ES-401-5 Written Examination Question Worksheet Technical Reference(s): RP1.ID6, Personnel Dose Limits and Monitoring Requirements, Attachment 8.1, Rev. 8. OIM Administrative Radiation Exposure Limits, Page S-1-1, Rev. 20. Proposed references to be provided to applicants during examination: NONE Learning Objective: STATE the DCPP administrative exposure guidelines. Bank # Modified Bank # INPO -30401 (Note changes or attach parent) Question Source: New Question History: Last NRC Exam N/A Question Cognitive Level: Memory or Fundamental Knowledge X Comprehension or Analysis 10 CFR Part 55 Content: 55.41 12 55.43 10 CFR Part 55 Content: Radiological safety principles and procedures. Comments:

Examination Outline Cross-Reference	Level	RO
Ability to control radiation releases.	Tier #	3
	Group #	3
	K/A #	G2.3.11.
	Rating	3.8
		41.11

GIVEN:

- Several Auxiliary Building radiation alarms are received
- It is confirmed that Liquid Hold-Up Tank 1-1 has ruptured, and is leaking in the Auxiliary Building
- The crew has entered OP AP-14, Tank Ruptures

What action must be taken to prevent the offsite release of radioactive particulate and iodine?

- A. Select "S" signal test, secure one Aux Bldg Ventilation train, and energize charcoal heaters.
- B. Push "Status Reset" at POV1 and POV2, and reset the "S" signal.
- C. Stop all Aux Bldg supply and exhaust fans, and energize charcoal heaters.
- D. Locally close dampers that isolate the Waste Gas Decay Tank rooms.

# Answer: A

# **Explanation:**

- A. Correct. AP-14, step 2 provides direction for placing ABVS in SFGDS Only. This isolates ventilation to general aux Bldg and ensures all other exhaust is filter by the Iodine Removal filter prior to exhaust to atmosphere.
- B. Incorrect. This will reset ventilation logic. System will be reposition to normal based on selected mode and selected equipment. This does not minimize release to environment.
- C. Incorrect. This will not provide for Iodine removal. Exhaust Fan E-1 needs to be running.
- D. Incorrect. This will isolate ventilation supply to Liquid Hold up tanks but will not provide for Iodine removal.

**Technical References:** OP-AP-14, LPA-14 page 6, STG H-1 **References to be provided to applicants during exam:** None **Learning Objective:** 

Question Source: (note changes; attach parent)	Bank # Modified Bank # New	Х
Question History:	Last NRC Exam	
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	
10CFR Part 55 Content:	55.41.11	

## DCPP REACTOR OPERATOR NRC LICENSE EXAM, Dec. 2007 ML 0801006050

Examination Outline Cross-reference:	Level	RO
Ability to control radiation releases.	Tier #	1
	Group #	2
	K/A #	059 G
		2.3.11
	Importance rating	2.7

Question: 22

Several Auxiliary Building radiation alarms are received. It is confirmed that Liquid Hold-Up Tank 1-1 has ruptured, and is leaking in the Auxiliary Building.

What action must be taken to prevent the offsite release of radioactive particulate and iodine?

A. Select "S" signal test, secure one Aux Bldg Ventilation train, and energize charcoal heaters.

B. Push "Status Reset" at POV1 and POV2, and reset the "S" signal.

C. Stop all Aux Bldg supply and exhaust fans, and energize charcoal heaters.

D. Locally close dampers that isolate the Waste Gas Decay Tank rooms.

Answer: <u>A</u>

Explanation: AP-14, step 2 provides direction for placing 100% of the ABVS exhaust through the charcoal filters for both units. This sequence is provided in answer A. The actions and sequences in B, C, & D will not accomplish the intent of the step.

Technical Reference(s): OP-AP-14, rev. 12, step 2, page 2 Proposed references to be provided to

applicants during examination: <u>None</u> Learning Objective: 3477

(As available) Question Source Bank # <u>B-0367</u>

Modified Bank # \_\_\_\_\_ (Note changes or attach parent) New \_\_\_\_\_ Question Cognitive Level: Memory or Fundamental Knowledge \_\_\_X\_\_Comprehension or Analysis \_\_\_\_ \_\_Comments:

Examination Outline Cross-Reference	Level	RO
	Tier #	3
Ability to comply with radiation work permit requirements	Group #	3
during normal or abnormal conditions.	K/A #	2.3.7
	Rating	3.5

Both units are at full power.

What type of Radiation Work Permit (RWP) would the operator sign on to for an oil addition to a Reactor Coolant Pump?

- A. Routine RWP.
- B. Job Specific RWP.
- C. Special WP.
- D. Planned Special Exposure.

## Answer: B

## Explanation:

- A. Incorrect issued for up to a year for considered routine in stable radiological conditions. Not to be used for entry into areas where general area dose rates exceed 1000 mr/hr.
- B. Correct. Issued for specific non routine work. Job specific RWPs such as adding oil to RCPs may be authorized for extended periods of time.
- C. Incorrect no longer used.
- D. Incorrect used for emergency exposures.

## **Technical References: RCP D-201, Writing Radiation Work Requests References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: Bank # (note changes; attach parent) Modified Bank #

	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41 (12)	

Examination Outline Cross-Reference	Level	RO
	Tier #	3
Ability to identify post accident instrumentation.	Group #	4
	K/A #	2.4.3
	Rating	3.7

Which of the following is monitored on PAM1?

- A. Wide Range Containment Sump Water Level
- B. Pressurizer Level
- C. Steam Line radiation monitors
- D. Auxiliary Feedwater Flow

## Answer: A

## **Explanation:**

- A. Correct Wide Range Containment Sump Water Level is monitored by PAM1
- **B.** Incorrect Not monitored by PAMS
- C. Incorrect Monitored separate rad monitor panel
- **D.** Incorrect Not monitored by PAMS

## **Technical References:** System Training Guide, B-10, Post-Accident Monitoring System **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes: attach parent)	Bank # Modified Bank #	
(note enanges, attach parent)	New	Х
Question History:	Last NRC Exam	No

**Question Cognitive Level:** 

**10CFR Part 55 Content:** 

Memory/Fundamental Comprehensive/Analysis 55.41 (7)

Examination Outline Cross-Reference	Level	RO
	Tier #	3
Knowledge of EOP layout, symbols, and icons.	Group #	4
	K/A #	2.4.19
	Rating	3.4

When proceeding through Emergency Operating Procedures, if the reader comes across a step number enclosed in a box (e.g. 1. step instruction...), this denotes to the reader...

- A. Continuous Action Step
- B. Refer to Foldout Page
- C. Refer to the Note/Caution of that step
- D. Immediate Action Step

Go to e-0 and see if it can be expanded like the example above) **Answer:** D

## **Explanation:**

- A. Incorrect Continuous Action Steps are bordered by a box around the entire step.
- **B.** Incorrect Instructions within the step will refer the reader to the Foldout Page.
- C. Incorrect Notes and Cautions are identified by their descriptors, NOTE or CAUTION, with the text extending across the entire page.
- **D.** Correct

## **Technical References: LPE-Rule (EOP Rules of Usage) References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank #	
Question History:	New Last NRC Exam	X No

**Question Cognitive Level:** 

**10CFR Part 55 Content:** 

Memory/Fundamental Comprehensive/Analysis 55.41 (10)

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Ability to Interpret and execute procedure steps.	Group	1
	#	
	K/A #	009
		G2.1.20
	Rating	4.6

Following a small break LOCA on Unit 2 the following conditions exist:

- The crew is performing the actions of E-1, Loss of Reactor or Secondary Coolant
- RCS temperature 525° F
- RWST level 32%
- RHR pumps are stopped by the operator
- RCS pressure 290 psig
- Hydrogen Concentration 0.4%

Which of the following procedures provides the required actions that mitigate these plant conditions?

- A. EOP E-1.4, Transfer to Hot Leg Recirculation
- B. EOP E-1.2, Post LOCA Cooldown and Depressurization
- C. OP H-9, Inside Containment Hydrogen Recombination System
- D. EOP E-1.3, Transfer to Cold Leg Recirculation

Answer: D

## **Explanation:**

- A. Incorrect Transfer to Hot Leg Recirculation occurs at step 20 of EOP E-1, but due to the current conditions, this procedure is exited at step 13 to Cold Leg Recirculation with RWST level less than 33% and RHR flow initially greater than 100 GPM before being stopped by the operator.
- B. Incorrect Entrance into E-1.2, Post LOCA Cooldown and Depressurization, does not occur due to RCS pressure being less than 300 PSIG in step 12 of E-1.
- C. Incorrect Entrance into OP H-9 would occur if Hydrogen concentration

**Comment [g1]:** Need s to be reworded to state what procedure the crew is operating in? was greater than .5%.

D. Correct – Transfer to Cold Leg Recirculation occurs in step 13 of EOP E-1 with RWST level less than 33% and RHR flow greater than 100 GPM before being stopped by the operator.

**Technical References: EOP E-1, Loss of Reactor or Secondary Coolant References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	X
10CFR Part 55 Content:	55.43 (5)	

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Ability to determine and interpret the following as they	Group	1
apply to the Loss of Residual Heat Removal System:	#	
Leakage of reactor coolant from RHR into closed cooling	K/A #	025
water system or into reactor building atmosphere.		AA2.02
	Rating	3.8

GIVEN:

- Unit 1 is performing a core offload
- Both trains of RHR are in service

PK11-21, High Radiation alarms. A few minutes later, PK02-16, RHR System and PK02-17, RHR Pumps, also goes into alarm.

Which of the following procedures should the SFM utilize to address the current plant conditions?

- A. AP-1, Excessive Reactor Coolant System Leakage
- B. AP SD-2, Loss of RCS Inventory
- C. AP-16, Malfunction of the RHR System
- D. AP-24, Shutdown LOCA

## Answer: B

## **Explanation:**

- A. Incorrect Only appropriate in MODES 1-4
- **B.** Correct
- C. Incorrect Not applicable in MODE 6 or if there is a loss of RCS inventory
- **D.** Incorrect Not applicable in MODE 6

Technical References: OP AP-24, OP AP SD-2, OP AP-1, OP AP-16, PK02-16, PK02-17, PK11-21 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	#78 2005 Exam
parent)	New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.43 (5)	

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Knowledge of the purpose and function of major system	Group	1
components and controls.	#	
	K/A #	026
		G2.1.28
	Rating	4.1

Given the following conditions:

- Unit 1 reactor is at 100% power in MODE 1
- An unisolable, 200 gpm CCW leak occurs
- CCW makeup is not available

Which of the following describes the minimum time the surge tank is designed to provide system make-up based and what the time is based on?

- A. 40 minutes; for operators to locate and isolate the leak before the system becomes impaired due to water loss.
- B. 20 minutes; for operators to locate and isolate the leak before the system becomes impaired due to water loss.
- C. 40 minutes; to cross-tie the units.
- D. 20 minutes; to cross-tie the units.

## Answer: B

Reworded question to focus on one theme **Explanation:** 

## A. Incorrect

- **B.** Correct Tech Spec Bases 3.7.7 states that 20 minutes based on a nonmechanistic leakage rate of 200 gpm, for operators to locate and isolate the leak or realign the CCW system into two separate vital loops before the system becomes impaired due to water loss.
- C. Incorrect
- D. Incorrect –

Technical References: T.S. 3.7.7, Bases 3.7.7, System Lesson Guide LF-1 (Component Cooling Water) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.43 (2)	Х

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Ability to determine or interpret the following as they apply	Group	1
to a Station Blackout: Actions necessary to restore power	#	
	K/A #	055 EA2.03
	Rating	4.7

Current Plant Conditions:

- The crew is performing the actions of ECA-0.0, Loss of All Vital AC Power
- No ECCS pumps are running
- No RCPs are running
- RCS subcooling is 15°F
- Pressurizer level is 11% and slowly decreasing
- RCS pressure is 2050 psig and slowly decreasing

The crew is implementing ECA-0.3, Restore 4kV Buses, to restore power to a vital 4 kV bus as directed by ECA-0.0.

Which of the following actions will be taken by the crew in order to load vital equipment and stabilize the plant once power is restored to a vital 4 kV bus?

- A. Transition to EOP ECA-0.1 (Loss of All AC Power Without SI Required).
- B. Continue in EOP ECA-0.0 and continue to implement EOP ECA-0.3 without transitioning.
- C. Transition to EOP ECA-0.2 (Loss of All AC Power With SI Required).
- D. Return to E-0 (Reactor Trip or Safety Injection).

Answer: C Lowered subcooling and pressurizer level, a little. Reworded setup. Explanation:

- A. Incorrect Transitioning to ECA-0.1 would occur in step 29 of ECA-0.0 if RCS subcooling were greater than 20°F, Pressurizer level were greater than 12% and no ECCS pumps were running. As current conditions indicate that RCS subcooling is less than 20°F, the correct transition would be to ECA-0.2
- **B.** Incorrect

- C. Correct Transition to ECA-0.2 from step 29 in ECA-0.0 with RCS subcooling less than 20°F.
- **D.** Incorrect

## **Technical References: ECA-0.0, ECA-0.1, ECA-0.2, ECA-0.3, EOP E-0 References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.43 (5)	Х

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Loss of offsite power: Knowledge of abnormal condition	Group	1
procedures.	#	
	K/A #	056 2.4.11
	Rating	4.2

GIVEN:

- The RCS is at 175°F and 100 psig
- RHR flow indicated on VB1 is 3500 gpm
- L-1, Plant Heatup from Cold Shutdown to Hot Standby, is in progress

A loss of offsite power (230 kV and 500 kV) occurs.

What procedure will the Shift Foreman use to restore heat removal?

- A. OP SD-1, Loss of AC Power
- B. OP AP-26, Loss of Offsite Power
- C. EOP ECA-0.0, Loss of ALL AC Power
- D. OP SD-5, Loss of RHR Heat Removal

Answer: D Original requires knowledge of procedure steps, recommend the revised question Explanation:

- A. Incorrect used in MODE 5, to restore power to vital buses. The vital buses are energized.
- B. Incorrect Used to restore power to non-vital 4 kV and/or 12 kV buses.
- C. Incorrect does not apply in MODE 5, or if vital buses are energized.
- D. Correct used in MODE 5 to restore power to decay heat removal.

**Technical References: OP AP SD-5 References to be provided to applicants during exam:** None **Learning Objective:** 3478 - Given initial conditions, assumptions, and symptoms, determine the correct abnormal operating procedure to be used to mitigate an operational event

Question Source: (note changes; attach	Bank # Modified Bank #	X – P-45897
purcht)	New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
<b>IUCFR Part 55 Content:</b>	55.43 ( 5 )	

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Ability to determine and interpret the following as they	Group	1
apply to the Loss of vital AC Instrument Bus: That	#	
substitute power sources have come on line on a loss of	K/A #	057
initial AC.		AA2.14
	Rating	3.6

**Comment [g2]:** RO question. Needs to be rewritten.

Unit 1 is at full power.

AR PK19-19, UPS Failure, is now alarming due to inputs 1503, Instr AC UPS 1-4 Inverter Failure, and 1505, Instr AC UPS 1-4 on Bypass. 120 VAC Bus 1-4 is energized from its alternate source.

Which of the following describes the status of inverter 1-4 and the vital AC instrument bus 14?

- A. Both the inverter and the vital AC instrument bus are OPERABLE.
- B. The inverter is OPERABLE; the vital AC instrument bus is de-energized and inoperable.
- C. The inverter is inoperable; the vital AC instrument bus is OPERABLE.
- D. Both the inverter and the vital AC instrument bus are inoperable.

**Answer:** C See if we can include ts and bases. **Explanation:** 

- A. Incorrect The inverter will be OPERABLE when it is powered from its normal source or from the DC source.
- **B.** Incorrect The inverter has transferred to its backup supply (input 1505), therefore the vital AC instrument bus is OPERABLE.
- C. Correct The vital instrument bus is powered from a class 1E CVT (backup supply) and OPERABLE. The inverter is inoperable.
- **D.** Incorrect The vital AC bus is currently energized.

## Technical References: T.S. 3.8.7 and T.S. Bases 3.8.7, AR PK19-19 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	#81 2005 Exam
parent)	New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.43 (2)	

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Ability to determine and interrupt the following as they	Group	2
apply to the Pressurizer Control Malfunctions: leak in PZR.	#	
	K/A #	028
		AA2.11
	Rating	3.6

The plant was stable at full power with all systems operating normally in automatic control when the following occurs:

- Pressurizer level increased slightly but is now decreasing
- Pressurizer pressure is 2220 psig and decreasing
- Pressurizer backup heaters energized
- Charging flow is increasing
- PRT pressure is stable
- PK01-16, Containment Environment PPC alarms
- Containment Temperature is rising

Which of the following describes the procedure the Shift Foreman will use for the given conditions?

- A. OP AP-1, Excessive Reactor Coolant System Leakage, due to a Pressurizer vapor space leak.
- B. OP AP-5, Malfunction of Protection or Control Channel, due to a Pressurizer pressure channel failure.
- C. OP AP-13, Malfunction of Reactor Pressure Control System, due to a malfunction of the Pressurizer pressure controller.
- D. OP AP-1, Excessive Reactor Coolant System Leakage, due to a leaking PORV or Pressurizer safety.

## Answer: A

## **Explanation:**

- A. Correct Pressure Vapor Space leak has occured
- B. Incorrect Elevated Containment Temperature is inconsistent with a Pzr instrument level or pressure instrument failure.
- C. Incorrect Pressure response is as expected.

D. Incorrect – Leaking PORV/safety would not cause containment temperature to increase at this time.

**Technical References:** ARP 01-16, Simulator Malfunction MALFPZR, OIM-A-4-2B **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
pulont	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	X
IUCT N I alt 55 Collelli	55.45(5 and 15)	

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Ability to evaluate plant performance and make operational	Group	2
judgments based on operating characteristics, reactor	#	
behavior, and instrument interpretation.	K/A #	051 G 2.1.7
	Rating	4.7

A turbine load increase is in progress with all systems operating normally in automatic control when the following occurs:

- Turbine Load is 600 MWE.
- Pressurizer pressure is 2235 psig and stable
- Tave/Tref is matched.
- Condenser Pressure PI-44 reads 4.0"Hg Abs.
- Condenser Pressure Recorder PR-11A and B both show condenser pressure is slowly rising.
- Condenser differential pressure is 7 psid and stable on all quadrants
- PK10-11 COND PRESS/LEVEL is in ALARM

Which of the following describes the action that will be taken by the Shift Foreman?

- A. Direct the operator to trip the reactor, then the turbine and go to E-0, Reactor Trip or Safety Injection.
- B. Direct the operator to trip the turbine and go to AP-29, Main Turbine Malfunction.
- C. Go to OP AP-7, Degraded Condenser, section A (Loss of Condenser Vacuum), and reduce load increase necessary to restore condenser pressure to within operating limits.
- D. Go to OP AP-7, Degraded Condenser, section B (Condenser Fouling) and reduce load to remove a Circulating Water pump from operation to lower condenser differential pressure.

## Answer: C

#### **Explanation:**

- A. Incorrect. No indication that a turbine trip required at this time.
- B. Incorrect. Condenser pressure is within acceptable operating region of Op AP-7 Attachment 6.2.

C. Correct. Normal condenser parameter should re be restored.

D. Incorrect. There are no abnormal CWP indications or indications of tube fouling. Technical References: OP-L-3 PK10-11 OP-AP-7 References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	Х
Question History:	Last NRC Exam	
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	
10CFR Part 55 Content:	55.41(7)	

Examination Outline Cross-Reference	Level	SRO
	Tier #	1
Ability to operate and/or monitor the following as they	Group	2
apply to the dropped rod: Rod position indication to actual	#	
rod position	K/A #	003
		AA2.01
	Rating	3.9

The plant is at full power, all rods out, when the following events occur:

- DRPI rod bottom light for a Control Bank D rod lights
- PK03-21, DRPI Failure/Rod Bottom, alarms
- PK03-17, Rod Cont Urgent Failure, alarms
- PK03-13, Rod Lo Insertion Limit Alarm and PK03-14, Rod Lo Lo Insertion Limit Alarm, alarm
- Reactor power and Tave are decreasing
- Group step counters for Control Bank D read 231 steps

Which of the following actions will be taken by the Shift Foreman?

- A. Direct a reactor trip and go to E-0, Reactor Trip or Safety Injection.
- B. Contact maintenance for troubleshooting a DRPI failure.
- C. Go to OP AP-12B, Control Rod Misalignment.
- D. Go to OP AP-12C, Dropped Control Rod.

#### Answer: D

#### **Explanation:**

- A. Incorrect. Only 1 rod has dropped, no call for reactor trip at this time.
- B. Incorrect. DRPI is functioning properly. Group step counters will not change and the urgent failure could be an expected alarm.
- C. Incorrect. With the rod bottom light lit, the appropriate section is AP-12C

D. Correct. A single rod has dropped.

**Technical References:** OP AP-12C

References to be provided to applicants during exam: None

Learning Objective: 3477 Given an abnormal condition, summarize the major actions

of the abnormal operating procedure to mitigate an event in progress. 5024 Explain the effect of dropped rod(s) on reactor operation

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	X
Question History:	Last NRC Exam	
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	
10CFR Part 55 Content:	55.43(5 and 13)	

Examination Outline Cross-Reference	Level	SRO
Knowledge of the limiting conditions for operation and	Tier #	1
safety limits	Group	2
	#	
	K/A #	WE08
		G2.2.22
	Rating	4.7

The plant is at 3% power when a steam break occurs outside containment.

As the crew reaches the diagnostic steps of E-0 Rector Trip or Safety Injection the following plant conditions exist:

- RCS temperature 265°F and rising after an initial decrease to 230°F
- RCS pressure 1750 psig and rising
- Pressurizer level 15% and rising
- Steam Generator pressures:

S/G 2-1	820 psig, rising
S/G 2-2	0 psig, stable
S/G 2-3	900 psig, rising
S/G 2-4	890 psig, rising

Which of the following procedures will the crew transition to from E-0?

A. E-1.1 Safety Injection Termination.

- B. E-2 Faulted Steam Generator Isolation
- C. ECA-2.1 Uncontrolled Depressurization of All Steam Generators
- D. FR-P.1 Response to Imminent Pressurized Thermal Shock Condition

#### Answer: B

#### **Explanation:**

- A. Incorrect. Transition to E-1.1 will occur at E-2 Step 8.
- B. Correct. Transition to E-2 is required at E-0 step 11
- C. Incorrect. Transition to ECA-2.1 could occur at E-2 step 2 but condition is not met.

D. Incorrect. Magenta FR-P.1 condition initially met but is now Yellow. Per EOP F-0 section 4.1.1, operator is not required to perform action of FR-P.1 since adequate time was not allowed for thermal stresses to affect the integrity of the vessel wall.

**Technical References: References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	Х
parent)	New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.41(5) 43(2) and 45(2)	
ML050	08904472 Feb 2005	
Examination Outline Cross-Reference	Level Tier # Group # K/A #	RO SRC    1    2   W/E02 EA2.1
	Importance	LA2.1 4.2
Proposed Question:SRO QA steam break occurs inside containing performing the steps of E-0, Reactor 7Current plant conditions:•Containment pressure – 14 ps•Steam Generator 2-2 early isd•Total AFW throttled to 500 g•RCS pressure – 1850 and inc•Steam Generator pressures:o 2-1 – 900 psig, stableo 2-2 – 0 psig, stableo 2-3 and 2-4 – 1000 p•Pressurizer Level – 35%, incr•RCS Subcooling 50°FThe procedural flowpath should be E-A. E-1.1B. E-2 to E-1.1C. FR-Z.1 to E-1.1	neetion 83 nent on Steam Generator 2- Trip or Safety Injection. sig (peak at 25 psig) plation performed spm reasing e e osig, stable reasing -0 to	2. The crew is
D. FR-Z.1 to E-2 to E-1.1		

Proposed Answer: B. E-2 to E-1.1

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Ability to interpret control room indications to verify the	Group	1
status and operation of a system, and understand how	#	
operator actions and directives affect plant and system	K/A #	007
conditions.		G2.2.44
	Rating	4.2

The plant is at full power.

The following events occur:

- PK05-25, PRT Press/Lvl/Temp alarms, input 545 Pzr Relief Tk Press Hi and Vent Hdr Isol. alarms
- PRT temperature is 110°F and rising at approximately 1°F every 5 minutes
- PRT pressure is 10 psig and rising at approximately 1 psig every 5 minutes
- AR PK05-25 has been entered by the Shift Foreman

What action will be taken by the Shift Foreman?

- A. Implement AP-1, Excessive RCS Leakage to aid in identifying the source and magnitude of the leakage.
- B. Direct the operator to trip the reactor and enter E-0, Reactor Trip or Safety Injection due to an unidentified loss of reactor coolant.
- C. Per AR PK05-25, contact maintenance to troubleshoot a possible failure of the PRT N<sub>2</sub> Supply regulator, RCS-1-PCV-3035.
- D. Per AR PK05-25, vent the PRT to the Waste Gas Header to less than 3 psig using PCV-472, PRT Vent to Vent Hdr, and verify RCS-1-8045, PRT N<sub>2</sub> Supply Isolation valve is closed.

**Answer:** A. Implement AP-1, Excessive RCS Leakage to aid in identifying the source and magnitude of the leakage.

## **Explanation:**

Answer A correct – increase in pressure with a corresponding increase in level/temperature is an indication of leakage into the PRT. AP-1 is implemented to aid in finding the leakage.

Answer B incorrect – there is no indication that a reactor trip is required at this time.

**Comment [g3]:** This is an RO question and needs to be rewritten.

Answer C incorrect – a failure of the regulator is suspected if only pressure is increasing (no corresponding increase in level or temperature)

Answer D incorrect – PCV-472 cannot be used when PRT pressure is 10 psig or higher. **Technical References: AR PK05-25** 

## References to be provided to applicants during exam: None

**Learning Objective:** 3552 - Given initial conditions, assumptions, and symptoms, determine the correct abnormal operating procedure to be used to mitigate an operational event

Question Source: (note changes; attach	Bank # Modified Bank #	Х
parent)	New	
Question History:	Last NRC Exam	2009 DCPP #87
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	X
IUCEK Part 55 Content:	33.43(3)	

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Ability to (a) predict the impacts of the following	Group	1
malfunctions or operations on the CSS; and (b) based on	#	
those predictions, use procedures to correct, control or	K/A #	026 A2.04
mitigate the consequences of those malfunctions or	Rating	4.2
operation: Failure of spray pump		

A large break LOCA occurred, resulting in a reactor trip and safety injection.

EOP E-1, "Loss of Reactor Coolant or Secondary Coolant" is in progress.

The following conditions exist:

- RCS Pressure is 60 psig and trending down slowly
- RCS Temperature is 300°F and trending down slowly
- RWST level is 50% and trending down
- RHR flow is 650 gpm
- Containment pressure is 32 psig and trending down slowly
- PK01-18 Containment Spray Actuation is ON
- Both trains of Containment Spray are in service

Containment Spray Pump 1-1 trips and cannot be manually started.

Based on the above, the Shift Forman will:

- A. Continue in E-1, "Loss of Reactor Coolant or Secondary Coolant," but may go to FR-Z.1 at the discretion of the SFM.
- B. GO TO E-1.3, "Transfer to Cold Leg Recirculation."
- C. GO TO ECA-1.1, "Loss of Emergency Coolant Recirculation."
- D. GO TO FR-Z.1, "Response to High containment Pressure."

## Answer: A

#### Color F-0.5

#### **Explanation:**

- A. Correct. Crew has transitioned out of E-O to E-1 already. Status Monitoring is in effect per EOP F-0 background document. YELLOW PATH on Containment which may be implemented per EOP F-0 rules but
- B. Incorrect. E-1.3 would be implemented if RWST level is < 33%. RWST level is above this transition criteria.

- C. Incorrect. ECA-1.1 Entry condition from E-1 Step 11 NOT met since RHR is available and running.
- D. Incorrect. Yellow PATH on Containment should be implemented per EOP F-0 rule of Usage 3.3.

#### **Technical References: References to be provided to applicants during exam:** None **Learning Objective:**

Question Source:	Bank #		
(note changes; attach	Modified Bank #		Х
parent)	New		
Question History:	Last NRC Exam		
Question Cognitive Level:	Memory/Fundamental		
	Comprehensive/Analysis		
10CFR Part 55 Content:	55.41(5) 43(5)		
	55.45(3 & 13)		
Modified from J ES-401 Form ES-401-5	June 2008 Exam ML 09127008 June 2008 DCPP		NRC
Written	Examination Question Worksh	leet	
5	SRO Question 2		
Examination Outline Cross-Reference	e:	DO	CDO
	Level	RO	SRO
	lier #		1
	Group #		1
	K/A #		
			011/2.4.4
	Importance Rating	4.7	

K/A: Large Break LOCA - Emergency Procedures/Plan: Ability to recognize abnormal indications for system operating parameters that are entry-level conditions for emergency and abnormal operating procedures.

Proposed Question:

A Large Break LOCA has occurred, resulting in a reactor trip and safety injection.

EOP E-1, "Loss of Reactor or Secondary Coolant" is in progress.
The following conditions currently exist:

- RCS Pressure is 40 PSIG and stable.
- RHR system flow is at 0 gpm.
- RWST Level is 32% and TRENDING DOWN SLOWLY.
- Containment Recirculation Sump level is 94 feet and TRENDING UP SLOWLY.

Based on the above parameters the Shift Foreman should:

A. Continue in E-1, "Loss of Reactor or Secondary Coolant."
B. GO TO E-1.3, "Transfer to Cold Leg Recirculation."
C. GO TO FR-Z.2, "Response to Containment Flooding."
D. GO TO ECA-1.2, "LOCA Outside Containment."

Proposed Answer: B

### Explanation:

Answer A is incorrect. E-1 foldout page directs the operator to transition to E-1.3 when RWST level reaches 33%.

Answer B is correct. E-1 Foldout page item is met for transition to E-1.3 based on the RWST level being below 33%, RHR flow is zero because the RHR pumps tripped off automatically on low RWST level of 33%. 92 ft is the expected level for the Containment Recirculation Sump following a DBA LOCA.

Answer C is incorrect. Containment flooding is only a concern if Recirc sump level is greater than 95.75 ft..

Answer D is incorrect. LOCA outside containment has not occurred; level in containment and the RWST are at the expected values. E-1.3 will check for this condition.

Technical Reference(s): LPE-1A, Loss of Coolant Response, Page 25, Rev. 10. EOP E-1, Loss of Reactor or Secondary Coolant, Step 13, page 14 and Foldout Page, Rev. 24.

EOP E-1.3, Transfer to Cold Leg Recirculation, Step 6, Page 4, Rev. 25.

Proposed references to be provided to applicants during examination: NONE

Learning Objective: 3552 - Given initial conditions, assumptions, and symptoms, determine the correct Emergency Operating Procedure to be used to mitigate an operational event.

Question Source:

Bank # Modified Bank # B-0101 (Note changes or attach parent) New

Question History: Last N	RC Exam N/A
Question Cognitive Level:	Memory or Fundamental Knowledge Comprehension or Analysis X
10 CFR Part 55 Content: 55.43	55.41 5
10 CFR Part 55 Content: approp situatio	Assessment of facility conditions and selection of riate procedures during normal, abnormal, and emergency ons.

Comments:

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Ability to prioritize and interpret the significance of each	Group	1
annunciator or alarm.	#	
	K/A #	005G2.4.45
	Rating	4.3

GIVEN:

- The crew is performing E-1, Loss of Reactor or Secondary Coolant
- RCS pressure is 200 psig
- Readings on RM-13, RHR Exhaust Duct, radiation monitor are increasing
- RWST level is 40% and decreasing
- RHR pump amps are fluctuating
- The following alarms are received in the Control Room:

PK02-16	RHR SYSTEM
PK02-17	RHR PUMPS

Which of the following procedures will the Shift Foreman transition to from E-1?

- A. E-1.2, Post-LOCA Cooldown and Depressurization
- B. ECA-1.1, Loss of Emergency Coolant Recirculation
- C. ECA-1.2, LOCA Outside Containment
- D. ECA-1.3, Sump Blockage Guideline

## Answer: C

### **Explanation:**

- A. Incorrect RCS pressure is below 300 psig.
- B. Incorrect this is entered if both trains are unable to be aligned to the containment sump.
- C. Correct increasing radiation levels, coupled with the RHR alarms indicate a LOCA outside containment.
- D. Incorrect the sump is not blocked.

**Technical References:** E-1, steps 11 - 13 **References to be provided to applicants during exam:** None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	X
Question History:	Last NRC Exam	
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	
10CFR Part 55 Content:	55.41(10), 43(5) and 55.45(3)	

Examination Outline Cross-Reference	Level	SRO
Ability to (a) predict the impacts of the following	Tier #	2
malfunctions or operations on the DC electrical systems;	Group	1
and (b) based on those predictions, use procedures to	#	
correct, control or mitigate the consequences of those	K/A #	063 A2.02
malfunctions or operation: Loss of ventilation during	Rating	3.1
battery charging.		

Unit 1 is at 100% power.

Maintenance Service requests to work on both Auxiliary Building Switchgear Ventilation System supply and exhaust fans (S-27 and E-27)

What is the operational concern and the action the SFM should take prior to approving the maintenance request?

- A. Reduced Battery Capacity; Implement compensatory measures for blocked open doors per ECG80.1, Doors Required for HELB, HVAC ECCS Function or Flood Protection.
- B. Reduced Battery Capacity; Declare Batteries Inoperable per Tech Spec 3.8.4, DC Sources Operating
- C. Elevated Hydrogen concentration in the Vital Battery Rooms; Implement compensatory measures for blocked open doors per ECG80.1, Doors Required for HELB, HVAC ECCS Function or Flood Protection.
- D. Elevated Hydrogen concentration in the Vital Battery Rooms; Declare Batteries Inoperable per Tech Spec 3.8.4, DC Sources - Operating

## Answer: C

- A. Incorrect Battery Capacity will not be diminished but ECG is correct.
- B. Incorrect Battery Capacity will not be diminished, T/S is incorrect
- C. Correct Hydrogen concentration will increase in battery rooms without adequate ventilation, blocked open doors are controlled by ECG 80.1.
- D. Incorrect Hydrogen concentration will increase in battery rooms without adequate ventilation, but T/S is incorrect.

## **Technical References: References to be provided to applicants during exam: None Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank #	Х
	New	
Question History:	Last NRC Exam	
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.41(5), 55.43(5) and 55.45(3 & 13)	

Banked From June 2008 Exam ML -8280427

## **SRO** Question 14

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #		2
Group #		1
K/A #		063/A2.02
Importance Rating		3.1

K/A: **D.C. Electrical Distribution System** - Ability to (a) predict the impacts of the following malfunctions or operations on the D.C. Electrical System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those malfunctions or operations: Loss of ventilation during battery charging.

Proposed Question:

Unit 1 is at 100% power.

Maintenance Services requests to work on both Auxiliary Building Switchgear Ventilation system supply and Exhaust fans (S-27 and E-27).

What are the operational concerns and the response by the SFM?

- A. Elevated H<sub>2</sub> (Hydrogen) concentration in the Vital Battery Rooms; Implement compensatory measures for blocked open doors per ECG 80.1, Doors required for HELB, HVAC, ECCS Function or Flood Protection.
- B. Reduced Battery Capacity, Implement compensatory measures for blocked open

doors per ECG 80.1, Doors required for HELB, HVAC, ECCS Function or Flood Protection.

- C. Reduced Battery Capacity, Declare the batteries inoperable per Tech Spec 3.8.4, DC Sources Operating.
- D. Elevated H<sub>2</sub> (Hydrogen) concentration in the Vital Battery Rooms; Declare the batteries inoperable per tech Spec 3.8.4, DC Sources Operating.

Proposed Answer: A

Explanation:

Answer A is correct.  $H_2$  concentration will increase in the battery rooms without sufficient ventilation, compensatory action would be to open doors to provide ventilation from other systems. Blocked open doors are controlled by ECG 80.1.

Answer B is incorrect. Capacity of the battery will not be diminished, ECG is correct.

Answer C is incorrect. Capacity of the battery will not be diminished, TS is incorrect.

Answer D is incorrect.  $H_2$  concentration will increase in the battery rooms without sufficient ventilation; Batteries do not have to be declared inoperable until operational limits are exceeded, there are no limits for high temperature.

Technical Reference(s)	: LH-10 Miscellaneous Building Ventilation System, Pages 11 & 22, Rev. 4.		
	ECG 80.1, Doors required for HELB, HVAC, ECCS		
	Function, or Flood Protection, Rev. 5.		
Proposed references to	be provided to applicants during examination: NONE		
Learning Objective:	65936 - Discuss significant Technical Specifications and		
	Equipment Control Guidelines associated with the		
Miscellaneous Building Ventilation System.			
Question Source:	Bank #		
	Modified Bank # (Note changes or attach parent)		
	New X		
Question History:	Last NRC Exam N/A		
Question Cognitive Lev	vel: Memory or Fundamental Knowledge		
	Comprehension or Analysis X		
10 CFR Part 55 Content: 55.41			
55.43 2			
10 CFR Part 55 Conten	t: Facility operating limitations in the technical specifications and their bases.		
Comments:			

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Ability to interpret control room indications to verify the	Group	1
status and operations of a system, and understand how	#	
operator actions and directives affect plant and system	K/A #	003
conditions.		G2.2.44
	Rating	4.4

Unit 1 is carrying out actions of an Emergency Operating Procedure, and all RCPs are off.

The crew is making preparations to start a RCP using Attachment B, Restart of Reactor Coolant Pump. Seal cooling was lost to RCP No. 2.

The following RCP conditions exist:

	RCP No. 1	RCP No. 2	RCP No. 3	RCP No. 4
Seal D/P	Slightly low	SAT	SAT	SAT
Seal Injection Flow	SAT	Slightly high	Slightly low	SAT
Seal Leak-off	SAT	SAT	SAT	Slightly high

What direction would the SFM give to the operator that is starting the RCP?

- A. Start RCP No. 1 after lowering VCT pressure to restore Seal D/P.
- B. Start RCP No. 2 after lowering VCT pressure to restore Seal Injection Flow.
- C. Start RCP No. 3 after lowering VCT pressure to restore Seal Injection Flow.
- D. Start RCP No. 4 after lowering VCT pressure to restore Seal Leak-off.

## Answer: A

- A. Correct Pump is second in order of preference for normal PZR Spray.
- B. Incorrect Preferred pump but RCP seal cooling was lost and should not be started WITHOUT an RCP Seal Status Evaluation.
- C. Incorrect Pump is behind RCP No 1 and No.2 in starting preference.
- D. Incorrect lowering VCT pressure will raise (not lower) seal leak off flow to

normal.

## **Technical References:** EOP FR-C.1 Appendix B **References to be provided to applicants during exam:** None **Learning Objective:**

Question Source: (note changes; attach parent)	Bank # Modified Bank #	Х
F	New	
Question History:	Last NRC Exam	
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	
10CFR Part 55 Content:	55.41(5), 55.43(5) and 55.45(12)	

### *Modified from FEB 2005* - ML 050890447

### **Question Worksheet**

Examination Outline Cross-Reference:

Level	RO	SRO
Tier #		2
Group #		1
K/A #	003	
	A2.05	
Importance		2.8
	Level Tier # Group # K/A # Importance	Level RO Tier # Group # K/A # 003 A2.05 Importance

### **Proposed Question:** SRO 86

The crew is making preparations to start a RCP using Attachment B in E-0.2, "Natural Circulation Cooldown". The CO reports Seal Leakoff flow is low. All other conditions for starting the RCP are met.

Which of the following actions should the SFM direct the operator to perform?

A. Start the RCP.

B. Increase VCT level.

C. Increase charging flow.

D. Decrease VCT pressure.

### Proposed Answer:

D. Decrease VCT pressure.

A incorrect, this is not a procedure in which RCPs are started if normal conditions are not met.

B incorrect, increasing VCT level will increase VCT pressure, which will further decrease seal leakoff flow.

C incorrect, increasing charging will not affect appreciably affect seal leakoff. D correct, decreasing VCT pressure will decrease the DP and increase seal leakoff flow.

Technical Reference(s):

E-0.2, Natural Circulation Cooldown, attachment B, Restart of Reactor Coolant Pump Proposed references to be provided to applicants during examination: none Learning Objective: 4892 - State the cause/effect relationship between VCT and RCPs sro tier 2 group 1\_86.doc **Question Source:** New X Question History: Last NRC Exam N/A Question Cognitive Level: Memory or Fundamental Knowledge Comprehension or Analysis X 10 CFR Part 55 Content: 55.41 41.5 55.43 43.5 Comments: K/A: 003 A2.05 – Reactor Coolant Pump - Ability to (a) predict the impacts of the following malfunctions or operations on the RCPS; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those malfunctions or

operations: Effects of VCT pressure on RCP seal leakoff flows

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Ability to (a) predict the impacts of the following	Group	2
malfunctions or operations on the NIS: and (b) based on	#	
those predictions, use procedures to correct, control, or	K/A #	015 A2.01
mitigate the consequences of those malfunctions or	Rating	3.9
operations: Power supply loss or erratic operation.		

A plant startup is in progress. Power is 3%.

The operator reports all Channel I bistable lights are out and Channel IV bistable lights are lit.

Which of the following actions will be taken by the Shift Foreman?

- A. Enter E-0, Reactor Trip or Safety Injection due to an Intermediate Range high flux trip.
- B. Go to OP AP-4, Loss of Vital or Non-vital Instrument AC, due to the loss of PY-11.
- C. Enter E-0, Reactor Trip or Safety Injection due to the loss of the Source Range block signal, causing the Source Ranges to energize and cause a trip on high flux.
- D. Go to OP AP-4, Loss of Vital or Non-vital Instrument AC, due to the loss of PY-14.

Answer: D. similar to 51

- A. Incorrect no IR channels off PY-14. Powered from PY-11 and 12.
- **B. Incorrect** bistable lights on Channel I are out because of a loss of power from Channel IV. PY-11 is still powered.
- **C. Incorrect** PY-14 loss will cause Source Ranges to energize, however, the trip is blocked.
- **D.** Correct- PY-14 powers PY-11 bistable lights, causes PR N44 to fail low, however, no trip occurs. The appropriate action is to go to AP-4 and take action to re-energize the PY.

## **Technical References: OP AP-4, LPA-4 References to be provided to applicants during exam:** None **Learning Objective:** 4274 - Explain the consequences of loss of vital instrument bus.

Question Source: (note changes; attach	Bank # Modified Bank #		
parent)	New	Х	
Question History:	Last NRC Exam	No	
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.43 (5)	Х	

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Malfunctions or operations on the HRPS; and (b) based on	Group	2
those predictions, use procedures to correct, control or	#	
mitigate the consequences of those malfunctions or	K/A #	028 A2.02
operations: LOCA condition and related concern over	Rating	3.9
hydrogen		

GIVEN:

- A large break LOCA occurred 2 hours ago
- Hydrogen concentration inside Containment as measured on PAM 1 is 1.6%
- EOP E-1, Loss of Reactor or Secondary Coolant, is being performed

Which of the following supplemental procedures to E-1 will be used to place the Containment Hydrogen Recombination System in service and who is responsible for directing this system be placed in service?

NOTE:

OP H-8, Containment Hydrogen Purge System OP H-9, Inside Containment Hydrogen Recombination System

- A. OP H-8; Shift Foreman
- B. OP H-9; TSC (Site Emergency Coordinator)
- C. OP H-8; TSC (Site Emergency Coordinator)
- D. OP H-9; Shift Foreman

Answer: B

- A. Incorrect
- B. Correct EOP E-1 step 19 directs operators to OP H-9 if hydrogen concentration is more than .5%. OP H-9 states that the IHRS is ONLY placed in service upon direction of the TSC and the Site Emergency Coordinator.
- C. Incorrect

## **D.** Incorrect

## Technical References: EOP E-1 (Loss of Reactor or Secondary Coolant), OP H-9 (Inside Containment H2 Recombination System) References to be provided to applicants during exam: None Learning Objective: To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	
parenty	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.43 (5)	Х

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Ability to analyze the effect of maintenance activities, such	Group	2
as degraded power sources, on the status of limiting	#	
conditions for operations.	K/A #	068 2.2.36
	Rating	4.2

The liquid radwaste effluent radiation monitor is to be removed from service for calibration. No discharges are in progress.

Which of the following describe the action, if any, that will be taken by the crew?

- A. Declare the monitor inoperable when it is removed from service.
- B. No action is required because there are no releases planned or in progress.
- C. No action required unless the monitor fails its calibration, then it must be declared inoperable.
- D. No action is required because ECG 39.3, NOTE A allows releases to occur for 14 days before having to declare the monitor inoperable and applying the Required Actions of Condition A.

## Answer: A

## **Explanation:**

This question is designed to test a problem that occurred at the plant. A gaseous rad monitor was removed from service multiple times without being declared inoperable because of the mistaken understanding that if there was no release planned/in progress the ECG did not apply. (Notification 50254364)

- **A.** Correct the 14 day clock starts when the monitor is removed from service, regardless of the status of any planned release.
- **B.** Incorrect the monitor is inoperable immediately.
- **C. Incorrect** the monitor is inoperable when removed from service.
- **D. Incorrect** its possible to read the note and think that as long as samples are processed correctly for 14 days there is no further action, and the 14 completion time of Condition A would start after the 14 days of Note A.

Technical References: ECG 39.3 pages 1 and 4, notification 50254364 (07/2009)

**Comment [g4]:** ANO THER discharge question. I think there is one similar written by Sean. This may need to be replaced.

# **References to be provided to applicants during exam:** ECG 39.3 **Learning Objective:** To be determined

Question Source: (note changes; attach	Bank # Modified Bank #		
parent)	New	Х	
Question History:	Last NRC Exam	No	
Question Cognitive Level: 10CFR Part 55 Content:	Memory/Fundamental Comprehensive/Analysis 55.43 (2)	Х	

Examination Outline Cross-Reference	Level	SRO
	Tier #	3
Ability to use procedures related to shift staffing, such as	Group #	1
minimum crew complement, overtime limitations, etc.	K/A #	2.1.5
	Rating	3.9
Question 94		

Comment [g5]: Repla ce this?

Unit 2 is in MODE 6 and Unit 1 is in MODE 5.

The Shift Foreman is developing the list of qualified personnel for the upcoming shift.

Is a Health Physics Technician and Shift Technical Advisor required for the current plant conditions?

	Health Physics Technician	Shift Technical Advisor
A.	No	Yes
B.	Yes	No
C.	Yes	Yes
D.	No	No

Answer: B

**Explanation:** 

- A. Incorrect
- B. Correct T.S. 5.2.2 (Unit Staff) requires a Health Physics Technician any time that fuel is in the core, which meets the current plant condition. A Shift Technical Advisor is required in MODES 1, 2, 3, and 4 only.
- C. Incorrect
- **D.** Incorrect

**Technical References: T.S. 5.2.2 References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source:	Bank #	
(note changes; attach	Modified Bank #	
parent)	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.43(2)	

Examination Outline Cross-Reference	Level	SRO
	Tier #	3
Ability to make accurate, clear, and concise verbal reports.	Group	1
	#	
	K/A #	2.1.17
	Rating	4.0

If the Shift Foreman has deviated from a license condition or Technical Specification in order to protect public health and safety in the event of an emergency, what would be the time requirement to report such the deviation to the NRC?

- A. 15 minutes
- B. 30 minutes
- C. 1 hour
- D. 4 hours

Answer: C

## **Explanation:**

- A. Incorrect
- **B.** Incorrect
- C. Correct 10CFR50.72(5)(b) directs a licensee to report within one hour if that licensee has departed from a license condition or technical specification pursuant to 10CFR50.54(x).
- **D.** Incorrect

**Technical References: 10CFR50.72(5)(b) References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source:		Bank #
	(note changes; attach	Modified Bank #
parent)		

New

Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	х
10CFR Part 55 Content:	55.43 (5)	

Examination Outline Cross-Reference	Level	SRO
	Tier #	3
Knowledge of the process for controlling equipment	Group	2
configuration or status.	#	
	K/A #	2.2.14
	Rating	4.3
Question 96		

Prior to the Shift Foreman approving an Emergent Temporary Modification (TMOD) which of the following must occur?

- A. A LBIE must be performed
- B. Engineering approval obtained
- C. An Operability Determination must be performed
- D. Engineering Director (or designee) approval obtained

### Answer: A

### **Explanation:**

- A. Correct per step 5.2.4, the Emergent TMOD process is used when requested by the SFM. The process requires the SFM document why the TMOD is required prior to engineering evaluation (attachment 4). An LBIE is performed prior to approval
- **B.** Incorrect engineering reviews as soon as possible.
- C. Incorrect Oper. Determination not applicable to TMODs.
- **D. Incorrect** Engineering director responsible for reviewing and obtaining approval for any TMOD to remain installed past a refueling outage.

## **Technical References: CF4.ID7 pages 20, attachment 2 and 4 References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: Bank # (note changes; attach Modified Bank # parent) **Comment [g6]:** RO question. Replace.

	New	-	X
Question History:	Last NRC Exam	١	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis 55.43 (3)		X
Examination Outline Cross-Re	ference	Level	SRO
		Tier #	3
Knowledge of the bases in Technical Specifications for limiting conditions for operations and safety limits.		Group	2
		#	
		K/A #	2.2.25
		Rating	4.2

Which of the following is the reason the minimum CST level required to satisfy Technical Specification 3.7.6, Condensate Storage Tank, is higher for one unit than it is for the other unit?

- A. Unit 1 requires a higher level because the assumed natural circulation cooldown rate to 350°F is half of the cooldown rate assumed for Unit 2.
- B. Unit 2 requires a higher level because the assumed natural circulation cooldown rate to 350°F is half of the cooldown rate assumed for Unit 1.
- C. Unit 1 requires a higher level because the assumed natural circulation cooldown rate to less than 200°F is half of the cooldown rate assumed for Unit 2.
- D. Unit 2 requires a higher level because the assumed natural circulation cooldown rate to 200°F is half of the cooldown rate assumed for Unit 1.

## Answer: A

## **Explanation:**

A. Correct – Bases for 3.7.6 states: For Unit 1 with a Thot upper head design, the analysis for CST minimum required storage assumes the unit is held in MODE 3 for 1 hour followed by an 8-hour cooldown to RHR entry conditions at a reduced cooldown rate of 25°F/hour. For Unit 2 with a Tcold upper head design, the analysis for CST minimum required storage assumes the unit is held in MODE 3 for 2 hours followed by a 4-hour cooldown to RHR entry conditions at a cooldown rate of 50°F/hour

- **B.** Incorrect The opposite is true.
- C. Incorrect cooldown is only until RHR can be placed in service.
- **D.** Incorrect cooldown only until RHR and higher for Unit 1.

## **Technical References:** T.S. 3.7.6. B3.7.6 **References to be provided to applicants during exam:** None **Learning Objective:** 9694G, Discuss 3.7 Technical Specification bases

Question Source: (note changes; attach	Bank # Modified Bank #	
parent)	New	Х
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	Х
10CFR Part 55 Content:	55.43 (2)	

Examination Outline Cross-Reference	Level	SRO
	Tier #	3
Ability to approve release permits.	Group	3
	#	
	K/A #	2.3.6
	Rating	3.8

A discharge of Gas Decay Tank 1-2 is planned.

### GIVEN:

- Current time and date 2200, 17 July
- RE-22 declared inoperable at 0100 on 3 July
- The planned discharge will take 4 hours
- 2 samples have been independently drawn and analyzed
- Release rate calculations have been independently verified

Which of the following describes whether the planned discharge may or may not occur?

- A. The planned discharge may proceed in its entirety.
- B. The discharge may occur, but only for 3 hours, then it must be terminated.
- C. The planned discharge may not occur until RE-22 is restored to OPERABLE status.
- D. The discharge may not proceed because during the discharge, the allowable time RE-22 may be inoperable will expire.

## Answer: C

- A. Incorrect –Discharge not allowed by OP-G-2:V step 6.1.7
- B. Incorrect The allowable outage time (14 days) has ALREADY expired. This is a credible distracter because <u>if</u> RE-22 was declared inoperable at 0100 on <u>4</u> July, OP G-2:V step 6.1.6 would allow 3 hours of discharge.
- C. Correct as of 0100 on 17 July, the 14 days allowed by ECG (and procedure OP G- 2:V step 6.1.7) has been exceeded. A discharge is not allowed.
- D. Incorrect The allowable outage time (14 days) has ALREADY expired.

**Technical References:** ECG 39.4, OP G-2:V, Gaseous Radwaste System – Gas Decay Tank Discharge **References to be provided to applicants during exam:** OP G-2:V ECG 39.4 **Learning Objective:** To be determined

Question Source: (note changes; attach	Bank # Modified Bank #	Х
parent)	New	
Question History:	Last NRC Exam	No
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis	
10CFR Part 55 Content:	55.41(13), 43(4), 45(10)	

## SRO Question 98 ML050890447 02/2005 Exam Question Worksheet

**Examination Outline Cross-Reference:** 

	Level	RO	SRO
	Tier #		3
	Group #		3
	K/A #		G2.3.8
	Importance		3.2
-			

### **Proposed Question**:

A discharge of Gas Decay Tank 1-2 is planned.

The current conditions exist:

- Current time and date 2200, 17 July
- RE-22 declared inoperable at 0100 on 3 July
- The planned discharge will take 4 hours
- 2 samples have been independently drawn and analyzed

Which of the following describes whether the planned discharge may or may not occur?

- A. The planned discharge may not occur until RE-22 is restored to OPERABLE status.
- B. The planned discharge may proceed in its entirety.
- C. The discharge may occur, but only for 3 hours, then it must be terminated.
- D. The discharge may not proceed because during the discharge the allowable time RE-22 may be inoperable will expire.

Proposed Answer: A. The planned discharge may not occur until RE-22 is restored to OPERABLE status.

## Explanation:

- A. Correct, as of 0100 on 17 July, the 14 days allowed by ECG (and procedure OP G- 2:V) has been exceeded. A discharge is not allowed.
- B. Incorrect, 14 days exceeded.
- C. Incorrect, 14 days already exceeded.
- D. Incorrect, if there is time available, the discharge could have continued for a short period of time.

Technical Reference(s): ECG 39.4 OP G-2:V, Gaseous Radwaste System – Gas Decay Tank Discharge

Proposed references to be provided to applicants during examination: OP G-2:V ECG 39.4

Learning Objective: 7428 - State gaseous radwaste system administrative controls 66068 - Discuss the requirements of System 39 ECGs.

Question Source: New X Question History: Last NRC Exam N/A

Examination Outline Cross-Reference	Level	SRO
	Tier #	2
Knowledge of EOP terms and definitions.	Group	4
	#	
	K/A #	2.4.17
	Rating	4.3

What is meant by the term "Hot Dry" Steam Generator?

- A. Primary Side Temperature >543°F and Wide Range level is less than 10% (18%).
- B. Primary Side Temperature >550°F and Wide Range level is less than 10% (18%).
- C. Primary Side Temperature >581°F and AFW flow has been isolated to the steam generator for an hour or longer.
- D. Primary Side Temperature >635°F and AFW flow has been isolated to the steam generator for an hour or longer.

### Answer: B

### **Explanation:**

A. Incorrect. This is Lo Tave. Second part correct.

- B. Correct. Section 2.4 EOP background for FR-H.1.
- C. Incorrect. This is DNB limit (T/S 3.4.1/COLR) temperature and Feed & Bleed initiation criteria for level.
- D. Incorrect. This 100% Tave Safety Limit and Feed & Bleed initiation criteria for level.

**Technical References:** FR-H.1 Background, FR-H.1 foldout page **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source:	Bank #	
(note changes; attach	Modified Bank #	
parent)	N	V
	New	Х
Question History:	Last NRC Exam	No

**Question Cognitive Level:** 

**10CFR Part 55 Content:** 

Memory/Fundamental Comprehensive/Analysis 55.41(10) 43(13)

Examination Outline Cross-Reference	Level	SRO
	Tier #	3
Knowledge of the basis for prioritizing safety functions	Group	4
during abnormal/emergency operations.	#	
	K/A #	2.4.22
	Rating	4.4

The control room operators have entered EOP FR-H.1 "Response to Loss of Secondary Heat Sink."

The Emergency Evaluation Coordinator (EEC) identifies a RED path on the "Integrity" Critical Safety Function Status Tree.

The Shift Foreman should:

- A. Continue with FR-H.1, it is a higher priority than RCS Integrity.
- B. GO TO FR-P.1, RCS Integrity is a higher priority than H.1.
- C. Implement FR-P.1 while continuing in FR-H.1; to minimize cooldown caused by FR-H.1 actions.

D. Immediately return to Step 1 of FR-H.1, to reassess secondary conditions. Answer: A

### **Explanation:**

- A. Correct. FR H.1 is a higher priority than FR-P.1, higher priority CSFSTs are always continued unless a higher priority challenge is identified. Fuel and Cladding Integrity are a higher priority for protection against radiation releases.
- B. Incorrect. FR P.1 is not a higher priority FRG, it is lower. FR-P.1 actions will be addressed when FR-H.1 actions are completed.
- C. Incorrect. FR-P.1 actions are not done in parallel with FR-H.1 actions; this is not allowed per rules of usage.
- D. Incorrect. Returning to step 1 is not required when FR-P.1 conditions are met.

**Technical References:** F-0 Critical Safety Functions Background Section 1.2 **References to be provided to applicants during exam:** None **Learning Objective:** To be determined

Question Source: (note changes; attach parent)	Bank # Modified Bank #	Х	
	New		
Question History:	Last NRC Exam	No	
Question Cognitive Level:	Memory/Fundamental Comprehensive/Analysis		
10CFR Part 55 Content:	55.41(7 and 10), 43(5) and 45(12)		
NRC Form ES-401-5 Written Examination Questic	June 2008 DCPP on Worksheet	ML0912	270008
Examination Outline Cross-Reference	ce:		
	Level Tier # Group # K/A #	RO	SRO 3 N/A G 2.4.23 4 4
	Rating		4.4

K/A: **Generic** - Emergency Procedures/Plan: Knowledge of the bases for prioritizing emergency procedure implementation during emergency operations.

Proposed Question:

The control room operators have entered EOP FR-H.1 "Response to Loss of Secondary Heat Sink," due to red path on the Heat Sink Critical Safety Function Status Tree. The Emergency Evaluation Coordinator (EEC) identifies a red path on the "Integrity" Critical Safety Function Status Tree.

The Shift Foreman should:

- A. NOTE FR-P.1 Response to Imminent Pressurized Thermal Shock Condition. Continue with FR-H.1, Fuel/Cladding Integrity is a higher priority than RCS Integrity.
- B. GO TO FR-P.1, RCS Integrity is a higher priority than Fuel/Clad Integrity.
- C. Implement FR-P.1 while continuing in FR-H.1; to minimize cooldown caused by FR-H.1 actions.
- D. Immediately return to Step 1 of FR-H.1, to reassess secondary conditions.

Proposed Answer: A

## Explanation:

- A. Answer A is correct. FR H.1 is a higher priority than FR-P.1, higher priority CSFSTs are always continued unless a higher priority challenge is identified. Fuel and Cladding Integrity are a higher priority for protection against radiation releases.
- B. Answer B is incorrect. FR P.1 is not a higher priority FRG, it is lower. FR-P.1 actions will be addressed when FR-H.1 actions are completed.
- C. Answer C is incorrect. FR-P.1 actions are not done in parallel with FR-H.1 actions; this is not allowed per rules of usage.
- D. Answer D is incorrect. Returning to step 1 is not required when FR-P.1 conditions are met.

Technical Reference(s): LPE-FR, Functional Restoration Guidelines, Page 5, Rev. 8. EOP F-0, Critical Safety Function Status Trees, Page 2 & 3, Rev. 14.

Proposed references to be provided to applicants during examination: NONE

Learning Objective: 38107 - Apply the Rules of Usage in EOPs for the CSFSTs and FRGs, including: the priority of use of the six CSFSTs

Question Source: New Bank # Modified Bank # INPO - 20219 (Note changes or attach parent)

Question History: Last NRC Exam N/A Question Cognitive Level: Memory or Fundamental Knowledge Comprehension or Analysis X 10 CFR Part 55 Content: 55.41 55.43 5

10 CFR Part 55 Content: Assessment of facility conditions and selection of appropriate procedures during normal, abnormal, and emergency situations.

Comments: