



CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>inoperable in MODE 1.</p>		<p>exceed 30 days]</p>
<p>D. -----NOTE----- Separate Condition entry is allowed for each MSIV. -----  One or more MSIVs inoperable in MODE 2 or 3.</p>	<p>D.1 Close MSIV.  <u>AND</u>  D.2 Verify MSIV is closed.  [Reviewer's Note: Below applicable to TSTF 505  OR  D.3.1 Establish a RICT  <u>AND</u>  D.3.2 Restore MSIV(s) to OPERABLE status.</p>	<p>[8] hours  Once per 7 days following closure    [8] Hours   In accordance with the Risk Informed Completion Time Program, not to exceed 30 days]</p>
<p>E. Required Action and associated Completion Time of Condition C or D not met.</p>	<p>E.1 Be in MODE 3.  <u>AND</u>  E.2 Be in MODE 4.</p>	<p>6 hours    12 hours</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.7.2.1</p> <p>-----NOTE----- Only required to be performed in MODES 1 and 2. -----</p> <p>Verify isolation time of each MSIV is <math>\leq</math> [6] seconds.</p>	<p>In accordance with the Inservice Testing Program</p>
<p>SR 3.7.2.2</p> <p>-----NOTE----- Only required to be performed in MODES 1 and 2. -----</p> <p>Verify each MSIV actuates to the isolation position on an actual or simulated actuation signal.</p>	<p>[18] months</p>