



NOTES:
 1. HS-67-295B, 296B, 297B & 298B ARE DISCONNECTED TO PREVENT UNADVERTISED ACTIVATION OF ASSOCIATED VALVES.
 2. UNIT 2 VALVES (2-FCV-67-123, 124, 125 AND 126) ARE IN THE CLOSED POSITION WITH POWER ADMINISTRATIVELY LOCKED OUT AT THE MOTOR CONTROL CENTER.
 3. ORIFICE PLATE REPLACED BY BLIND PLATE.
 4. BLIND PLATE INSTALLED.
 5. BLIND PLATE INSTALLED.
 SYMBOLS:
 IP --- DENOTES SAFETY RELATED UNIT 1/2 INTERFACE POINTS

THIS CONFIGURATION CONTROL DRAWING SUPERSEDES UNIT 1 AS-CONSTRUCTED DRAWING 47W610-67-3 REVISION K.

7	ADMIN	RWE	JKA	<i>[Signature]</i>	10/19/98
REVISED TO CORRECT DISCREPANCY IDENTIFIED BY PER 204497 (171 091014 800).					
REV	CHANGE REF	PREPARER	CHECKER	APPROVED	DATE
SCALE: NTS					EXCEPT AS NOTED

PROJECT FACILITY
 POWERHOUSE
 UNIT 2
 TITLE
ELECTRICAL CONTROL DIAGRAM
ERCW SYSTEM

1	WATTS BAR NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY			Q
DESIGN	INITIAL ISSUE	ENGINEERING APPROVAL		
DRAFTER C.N. CLABOUGH	CHECKER S.E. MINOR	RO ISSUE PER WBP 5.17, RIMS B26 '90 0110 375	1 H.E. JERMAKOWITZ	
DESIGNER M.L. CHAPMAN	REVIEWER J.F. EDWARDS	DATE 1-31-90	85	E
DATE		1-47W610-67-3A		R7

COMPANION DRAWINGS:
 47W610-67-1, 1A, 2, 2A, 3, 4, 5, 5A, 6
 FSAR ISSUED BY: R.M. JOHNSON