



NOTES:  
 1. HS-67-295B, 296B, 297B & 298B ARE DISCONNECTED TO PREVENT UNADVERTISED ACTIVATION OF ASSOCIATED VALVES.  
 2. UNIT 2 VALVES (2-FCV-67-123, 124, 125 AND 126) ARE IN THE CLOSED POSITION WITH POWER ADMINISTRATIVELY LOCKED OUT AT THE MOTOR CONTROL CENTER.  
 3. ORIFICE PLATE REPLACED BY BLIND PLATE.  
 4. BLIND PLATE INSTALLED.  
 SYMBOLS:  
 (112) --- DENOTES SAFETY RELATED UNIT 1/2 INTERFACE POINTS

THIS CONFIGURATION CONTROL DRAWING SUPERSEDES UNIT 1 AS-CONSTRUCTED DRAWING 47W610-67-3 REVISION K.

7	ADMIN	RWE	JKA	<i>[Signature]</i>	10/19/2008
REVISED TO CORRECT DISCREPANCY IDENTIFIED BY PER 204497 (171 091014 800).					
REV	CHANGE REF	PREPARER	CHECKER	APPROVED	DATE
SCALE: NTS					EXCEPT AS NOTED

PROJECT FACILITY  
 POWERHOUSE  
 UNIT 2  
 TITLE  
**ELECTRICAL CONTROL DIAGRAM**  
**ERCW SYSTEM**

1	WATTS BAR NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY			Q
DESIGN	INITIAL ISSUE	ENGINEERING APPROVAL		
DRAFTER C.N. CLABOUGH	CHECKER S.E. MINOR	RO ISSUE PER WBP 5.17, RIMS B26 '90 0110 375	1 H.E. JERMAKOWITZ	
DESIGNER M.L. CHAPMAN	REVIEWER J.F. EDWARDS	DATE 1-31-90	85	E
DATE		1-31-90		85
DATE		1-31-90		85

COMPANION DRAWINGS:  
 47W610-67-1, 1A, 2, 2A, 3, 4, 5, 5A, 6  
 FSAR ISSUED BY: R.M. JOHNSON