



NOTES:
 1. FCV-87-BY AND FCV-87-BZ ARE ADMINISTRATIVELY LOCKED IN THE OPEN POSITION AT MOTOR CONTROL CENTER. BREAKER IS SET IN TRIP POSITION TO PREVENT UNAUTHORIZED OPERATION.

NOTES:
 1. REFER TO TABLE AS FOR ADDITIONAL DIGITAL COMPUTER POINTS (POWER AVAILABLE, PUMP RUNNING, ETC.)
 2. VALVE INTERNALS REMOVED. BLIND PLATE INSTALLED.

SYMBOLS:
 (I) --- DENOTES SAFETY RELATED UNIT 1/2 INTERFACE POINTS
 COMPANION DRAWINGS: 47W610-67-1, 2, 3, 3A, 4, 5, 5A, 6

THIS CONFIGURATION CONTROL DRAWING SUPERSEDES UNIT 1 AS-CONSTRUCTED DRAWING 47W610-67-2 REVISION L

8	52283	ESJ	GJB	JJA	3-5-99
REVISED PER DCA'S 52283-213-0 THRU -218-0.					
REV	CHANGE REF	PREPARER	CHECKER	APPROVED	DATE
					EXCEPT AS NOTED

PROJECT FACILITY
 POWERHOUSE
 UNIT 2

TITLE
**ELECTRICAL CONTROL DIAGRAM
 ERCW SYSTEM**

1 WATTS BAR NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY Q

DESIGN	INITIAL ISSUE	ENGINEERING APPROVAL
DRAFTER C.N. CLABOUGH	CHECKER S.E. MINOR	RO ISSUE PER WBEP 5.17 & RIMS B26 '90 0110 375
DESIGNER M.L. CHAPMAN	REVIEWER J.F. EDWARDS	1 H.E. JERMAKOWITZ 2 H.E. JERMAKOWITZ 3 M.C. BRICKEY

DATE 1-31-90 85 E 1-47W610-67-2A R8

ISSUED BY: R.M. JOHNSON

FSAR PRINTS REQ'D R