

PUBLIC SUBMISSION

As of: August 17, 2010 Received: August 13, 2010 Status: Pending_Post Tracking No. 80b3036d

Comments Due: August 13, 2010 Submission Type: Web

Docket: NRC-2010-0202

Draft Regulatory Guide: Issuance, Availability

Comment On: NRC-2010-0202-0001

Draft Regulatory Guide: Issuance, Availability

Document: NRC-2010-0202-DRAFT-0009 Comment on FR Doc # 2010-14339 RULES AND DIRECTIVES
BRANCH
USNRC

2810 AUG 17 AM II: 38

Submitter Information

Name: J. Vandenbroek

General Comment

DG-1240 uses the word "qualified" twice. Please reword. The term "qualified" only has meaning in the context of the EQ rule. Except for EQ rule qualification, cables have never been "qualified," so the use of the term in this context is incorrect.

50NSIR eview Complier
Templace = ADM-213

Cold = R.A. Garrey (195) M. Care (m5C)