

6/15/2010  
To FR 33853 (9)

# PUBLIC SUBMISSION

As of: August 17, 2010  
Received: August 13, 2010  
Status: Pending\_Post  
Tracking No. 80b3036e  
Comments Due: August 13, 2010  
Submission Type: Web

**Docket:** NRC-2010-0202  
Draft Regulatory Guide: Issuance, Availability

**Comment On:** NRC-2010-0202-0001  
Draft Regulatory Guide: Issuance, Availability

**Document:** NRC-2010-0202-DRAFT-0010  
Comment on FR Doc # 2010-14339

RECEIVED

2010 AUG 17 AM 11:38

RULES AND DIRECTIVES  
BRANCH  
USNRC

## Submitter Information

**Name:** J. Vandenbroek

## General Comment

"Eventually, power and control cables that are not designed to operate in a submerged state will experience early failures, often resulting in significant safety consequences."

1. Please review the GL2007-01 data to support the term "often resulting in significant safety consequences." I submit that there have been NO significant safety consequences from the reported cable failures. If there have, I submit that the failure have been "seldom." If no significant safety consequences HAVE resulted, please change the text to reflect this fact.
2. "Eventually," ...."will experience early failures." These two terms contradict each other.
3. The question is not "will a submerged cable fail sooner than a dry cable," but "will a submerged cable remain Operable throughout its [40 year] design life."
4. Please supply support for the contention that control cables (low voltage) will fail early when submerged. I believe that this is supposition rather than fact.

*SOVSI Review Complete  
Template = ADM-013*

*FRIDS = ADM-03  
Cde = R.A. Jervey (R95)  
m. Cue (m.5c)*