

Dominion Nuclear Connecticut, Inc.
Millstone Power Station
Rope Ferry Road
Waterford, CT 06385



DominionSM

AUG 13 2010

Attn: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Serial No. 10-482
MPS Lic: GJC R0
Docket Nos. 50-423
License Nos. NPF-49

DOMINION NUCLEAR CONNECTICUT, INC.
MILLSTONE POWER STATION UNIT 3
SPECIAL REPORT FOR INOPERABLE METEOROLOGICAL
TOWER WIND SPEED AND DIRECTION INSTRUMENTATION

Pursuant to reporting requirements of the Millstone Power Station Unit 3 (MPS3) Technical Specifications (TS) Administrative Control section 6.9.2, Dominion Nuclear Connecticut, Inc. (DNC) hereby submits a Special Report for the number of operable meteorological monitoring channels less than required by Technical Requirements Manual (TRM) Table 3.3.3.4-1. The TRM states that with one or more required meteorological monitoring channels inoperable for more than 7 days, prepare and submit a Special Report to the Commission within the next 10 days outlining the cause of the malfunction and the plans for restoring the channel(s) to OPERABLE status.


On July 30, 2010 at 0157, instrumentation related to wind speed at the 142 foot level (WS-142) of the Millstone Meteorological Tower was declared inoperable when the instrument failed to meet the acceptance criteria during surveillance testing. The cause of the instrument malfunction is currently unknown. Subsequently, on August 5, 2010 at 0857, instrumentation related to wind direction at the 374 foot level (WD-374) and wind direction at the 33 foot level (WD-33) failed and was also declared inoperable. Although the cause of the failures is not definitively known at this time, severe thunderstorms were in the area and several lightning strikes were noted. Since these instruments are not expected to be repaired within the TRM requirement of 7 days, they are included in this report.

The instrumentation repairs/replacement, and testing is currently scheduled to be completed by the week ending August 20, 2010. This schedule is contingent on the known scope of repairs, availability of parts, and the availability of qualified climbers. The actions associated with the restoration the WS-142 instrumentation as well as the WD-374 and WD-33 instrumentation are being tracked by DNC's corrective action program.

IE22
NRK

If you have any questions or require additional information, please contact
Mr. William D. Bartron at (860) 444-4301.

Sincerely,



A. J. Jordan
Site Vice President – Millstone

Attachments: None

Commitments made in this letter: None

cc: U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406-1415

C. J. Sanders
Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Mail Stop 08B3
Rockville, MD 20852-2738

NRC Senior Resident Inspector
Millstone Power Station