



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
WASHINGTON, DC 20555 - 0001**

August 25, 2010

MEMORANDUM TO:           ACRS Members

FROM:                       Sherry Meador                       */RA/*  
                                  Technical Secretary, ACRS

SUBJECT:                    CERTIFICATION OF THE MEETING MINUTES FROM  
                                  THE ADVISORY COMMITTEE ON REACTOR  
                                  SAFEGUARDS 564<sup>th</sup> FULL COMMITTEE MEETING  
                                  HELD ON JULY 8-10, 2009 IN ROCKVILLE, MARYLAND

The minutes of the subject meeting were certified on July 22, 2009 as the official record of the proceedings of that meeting. A copy of the certified minutes is attached.

Attachment:  
As stated



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
WASHINGTON, DC 20555 - 0001

July 22, 2009

MEMORANDUM TO: Sherry Meador, Technical Secretary  
Advisory Committee on Reactor Safeguards

FROM: Cayetano Santos, Chief */RA/*  
Reactor Safety Branch  
Advisory Committee on Reactor Safeguards

SUBJECT: MINUTES OF THE 564<sup>th</sup> MEETING OF THE ADVISORY  
COMMITTEE ON REACTOR SAFEGUARDS (ACRS),  
JULY 8-10, 2009

I certify that based on my review of the minutes from the 564<sup>th</sup> ACRS Full Committee meeting, and to the best of my knowledge and belief, I have observed no substantive errors or omissions in the record of this proceeding subject to the comments noted below.

|        |            |             |
|--------|------------|-------------|
| OFFICE | ACRS       | ACRS:RSB    |
| NAME   | SMeador    | CSantos/sam |
| DATE   | 07/ 22 /09 | 07/ 22 /09  |

OFFICIAL RECORD COPY

CERTIFIED

Date Certified: 07/22/2009

TABLE OF CONTENTS  
MINUTES OF THE 564<sup>th</sup> ACRS MEETING

July 8-10, 2009

- I. Opening Remarks by the ACRS Chairman (Open)
- II. License Renewal Application and the Final Safety Evaluation Report (SER) for the Beaver Valley Power Station (Open)
- III. Draft Final Revision 3 to Regulatory Guide 1.100, "Seismic Qualification of Electric and Mechanical Equipment for Nuclear Power Plants" (Open)
- IV. Applicability of TRACE Code to Evaluate New Light Water Reactor (LWR) Designs (Open/Closed)
- V. Format and Content of the Biennial Research Report to the Commission on the NRC Safety Research Program (Open)
- VI. Design Certification (DC)/Combined License (COL) Interim Staff Guidance (ISG) -006 and Nuclear Energy Institute (NEI) document NEI 08-08, Revision 1 (Open)
- VII. Draft Final Regulatory Guide 1.215, "Guidance for ITAAC Closure under 10 CFR Part 52" (Open)
- VIII. Quality Assessment of Selected Research Projects (Open)
- IX. Subcommittee Reports (Open)
- X. Executive Session (Open)
  - A. Reconciliation of ACRS Comments and Recommendations
  - B. Report on the Meeting of the Planning and Procedures Subcommittee Held on Wednesday July 7, 2009

**Appendices**

- Appendix I – *Federal Register* Notice
- Appendix II – Meeting Schedule and Outline
- Appendix III – Attendance List
- Appendix IV – Future Agenda
- Appendix V – List of Meeting Handouts

During its 564<sup>th</sup> meeting, July 8-10, 2009, the Advisory Committee on Reactor Safeguards (ACRS) discussed several matters and completed the following report, letters, and memoranda:

### REPORT

Report to Gregory B. Jaczko, Chairman, NRC, from Mario V. Bonaca, Chairman, ACRS:

- Draft Final Regulatory Guide 1.215, "Guidance for ITAAC Closure Under 10 CFR Part 52," dated July 24, 2009

### LETTERS

Letters to R. W. Borchardt, Executive Director for Operations, NRC, from Mario V. Bonaca, Chairman, ACRS:

- Draft Template NEI-08-08, "Generic FSAR Template Guidance for Life Cycle Minimization of Contamination," and Draft DC/COL- Interim Staff Guidance - 06, dated July 22, 2009
- Draft Final Revision 3 to Regulatory Guide 1.100, "Seismic Qualification of Electrical and Active Mechanical Equipment and Functional Qualification of Active Mechanical Equipment for Nuclear Power Plants," dated July 27, 2009
- Applicability of TRACE Thermal-Hydraulic System Analysis Code to Evaluate the ESBWR Design and Related Matters, dated July 29, 2009

### MEMORANDA

Memoranda to R. W. Borchardt, Executive Director for Operations, NRC, from Edwin M. Hackett, Executive Director, ACRS:

- Supplement 1 to NUREG-1907, "Safety Evaluation Report Related to License Renewal of Vermont Yankee Nuclear Power Station," dated July 15, 2009
- Letter From Citizen Power and Beyond Nuclear Concerning the License Renewal for the Beaver Valley Power Station, dated July 21, 2009
- Proposed Revisions to Regulatory Guides 1.11, 2.5, 3.39, 5.10, 5.15, and DG-8039, dated July 21, 2009
- Proposed Revision 1 to Regulatory Guide 4.2 Supplement 1 (DG-4015), "Preparation of Environmental Reports for Nuclear Power Plant License Renewal Applications," dated July 21, 2009
- Withdrawal of Regulatory Guides 7.2, 1.16, 6.3, and 1.135, dated July 22, 2009

MINUTES OF THE 564<sup>th</sup> MEETING OF THE  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

ROCKVILLE, MARYLAND

The 564<sup>th</sup> meeting of the Advisory Committee on Reactor Safeguards (ACRS) was held in Conference Room 2B3, Two White Flint North Building, Rockville, Maryland, on July 8-10, 2009. Notice of this meeting was published in the *Federal Register* on June 24, 2009 (72 FR 30174-30175). The purpose of this meeting was to discuss and take appropriate action on the items listed in the meeting agenda. The meeting was open to public attendance.

A transcript of selected portions of the meeting is available in the NRC's Public Document Room at One White Flint North, Room 1F-19, 11555 Rockville Pike, Rockville, Maryland. Copies of the transcript are available for purchase from Neal R. Gross and Co., Inc., 1323 Rhode Island Avenue, NW, Washington, DC 20005. Transcripts are also available at no cost to download from, or review on, the Internet at <http://www.nrc.gov/ACRS/ACNW>.

ATTENDEES

ACRS Members: Dr. Mario Bonaca (Chairman), Dr. Said Abdel-Khalik (Vice-Chairman), Mr. J. Sam Armijo (Member-at-Large), Dr. George E. Apostolakis, Dr. Sanjoy Banerjee, Dr. Dennis Bley, Mr. Charles Brown, Dr. Michael Corradini, Mr. Otto L. Maynard, Dr. Dana A. Powers, Mr. Harold Ray, Dr. Michael Ryan, Dr. William Shack, Mr. John Sieber, and Mr. John Stetkar.

I. Chairman's Report (Open)

[Note: Mr. Sam Duraiswamy was the Designated Federal Official for this portion of the meeting.]

Dr. Mario Bonaca, Committee Chairman, convened the meeting at 8:30 a.m. In his opening remarks he announced that the meeting was being conducted in accordance with the provisions of the Federal Advisory Committee Act. He reviewed the agenda items for discussion and noted that no written comments or requests for time to make oral statements from members of the public had been received. Dr. Bonaca also noted that a transcript of the open portions of the meeting was being kept and speakers were requested to identify themselves and speak with clarity and volume.

II. License Renewal Application and the Final Safety Evaluation Report (SER) for the Beaver Valley Power Station

[Note: Mr. Christopher Brown was the Designated Federal Official for this portion of the meeting.]

The Committee met with representatives of the NRC staff and FirstEnergy Nuclear Operating Company (FENOC), the applicant, to discuss the Beaver Valley Power Station (BVPS) license renewal application and the associated NRC staff's final Safety Evaluation Report (SER).

The applicant discussed the follow-up item from the ACRS Subcommittee meeting concerning inaccessible medium-voltage cables located in manholes. These cables in some instances can become submerged in water. The concern of the Committee and the staff was that inaccessible medium-voltage cables that have been submerged may degrade and not perform their intended safety function. In response to this concern, the applicant committed to minimize exposure of these cables to significant moisture or replace them with those designed for submerged service. In addition, the applicant discussed Unit 1 operating experience regarding the containment liner corrosion identified in 2006. Analyses and evaluations of the Unit 1 containment liner corrosion were performed for FENOC by several vendors that specialize in these types of analyses. Of the three areas of corrosion identified, two were replaced with new plate material. In the third area, the liner showed minimal loss of thickness at the deepest pit and was left in place for further monitoring. The applicant further discussed the containment liner inspection performed in April 2009 on Unit 1, in which a paint blister was discovered on the containment liner revealing through-wall corrosion. The applicant attributed this corrosion to a moist piece of foreign material (wood) which was found embedded in the concrete immediately behind and in contact with the liner. The applicant's corrective actions include removal of the wood, inspection of the concrete, and replacement of the affected section of the liner. Future corrective actions include follow-up ultrasonic examination of the replaced area and visual examinations during the next Unit 1 refueling outage. Supplemental volumetric examinations on both units' containment liners prior to the period of extended operation were also committed to be performed by the applicant.

The NRC staff provided an overview of the BVPS, Units 1 and 2 license renewal review and the license renewal audit and inspection. The staff discussed resolution of the open item relating to medium-voltage non-safety related cables. The staff also discussed its evaluation of the applicant's corrective actions in response to the containment liner corrosion. The BVPS, Units 1 and 2 final SER contained no open or confirmatory items. Based on its review, the staff concluded that the requirements of 10 CFR 54.29(a) have been met.

The Committee completed a report to the NRC Chairman on this matter. Due to new information provided by FENOC regarding the liner inspection, the Committee decided to delay issuance of this report until meeting with the staff and the applicant to discuss the new information during its September 10-12, 2009 meeting.

III. Draft Final Revision 3 to Regulatory Guide 1.100, "Seismic Qualification of Electric and Mechanical Equipment for Nuclear Power Plants"

[Note: Mr. Mike Lee was the Designated Federal Office for this portion of the meeting.]

The Committee met with representatives of the NRC staff, MPR Associates, and the Westinghouse Electric Company to discuss draft final Revision 3 to Regulatory Guide (RG) 1.100, "Seismic Qualification of Electrical and Active Mechanical Equipment and Functional Qualification of Active Mechanical Equipment for Nuclear Power Plants."

This Guide describes methods that the staff considers acceptable for use in establishing the seismic qualification of electrical and active mechanical equipment defined to be important to safety. Draft final Revision 3 to RG 1.100 endorses, with exceptions and clarifications, the June 2005 edition of the Institute of Electrical and Electronics Engineers (IEEE) Standard, IEEE 344-2004, "IEEE Recommended Practice for Seismic Qualification of Class 1E Equipment for Nuclear Power Generating Stations," and extended the application of this Standard to the seismic qualification of mechanical equipment. In extending the application of IEEE Standard 344-2004 to mechanical equipment, the NRC staff recognized differences in seismic qualification methods for electrical equipment [including instrumentation and control (I&C) components] and mechanical equipment. In November 2007, the American Society of Mechanical Engineers (ASME) issued a revised Standard, ASME QME-1-2007, "Qualification of Active Mechanical Equipment Used in Nuclear Power Plants." This Standard covers both seismic qualification and functional qualification of active mechanical equipment. Revision 3 to draft final RG 1.100 also endorses, with exceptions and clarifications, ASME QME-1-2007.

The principal NRC Staff Positions in Revision 3 of RG 1.100 address specific elements of the seismic qualification guidance in the aforementioned consensus Standards. The most recent change to the IEEE Standard 344-2004 involves updated and expanded guidance concerning the use of past operating experience data to seismically qualify electrical equipment, including I&C components. Appendix QR-A to the ASME Standard QME-1-2007 now recognizes the use of past operating experience as an acceptable method for seismic qualification of active mechanical equipment. Previously, the NRC has accepted the use of experience and/or test data to justify the seismic adequacy of equipment in older operating nuclear power plants that are the subject of Unresolved Safety Issue (USI) A-46.

Representatives from MPR Associates and the Westinghouse Electric Company stated that the revised guidance was biased against the use of past operating experience data by virtue of language in the draft final RG indicating the necessity of staff reviews for each proposed use.

The industry representatives stated that the large number of exceptions cited in the guidance requiring a case-by-case staff review would discourage the use of experience data by licensees and their vendors. In response, the staff explained that it is not the intent of RG 1.100 to preclude the use of experience data to support qualification of equipment at non-USI A-46 plants. The staff also explained that it is not their intent to require a case-by-case review of each proposed use of experience-based seismic qualification data. However, this intent is not clearly stated in the current revision of this Guide.

The Committee issued a letter to the EDO on this matter, dated July 27, 2009, recommending that the staff amend draft final Revision 3 to RG 1.100 to delineate clearly the process for submitting and approving the details of experience data, including applicable implementation procedures, so as to obviate the need for case-by-case review.

#### IV. Applicability of TRACE Code to Evaluate New Light Water Reactor (LWR) Designs

[Note: Dr. Hossein Nourbakhsh was the Designated Federal Official for this portion of the meeting.]

The Committee met with representatives of the NRC staff to discuss applicability of the TRACE thermal-hydraulic system analysis code to evaluate new LWR designs, specifically, Economic Simplified Boiling Water Reactor (ESBWR) loss-of-coolant accidents (LOCAs).

The NRC staff provided an overview of the regulatory application of the TRACE code. TRACE is being incorporated into the regulatory process for performing confirmatory analyses of new LWR designs. The Committee discussed the staff's assessment of the applicability of TRACE to analyze ESBWR LOCAs.

The Committee also discussed the deficiencies associated with the formulation of the TRACE momentum equation. The momentum formulation in TRACE does not conserve momentum. As pointed out by the TRACE peer review group, for current LWR LOCAs, the treatment of the momentum conservation equation in TRACE can lead to incorrect results for components in which flows merge or change direction. This issue is more important for passive systems where the driving forces are relatively small and need to be accurately modeled in order to correctly predict the system response. Corrections have been made to TRACE to fix, to some extent, the more acute of such problems, but the recommendation made by the peer review group to solve the momentum equations in conservative form has not been implemented. The members noted that the current momentum equation formulation in TRACE, including the recent patches incorporated by the staff, may not be defensible under external scrutiny.

The Committee issued a letter to the EDO on this matter, dated July 29, 2009, with several recommendations, including: the capability of TRACE to predict the effect of trapped noncondensables in the GDSCS and the resulting collapsed liquid level in the reactor pressure vessel should be assessed; the adequacy of TRACE and other analysis methods, such as MELCOR, used for confirmatory analyses of long-term cooling phase of ESBWR LOCAs should be evaluated; TRACE should be assessed for applicability to analyses of coupled neutronic and thermal-hydraulic phenomena important to safety, such as instabilities and anticipated transient without scram (ATWS), in the ESBWR design; ongoing work to demonstrate that TRACE is adequate for confirmatory analyses of LOCAs and other safety-significant thermal-hydraulic phenomena in the new pressurized water reactor (PWR) designs should be completed in a timely fashion to allow application in the design certification process; and TRACE should be improved to properly formulate and solve the momentum equation when the flow changes direction and merges.



VI. Format and Content of the Biennial Research Report to the Commission on the NRC Safety Research Program

[Note: Dr. Hossein Nourbakhsh was the Designated Federal Official for this portion of the meeting.]

The Committee discussed the format and content of the 2010 ACRS biennial report to the Commission on its review and evaluation of the NRC Safety Research Program. The Committee plans to discuss its draft report on its review and evaluation of the NRC Safety Research Program during its October 8-10, 2009 meeting.

VII. Design Certification (DC)/Combined License (COL) Interim Staff Guidance (ISG) -006 and Nuclear Energy Institute (NEI) document NEI 08-08, Revision 1

[Note: Mr. Derek Widmayer was the Designated Federal Official for this portion of the meeting.]

The Committee met with representatives of the NRC staff to discuss Draft Template NEI-08-08, Revision 1, "Generic FSAR Template Guidance for Life Cycle Minimization of Contamination," and Draft interim staff guidance DC/COL-ISG-006, "Interim Staff Guidance on Evaluation and Acceptance Criteria for 10 CFR 20.1406 to Support Design Certification and Combined License Applications."

RG 4.21, "Minimization of Contamination and Radioactive Waste Generation: Life-Cycle Planning," provides guidance for meeting the requirements of 10 CFR 20.1406, "Minimization of Contamination." 10 CFR 20.1406 was promulgated by NRC staff to prevent the recurrence of "legacy decommissioning sites."

The staff provided an overview of NEI-08-08 and DC/COL-ISG-006 and described the role of these documents in the licensing process. Draft Template NEI-08-08 provides a standard approach for new reactors to address the guidance in RG 4.21 and the requirements of 10 CFR 20.1406. The staff is in the process of completing a safety evaluation of NEI-08-08 that will be the basis for endorsing the NEI template. Draft ISG-006 contains the review and approval methods and criteria for use by the staff to review the information in the Design Control documents (DCDs) and in the COLAs and decide whether the requirements of 10 CFR 20.1406 are met.

The Committee issued a letter to the EDO on this matter, dated July 22, 2009, recommending that the definition of the term "radiologically significant" in NEI 08-08 be revised to address unexpected radiological conditions resulting from spills, leaks, unplanned releases, or the identification of radioactive materials in unexpected locations that could have an adverse impact on license termination under Subpart E of 10 CFR Part 20. The Committee also recommended that NEI-08-08 not be endorsed and ISG-06 not be issued until a satisfactory definition of the term "radiologically significant" is developed.

VIII. Draft Final Regulatory Guide 1.215, "Guidance for ITAAC Closure Under 10 CFR Part 52"

[Note: Mr. Girija Shukla was the Designated Federal Official for this portion of the meeting.]

The Committee met with representatives of the NRC staff to discuss draft final RG 1.215 (DG-1204), "Guidance for ITAAC Closure under 10 CFR Part 52."

RG 1.215 describes a method that the staff considers acceptable for use in satisfying the requirements for documenting the completion of inspections, tests, analyses, and acceptance criteria (ITAAC). In particular, this Guide endorses the methodologies described in the document NEI 08-01, Revision 3, "Industry Guideline for the ITAAC Closure Process under 10 CFR Part 52," as an acceptable method of complying with the requirements of 10 CFR 52.99, "Inspection during construction."

The staff provided an overview of RG 1.215 and NEI 08-01, stating that RG 1.215 promotes a standardized approach for documenting ITAAC closures. NEI 08-01 provides guidance for licensees on the ITAAC closure documentation process. NEI 08-01 references other documents, but this Guide does not endorse any of the referenced documents. The staff stated that the actual inspection process for ITAAC and Design Acceptance Criteria (DAC) are not part of NEI 08-01 and RG 1.215. The staff further discussed the ITAAC closure letter templates and the 225-day notification letters for uncompleted ITAAC, provided in NEI 08-01. The staff also discussed resolution of public comments on DG1204 and DAC.

The Committee issued a report to the NRC Chairman on this matter, dated July 24, 2009, recommending that, prior to issuance, RG 1.215 be revised to specify where the detailed closure process guidance for DAC will be provided. The Committee also recommended that the DAC closure process guidance include a provision for an in-depth review comparable to the usual design certification process to ensure adequacy of the design and that the DAC closure process guidance be provided to the ACRS for review.

IX. Quality Assessment of Selected Research Projects

[Note: Dr. Hossein Nourbakhsh was the Designated Federal Official for this portion of the meeting.]

The Committee discussed its draft report on the assessment of the quality of the following NRC research projects: NUREG/CR-6964, "Crack Growth Rates and Metallographic Examinations of Alloy 600 and Alloy 82/182 from Field and Laboratory Materials Testing in PWR Environments," and Draft NUREG/CR-XXXX, "Diversity Strategies for Nuclear Power Plant Instrumentation and Control Systems." The Committee plans to finalize this report during its September 10-12, 2009 meeting.

## X. Subcommittee Reports

### ESBWR Subcommittee Report

The Chairman of the ESBWR Subcommittee provided a report to the Committee summarizing the results of the June 17-18, 2009, meeting with the NRC staff and GE Hitachi (GEH) to review the resolution of specific issues concerning the ESBWR containment analysis contained in Section 6.2 of the SER. GEH discussed the ESBWR design basis containment analysis performed using TRACG and the confirmatory design basis containment analysis performed using MELCOR. The discussion allowed the Subcommittee to compare the modeling between TRACG and MELCOR. The modified design of the vacuum breaker with the associated isolation valve was also discussed by GEH. However, it was concluded that additional information is needed to guarantee that the temperature sensors and the proximity switches in the design are capable of detecting excessive leakage through the vacuum breaker.

On June 18, 2009, the staff and Dominion presented multiple SER chapters (1, 4, 6, 7, 8, 15, 17, 18, and 19,) with open items, related to the North Anna combined license application. Most of the SER Chapters contained information Incorporated by Reference from the ESBWR DCD. Several technical issues were raised by the Subcommittee that will have to be resolved in the context of the certification of the ESBWR design; such as long term post LOCA containment pressure changes, steam dryer vibration, sump screen blockage, and downstream effects. The Committee plans to review the SER associated with the North Anna COLA at its October 8-10, 2009, meeting.

### Plant License Renewal Subcommittee Report

The Chairman of the Plant License Renewal Subcommittee provided a report to the Committee summarizing the results of the July 7, 2009 meeting, with the NRC staff and representatives of Northern States Power, a Minnesota Corporation (NSPM), to review the draft SER related to license renewal application for the Prairie Island Nuclear Generating Plant (PINGP), Units 1 and 2. PINGP submitted an application to the NRC in April 2008 to extend the PINGP Units 1 and 2 licenses for 20 years. The NRC staff's draft SER, issued in June 2009, contained three open items.

During the meeting, PINGP representatives described the operating history, the license renewal review methodology, and the aging management programs. The staff discussed its aging management review, audit, and inspection along with the open items in the draft SER. The open items were related to vessel internals, waste gas decay tank, and the refueling cavity. Discussion of pertinent issues raised by the subcommittee centered around the following: (1) a decision by PINGP to perform ultrasonic inspection of the bottom thickness of only one of three condensate storage tanks, (2) possible freezing and thawing of electrical cables in manholes, (3) a concern, or lack thereof, regarding the exposure of the containment liner, to borated water, (4) prolonged leakage from the refueling cavity, and (5) the adequacy of the corrective action and root cause analysis. The Committee plans to review the final SER related to the license renewal application for the PINGP Units 1 and 2, at its December 3-5, 2009 meeting.

## XI. Executive Session

[Note: Mr. Edwin Hackett was the Designated Federal Official for this portion of the meeting.]

### A. Reconciliation of ACRS Comments and Recommendations/EDO Commitments

- The Committee considered the EDO's response of June 4, 2009, to comments and recommendations included in the March 18, 2009 ACRS letter concerning Crediting Containment Overpressure in Meeting the Net Positive Suction Head Required to Demonstrate that the Safety Systems Can Mitigate the Accidents as Designed. The Committee decided that, based on the following commitments made by the staff, it was satisfied with the EDO's response.

The staff plans to revise Regulatory Guide 1.82, "Water Sources for Long-Term Recirculation Cooling Following a Loss-of-Coolant Accident," although it may take some time. The staff plans to factor the ACRS members' questions and suggestions into the on-going Browns Ferry Plant, Units 1, 2, and 3 extended power uprate (EPU) applications. The staff will brief the ACRS on how Browns Ferry EPU applications meet the ACRS March 18, 2009 letter, upon completion of the review. The staff plans to delay issuance of licensing actions that are currently under staff review that relate to containment over pressure (COP) credit.

- The Committee considered the EDO's response of May 22, 2009 to comments and recommendations included in the April 17, 2009 ACRS report on the Safety Aspects of the License Renewal Application for the Vogtle Electric Generating Plant, Units 1 and 2. The Committee decided that it was satisfied with the EDO's response.
- The Committee considered the EDO's response of June 1, 2009 to comments and recommendations included in the April 21, 2009 ACRS report on Digital I&C Interim Staff Guidance 5, "Highly Integrated Control Room-Human Factors Issues," and 6, "Licensing Processes." The Committee decided that, based on the following commitments made by the staff, it was satisfied with the EDO's response.

The staff will provide additional guidance, either through incorporation or reference, to ensure that estimates of time required are derived using methods that minimize the potential for bias. In addition, the staff will evaluate how to revise the guidance to address the concern that, as the margin decreases between estimates of time available and time required, there will be increasing potential for uncertainties and bias in the calculations to substantively misrepresent the adequacy of the margin and subsequently decrease confidence in the analysis. Specifically, the staff will evaluate the feasibility of tailoring the analysis and integrated system validation guidance based on the amount of margin between the time available and time required for operator action.

The staff will ensure that the requirement for deterministic behavior is clearly stated in the guidance. The staff will also ensure that the guidance describes methods for determining that the software cannot enter into an undetermined state or that, if such an undetermined state is reached via software or hardware failure, the hardware-based watchdog timer will alert the operators.

Reviewer guidance will be added to ISG-6 to clearly identify that requirement and to ensure consistency between ISG-4 and ISG-6. As such, the staff currently plans to revise Sections C and D of ISG-6 to specify that sufficient design detail be provided to ensure deterministic behavior and independence of each digital I&C safety train.

B. Report of the Planning and Procedures Subcommittee Meeting

Review of the Member Assignments and Priorities for ACRS Reports and Letters for the July ACRS Meeting

Member assignments and priorities for ACRS reports and letters for the July ACRS meeting were discussed. Reports and letters that would benefit from additional consideration at a future ACRS meeting were also discussed.

Anticipated Workload for ACRS Members

The anticipated workload for ACRS members through October 2009 was discussed and the objectives were to:

- Review the reasons for the scheduling of each activity and the expected work product and to make changes, as appropriate
- Manage the members' workload for these meetings
- Plan and schedule items for ACRS discussion of topical and emerging issues

Staff Requirements Memorandum

The Staff Requirements Memorandum (SRM) resulting from the ACRS meeting with the Commission on June 4, 2009. In this SRM, the Commission states:

The staff should continue working to resolve the differences of opinion between the Committee and the staff concerning containment overpressure (COP) credit.

Supplement 1 to the Safety Evaluation Report (SER) Related to the Vermont Yankee License Renewal Application

The final SER related to the license renewal of the Vermont Yankee Nuclear Plant required the applicant, Entergy, to perform fatigue analyses on the core spray and recirculation outlet nozzles at the Vermont Yankee plant no later than two years prior to entering the period of extended operation. In its March 20, 2008 report on the Vermont Yankee license renewal application, the Committee agreed with the license condition imposed by the staff. On January 15, 2009, Entergy submitted for staff review the results of its confirmatory environmentally adjusted fatigue cumulative usage factor analyses for the core spray and recirculation outlet nozzles. Based on its review of the analyses, the staff has concluded that Entergy has satisfied the concern identified in the license condition and that the analyses are acceptable. The staff documented its conclusions in Supplement 1 to the final SER and provided a copy of the Supplement for ACRS consideration.

Based on his review of the above Supplement, Dr. Bonaca recommends that the Committee not review this Supplement.

### 2009 Fuel Cycle Information Exchange Conference

On June 23-25, 2009, the NRC hosted the fourth annual Fuel Cycle Information Exchange Conference. The main objective of this Conference was to provide an opportunity for NRC staff, industry, licensees, and other stakeholders to discuss issues involving the regulation of civilian nuclear fuel cycle facilities. Drs. Mike Ryan and John Flack attended this Conference.

### Reappointment of ACRS Members

The Commission has reappointed Drs. Abdel-Khalik and Corradini for a second term.

### Regulatory Guides

#### a) Draft Final Regulatory Guide

The staff plans to issue the following Draft Final Regulatory Guide and would like to know whether the Committee wants to review this Guide prior to being issued final.

- Draft Final Revision 2 to Regulatory Guide 1.189, "Fire Protection for Nuclear Power Plants"

The staff developed Regulatory Guide 1.189 to provide a comprehensive fire protection guidance document and to identify the scope and depth of fire protection that the staff would consider acceptable for nuclear power plants. This Guide incorporates experience gained over the last three decades and information in many guidance documents by the NRC in the area of the fire protection. The proposed Revision 2 to Regulatory Guide 1.189 updates the resolution of fire-induced circuit failures. During the 480<sup>th</sup> meeting of the ACRS, March 1-3, 2001, the Committee considered the proposed RG 1.189, Rev 0 and decided not to review it. This RG (Rev 0) was issued in April 2001. The staff briefed the Committee on the proposed Revision 1 to RG 1.189, which added information for the application of new plants, during November 2006 and February 2007 meetings. In a letter, dated February 14, 2007, the ACRS recommended that Revision 1 to RG 1.189 be issued. The staff issued this Guide in March 2007.

Since the issuance of Revision 1 to RG 1.189, the staff has been working on Revision 2 to incorporate information described in SECY-08-0093, regarding the resolution of issues related to fire-induced circuit failures. Subsequently, the staff prepared a draft Revision 2 to RG 1.189, as DG-1214, which was issued for public comment in April 2009. The staff received 94 public comments, of which, 83 comments were from NEI and 11 comments were from FPL.

After reviewing these comments and the associated staff's resolution, the Subcommittee's chairman concluded that the bulk of the document did not change from Revision 1. All comments were well thought out and almost all comments were specifically directed toward a portion of the RG text that the commenter believed should be changed. Also, all the comments that were fully accepted or partially

accepted were incorporated into the draft RG. The staff stated a reasonable position related to the two rejected comments. The focus of the changes was in the discussion related to analysis of circuits to assure safe shutdown and particularly related to spurious actuations. No comments were stated which would lead to a conclusion that the draft RG went beyond the regulations or the historical regulations or regulatory guidance. Some inferences to implied guidance contained in past Generic Letters or other staff information which did not appear to have an underpinning in regulations or regulatory guidance were not included in (or was deleted from) the final draft RG.

Based on his review of this Regulatory Guide, Mr. Sieber recommends that the Committee not review this Guide.

#### b) Proposed Regulatory Guides

The staff plans to issue the following Proposed Regulatory Guides for public comment and would like to know whether the Committee wants to review these Guides prior to being issued for public comment.

- Proposed Revision 1 to Regulatory Guide 1.11 (DG-1225), "Instrument Lines Penetrating the Primary Reactor Containment"

The staff issued RG 1.11 in March 1971. The objective of Revision 1 to RG 1.11 is to update the NRC guidance on acceptable methods for the isolation of instrument lines that penetrate the primary containments of light-water-cooled reactors. General Design Criterion (GDC) 55, "Reactor Coolant Pressure Boundary Penetrating Containment," and GDC 56, "Primary Containment Isolation," of Appendix A, "General Design Criteria for Nuclear Power Plants," to Title 10, Part 50, "Domestic Licensing of Production and Utilization Facilities," of the *Code of Federal Regulations*, establish that a plant's principal design criteria require, in part, that each line that penetrates the primary reactor containment and that is part of the reactor coolant pressure boundary or connects directly to the containment atmosphere has at least one locked, closed isolation valve or one automatic valve inside and one automatic valve outside containment "unless it can be demonstrated that the containment isolation provisions for a specific class of lines, such as instrument lines, are acceptable on some other defined basis." This Guide defines a basis that the staff considers acceptable to implement the intent of GDC 55 and 56 with regard to instrument lines. This Guide applies to all types of nuclear power plants with a primary containment.

Based on his review of this Proposed Regulatory Guide, Mr. Ray recommends that the Committee review the draft final revision to this Guide after reconciliation of public comments.

- Proposed Revision 1 to Regulatory Guide 2.5 (DG-2001), “Quality Assurance Program Requirements for Research and Test Reactors”

The ANSI and the ANS issued the first version of ANSI/ANS-15.8-1976, the “Quality Assurance Program Requirements for Research Reactors,” in August 1976. The staff subsequently endorsed this guidance in Revision 0 to Regulatory Guide 2.5, “Quality Assurance Program Requirements for Research Reactors,” issued October 1977 and reaffirmed in 1986. Because of the significant changes subsequently made to management programs and to the expected level of detail and documentation of program elements for nonpower (research and test) reactors, ANSI and ANS issued ANSI/ANS-15.8-1995 in 1995 and reaffirmed it in September 2005, to incorporate the acknowledged enhancements to quality assurance programs. The guidance endorsed in the current version of this Guide is outdated. Therefore, a revision of this regulatory guidance is necessary to endorse the updated quality assurance guidance provided in the industry standard.

Based on his review of this Proposed Regulatory Guide, Mr. Stetkar recommends that the Committee review the draft final revision to this Guide after reconciliation of public comments.

- Proposed Revision 1 to Regulatory Guide 4.2 Supplement 1 (DG-4015), “Preparation of Environmental Reports for Nuclear Power Plant License Renewal Applications”

Draft Guide 4015 is a proposed revision 1 to Regulatory Guide 4.2 Supplement 1 dated September 2000. DG-4015 is part of a proposed rulemaking to 10 CFR Part 51. This proposed rule is part of the Commission’s intent to review and update, on a 10 year cycle, the findings in Table B-1, Appendix B to Subpart A of Part 51, “Environmental Effect of Renewing the Operating License of a Nuclear Power Plant.” This proposed rule and update to the technical basis documents are

Commission tracking items. Per the rulemaking guidelines, the staff is issuing for comment in parallel the proposed rule and all technical basis documents (i.e.; Regulatory Guide, Environmental Standard Review Plan, NUREG-1555, Supplement 1, Rev. 1; and NUREG-1437, Rev. 1). DG-4015 reorganizes RG 4.2 to conform to 10 CFR 51, Appendix A, and was updated in keeping with the 10-year review of the rule. The draft guide reflects the changes to the rule and is supported by the technical basis for the 10-year update of Appendix B. The overall scope of the Regulatory Guide has not changed.

Based on his review of this Proposed Regulatory Guide, Dr. Ryan recommends that the Committee not review the draft and the final revisions to this Guide.



- Proposed Revision 1 to Regulatory Guide 3.39 (DG-3038), “Standard Format and Content of License Applications for Plutonium Processing and Fuel Fabrication Facilities”

The staff issued Regulatory Guide 3.39 in January 1976. DG-3038 is a proposed revision 1 to RG 3.39 that endorses the standard format and content for safety analysis reports (SARs) described in the current version of NUREG-1718, “Standard Review Plan for the Review of an Application for a Mixed Oxide Fuel Fabrication Facility”, as a method that the NRC staff finds acceptable for meeting the regulatory requirements. DG-3038 directs the reader to documentation regarding the type of information acceptable to the staff for review of an SAR for plutonium processing and fuel fabrication facilities. The SAR may be a separate report submitted as part of the application, or it may be integrated into the license application. This documentation also provides the standard format and content of SARs and related documents submitted as part of an application to construct or modify and operate a plutonium processing and fuel fabrication facility.

Based on his review of this Proposed Regulatory Guide, Dr. Ryan recommends that the Committee review the draft final revision to this Guide after reconciliation of public comments.

- Proposed Revisions to Regulatory Guides 5.10, “Selection and Use of Pressure-Sensitive Seals on Containers for Onsite Storage of Special Nuclear Material”, and 5.15, “Tamper-Indicating Seals for the Protection and Control of Special Nuclear Material”

Draft Guide 5029 revises and combines the information from Regulatory Guides 5.10, “Selection and Use of Pressure-Sensitive Seals on Containers for Onsite Storage of Special Nuclear Material,” and 5.15, “Tamper-Indicating Seals for the Protection and Control of Special Nuclear Material,” dated July 1973 and March 1997, respectively. The updated guidance removes references to devices that are no longer commercially available, corrects references to the regulations that are no longer valid, and reflects recent operating experience regarding the use of various types of seals to protect special nuclear material. The combined guidance will make all information related to seals for special nuclear material available in one location in a more clear and concise format.

Based on his review of this Proposed Regulatory Guide, Dr. Ryan recommends that the Committee review the draft final revision to these Guides after reconciliation of public comments.

- Proposed New Division 8 Draft Regulatory Guide (DG-8039), “Methods for Estimating Effective Dose Equivalent from External Exposure”

Draft Guide 8039 is a proposed new Regulatory Guide which describes dosimetry methods that the NRC considers acceptable for determining effective dose equivalent for external (EDEX) radiation exposures. These methods provide a conservative estimate of EDEX and may be used to calculate total effective dose equivalent (TEDE) in demonstrating compliance with TEDE-based regulatory requirements consistent with the provisions in 10 CFR 20.1201(c).

Licensees will most likely need to provide additional dosimeters if monitoring is required by 10 CFR 20.1502, “Conditions Requiring Individual Monitoring of External and Internal Occupational Dose,” to demonstrate compliance with any of these non-TEDE dose limits. Regulatory Guide 8.34, “Monitoring Criteria and Methods to Calculate Occupational Radiation Doses,” issued July 1992, provides guidance on meeting the monitoring requirements of 10 CFR 20.1502. Therefore, using the methods described below will not, in most cases, lead to any reduction in monitoring requirements. Instead, they may help provide a more accurate estimate of EDEX than may be possible using a single dosimeter when the radiation fields to which the monitored person is exposed are very non-uniform, and particularly when significant parts of the body, especially the torso, are shielded.

Based on his review of this Proposed New Draft Regulatory Guide, Dr. Ryan recommends that the Committee review the draft final version of this Guide after reconciliation of public comments.

c) Withdrawal of Regulatory Guides

The staff plans to withdraw the following Regulatory Guides and would like to know whether the Committee wants to review these prior to being issued.

- Regulatory Guide 7.2, “Packaging and Transportation of Radioactively Contaminated Biological Materials

Regulatory Guide 7.2 was published in June 1974. The regulations for transport of hazardous materials have been revised several times since Regulatory Guide 7.2 was issued. However, neither Regulatory Guide 7.2 nor the referenced ANSI guidance has been revised to keep current with the changing regulations. The ANSI guidance, issued as Standard N14.3-1973, “Packaging and Transportation of Radioactively Contaminated Biological Materials,” by the N14.3 subcommittee has been withdrawn. The transportation of radioactively contaminated biological

materials would be governed by the Department of Transportation (DOT) regulations. Additionally, there has never been an application for a permit to package or transport radioactively contaminated biological material, as described in Regulatory Guide 7.2. The DOT regulations are an acceptable means of meeting the regulations. The staff decided that this Regulatory Guide is no longer needed.

Based on his review of the proposed withdrawal of this Guide, Dr. Ryan recommends that the Committee not object to the staff's proposal to withdraw this Guide.

- Regulatory Guide 1.16, "Reporting of Operating Information-Appendix A Technical Specifications"

Regulatory Guide 1.16 was issued for comment in August 1975 and never finalized. This Guide identifies the content and format of reports required by 10 CFR Part 50 and the Technical Specifications which are Appendix A of the license. The staff decided that this Regulatory Guide is no longer needed.

Based on his review of the proposed withdrawal of this Guide, Mr. Maynard recommends that the Committee not object to the staff's proposal to withdraw this Guide.

- Regulatory Guide 6.3, "Design, Construction, and use of Radioisotopic Power Generators for Certain Land and Sea Applications"

Regulatory Guide 6.3 was published in March 1974 and provides guidance on the safe design, construction, and use of radioisotopic power generators. This Guide supported activities requiring a license pursuant to Title 10 CFR, Parts 30, 40, and 70. Regulatory Guide 6.3 applies to types of devices that are no longer used and have been replaced by other technology. Therefore, no licensing actions for these devices are being submitted or reviewed by license reviewers. The staff decided that this Regulatory Guide is no longer needed.

Based on his review of the proposed withdrawal of this Guide, Mr. Brown recommends that the Committee not object to the staff's proposal to withdraw this Guide.

- Regulatory Guide 1.135, "Normal Water Level and Discharge at Nuclear Power Plants"

Regulatory Guide 1.135 was issued for comment in September 1977 and never finalized. Regulatory Guide 1.135 was intended to provide guidance on estimating the normal ground and surface water elevations at a nuclear power plant site. The determination of normal and flood water elevation is one of the site characteristics required by Title 10 of the *Code of Federal Regulations* (CFR), Part 100, "Reactor Site Criteria," as factors to be considered when evaluating sites for test reactors and stationary power reactor site applications. General Design Criterion (GDC) 2, "Design Basis for Protection Against Natural

Phenomena,” of Appendix A, “General Design Criteria for Nuclear Power Plants,” to 10 CFR Part 50 requires facilities to be designed for protection against the most severe of the natural phenomena that have been historically reported for the site and surrounding area. This includes events such as floods, tsunamis, and seiches. A determination of the normal pool level is not required by GDC 2 and thus, not impacted by the withdrawal of Regulatory Guide 1.135. A review of updated Final Safety Analysis Reports (FSARs) from licensees and applicants determined that only a few FSARs referenced Regulatory Guide 1.135 and no applicant or licensee is currently using it. Applicants and licensees use the guidance in the SRP and ANSI/ANS-2.8-1992, “Determining Design Basis Flooding at Power Reactor Sites” for water level determinations.

Based on his review of the proposed withdrawal of this Guide, Dr. Banerjee recommends that the Committee not object to the staff’s proposal to withdraw this Guide.

### eTravel

All new domestic travel must be processed through eTravel. On July 14-15, 2009 the members will receive an email from [LKister@CWTSatoTravel.com](mailto:LKister@CWTSatoTravel.com) in their NRC email accounts. Members will have 72 hours from the initial email to access the eTravel site to set up their profiles. eTravel does not require CITRIX and it allows individuals to view status of their authorizations and file claims online.

The meeting was adjourned at 7:00 p.m. on July 9, 2009..

### B. Industry Competency Models

ETA supports an Industry Competency Model Initiative to promote an understanding of the skill sets and competencies that are essential to an educated and skilled workforce. A competency model is a collection of competencies that taken together define successful performance in a particular work setting. Competency models serve as a starting point for the design and implementation of workforce and talent development programs. To learn about the industry-validated models visit the Competency Model Clearinghouse (CMC) at <http://www.careeronestop.org/CompetencyModel>. The CMC site also provides tools to build or customize industry models, as well as tools to build career ladders and/or career lattices.

### C. Federal Collaboration

DOL encourages other Federal partners to recommend or require, where appropriate, that organizations receiving Recovery Act funding list jobs created with their State public labor exchange. The Department is developing specific strategies to link job listings, training opportunities and placement among programs funded by Departments of Housing and Urban Development, Energy, and Education. Where the grantee is not the public workforce system, they are strongly encouraged to work with the local One Stop Career Centers to make these connections.

### D. Links to Federal Recovery Sites

For specific information on a range of Federal agency Recovery Act activities and funding opportunities, please access the following Web sites:

- Department of Education: <http://www.ed.gov/policy/gen/leg/recovery/index.html>.
- Department of Energy: <http://www.doe.gov/recovery>.
- Department of Housing and Urban Development: <http://www.hud.gov/recovery>.
- Department of Transportation: <http://www.dot.gov/recovery/>.
- Environmental Protection Agency: <http://www.epa.gov/recovery>.

### E. Promising Training Approaches

ETA encourages applicants to research promising training approaches in order to inform their proposals. The following list of Web sites provides a starting place for this research, but by no means should be considered a complete list:

- ETA's home site (<http://www.doleta.gov>) and the ETA Research

Publication Database ([wdr.doleta.gov/research/keyword.cfm](http://wdr.doleta.gov/research/keyword.cfm))

- ETA's knowledge sharing site (<http://www.workforce3one.org>), including the "workforce solutions" section that contains over 6,000 additional resources applicants may find valuable in developing workforce strategies and solutions
- The National Governors Association Center for Best Practices (<http://www.nga.org>)
- The National Association of State Workforce Agencies (<http://www.workforceatm.org>)
- The National Association of Workforce Boards (<http://www.nawb.org>)

### IX. Other Information

OMB Information Collection No. 1225-0086.

Expires September 30, 2009.

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless such collection displays a valid OMB control number. Public reporting burden for this collection of information is estimated to average 20 hours per response, including time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding the burden estimated or any other aspect of this collection of information, including suggestions for reducing this burden, to the OMB Desk Officer for ETA, Department of Labor, in the Office of Management and Budget, Room 10235, Washington, DC 20503. Please do not return the completed application to the OMB. Send it to the sponsoring agency as specified in this solicitation.

This information is being collected for the purpose of awarding a grant. The information collected through this SGA will be used by DOL to ensure that grants are awarded to the applicant best suited to perform the functions of the grant. Submission of this information is required in order for the applicant to be considered for award of this grant. Unless otherwise specifically noted in this announcement, information submitted in the respondent's application is not considered to be confidential.

Signed at Washington, DC, this 19th day of June, 2009.

**B. Jai Johnson,**

*Grant Officer, Employment and Training Administration.*

[FR Doc. E9-14920 Filed 6-23-09; 8:45 am]

**BILLING CODE 4510-FN-P**

### NATIONAL SCIENCE FOUNDATION

#### National Science Board; Committee on Strategy and Budget; Sunshine Act Meetings; Notice

The National Science Board's Committee on Strategy and Budget, pursuant to NSF regulations (45 CFR Part 614), the National Science Foundation Act, as amended (42 U.S.C. 1862n-5), and the Government in the Sunshine Act (5 U.S.C. 552b), hereby gives notice in regard to the scheduling of meetings for the transaction of National Science Board business and other matters specified, as follows:

**DATE AND TIME:** Friday, June 26, 2009 at 2 p.m.

**SUBJECT MATTER:** Discussion of future NSF budgets.

**STATUS:** Closed.

This meeting will be held by teleconference originating at the National Science Board Office, National Science Foundation, 4201 Wilson Blvd., Arlington, VA 22230. Please refer to the National Science Board Web site (<http://www.nsf.gov/nsb>) for information or schedule updates, or contact: Jennie Moehlmann, National Science Foundation, 4201 Wilson Blvd., Arlington, VA 22230. Telephone: (703) 292-7000.

**Ann Ferrante,**

*Writer-Editor.*

[FR Doc. E9-14962 Filed 6-22-09; 11:15 am]

**BILLING CODE 7555-01-P**

### NUCLEAR REGULATORY COMMISSION

#### Advisory Committee on Reactor Safeguards; Revision to July 8-10, 2009 ACRS Meeting Federal Register Notice

The **Federal Register** Notice for the ACRS meeting scheduled to be held on July 8-10, 2009, is being revised to make the following changes:

The discussion of Draft Final Regulatory Guide 1.215, "Guidance for ITAAC Closure under 10 CFR Part 52," scheduled between 10:15 and 11:45 a.m. on Wednesday, July 8, 2009, is now scheduled between 10:45 a.m. and 12:15 p.m. on Thursday, July 9, 2009. The discussion of Draft Final Revision 3 to Regulatory Guide 1.100, "Seismic Qualification of Electric and Mechanical Equipment for Nuclear Power Plants," scheduled between 10:45 a.m. and 12:15 p.m. on Thursday, July 9, 2009, is now scheduled between 10:15 and 11:45 a.m. on Wednesday, July 8, 2009.

In addition, the topic on Applicability of TRACE Code to Analyze ESBWR

Stability, scheduled between 12:45 and 2:45 p.m. on Wednesday, July 8, 2009, has been clarified to state "Applicability of TRACE Code to Evaluate New LWR Designs."

The notice of this meeting was previously published in the **Federal Register** on Wednesday, June 17, 2009 [74 FR 28727–28728]. All other items remain the same as previously published.

Further information regarding this meeting can be obtained by contacting Girija Shukla, Cognizant ACRS staff (301–415–6855), between 7:15 a.m. and 5 p.m., (ET).

Dated: June 18, 2009.

**Andrew L. Bates,**

*Advisory Committee Management Officer.*

[FR Doc. E9–14833 Filed 6–23–09; 8:45 am]

**BILLING CODE 7590–01–P**

## **NUCLEAR REGULATORY COMMISSION**

[NRC–2009–0257]

### **Notice of Public Workshop on a Potential Rulemaking for Safe Disposal of Unique Waste Streams Including Significant Quantities of Depleted Uranium**

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Notice of public workshop and a request for comment.

**SUMMARY:** The U.S. Nuclear Regulatory Commission (NRC) plans to conduct two public workshops to solicit public input on major issues associated with a potential rulemaking for land disposal of unique waste streams including, but not limited to, significant quantities of depleted uranium in near-surface radioactive waste disposal facilities. The public workshops are intended to solicit the views of representatives of interests that may be affected by the rulemaking. Members of the public are invited to provide written comments on the issues presented in this notice and to attend the workshops to provide feedback on the potential rulemaking. The public workshops will be held in Rockville, Maryland on September 2–3, 2009 and in Salt Lake City, Utah on September 23–24, 2009.

**DATES:** Members of the public may provide feedback at the transcribed public workshops or may submit written comments on the issues discussed in this notice. Comments on issues for the agenda should be postmarked no later than August 1, 2009. Comments on the issues and questions presented in this notice and

discussed at the workshops should be postmarked no later than October 30, 2009. Comments received after these dates will be considered if it is practical to do so. NRC plans to consider these stakeholder views in the development of a technical basis for the planned rulemaking. Written comments may be sent to the address listed in the **ADDRESSES** section. Questions about participation in the roundtable discussion at the public workshops should be directed to the facilitator at the address listed in the **ADDRESSES** section. Members of the public planning to attend the workshops are invited to RSVP at least ten (10) days prior to each workshop. Replies should be directed to the points of contact listed in the **FOR FURTHER INFORMATION CONTACT** section.

The public workshops will be held in Rockville, Maryland on September 2, 2009, from 8 a.m. to 5 p.m. and on September 3, 2009, from 8 a.m. to 5 p.m. and in Salt Lake City, Utah on September 23, 2009, from 8 a.m. to 5 p.m. and on September 24, 2009, from 8 a.m. to 5 p.m. The location of and final agenda for each public workshop will be noticed no fewer than ten (10) days prior to each workshop on the NRC's electronic public workshop schedule at <http://www.nrc.gov/public-involve/public-meetings/index.cfm>. Please refer to the **SUPPLEMENTARY INFORMATION** section for additional information on the issues proposed for discussion at the public workshops.

**ADDRESSES:** Submit written comments to the Chief, Rulemaking and Directives Branch, Division of Administrative Services, Office of Administration, U.S. Nuclear Regulatory Commission, Mail Stop TWB 5B01M, Washington, DC 20555–0001, and cite the publication date and page number of this **Federal Register** notice, or by fax at 301–492–3446. Comments may also be submitted electronically at <http://www.regulations.gov>. Search on docket ID NRC–2009–0257.

Questions regarding participation in the roundtable discussions should be submitted to the facilitator, Francis Cameron, by mail to Mail Stop O16–E15, U.S. Nuclear Regulatory Commission, Washington, DC 20555–0001, by telephone at 301–415–1006 or 240–205–2091, or by e-mail at [francis.cameron@nrc.gov](mailto:francis.cameron@nrc.gov).

**FOR FURTHER INFORMATION CONTACT:** Priya Yadav, Office of Federal and State Materials and Environmental Management Programs, U.S. Nuclear Regulatory Commission, Washington, DC 20555–0001, telephone 301–415–6667; e-mail [priya.yadav@nrc.gov](mailto:priya.yadav@nrc.gov), or Christopher Grossman, Office of Federal

and State Materials and Environmental Management Programs, U.S. Nuclear Regulatory Commission, Washington, DC 20555–0001, telephone 301–415–7658; e-mail [christopher.grossman@nrc.gov](mailto:christopher.grossman@nrc.gov).

The public may examine and have copied for a fee, publicly available documents at the Public Document Room, One White Flint North, 11555 Rockville Pike, Rockville, Maryland. Publicly available documents created or received at NRC after November 1, 1999, are available electronically at the NRC's Electronic Reading Room at <http://www.nrc.gov/reading-rm/adams.html>. From this site, the public can gain entry into the NRC's Agencywide Documents Access and Management System (ADAMS), which provides text and image files of NRC's public documents. If you do not have access to ADAMS, contact the Public Document Room at 1–800–397–4209, 301–415–4737, or by e-mail to [pdr.resource@nrc.gov](mailto:pdr.resource@nrc.gov).

#### **SUPPLEMENTARY INFORMATION:**

##### **I. Background**

The Low-Level Radioactive Waste Policy Amendments Act of 1985 (Pub. L. 99–240) sets forth the Federal policy, including responsibilities, for the disposal of low-level radioactive waste to ensure available disposal capacity for all classes of waste, as specified by Title 10, § 61.55, of the *Code of Federal Regulations* (CFR). Existing NRC regulations in 10 CFR 61.55 specify criteria for determining the classification of low-level radioactive waste for land disposal at a near-surface facility. The original development of 10 CFR 61.55 did not explicitly consider the impacts resulting from the disposal of significant quantities of depleted uranium from the operation of a commercial uranium enrichment facility ("Draft Environmental Impact Statement on 10 CFR Part 61 Licensing Requirements for Land Disposal of Radioactive Waste," NUREG–0782, 1981, ADAMS Accession Nos. ML060930564 (vol. 1), ML060930573 (vol. 2), ML060930577 (vol. 3), and ML060930583 (vol. 4); "Final Environmental Impact Statement on 10 CFR Part 61 Licensing Requirements for Land Disposal of Radioactive Waste," NUREG–0945, 1982, ADAMS Accession Nos. ML052590184 (vol. 1) and ML052920727 (vol. 2)). When 10 CFR Part 61 was initially developed, there were no commercial facilities generating significant quantities of depleted uranium waste. As a result, the analysis only considered the types of uranium-bearing waste streams being typically

Revised June 18, 2009



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
WASHINGTON, DC 20555 - 0001**

June 18, 2009

**AGENDA  
564<sup>th</sup> ACRS MEETING  
JULY 8-10, 2009**

**WEDNESDAY, JULY 8, 2009, CONFERENCE ROOM T-2B3, TWO WHITE FLINT NORTH,  
ROCKVILLE, MARYLAND**

- 1) 8:30 – 8:35 A.M. Opening Remarks by the ACRS Chairman (Open) (MVB/EMH/SD)
  - 1.1) Opening statement
  - 1.2) Items of current interest
  
- 2) 8:35 – 10:00 A.M. License Renewal Application and the Final Safety Evaluation Report (SER) for the Beaver Valley Power Station (Open) (DCB/CLB)
  - 2.1) Remarks by the Subcommittee Chairman
  - 2.2) Briefing by and discussions with representatives of the NRC staff and FirstEnergy Nuclear Operating Company regarding the License Renewal Application for the Beaver Valley Power Station, the associated NRC staff's final SER, and related matters.

Members of the public may provide their views, as appropriate.

**10:00 – 10:15 A.M. \*\*\* BREAK \*\*\***

- 3) 10:15 – 11:45 A.M. Draft Final Revision 3 to Regulatory Guide 1.100, "Seismic Qualification of Electric and Mechanical Equipment for Nuclear Power Plants" (Open) (JWS/MPL)
  - 3.1) Remarks by the Subcommittee Chairman
  - 3.2) Briefing by and discussions with representatives of the NRC staff regarding Draft Final Revision 3 to Regulatory Guide 1.100, "Seismic Qualification of Electric and Mechanical Equipment for Nuclear Power Plants," and related matters.

Representatives of the nuclear industry and members of the public may provide their views, as appropriate.

**11:45 – 12:45 P.M. \*\*\* LUNCH \*\*\***

- 4) 12:45 – 2:45 P.M. Applicability of TRACE Code to Evaluate New Light Water Reactor (LWR) Designs (Open/Closed) (SB/HPN/DEB)  
4.1) Remarks by the Subcommittee Chairman  
4.2) Briefing by and discussions with representatives of the NRC staff regarding applicability of the TRACE Code to evaluate new LWR designs, and related matters.

**[NOTE: A portion of this Session may be closed to protect information that is proprietary to General Electric-Hitachi or its contractors pursuant to 5 U.S.C. 552b (c)(4)]**

Representatives of the nuclear industry and members of the public may provide their views, as appropriate.

**2:45 – 3:00 P.M. \*\*\* BREAK \*\*\***

- 5) 3:00 – 4:00 P.M. Format and Content of the Biennial Research Report to the Commission on the NRC Safety Research Program (Open) (DAP/HPN)  
5.1) Remarks by the Subcommittee Chairman  
5.2) Discussion of the Format and Content of the ACRS Biennial Report to the Commission on its review and evaluation of the NRC Safety Research Program, and related matters.

**4:00 – 4:15 P.M. \*\*\* BREAK \*\*\***

- 6) 4:15 – 7:00 P.M. Preparation of ACRS Reports (Open)  
Discussion of proposed ACRS reports on:  
6.1) License Renewal Application and the Final Safety Evaluation Report for the Beaver Valley Power Station (DCB/CLB)  
6.2) Draft Final Revision 3 to Regulatory Guide 1.100, "Seismic Qualification of Electric and Mechanical Equipment Nuclear Power Plants" (JWS/MPL)  
6.3) Applicability of TRACE Code to Evaluate New Light Water Reactor (LWR) Designs (SB/HPN/DEB)

**THURSDAY, JULY 9, 2009, CONFERENCE ROOM T-2B3, TWO WHITE FLINT NORTH, ROCKVILLE, MARYLAND**

- 7) 8:30 – 8:35 A.M. Opening Remarks by the ACRS Chairman (Open) (MVB/CS/SD)  
8) 8:35 – 10:30 A.M. Design Certification (DC)/Combined License (COL) Interim Staff Guidance (ISG) -006 and Nuclear Energy Institute (NEI) document NEI 08-08, Revision 1 (Open) (MTR/DAW)  
8.1) Remarks by the Subcommittee Chairman  
8.2) Briefing by and discussions with representatives of the NRC staff regarding DC/COL-ISG-006, "Interim Staff



Guidance on Evaluation and Acceptance Criteria for 10 CFR 20.1406 to Support Design Certification and Combined License Applications,” and NEI 08-08, Revision 1, “Generic FSAR Template Guidance for Life Cycle Minimization of Contamination,” Contamination,” and related matters.

Representatives of the nuclear industry and members of the public may provide their views, as appropriate.

**10:30 – 10:45 A.M. \*\*\* BREAK \*\*\***

- 9) 10:45 – 12:15 P.M. Draft Final Regulatory Guide 1.215, “Guidance for ITAAC Closure under 10 CFR Part 52” (Open) (DCB/MLC/GSS)
- 9.1) Remarks by the Subcommittee Chairman
  - 9.2) Briefing by and discussions with representatives of the NRC staff regarding Draft Final Regulatory Guide 1.215 that provides guidance for closure of Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC ) under 10 CFR Part 52, and related matters.

Representatives of the nuclear industry and members of the public may provide their views, as appropriate.

**12:15 – 1:15 P.M. \*\*\* LUNCH \*\*\***

- 10) 1:15 – 1:45 P.M. Quality Assessment of Selected Research Projects (Open) (DAP/HPN)
- 10.1) Remarks by the Subcommittee Chairman
  - 10.2) Discussion of the draft final report on ACRS assessment of the quality of the NRC research projects on: NUREG/CR-6964, “Crack Growth Rates and Metallographic Examinations of Alloy 600 and Alloy 82/182 from Field and Laboratory Materials Testing in PWR Environments,” and Draft NUREG/CR-XXXX, “Diversity Strategies for Nuclear Power Plant Instrumentation and Control Systems.”
- 11) 1:45 – 2:15 P.M. Subcommittee Reports (Open)
- 11.1) Report by and discussion with the Chairman of the ESBWR Subcommittee regarding review of the resolution of containment issues associated with the ESBWR design certification; and selected Chapters of the draft SER associated with the North Anna COL application referencing the ESBWR design, that were discussed on June 17-18, 2009. (MLC/CLB)

11.2) Report by and discussion with the Chairman of the Plant License Renewal Subcommittee regarding interim review of the Prairie Island License Renewal Application and the SER with Open Items, that were discussed on July 7, 2009. (HBR/CLB)

12) 2:15 – 3:00 P.M.

Future ACRS Activities/Report of the Planning and Procedures Subcommittee (Open/Closed) (MVB/EMH)

12.1) Discussion of the recommendations of the Planning and Procedures Subcommittee regarding items proposed for consideration by the full Committee during future ACRS meetings.

12.2) Report of the Planning and Procedures Subcommittee on matters related to the conduct of ACRS business, including anticipated workload and member assignments.

**[NOTE: A portion of this session may be closed pursuant to 5 U.S.C. 552b (c)(2) and (6) to discuss organizational and personnel matters that relate solely to internal personnel rules and practices of ACRS, and information the release of which would constitute a clearly unwarranted invasion of personal privacy]**

13) 3:00 – 3:15 P.M.

Reconciliation of ACRS Comments and Recommendations (Open) (MVB/CS/AFD)

Discussion of the responses from the NRC Executive Director for Operations to comments and recommendations included in recent ACRS reports and letters.

**3:15 – 3:30 P.M.**

**\*\*\* BREAK \*\*\***

14) 3:30 – 7:00 P.M.

Preparation of ACRS Reports (Open)

Discussion of proposed ACRS reports on:

14.1) License Renewal Application and the Final Safety Evaluation Report for the Beaver Valley Power Station (DCB/CLB)

14.2) Draft Final Revision 3 to Regulatory Guide 1.100, "Seismic Qualification of Electric and Mechanical Equipment Nuclear Power Plants" (JWS/MPL)

14.3) Applicability of TRACE Code to Evaluate New Light Water Reactor (LWR) Designs (SB/HPN/DEB)

14.4) DC/COL-ISG-006 and NEI 08-08, Revision 1, for meeting requirements of 10 CFR 20.1406, "Minimization of Contamination" (MTR/DAW)

14.5) Draft Final Regulatory Guide 1.215, "Guidance for ITAAC Closure under 10 CFR Part 52" (DCB/MLC/GSS)

for

**FRIDAY, JULY 10, 2009, CONFERENCE ROOM T-2B3, TWO WHITE FLINT NORTH,  
ROCKVILLE, MARYLAND**

- 15) 8:30 – 6:00 P.M. Preparation of ACRS Reports (Open)  
**(12:00-1:00 P.M. LUNCH)** Continue discussion of the proposed ACRS reports listed under Item 14.
- 16) 6:00 – 6:30 P.M. Miscellaneous (Open) (MVB/EMH)  
Discussion of matters related to the conduct of Committee activities and specific issues that were not completed during previous meetings, as time and availability of information permit.

**NOTES:**

- During the days of the meeting, phone number 301-415-7360 should be used in order to access anyone in the ACRS Office.
- Presentation time should not exceed 50 percent of the total time allocated for a given item. The remaining 50 percent of the time is reserved for discussion.
- Thirty five (35) hard copies and one (1) electronic copy of the presentation materials should be provided to the ACRS in advance of the briefing.

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
564<sup>th</sup> FULL COMMITTEE MEETING

July 8-10, 2009

PLEASE PRINT

TODAY'S DATE: July 8, 2009

| <u>NAME</u>            | <u>NRC ORGANIZATION</u> |
|------------------------|-------------------------|
| 1 Emma Wong            | NRR/DCI                 |
| 2 Tommy Morgan         | NRR/DCI                 |
| 3 RONALD BELLAMY       | NRC/REGION 1            |
| 4 DAVID WERKHEISER     | NRC/REGION 1/BUSRI      |
| 5 ALICE PAULSEN        | NRC/NRR/DLR             |
| 6 DAN HANUL            | NRR/DLR/PERZ            |
| 7 Matthew Mitchell     | NRR/DCI/CUEB            |
| 8 Thomas D'Agostino    | ACRS                    |
| 9 Patrick A. Azarbarin | ACRS (NRC)              |
| 10 DAVID ALLY          | NRR/DLR                 |
| 11 Bruce Heida         | NRR/ISS/SCUEB           |
| 12 Jim Davis           | NRR/DLR                 |
| 13 Seanf Min           | NRR/DLR/RRR/            |
| 14 On Yee              | NRR/DLR                 |
| 15 JAY ROBINSON        | NRR/DLR                 |
| 16 Rui Li              | NRR/DLR                 |
| 17 Nancy L. Salgado    | NRR/DORL/LPLI-1         |
| 18 Nadiyah Morgan      | NRR/DORL                |
| 19 CLIFF DAVIT         | NRR/DLR                 |
| 20 Bill Rogers         | NRR/DLR                 |
| 21 Rachel Vaucher      | NRR/DLR. ASA            |
| 22 Mita Svicar         | NRR/DLR                 |
| 23 Bruce Lehman        | DLR                     |
| 24 SAMSON LEE          | NRR/DLR                 |
| 25 Chang-yeh yang      | NRR/DLR                 |
| 26 Rarf Fu             | NRR/DLR                 |
| 27 John Dajly          | NRR/DLR                 |
| 28 Andrew Frincharis   | NRR/DLR                 |

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
564<sup>th</sup> FULL COMMITTEE MEETING

July 8-10, 2009

PLEASE PRINT

TODAY'S DATE: July 8, 2009

|    | <u>NAME</u>        | <u>NRC ORGANIZATION</u> |
|----|--------------------|-------------------------|
| 1  | Nareem TQBAL       | NRR/DRA/AFPB            |
| 2  | Evelyn Gettys      | WRR/DLR                 |
| 3  | Caroline E Tilton  | Reg III / DRG           |
| 4  | Vance A Perin      | NRR/DLR                 |
| 5  | Bruce Mallett      | NAC/DEDO                |
| 6  | THOMAS KOSIY       | NRC/RES/DE              |
| 7  | ANNE KAMMERER      | NRC/RES/DE              |
| 8  | Pei-Ying Chen      | NRC/NRO/DE/EMB          |
| 9  | STUART RICHARDS    | NRC/RES/DE              |
| 10 | GOOTAM BAGCHI      | NRC/NRO/DSEB            |
| 11 | KAMAL MANOLY       | NRR/DE                  |
| 12 | DAVID PASQUALE     | NRO/DCTP/CAUB2          |
| 13 | Thomas Sorebrough  | NRO/DE/CIB2             |
| 14 | Andy Campbell      | NRO/DCTP                |
| 15 | Ayo Ayebugi        | NRC/RI/DRS/EB3          |
| 16 | Emmanuel Sayoc     | NRC/NRR/DLR             |
| 17 | Hans Ashiv         | NRR/DLR                 |
| 18 | BRIAN HOLIAN       | ↓                       |
| 19 | John Burke         | RES/DE                  |
| 20 | Ching Ng           | NRO/DE                  |
| 21 | Joseph Studenmeier | RES/DSA                 |
| 22 | Chris Hoxie        | RES/DSA                 |
| 23 | Steve Bajorek      | RES/DSA                 |
| 24 |                    |                         |
| 25 |                    |                         |
| 26 |                    |                         |
| 27 |                    |                         |
| 28 |                    |                         |

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
564<sup>th</sup> FULL COMMITTEE MEETING

July 8-10, 2009

PLEASE PRINT

TODAY'S DATE: July 8, 2009

|    | <u>NAME</u>         | <u>NRC ORGANIZATION</u> |
|----|---------------------|-------------------------|
| 1  | DON DUBE            | NRO/DSRA                |
| 2  | Kathy Halvey Gibson | RES/DSA                 |
| 3  | RADPH LANDRY        | NRO/DSRA                |
| 4  | CARL THURSTON       | RES/DSA                 |
| 5  | J.M. KELLY          | RES/DSA                 |
| 6  | Tim Collins         | NRA/OSS                 |
| 7  | Jocelyn Mitchell    | RES/DSA                 |
| 8  | NATHAN SUE          | RES/DRA                 |
| 9  |                     |                         |
| 10 |                     |                         |
| 11 |                     |                         |
| 12 |                     |                         |
| 13 |                     |                         |
| 14 |                     |                         |
| 15 |                     |                         |
| 16 |                     |                         |
| 17 |                     |                         |
| 18 |                     |                         |
| 19 |                     |                         |
| 20 |                     |                         |
| 21 |                     |                         |
| 22 |                     |                         |
| 23 |                     |                         |
| 24 |                     |                         |
| 25 |                     |                         |
| 26 |                     |                         |
| 27 |                     |                         |
| 28 |                     |                         |

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
564<sup>th</sup> FULL COMMITTEE MEETING

July 8-10, 2009

PLEASE PRINT

TODAY'S DATE: July 8, 2009

| <u>NAME</u>            | <u>AFFILIATION</u>          |
|------------------------|-----------------------------|
| 1 LEVI STAHL           | FENOC                       |
| 2 Max Mancuso          | FENOC                       |
| 3 Tada Schneider       | FENOC                       |
| 4 DAVID JENKINS        | FENOC                       |
| 5 DENNIS WEARLAND      | FENOC                       |
| 6 F. WILLIAM ETZEL     | FENOC                       |
| 7 Dave Grubski         | FENOC                       |
| 8 G Thomas Westbrook   | FENOC                       |
| 9 Steve Buffington     | FENOC                       |
| 10 Larry Hinkle        | FENOC                       |
| 11 GLENN S. RITZ       | FENOC                       |
| 12 BRIAN MURTAGH       | FENOC                       |
| 13 JOHN THOMAS         | FENOC                       |
| 14 Anthony Dometrovich | FENOC                       |
| 15 Bryan Paul          | FENOC                       |
| 16 Ann Tweedell        | Public                      |
| 17 JOSEPH TWENDELL     | FENOC                       |
| 18 Julie Keys          | NEI                         |
| 19 Thomas Lentz        | FENOC                       |
| 20 KATHY M. SIMON      | Morgan Lewis                |
| 21 CHRIS WILSON        | EXELON                      |
| 22 CURT COSTER         | FENOC                       |
| 23 CARMEN MANCUSO      | FENOC                       |
| 24 CURT BOCK           | Next Era Energy Name Arnold |
| 25 MICHAEL BANKO       | FENOC                       |
| 26 James Parell o      | Westinghouse                |
| 27 Dave Flyte          | PPL Susquehanna             |
| 28 PETE SENA           | FENOC                       |

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
564<sup>th</sup> FULL COMMITTEE MEETING

July 8-10, 2009

PLEASE PRINT

TODAY'S DATE: July 8, 2009

| <u>NAME</u>             | <u>AFFILIATION</u>        |
|-------------------------|---------------------------|
| 1 Kimberly Keithline    | NEI                       |
| 2 JEANNIE M RINCKEL     | NET                       |
| 3 AK Kainik             | APS/PVNGS/STARS           |
| 4 PAUL GUNTER           | BEYOND NUCLEAR            |
| 5 cliff marks           | ESL inc                   |
| 6 <del>XXXXXXXXXX</del> |                           |
| 7 NIFIN BATEL           | MRE                       |
| 8 ROY MATHEW            | NRC/NRR                   |
| 9 DUC NGUYEN            | NRR/DCR                   |
| 10 Zuhuan Xi            | NRC/DSBR                  |
| 11 L. ROYER             | NRC/RPB2                  |
| 12 S. SHEN              | NRC/DLP                   |
| 13 Richard Starck       | MPR Associates, Inc.      |
| 14 MIKARU OGASAWARA     | MIITSUBISHI (MNEE)        |
| 15 Patricia Campbell    | GE Hitachi Nuclear Energy |
| 16                      |                           |
| 17                      |                           |
| 18                      |                           |
| 19                      |                           |
| 20                      |                           |
| 21                      |                           |
| 22                      |                           |
| 23                      |                           |
| 24                      |                           |
| 25                      |                           |
| 26                      |                           |
| 27                      |                           |
| 28                      |                           |



ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
564<sup>th</sup> FULL COMMITTEE MEETING

July 8-10, 2009

PLEASE PRINT

TODAY'S DATE: July 8, 2009

| <u>NAME</u>             | <u>AFFILIATION</u>        |
|-------------------------|---------------------------|
| 1 <u>Maureen Conley</u> | <u>Platts/McGraw-Hill</u> |
| 2 _____                 | _____                     |
| 3 _____                 | _____                     |
| 4 _____                 | _____                     |
| 5 _____                 | _____                     |
| 6 _____                 | _____                     |
| 7 _____                 | _____                     |
| 8 _____                 | _____                     |
| 9 _____                 | _____                     |
| 10 _____                | _____                     |
| 11 _____                | _____                     |
| 12 _____                | _____                     |
| 13 _____                | _____                     |
| 14 _____                | _____                     |
| 15 _____                | _____                     |
| 16 _____                | _____                     |
| 17 _____                | _____                     |
| 18 _____                | _____                     |
| 19 _____                | _____                     |
| 20 _____                | _____                     |
| 21 _____                | _____                     |
| 22 _____                | _____                     |
| 23 _____                | _____                     |
| 24 _____                | _____                     |
| 25 _____                | _____                     |
| 26 _____                | _____                     |
| 27 _____                | _____                     |
| 28 _____                | _____                     |

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
564<sup>th</sup> FULL COMMITTEE MEETING

July 8-10, 2009

PLEASE PRINT

TODAY'S DATE: July 9, 2008

| <u>NAME</u>                 | <u>NRC ORGANIZATION</u> |
|-----------------------------|-------------------------|
| EDWARD H. ROACH             | NRO/DCIP/CHPB           |
| Richard S. Clement          | NRO/DCIP/CHPB           |
| Tim Fry                     | NRO/DCIP/CHPB           |
| Zach Gran                   | NRO/DCIP/CHPB           |
| <del>William E. Smith</del> |                         |
| Sara Bernal                 | NRO/DCIP/CHPB           |
| Roa Lopera                  | NRO/DCIP/CHPB           |
| Andy Campbell               | NRO/DCIP                |
| Geoffrey Bejda              | NRO/DSEB                |
| Steve Williams              | NRO/DCIP/CHPB           |
| Robert Kellner              | NRO/DCIP/CHPB           |
| Richard L. Conatser         | NRR/IRIS                |
| George Cicotte              | NRO/DCIP/CHPB           |
| Michael Spencer             | NRC/OGC                 |
| John Tappert                | NRC/DCIP                |
| Mark Kowal                  | NRC/DCIP                |
| Tony Cerse                  | NRC/DCIP                |
| Ron Gardner                 | NRC/DCIP                |
| John A. Rigby               | RES/LE/REGS             |
| Terry Jackson               | NRO/DE/ICE1             |
| Eric Oesterle               | NRO/DNRL/NRGA           |
| Juelle Stanfin              | NRO/DCIP/CCIB           |
| Jerry Wilson                | NRO/DNRL/NRGA           |
| Hulbert Li                  | NRO/DE/ICE2             |
| Bruce Mallett               | NRC/DBDD                |
| Mahmoud Jardaneh            | NRO/DCIP/CTSB           |







**UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
WASHINGTON, DC 20555 - 0001**

June 18, 2009

**AGENDA  
564<sup>th</sup> ACRS MEETING  
JULY 8-10, 2009**

**WEDNESDAY, JULY 8, 2009, CONFERENCE ROOM T-2B3, TWO WHITE FLINT NORTH,  
ROCKVILLE, MARYLAND**

- 1) 8:30 – 8:35 A.M. Opening Remarks by the ACRS Chairman (Open) (MVB/EMH/SD)
  - 1.1) Opening statement
  - 1.2) Items of current interest
  
- 2) 8:35 – 10:00 A.M. License Renewal Application and the Final Safety Evaluation Report (SER) for the Beaver Valley Power Station (Open) (DCB/CLB)
  - 2.1) Remarks by the Subcommittee Chairman
  - 2.2) Briefing by and discussions with representatives of the NRC staff and FirstEnergy Nuclear Operating Company regarding the License Renewal Application for the Beaver Valley Power Station, the associated NRC staff's final SER, and related matters.

Members of the public may provide their views, as appropriate.

**10:00 – 10:15 A.M. \*\*\* BREAK \*\*\***

- 3) 10:15 – 11:45 A.M. Draft Final Revision 3 to Regulatory Guide 1.100, "Seismic Qualification of Electric and Mechanical Equipment for Nuclear Power Plants" (Open) (JWS/MPL)
  - 3.1) Remarks by the Subcommittee Chairman
  - 3.2) Briefing by and discussions with representatives of the NRC staff regarding Draft Final Revision 3 to Regulatory Guide 1.100, "Seismic Qualification of Electric and Mechanical Equipment for Nuclear Power Plants," and related matters.

Representatives of the nuclear industry and members of the public may provide their views, as appropriate.

**11:45 – 12:45 P.M. \*\*\* LUNCH \*\*\***

- 4) 12:45 – 2:45 P.M. Applicability of TRACE Code to Evaluate New Light Water Reactor (LWR) Designs (Open/Closed) (SB/HPN/DEB)  
4.1) Remarks by the Subcommittee Chairman  
4.2) Briefing by and discussions with representatives of the NRC staff regarding applicability of the TRACE Code to evaluate new LWR designs, and related matters.

**[NOTE: A portion of this Session may be closed to protect information that is proprietary to General Electric-Hitachi or its contractors pursuant to 5 U.S.C. 552b (c)(4)]**

Representatives of the nuclear industry and members of the public may provide their views, as appropriate.

**2:45 – 3:00 P.M. \*\*\* BREAK \*\*\***

- 5) 3:00 – 4:00 P.M. Format and Content of the Biennial Research Report to the Commission on the NRC Safety Research Program (Open) (DAP/HPN)  
5.1) Remarks by the Subcommittee Chairman  
5.2) Discussion of the Format and Content of the ACRS Biennial Report to the Commission on its review and evaluation of the NRC Safety Research Program, and related matters.

**4:00 – 4:15 P.M. \*\*\* BREAK \*\*\***

- 6) 4:15 – 7:00 P.M. Preparation of ACRS Reports (Open)  
Discussion of proposed ACRS reports on:  
6.1) License Renewal Application and the Final Safety Evaluation Report for the Beaver Valley Power Station (DCB/CLB)  
6.2) Draft Final Revision 3 to Regulatory Guide 1.100, "Seismic Qualification of Electric and Mechanical Equipment for Nuclear Power Plants" (JWS/MPL)  
6.3) Applicability of TRACE Code to Evaluate New Light Water Reactor (LWR) Designs (SB/HPN/DEB)

**THURSDAY, JULY 9, 2009, CONFERENCE ROOM T-2B3, TWO WHITE FLINT NORTH, ROCKVILLE, MARYLAND**

- 7) 8:30 – 8:35 A.M. Opening Remarks by the ACRS Chairman (Open) (MVB/CS/SD)  
8) 8:35 – 10:30 A.M. Design Certification (DC)/Combined License (COL) Interim Staff Guidance (ISG) -006 and Nuclear Energy Institute (NEI) document NEI 08-08, Revision 1 (Open) (MTR/DAW)  
8.1) Remarks by the Subcommittee Chairman  
8.2) Briefing by and discussions with representatives of the NRC staff regarding DC/COL-ISG-006, "Interim Staff

Guidance on Evaluation and Acceptance Criteria for 10 CFR 20.1406 to Support Design Certification and Combined License Applications,” and NEI 08-08, Revision 1, “Generic FSAR Template Guidance for Life Cycle Minimization of Contamination,” Contamination,” and related matters.

Representatives of the nuclear industry and members of the public may provide their views, as appropriate.

**10:30 – 10:45 A.M. \*\*\* BREAK \*\*\***

- 9) 10:45 – 12:15 P.M. Draft Final Regulatory Guide 1.215, “Guidance for ITAAC Closure under 10 CFR Part 52” (Open) (DCB/MLC/GSS)
- 9.1) Remarks by the Subcommittee Chairman
  - 9.2) Briefing by and discussions with representatives of the NRC staff regarding Draft Final Regulatory Guide 1.215 that provides guidance for closure of Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC ) under 10 CFR Part 52, and related matters.

Representatives of the nuclear industry and members of the public may provide their views, as appropriate.

**12:15 – 1:15 P.M. \*\*\* LUNCH \*\*\***

- 10) 1:15 – 1:45 P.M. Quality Assessment of Selected Research Projects (Open) (DAP/HPN)
- 10.1) Remarks by the Subcommittee Chairman
  - 10.2) Discussion of the draft final report on ACRS assessment of the quality of the NRC research projects on: NUREG/CR-6964, “Crack Growth Rates and Metallographic Examinations of Alloy 600 and Alloy 82/182 from Field and Laboratory Materials Testing in PWR Environments,” and Draft NUREG/CR-XXXX, “Diversity Strategies for Nuclear Power Plant Instrumentation and Control Systems.”
- 11) 1:45 – 2:15 P.M. Subcommittee Reports (Open)
- 11.1) Report by and discussion with the Chairman of the ESBWR Subcommittee regarding review of the resolution of containment issues associated with the ESBWR design certification; and selected Chapters of the draft SER associated with the North Anna COL application referencing the ESBWR design, that were discussed on June 17-18, 2009. (MLC/CLB)

11.2) Report by and discussion with the Chairman of the Plant License Renewal Subcommittee regarding interim review of the Prairie Island License Renewal Application and the SER with Open Items, that were discussed on July 7, 2009. (HBR/CLB)

12) 2:15 – 3:00 P.M.

Future ACRS Activities/Report of the Planning and Procedures Subcommittee (Open/Closed) (MVB/EMH)

12.1) Discussion of the recommendations of the Planning and Procedures Subcommittee regarding items proposed for consideration by the full Committee during future ACRS meetings.

12.2) Report of the Planning and Procedures Subcommittee on matters related to the conduct of ACRS business, including anticipated workload and member assignments.

**[NOTE: A portion of this session may be closed pursuant to 5 U.S.C. 552b (c)(2) and (6) to discuss organizational and personnel matters that relate solely to internal personnel rules and practices of ACRS, and information the release of which would constitute a clearly unwarranted invasion of personal privacy]**

13) 3:00 – 3:15 P.M.

Reconciliation of ACRS Comments and Recommendations (Open) (MVB/CS/AFD)

Discussion of the responses from the NRC Executive Director for Operations to comments and recommendations included in recent ACRS reports and letters.

**3:15 – 3:30 P.M.**

**\*\*\* BREAK \*\*\***

14) 3:30 – 7:00 P.M.

Preparation of ACRS Reports (Open)

Discussion of proposed ACRS reports on:

14.1) License Renewal Application and the Final Safety Evaluation Report for the Beaver Valley Power Station (DCB/CLB)

14.2) Draft Final Revision 3 to Regulatory Guide 1.100, "Seismic Qualification of Electric and Mechanical Equipment for Nuclear Power Plants" (JWS/MPL)

14.3) Applicability of TRACE Code to Evaluate New Light Water Reactor (LWR) Designs (SB/HPN/DEB)

14.4) DC/COL-ISG-006 and NEI 08-08, Revision 1, for meeting requirements of 10 CFR 20.1406, "Minimization of Contamination" (MTR/DAW)

14.5) Draft Final Regulatory Guide 1.215, "Guidance for ITAAC Closure under 10 CFR Part 52" (DCB/MLC/GSS)



**FRIDAY, JULY 10, 2009, CONFERENCE ROOM T-2B3, TWO WHITE FLINT NORTH,  
ROCKVILLE, MARYLAND**

- 15) 8:30 – 6:00 P.M. Preparation of ACRS Reports (Open)  
**(12:00-1:00 P.M. LUNCH)** Continue discussion of the proposed ACRS reports listed under Item 14.
- 16) 6:00 – 6:30 P.M. Miscellaneous (Open) (MVB/EMH)  
Discussion of matters related to the conduct of Committee activities and specific issues that were not completed during previous meetings, as time and availability of information permit.

**NOTES:**

- During the days of the meeting, phone number 301-415-7360 should be used in order to access anyone in the ACRS Office.
- Presentation time should not exceed 50 percent of the total time allocated for a given item. The remaining 50 percent of the time is reserved for discussion.
- Thirty five (35) hard copies and one (1) electronic copy of the presentation materials should be provided to the ACRS in advance of the briefing.

LIST OF DOCUMENTS FROM THE  
564<sup>TH</sup> ACRS MEETING JULY 8-10, 2009

- I. Opening Remarks by the ACRS Chairman
  1. Opening Remarks
  2. Items of Interest
  
- II. License Renewal Application and the Final Safety Evaluation Report (SER) for the Beaver Valley Power Station
  3. Proposed Schedule
  4. Status Report
  5. Beaver Valley Final SER
  6. Subcommittee meeting minutes dated April 23, 2009
  7. Letter from Peter Sena III, FENOC III to NRC, dated March 24, 2009, - Related to OI3.0.3.1.11-1 for Inaccessible Medium-Voltage Cables Not Subject to 10 FR 50.49 Environmental Qualification Requirements Program
  8. Letter from Peter Sena III, FENOC III to NRC, dated May 14, 2009 - Related to OI3.0.3.1.11-1 for Inaccessible Medium-Voltage Cables Not Subject to 10 FR 50.49 Environmental Qualification Requirements Program
  9. Letter from Peter Sena III, FENOC III to NRC, dated May 20, 2009, - Related to OI3.0.3.1.11-1 for Inaccessible Medium-Voltage Cables Not Subject to 10 CFR 50.49 Environmental Qualification Requirements Program
  10. Memorandum from George Wilson, NRR to Patrick Hiland, NRR regarding Generic Letter 2007-01, "Inaccessible or Underground Power Cable Failures that Disable Accident Mitigation Systems or Cause Plant Transients": Summary Report
  11. NRC Final Safety Evaluation Report, dated June 2009
  
- III. Draft Final Revision 3 to Regulatory Guide 1.100, "Seismic Qualification of Electric and Mechanical Equipment for Nuclear Power Plants"
  12. Proposed Schedule
  13. Status Report
  14. Draft Regulatory Guide DG-1175
  15. Regulatory Guide 1.100
  16. Staff Responses to Public Comments on Draft Regulatory Guide DG-1175
  
- IV. Applicability of TRACE Code to Evaluate New Light Water Reactor (LWR) Designs
  17. Table of Contents
  18. Proposed Schedule
  19. Status Report
  20. U.S. Nuclear Regulatory Commission, "Adequacy of the TRACE Computer Code for Simulating ESBWR Loss-of-Coolant Accidents," NUREG/CR-XXXX, ISL-NSAD-TR-08-01, Draft, August 2008
  21. Memorandum dated January 6, 2009, from Brian W. Sheron, Director, Office of Nuclear Regulatory Research, to the Commission, Subject: TRACE Thermal-Hydraulic Systems Analysis Code
  22. Consultant Report: "TRACE for ESBWR," March 19, 2009

LIST OF DOCUMENTS FROM THE  
564<sup>TH</sup> ACRS MEETING JULY 8-10, 2009

- II. Design Certification (DC)/Combined License (COL) Interim Staff Guidance (ISG) -006 and Nuclear Energy Institute (NEI) document NEI 08-08, Revision 1
- 23. Proposed Schedule
  - 24. Status Report
  - 25. NEI-08-08, "*Generic FSAR Template Guidance for Life-Cycle Minimization of Contamination*," Revision 1
  - 26. Draft ISG-006 on "*Evaluation and Acceptance Criteria for 10 CFR 20.1406 to Support Design Certification and Combined License Applications.*"
- IX. Draft Final Regulatory Guide 1.215, "Guidance for ITAAC Closure under 10 CFR Part 52
- 27. Proposed Schedule
  - 28. Status Report
  - 29. RG 1.215 (DG-1204), "Guidance for ITAAC Closure Under 10 CFR Part 52"
  - 30. Public Comments to DG-1204
  - 31. NEI 08-01, Revision 3, "Industry Guideline for the ITAAC Closure Process under 10 CFR Part 52"



# **ACRS Committee Brief on Staff Review of NEI 08-08 Template and DC/COL ISG-6**

**July 9, 2009**

**Presented by:**

**Timothy Frye, Chief, NRO/DCIP/CHPB**

**Edward Roach, Sr. Health Physicist, NRO/DCIP/CHPB**

**Dr. Hosung Ahn, NRO/DSER/RHEB**

# ACRS Presentation

- Purpose

- Brief the Subcommittee on the staff's review of revisions to NEI 08-08 and DC/COL ISG-6
- Explain the intended role of these documents in the licensing process.
- Discuss future activities incorporating this guidance

# NRC Staff Engagement

## – NRO

- Health Physics Branch
- Hydrologic Engineering Branch
- Balance of Plant Branches
- Containment and Ventilation Branches
- Rulemaking and Guidance Development Branch

## – NRR- Health Physics team

## – RES-

- Radiological Health Effects Branch
- Regulatory Guide Development branch

## – FSME- Reactor Decommissioning Branch

# Introduction/Background

- Subpart E- Radiological Criteria for License Termination Rule [i.e., 10CFR 20.1406(a) and (b)]
- Liquid Radioactive Release Lessons Learned Task Force Final Report, 9/1/2006
- NEI 07-07[Final] Industry Ground water Protection Initiative- Final guidance Document August 2007
- Regulatory Guide 4.21, Revision 0, “Minimization of Contamination and Radioactive Waste Generation: Life-Cycle Planning” June 2008

# Introduction/Background

- NRO actions Re:10CFR 20.1406
  - Conducted awareness training on RG 4.21 guidance for NRO technical branches.
  - Identified need for scoping, evaluation and acceptance criteria
  - Developed ISG-6 based on reviewer needs.
  - Industry developed NEI 08-08 template to support standard implementation of RG 4.21.



# NEI 08-08 Overview

- NEI 08-08 describes a generic FSAR operating program for COL applicants. The program uses a risk informed approach.
- It is intended to apply to all COLs regardless of the certified design type.
- The program will be implemented as a milestone under the license condition for the radiation protection program

# NEI 08-08 Issues

Key issues discussed in the NEI 08-08 template public meetings:

- Design Features- certified design features necessary to address 10 CFR 20.1406 (b); and Site-specific design features.
- Operating Programs- how NEI 08-08 proposed a standardized program for COL applicants
- Ensure coordination of NEI 08-08 with the existing operating reactor sites. (NEI 07-07 voluntary program, EPRI Technical report, and IE Bulletin 80-10)

# NEI 08-08 Template Overview

- Major sections include:
  - Applicability and Controls
  - Minimizing Facility Contamination
  - Guides for Minimizing Contamination of the Environment
  - Facilitation of Decommissioning
  - Minimizing the Generation of Waste
- The sections of NEI 08-08 are aligned with the sections of RG 4.21

# NEI 08-08 Staff Review Issues

- Introduction

- Staff questions related to the technical basis for the program.
- Staff concern that cost alone is not the determining factor when implementing the ALARA features

# NEI 08-08 Review Issues

- Applicability and Controls
  - Clarify comments related to NEI template and application. (Operating programs/site specific features)
  - NEI 08-08 did not address communication of offsite releases as described in NEI 07-07.
  - NEI 08-08 needed to address other mechanisms for release of radioactive material, not only ground water contamination.
  - Clarify if program would involve both initial and periodic evaluations. (Risk Assessment)

# NEI 08-08 Review Issues

- Minimizing Facility Contamination
  - Establish definition of thresholds- e.g., “credible mechanism” and “reasonably expected”
  - Discussion of examples or making all inclusive list of SSCs in document.
  - Inclusion of other programs with responsibilities for safe handling or containment of radioactive materials.
  - Ensure evaluation of cause and extent of condition when material is released.

# NEI 08-08 Review Issues

- Minimizing Contamination of the Environment  
(Hydrology issues)
  - Guidance on Site Conceptual Model (CSM) use
  - Use of term “downgradient” when locating monitoring wells,
  - Meaning of term “site boundary” for contamination analysis,
  - Clarify a “substantial change” to hydrological conditions
  - Program implementation timing (milestones)

# NEI 08-08 Review Issues

- Minimizing the Generation of Waste
  - Significant radioactive components-examples
  - Assessment of waste stored on site-
  - Establishment of Waste Management Plan



# NEI 08-08 Review Issues

- NEI 08-08 template usage:
  - Provides a program level description for COL applicants. It is not intended for DC applicants.
  - If accepted by staff, COL applicants can update the FSAR to incorporate the program and its milestone.
  - Establish a standard approach for procedures for operation to meet the guidance of RG 4.21.

# NEI 08-08 Summary

- NEI 08-08 describes a generic operating program for COL applicants.
- NRC Staff is currently conducting a safety evaluation to complete an SER on the generic FSAR guidance.
- If accepted COL applicants may commit to NEI 08-08 in the FSAR as the program description to be implemented.
- NRC staff will verify program implementation via the construction inspection program.
- Questions?

# DC/COL ISG-6-Interim Staff Guidance

- Background/Overview:
  - ISG-6-”Interim Staff Guidance on Evaluation and Acceptance Criteria for 10 CFR 20.1406 to Support Design Certification and Combined License Application” was developed to provide the NRC staff position on information and level of detail to demonstrate compliance with 10 CFR 20.1406.
  - Initial ISG issued for public comment on May 31, 2008 and received no public comments. Comment period closed July 31, 2008.

# DC/COL ISG-6-Interim Staff Guidance

- Acceptance Criteria:
  - Adequate design features exist, supplemented by operating programs.
  - Reasonable assurance that leaks and spills will be detected in a timely manner.
  - Site has been adequately characterized and conceptual site models developed.
  - Decommissioning features and their role are described.
  - Site will be operated in a manner to minimize the generation of radioactive waste (during operation and decommissioning).

# DC/COL ISG-6-Interim Staff Guidance

- Identifies the RG 4.21, Regulatory Positions C.1 –C.4 as providing guidance for compliance with 10 CFR20.1406.
- References the RG 4.21 Appendix A as a risk informed tool to determine applicable measures to consider.
- Interim staff guidance revision was based on staff comments questioning SSCs to review.
- Revision included a screening approach for SSCs (Attachment A); a list of operating experience events (Table 1).

# DC/COL ISG-6-Interim Staff Guidance Summary

- The DC/COL ISG-6-Interim Staff Guidance will provide interim guidance to assist the review of certified design applications and combined license applications.
- The guidance will be incorporated in upcoming NUREG-0800, Standard Review Plan revisions.
- Questions?



# U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

## REGULATORY GUIDE 1.215 GUIDANCE FOR ITAAC CLOSURE UNDER 10 CFR PART 52 (DG 1204)

Richard Laura, Team Lead  
Construction ITAAC Team  
NRO/DCIP/CTSB



# Purpose of RG 1.215

- Used as a vehicle to endorse NEI 08-01
- Promotes a standardized approach to ITAAC closure
- NEI 08-01 was primarily developed for the implementation of 10 CFR 52.99 “Inspection During Construction”
- Future update and revision of RG 1.215 and NEI 08-01 expected due to emerging topics such as ITAAC maintenance
- Staff considers the inspection process for ITAAC and DAC are beyond the scopes of NEI 08-01 and RG 1.215 (potentially separate ACRS briefing)





# Requirements of 10 CFR 52.99

## Inspection during construction:

- § 52.99(c)(1) The licensee shall notify the NRC that the prescribed inspections, tests, and analyses have been performed and that the prescribed acceptance criteria have been met. The notification must contain **sufficient information** to demonstrate that the prescribed inspections, tests, and analyses have been performed and that the prescribed **acceptance criteria have been met.**
- Referred to as ITAAC closure letters



# Requirements of 10 CFR 52.99

## Inspection during construction:

- § 52.99(c)(2)..... The notification must be provided no later than the date 225 days before the scheduled date for initial loading of fuel, and must provide **sufficient information** to demonstrate that the prescribed inspections, tests, or analyses will be performed and the prescribed acceptance criteria for the uncompleted ITAAC will be met, including, but not limited to, a description of the specific procedures and analytical methods to be used for performing the prescribed inspections, tests, and analyses and determining that the prescribed **acceptance criteria have been met.**
- Referred to as 225-day notifications, or “uncomplete” ITAAC notifications




# Key Points of 52.99

## Statements of Consideration

- The NRC expects the notification to be sufficiently complete and detailed for a **reasonable person** to understand the licensee's bases for the ITAAC closure notification
- Information disclosure requirements of 52.99(c) based on:
  - Need to provide information to support a timely NRC staff recommendation and Commission finding on an ITAAC
  - Need to provide access to sufficient information to potential interveners at the ITAAC hearing stage



# 52.99 and 52.103(g) Process Flowchart and Timeline





# Closure Letter Template

## **ITAAC Statement**

Lists the Design Commitment, Inspection/Test/Analysis, and Acceptance Criteria

## **ITAAC Determination Basis**

Summarizes the methodology for conducting the ITA, and the results that demonstrate that the acceptance criteria were met

## **ITAAC-Related Construction Finding Review**

Lists relevant ITAAC-related construction findings and states that all corrective actions have been completed, or provides a justification for why the ITAAC can be closed despite unresolved findings

## **ITAAC Closure Statement**

Statement that the ITAAC was performed and that the prescribed acceptance criteria were met

## **References**



# 225-Day Notification Template

## **ITAAC Statement**

Lists the Design Commitment, Inspection/Test/Analysis, and Acceptance Criteria

## **Actions Achieved Toward ITAAC Closure**

Provides status of activities related to ITAAC closure

## **Actions Remaining to Attain ITAAC Closure**

Provides a high level discussion of the remaining activities, and summarizes the methodology for conducting the ITA

## **ITAAC Closure Schedule**

Provides forward looking statements for confidence that these actions will be achieved

## **References**



# Public Comments on DG1204

- 60-day public comment period ended May 13, 2009
- Comments received from 2 stakeholders
- NEI comments comprised majority, but were mostly editorial in nature
- Comment requiring significant effort involves the definition of “as-built”
  - NEI 08-01 has additional language in 3.1.4 that limits the use of as-built inspections that do not occur in the final location at the plant site to when it is “impractical”
  - RG clarifies that this limitation should be included in future design certifications



## AP-1000 ITAAC 2.1.3.2.c

### “Impractical” As-built Field Measurements

- Requires inspection of “as-built” reactor system to confirm the reactor vessel arrangement illustrated on a drawing with dimensional criteria
- One dimension identified is the RV wall thickness (without cladding) at its beltline
- Since the RV will be delivered to the site with cladding installed, the inspection of this critical dimension must be performed and accepted at the RV supplier fabrication facility
- RV is an ASME Code, Class 1 component, and delivered onsite as a Code stamped component with certification to substantiate that the properties and dimensional requirements meet the design specification and procurement requirements





# July 7<sup>th</sup> ACRS Subcommittee Meeting

- Through prioritization, targeted ITAAC inspections will encompass all significant construction activities
- RG 1.215 and NEI 08-01 will be compared for terminology consistency (closure vs complete)
- Recommended editorial changes to the 52.99 and 52.103(g) flowchart and timeline in App B will be completed before final issuance



# Design Acceptance Criteria (DAC)

- DAC is a subset of ITAAC
- All DAC will be reviewed and/or inspected
- DAC inspection processes will be included in IMCs
- Design-level review and/or inspection will be completed by HQ
- As-built field inspections
- Documentation for DAC closure to follow process in NEI 08-01



# ESBWR ITAAC, Rev 5

| Design Commitment  | Inspections, Tests, Analyses  | Acceptance Criteria   |
|--|---|---|
| <p>1. Criterion 5.1, Single Failure:<br/>The Criterion 5.1 systems listed in Table 2.2.15-1 are designed to ensure that safety-related functions required for design basis events (DBE) are performed in the presence of: (a) single detectable failures within safety-related systems concurrent with identifiable but non-detectable failures; (b) failures caused by the single failure; and (c) failures and spurious system actions that cause or are caused by the DBE requiring the safety-related functions, as identified in the applicable FMEA.</p> | <p>Block level FMEA of the Criterion 5.1 systems listed in Table 2.2.15-1 show that they perform safety-related functions required for design basis events in the presence of: (a) single detectable failures within safety-related systems concurrent with identifiable but non-detectable failures; (b) failures caused by the single failure; and (c) failures and spurious system actions that cause or are caused by the DBE requiring the safety-related functions, as identified in the applicable FMEA.</p> <p>{{Design Acceptance Criteria}}</p> | <p>Analysis report(s) conclude(s) that the systems identified in Table 2.2.15-1 for Criterion 5.1 ensure(s) that safety-related functions required for design basis events are performed in the presence of: (a) single detectable failures within safety-related systems concurrent with identifiable but non-detectable failures; (b) failures caused by the single failure; and (c) failures and spurious system actions that cause or are caused by the DBE requiring the safety related functions, as identified in the applicable FMEA.</p> <p>{{Design Acceptance Criteria}}</p> <p style="text-align: right;"><b>HQ</b></p> |
| <p>2. Criteria 5.2 and 7.3, Completion of Protective Actions:<br/>The Criteria 5.2 and 7.3 systems listed in Table 2.2.15-1 are designed so that, (a) once initiated (automatically or manually), the intended sequences of safety-related functions of the execute features continue until completion, and (b) after completion, deliberate operator action is required to return the safety-related systems to normal.</p>   | <p>a. Inspection of the current revision of the simplified logic diagrams (SLDs) for the Criteria 5.2 and 7.3 systems listed in Table 2.2.15-1 verifies that the design shows (a) “seal-in” features that are provided to enable system-level safety-related functions to go to completion, and (b) “manual reset” features that are provided to require deliberate operation action to return the safety-related systems to normal.</p> <p>{{Design Acceptance Criteria}}</p>  | <p>a. Inspection report(s) conclude(s) that the current revision of the SLDs show (a) “seal-in” features, and (b) “manual reset” features.</p> <p>{{Design Acceptance Criteria}}</p> <p style="text-align: center;"><b>RII</b></p>  |



# Key Points

- Staff has accomplished what was originally intended for guidance, and considers the RG ready for issuance
- Through endorsing industry guidance, the RG sets a milestone on Part 52 process agreement between staff and external stakeholders
- Substantial progress has been made in developing guidance for implementing Part 52
- Consensus was achieved in the 26 templates that form the basis for ITAAC closure
- Staff to provide the RG to the Commission as requested in August 2009