ArevaEPRDCPEm Resource

From: BRYAN Martin (EXTERNAL AREVA) [Martin.Bryan.ext@areva.com]
Sent: Wednesday, September 01, 2010 6:43 PM
To: Tesfaye, Getachew
Cc: DELANO Karen (AREVA); ROMINE Judy (AREVA); BENNETT Kathy (AREVA); GUCWA Len (EXTERNAL AREVA)
Subject: Response to U.S. EPR Design Certification Application RAI No. 297, FSAR Ch 6, Supplement 9

Getachew,

AREVA NP Inc. (AREVA NP) provided a response to 1 of the 10 questions of RAI No. 297 on November 16, 2009. AREVA NP submitted Supplement 1 to the response on December 17, 2009 to address 1 of the remaining 9 questions. AREVA NP submitted Supplement 2 to the response on February 16, 2010 to address 5 of the remaining 8 questions. AREVA NP submitted Supplement 3 to the response on March 16, 2010 to provide a revised response schedule. AREVA NP submitted Supplement 4 response to RAI No. 297 on April 22, 2010 to provide a revised response schedule. AREVA NP submitted Supplement 5 response to RAI No. 297 on May 5, 2010 to also provide a revised response schedule. The Supplement 6 response was submitted on May 20, 2010 to address 2 of the remaining 3 questions. On June 30, 2010 and August 4, 2010, Supplement 7 and Supplement 8, respectively, were submitted to provide a revised schedule. As additional time is needed to interact with the NRC on the DRAFT response, the schedule is revised below.

The revised schedule for a technically correct and complete response to the remaining RAI 297 question is provided below.

Question #	Response Date
RAI 297 — 06.02.01-51	October 7, 2010

Sincerely,

Martin (Marty) C. Bryan
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.
Tel: (434) 832-3016
702 561-3528 cell
Martin.Bryan.ext@areva.com

From: BRYAN Martin (EXT)
Sent: Wednesday, August 04, 2010 5:09 PM
To: 'Tesfaye, Getachew'
Cc: DELANO Karen (RS/NB); ROMINE Judy (RS/NB); BENNETT Kathy (RS/NB); GUCWA Len T (EXT)
Subject: Response to U.S. EPR Design Certification Application RAI No. 297, FSAR Ch 6, Supplement 8

Getachew,

AREVA NP Inc. (AREVA NP) provided a response to 1 of the 10 questions of RAI No. 297 on November 16, 2009. AREVA NP submitted Supplement 1 to the response on December 17, 2009 to address 1 of the remaining 9 questions. AREVA NP submitted Supplement 2 to the response on February 16, 2010 to address 5 of the remaining 8 questions. AREVA NP submitted Supplement 3 to the response on March 16, 2010 to provide a revised response schedule. AREVA NP submitted Supplement 4 response to RAI No. 297 on April 22, 2010 to provide a revised response schedule. AREVA NP submitted Supplement 5 response to RAI No.

297 on May 5, 2010 to also provide a revised response schedule. The Supplement 6 response was submitted on May 20, 2010 to address 2 of the remaining 3 questions. On June 30, 2010, Supplement 7 was submitted to provide a revised schedule. As additional time is needed to interact with the NRC on the response, the schedule is revised below.

The schedule for providing a technically correct and complete response is changed and provided below.

Question #	Response Date
RAI 297 — 06.02.01-51	September 1, 2010

Sincerely,

Martin (Marty) C. Bryan
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.
Tel: (434) 832-3016
702 561-3528 cell
Martin.Bryan.ext@areva.com

From: BRYAN Martin (EXT)
Sent: Wednesday, June 30, 2010 3:54 PM
To: 'Tesfaye, Getachew'
Cc: DELANO Karen V (AREVA NP INC); ROMINE Judy (AREVA NP INC); BENNETT Kathy A (OFR) (AREVA NP INC); GUCWA Len T (EXT)
Subject: Response to U.S. EPR Design Certification Application RAI No. 297, FSAR Ch 6, Supplement 7

Getachew,

AREVA NP Inc. (AREVA NP) provided a response to 1 of the 10 questions of RAI No. 297 on November 16, 2009. AREVA NP submitted Supplement 1 to the response on December 17, 2009 to address 1 of the remaining 9 questions. AREVA NP submitted Supplement 2 to the response on February 16, 2010 to address 5 of the remaining 8 questions. AREVA NP submitted Supplement 3 to the response on March 16, 2010 to provide a revised response schedule. AREVA NP submitted Supplement 4 response to RAI No. 297 on April 22, 2010 to provide a revised response schedule. AREVA NP submitted Supplement 5 response to RAI No. 297 on May 5, 2010 to also provide a revised response schedule. The Supplement 6 response was submitted on May 20, 2010 to address 2 of the remaining 3 questions.

As agreed with NRC, AREVA NP is providing a revised date for RAI 297 Supplement 7 at this time to accommodate the opportunity to interact with the NRC on the response. The revised schedule for a technically correct and complete response to the remaining RAI 297 question is provided below.

Question #	Response Date
RAI 297 — 06.02.01-51	August 4, 2010

Sincerely,

Martin (Marty) C. Bryan
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.
Tel: (434) 832-3016
702 561-3528 cell
Martin.Bryan.ext@areva.com

From: BRYAN Martin (EXT)
Sent: Thursday, May 20, 2010 3:42 PM
To: 'Tesfaye, Getachew'
Cc: DELANO Karen V (AREVA NP INC); ROMINE Judy (AREVA NP INC); BENNETT Kathy A (OFR) (AREVA NP INC); GUCWA Len T (EXT)
Subject: Response to U.S. EPR Design Certification Application RAI No. 297, FSAR Ch 6, Supplement 6

Getachew,

AREVA NP Inc. (AREVA NP) provided a response to 1 of the 10 questions of RAI No. 297 on November 16, 2009. AREVA NP submitted Supplement 1 to the response on December 17, 2009 to address 1 of the remaining 9 questions. AREVA NP submitted Supplement 2 to the response on February 16, 2010 to address 5 of the remaining 8 questions. AREVA NP submitted Supplement 3 to the response on March 16, 2010 to provide a revised response schedule. AREVA NP submitted Supplement 4 response to RAI No. 297 on April 22, 2010 to provide a revised response schedule. AREVA NP submitted Supplement 5 response to RAI No. 297 on May 5, 2010 to also provide a revised response schedule.

The attached file, "RAI 297 Supplement 6 Response US EPR DC.pdf," provides a technically correct and complete response to 2 of the 3 remaining questions.

The following table indicates the respective pages in the response document, "RAI 297 Supplement 6 Response US EPR DC.pdf," that contain AREVA NP's responses to the subject questions.

Question #	Start Page	End Page
RAI 297 — 06.02.02-39	2	2
RAI 297 — 06.02.02-40	3	3

The schedule for a technically correct and complete response to Question 06.02.01-51 is unchanged and provided below.

Question #	Response Date
RAI 297 — 06.02.01-51	June 30, 2010

Sincerely,

Martin (Marty) C. Bryan
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.
Tel: (434) 832-3016
702 561-3528 cell
Martin.Bryan.ext@areva.com

From: BRYAN Martin (EXT)
Sent: Wednesday, May 05, 2010 5:55 PM
To: 'Tesfaye, Getachew'
Cc: DELANO Karen V (AREVA NP INC); ROMINE Judy (AREVA NP INC); BENNETT Kathy A (OFR) (AREVA NP INC); GUCWA Len T (EXT)
Subject: Response to U.S. EPR Design Certification Application RAI No. 297, FSAR Ch 6, Supplement 5

Getachew,

AREVA NP Inc. (AREVA NP) provided a response to 1 of the 10 questions of RAI No. 297 on November 16, 2009. AREVA NP submitted Supplement 1 to the response on December 17, 2009 to address 1 of the remaining 9 questions. AREVA NP submitted Supplement 2 to the response on February 16, 2010 to address 5 of the remaining 8 questions. AREVA NP submitted Supplement 3 to the response on March 16, 2010 to provide a revised response schedule, and Supplement 4 response to RAI No. 297 was sent on April 22, 2010 to also provide a revised response schedule.

The response to RAI 297 Question 06.02.01-51 is dependent upon an ongoing analysis of the main steam line break using FSAR Chapter 15 assumptions. Because of these ongoing activities, AREVA NP is not providing a response at this time. The revised schedule for a technically correct and complete response to RAI 297 is provided below. The schedule for responding to Question 06.02.01-55 has been revised while the schedule for providing technically correct and complete responses to Questions 06.02.02-39 and 06.02.02-40 is unchanged. The bases for the schedule change were discussed with NRC staff during an audit conducted on April 30, 2010.

Question #	Response Date
RAI 297 — 06.02.01-51	June 30, 2010
RAI 297 — 06.02.02-39	May 20, 2010
RAI 297 — 06.02.02-40	May 20, 2010

Sincerely,

Martin (Marty) C. Bryan
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.
Tel: (434) 832-3016
702 561-3528 cell
Martin.Bryan.ext@areva.com

From: BRYAN Martin (EXT)
Sent: Thursday, April 22, 2010 6:17 PM
To: 'Getachew.Tesfaye@nrc.gov'
Cc: DELANO Karen V (AREVA NP INC); BENNETT Kathy A (OFR) (AREVA NP INC); ROMINE Judy (AREVA NP INC); GUCWA Len T (EXT)
Subject: Response to U.S. EPR Design Certification Application RAI No. 297, FSAR Ch 6, Supplement 4

Getachew,

AREVA NP Inc. (AREVA NP) provided a response to 1 of the 10 questions of RAI No. 297 on November 16, 2009. AREVA NP submitted Supplement 1 to the response on December 17, 2009 to address 1 of the remaining 9 questions. AREVA NP submitted Supplement 2 to the response on February 16, 2010 to address 5 of the remaining 8 questions. AREVA NP submitted Supplement 3 to the response on March 16, 2010 to provide a revised response schedule.

Responses to RAI 297 Questions 06.02.02-39 and 06.02.02-40 are dependent upon the results of ongoing GSI-191 evaluations for demonstrating sump strainer performance. Because of these ongoing activities, AREVA NP is not providing a response at this time. The revised schedule for technically correct and complete responses to Questions 06.02.02-39 and 06.02.02-401-51 is provided below. The schedule for providing a response to Question 06.02.01-51 is unchanged.

Question #	Response Date
RAI 297 — 06.02.01-51	May 5, 2010
RAI 297 — 06.02.02-39	May 20, 2010

RAI 297 — 06.02.02-40	May 20, 2010

Sincerely,

Martin (Marty) C. Bryan
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.
Tel: (434) 832-3016
702 561-3528 cell
Martin.Bryan.ext@areva.com

From: BRYAN Martin (EXT)
Sent: Tuesday, March 16, 2010 11:41 AM
To: 'Tesfaye, Getachew'
Cc: DELANO Karen V (AREVA NP INC); BENNETT Kathy A (OFR) (AREVA NP INC); ROMINE Judy (AREVA NP INC); GUCWA Len T (EXT)
Subject: Response to U.S. EPR Design Certification Application RAI No. 297, FSAR Ch 6, Supplement 3

Getachew,

AREVA NP Inc. (AREVA NP) provided a response to 1 of the 10 questions of RAI No. 297 on November 16, 2009. AREVA NP submitted Supplement 1 to the response on December 17, 2009 to address 1 of the remaining 9 questions. AREVA NP submitted Supplement 2 to the response on February 16, 2010 to address 5 of the remaining 8 questions.

The response to Question 06.02.01-51 is dependent upon certain activities which have been rescheduled as reported in the response to RAI 266, Supplement 4. Therefore, the schedule for a technically correct and complete response to Question 06.02.01-51 is revised and provided below. The schedule for providing responses to the other two RAI questions is unchanged.

The schedule for technically correct and complete responses to the remaining 3 questions is provided below.

Question #	Response Date
RAI 297 — 06.02.01-51	May 5, 2010
RAI 297 — 06.02.02-39	April 22, 2010
RAI 297 — 06.02.02-40	April 22, 2010

Sincerely,

Martin (Marty) C. Bryan
Licensing Advisory Engineer
AREVA NP Inc.
Tel: (434) 832-3016
Martin.Bryan.ext@areva.com

From: DUNCAN Leslie E (AREVA NP INC)
Sent: Tuesday, February 16, 2010 5:20 PM
To: 'Tesfaye, Getachew'
Cc: DELANO Karen V (AREVA NP INC); BENNETT Kathy A (OFR) (AREVA NP INC); ROMINE Judy (AREVA NP INC);

GUCWA Len T (EXT)
Subject: Response to U.S. EPR Design Certification Application RAI No. 297, FSAR Ch 6, Supplement 2

Getachew,

AREVA NP Inc. (AREVA NP) provided a response to 1 of the 10 questions of RAI No. 297 on November 16, 2009. AREVA NP submitted Supplement 1 to the response on December 17, 2009 to address 1 of the remaining 9 questions. The attached file, "RAI 297 Supplement 2 Response US EPR DC.pdf," provides a technically correct and complete response to 5 of the remaining 8 questions.

The following table indicates the respective pages in the response document, "RAI 297 Supplement 2 Response US EPR DC.pdf," that contain AREVA NP's response to the subject questions.

Question #	Start Page	End Page
RAI 297 — 06.02.01-49	2	3
RAI 297 — 06.02.01-50	4	22
RAI 297 — 06.02.02-37	23	23
RAI 297 — 06.02.02-38	24	24
RAI 297 — 06.02.02-39	25	25
RAI 297 — 06.02.02-40	26	26
RAI 297 — 06.02.02-41	27	27

The schedule for a technically correct and complete response to Question 06.02.01-51 is unchanged and provided below. Responses to Questions 06.02.02-39 and 06.02.02-40 are dependent upon the results of ongoing GSI-191 head loss testing, which will demonstrate sump strainer performance. Because additional testing is planned, AREVA NP is not providing a response at this time. The schedule for technically correct and complete responses to Questions 06.02.02-39 and 06.02.02-40 has been revised and is provided below.

Question #	Response Date
RAI 297 — 06.02.01-51	March 17, 2010
RAI 297 — 06.02.02-39	April 22, 2010
RAI 297 — 06.02.02-40	April 22, 2010

Sincerely,

Les Duncan
Licensing Engineer
AREVA NP Inc.
An AREVA and Siemens Company
Tel: (434) 832-2849
Leslie.Duncan@areva.com

From: WELLS Russell D (AREVA NP INC)
Sent: Thursday, December 17, 2009 10:51 AM
To: 'Getachew Tesfaye'
Cc: Pederson Ronda M (AREVA NP INC); BENNETT Kathy A (OFR) (AREVA NP INC); DELANO Karen V (AREVA NP INC)
Subject: Response to U.S. EPR Design Certification Application RAI No. 297, FSAR Ch 6, Supplement 1

Getachew,

AREVA NP Inc. (AREVA NP) provided a response to 1 of the 10 questions of RAI No. 297 on November 16, 2009. The attached file, "RAI 297 Supplement 1 Response US EPR DC.PDF" provides a technically correct and complete response to 1 of the remaining 9 questions, as committed.

The following table indicates the respective pages in the response document, "RAI 297 Supplement 1 Response US EPR DC.PDF," that contain AREVA NP's response to the subject question.

Question #	Start Page	End Page
RAI 297 — 06.02.01-52	2	6

The schedule for technically correct and complete responses to the remaining 8 questions is unchanged and provided below:

Question #	Response Date
RAI 297 — 06.02.01-49	February 16, 2010
RAI 297 — 06.02.01-50	February 16, 2010
RAI 297 — 06.02.01-51	March 17, 2010
RAI 297 — 06.02.02-37	February 16, 2010
RAI 297 — 06.02.02-38	February 16, 2010
RAI 297 — 06.02.02-39	February 16, 2010
RAI 297 — 06.02.02-40	February 16, 2010
RAI 297 — 06.02.02-41	February 16, 2010

Sincerely,

(Russ Wells on behalf of)

Ronda Pederson
ronda.pederson@areva.com
Licensing Manager, U.S. EPR Design Certification
New Plants Deployment
AREVA NP, Inc.
An AREVA and Siemens company
3315 Old Forest Road
Lynchburg, VA 24506-0935
Phone: 434-832-3694
Cell: 434-841-8788

From: Pederson Ronda M (AREVA NP INC)
Sent: Monday, November 16, 2009 5:58 PM
To: Tesfaye, Getachew
Cc: BENNETT Kathy A (OFR) (AREVA NP INC); DELANO Karen V (AREVA NP INC); GUCWA Len T (EXT)
Subject: Response to U.S. EPR Design Certification Application RAI No. 297, FSAR Ch. 6

Getachew,

Attached please find AREVA NP Inc.'s response to the subject request for additional information (RAI). The attached file, "RAI 297 Response US EPR DC.PDF" provides technically correct and complete responses to 1 of the 10 questions.

The following table indicates the respective page(s) in the response document, "RAI 297 Response US EPR DC.PDF," that contain AREVA NP's response to the subject questions.

Question #	Start Page	End Page
RAI 297 — 06.02.01-49	2	2
RAI 297 — 06.02.01-50	3	3
RAI 297 — 06.02.01-51	4	4
RAI 297 — 06.02.01-52	5	5
RAI 297 — 06.02.02-37	6	6
RAI 297 — 06.02.02-38	7	7
RAI 297 — 06.02.02-39	8	8
RAI 297 — 06.02.02-40	9	9
RAI 297 — 06.02.02-41	10	10
RAI 297 — 06.02.02-42	11	12

A complete answer is not provided for 9 of the 10 questions. The schedule for a technically correct and complete response to these questions is provided below.

Question #	Response Date
RAI 297 — 06.02.01-49	February 16, 2010
RAI 297 — 06.02.01-50	February 16, 2010
RAI 297 — 06.02.01-51	March 17, 2010
RAI 297 — 06.02.01-52	January 7, 2010
RAI 297 — 06.02.02-37	February 16, 2010
RAI 297 — 06.02.02-38	February 16, 2010
RAI 297 — 06.02.02-39	February 16, 2010
RAI 297 — 06.02.02-40	February 16, 2010
RAI 297 — 06.02.02-41	February 16, 2010

Sincerely,

Ronda Pederson
ronda.pederson@areva.com
Licensing Manager, U.S. EPR Design Certification
AREVA NP Inc.
An AREVA and Siemens company
3315 Old Forest Road
Lynchburg, VA 24506-0935
Phone: 434-832-3694
Cell: 434-841-8788

From: Tesfaye, Getachew [mailto:Getachew.Tesfaye@nrc.gov]
Sent: Thursday, October 15, 2009 1:40 PM
To: ZZ-DL-A-USEPR-DL
Cc: Jensen, Walton; Ashley, Clinton; Jackson, Christopher; Hammer, Charles; Terao, David; Carneal, Jason; Colaccino, Joseph; ArevaEPRDCPEm Resource
Subject: U.S. EPR Design Certification Application RAI No. 297(3759,3719,3775), FSAR Ch. 6

Attached please find the subject requests for additional information (RAI). A draft of the RAI was provided to you on September 22, 2009, and discussed with your staff on October 13, 2009. Draft RAI Question 06.02.02-41 was modified as a result of that discussion. The schedule we have

established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a date for receipt of this information will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the published schedule.

Thanks,
Getachew Tesfaye
Sr. Project Manager
NRO/DNRL/NARP
(301) 415-3361

Hearing Identifier: AREVA_EPR_DC_RAIs
Email Number: 1940

Mail Envelope Properties (BC417D9255991046A37DD56CF597DB710768F30A)

Subject: Response to U.S. EPR Design Certification Application RAI No. 297, FSAR Ch 6, Supplement 9
Sent Date: 9/1/2010 6:43:00 PM
Received Date: 9/1/2010 6:47:30 PM
From: BRYAN Martin (EXTERNAL AREVA)

Created By: Martin.Bryan.ext@areva.com

Recipients:
"DELANO Karen (AREVA)" <Karen.Delano@areva.com>
Tracking Status: None
"ROMINE Judy (AREVA)" <Judy.Romine@areva.com>
Tracking Status: None
"BENNETT Kathy (AREVA)" <Kathy.Bennett@areva.com>
Tracking Status: None
"GUCWA Len (EXTERNAL AREVA)" <Len.Gucwa.ext@areva.com>
Tracking Status: None
"Tesfaye, Getachew" <Getachew.Tesfaye@nrc.gov>
Tracking Status: None

Post Office: AUSLYNCMX02.adom.ad.corp

Files	**Size**	**Date & Time**
MESSAGE	19166	9/1/2010 6:47:30 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: