

PMComanchePeakPEm Resource

From: Monarque, Stephen
Sent: Thursday, September 02, 2010 4:40 PM
To: John.Only@luminant.com; Donald.Woodlan@luminant.com; cp34-rai-luminant@mnes-us.com; Diane Yeager; Eric.Evans@luminant.com; joseph tapia; Kazuya Hayashi; Matthew.Weeks@luminant.com; MNES RAI mailbox; Russ Bywater
Cc: ComanchePeakCOL Resource; Otto, Ngola
Subject: Comanche Peak RCOL Chapter 14, Section 14.3.7 - RAI Number 175
Attachments: RAI 5005 (RAI 175).docx

The NRC staff has identified that additional information is needed to continue its review of the combined license application. The NRC staff's request for additional information (RAI) is contained in the attachment. Luminant is requested to inform the NRC staff if a conference call is needed.

The response to this RAI is due within **35** calendar days of September 2, 2010.

Note: If changes are needed to the safety analysis report, the NRC staff requests that the RAI response include the proposed changes.

thanks,

Stephen Monarque
U. S. Nuclear Regulatory Commission
NRO/DNRL/NMIP
301-415-1544

Hearing Identifier: ComanchePeak_COL_Public
Email Number: 1032

Mail Envelope Properties (9C2386A0C0BC584684916F7A0482B6CA18FF355F54)

Subject: Comanche Peak RCOL Chapter 14, Section 14.3.7 - RAI Number 175
Sent Date: 9/2/2010 4:39:57 PM
Received Date: 9/2/2010 4:40:00 PM
From: Monarque, Stephen

Created By: Stephen.Monarque@nrc.gov

Recipients:

"ComanchePeakCOL Resource" <ComanchePeakCOL.Resource@nrc.gov>

Tracking Status: None

"Otto, Ngola" <Ngola.Otto@nrc.gov>

Tracking Status: None

"John.Only@luminant.com" <John.Only@luminant.com>

Tracking Status: None

"Donald.Woodlan@luminant.com" <Donald.Woodlan@luminant.com>

Tracking Status: None

"cp34-rai-luminant@mnes-us.com" <cp34-rai-luminant@mnes-us.com>

Tracking Status: None

"Diane Yeager" <diane_yeager@mnes-us.com>

Tracking Status: None

"Eric.Evans@luminant.com" <Eric.Evans@luminant.com>

Tracking Status: None

"joseph tapia" <joseph_tapia@mnes-us.com>

Tracking Status: None

"Kazuya Hayashi" <kazuya_hayashi@mnes-us.com>

Tracking Status: None

"Matthew.Weeks@luminant.com" <Matthew.Weeks@luminant.com>

Tracking Status: None

"MNES RAI mailbox" <cp34-rai@mnes-us.com>

Tracking Status: None

"Russ Bywater" <russell_bywater@mnes-us.com>

Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

| Files | Size | Date & Time |
|-------------------------|-------------|------------------------|
| MESSAGE | 647 | 9/2/2010 4:40:00 PM |
| RAI 5005 (RAI 175).docx | | 20013 |

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received:

Request for Additional Information (RAI) No. 5005, COLA Revision 1

RAI Number 175

9/2/2010

Comanche Peak Units 3 and 4
Luminant Generation Company, LLC.
Docket No. 52-034 and 52-035

SRP Section: 14.03.07 - Plant Systems - Inspections, Tests, Analyses, and Acceptance Criteria
Application Section: Part 10, Table A.1-1, Items 11 and 12

QUESTIONS for Technical Specification Branch (CTSB)

14.03.07-30

The regulatory basis for this question is 10 CFR 50.70 and 10 CFR 50, Appendix B, Criterion III, Design Control.

Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Items 11 and 12 in Table A.1-1

The staff requested the applicant to revise ITAAC Items 11 and 12 and also Table A.1-3 in RAI question (RAI Number 81 (3293), Question 14.03.07-7 (13065)). The applicant in its response, dated November 13, 2009, made the following revisions: (a) ITAAC 11 in Table A.1-1 was revised to state that the Main Control Room (MCR) alarms and displays in Table A.1-3 can be retrieved, (b) ITAAC 12 in Table A.1-1 was revised to state that Remote Shutdown Console (RSC) alarms, displays, and controls identified in Table A.1-3 exist, and (c) Table A.1-3 was revised to correctly indicate all control functions, alarms, and displays in MCR and on RSC. The staff agreed with the majority of the applicant's response, but the staff did not agree with the following: (i) that MCR controls, displays, and alarms can be retrieved, and that RSC controls, displays, and alarms only exist, and (ii) inspections are being used to verify the proper functioning of controls. The staff requests that ITAAC Item 12 be revised to state that RSC controls, displays, and alarms can be retrieved at the RSC, and that both ITAAC Items 11 and 12 should be revised to require the performance of a combination of tests and inspections because inspections alone cannot verify the operation of controls.