[55.100] ESTD 10/4/82

NOTES:

1. SYSTEM FUNCTIONS SHOWN ARE FOR NORMAL OPERATION UNDER FULL LOAD.
2. FOR GENERAL NOTES, PIPING SYMBOLS AND P & ID INDEX SEE DWG. M-001.
3. FOR INSTRUMENTATION SYMBOLS SEE DWG. M-002.
4. DELETED
5. UNLESS OTHERWISE NOTED, ALL VENT CONNECTIONS ARE ¾" AND DRAIN CONNECTIONS 1". LINE IDENT SAME AS HEADER.
6. FOR STOP VALVES AND GOVERNOR VALVES DRAINS SEE DWG. M-022.
7. THE ONLY VENT OR DRAIN LINE CAPS REQUIRED TO BE SHOWN ON PIPING AND INSTRUMENTATION DIAGRAMS ARE THOSE CONTROLLED UNDER DB-OP-00009 (FORMERLY AD1839.03). THE ACTUAL TERMINATION OF ALL OTHER VENTS OR DRAINS ARE NOT SHOWN AND INSTEAD, AN OPEN ENDED PIPE IS DISPLAYED.

H.P. TURBINE STOP VALVES (NOTE 6)

GOVERNOR VALVES (NOTE 6)

H.P. TURBINE 1-1

L.P. TURBINE 1-1

L.P. TURBINE 1-2

MOISTURE SEPARATOR REHEATER 1-1 T33-1

MOISTURE SEPARATOR REHEATER 1-2 T33-2

LR NOTES:
A. FOR GENERAL LICENSE RENEWAL NOTES REFER TO LR-M001-01

LICENSE RENEWAL BOUNDARY DRAWING
LR-M003B REV. 0

SYSTEMS SHOWN ON THIS DRAWING:
09: MAIN STEAM

BECHTEL ASSOCIATES PROFESSIONAL CORPORATION (OHIO)
GAITHERSBURG, MARYLAND

DAVIS-BESSE NUCLEAR POWER STATION UNIT NO.1
THE TOLEDO EDISON COMPANY

PIPING & INSTRUMENT DIAGRAM MAIN STEAM AND REHEAT SYSTEM SHEET 2

THIS DRAWING REV. 0 SUPERSEDES IN PART DWG. M-003 REV. 34. WORK THIS DWG. WITH M-003A & M-003C

JOB No.	DRAWING No.	REV.
12501	M-003B	23

DB 07-25-06

DFN= :/PIDS/M003B.DGN

01905