The Detroit Edison Company One Energy Plaza, Detroit, MI 48226-1279



10 CFR 51.45 10 CFR 52.77 10 CFR 52.79

September 1, 2010 NRC3-10-0040

U. S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, DC 20555-0001

- References: 1) Fermi 3
 - Docket No. 52-033
 - Letter from Stephen Lemont (USNRC) to Peter W. Smith (Detroit Edison), "Requests for Additional Information Related to the Environmental Review for the Combined License Application for Fermi Nuclear Power Plant, Unit 3," dated May 12, 2009
 - 3) Letter from Jerry Hale (USNRC) to Jack M. Davis (Detroit Edison), "Request for Additional Information Letter No. 9 Related to the SRP Sections Chapter 1, 05.03.02, 09.05.02.02, 13.01.01, 13.03, and 14.03.07 for the Fermi 3 Combined License Application," dated July 29, 2009
 - Letter from Peter W. Smith (Detroit Edison) to USNRC, "Detroit Edison Company Response to NRC Request for Additional Information Letter No. 9," NRC3-09-0025 dated September 24, 2009
 - Letter from Peter W. Smith (Detroit Edison) to USNRC, "Detroit Edison Company Response to NRC Requests for Additional Information Related to the Environmental Review," NRC3-09-0010 dated June 19, 2009
 - 6) Letter from Peter W. Smith (Detroit Edison) to USNRC, "Detroit Edison Company Response to NRC Requests for Additional Information Related to the Environmental Review," NRC3-09-0012 dated July 31, 2009
 - Letter from Peter W. Smith (Detroit Edison) to USNRC, "Detroit Edison Company Response to NRC Requests for Additional Information Related to the Environmental Review," NRC3-09-0013 dated August 25, 2009
 - 8) Letter from Peter W. Smith (Detroit Edison) to USNRC, "Detroit Edison Company Response to NRC Requests for Additional Information Related to the Environmental Review," NRC3-09-0014 dated September 30, 2009

A DTE Energy Company

USNRC NRC3-10-0040 Page 2

- 9) Letter from Peter W. Smith (Detroit Edison) to USNRC, "Detroit Edison Company Response to NRC Requests for Additional Information Related to the Environmental Review," NRC3-09-0015 dated October 30, 2009
- 10) Letter from Peter W. Smith (Detroit Edison) to USNRC, "Detroit Edison Company Response to NRC Requests for Additional Information Related to the Environmental Review," NRC3-09-0016 dated November 23, 2009
- 11) Letter from Peter W. Smith (Detroit Edison) to USNRC, "Detroit Edison Company Response to NRC Requests for Additional Information Related to the Environmental Review," NRC3-09-0017 dated December 23, 2009
- 12) Letter from Peter W. Smith (Detroit Edison) to USNRC, "Detroit Edison Company Response to NRC Requests for Additional Information Related to the Environmental Review," NRC3-10-0025 dated July 9, 2010
- Subject: Detroit Edison Company Response to NRC Requests for Additional Information Letter No. 9 and Requests for Additional Information Letter Related to the Environmental Review

In References 2 and 3, the NRC requested additional information to support the review of certain portions of the Fermi 3 Combined License Application (COLA). Since June 2009, Detroit Edison has submitted responses to all of the Requests for Additional Information (RAIs) identified in Reference 2 in a series of monthly letters (References 5 through 11). This letter is providing revised responses to five RAIs previously submitted in References 5 through 11. These responses are consistent with the schedule outlined in Appendix B of Reference 12. Additionally, Detroit Edison is providing a revised response to FSAR RAI 01-1, which was originally submitted in Reference 4.

Enclosed with this letter is a disk containing GASPAR input and output files requested by ER RAI HH5.4.2-1.

The file format and names on the enclosed disk do not comply with the requirements for electronic submission in NRC guidance document, "Guidance for Electronic Submissions to the NRC," dated May 17, 2010; the files are not ".pdf" formatted. The NRC staff requested the files be submitted in their native formats required by the software in which they are utilized to support the Environmental Report development.

If you have any questions, or need additional information, please contact me at (313) 235-3341.

USNRC NRC3-10-0040 Page 3

I state under penalty of perjury that the foregoing is true and correct. Executed on the 1st day of September 2010.

Sincerely,

Peter W. Smith, Director Nuclear Development – Licensing and Engineering Detroit Edison Company

Attachments:

- 1) Response to FSAR RAI Question 01-1 Response to ER RAI Question GE1.2-3
- 2) Response to ER RAI Question GE2-2
- 3) Response to ER RAI Question HH5.4.2-1 Response to ER RAI Question HH5.4.3-3
- 4) Response to ER RAI Question HH5.4.4-1

cc: Adrian Muniz, NRC Fermi 3 Project Manager Jerry Hale, NRC Fermi 3 Project Manager Bruce Olson, NRC Fermi 3 Environmental Project Manager Fermi 2 Resident Inspector (w/o attachments) NRC Region III Regional Administrator (w/o attachments) NRC Region II Regional Administrator (w/o attachments) Supervisor, Electric Operators, Michigan Public Service Commission (w/o attachments) Michigan Department of Natural Resources and Environment Radiological Protection Section (w/o attachments)

> Attachment 1 NRC3-10-0040

Response to FSAR RAI Letter No. 9 and RAI letter related to Fermi 3 ER

RAI Question 01-1 RAI Question GE1.2-3

NRC RAIs

The following RAIs concern the U.S. Department of Energy (DOE) Nuclear Waste Fund waste disposal contract. Detroit Edison has elected to address these RAIs with a single response.

FSAR RAI 01-1

Section 302(b)(1)(B) of the Nuclear Waste Policy Act of 1982, as amended, states "The Commission, as it deems necessary or appropriate, may require as a precondition to the issuance or renewal of a license under section 103 or 104 of the Atomic Energy Act of 1954 (42 U.S.C. 2133, 2134) that the applicant for such license shall have entered into an agreement with the Secretary for the disposal of high-level radioactive waste and spent nuclear fuel that may result from the use of such license."

Please identify the DOE contract number applicable to Fermi 3 for disposal of high-level radioactive waste and spent nuclear fuel or provide Detroit Edison's plans, including the time frame, for entering into such a contract.

ER RAI GE1.2-3

Provide documentation or a description of the status of the required Nuclear Waste Fund waste disposal contract with the U.S. Department of Energy (DOE).

Supporting Information

Per the Nuclear Waste Policy Act of 1982, as amended, before a combined license can be issued by the NRC for Fermi 3, Detroit Edison must provide either proof that such a contract is in place with DOE or an official document from DOE stating that Detroit Edison is making a good faith effort to get a contract.

Supplemental Response

Detroit Edison has completed all reviews of the "Contract for Disposal of Spent Nuclear Fuel and/or High-level Radioactive Waste" prescribed by the Nuclear Waste Policy Act of 1982 (Pub. L. 97-425, 42 U.S.C. 10101 *et seq.*) and the "Amendment to Contract (for Disposal of Spent Nuclear Fuel and/or High-level Radioactive Waste)." Both the Contract and the Amendment are awaiting signature and will then be sent to the U.S. Department of Energy. Detroit Edison will notify the NRC once the fully executed contract has been received from the U.S. Department of Energy.

> Attachment 2 NRC3-10-0040

Supplemental Response to RAI letter related to Fermi 3 ER

RAI Question GE2-2

NRC RAI GE2-2

Provide electronic versions of all Environmental Report Rev. 0, September 2008 (the "ER") figures in .jpeg, .png or .tif format at a resolution of at least 300 dpi.

Supporting Information

Electronic versions of the figures used in the ER at sufficiently high resolution would facilitate production of the EIS and prevent the need for redrafting figures.

Supplemental Response

Environmental Report Rev. 0 figures were provided in .tif format in Detroit Edison letter NRC3-09-0019 (ML092380595), dated July 29, 2009, in RAI GE2-2.

The NRC indicated in an email dated June 25, 2010 that 13 ER figures had poor image clarity, and were therefore unsuitable for use in the draft Environmental Impact Statement (EIS). The NRC is tracking these figure-clarity issues under RAI GE3.1-1 in their RAI status tracking document. Six additional ER figures were identified with image-clarity issues by the NRC during a conference call on August 23, 2010. To date, ten of the 19 image-clarity issues have been resolved and courtesy copies have been provided to the NRC. Detroit Edison will work with the NRC staff to resolve the remaining image clarity issues for inclusion in the draft EIS.

Additionally, on June 7, 2010, the NRC staff requested 43 figures in the ER be converted to black and white to support the issuance of the draft EIS. Detroit Edison notes that NUREG-1943, "Environmental Impact Statement for Combined Licenses (COLs) for Comanche Peak Nuclear Power Plant Units 3 and 4", dated August 2010, contains 45 color figures. Detroit Edison believes that the color figures presented in the ER are adequate for issuance of the draft EIS and will not pursue the conversion of color figures.

Proposed COLA Revision

None.

Attachment 3 NRC3-10-0040

Supplemental Response to RAI letter related to Fermi 3 ER

RAI Question HH5.4.2-1 RAI Question HH5.4.3-3

NRC RAIs

The following RAIs concern the GASPAR and MEI dose from gaseous effluent releases analyses. Detroit Edison has elected to address these RAIs with a single response.

RAI HH5.4.2-1

Provide input and output data (in electronic format) of the LADTAP and GASPAR computer codes.

Supporting Information

ESRP 5.4.2, Section III, states "Assess the computer outputs to ensure that data were entered properly and that the outputs appear normal."

The input and output files for LADTAP and GASPAR codes used in dose calculations will enable the staff to perform confirmatory analyses. Provide the basis for any factors other than defaults used as input to the computer codes.

RAI HH5.4.3-3

Provide updated calculations of dose from gaseous effluent releases for the MEI and population based on the new site layout.

Supporting Information

During the site audit it was mentioned that the site layout for Fermi 3 would change. This change may result in changes to the MEI and population doses from gaseous effluent releases. These revised estimates are needed for the analysis that will be presented in the EIS.

Supplemental Response

In the original response to ER RAI HH5.4.3-3 in Detroit Edison letter NRC3-09-0015 (ML093090165), dated October 30, 2009, the long-term, routine dispersion estimates (X/Qs) were based on ESBWR DCD Rev. 5. A supplemental response to ER RAI HH5.4.3-3 in Detroit Edison letter NRC3-10-0015 (ML100960474), dated March 30, 2010, provided the long-term, routine X/Qs for all possible release source locations determined by XOQDOQ utilizing the new-site layout described in FSAR Rev. 2, ER Rev. 1 and the joint frequency distributions provided in supplemental response to RAI 02.03.01-3 in Detroit Edison letter NRC3-10-0015.

As a result of changes to the source term in DCD Rev. 7 and utilizing previously communicated changes to the X/Qs presented in Detroit Edison Letter NRC3-10-0033 (ML102180224), dated

July 25, 2010, the gaseous effluent release calculations for the Maximum Exposed Individual (MEI), population, and biota were updated as described below.

The gaseous source term presented in DCD Rev. 7 Table 12.2-16 was increased to account for the pumped-forward design of the ESBWR feed water heaters. In a pumped-forward feed water heater configuration, a significant portion of the steam flow bypasses the condensate demineralizers, increasing the concentration of radionuclides in the reactor water and, when the methodology of NUREG-0016 is applied, increasing the concentration of radionuclides in the gaseous effluents. The full gaseous effluents predicted from DCD Rev. 7 Table 12.2-16 result in exposure that could exceed 15 mrem to the Fermi 3 MEI critical organ during a calendar year. Although based upon ANSI 18.1-1999, the gaseous effluent predicted by the NUREG-0016 methodology are overly conservative given the industries low tolerance for fuel failures and industry wide efforts to reduce radiation exposures as low as is reasonably achievable (ALARA) in operations.

Fermi 3 FSAR Section 11.5.4.5, "Offsite Dose Calculation Manual" incorporates by reference NEI 07-09A, Rev 0 which states in Section 6.3.4, "I-131, I-133, H-3 & Radionuclides in Particulate Form Effluent Dose Limit":

- a. Requirement
- 1. Methods shall be implemented to ensure that the dose to any organ of a member of the public from I¹³¹, I¹³³, tritium, and all radionuclides in particulate form with half-lives greater than 8 days, in gaseous effluents released from the site to unrestricted areas from each reactor unit shall be:
 - a. During any calendar quarter less than or equal to 7.5 mrem to the critical organ
 - b. During any calendar year less than or equal to 15 mrem to the critical organ
- 2. Cumulative dose contributions to a member of the public from I¹³¹, I¹³³, tritium, and radionuclides in particulate form with half-lives less greater than 8 days, in gaseous effluents released to unrestricted areas for the current calendar quarter and current calendar year shall be determined at least once per 31 days in accordance with Step 6.3.4.c ("Dose Calculations").

Consistent with Subsection 11.5.4.5, the ESBWR Safety Evaluation Report (SER) for Chapter 2 recognizes that "other parameters, such as release rates, can also be adjusted to demonstrate compliance with 10 CFR Part 50, Appendix I, dose criteria." (ML100491205, see page 2-38). In accordance with FSAR Section 11.5.4.5, the Fermi 3 ODCM, and the ESBWR SER, methods shall be implemented to ensure that the annual estimated dose to the MEI is less than 15 mrem to the critical organ or thyroid. Such methods could include, if needed, altering the feed water system valve lineup to secure pump forward feed water heaters to produce an increase in the amount of the steam flow passing through the condensate demineralizer. Such actions would only be necessary should the reactor water radioiodine concentrations approach the radioiodine concentrations assumed in the calculations.

Consistent with the Fermi 3 ODCM and the ESBWR SER, Detroit Edison will limit the Fermi 3 gaseous effluent release rates by limiting the radioiodine concentrations in the reactor water to the concentrations prescribed in FSAR Table 12.2-205 in the attached markup and repeated here:

T 4	Reactor Water	Concentration
Isotope	(MBq/gm)	(µCi/gm)
I-131	5.6 E -05	1.5 E -03
I-132	5.3 E -04	1.4 E -02
I-133	3.8 E -04	1.0 E -02
I-134	9.7 E -04	2.6 E -02
I-135	5.5 E -04	1.5 E -02

Source: DCD Rev. 5 Table 11.1-4b

These concentration limits would not present an operational issue, e.g. restricting pumped forward feed water heaters, and are representative of measured concentrations found in operating boiling water reactors, adjusting for power level, reactor water mass, and system flows, as described in DCD Section 11.1.3.

The corresponding radioiodine gaseous effluent estimates, consistent with NUREG-0016, are listed in FSAR Table 12.2-206 in the attached markup and repeated here:

Nuclide	Reactor Building	Turbine Building	Radwaste Building	Mechanical Vacuum Pump	Turbine Seal	Offgas System	Drywell
I-131	9.4E+02	5.2E+03	3.4E+02	1.8E+03	4.7E+01		3.4E+02
I-132	8.5E+03	4.6E+04	3.0E+03				4.9E+01
I-133	6.2E+03	3.4E+04	2.2E+03		8.4E+01		3.3E+02
I-134	1.5E+04	8.4E+04	5.5E+03				3.4E+01
I-135	8.6E+03	4.7E+04	3.1E+03				1.4E+02

Source: DCD Rev. 6 Table 12.2-16

The gaseous source term presented in DCD Rev. 7 Table 12.2-16 with the radioiodine concentrations in new FSAR Table 12.2-206 and the previously communicated changes to the atmospheric dispersion estimates presented in Detroit Edison Letter NRC3-10-0033 were utilized to provide updated estimates for the dose to the MEI, population, and biota.

All changes to the FSAR and ER which address the gaseous effluent releases, including MEI, population, and biota dose analyses are shown in the attached Fermi 3 COLA markups. The requested GASPAR input and output files, used for gaseous effluent release calculations, are also provided in Enclosure 1.

Proposed COLA Revision

Proposed revisions to FSAR Table 1.9-201, FSAR Chapter 11, and FSAR Chapter 12 are shown on the attached markup.

Proposed revisions to ER Sections 3.5, 5.4, and 7.2 are shown on the attached markup.

.

NRC3-10-0040 RAI Question HH5.4.2-1

Enclosure 1

GASPAR Input/Output Files (following 2 pages)

GASPAR Input/Output Files

Directory of D:\GASPAR Files

 08/17/2010
 08:14 AM
 <DIR>
 indiv DCDr7

 08/17/2010
 08:14 AM
 <DIR>
 population DcDr7

 0 File(s)
 0 bytes
 2 Dir(s)
 0 bytes free

Directory of D:\GASPAR Files\indiv DCDr7

08/17/2010 08:14 AM <DIR> 08/17/2010 08:14 AM <DIR> 61,704 Fermi COL 1st-08/17/2010 07:46 AM SourceSet Animals DCDr7 XOQr6 combo.gnp 08/17/2010 07:46 AM 61,702 Fermi COL 1st-SourceSet ResGarden DCDr7 X OOr6 combo.gnp 08/17/2010 07:46 AM 61,718 Fermi COL 1st-SourceSet SB DCDr7 XOOr6 combo.gnp 08/17/2010 07:46 AM Fermi COL 2nd-61,583 SourceSet Animals DCDr7 XOQr6 combo.gnp 08/17/2010 07:46 AM 61.585 Fermi COL 2nd-SourceSet ResGarden DCDr7 XOQr6 combo.gnp 08/17/2010 07:46 AM 61,598 Fermi COL 2nd-SourceSet SB DCDr7 XOQr6 combo.gnp 08/17/2010 07:46 AM 61,622 Fermi COL Indiv Noble DCDr7 XOQr6 combo.gnp 08/17/2010 07:46 AM 3,035 GAS INP Fermi 1stAnimals DCD7 XQ6 combo.DAT 08/17/2010 07:46 AM 3,034 GAS INP Fermi 1stRes DCD7 XQ6 combo.DAT 08/17/2010 07:46 AM 3,031 GAS INP Fermi 1stSB DCD7 XQ6 combo.DAT 08/17/2010 07:46 AM 2,198 GAS INP Fermi 2ndAnimals DCD7 XQ6 combo.DAT 08/17/2010 07:46 AM 2,200 GAS INP Fermi 2ndRes DCD7 XQ6 combo.DAT 08/17/2010 07:46 AM 2,196 GAS INP Fermi 2nd SB DCD7 XQ6 combo.DAT 08/17/2010 07:46 AM 2,308 GAS INP Fermi Noble DCD7 XQ6 combo.DAT 08/17/2010 07:46 AM 39.518 GAS OUT Fermi_1stAnimals DCD7 XQ6 combo.DAT 08/17/2010 07:46 AM 39.518 GAS OUT Fermi 1stRes DCDr7 XQ6 combo.DAT 08/17/2010 07:46 AM 39,518 GAS OUT Fermi 1stSB DCD7 XQ6 combo.DAT

08/17/2010 07:46 AM 38,298 GAS_OUT_Fermi_2ndAnimals_DCD7_XQ6_combo.DAT 08/17/2010 07:46 AM 38,298 GAS_OUT_Fermi_2ndRes_DCD7_XQ6_combo.DAT 08/17/2010 07:46 AM 38,298 GAS_OUT_Fermi_2ndSB_DCD7_XQ6_combo.DAT 08/17/2010 07:46 AM 17,782 GAS_OUT_Fermi_Noble_DCD7_XQ6_combo.DAT

 21 File(s)
 700,744 bytes

 2 Dir(s)
 0 bytes free

Directory of D:\GASPAR Files\population DcDr7

08/17/2010 08:14 AM <DIR> 08/17/2010 08:14 AM <DIR> •• Fermi ESBWR COL DCDR7 XOQr6 Popl.gnp 08/17/2010 07:47 AM 61,521 Fermi ESBWR COL DCDR7 XOQr6_Pop2.gnp 08/17/2010 07:47 AM 61,575 GAS INP Fermi DCD7 XQ6 combo pop1.DAT 08/17/2010 07:47 AM 3,930 GAS_INP_Fermi_DCD7_XQ6_combo_pop2.DAT 08/17/2010 07:47 AM 3,832 08/17/2010 07:47 AM 188,026 GAS OUT Fermi DCD7 XQ6 combo pop1.DAT 08/17/2010 07:47 AM 156,474 GAS OUT Fermi DCD7 XQ6 combo pop2.DAT 08/17/2010 07:47 AM 22,590 GAS XOQ Fermi DCD7 composite.dat

- 7 File(s) 497,948 bytes
- 2 Dir(s) 0 bytes free

)

Markup of Detroit Edison FSAR (following 32 pages)

The following markup represents how Detroit Edison intends to reflect this RAI response in the next submittal of the Fermi 3 FSAR Revision 3. However, the same COLA content may be impacted by revisions to the ESBWR DCD, responses to other COLA RAIs, other COLA changes, plant design changes, editorial or typographical corrections, etc. As a result, the final COLA content that appears in a future submittal may be different than presented here.

Table 1.9-201 Conformance with Standard Review Plan (Sheet 28 of 47)

[EF3 COL 1.9-3-A]

SRP Section	Title	Rev	Date	Specific Acceptance C	Criteria	Evaluation	
10.4.7	Condensate and Feedwater System (Continued)			11.8		Conforms. Addressed in DCD Sections 3.9.3, 5.2.4 and DCD Tables 1.9-22 ar	, and 10.4.7, nd 1.11-1.
⁻ 10.4.8	Steam Generator Blowdown System (PWR)	Rev. 3	Mar-07			Not applicable to the ESB	WR
10.4.9	Auxiliary Feedwater System (PWR)	Rev. 3	Mar-07			Not applicable to the ESB	WR
BTP 10-1	Design Guidelines for Auxiliary Feedwater System Pump Drive and Power Supply Diversity for Pressurized Water Reactor Plants	Rev. 3	Mar-07			Not applicable to the ESB	WR
BTP 10-2	Design Guidelines for Avoiding Water Hammers in Steam Generators	Rev. 4	Mar-07			Not applicable to the ESB	WR
11.1	Source Terms	Rev. 3	Mar-07	.1, .2, .3, .4, .6,	.7, 11.8, 11.9	Conforms, Addressed in DCD Section 12.2 and in I Section 12.2.	FSAR
				II.5		Conforms Addressed in S and 11.3	ection 11.2
11.2	Liquid Waste Management System	Rev. 3	Mar-07	.1, .2, .3, .4, .5		Conforms Addressed in D 11.2 and 12.2, and in Sec and 12.2.	CD Sections ion 11.2
				II.6		Not applicable. Applies to applications.	ESP
					For accept alternate c BWR GAL described	ance criteria II.9, an omputer code to the E code is used as in the DCD.	
Fermi 3 Combined Lice	nse Application			1-60			Revision 2 March 2010

.

• Labor Cost Correction Factor (LCCF) - Obtained from RG 1.110, Table A-4, this factor takes into account the relative labor cost differences among geographical regions. A factor of 1.5 is assumed in the analysis based on Fermi being located in Region II as shown on RG 1.110, Figure A-1.

A value of \$1,000 per person-rem is prescribed in 10 CFR 50, Appendix I.

There are three augments which fall below the \$1000 per person-rem threshold value; these are a 20 gpm cartridge filter, evaporator distillate demineralizer, and 10,000 gallon tank.

If it is conservatively assumed that each radwaste treatment system augment is a "perfect" technology that reduces the effluent dose by 100 percent, the annual cost of the augment can be determined and the lowest annual cost can be considered a threshold value. The lowest-cost option for augments is a 20 gpm cartridge filter at \$11,900 per year, which yields a threshold value of 11.9 person-rem whole body or thyroid dose from liquid effluents.

Neglecting the modeling of filters in the development of the source term, the addition of a 20 gpm cartridge filter would treat only 20 percent of the total analyzed liquid radwaste discharge of 105 gpm. Assuming 100 percent effectiveness, this would represent a dose reduction of 30.07 person-rem x 20 percent = 6.014 person-rem. The cost benefit ratio for this augment is therefore greater than the \$1000/person-rem and not a cost benefit augment.

The addition of an evaporator distillate demineralizer is dependent on the existence of an evaporator. Even though the cost of the option, \$16,400, is below the threshold value, this system cannot be incorporated without the use of an evaporator which would have a cost greater than the $\frac{1}{2}$ threshold. Based on the threshold of $\frac{21,080}{21,080}$ and the presence of the evaporator, it is determined that this augment is not cost-beneficial.

The cost to incorporate a 10,000 gallon tank is \$18,600. The purpose of such a tank is to provide additional holdup capacity to allow decay of short-lived radionuclides prior to discharge. The 10,000 gallon tank would be used for holdup, based on 105 gpm effluent discharge; holdup time would be 95 minutes. The list of nuclides in the effluent discharge can be found from the average annual liquid release in ESBWR DCD Table 12.2-19b. By examining the half-life of each nuclide, only three of the half-lives are less than the 95 minute holdup time Compared to overall



\$6700 and \$27,100

person-rem and/or \$1000 per person-thyroid-rem, should be implemented in order of diminishing cost-benefit. TAC of radwaste system augments considered herein is determined following Regulatory Guide 1.110, Appendix A, assuming that Fermi 2 and Fermi 3 will have separate radwaste systems and a seven percent per year cost of money. The maximum redustion of any augment is bounded by the total annual dose exposures. As shown in Table 12.2-204, the annual whole body dose from gaseous effluents is less than 4.5 person-rem/year whole body and 24.4 person-rem/year thyroid for the 80-km (50-mile) population. Therefore, for augments that have a TAC below the \$4509-and \$24,160 27.1 thresholds, the TAC is divided by the amount of the total annual dose that the augment is assumed to eliminate.

3-Ton Charcoal Absorber

6.7

4.4

27.1

190,000

The annual cost of the 3-ton charcoal absorber is \$9691/year; thus, potential reductions to thyroid dose are considered. Per DCD Table 11.3-1, the total mass of charcoal in the Offgas System (OGS) is 237,000 kg (523,000 lb), or approximately 237 metric tonnes (262 tons). Addition of a 3-ton charcoal absorber provides an additional 1.1 percent capacity to the existing OGS. Section 12.2 shows that the annual airborne releases from the OGS represent approximately 4 percent of the total annual airborne releases. Additional charcoal absorbers would improve the holdup times of the xenon and krypton isotopes, but those only contribute 4.4 percent to the thyroid dose. Therefore, additional charcoal absorber material could make a maximum improvement of of the percent of the 23.5 person-rem/year thyroid dose, or 0.64 person-rem/year. The \$9691/year cost of the 3-ton charcoal absorber augment divided by the annual dose reduction of 0.04 person-rem/year, results in an estimated cost of over \$240,000/person-rem saved. This augment exceeds the cost-benefit ratio of \$1000/person-rem and is eliminated from further consideration.

Charcoal Vault Refrigeration

Charcoal vault refrigeration would improve the performance of the OGS which uses activated charcoal absorber beds to minimize and control the release of radioactive material into the atmosphere by delaying release of the offgas process stream. The annual cost of the charcoal vault \$27,100 refrigeration system is \$29,655/year. This value exceeds \$24,408 for person-rem/year thyroid dose and \$4500 person-rem/year whole body

\$6700

11-5

Revision 2 March 2010 0.18

0.05

dose; therefore this augment exceeds the cost-benefit ratio of \$1000/person-rem and is eliminated from further consideration.

Main Condenser Vacuum Pump Charcoal/HEPA Filtration System

The annual cost of the main condenser vacuum pump charcoal/HEPA filtration system is \$8210/year; thus, potential reductions to thyroid dose are considered. The addition of a main condenser vacuum pump charcoal/HEPA filtration system would provide for a reduction in the amount of iodides discharged from the plant. DCD Table 12.2-16 shows the mechanical vacuum pump contributes approximately 0.7 percent of the total iodine releases. The maximum improvement to the off-site dose would be 0.7 percent of the 24.4 person-rem/year thyroid dose, or less than 0.20 person-rem/year. The \$8210/year cost of the main condenser vacuum pump HEPA filtration system augment divided by the annual dose reduction of 0.2 person-rem/year, results in an estimated cost of over \$41,000/person-rem saved. This augment exceeds the cost-benefit ratio of \$1000/person-rem and is eliminated from further consideration.

15,000-cfm HEPA Filtration System

ESBWR has four structures that contain potentially radioactive air: the Fuel Building, Radwaste Building, Reactor Building, and Turbine Building. Because the buildings all have flow rates that exceed the 15,000-cfm flow rate, multiple 15,000-cfm HEPA filters would be needed. The total annual cost for each 15,000-cfm HEPA filter is \$17,167 for those located in the Turbine Building, and \$27,952 for all other locations. The number of HEPA filters and the total annual cost for those filters is shown in Table 11.3-201.

\$6700

27.1

These values all exceed $\frac{223,400}{5,400}$ for person-rem/year thyroid dose and $\frac{4500}{5,4500}$ person-rem/year whole body dose; therefore this augment exceeds the cost-benefit ratio of \$1000/person-rem and is eliminated from further consideration.

Charcoal/HEPA Filtration Systems

Table A-1 of Regulatory Guide 1.110 lists several charcoal/HEPA filtration system sizes, 1000-cfm, 15,000-cfm, and 30,000-cfm. It is assumed that these are to be combined in the most economical manner to envelope the building flow rates. There are different direct costs for the 15,000-cfm and 30,000-cfm systems depending on their location.

ESBWR has four structures that contain potentially radioactive air: the Fuel Building, Radwaste Building, Reactor Building, and Turbine Building. The exhaust systems for these buildings and their flow rates are listed in Table 11.3-201.

Because the buildings all have flow rates that exceed the 30,000-cfm flow rate, combinations of 1000-cfm, 15,000-cfm, and 30,000-cfm charcoal/ HEPA filters are needed. The total annual cost for each 1000-cfm charcoal/HEPA filter is \$8231; each 15,000-cfm charcoal/HEPA filter is \$33,286 for those located in the Turbine Building, and \$34,792 for all other locations; and each 30,000-cfm charcoal/HEPA filter is \$54,958 for those located in the Turbine Building, and \$57,578 for all other locations. The number of HEPA filters and the total annual cost for those filters is shown in Table 11.3-202.

\$6700 —

\$27,100

These values all exceed \$2⁴,100 for person-rem/year thyroid dose and \$4500 person-rem/year whole body dose; therefore this augment exceeds the cost-benefit ratio of \$1000/person-rem and is eliminated from further consideration.

600-ft³ Gas Decay Tank

The gas decay tank would be used as an augment to the OGS. The gas decay tank would be utilized to allow noble gas decay before release through the exhaust. Based on the OGS flow rate of 54 m³/hr (31.8 cfm) (DCD Table 12.2-15), the average residence time in the decay tank is 18.9 minutes.

The total tank size would need to be sized for 4.48 hours (Kr-85m half-life) of hold-up to impact the half-lives of the Ar and Kr isotopes (with the exception of Kr-85). Fifteen 600 ft³ tanks would be required to provide a hold-up of 4.48 hours. Each 600 ft³ tank has a total annual cost of \$9036, and 15 tanks would cost over \$135,000. This value exceeds the $\frac{524,100}{24,100}$ threshold for person-rem/year thyroid dose, and the $\frac{$4509}{24,100}$ person-rem/year whole body dose; therefore this augment is not cost beneficial for dose reduction.

Conclusion

There are no gaseous radwaste system augments that are cost beneficial to implement for Fermi 3.

\$6700

	11.5 Process Radiation Monitoring System
	This section of the referenced DCD is incorporated by reference with the following departures and/or supplements.
· · ·	Add the following paragraph at the end of this section.
STD COL 11.5-3-A	Replace text references to DCD Table 11.5-5 with Table 11.5-201.
	11.5.4.4 Setpoints
	Replace the first sentence in this section with the following.
STD COL 11.5-2-A	The derivation of setpoints used for offsite dose monitors described in the ODCM. Refer to Subsection 11.5.4.5 for a discussion regarding ODCM development and implementation.
	11.5.4.5 Offsite Dose Calculation Manual
	Replace this section with the following.
STD COL 11.5-2-A lodine concentrations in the reactor water are maintained less than the values in Table 12.2-206 per the ODCM.	The methodology and parameters used for calculation of offsite dose and monitoring are described in the ODCM. NEI 07-09, Generic FSAR Template Guidance for Offsite Dose Calculation Manual (ODCM) Program Description, which is under review by the NRC, is incorporated by reference. (Reference 11.5-201) The milestone for development and implementation of the ODCM is addressed in Section 13.4. [START COM 11.5-001] The provisions for sampling liquid and gaseous waste streams identified in Table 11.5-201and DCD Table 11.5-6 will be included in the ODCM. [END COM 11.5-001]
	11.5.4.6 Process and Effluent Monitoring Program
	Replace this section with the following.
STD COL 11.5-3-A	The program for process and effluent monitoring and sampling is described in the ODCM. Refer to Subsection 11.5.4.5 for a discussion

regarding ODCM development and implementation.

Instrument calibrators are normally used for calibrating gamma dose rate instrumentation. These may be self-contained, heavily shielded, multiple source calibrators. Beta and alpha radiation sources are also available for instrument calibration. Calibration sources are traceable to the National Institute of Standards and Technology, or equivalent.

Radiography sources are surveyed upon entry to the site. Radiation protection personnel maintain copies of the most recent leak test records for owner-controlled sources. Contractor radiography personnel provide copies of the most recent leak test records upon radiation protection personnel request. Radiography is conducted in accordance with approved procedures.

12.2.2.1 Airborne Releases Offsite

Replace this section with the following.

EF3 COL 12.2-2-A	Airborne sources are calculated using the source terms Section 11.1.	given in
	The bases for these calculations are shown in Table 12.2-15R.	
. ·	The ESBWR standard design employs three ventilation stacks release points). Individual stacks service the ventilation flows Reactor/Fuel Buildings (RB/FB), the Turbine Building (TB Radwaste Building (RWB). The offsite airborne release analy ESBWR ventilation stack design employs separate-le atmospheric dispersion (X/Q) and deposition (D/Q) parameter each release location. Fermi site-specific values for these parar shown in Table 12.2-15R.	(airborne s from the) and the ysis of the ong term values for meters are Table 12.2-18bR
	The subject X/Q and D/Q values in Table 12.2-15R are us calculation of the gaseous effluent normal operation d Calculation of site-specific doses is discussed in Subsection 12	sed in the oses in 2.2.2.2.
Insert 1 Here	Table 12.2-15R contains values used in calculating the annual	airborne
	release source term>These source terms are provided in D 12.2-16. Design basis noble gas, iodine, and other fission -concentrations are takon from the tables in DCD Chapter 11 details and information on the derivation of the airborne source provided in DCD Appendix 12B.	r CD Table n product L Specific terms are

Insert 1 Section 12.2.2.1

The gaseous source term presented in DCD Table 12.2-16 accounts for the pumped forward design of the ESBWR feed water heaters. In a pumped-forward feed water heater configuration, a significant portion of the steam flow bypasses the condensate demineralizers, increasing the concentration of radionuclides in the reactor water and, when the methodology of NUREG-0016 is applied, increasing the concentration of radionuclides in the gaseous effluents. Gaseous effluents predicted from DCD Table 12.2-16 indicate that the resultant exposure could exceed 15 mrem to the Fermi 3 MEI critical organ during a calendar year. Based upon ANSI 18.1-1999, the gaseous effluent predicted by the NUREG-0016 methodology is overly conservative given the industry's low tolerance for fuel failures and industry wide efforts to reduce radiation exposures ALARA. Additionally, the NUREG-0016 calculated reactor water radioiodine concentrations, upon which the effluent release rates are based, are also overly conservative based upon the measured radioiodine concentrations seen at boiling water reactors, adjusting for power level, reactor water mass, and system flows consistent with DCD Section 11.1.3. In accordance with Subsection 11.5.4.5 and the Fermi 3 ODCM, methods, such as altering the feed water system valve lineup, if necessary, to secure pumped forward feed water heaters, are implemented to ensure that the estimated dose to the MEI is less than 15 mrem to the critical organ. Gaseous effluent release rates will be maintained by limiting the radioiodine concentrations in the reactor water to the annual limits prescribed in Table 12.2-205.

The radioiodine gaseous effluent estimates, consistent with NUREG-0016, are listed in Table 12.2-206. The gaseous source term presented in DCD Table 12.2-16 with the radioiodine concentrations in Table 12.2-206 were utilized to calculate estimates for the dose to the MEI and population. The source term for noble gas and other fission products are provided in DCD Table 12.2-16. Design basis noble gas and other fission product concentrations are taken from the tables in DCD Chapter 11. The source term for iodine is provided in Table 12.2-205. These concentration limits should not present an operational issue and are consistent with the measured concentrations found in operating boiling water reactors, adjusting for power level, reactor water mass, and system flows. Design basis iodine concentrations listed in Table 12.2-206.

Fermi 3 Combined License Application Part 2: Final Safety Analysis Report

Annual Releases

and Table 12.2-206

Based upon the above criteria, the normal operating source terms are given in DCD Table 12.2-16 and a comparison to 10 CFR 20 criteria is given in Table 12.2-17R. For-determining the maximum activity concentration at the site boundary, the site specific X/Q values from each vent stack are conservatively assumed to be 800 meters (0.5 mile) from the site boundary. This table also shows the maximum activity concentration for each nuclide at the site boundary from combined operation of Fermi 2 and Fermi 3, and the corresponding concentration limit from 10 CFR 20, Appendix B, Table 2, Column 1.

12.2.2.2 Airborne Dose Evaluation Offsite

Replace this section with the following.

EF3 COL 12.2-2-A

Table 12.2-18bR

ground exposure.

The NW direction provides the limiting dose for residents and consumption of vegetables.

The bases for the calculation of Fermi 3-specific airborne offsite doses are provided in Table 12.2-18aR. The annual gaseous pathway doses are provided in . The methodology in RG 1.109 was used in determining the annual airborne dose values. The bases include values that are default parameters in RG 1.109 and other values that are Fermi 3 site-specific inputs. As part of the analysis, several sensitivities were performed to account for potentially limiting combinations of atmospheric dispersion, deposition and ingestion pathways. The SSE direction provides the limiting plume dose. The WNW direction at the site boundary provides the limiting dose for non-milk iodine and particulate sources. This is conservative relative to the doses at the actualresidences, vegetable-gardens-and-meat-sews. The WNW direction atthe actual locations provides the dose contribution due to milk consumption. In this case the cow-and-goat-milk-are-both included for conservation The total dose is the sum of these individual pathways. The results of the Fermi 3 gaseous pathway dose analysis are given in,



NNW

applicable

12.2.2.2.1 Compliance with 10 CFR 50, Appendix I, Sections II.B and II.C

Table 12.2-201 demonstrates that offsite doses due to Fermi 3 radioactive airborne effluents comply with the regulatory dose limits in 10 CFR 50, Appendix I, Sections II.B and II.C.

12.2.2.2.2 Compliance with 10 CFR 50, Appendix I, Section II.D

Population dose is determined for the gaseous effluent releases from
 6.7 Fermi 3 for both whole body dose and thyroid dose. The whole body dose is person-rem/yr as shown in Table 12.2-204. The thyroid dose is 24.4 person-rem/yr. The cost-benefit analysis performed to consider gaseous radwaste augments to reduce doses due to gaseous effluents is presented in Section 11.3. Based on the results from the cost-benefit analyses, no augments are cost-beneficial. Therefore, Fermi 3 complies with 10 CFR 50, Appendix I, Section II.D.

12.2.2.2.3 Compliance with 10 CFR 20 Appendix B, Table 2, Column 1

Table 12.2-17R provides the gaseous effluent concentrations in comparison to the 10 CFR 20, Appendix B, Table 2, Column 1 limits. The Fermi 3 gaseous effluent concentrations comply with 10 CFR 20, Appendix B, Table 2, Column 1.

12.2.2.2.4 Compliance with 10 CFR 20.1301 and 20.1302

Compliance with 10 CFR 20.1301 and 20.1302 is demonstrated in Subsection 12.2.2.4.4 and 12.2.2.4.5, respectively.

12.2.2.4 Liquid Doses Offsite

Replace this section with the following.

EF3 COL 12.2-3-A The ESBWR LWMS is designed with the capability to recycle 100 percent of the liquid radwaste (zero liquid release). The analysis of dose via liquid effluents is presented in order to provide a conservative representation of unit operation. Detroit Edison intends to operate Fermi 3 with zero liquid effluents.

Liquid pathway doses were calculated based on the criteria specified in DCD Section 12.2.2.3 for compliance with 10 CFR 50, Appendix I. Dose conversion factors and methodologies consistent with RGs 1.109 and

Using the Fermi 3-specific gaseous effluent release activities identified in Table 12.2-17R and the liquid effluent release activities identified in Table 12.2-19bR, the total annual doses to the MEI and the population resulting from Fermi 3 liquid and gaseous effluents are calculated and presented in Table 12.2-203 and Table 12.2-204, respectively.

The direct radiation contribution from operation of Fermi 3 is negligible. The direct dose contribution from Fermi 3 at two distances is provided in DCD Table 12.2-21. The annual dose of 5.93E-04 mrem/yr at 800 m (0.5 mi) is negligible. The distance to the site boundary from Fermi 3 is at least 890 m (0.56 mi) and the increase in distance further reduces the low dose rate.

The total annual doses to the MEI and the population resulting from Fermi 2 liquid and gaseous effluents are provided in Table 12.2-203 and Table 12.2-204, respectively. The values shown are representative based on review of Fermi 2 annual radiological environmental reports (Reference 12.2-201).

The direct radiation contribution from operation of Fermi 2 is negligible. An evaluation of operating plants by the NRC states that:

"...because the primary coolant of an LWR is contained in a heavily shielded area, dose rates in the vicinity of light water reactors are generally undetectable and are less than 1 mrem/year at the site boundary."

The NRC concludes that the direct radiation from normal operation results in "small contributions at site boundaries" (Reference 12.2-202, Section 4.6.1.2).

Table 12.2-203 shows that the total Fermi site doses resulting from the normal operation of Fermi 2 and Fermi 3 are well within the regulatory limits of 40 CFR 190.

Table 12.2-204 shows the whole body doses from liquid and gaseous effluents doses attributable to Fermi 3 for the population within 80 km (50 mi) from the Fermi site.

12.2.2.4.5 **Compliance with 10 CFR 20.1302**

Surveys of radiation levels in unrestricted and controlled areas and radioactive materials in effluents released to unrestricted and controlled areas are conducted to demonstrate compliance with the dose limits given in 10 CFR 20.1302 for individual members of the public.

Table 12.2-15R Air	borne Sources Calculation	[EF3 COL 12.2-2-A]	
	Calculation Bases	and Tables 2.3-X	XX
	Methodology	DCD Appendix 12B	
	Noble Gas Source at t=30 min	740 MBq/sec (20,000 µCi/sec)	
	I-131 Release Rate	3.7 MBq/sec (100 µCi/sec)	
EF3 COL 12.2-2-A	Meteorology Boundary>	Table 2.3-305 and Table 2.3-306	
		(Residences, Vegetable Gardens-and-Meat-	
		Cows-conservatively-assumed to be- located-at-site-boundary)-	
EF3 COL 12.2-2-A	Meteorology X/Qs>		
	RWB Ventilation Stack	Table 2.3-328 through Table 2.3-330	
	RB/FB Ventilation Stack	Table 2.3-332 through Table 2.3-334	
	TB Ventilation Stack	Table 2.3-336 through Table 2.3-338	
EF3 COL 12.2-2-A	Meteorology D/Qs		
	RWB Ventilation Stack	Table 2.3-331 and Table 2.3-XXX	
	RB/FB Ventilation Stack	Table 2.3-335 and Table 2.3-XXX	
	TB Ventilation Stack	Table 2.3-339 and Table 2.3-XXX	
	Plant Availability Factor	0.92	
	Offgas System:	· · ·	
	Offgas stream temperature	100°F	
	Flow rate	54 m ³ /hr	
	K _d (Kr)	18.5 cm ³ /g	
	K _d (Xe)	330 cm ³ /g	
	K _d (Ar)	6.4 cm ³ /g	
	Guard tank charcoal mass	7,500 kg (single tank)	
	Adsorber tank charcoal mass	27,750 kg (each)	
	Adsorber tank arrangement	2 parallel trains of 4 tanks each	
	Turbine Gland Sealing System Ex	haust:	
	I-131 release	0.81 Ci/yr per µCi/g of I-131 in coolart	
٦	I-133 release	0.22 Ci/yr per μCi/g of I-133 in coolant	
	· · · · · · · · · · · · · · · · · · ·		
(1) Ir value both used value	n Section 2.3.5, long-term rout es are determined based on m 1985-1989 and 2002-2007. T in the airborne sources calcu es from both time periods.	tine release X/Q and D/Q eteorological data from he X/Q and D/Q values llation are the greatest	
		and Table 2.3-XXX through 2	.3-XXX
		and Table 2.3-XXX through 2	.3-XXX
		and Table 2.3-XXX through 2	.3-XXX

-

`

Nuchde Kr-83m Kr-85m Kr-85 Kr-87 Kr-88	MBq/yr 8.5E+01 6.65+05 5.2E+06 1.4E+06 2.1E+06	Ci/yr 2.3E-03 1.8E+01 1.4E+02 3:9E+01	Bq/m ³ 1.7E-06 1.4E-02 1.1E-01	μ Ci/ml 4.6E-17 3.9E-13 3.1E-12	μ Ci/ml 3.6E-12 1.4E-10	μ Ci/ml 5.0E-05	1.2E-08
Kr-83m Kr-85m Kr-85 Kr-87 Kr-88	8.5E+01 6.65+05 5.2E+06 1.4E+06 2.1E+06	2.3E-03 1.8E+01 1.4E+02 3:9E+01	1.7E-06 1.4E-02 1.1E-01	4.6E-17 3.9E-13 3.1E-12	3.6E-12 1.4E-10	5.0E-05	1.2E-08
Kr-85m Kr-85 Kr-87 Kr-88	6.65+05 5.2E+06 1.4E+06 2.1E+06	1.8E+01 1.4E+02 3.9E+01	1.4E-02 1.1E-01	3.9E-13 3.1E-12	1.4E-10		//
Kr-85 Kr-87 Kr-88	5.2E+06 1.4E+06 2.1E+06	1.4E+02 3.9E+01	1.1E-01	3.1E-12		1.0E-07	1.4E-03
Kr-87 Kr-88	1.4E+06 2.1E+06	3.9E+01			2.2E-11	7.05-07	3.2E-05
Kr-88	2.1E+06		3.2E-02	8.6E-13	3.2E-12	2.0E-08	1.6E-04
		5.6E+0	4.6E-02	1.2E-12	5.4E-11	9.0E-09	6.0E-03
Kr-89	1.4E+07	3.7E+02	7.0E-01	1.9E-11	9.8E-11	1.0E-09	9.8E-02
 Xe-131m	1.5E+05	4.1E+00	3.3E-03	8.95-14	5.8E-12	2.0E-06	2.9E-06
 Xe-133m	1.9E+02	5.2E-03	3.8E	Table 12.2-17	R 2.4E-12	6.0E-07	4.0E-06
Xe-133	4.1E+07	1.1E+03	4.0E+0	1.1E-10	1.1E-09	5.0E-07	2.1E-03
Xe-135m	2.2E+07	6.0E+02	7.8E+00	2.1E-10	21E-10	4.0E-08	5.3E-03
Xe-135	2.8E+07	7.5E+02	4.5E+00	1.2E-10	1.4E-10	7.0E-08	2.1E-03
Xe-137	2.8E+07	7,8E+02	1.8E+00	4.8E-11	7.1E-11	1.0E-09	7.1E-02
Xe-138	2.3E+07	6.3E+02	5.4E-01	1.5E-11	1.1E-10	2.05-08	5.7E-03
I-131	8.7E+03	2.3E-01	4.0E-04	1.1E-14	2.2E-14	2.0E-10	1.1E-04
	5.8E+04	1.6E+00	3.1E-03	8.3E-14	1.8E-13	2.0E-08	9.2E-86
 I-1⁄63	4.3E+04	1.2E+00	2.3E-03	6.1E-14	1.4E-13	1.0E-09	1.4E-04

Table 12.2-17R Comparison of Airborne Release Concentrations with 10 CFR 20 Limit (Sheet 1 of 5) [EF3 12.2	COL
--	-----

Fermi 3 Combined License Application Revision 2 March 2010

Table 12.2-17R	Comparison of Airborne Release Concentrations with 10 CFR 20 Limit (Sheet 2 of 5)	[EF3 COL
		12.2-2.A]

	Fer	mi 3 Release	Fer	mi 3	Fermi 2 + 3	10 CFR 20 Concentration	Fermi 2 + 3 Fraction of 10 CFR 20
					Concentration		
Ruclide	MBq/yr	Ci/yr	Bq/m°	µCi/ml	µCi/mi	µCi/ml	
I-134	1.1E+05	3.0E+00	5.6E-03	1.5E-13	3.4E-13	6.0E-08	5.7E-06
I-135	6.9E+04	1.6E+00	3.2E-03	8.6E-14	2.0E-13	6.0E-09	3.3E-05
H-3	2.8E+06	7.6E+01	5.5E-02	1.5E-12	1.6E-12	1.0E-07	1.6E-05
					/	<i>r</i>	
C-14	5.3E+05	1.4E+01	1.2E-02	3.2E-13	3.22-13	3.0E-09	1.1E-04
Na-24	5.4E+00	1.5E-04	1.1€-07	2.9E-18	2.9E-18	7.0E-09	4.1E-10
P-32	1.3E+00	3.5E-05	2.6E-08	7.0E-19	7.0E-19	5.0E-10	1.4E-09
Ar-41	1.4E+03	3.8E-02	3.1E-05	0:3E-16	8.3E-16	1.0E-08	8.3E-08
Cr-51	1.8E+02	4.7E-03	1.4E-05	3.8E-10	3.8E-16	3.0E-08	1.3E-08
Mn-54	1.5E+02	4.1E-03	6.2E-05	1.7E-15	1.7E-15	1.0E-09	1.7E-06
Mn-56	1.1E+01	3.0E-04	2.2E-07	5.9E-18	5.9E-48	2.0E-08	2.9E-10
Fe-55	4.7E+01	1.2 € -03	9.3E-07	2.5E-17	2.5E-17	3.0E-09	8.4E-09
Fe-59	2.0E+01	5.4E-04	4.8E-06	1.3E-16	1.3E-16	5:9E-10	2.6E-07
Co-58	4.0 F =01	1.1E-03	3.8E-06	1.0E-16	1.0E-16	1.0E-09	1.0E-07
Co-60	3.2E+02	8.7E-03	1.1E-04	3.0E-15	3.0E-15	5.0E-11	6.0E-05
Ni-63	4.7E+02	1.3E-06	9.3E-10	2.5E-20	2.5E-20	1.0E-09	2.55 11
Cy=64	6.9E+00	1.9E-04	1.4E-07	3.7E-18	3.7E-18	3.0E-08	1.2E-10
/							

Fermi 3 Combined License Application

١

Revision 2 March 2010

_

Table 12.2-17R	Comparison of Airborne Release Concentrations with 10 CFR 20 Limit (Sheet 3 of 5)	[EF3 COL
		12.2-2.A]

	Fern Annual F	ni 3 Release	Fer Conce	mi 3 ntration	Fermi 2 + 3 Concentration	10 CFR 20 Concentration Limit	Fraction of 10 CFR 20 Limit
Huclide	MBq/yr	Ci/yr	Bq/m ³	µCi/ml	µCi/ml	µCi/ml	
Zn-65	3.2E+02	8.6E-03	1.1E-05	3.0E-16	3.0E-16	4.0E-10	7 Æ-07
Rb-89	2.0E-01	5.4E-06	4.0E-09	1.1E-19	1.1E-19	2.0E-07	5.4E-13
Sr-89	1.5E+62	3.9E-03	3.2E-06	8.6E-17	7.4E-16	2.0E-20	3.7E-06
Sr-90	1.0E+00	2.7E-05	2.2E-08	5.9E-19	5.0E-17	6.0E-12	8.3E-06
Y-90	8.1E-02	2.2E-96	1.6E-09	4.3E-20	4.3E-20	9.0E-10	4.8E-11
Sr-91	6.7E+00	1.8E-04	1.3E-07	3.6E-18	1,4€-14	5.0E-09	2.8E-06
Sr-92	4.6E+00	1.2E-04	9.1E-08	2.5E-18	2.2E-14	9.0E-09	2.4E-06
Y-91	1.7E+00	4.6E-05	3.4E-08	9.1E 19	9.1E-19	2.0E-10	4.6E-09
Y-92	3.7E+00	1.0E-04	7.3E-08	2.05-18	2.0E-18	1.0E-08	2.0E-10
Y-93	7.2E+00	1.9E-04	1.4E-07	3.9E-18	3.9E-18	3.0E-09	1.3E-09
Zr-95	4.4E+01	1.2E-03	1.3E-05	3.4E-16	3:5E-16	4.0E-10	8.7E-07
Nb-95	2.4E+02	6.5E-02	4.8E-06	1.3E-16	1.3E-16	2.0E-09	6.5E-08
Mo-99	1.7E+03	1.5E-02	3.3E-05	9.0E-16	5.5E-15	2.0E-09	2.8E-06
Tc-99m	2.2E+00	5.9E-05	4.4E-08	1.2E-18	5.7E-14	2.0E-07	2.9E-07
Ru-103	1.0E+02	2.8E-03	2.0E-06	5.5E-17	5.9E-17	9.0E-10	6.5E-08
Rh-103m	3.5E-03	9.5E-08	6.9E-11	1.9E-21	1.9E-21	2.0E-06	9.4E-16
Ru-106	1.4E-01	3.8E-06	2.8E-09	7.5E-20	7.5E-20	2.0E-11	3.8E-09

Fermi 3 Combined License Application

.

Table 12.2-17R	Comparison of Airborne Release Concentrations with 10 CFR 20 Limit (Sheet 4 of 5)	[EF3 COL
		12.2-2.A]

	Ferr	mi 3	Fern	ni 3	Fermi 2 + 3	10 CFR 20 Concentration	Fermi 2 + 3 Fraction of 10 CFR 20
	Annual	Release	Concen	tration	Concentration	Limit	Limit
Nuclide	MBq/yr	Ci/yr	Bq/m ³	µCi/ml	µCi/ml	µCi/ml	
Rh-106	4.5E-06	1.2E-10	8.9E-14	2.4E-24	2.4E-24	1.0E-09	2.4E-15
Ag-110m	1.0E-01	2.8E-06	2.0E-09	5.5E-20	5.5E-20	1.0E-10	5.5E-10
Sb-124	5.3E+00	1.4E-04	1.2E-06	3.1E-17	3.1E-17	3.0E-10	1.0E-07
Te-129m	1.6E+00	4.9E-05	3.2E-08	8.6E-19	8.6E-19	3.0E-10	2.9E-09
Te-131m	5.5E-01	1.5E-05	1.1E-08	2.9E-19	2.5E-19	1.0E-09	2.9E-10
Te-132	1.4E-01	3.8E-06	2.8E-09	7.5E-29	1.0E-15	9.0E-10	1.1E-06
Cs-134	1.8E+02	4.9E-03	3.8E-05	E-15	1.1E-15	2.0E-10	5.4E-06
Cs-136	1.5E+01	4.0E-04	3.0E-07	8.2E-18	3.1E-17	9.0E-10	3.5E-08
Cs-137	2.7E+02	7.3E-03	64E-05	1.7E-15	1.8E-15	2.0E-10	8.9E-06
Cs-138	8.5E-01	2.3E-05	1.7E-08	4.6E-19	3.1E-14	8.0E-08	3.9E-07
Ba-140	7.8E+02	2.12-02	1.6E-05	4.4E-16	2.3E-15	2.0E-09	1.2E-06
La-140	1.3E+01	3.5E-04	2.6E-07	7.0E-18	7.0E-18	2-0E-09	3.5E-09
Ce-141	2.6E+02	7.1E-03	5.8E-06	1.6E-16	1.7E-16	8.0E-10	2.1E-07
Ce-144	1.3E-01	3.5E-06	2.6E-09	7.0E-20	7.3E-18	2.0E-11	3.6E-07
Pr-144	1.6E-04	4.3E-09	3.2E-12	8.6E-23	8.6E-23	2.0E-07	4.35-16
W-187	1.3E+00	3.5E-05	2.6E-08	7.0E-19	7.0E-19	1.0E-08	7.0E-11

 Table 12.2-17R
 Comparison of Airborne Release Concentrations with 10 CFR 20 Limit (Sheet 5 of 5)
 [EF3 COL 12.2-2.A]

	Ferm Annual R	i 3 elease	Fer Concer	mi 3 ntration	Fermi 2 + 3 Concentration	10 CFR 20 Concentration Limit	Fermi 2 + 3 Fraction of 10 CFR 20 Limit
Nuclide	MBqtyr	Ci/yr	Bq/m ³	µCi/ml	µCi/ml	µCi/ml	
Np-239	8.3E+01	2.2E-03	1.6E-06	4.5E-17	4.9E-14	3.0E-09	1.6E-05
Total (w/ H-3)	1.7E+08	4.6E+03	2.0E+01	5:3E-10	1.9E-09		1.9E-01
Total (w/o H-3)	1.7E+08	4.5E+03	2.0E+01	5.3E-10	1.9E-09		1.9E-01

.

Insert Table 12.2-17R

						10 CFR 20	Fermi 2 + 3
	Fermi 3 Ann	ual Release	Fermi 3 Co	oncentration	Fermi 2+3	Concentration	Fraction of 10
Nuclide	(MBq/yr)	(Ci/yr)	(Bq/m ³)	(µCi/mL)	(µCi/mL)	Limit (µCi/mL)	CFR 20 Limit
Kr-83m	8.5E+01	2.3E-03	2.3E-06	6.3E-17	3.6E-12	5.00E-05	7.2E-08
Kr-85m	6.6E+05	1.8E+01	2.0E-02	5.3E-13	1.4E-10	1.00E-07	1.4E-03
Kr-85	5.2E+06	1.4E+02	1.6E-01	4.3E-12	2.3E-11	7.00E-07	3.3E-05
Kr-87	1.4E+06	3.9E+01	4.4E-02	1.2E-12	3.5E-12	2.00E-08	1.7E-04
Kr-88	2.1E+06	5.7E+01	6.3E-02	1.7E-12	5.5E-11	9.00E-09	6.1E-03
Kr-89	1.4E+07	3.7E+02	6.2E-01	1.7E-11	9.6E-11	1.00E-09	9.6E-02
Xe-131m	1.5E+05	4.1E+00	4.6E-03	1.2E-13	5.8E-12	2.00E-06	2.9E-06
Xe-133m	1.9E+02	5.2E-03	5.3E-06	1.4E-16	2.4E-12	6.00E-07	4.0E-06
Xe-133	4.1E+07	1.1E+03	2.8E+00	7.6E-11	1.0E-09	5.00E-07	2.1E-03
Xe-135m	2.2E+07	6.1E+02	4.5E+00	1.2E-10	1.2E-10	4.00E-08	3.0E-03
Xe-135	2.8E+07	7.5E+02	2.8E+00	7.7E-11	1.0E-10	7.00E-08	1.4E-03
Xe-137	2.8E+07	7.8E+02	1.5E+00	4.0E-11	6.3E-11	1.00E-09	6.3E-02
Xe-138	2.3E+07	6.3E+02	7.2E-01	1.9E-11	1.2E-10	2.00E-08	5.9E-03
I-131	8.7E+03	2.3E-01	3.7E-04	1.0E-14	2.1E-14	2.00E-10	1.0E-04
I-132	5.8E+04	1.6E+00	2.7E-03	7.3E-14	1.7E-13	2.00E-08	8.6E-06
I-133	4.3E+04	1.2E+00	2.0E-03	5.4E-14	1.3E-13	1.00E-09	1.3E-04
I-134	1.1E+05	2.8E+00	4.9E-03	1.3E-13	3.2E-13	6.00E-08	5.4E-06
I-135	5.9E+04	1.6E+00	2.8E-03	7.4E-14	1.8E-13	6.00E-09	3.1E-05
H-3	2.8E+06	7.2E+01	7.7E-02	2.1E-12	2.2E-12	1.00E-07	2.2E-05
C-14	5.3E+05	1.4E+01	1.6E-02	4.4E-13	4.4E-13	3.00E-09	1.5E-04
Na-24	5.9E+00	1.6E-04	1.6E-07	4.4E-18	4.4E-18	7.00E-09	6.3E-10
P-32	1.5E+00	4.1E-05	4.1E-08	1.1E-18	1.1E-18	5.00E-10	2.2E-09

	Fermi 3 Ann	ual Release	Fermi 3 Co	oncentration	Earmi 2+2	10 CFR 20	Fermi 2 + 3 Fraction of 10
Nuclide	(MBa/vr)	(Ci/vr)	(Ba/m^3)	(uCi/mL)	(uCi/mL)	Limit (uCi/mL)	CFR 20 Limit
Ar-41	1.4E+03	3.8E-02	4.3E-05	1.2E-15	1.2E-15	1.00E-08	1.2E-07
Cr-51	2.7E+02	7.2E-03	1.9E-05	5.0E-16	5.0E-16	3.00E-08	1.7E-08
Mn-54	3.0E+02	8.2E-03	7.3E-05	2.0E-15	2.0E-15	1.00E-09	2.0E-06
Mn-56	1.2E+01	3.2E-04	3.3E-07	8.9E-18	8.9E-18	2.00E-08	4.5E-10
Fe-55	5.1E+01	1.4E-03	1.4E-06	3.8E-17	3.8E-17	3.00E-09	1.3E-08
Fe-59	4.1E+01	1.1E-03	6.0E-06	1.6E-16	1.6E-16	5.00E-10	3.2E-07
Co-58	8.0E+01	2.2E-03	5.6E-06	1.5E-16	1.5E-16	1.00E-09	1.5E-07
Co-60	6.6E+02	1.8E-02	1.3E-04	3.5E-15	3.5E-15	5.00E-11	7.1E-05
Ni-63	5.2E-02	1.4E-06	1.4E-09	3.9E-20	3.9E-20	1.00E-09	3.9E-11
Cu-64	7.5E+00	2.0E-04	2.1E-07	5.6E-18	5.6E-18	3.00E-08	1.9E-10
Zn-65	6.2E+02	1.7E-02	2.3E-05	6.1E-16	6.1E-16	4.00E-10	1.5E-06
Rb-89	2.0E-01	5.4E-06	5.5E-09	1.5E-19	1.5E-19	2.00E-07	7.5E-13
Sr-89	3.1E+02	8.3E-03	9.3E-06	2.5E-16	9.0E-16	2.00E-10	4.5E-06
Sr-90	1.9E+00	5.0E-05	5.4E-08	1.5E-18	5.0E-17	6.00E-12	8.4E-06
Y-90	8.9E-02	2.4E-06	2.5E-09	6.6E-20	6.6E-20	9.00E-10	7.4E-11
Sr-91	7.5E+00	2.0E-04	2.1E-07	5.6E-18	1.4E-14	5.00E-09	2.8E-06
Sr-92	4.9E+00	1.3E-04	1.4E-07	3.7E-18	2.2E-14	9.00E-09	2.4E-06
Y-91	1.9E+00	5.1E-05	5.2E-08	1.4E-18	1.4E-18	2.00E-10	7.1E-09
Y-92	3.8E+00	1.0E-04	1.0E-07	2.8E-18	2.8E-18	1.00E-08	2.8E-10
Y-93	8.1E+00	2.2E-04	2.2E-07	6.0E-18	6.0E-18	3.00E-09	2.0E-09
Zr-95	9.2E+01	2.5E-03	1.5E-05	4.2E-16	4.2E-16	4.00E-10	1.1E-06
Nb-95	5.0E+02	1.4E-02	1.4E-05	3.8E-16	3.8E-16	2.00E-09	1.9E-07
Mo-99	3.4E+03	9.3E-02	9.5E-05	2.6E-15	7.2E-15	2.00E-09	3.6E-06
Tc-99m	2.4E+00	6.5E-05	6.6E-08	1.8E-18	5.7E-14	2.00E-07	2.9E-07
Ru-103	2.1E+02	5.8E-03	5.9E-06	1.6E-16	1.6E-16	9.00E-10	1.8E-07
Rh-103m	3.8E-03	1.0E-07	1.0E-10	2.8E-21	2.8E-21	2.00E-06	1.4E-15
Ru-106	1.6E-01	4.3E-06	4.4E-09	1.2E-19	1.2E-19	2.00E-11	6.0E-09
Rh-106	5.2E-06	1.4E-10	1.4E-13	3.9E-24	3.9E-24	1.00E-09	3.9E-15
Ag-110m	1.7E-01	4.6E-06	4.7E-09	1.3E-19	1.3E-19	1.00E-10	1.3E-09

-

	Fermi 3 Anni	ual Release	Fermi 3 Co	oncentration	Formi 2+3	10 CFR 20 Concentration	Fermi 2 + 3 Fraction of 10
Nuclide	(MBq/yr)	(Ci/yr)	(Bq/m ³)	(µCi/mL)	(µCi/mL)	Limit (µCi/mL)	CFR 20 Limit
Sb-124	1.1E+01	3.0E-04	1.4E-06	3.9E-17	3.9E-17	3.00E-10	1.3E-07
Te-129m	1.8E+00	4.9E-05	5.0E-08	1.3E-18	1.3E-18	3.00E-10	4.5E-09
Te-131m	6.0E-01	1.6E-05	1.7E-08	4.5E-19	4.5E-19	1.00E-09	4.5E-10
Te-132	1.5E-01	4.1E-06	4.1E-09	1.1E-19	1.0E-15	9.00E-10	1.1E-06
Cs-134	3.7E+02	1.0E-02	4.9E-05	1.3E-15	1.4E-15	2.00E-10	6.8E-06
Cs-136	3.1E+01	8.3E-04	8.6E-07	2.3E-17	4.6E-17	9.00E-10	5.1E-08
Cs-137	5.5E+02	1.5E-02	8.0E-05	2.2E-15	2.2E-15	2.00E-10	1.1E-05
Cs-138	8.5E-01	2.3E-05	2.3E-08	6.3E-19	3.1E-14	8.00E-08	3.9E-07
Ba-140	1.6E+03	4.4E-02	4.6E-05	1.2E-15	3.1E-15	2.00E-09	1.6E-06
La-140	1.4E+01	3.8E-04	3.9E-07	1.0E-17	1.0E-17	2.00E-09	5.2E-09
Ce-141	5.5E+02	1.5E-02	1.7E-05	4.5E-16	4.6E-16	8.00E-10	5.7E-07
Ce-144	1.6E-01	4.3E-06	4.4E-09	1.2E-19	7.3E-18	2.00E-11	3.7E-07
Pr-144	1.8E-04	4.9E-09	5.0E-12	1.3E-22	1.3E-22	2.00E-07	6.7E-16
W-187	1.4E+00	3.8E-05	3.9E-08	1.0E-18	1.0E-18	1.00E-08	1.0E-10
Np-239	9.0E+01	2.4E-03	2.5E-06	6.7E-17	4.9E-14	3.00E-09	1.6E-05
Total (w/ H-3)	1.7E+08	4.6E+03	1.3E+01	3.6E-10	1.8E-09		1.8E-01
Total (w/o H-3)	1.7E+08	4.5E+03	1.3E+01	3.6E-10	1.8E-09		1.8E-01

Table 12.2-18aR	Offsite Dose Calculation Bases	[EF3 COL	. 12.2-2-A]	
	Calculation Bases			
EF3 COL 12.2-2-A	Meteorology X/Qs	Table 12.2-15R		
EF3 COL 12.2-2-A	Meteorology D/Qs	Table 12.2-15R		
	Airborne Release Source Term	DCD Table 12.2-16	(
	Calculation Methodology	RG 1.109	and Table	12.2-206
	Computer Code Utilized	GASPAR II (NUREG/CR-4653)		
	Individual Consumption Rates	Table E-5 of RG 1.1	09	
	Misc. Calculation Inputs (other than RG 1.109 defa	ult values):	<u> </u>	
EF3 COL 12.2-2-A	Midpoint of plant operating life	20 years		
EF3 COL 12.2-2-A	Fraction of year that leafy vegetables are grown	0.33		
EF3 COL 12.2-2-A	Fraction of year that animals graze on pasture	0.58 for milk cows 0.67 for goats		
EF3 COL 12.2-2-A	Fraction of daily feed that is pasture grass when the animal grazes on pasture	1 for cows 1 for goats		
	Animal milk considered for milk pathway	Cow and Goat		
EF3 COL 12.2-2-A	Annual Average Doses from Airborne Releases			

Fermi 3			
Skin			
em/year)			
2.53F-01			
3.01E-01			
4.18E-02			
7.02E-02			
1.71E-01			
1.69E-02			
1.42E-02			
2.66-02			
8.61E-04			
8.69E-04			
7.67E-04			
4.41E-04			
1.85E-03			
3.35E-03			
8.15E-03			
1.70E-02			
1.97E-03			
8.60E-03			
8.80E-03			
1.83E-02			

[EF3 COL 12.2-2-A]



2 1 mrem = 0.01 mSv.

Insert Table 12.2-18bR

.

.

		Annual Dose (mrem/yr)					
Location	Pathway	Total Body	Thyroid	Bone	Skin		
Site Boundary (769 m [0.48 mi] NNW)	Plume	1.42E-01	1.42E-01	1.42E-01	3.35E-01		
	Radioiodines and Pa	articulates:					
	Ground	6.96E-01	6.96E-01	6.96E-01	8.16E-01		
	Inhalation						
	Adult	3.88E-03	2.43E-01	2.44E-03	1.49E-03		
	Teen	3.70E-03	3.16E-01	3.38E-03	1.50E-03		
Site Boundary (769	Child	2.94E-03	3.85E-01	4.53E-03	1.33E-03		
m [0.48 mi] NW)	Infant	1.69E-03	3.51E-01	3.06E-03	7.63E-04		
	Total (lodine & Par	ticulates)					
	Adult	7.00E-01	9.39E-01	6.98E-01	8.17E-01		
	Teen	7.00E-01	1.01E+00	6.99E-01	8.18E-01		
	Child	6.99E-01	1.08E+00	7.01E-01	8.17E-01		
	Infant	6.98E-01	1.05E+00	6.99E-01	8.17E-01		
· · · · · · · · · · · · · · · · · · ·	Radioiodines and Pa	articulates:					
	Ground	4.95E-01	4.95E-01	4.95E-01	5.81E-01		
	Vegetable				· · · · ·		
	Adult	1.73E-01	3.89E+00	4.18E-01	5.38E-02		
	Teen	2.07E-01	5.41E+00	6.96E-01	9.03E-02		
	Child	3.37E-01	1.05E+01	1.68E+00	2.20E-01		
Residence (957 m	Inhalation						
[0.59 mi]) + Garden	Adult	2.81E-03	1.85E-01	1.74E-03	1.14E-03		
(960 m [0.60] mi	Teen	2.72E-03	2.40E-01	2.41E-03	1.16E-03		
NW)	Child	2.23E-03	2.93E-01	3.23E-03	1.02E-03		
	Infant	1.29E-03	2.68E-01	2.20E-03	5.87E-04		
	Total (Iodine & Par	ticulates)					
	Adult	6.71E-01	4.57E+00	9.15E-01	6.36E-01		
	Teen	7.05E-01	6.15E+00	1.19E+00	6.72E-01		
	Child	8.34E-01	1.13E+01	2.18E+00	8.02E-01		
	Infant	4.96E-01	7.63E-01	4.97E-01	5.82E-01		
Meat Cow (4754 m	Radioiodines and Pa	articulates:					
[2.95 mi] NNW)	Ground	1.07E-02	1.07E-02	1.07E-02	1.26E-02		
	Cow Meat						
	Adult	1.61E-03	4.93E-03	6.67E-03	1.29E-03		
	Teen	1.27E-03	3.72E-03	5.62E-03	1.09E-03		
	Child	2.22E-03	6.02E-03	1.05E-02	2.05E-03		
	Inhalation						
/	Adult	1.31E-04	8.69E-03	6.62E-05	7.40E-05		

		Annual Dose (mrem/yr)			
Location	Pathway	Total Body	Thyroid	Bone	Skin
	Teen	1.32E-04	1.13E-02	9.16E-05	7.46E-05
	Child	1.14E-04	1.37E-02	1.23E-04	6.59E-05
	Infant	6.68E-05	1.25E-02	8.54E-05	3.79E-05
	Total (Iodine & P	articulates)			
	Adult	1.25E-02	2.43E-02	1.75E-02	1.39E-02
	Teen	1.21E-02	2.57E-02	1.64E-02	1.37E-02
	Child	1.31E-02	3.04E-02	2.13E-02	1.47E-02
	Infant	1.08E-02	2.32E-02	1.08E-02	1.26E-02
	Radioiodines and	Particulates:			
	Ground	2.90E-02	2.90E-02	2.90E-02	3.40E-02
	Cow Milk				
	Adult	8.56E-03	2.84E-01	1.76E-02	2.53E-0
	Teen	1.13E-02	4.52E-01	3.22E-02	4.64E-0.
	Child	1.86E-02	9.00E-01	7.80E-02	1.13E-02
	Infant	3.28E-02	2.18E+00	1.46E-01	2.37E-02
	Inhalation				
Milk Cow (3363 m	Adult	2.41E-04	1.61E-02	1.26E-04	1.31E-04
[2.09 m] winw)	Teen	2.42E-04	2.09E-02	1.74E-04	1.32E-04
	Child	2.08E-04	2.55E-02	2.32E-04	1.17E-04
	Infant	1.23E-04	2.32E-02	1.62E-04	6.71E-0
	Total (Iodine & P	articulates)			
	Adult	3.78E-02	3.30E-01	4.67E-02	3.67E-02
	Teen	4.05E-02	5.01E-01	6.13E-02	3.88E-02
	Child	4.78E-02	9.55E-01	1.07E-01	4.54E-02
	Infant	6.19E-02	2.24E+00	1.76E-01	5.77E-02
	Radioiodines and	Particulates:	•		
	Ground	2.57E-02	2.57E-02	2.57E-02	3.01E-02
	Goat Milk				
	Adult	1.68E-02	3.48E-01	2.38E-02	2.39E-02
	Teen	1.86E-02	5.53E-01	4.32E-02	4.34E-0
	Child	2.24E-02	1.10E+00	1.05E-01	1.05E-02
	Infant	3.48E-02	2.67E+00	1.88E-01	2.19E-02
	Inhalation				
Milk Goat (3554 m	Adult	2.17E-04	1.45E-02	1.12E-04	1.20E-0
[2.21 mij WNW]	Teen	2.19E-04	1.88E-02	1.54E-04	1.21E-04
	Child	1.89E-04	2.30E-02	2.07E-04	1.07E-04
	Infant	1.11E-04	2.10E-02	1.44E-04	6.17E-0
	Total (Iodine & P	Particulates)			
	Adult	4.27E-02	3.88E-01	4.96E-02	3.26E-0
	Teen	4.45E-02	5.98E-01	6.91E-02	3.46E-0
	Child	4.83E-02	1.15E+00	1.30E-01	4.07E-02
	Infant	6.06E-02	2.72E+00	2.14E-01	5 21E-0

•

Type of Dose	Location	Fermi 3	10 CFR 50 Limit
Semma Air (mrad/yr)	Site Boundary (1131 m [0.70 mi] SSE)	1.62E-01	10
Beta Air (mræd/yr)	Site Boundary (1131 m [0.70 mi] SSE)	2.00E-01	20
Whole Body (mrem/yr)	Site Boundary (1131 m [0-20 mi] SSE)	0.66E-01	5
Skin (mrem/yr)	Site Boundary (1121 m [0 Insert Table 12.2-201	7.69E-01	15
lodines and Particulates – Max Organ Thyroid	WNW Direction, Site Boundary (919 m	1.47E+01	15
(mrem/yr)	Garden and Meat Cow 3704 m [2.3 mi} for Goat		
	3513 m [2.18 mi]) for Cow Milk		
1 mrad = 0.01 mGy 1 mrem = 0.01 mSv			

Table 12.2-201 Comparison of Annual Doses to the MEI from Gaseous Effluents [EF3 COL 12.2-2-A]

Insert Table 12.2-201

				2.18E-01
			10 CFR50	
Type of Dose	Location	Fermi 3	Limit	
Gamma Air (mrad/yr)	Site Boundary (769 m [0.48 mi] NNW)	1.90E-01	10	2.59E-01
Beta Air (mrad/yr)	Site Boundary (769 m [0.48 mi] NNW)	2.33E-01	20	
Whole Body (mrem/yr) [Includes Plume Exposure]	Table 12.2-18bR	5.69E-01	< <u>−</u>	-19.76E-01
Skin (mrem/yr) [Includes Plume Exposure]	Table 12.2-18bR	7 .17E-01	< <u>−−15</u>	_1.15E+00
Iodines and Particulates – Max Organ Thyroid (mrem/yr)	Table 12.2-18bR	1.08E+01	← 15	1.13E+01
1 mrad = 0.01 mGy				

1 mrem = 0.01 mSv

Table 12.2-203 Comparison of Site Doses to the MEI[EF3 COL 12.2-2-A] [EF3 COL 12.2-3-A]

	Fe	rmi 3 (ESBWI	R)		Site	40 CFR 190	
Type of Dose	Liquid	Gaseous	Total	– Fermi 2	Total ⁽¹⁾	Limit	
Whole Body (mrem/yr)	0.006	0.67	0.68	4.68	5-26	25	
Thyroid (mrem/yr)	0.026	Insert Ta	ble 12.2-2	03 2.66	17.39	75	
Bone (mrem/yr)	0.088	1.81	1.90	0.052	1.95	25	

Notes:

- 1. This site total dose includes the Fermi 3 total dose and the dose from Fermi 2.
- 2. 1 mrem = 0.01 mSv

insert Table 12.2-203

	F	ermi 3 (ESBWF	R)		Site Total	40 CFR 190
Type of Dose	Liquid	Gaseous	Total	Fermi 2	(1)	Limit
Whole Body (mrem/yr)	0.006	0.589	- <u></u>	4.68	- 5.26-	25
Thyroid (mrem/yr)	0.026	10.8		2.66	-13.49	75
Bone (mrem/yr)	0.088	-1.29	1.38	0.05	1.43-	25
		Gaseous	 Total		Site To	tal
		0.976	0.98		5.66	
		11.3	11.33		13.99	
		2.18	2.27		2.32	

Table 12.2-204Collective Total Body (Population) Doses Within 50 Miles[EF3 COL12.2-2-A][EF3 COL 12.2-3-A]

Units in person-rem/	yr	
	Fermi 3	
Total Body (Liquid)	14.9	
Bone (Liquid)	104.2	
Thyroid (Liquid)	30.1	6.7
Total Body (Gaseous)	-4.5-K	
Max Organ – Thyroid (Gaseous)	-24.1	
1 rom = 0.01 Sv		27.1

1 rem = 0.01 Sv

1

Instanc	Decay	Water Concentration				
isotope	Constant	(MBq/gm)	μCi/gm)			
I-131	3.59E-03	5.6E-05	1.5E-03			
1-132	3.03E-01	5.3E-04	1.4E-02			
I-133	3.33E-02	3.8E-04	1.0E-02			
I-134	7.91E-01	9.7E-04	2.6E-02			
I-135	1.05E-01	5.5E-04	1.5E-02			

Table 12.2-205Fermi 3 Normal Operational Iodine Radioisotopes in Reactor Water
(Based on Fermi 3 ODCM)[EF3 COL 12.2-2-A]

Table 12.2-206 Fermi 3 Annual Airborne Iodine Releases for Offsite Dose Evaluations (MBq)** - Based on Reactor Water Iodine Concentrations in Table 12.2-205 [EF3 COL 12.2-2-A]

Nuclide	Reactor Building	Turbine Building	Radwaste Building	Mechanical Vacuum Pump	Turbine Seal	Offgas System	Drywell
I-131	9.4E+02	5.2E+03	3.4E+02	1.8E+03	4.7E+01		3.4E+02
I-132	8.5E+03	4.6E+04	3.0E+03				4.9E+01
I-133	6.2E+03	3.4E+04	2.2E+03		8.4E+01		3.3E+02
I-134	1.5E+04	8.4E+04	5.5E+03				3.4E+01
I-135	8.6E+03	4.7E+04	3.1E+03				1.4E+02

** The releases (as designated in the table column headings) from the building stacks are as follows:

Reactor Building/Fuel Building stack: "Reactor Building" and "Drywell" Turbine Building stack: "Turbine Building", "Mechanical Vacuum Pump", "Turbine Seal", and "Offgas System"

Radwaste Building stack: "Radwaste Building"

.

Markup of Detroit Edison ER (following 18 pages)

The following markup represents how Detroit Edison intends to reflect this RAI response in the next submittal of the Fermi 3 ER Revision 2. However, the same COLA content may be impacted by revisions to the ESBWR DCD, responses to other COLA RAIs, other COLA changes, plant design changes, editorial or typographical corrections, etc. As a result, the final COLA content that appears in a future submittal may be different than presented here.

3.5 Radioactive Waste Management System

This section describes the liquid, gaseous, and solid radioactive waste (radwaste) treatment systems and the instrumentation used to monitor the effluent release points. The information includes the origin, treatment, and disposal of all liquid, gaseous, and solid radioactive wastes generated by the station during normal operation including anticipated operational occurrences (e.g., refueling, purging, equipment downtime, maintenance). Low Level Mixed Waste is discussed in Subsection 3.6.3.4.

During normal operations of reactors, fission neutrons can activate nonradioactive materials normally present in the reactor coolant. Trace metals such as iron, cobalt, and manganese can become activated. Small amounts of fission-activated products within the fuel can enter the coolant by diffusing through the fuel cladding, or by escaping through fuel cladding leaks, if they occur. Thus, the reactor coolant normally carries materials with varying degrees of radioactivity. The sources of radioactivity and the source terms used for the design of the radioactive waste management systems are described in DCD Chapter 11 (Reference 3.5-1).

The radioactive waste management systems are designed to maintain releases of radioactive materials in effluents to "as low as reasonably achievable" levels in conformance with 10 CFR Parts 20 and 50, including the design objectives of 10 CFR 50 Appendix I. Brief descriptions of the radioactive waste management systems are provided in this section. More complete descriptions of the radioactive waste management systems design, including process flow diagrams, are included in DCD Sections 11.2, 11.3, and 11.4.

3.5.1 Source Terms /



The sources of radioactivity that serve as input to the liquid, gaseous, and solid radioactive waste treatment systems for normal operation (including anticipated operational occurrences) are described in DCD Section 11.1. These sources include fission products (noble radiogas, radioiodines, and transuranic nuclides) and activation products (coolant, non-coolant, tritium, and Argon-41). DCD Section 12.2 provides additional information on plant sources of radioactivity.

The calculation model used to determine the activity of each radionuclide in the primary containment is based on the ANSI/ANS 18.1 source terms (Reference 3.5-2) with appropriate adjustment factors applied. The details of the model, including the fission product noble gas release rate used, are provided in DCD Section 11.1.

Regulatory Guide 1.112, Appendix A, provides a listing of data needed for radioactive source term calculations for Boiling Water Reactors. General data needed for calculation of the radioactive source term is provided in DCD Sections 11.1, 11.2, and 11.3. Additional information on condensate demineralization and condensate and gland seal air removal systems is provided

in DCD Sections 10.4.6 and 10.4.3, respectively. The ESBWR DCD concluded that the ESBWR conforms to Regulatory Guide 1.112 as shown in DCD Table 1.9-21 (Reference 3.5-1). There are no site-specific parameters that change that conclusion.

DCD Section 9.4 describes the building HVAC systems servicing the Fuel Building, Turbine Building, Radwaste Building, and Reactor Building, and includes process diagrams for each system. Detailed discussion of the potential sources of airborne activity to each of these systems is provided in DCD Section 12.2.3. This includes information on airborne sources from the fuel pool resulting from refueling activities.

During periods of high radioactivity, the Reactor Building and Fuel Building HVAC systems may direct exhaust to the Reactor Building HVAC purge exhaust filter unit. The Reactor Building purge exhaust filter units are equipped with prefilters, high efficiency particulate air (HEPA) filters and carbon filters for mitigating and controlling gaseous effluents from the Reactor Building or Fuel Building. DCD Table 9.4-11 provides design information for the Reactor Building purge exhaust filter units. The exhaust air is monitored for radiation prior to discharge to atmosphere through the RB/FB stack.

The Radwaste Building HVAC system directs exhaust air to exhaust filtration units. The system uses HEPA filtration of the exhaust air from the building prior to discharge to the atmosphere. The exhaust air is monitored for radiation prior to discharge to atmosphere through the RW stack. DCD Table 9.4-7 provides design information for the Radwaste Building HVAC system.

The Turbine Building HVAC system directs building exhaust air to filtration units. Exhaust air from low potential contamination areas is exhausted to the TB stack, where it is monitored for radioactive contamination. Exhaust air from high potential contamination areas is filtered using HEPA filters before being exhausted to the TB stack. Areas with high potential contamination have exhaust subsystems equipped with HEPA filtration units for localized air cleanup prior to mixing with the main ventilation exhaust. The Turbine Building combined ventilation exhaust is monitored for halogens, particulates and noble gas releases. Turbine Building exhaust air is directed to the TB stack where it is monitored for radiation prior to being discharged to the atmosphere.

Process radiation monitoring is provided for the systems described above. FSAR Section 11.5 describes the PRMS in further detail. as supplemented by FSAR Table 12.2-206

The bounding annualized airborne radioactivity source terms for Fermi 3 are shown in DCD Table 12.2-16. The parameters used for determining the release characteristics are shown in DCD Table 12.2-16. The resulting bounding annualized release was used in determining the radiological impacts of operation. This analysis, resulting impact determinations, and evaluation showing conformance with 10 CFR 50, Appendix I design objectives are described in more detail in Section 5.4.

FSAR Table 12.2-15R

I

3.5.2.3 Solid Waste Management System

Certain amounts of radioactive materials are generated in solid form. The Solid Waste Management System (SWMS) collects, processes, packages, and temporarily stores these solid radioactive wastes for offsite shipment and permanent disposal.

The SWMS controls, collects, handles, processes, packages, and temporarily stores solid waste generated by the plant prior to shipping the waste offsite. These wastes include filter backwash

In lieu of onsite storage, Fermi 3 could enter into a commercial agreement with a third-party contractor that will process, store, own, and ultimately dispose of low-level waste generated as a result of Fermi 3 operations. Activities associated with the transportation, processing, and ultimate disposal of low level waste by the third-party contractor would necessarily comply with all applicable laws and regulations in order to assure public health and safety and protection of the environment. In particular, the third-party contractor would conduct its operations consistent with applicable Agreement State or NRC regulations (e.g., 10 CFR Part 20), which will assure that the radiological impacts from these activities would be small. Environmental impacts resulting from management of low-level wastes are expected to be bounded by the NRC's findings in 10 CFR 51.51(b) (Table S-3). Table S-3 assumes that solid, low-level waste from reactors will be disposed of through shallow land burial, and concludes that this kind of disposal will not result in the release of any significant effluent to the environment.

3.5.2.4 **Population Doses**

Population doses offsite were determined for airborne and liquid release pathways. A detailed discussion of the calculation methods and inputs is provided in Section 5.4.

Results of the analysis and conformance with 10 CFR 20 and 10 CFR 50, including the design objectives of 10 CFR 50, Appendix I are provided in Section 5.4.

3.5.3 References

- 3.5-1 GE-Hitachi Nuclear Energy, "ESBWR Design Control Document Tier 2," Revision 6, -August 2009.
- 3.5-2 ANSI/ANS 18.1, "Source Term Specification," 1976.
- 3.5-3 EPRI Class B/C Waste Reduction Guide (November 2007).
- 3.5-4 EPRI Operational Strategies to Reduce Class B/C Wastes (April 2007). 7, March 2010.

DCD

Combined License Application Part 3: Environmental Report

5.4 Radiological Impacts of Normal Operation

This section describes the radiological impacts of normal plant operation on members of the public, plant workers, and biota. A 50-mile region of interest is chosen for determining impacts to the general public although maximum impacts to individuals are calculated for the immediate plant environs. Subsection 5.4.1 describes the exposure pathways by which radiation and radioactive effluents could be transmitted from Fermi 3 to organisms living near the plant. Subsection 5.4.2 estimates the maximum doses to the public from the operation of Fermi 3. Subsection 5.4.3 evaluates the impacts of these doses by comparing them to regulatory limits. In addition, the impact of Fermi 3 in conjunction with Fermi 2 is compared to the corresponding regulatory limit. Subsection 5.4.4 considers the impact to non-human biota.

5.4.1 Exposure Pathways

Radioactive gases would be discharged to the environment during normal operation of Fermi 3. Fermi 3 is planned to be operated as a zero liquid effluent discharge plant. However, the analyses discussed herein conservatively assume that liquid effluents are discharged as part of normal operation. The released quantities have been estimated in ESBWR Tables 12.2-16 (gases) and 12.2-19b (liquids) (Reference 5.4-10). The impact of these releases and any direct radiation to individuals, population groups, and biota in the vicinity of Fermi 3 was evaluated by considering the most important pathways from the release to the receptors of interest. The major pathways are those that could yield the highest radiological doses for a given receptor. The relative importance of a pathway is based on the type and amount of radioactivity released, the environmental transport mechanism, and the consumption or usage factors of the receptor.

The exposure pathways considered and the analytical methods used to estimate doses to the maximally exposed individual (MEI) and to the population surrounding the new unit are based on Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR 50, Appendix I" (Reference 5.4-1) and Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors," (Reference 5.4-2). An MEI is a member of the public located to receive the maximum possible calculated dose. The annual dose to each nearby receptor indicated in Section 2.7 from the estimated releases from Fermi 3 was calculated, and the maximum of those was denoted the MEI. The use of the MEI allows comparisons with established dose criteria to the public.

5.4.1.1 Liquid Pathways

As noted above, Fermi 3 is designed for zero liquid effluent discharge during normal operation. However, the analyses discussed herein conservatively assume that liquid effluents are discharged as part of normal operation. For this analysis, the liquid effluents would be released through the Circulating Water (CIRC) blowdown line, approximately 1300 feet into Lake Erie. Dilution would occur due to mixing of the liquid effluent with the normal CIRC blowdown. Additional dilution would occur in Lake Erie. The dilution factors in Lake Erie are determined as part of the thermal analysis. The LADTAP II computer program (Reference 5.4-4) was used to calculate these doses with parameters specific to Lake Erie. This program implements the radiological exposure models described in Regulatory Guide 1.109 for radioactivity releases in liquid effluent. The following exposure pathways are considered in LADTAP II:

- Ingestion of drinking water from Lake Erie
- Ingestion of aquatic organisms as food
- External exposure to contaminated sediments deposited along the shoreline (shoreline exposure)

Although less important, as determined by LADTAP II calculations, the swimming and boating exposure pathways are also considered in the analysis. The program also considers ingestion of food sources that use the affected water for irrigation. However, as discussed in Subsection 2.3.2, water from Lake Erie in the vicinity of Fermi 3 is not used for irrigation. The site-specific input parameters for the liquid pathway are presented in Table 5.4-1.

5.4.1.2 Gaseous Pathways

The GASPAR II computer program (Reference 5.4-11) was used to calculate the doses to offsite receptors (the general public within 50 miles and the nearest individual receptors in various directions) from Fermi 3. This program implements the radiological exposure models described in Regulatory Guide 1.109 to estimate the doses resulting from radioactive releases in gaseous effluent. The atmospheric dispersion component of the analysis was calculated with the XOQDOQ computer program (Reference 5.4-5). Dispersion and deposition factors were calculated from validated onsite meteorological parameters (wind speed, wind direction, stability class) for the combined years 2002 through 2007 as described in Section 2.7. and 1985 through 1989)

Section 2.7 describes the meteorological data, gives the dispersion and deposition factors, and gives the locations of the individual receptors (distance and direction) relative to Fermi 3.

The following exposure pathways are considered in GASPAR II:

- External exposure to contaminated ground
- External exposure to gases in air
- Inhalation of airborne activity
- Ingestion of contaminated meat and milk ٠
- ٠ Ingestion of contaminated garden vegetables

The spatial distribution of population was discussed in Section 2.5. The agricultural production for the 50 miles surrounding the site was developed from information in Section 2.2. The input parameters for the gaseous pathway are presented in Table 5.4-3.

5.4.1.3 Direct Radiation from Fermi 3

The primary objective of radiation shielding is to protect operating personnel and the general public from radiation emanating from the reactor, power conversion systems, radwaste process systems and auxiliary systems.

centerline)

Figure 4.5-2 shows the locations of thermoluminescent dosimeter (TLD) measurements at Fermi 2. Measurements show that the direct dose levels at the site boundary are at background levels.

Shielding in Fermi 3 is provided to protect the general public outside the controlled area. The direct dose contribution from Fermi 3 is provided at two distances in DCD Table 12.2-21. The DCD annual dose at 800 meters is 5.93E-04 mrem/year. The distance from Fermi 3 to the site boundary is at least 890 meters. Therefore, the value from DCD Table 12.2-21 is conservative. This annual dose is considered to be negligible.

5.4.2 Radiation Doses to Members of the Public (Individuals)

Doses to MEIs residing near Fermi 3, from liquid and gaseous effluents are estimated using the methodologies and parameters specified in Subsection 5.4.1. Collective doses to the general public from Fermi 3 are described in Subsection 5.4.3.

Doses from the ISFSI to Fermi 3 construction workers are discussed in Section 4.5. These dose values are representative of doses anticipated during Fermi 3 operations.

It is noted that radiation is naturally present in the environment. It comes from outer space (cosmic), the ground (terrestrial), and even from our own bodies. It is present in the air breathed, the food and water consumed, and in the construction materials used to build homes. The average annual radiation exposure from natural sources to an individual in the United States is about 300 mrem (Reference 5.4-3).

5.4.2.1 Liquid Pathway Doses

Based on the parameters shown in Table 5.4-1, the LADTAP II computer program was used to calculate the important doses to the MEI via the following activities:

- Drinking contaminated water
- Eating fish and invertebrates caught in Lake Erie
- Shoreline exposure

The liquid activity releases (source terms) for each radionuclide in the discharge are described in Subsection 3.5.1. The MEI for the total body dose is determined to be an adult. The maximum organ dose occurs to the bone for a child. The maximum annual doses to the total body and organs from all pathways for all age groups calculated by the LADTAP program are presented in Table 5.4-4.

5.4.2.2 Gaseous Pathway Doses

Based on the parameters in Table 5.4-3, the GASPAR II computer program was used to calculate doses to the MEI child, who represents the bounding age group for total body and all organs. GASPAR determined that a child was the MEI because of the greater sensitivity of that age group to internal exposure from vegetables and meat. The gaseous activity releases (source terms) for each radionuclide are described in Subsection 3.5.1. The annual pathway components for the total

The NW direction provides the limiting dose for residents and consumption of vegetables.

11.3

due to meat consumption.

body, thyroid, and other organ doses calculated by the GASPAR computer program for this individual are presented in Table 5.4-5.

As shown in Table 5.4-5, the annual total body dose to the MEI is 0.67 mrem to a child, and the maximum annual thyroid dose of 14.7 mrem to a child. Experience at Fermi 2 (Reference 5.4-6) indicates that these calculations are likely very conservative.

5.4.2.3 **Summary**

The maximum doses due to the liquid and gaseous effluents are summarized in Table 5.4-5. As shown, all results are well within the 10 CFR 50, Appendix I limits. Therefore, the impacts are SMALL and no mitigation actions are necessary.

5.4.3 Impacts to Members of the Public (Individual and Collective Dose to the Public and Comparison with Regulations)

The radiological impacts to individuals and population groups from liquid and gaseous effluents are presented using the methodologies and parameters specified in Subsection 5.4.1. Table 5.4-5 estimates the total body and organ doses to the MEI from liquid effluents and gaseous releases from Fermi 3 for analytical endpoints prescribed in 10 CFR 50, Appendix I. The MEI receptor age group and location are those described in Subsection 5.4.2. As Table 5.4-5 indicates, the predicted doses are below Appendix I limits. These results are discussed in Subsection 5.4.2.3, above.

The total site liquid and gaseous effluent doses from Fermi 2 plus Fermi 3 would be well within the regulatory limits of 40 CFR 190 (Table 5.4-8). As indicated in NUREG-1555, demonstration of compliance with the limits of 40 CFR 190 is considered to be in compliance with the 0.1 rem limit of 10 CFR 20.1301.

Table 5.4-6 and Table 5.4-7 show the total body dese to the population within 50 miles that would be attributable to Fermi 3. Based on the information in these tables, the total whole body dose due to liquid and gaseous effluents from Fermi 3 is 19.4 person-rem/year. As discussed above, the average annual radiation exposure from natural sources to an individual in the United States is about 300 mrem (Reference 5.4-3). Multiplying this by the population of 7,713,709 (Table 5.4-1), results in 2,300,000 person-rem/year. Thus, the dose from Fermi 3 is less than 0.001 percent of that received by the population from natural causes. Impacts to members of the public from operation of Fermi 3 would be SMALL and would not warrant mitigation.

Occupational exposure to Fermi 3 workers from Fermi 3 sources are described in the ESBWR DCD (Reference 5.4-12), Section 12.4. After consideration of shielding provided by the Fermi 3 facilities,

occupational exposure from other sources on-site are relatively insignificant. As described in the Fermi 3 FSAR, Appendix 12AA, occupational exposure at Fermi 3 will be maintained as low as reasonably achievable (ALARA).

5.4.4 Impacts to Biota Other than Members of the Public

Subsection 2.4.1 and Subsection 2.4.2 identify the relevant species within the site area. Radiation exposure pathways to biota are expected to be the same as those to humans, i.e., inhalation, external (from ground, airborne plume, water submersion, and shoreline), drinking water and ingestion. These pathways were examined to determine if they could result in doses to biota significantly greater than those predicted for humans from operation of Fermi 3. This assessment used surrogate species that provide representative information about the various dose pathways potentially affecting broader classes of living organisms. The gaseous pathway doses for muskrats, raccoons, herons and ducks were taken as equivalent to human doses for the inhalation (child), plume (adult), and twice the ground (adult) pathways, conservatively adjusted based on the assumption that the affected biota are located at 0.25 miles from the facility. The doubling of doses from ground deposition reflects the closer proximity of these organisms to the ground. Doses to those same species plus fish, invertebrate and algae are calculated by the LADTAP II computer program.

criteria

Estimated dose to two of the surrogates (duck and muskrat) are slightly greater than the criteria in 40 CFR 190.

Deses to biota from liquid and gaseous effluents from Fermi 8 are shown in Table 5.4-9. The total dose is taken as the sum of the internal and external dose. Annual doses to all of the surrogates meet the requirements of 40 CFR 190. The Bald Eagle, a species of significance known to inhabit the site, is represented by the surrogate species of Table 5.4-9. The Heron is a representative surrogate for the Bald Eagle. five

Use of exposure guidelines, such as 40 CFR 190, which apply to members of the public in unrestricted areas, is considered very conservative when evaluating calculated doses to biota. The International Council on Radiation Protection states that "...if man is adequately protected then other living things are also likely to be sufficiently protected," and uses human protection to infer environmental protection from the effects of ionizing radiation (Reference 5.4-7 and Reference 5.4-8). This assumption is appropriate in cases where humans and other biota inhabit the same environment and have common routes of exposure. It is less appropriate in cases where human access is restricted or pathways exist that are much more important for biota than for humans. R

Species in most ecosystems experience dramatically higher mortality rates from natural causes than man, as with essed by their lesser life spans. From an ecological viewpoint, population stability is considered more important to the survival of the species than the survival of individual organisms. Thus, higher dose limits could be permitted. In addition, no biota has been discovered that show significant changes in morbidity or mortality due to radiation exposures predicted from nuclear power plants.

An international consensus has been developing with respect to permissible dose exposures to biota. The International Atomic Energy Agency (IAEA) (Reference 5.4-9) evaluated available evidence including the "Recommendations of the International Commission on Radiological

NUREG 155, Section 5.4.4, indicates that if the doses are approximately the same order of magnitude as the criteria in 40 CFR 190, no further review is necessary. Thus, as the results for the duck and muskrat are of the same order of magnitude as 40 CFR 190, the results are considered to be acceptable

- 5.4-6 Detroit Edison, "Fermi 2 2006 Annual Radioactive Effluent Release and Radiological Environmental Operating Report for the period of January 1, 2006 through December 31, 2006.
- 5.4-7 International Council on Radiation Protection, "Recommendations of the International Commission on Radiological Protection," Publication 26, 1977.
- 5.4-8 International Council on Radiation Protection, "Recommendations of the International Commission on Radiological Protection," Publication 60, 1991.
- 5.4-9 International Atomic Energy Agency, "Effects of Ionizing Radiation on Plants and Animals at Levels Implied by Current Radiation Protection Standards," Report Series No. 332, 1992.
- 5.4-10 GE-Hitachi Nuclear Energy, "ESBWR Design Control Document Tier 2," Revision 6, August 2009.--
- 5.4-11 U.S. Nuclear Regulatory Commission, Office of Nuclear Reactor Regulation, "GASPAR II Technical Reference and User Guide," NUREG/CR-4653, March 1987.



Parameter	Value
Release Source Term	Refer to Subsection 3.5.1
Agricultural Production within 50 mile radius Meat Production Milk Production Vegetable Production (grain, tomatoes, potatoes)	Developed from Section 2.2 1.919E+07 kg/year 6.043E+08 liter/year 9.689E+09 kg/year
Fraction of the year that leafy vegetables are grown	0.33
Fraction of a maximum individual's vegetable intake from own garden	0.76
Fraction of the year milk cows are on pasture	0.58
Fraction of milk cow feed intake from pasture while on pasture	1.0
Fraction of year goats are on pasture	0.67
Fraction of goat feed intake from pasture while on pasture	1.0
Fraction of year meat cows are on pasture	0.58
Fraction of meat cow feed intake from pasture while on pasture	1.0
Consumption/Usage Rates	Table 5.4-2
Population Distribution 50-mile Population	Refer to Section 2.5 7,713,709 ⁽¹⁾
Distance and Direction to Receptors and Associated Atmospheric Dispersion Factors	Refer to Section 2.7
Humidity	- 10:98 g/m ³
Notes: 1. Estimated population for the year 2060, from Sectior	12.511

Table 5.4-3 Gaseous Pathway Input Parameters

I

Dose (mrem/yr)							
Skin ⁽¹⁾	Bone ⁽²⁾	Liver ⁽¹⁾	Total Body (3)	Thyroid ⁽⁴⁾	Kidney ⁽¹⁾	Lung (1);(2)	GI-LLI ⁽³⁾
1.19E-04	8.77E-02	1.00E-02	6.48E-03	2.63E-02	2.49E-03	1.11E-03	8.40E-03

Table 5.4-4 Liquid Pathway Doses for Maximally Exposed Individual

Notes:

1. Total of all pathways for Teen

2. Total of all pathways for Child

3. Total of all pathways for Adult

4. Total of all pathways for Infant

I

I

I

I

Table 5.4-5Comparison of Annual Maximally Exposed Individual Doses with
10 CFR 50, Appendix I Limits

		Annual	Dose
Type of Dose		Fermi 3	
Liquid Effluents			
Total Body (mrem/yr)		0.006 ⁽¹⁾	3
Max Organ – Bone (mrem/yr)		0.088 ⁽²⁾	10
Gaseous Effluents			
Total External Body (mrem/yr)		-0.67	5
Skin (mrem/yr)	0.98 1.15	0.77	15
Beta Air Dose (mrem/yr)	0.26	0.20	20
Gamma Air Dose (mrem/yr)	11.3	0.15	10
Max Organ – Thyroid (mrem/yr) Child	1	_{+4:7}	15

Notes:

1. Total dose from all pathways for an adult

2. Total dose from all pathways for a child

	Dose
Pathway	person-rem/yr
Plume	
Total Body	-0.86 -
Max Organ – Skin	2.94 -
Ground	
Total Body	1.86
Max Organ – Skin	<u>4.24</u>
Inhalation	
Total Body	-8:68 -
Max Organ – Thyroid	4,80
Vegetable	
Total Body	-1.86
Max Organ Bone	8.39
Cow Milk	,,,,,,,,
Total Body	-0.56
Max Organ – Thyroid	1 5.0
Meat Cow	
Total Body	-0.03-
Max Organ – Bone	0.12
50-Mile Total Dose	
Total Body	- 4.5-
Max Organ – Thyroid	24.1

Table 5.4-7 50-mile Population Doses from Gaseous Effluents

l

I

I

	F	ermi 3 (ESBW	R)		Sife Total	40 CFR 19
Type of Dose	Liquid	Gaseous	Total	Eermi 2	(1)	Limit
Total Body (mrem/yr)	0.006	Insert Table 5.4-	8 here.	4.68	5.36	25
Thyroid (mrem/yr)	0.026	14.7	14.7	2.86	17.39	75
Bone (mrem/yr)	0.088	1.81	1.90	0.05	1.95	25

Notes:

1. This site total dose includes the Fermi 3 total dose and the dose from Fermi 2.

.

2. 1 mrem = 0.01 mSv

Insert Table 5.4-8

	Fermi 3 (ESBWR)				Site Total	40 CFR 190	
Type of Dose	Liquid	Gaseous	Total A		Fermi 2	(1)	Limit
Total Body (mrem/yr)	0.006	- 0.569 -			4.68	5.26	25
Thyroid (mrem/yr)	0.026	-10.8	10.83		2.66	13.49	75
Bone (mrem/yr)	0.088	-1.29			0.05	-1.43 -	25

Ţ

Gaseous	Total	Site Total
0.976	0.98	5.66
11.3	11.33	13.99
2.18	2.27	2.32

I

	Dose (mrem per year)			
Biota	Liquid Effluents	Gaseous Effluents ⁽¹⁾	Total	40 CFR 190 Limit
Fish	2.31	0	2.31	25
Invertebrate	7.65	0	7.65	25
Algae	11.9	0	11.9	25
Muskrat	14.8 11.	15 7 .04	21.8 25.	95 25
Raccoon	0.43 11.	15 -7:04 -	7:47 -11.	58 25
Heron	6.87 11.	15 7.94	18. 1 3.9 25.	95 25
Duck	14.8	7.04	21.8	25

Table 5.4-9 Doses to Biota from Liquid and Gaseous Effluents

Notes:

1. Dose from gaseous effluents determined based on whole body inhalation dose for child + whole body ground and plume exposure at 0.25 miles from the facility. Ground exposures increased by a factor of two to account for ground proximity.

Fermi 3 Combined License Application Part 3: Environmental Report

FR 30028), "vicinity" is the area within one mile of the plant site boundary. "Prompt Fatality Risks" are defined as the sum of risks which the average individual residing in the vicinity of the plant is exposed to as a result of normal daily activities (driving, household chores, occupational activities, etc). For this evaluation, the sum of prompt fatality risks was taken as the U.S. accidental death risk value of 37.7 deaths per 100,000 people per year (Reference 7.2-2).

7.2.4.2 Societal Risk Goal

The risk to the population in the area near a nuclear power plant of cancer fatalities that might result from its operation should not exceed one-tenth of one percent (0.1 percent) of the sum of the cancer fatality risks resulting from all other causes. As defined in the Safety Goal Policy Statement (51 FR 30028), "near" is within 10 miles of the plant. The cancer fatality risk was taken as 191.4 deaths per 100,000 people per year based upon National Center for Health Statistics data for 2001–2004 (Reference 7.2-2).

7.2.4.3 Radiation Dose Goal

The probability of an individual exceeding a whole body dose of 25 rem at a distance of 0.5 mile from the reactor shall be less than one in a million per reactor year.

7.2.5 Conclusions

The total calculated dose-risk to the 50-mi population from airborne releases from an ESBWR reactor at the Fermi site would be 0.032 person-rem per reactor year (Table 7.2-1). This value is less than the population risk for all current reactors that have undergone license renewal, and less than that for the five reactors analyzed in NUREG-1150 (Reference 7.2-7).

Seventy-five percent of the Fermi 3 dose-risk is from late phase pathway exposures, especially groundshine and ingestion. The Fermi 3 early phase dose-risk, 0.0071 person-rem per reactor year, can be compared with the GEH generic calculation of 24-hour dose-risk (which does not include late phase exposure) of 0.017 person-rem per reactor year (Reference 7.2-3); GEH did not calcualte late phase consequences.

Comparisons with the existing nuclear reactor fleet (Subsection 7.2.3.2) indicate that risk from the surface-water pathway is SMALL. Under the severe accident scenarios, surface-water is primarily contaminated by atmospheric deposition. The ESBWR atmospheric pathway doses are significantly lower than those of the current nuclear fleet. Therefore, it is reasonable to conclude that the doses from the surface-water pathway at the Fermi site would be consistently lower than those reported in Subsection 7.2.3.2 for the current fleet.

The risks of groundwater contamination from a severe ESBWR accident (see Subsection 7.2.3.3) would be much less than the risk from currently licensed reactors. Additionally, interdiction could substantially reduce the groundwater pathway risks. 21.6

For comparison, as reported in Subsection 5.4.3, the whole body dose from the Fermi site normal cirberne releases is predicted to be $\frac{22.2}{22.2}$ person-rem annually. As previously described, dose-risk is dose times frequency. Normal operations have a frequency of one. Therefore, the dose-risk for normal operations is $\frac{22.5}{22.5}$ person-rem per reactor year. Comparing this value to the severe

21.6

L



2.0

accident dose risk of 0.032 person-rem per reactor year indicates that the dose risk from severe accidents is approximately 0.1-percent of the dose-risk from normal operations.

The probability-weighted risk of early and late cancer fatalities from a severe accident at the Fermi site in the surrounding 50-mile population projected for 2060 of 7.7 million is reported as 1.8×10^{-5} fatalities per reactor year in Table 7.2-1. For a 60-year reactor operating life, this population cancer fatality risk becomes 1.2×10^{-3} .

The probability of an individual dying from any cancer from any cause is approximately 0.23 for men and 0.20 for women over a lifetime (Reference 7.2-1). This implies that more than 1.5×10^6 members of the 50-mile population will die of cancer.

The cancer fatality risk from a severe accident at Fermi 3 to the 50-mile population is then less than 10^{-7} percent of the background risk, which is much less than the societal risk goal of 0.1 percent of the background risk.

The results from the analysis discussed in this section are used in Section 7.3 to determine if there are any cost-beneficial design alternatives that should be considered to mitigate the impacts described herein.

7.2.6 References

7.2-1	American Cancer Society, "Lifetime Probability of Developing or Dying from Cancer," http://www.cancer.org/docroot/CRI/content/CRI_2_6x_Lifetime_Probability_of_Developin g_or_Dying_From_Cancer.asp, accessed 1 May 2008.
7.2-2	Centers for Disease Control, "Deaths: Final Data for 2004," National Vital Statistics Reports, Volume 55 Number 19, August 21, 2007.
7.2-3	GE Energy, "ESBWR Probabilistic Risk Assessment," NEDO-33201, Revision 4, June 2009.
7.2-4	GE-Hitachi Nuclear Energy, "ESBWR Design Control Document - Tier 2," Revision 6, August 2009.
7.2-5	U.S. Nuclear Regulatory Commission, "SECPOP 2000: Sector Population Land Fraction, and Economic Estimation Program," NUREG/CR-6525, August 2003.
7.2-6	U.S. Nuclear Regulatory Commission, "Liquid Pathway Generic Study: Impacts of Accidental Radioactive Releases to the Hydrosphere from Floating and Land-Based Nuclear Power Plants," NUREG-0440, February 1978.
7.2-7	U.S. Nuclear Regulatory Commission, "Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants," NUREG-1150, June 1989.
7.2-8	U.S. Nuclear Regulatory Commission, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," NUREG-1437, Volumes 1 and 2, May 1996.

Revision 1 March 2010

> Attachment 4 NRC3-10-0040

Supplemental Response to RAI letter related to Fermi 3 ER

RAI Question HH5.4.4-1

NRC RAI HH5.4.4-1

Provide dose estimates for biota (including the bald eagle) inside the site boundary (0.25 mi from Fermi 3 emission sources).

Supporting Information

Biota doses are presented in Table 5.4-9 (Dose to Biota from Liquid and Gaseous Effluents) but the assumptions used with the LADTAP computer code to estimate dose to biota from liquid effluents are not provided. It is assumed that biota would be at the site boundary to calculate the dose from gaseous effluent but biota could be inside the site boundary and very near the proposed Fermi Unit 3.

According to ESRP Section 5.4.4, "the biota to be considered in this evaluation should include those in the pathways identified in ESRP 5.4.1, those appearing on the endangered/threatened species lists, and others of significance." ER Section 2.4.1.2.1, page 2-330 states that two bald eagle nests were observed on the Fermi site in May 2008. Dose calculations for the bald eagle should be made because the species is protected by the Migratory Bird Treaty Act and the Bald and Golden Eagle Protection Act.

Supplemental Response

In the original response to ER RAI HH5.4.4-1 in Detroit Edison letter NRC3-09-0015 (ML093090165), dated October 30, 2009, the biota dose estimates were based on ESBWR DCD Rev. 5. Based on discussion with NRC staff on November 16, 2009, it was determined that the biota dose estimate needed to be updated to incorporate DCD Rev. 6 information. A supplemental response to ER RAI HH5.4.4-1 was submitted in Detroit Edison letter NRC3-10-0005 (ML100541329), dated February 15, 2010. Subsequently, an additional supplemental response to ER RAI HH5.4.4-1 was submitted in Detroit Edison letter NRC3-10-0015 (ML100960474), dated March 30, 2010, to describe changes made to the biota dose calculation as a result of changes to the long term, routine X/Q and D/Q values.

The gaseous source term presented in DCD Rev. 7 Table 12.2-16 with the radioiodine concentrations in new FSAR Table 12.2-206 and the previously communicated changes to the atmospheric dispersion estimates presented in Detroit Edison Letter NRC3-10-0033 (ML102180224), dated July 25, 2010, were utilized to provide updated estimates for the dose to the MEI, population, and biota.

The estimated total dose to biota from gaseous releases, liquid effluents, and direct radiation for five of the surrogate species are less than exposure criteria in 40 CFR 190 (25 mrem/yr). The estimated total dose for the muskrat and the duck are 25.95 mrem/yr, or slightly greater than the criteria in 40 CFR 190. It is noted, as described in ER Section 5.4.4, that the heron is considered as the representative surrogate for the bald eagle and the estimated total biota dose to the heron is

18 mrem/yr; less than the criteria in 40 CFR 190. The biota dose estimate includes conservatisms in the calculation, most notably, the assumption that the biota is located at the limiting location for both gaseous and liquid releases although these are two distinctly different locations. That is, the contribution from the liquid release is in the vicinity of the discharge pipe to the East of the site in Lake Erie. The contribution from the gaseous release is towards the NNW and NW directions. These two locations were selected to provide a conservative result.

As described in ER Section 5.4.4, using exposure guidelines, such as 40 CFR 190, which apply to members of the public, is considered conservative when evaluating calculated doses to biota. NUREG-1555, Section 5.4.4, "Impacts to Biota Other Than Members of the Public," Section III.(2), second bullet, states:

"If the doses are of approximately the same order of magnitude or less than the dose criteria, in 40 CFR 190, no further review is necessary."

Although the estimated biota dose results for Fermi 3 exceed the dose criteria in 40 CFR 190, the results are approximately the same order of magnitude. Therefore, the results are considered to be acceptable and the impact continues to be SMALL.

Proposed COLA Revision

Proposed revision to ER Section 5.4 is shown on the markup provided with ER RAIs HH5.4.2-1 and HH5.4.3-3 (Attachment 3).