



NOTES:
 1. FOR LEGEND AND ADDITIONAL NOTES SEE M-025
 2. DAMPER HV5709 IS NORMALLY DISABLED IN THE CLOSED POSITION AND THE LOCAL CONTROL SWITCH HV5818 IS ADMINISTRATIVELY CONTROLLED IN THE OFF POSITION (REF. CR 1999-1412).

LR NOTES:
 A. FOR GENERAL LICENSE RENEWAL NOTES REFER TO LR-M001-01

LICENSE RENEWAL BOUNDARY DRAWING
 LR-M026A REV. 0

SYSTEMS SHOWN ON THIS DRAWING:
 14 HVAC

BECHTEL COMPANY
 GAITHERSBURG, MARYLAND

DAVIS-BESSE NUCLEAR POWER STATION
 THE TOLEDO EDISON COMPANY
 THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P 8 10 - HV 8 A/C AIR FLOW DIAGRAM
 TURBINE BUILDING & AUXILIARY
 FEED PUMP ROOM

JOB No.	DRAWING No.	REV.
7749	M-026A	51

AUX. BOILER FORCED DRAFT FAN DRG. MOTOR DRG. AND WINDING TEMPERATURE INSTRUMENTATION SCHEDULE.	COMPUTER ANALOG INPUT	MOTOR F/E BEARING TEMP. DT.	COMPUTER ANALOG INPUT	MOTOR STATOR TEMP.	COMPUTER ANALOG INPUT
C41	TE-2776D TE-2776E	T022(M/E) T026(I/O)	TE-2776C	T023	TE-2776B
				T024	TE-2776A
					T025

01 D 32