



NOTES:  
 1. FOR GENERAL NOTES, SEE DWG. M-037E.  
 2. PIPING DOWNSTREAM OF WC306 IS "ABANDONED IN PLACE". A 1/2" THICK BLANK PLATE INSERTED BETWEEN FLANGES DOWNSTREAM OF WC306 ISOLATES THE PRIMARY WATER STORAGE TANK FROM THE CLEAN WASTE PIPING. REFERENCE MOD 95-0050.

LR NOTES:  
 A. FOR GENERAL LICENSE RENEWAL NOTES REFER TO LR-M001-01.  
 LICENSE RENEWAL BOUNDARY DRAWING  
 LR-M037F REV. 0  
 SYSTEMS SHOWN ON THIS DRAWING:  
 23: SAMPLING  
 24: NONSAFETY AFFECTING SAFETY  
 25: BORON RECOVERY

BECHTEL ASSOCIATES  
 PROFESSIONAL CORPORATION (OHIO)  
 GAITHERSBURG, MARYLAND  
 DAVIS-BESSE NUCLEAR POWER STATION  
 UNIT NO. 1  
 THE TOLEDO EDISON COMPANY  
 PIPING & INSTRUMENT DIAGRAM  
 CLEAN WASTE MONITOR TANKS

JOB NO.	DRAWING NO.	REV.
12501	M-037F	10

THIS DRAWING REV. 0  
 SUPERSEDES IN PART  
 DWG. M-037B REV. 39,  
 WORK THIS DWG. WITH M-037E.

D-60

012960