



HIGHLIGHTING CONTINUED ON LR-M037G

NOTES: (CONT'D)
 6. TUBING CONNECTION TO VALVE DW1641G (ZONE B-14)
 7. SOME VALVES NUMBERED WITH A "PW" DESIGNATION (I.E. PW32) ARE BEING USED TO SUPPLY DEMINERALIZED WATER. REFERENCE MOD 95-0050.

LR NOTES:
 A. FOR GENERAL LICENSE RENEWAL NOTES REFER TO LR-M001-01.
 LICENSE RENEWAL BOUNDARY DRAWING
LR-M037G REV. 1
 SYSTEMS SHOWN ON THIS DRAWING:
 23: SAMPLING
 24: NONSAFETY AFFECTING SAFETY
 25: BORON RECOVERY

DAVIS-BESSE NUCLEAR POWER STATION
 UNIT NO. 1
THE TOLSON EDISON COMPANY

BORIC ACID EVAPORATOR 1-1

DRAWING NO.	REV.
M-037G	12

NOTES:
 1. FOR GENERAL NOTES, SEE DWG. M-037C.
 2. THE BORIC EVAPORATOR PACKAGES ARE LOCATED INSIDE HEATED AREAS.
 3. ALL PIPING AND VALVES WHICH CARRY CONCENTRATED EVAP. BOTTOMS AND WHICH ARE OUTSIDE HEATED AREAS WILL HAVE REDUNDANT HEAT TRACING.
 4. FOR THE BORIC EVAP. PACKAGE PNEUMATIC DETAILS SEE DRAWINGS 154-041-E-001 AND 154-040-E-001. (AMF BEATRD NUMBERS) AND 154-023-E-003.
 5. WHERE NOTED THE TANK CAPACITY IS NOMINAL, WHERE APPLICABLE, SEE DB-PP-08105 (TANK LEVEL CALIBRATION CURVES) FOR INDICATED LEVEL VS. VOLUME RELATIONSHIP. (REF: PCAOR 96-0976).
 (NOTES CONT'D ABOVE @ H-13)

DB 07-30-07 13 DFN: /1/PIDS/M037G.DGN

D-01
 01/261