



- NOTES:**
1. FOR GENERAL NOTES, PIPING SYMBOLS AND P & ID INDEX SEE DWG. M-001.
 2. FOR INSTRUMENTATION SYMBOLS SEE DWG. M-002.
 3. PIPING AND EQUIPMENT TO THE LEFT OF REFERENCES DO NOT SHOW EXACT ARRANGEMENTS. (SEE REFERENCED P & ID'S FOR EXACT DETAILS).
 4. WATER TRAP TO BE WALL MOUNTED SO THAT WATER DRAINS BACK TO THE LINER.
 5. CONTROL LOGIC SHOWN ON PPI DRAWING NO. 32355.
 6. TO SEND RADWASTE TO THE TRUCK FILL STATION, THE FLEXIBLE HOSES WHICH WOULD NORMALLY CONNECT TO THE DISPOSABLE LINER ARE CONNECTED IN THE PIPING RUN TO THE TRUCK FILL STATION.
 7. THE ONLY VENT OR DRAIN LINE CAPS REQUIRED TO BE SHOWN ON PIPING AND INSTRUMENTATION DIAGRAMS ARE THOSE CONTROLLED UNDER DB-0P-0009 (FORMERLY AD1839.03). THE ACTUAL TERMINATION OF ALL OTHER VENTS OR DRAINS ARE NOT SHOWN AND INSTEAD, AN OPEN ENDED PIPE IS DISPLAYED.

LR NOTES:

A. FOR GENERAL LICENSE RENEWAL NOTES REFER TO LR-M001-01.
 B. COMPONENTS BEYOND THE HIGHLIGHTING ARE IN THE CONDENSATE DIMINERIALIZER SYSTEM AND ARE NOT WITHIN THE SCOPE OF LICENSE RENEWAL.
 C. COMPONENTS BEYOND THE HIGHLIGHTING ARE ABANDONED IN PLACE AND ARE NOT WITHIN THE SCOPE OF LICENSE RENEWAL.

LICENSE RENEWAL BOUNDARY DRAWING
LR-M047 REV. 0

SYSTEMS SHOWN ON THIS DRAWING:
 24: NONSAFETY AFFECTING SAFETY

NO.	DATE	REVISIONS	BY	CHK	DESIGN	ENGR.	PROJ. MGR.	OWNER APPR.
30	01/21/00	INC DCN M-047-21 PER ERR 60-0003-062						
29	12/16/99	INC DCN M-047-20 PER MOD 95-0055 SUP. 01						
32	10/26/99	INC DCN M-047-18 PER MOD 95-0055 SUP. 00	SBW					
31	12/6/01	INC. DCN M-047-22 PER DCR 00-0016						
18	11/4/87	ISSUED FOR FCR 87-087 SUPP. 33 "AS-BUILT" INCDRP. DCN M-047-4.	AZ	LEB	PJC	PN	KJT	VM

BECHTEL COMPANY
 GAITHERSBURG, MARYLAND

DAVIS-BESSE NUCLEAR POWER STATION
 THE TOLEDO EDISON COMPANY
 THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

PIPING & INSTRUMENT DIAGRAM
RADWASTE DRUMMING STATION

JOB NO.	DRAWING NO.	REV.
7749	M-047	32

SCALE NONE DESIGNED TO DRAW CAD/AZ

OPN-1:7:P105/M047.DGN 08-01-22-03 14 34X44 C SIZE

D-78
 01/2/78