



AUXILIARY BUILDING DRAINAGE SYSTEM

CTMT. BLDG. DRAINAGE SYSTEM

TURBINE BUILDING DRAINAGE SYSTEM

AUXILIARY BUILDING SANITARY WASTE

TURBINE AND OFFICE BLDGS. SANITARY WASTE

TURBINE AND OFFICE BUILDINGS PART. DRAINAGE SYSTEM

SCHEMATIC OIL INTERCEPTOR SYSTEM

LR NOTES:
 A. FOR GENERAL LICENSE RENEWAL NOTES REFER TO LR-M001-01.
 B. THIS LINE CONTAINS A CHECK VALVE. THE VALVE AND THE PIPING TO THAT VALVE ARE SAFETY-RELATED.
 C. 10 FLOOR DRAINS ARE LOCATED INSIDE THE AUX. BLDG. NEGATIVE PRESSURE AREA AND ARE FITTED WITH SAFETY-RELATED CHECK VALVES (SEE M-172 THRU M-174 FOR LOCATIONS).

GENERAL NOTES

- NUMBERS SHOWN IN PARENTHESES INDICATE COUNT OF EACH ITEM REPRESENTED BY THAT PARTICULAR SYMBOL.
- LIMIT OF PIPING REQUIRING SEISMIC I ANALYSIS
- FLOOR DRAINS IN THE AUX. BLDG. NEGATIVE PRESSURE AREAS SHALL BE FITTED WITH SPRING LOADED WAFER CHECKS.
- SEE DRAWING M-172 FOR COVERED FLOOR DRAINS.

LEGEND
 ▲ = PLUG
 C = CAP

BECHTEL COMPANY
 GAITHERSBURG, MARYLAND

DAVIS-BESSE NUCLEAR POWER STATION
 THE TOLEDO EDISON COMPANY
 THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

SCHEMATIC DIAGRAM
STATION PLUMBING AND DRAINS

JOB NO.	DRAWING NO.	REV.
7749	M-090	4

08/04-14-99

012979

m90.m plotted by rohrbaeher from DINO to Wilma on Wednesday, April 14 1999 - 02:06:15 PM EDT