



HIGHLIGHTING CONTINUED ON LR-M039B

M-281N-13-3

LR NOTES:

- A. FOR GENERAL LICENSE RENEWAL NOTES REFER TO LR-M001-01
- B. COMPONENTS BEYOND THE HIGHLIGHTING ARE AIR LINES THAT DO NOT CONTAIN LIQUID AND ARE NOT WITHIN THE SCOPE OF LICENSE RENEWAL
- C. THE SAMPLE SINK DOES NOT FULFILL A LICENSE RENEWAL FUNCTION SINCE IT IS NOT SAFETY-RELATED, DOES NOT CONTAIN LIQUID FOR LONG DURATIONS, IS NOT A LEAKAGE OR SPRAY CONCERN, AND IS THEREFORE NOT IN SCOPE
- D. COMPONENTS BEYOND THE HIGHLIGHTING ARE TEMPORARILY CONNECTED TO THE SYSTEM AND ARE THEREFORE NOT IN SCOPE

LICENSE RENEWAL BOUNDARY DRAWING LR-M281N13 REV. 1

SYSTEMS SHOWN ON THIS DRAWING: 24: NONSAFETY AFFECTING SAFETY

- NOTES:
1. ALL VALVES PREFIXED DT UNLESS OTHERWISE SPECIFIED.
 2. COMPONENTS REPLACED VIA MOD 96-0034.

**DAVIS-BESSE NUCLEAR POWER STATION
UNIT NO. 1**
THE TOLEDO-EDISON COMPANY

**SYSTEM LINE I.D.
FOR RADWASTE DEMINERALIZER SKID**

DRAWING NO.	REV.
DT-60	T2

THIS DRAWING WAS REDRAWN ON CADD AND SUPERSEDES SUBMITAL 2

012981