

Peter Zarakas
Vice President

Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, NY 10003
Telephone (212) 460-3000

September 24, 1980

Re: Indian Point Unit No. 2
Docket No. 50-247

Director of Nuclear Reactor Regulation
ATTN: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555


Dear Mr. Varga:

Pursuant to paragraph 3.1.B.2 of the Indian Point Unit No. 2 Technical Specifications and Bases (Appendix A to Facility Operating License DPR-26), notification is hereby being made of a planned change in the surveillance specimen removal schedule contained in Item 7.2 of Technical Specification 4.2. The proposed change is consistent with the ASTM National Standard E185-79 recommendation on the removal schedule of surveillance capsules and would provide better data with which to evaluate the effects of radiation on the reactor vessel. The proposed change has also been discussed and agreed to by Mr. Warren Hazelton of the NRC Staff. The revised schedule is as follows:

Capsule 3	Replacement of 5th Region
Capsule 4	Replacement of 8th Region
Capsule 5	Replacement of 16th Region
Capsule 6	Spare

An application for an amendment to the Indian Point Unit No. 2 Technical Specifications to reflect the above surveillance capsule specimen removal schedule will be filed shortly.

Very truly yours,


Peter Zarakas
Vice President

A001
5/10

5009 500481

P