**From:** Kim, James
**Sent:** Monday, September 13, 2010 10:28 AM
**To:** 'Devincentis, James M'
**Cc:** 'Couture III, Philip'
**Subject:** Vermont Yankee Nuclear Power Station – Acceptance of LAR Application for Suppression Chamber-Drywell Vacuum Breakers TS Change No. 289 (TAC NO. ME4554)

SUBJECT: Vermont Yankee Nuclear Power Station – Acceptance of License Amendment Request Application for TS Change No. 289, Suppression Chamber-Drywell Vacuum Breakers (TAC NO. ME4554)

By letter dated August 19, 2010, you submitted a license amendment request to revise the Technical Specifications (TS) to be consistent with Standard Technical Specifications 3.6.1.8 "Suppression Chamber-to-Drywell Vacuum Breakers" and 3.6.2.5 "Drywell-to-Suppression Chamber Differential Pressure," along with the associated Bases, of NUREG-1433, Revision 3, "Standard Technical Specifications General Electric Plants, BWR/4," modified to account for plant specific design details. The purpose of this communication is to provide the results of the NRC staff's acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an amendment to the license (including the technical specifications) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the staff to proceed with its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. If additional information is needed for the staff to complete its technical review, you will be advised by separate correspondence. If you have any questions, please contact me.

**James Kim**
Licensing Project Manager
U. S. NRC, NRR/DORL
301-415-4125(Office)
301-415-2102 (Fax)
James.Kim@nrc.gov

---

## E-mail Properties

Mail Envelope Properties ()

Subject: Vermont Yankee Nuclear Power Station ? Acceptance of LAR Application for Suppression Chamber-Drywell Vacuum Breakers TS Change No. 289 (TAC NO. ME4554)
Sent Date: 09/13/2010 10:17:34 AM
Received Date: 09/13/2010 10:27:00 AM
From: Kim, James

Created By: James.Kim@nrc.gov

Recipients:
jdevinc@entergy.com ('Devincentis, James M')
Tracking Status: None
pcoutur@entergy.com ('Couture III, Philip')
Tracking Status: None

Post Office:

| Files | Size | Date & Time |
|---|---|---|
| MESSAGE | 13661 | 09/13/2010 |

Options
Expiration Date:
Priority: olImportanceNormal
ReplyRequested: False
Return Notification: False

Sensitivity: olNormal
Recipients received: