

2.4.15 Reactor Control, Surveillance, and Limitation System**1.0 Description**

The reactor control, surveillance, and limitation system (RCSL) implements non-safety related automatic and manual control functions, limitation functions, and monitoring functions required to control and limit the reactor core parameters.

2.0 Equipment and System Performance

2.1 The RCSL limits the rod control cluster assembly (RCCA) bank withdrawal rate to a maximum value.

3.0 System Inspections, Tests, Analyses, and Acceptance Criteria

Table 2.4.15-1 lists the RCSL ITAAC.

Table 2.4.15-1—Reactor Control, Surveillance, and Limitation System ITAAC

	Commitment Wording	Inspections, Tests, Analyses	Acceptance Criteria
2.1	The RCSL limits the RCCA bank withdrawal rate to a maximum value.	Tests will be performed to determine the maximum RCCA bank withdrawal rate.	The RCSL limits the RCCA bank withdrawal rate to 30 inches per minute or less.