

4.0 DESIGN FEATURES

4.1 Site Location

[A COL applicant that references the U.S. EPR design certification will provide site-specific information for Section 4.1, Site Location.]

4.2 Reactor Core

4.2.1 Fuel Assemblies

The reactor shall contain 241 fuel assemblies. Each assembly shall consist of a matrix of fuel rods clad with a zirconium based alloy with an initial composition of natural or slightly enriched uranium dioxide (UO₂) as fuel material. Limited substitutions of zirconium alloy or stainless steel filler rods for fuel rods, in accordance with approved applications of fuel rod configurations, may be used. Fuel assemblies shall be limited to those fuel designs that have been analyzed with applicable NRC approved codes and methods and shown by tests or analyses to comply with all fuel safety design bases. A limited number of lead test assemblies that have not completed representative testing may be placed in nonlimiting core regions.

4.2.2 Control Rod Assemblies

The reactor core shall contain 89 control rod assemblies. The control material shall be silver indium cadmium as approved by the NRC.

4.3 Fuel Assembly Storage

4.3.1 Criticality

4.3.1.1 The spent fuel storage racks are designed and shall be maintained with:

- a. Fuel assemblies having a maximum U-235 enrichment of 5.0 weight percent;
- b. $k_{\text{eff}} < 1.0$ if fully flooded with unborated water, which includes an allowance for uncertainties as described in FSAR Section 9.1.1, "Criticality Safety of New and Spent Fuel Storage and Handling";

4.0 DESIGN FEATURES

4.3 Fuel Assembly Storage (continued)

- c. $k_{\text{eff}} \leq 0.95$ if fully flooded with water borated to 582 ppm enriched, which includes an allowance for uncertainties as described in fsar Section 9.1.1, "Criticality Safety of New and Spent Fuel Storage and Handling";
- d. A nominal 11.22 inch center-to-center distance between fuel assemblies placed in Region 1;
- e. A nominal 9.50 inch center-to-center distance between fuel assemblies placed in Region 2; and
- f. Neutron absorber installed between fuel assemblies in the Region 1 and 2 storage racks.

4.3.1.2 The new fuel storage racks are designed and shall be maintained with:

- a. Fuel assemblies having a maximum U-235 enrichment of 5.0 weight percent;
- b. $k_{\text{eff}} \leq 0.95$ if fully flooded with unborated water, which includes an allowance for uncertainties as described in FSAR Section 9.1.1, "Criticality Safety of New and Spent Fuel Storage and Handling";
- c. $k_{\text{eff}} \leq 0.98$ if moderated by aqueous foam, which includes an allowance for uncertainties as described in FSAR Section 9.1.1, "Criticality Safety of New and Spent Fuel Storage and Handling"; and
- d. A nominal 11.22 inch center-to-center distance between fuel assemblies placed in the storage racks.

4.3.2 Drainage

The spent fuel pool is designed and shall be maintained to prevent inadvertent draining of the pool below elevation 23 ft.

4.3.3 Capacity

The spent fuel pool is designed and shall be maintained with a storage capacity limited to no more than 1247 fuel assemblies.
