

Scan Action Limits (ALs): Rock Wool Insulation

Radionuclide	Waste Limit ^a (pCi/g)	Scan Action Level ^b (dpm/100 cm ²)
Cs-137	15.0	1,400
Co-60	5.0	480
Sr-90	1.0	95
Eu-152	1.0	95
Eu-154	1.0	95
Ag-108m	0.1	10

^aValue from Table 1 in PG&E Letter HBL-10-003.

^bValue based on mass-weighted density assuming 98% rock wool insulation and 2% asbestos-cement sheet. Value shown has been rounded down to 2 significant digits.

Relative Fractions^a:

Radionuclide-of-Concern	Average (pCi/g)	Relative Fraction
Cs-137	7.96	0.9583
Co-60	0.35	0.0417

^aBased on positive Cs-137 and Co-60 results for samples collected from Units 1 and 2, as reported in Table 4-7 in *Radiological Characterization Report, Humboldt Bay Power Plant* [ref ____].

The gross activity limit for scans was determined through the application of MARSSIM equation 4-4"

Gross activity scan limit = $1/\Sigma(f_1/\text{limit}_1 + f_2/\text{limit}_2 + \dots f_n/\text{limit}_n)$

For the Cs-Co mix associated with the fuel oil system, the gross activity scan limit is:

Gross activity scan limit = $1/\Sigma(0.9583/1,400 + 0.0417/480) = 1,296 \text{ dpm}/100\text{cm}^2$

Scan ALs: Ventilation

Radionuclide	Waste Limit ^a (pCi/g)	Scan Action Level ^b (dpm/100 cm ²)
Cs-137	15.0	44,600
Co-60	5.0	14,800
Sr-90	1.0	2,900
Eu-152	1.0	2,900
Eu-154	1.0	2,900
Ag-108m	0.1	290

^aValue from Table 1 in PG&E Letter HBL-10-003.

^bValue based on density for aluminum. Value shown has been rounded down to 2 significant digits.

Relative Fractions^a:

Radionuclide-of-Concern	Average (pCi/g)	Relative Fraction
Cs-137	7.96	0.9583
Co-60	0.35	0.0417

^aBased on positive Cs-137 and Co-60 results for samples collected from Units 1 and 2, as reported in Table 4-7 in *Radiological Characterization Report, Humboldt Bay Power Plant* [ref ____].

The gross activity limit for scans was determined through the application of MARSSIM equation 4-4"

$$\text{Gross activity scan limit} = 1/\Sigma(f_1/\text{limit}_1 + f_2/\text{limit}_2 + \dots f_n/\text{limit}_n)$$

For the Cs-Co mix associated with the fuel oil system, the gross activity scan limit is:

$$\text{Gross activity scan limit} = 1/\Sigma(0.9583/44,600 + 0.0417/14,800) = 41,145 \text{ dpm}/100\text{cm}^2$$

Scan ALs: Steel

Radionuclide	Waste Limit ^a (pCi/g)	Scan Action Level ^b (dpm/100 cm ²)
Cs-137	15.0	130,000
Co-60	5.0	44,000
Sr-90	1.0	8,800
Eu-152	1.0	8,800
Eu-154	1.0	8,800
Ag-108m	0.1	880

^aValue from Table 1 in PG&E Letter HBL-10-003.

^bValue based on density of iron. Value shown has been rounded down to 2 significant digits.

Relative Fractions^a:

Radionuclide-of-Concern	Average (pCi/g)	Relative Fraction
Cs-137	7.96	0.9583
Co-60	0.35	0.0417

^aBased on positive Cs-137 and Co-60 results for samples collected from Units 1 and 2, as reported in Table 4-7 in *Radiological Characterization Report, Humboldt Bay Power Plant* [ref ____].

The gross activity limit for scans was determined through the application of MARSSIM equation 4-4"

Gross activity scan limit = $1/\Sigma(f_1/\text{limit}_1 + f_2/\text{limit}_2 + \dots f_n/\text{limit}_n)$

For the Cs-Co mix associated with the fuel oil system, the gross activity scan limit is:

Gross activity scan limit = $1/\Sigma(0.9583/130,000 + 0.0417/44,000) = 120,169 \text{ dpm}/100\text{cm}^2$

Scan ALs: DAW

Radionuclide	Waste Limit ^a (pCi/g)	Scan Action Level ^b (dpm/100 cm ²)
Cs-137	15.0	14,000
Co-60	5.0	4,900
Sr-90	1.0	990
Eu-152	1.0	990
Eu-154	1.0	990
Ag-108m	0.1	90

^aValue from Table 1 in PG&E Letter HBL-10-003.

^bValue based on assigned density equal to 55 lbs per cubic foot (PG&E Letter HBL-10-0030. Value shown has been rounded down to 2 significant digits.

Relative Fractions^a:

Radionuclide-of-Concern	Average (pCi/g)	Relative Fraction
Cs-137	7.96	0.9583
Co-60	0.35	0.0417

^aBased on positive Cs-137 and Co-60 results for samples collected from Units 1 and 2, as reported in Table 4-7 in *Radiological Characterization Report, Humboldt Bay Power Plant* [ref ____].

The gross activity limit for scans was determined through the application of MARSSIM equation 4-4"

Gross activity scan limit = $1/\Sigma(f_1/\text{limit}_1 + f_2/\text{limit}_2 + \dots f_n/\text{limit}_n)$

For the Cs-Co mix associated with the fuel oil system, the gross activity scan limit is:

Gross activity scan limit = $1/\Sigma(0.9583/14,000 + 0.0417/4,900) = 12,990 \text{ dpm}/100\text{cm}^2$



WHERE EVERYTHING COMES TOGETHER

What A Foot Believes

Female Vocal (M People?)


Dance Beat

★ Update Zion Notebooks!

License & TS Pages

Binder Spines (Zion Solutions!)

Visit lagunacliffs.com for your next Southern California experience.





WHERE EVERYTHING COMES TOGETHER

50.65(a)(4) Maint Rule

Fire to be addressed later

Does 50.65(a)(4) apply
to decom reactors?

What is Helon?

\$140 K for 6K #s

Why use Helon?

Visit lagunaciffs.com for your next Southern California experience.


LAGUNA CLIFFS
RESORT & SPA