

NRC Questions from 10/22 (assigned to G. Pugh):

Question #36 (Request Number 42)

NRC Question:

Was the original radial tension stresses due to the hoop stresses considered in the original design?

CR3 Response:

Cannot readily determine from the old Gilbert Calculations what the direct answer is to the request. It appears that the tendon design is based on limiting the concrete tensile stress to 212 psi. This limit bounds the tensile stresses in meridional, and hoop directions. See Book 2, Section 1.01.7, pages 1.01.7/6 and 1.01.7/7 for a brief memorandum outlining the critical loading of the cylindrical RB wall. The tendon pre-stress is designed to limit the tensile stresses in the concrete for the load combinations. It does not appear that the calculations considered the tensile stresses in the concrete outside the tendon's influence.

Copies of calculation pages are included at following drive location:

L:\Shared\2009 NRC SPECIAL INSPECTION TEAM Q-A\WILLIAMS Q-A\Request 42, Q36 Response Info- Pugh

	MADE	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.			
	CHK'D. <i>FKL</i>				
	SO. CP.				
	CP. DFM.				
	ENG.	WORK ORDER	SIZE	DRAWING	REV.
	REV. CH. APP. DATE				

INDEX

FLORIDA POWER CORPORATION

CRYSTAL RIVER UNIT #3

1.01.7 REACTOR BUILDING DESIGN-PRESTRESSING

1:01.7/1 - 1:01.7/56 PRESTRESSING REQUIREMENTS - NO TENDONS ETC.


1:01.7/56 - 1:01.7/59 CHECK PRESCON COMPONENTS + ANCHOR BLOCK REINPT +
DENSITY (ρ) OF PRESTRESS REINPT.

1:01.7A - SH 1 to 11 Tendon Surveillance/Prestress losses

1:01.7A - SH 12 to 17 REVIEW & Design Verification

1.01.7 | 1

READING PERRA		GILBERT ASSOCIATES INC ENGINEERS AND CONSULTANTS				NEW YORK WASHINGTON	
MADE	CHKD	SO	CF	CD	APPD	SIZ	DRAWING NO.
RS	11						
REV.							W.O. 4200-0 DATE 4-29-61



CRYSTAL RIVER
TYPICAL HOOP TENSIONS
IN THE WALL

1.01.7/2

FLORIDA POWER CORPORATION	MADE R.S.	GILBERT ASSOCIATES, INC.		
	CHK'D. E.R.	ENGINEERS AND CONSULTANTS		
CRYSTAL RIVER UNIT #3	SO. CP.	READING, PENNA.		
REACTOR BUILDING	CP. OFN.	4203-00		
SPACING OF VERTICAL TENDON	ENG.	WORK ORDER	SIZE	DRAWING
	WELDED APP. DATE			REV.
	10-15-69			

$$\begin{aligned}
 \text{TOTAL NO OF TENDONS} &= 144 \\
 \text{RADIUS OF } \phi \text{ OF TENDONS} &= 807.375" \\
 \text{SPACING OF TENDON} &= \frac{2 \times \pi \times 807.375}{144} \\
 &= \frac{\pi \times 807.375}{72} \\
 &= 35.23" = 35\frac{1}{4}" \text{ SAY}
 \end{aligned}$$

R. Shan

MEMORANDUM

GILBERT ASSOCIATES, INC.

March 13, 1969

TO: DISTRIBUTION LISTED BELOW

FROM: R. Shammugasundaram

SUBJECT: Crystal River
Reactor Building - Prestress Requirements
GAI-4203

1.01.7/3

VOID

See letter of April 10, 69
for Revised Prestress Requirements

At present prestress for Reactor Building for Met-Ed and Crystal River are designed to take care of the following effects:

1. 1.5 accident pressure.
2. Effects of accident temperature above operating temperature.

During accident condition the liner is heated to in the order of 280° F. whereas concrete is heated to only 110° F. Because of this difference in temperature, the steel liner is trying to expand with reference to concrete. As this movement is restrained the steel liner exerts a pressure on the concrete. Necessary prestress is added to take care of the above effect.

During operating temperature the liner is gradually heated along with the concrete. In order to analyse for this loading condition either one of the following assumptions has to be made.

1. Concrete and liner act as a composite material.
2. Concrete and liner act as two independent materials.

If we consider the first assumption there is only bending stress. Therefore, no prestressing is required.

If we consider the second assumption there are membrane forces (tension) in addition to bending stress. Hence we need additional prestressing.

Additional prestressing required if we consider second assumption.

Vertical Prestressing

Prestressing required without the above additional requirements - 181200 kips

Stress in steel due to operating temperature

$$\begin{aligned} &= \alpha \Delta T E \\ &= 6.5 \times 10^{-6} \times (110-70) \times 30 \times 10^6 \\ &= 6.5 \times 40 \times 30 = 7800 \text{ psi} \end{aligned}$$

DISTRIBUTION LISTED BELOW

-2-

March 13, 1969

1.01.7/A

$$N\phi = 7.8 \times \frac{3}{8} \times 12 \times \pi \times 130$$

$$= 14300 \text{ kips}$$

$$\% \text{ increase} = \frac{14300}{181200} = 8\%$$

Hoop Prestressing

Prostressing required without the above additional requirements = 756^k/ft ht

$$N\phi = 7.8 \times \frac{3}{8} \times 12 = 35^k/\text{ft}$$

$$\% \text{ increase} = \frac{35}{756} = 4.6\%$$

Therefore a decision is to be made about the assumption to be followed in case of operating temperature.

R. Shammugasundaram

R. Shammugasundaram

RS:flg

cc: H. P. Lorenz
S. N. Dobreff
D. A. Godfrey
D. K. Croneberger
K. E. Nodland
W. J. Leininger
D. A. Skilton

CRYSTAL RIVER	MADE R.S.	GILBERT ASSOCIATES, INC.			
	CHK'D. F.K.	ENGINEERS AND CONSULTANTS			
REACTOR BUILDING	BO. CP.	READING, PENNA.			
REVISED PRESTRESS REQUIREMENTS	CP. DFM.	4203-00	10.01.75		
	ENG.	WORK ORDER	SIZE	DRAWING	REV.
	REV. CH. APP. DATE	4-2-69			

PRESTRESS DESIGN REQUIREMENTS AS GIVEN IN THE SPECIFICATIONS

- (1) VERTICAL FORCE OF 45.7 KIPS PER FOOT OF CIRCUMFERENCE AT A RADIUS OF 67'-3"
- (2) HOOP FORCE OF 82.9 KIPS PER FOOT OF VERTICAL HEIGHT AT A RADIUS OF 67'-7". THE HOOP FORCE FOR THE LOWER TEN FEET OF WALL SHALL BE 415 KIPS PER FOOT
- (3) DOME FORCE OF 820 KIPS PER FOOT OF CIRCUMFERENCE AT A RADIUS OF 60'-0"

R. Shan

1.01.7/6

MEMORANDUM

GILBERT ASSOCIATES, INC.

April 10, 1969

TO: DISTRIBUTION LISTED BELOW

FROM: R. Shammugasundaram and W. J. Leininger

SUBJECT: Crystal River and Metropolitan Edison Company
Reactor Building - Revised Final Prestress Requirements
GAI-4203 and GAI-4192

Cylindrical Wall - (R. Shammugasundaram)

The critical loading condition for prestressing in the cylindrical wall is 0.95 dead load + prestressing force + 1.5 accident pressure + 1.5 accident temperature. In calculation, the following are considered:

- (1) As per PSAR a principal tensile stress of $3\sqrt{f'_c} = 3\sqrt{5000} = 212$ psi is allowed. Without exceeding the above value, the following stresses can be allowed.

Tensile stress in meridional direction

$$= \sigma = 200 \text{ psi}$$

Tensile stress in hoop direction

$$= \sigma = \overset{211}{(212)} \text{ psi}$$

Shear stress

$$= Q = \overset{27.4}{(24)} \text{ psi}$$

- (2) Credit is given for 0.95 dead load of the dome only.
- (3) Necessary prestressing force is added to limit the tensile stress caused by 1.5 accident pressure.
- (4) Creep and shrinkage effects in the concrete due to the prestressing force are taken care of by analysing the vessel with the lower 'E' value of 2.5×10^6 .
- (5) During the accident condition the liner is quickly heated to in the order of 280° F. whereas concrete remains at 110° F. Because of this difference in temperature the steel liner is trying to expand with reference to the concrete. As this

1.01.7/7

Distribution Listed Below

-2-

April 10, 1969

movement is restrained the steel liner exerts a pressure which causes tension on the concrete. Necessary prestressing force is added to limit the tensile stress in concrete.

- (6) With the 1.5 accident pressure and the accident temperature, the vessel expands which stretches the prestressing tendons. The stretching of the tendons gives additional prestressing force. Due credit is given for this effect also.

Detailed calculations for prestress requirements in the cylindrical wall are enclosed.

Dome - (W. J. Leininger)

The criteria for the design of prestress in the dome is the same as the criteria for the cylindrical wall except as noted.

- (1) The allowable principle tensile stress in the concrete is 212 psi. But, because one prestressing system provides the required prestressing force in both the hoop and meridional directions, the tensile stress in the meridional direction is dependent upon the tensile stress in the hoop direction which controls the design. The tensile stresses are as follows:

Tensile stress in the meridional direction

$$= \sigma_{\theta} = 56 \text{ psi}$$

Tensile stress in the hoop direction

$$= \sigma_{\theta} = 205 \text{ psi}$$

Shear stress

$$= Q = 16 \text{ psi}$$

- (2) Credit is given for the dead load stress at the point under consideration.

Calculations to determine the required prestressing force are enclosed.

W. J. Leininger
W. J. Leininger

R. Shanmugasundaram
R. Shanmugasundaram

flg

Distribution

H. F. Lorenz
D. K. Croneberger
S. N. Dobreff
D. A. Godfrey

K. E. Nodland
W. J. Leininger
R. Shanmugasundaram
D. A. Skilton

PRESTRESS CALCULATIONS FOR CYLINDRICAL WALL OF THE REACTOR BUILDING	MADE	RS	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D.	FR.			
	SO. CP.				
	CP. DFN.				1.01.11.18
	ENG.		WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE				

PRESTRESS REQUIREMENT IN MERIDIONAL DIRECTION
IN WALL

THE FOLLOWING ARE TABULATED
AS STRESSES IN TYPICAL WALL FOR THE LOADING
CONDITION OF 0.95 D.L. + PRESTRESSING + 1.5 ACCIDENT
PRESSURE + 1.5 ACCIDENT TEMPERATURE WITH THE
EXCEPTIONS AS NOTED.

LOADING	STRESS IN STEEL LINER PSI	CONCRETE STRESS PSI
0.95 DEADLOAD	704.5	55.8
OPERATING TEMPERATURE	0.0	0.0
PRESTRESS	11353.5	765.6
P 82.5	6653.1	703.3
ACCIDENT TEMPERATURE	20720.0	185.0

0.95 DEAD LOAD STRESS IS DUE TO THE
WEIGHT OF THE DOME ONLY.

OPERATING DURING SUMMER CONDITION THE
TEMPERATURE GRADIENT IS VERY SMALL.

THEREFORE IT IS CONSERVATIVE TO NEGLECT
THIS EFFECT FOR COMPUTING PRESTRESS
REQUIREMENTS.

YIELD STRENGTH OF THE LINER PLATE
IS 30,000 PSI. ASSUME 2.0% INCREASE
HENCE ASSUMED YIELD STRENGTH OF THE LINER PLATE
IS $30,000 \times 1.2 = 36,000$ PSI

	MADE	R.S.	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.			
	CHK'D.	F.P.				
	BQ. CF.					
	CP. DFM.					
	ENG.		1.01.79			
	REV. CH. APP. DATE		WORK ORDER	SIZE	DRAWING	REV.

THE FOLLOWING TWO CONDITIONS ARE TO BE SATISFIED.

(1) WE HAVE TO CONSIDER THE LINER STRESS UP TO THE YIELD POINT STRESS OF 36,000 PSI ONLY. BEYOND THIS POINT, THE LINER WILL BE IN THE PLASTIC REGION AND DOES NOT GET INTO THE STRAIN-HARDENING REGION FOR ANY LOADING COMBINATION. THEREFORE THE LINER WILL NOT TRANSMIT ANY FORCE BEYOND THE YIELD POINT.

(2) WE HAVE TO LIMIT THE FINAL TENSILE STRESS IN THE CONCRETE TO 200 PSI.

LET $\sigma_{cs}(P.S.)$ = REVISED STRESS IN THE CONCRETE/STEEL DUE TO PRESTRESSING

$\sigma_{cs}(A.T.)$ = REVISED STRESS IN THE CONCRETE/STEEL DUE TO ACCIDENT TEMPERATURE

$\sigma_{cs}(P82.5)$ = STRESS IN THE CONCRETE/STEEL DUE TO 1.5 ACCIDENT PRESSURE

$\sigma_{cs}(D.L.)$ = STRESS IN THE CONCRETE/STEEL DUE TO DEAD LOAD

$$\sigma_s(A.T.) = 36000 - \sigma_{s(D.L.)} + \sigma_{s(P82.5)} - 11353.5 \sigma_{cs(P.S.)} - 765.6$$

$$\begin{aligned} \sigma_{cs}(A.T.) &= \sigma_{s(A.T.)} \times \frac{1.85.0}{20720.0} \\ &= \left[36000 - \sigma_{s(D.L.)} + \sigma_{s(P82.5)} - \frac{11353.5 \times \sigma_{cs(P.S.)} \times 1.85}{765.6} \right] \frac{1.85}{20720.0} \\ &= \frac{(36000 - 704.5 + 6653.1 - 14.85 \sigma_{cs(P.S.)}) \times 1.85}{20720.0} \end{aligned}$$

$$\sigma_{cs(A.T.)} = \frac{(41948.6 - 14.85 \sigma_{cs(P.S.)}) \times 1.85.0}{20720.0} \quad \text{--- (1)}$$

1.01.7/10

	MADE	R.S.	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHECKED	F.R.			
	NO. OF				
	CF. OF				
	ENCL.		WORK ORDER	SIZE	DRAWING
REV. CH. APP. DATE					

$$\sigma_{c(AT)} + \sigma_{c(PB2.5)} - \sigma_{c(D.L)} - \sigma_{c(P.S)} = 200 \quad (2)$$

SUBSTITUTE FROM EQN (1) FOR $\sigma_{c(AT)}$

$$(41948.6 - 14.85 \sigma_{c(P.S)}) 185.0 + 703.3 - 55.8 \sigma_{c(P.S)} = 200$$

$$41948.6 - 14.85 \sigma_{c(P.S)} + 647.5 - \sigma_{c(P.S)} = 200$$

112

$$41948.6 - 14.85 \sigma_{c(P.S)} + 72500.0 - 112 \sigma_{c(P.S)} = 22,400$$

$$-126.85 \sigma_{c(P.S)} = 92048.6$$

$$\sigma_{c(P.S)} = \frac{92048.6}{-126.85} = -728 \text{ PSI}$$

$$\sigma_{s(P.S)} = \frac{728 \times 11.353.5}{765.6} = 10790 \text{ PSI}$$

$$\sigma_{s(AT)} = 36000 - \sigma_{s(D.L)} + \sigma_{s(PB2.5)} - 11.353.5 \times \sigma_{c(P.S)}$$

$$= 36000 - 704.5 + 6653.1 - 11.353.5 \times 728$$

$$= 36000 - 704.5 + 6653.1 - 10790.0$$

$$= 42653.1 - 11494.5$$

$$= 31158.6 \text{ PSI}$$

$$\sigma_{c(AT)} = 200 - \sigma_{c(PB2.5)} + \sigma_{c(D.L)} + \sigma_{c(P.S)}$$

$$= 200 - 703.3 + 55.8 + 728.0$$

$$= 280.5 \text{ PSI}$$

$$\text{FORCE PRESTRESS REQD} = 10790 \times \frac{3}{8} + 728 \times 42$$

$$= 4050 + 30500$$

$$= 34,550 \text{ #/IN}$$

$$= 34.55 \text{ KIPS/IN}$$

$$= 414.6 \text{ KIPS/FT}$$

0.95 DL + Prestress + 1.5 acc. pressure + 1.5 acc. temp.

	Concrete	Steel
0.95 DL	-704	-55.8 comp.
op temp	0	0
prestress	-11,354	-766 comp
pressure	6653	703
acc temp.	-20720	+185

YS Limit
= 26000 psi

$\sigma_c/s(p.s.)$ = Residual stress in the concrete/steel due to prestress

$\sigma_c/s(\Delta T)$ = " " " " " " due to acc. temp

$\sigma_c/s(pres)$ = " " " " " " 1.5 acc pres

$\sigma_c/s(D.L.)$ = " " " " " " Dead load

Subst

$$\sigma_s(\Delta T) = 26000 - \sigma_s(D.L.) + \sigma_s(pres) - \left(\frac{\sigma_s(p.s.) \cdot \sigma_c(p.s.)}{\sigma_c(p.s.)} \right) \quad \frac{11354}{766} \sigma_c(p.s.)$$

$$\sigma_c(\Delta T) = \sigma_s(\Delta T) \times \frac{\sigma_c(\Delta T)}{\sigma_s(\Delta T)} = \sigma_s(\Delta T) \times \frac{185}{20720}$$

$$\therefore \sigma_c(\Delta T) = (419486 - 14.85 \sigma_c(p.s.)) \frac{185}{20720} \quad (1)$$

$\sigma_c(\Delta T)$
 $\sigma_c(pres)$
 $\sigma_c(D.L.)$
 $\sigma_c(p.s.)$

$$\text{AND: } \sigma_c(\Delta T) + \sigma_c(pres) - \sigma_c(D.L.) - \sigma_c(p.s.) = 200 \text{ (Tension)} \quad (2)$$

1.01.7/10a

1.01.7/11

	MADE R.S.	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHE'D. <i>FL</i>			
	SO. CP.			
	CP. DPH.			
	ENG.	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE			REV.

REVISED STRESSES

LOADING CONDITION	STEEL LINER PSI	CONCRETE STRESS PSI
0.95 READ LOAD	- 704.5	- 55.8
OPERATING TEMPERATURE	0.0	0.0
PRESTRESS	- 10790.0	- 728.0
P82.5	6653.1	703.3
ACCIDENT TEMPERATURE	- 31,158.6	280.5
	- 36,000.0	200.0

NUMBER OF TENDONS REQUIRED

THE FOLLOWING 2 TYPES ARE CONSIDERED.

TYPE I 163 - 0.276" ϕ WIRE

f_s = ULTIMATE STRENGTH OF PRESTRESSING
STEEL = 240 KSI

RELAXATION OF STEEL STRESS = 12% OF $0.6f_s$
(DOMESTIC STRESS RELIEVED WIRE)

TYPE II 163 - 0.276" ϕ WIRE

f_s = 235 KSI

RELAXATION OF STEEL STRESS = 4% OF $0.6f_s$
(FOREIGN STABILIZED WIRE)

TYPE I

FORCE PRESTRESS, REQD. AT 67'-3" RADIUS

FORCE = 414.6 K/FT

TOTAL PRESTRESS, REQD. = $414.6 \times 2 \times \pi \times 67.25$
= 175,200 KIPS

1.01.7/12

	MADE	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.			
	CHK'D. <i>FV</i>				
	SG. CP.				
	CP. DPM.				-5
	ENG.	WORK ORDER	SIZE	DRAWING	REV.
	REV. CH. APP. DATE				

LOSSES:

$$\text{CREEP} = 200 \times 10^{-6} \times 29 \times 10^6$$

$$= 5.8 \text{ KSI}$$

$$\text{SHRINKAGE} = 1.20 \times 10^{-6} \times 29 \times 10^6$$

$$= 3.48 \text{ KSI}$$

$$1.2\% \text{ RELAXATION} = 0.12 \times 0.6 \times 240$$

$$= 17.28 \text{ KSI}$$

ELASTIC SHORTENING

$$= \frac{1}{2} \times \frac{414.6 \times 29 \times 10^6}{42 \times 12 \times 4.08 \times 10^6}$$

$$= \frac{207.3 \times 29}{504 \times 4.08}$$

$$= 2.92 \text{ KSI}$$

$$\text{TOTAL LOSSES} = 5.8 + 3.48 + 17.28 + 2.92$$

INITIAL

$$= 29.48 \text{ KSI} \leftarrow$$

$$\text{EFFECTIVE PRESTRESS} = 168 - 29.48 = 138.52 \text{ KSI} < 0.6 f_s$$

A CREDIT FOR EXPANSION OF THE WIRES

$$= 0.6 \times 240$$

$$= 983.8 \times \frac{29 \times 10^6}{4.08 \times 10^6} \text{ PSI} = 144 \text{ KSI}$$

$$= 6.98 \text{ KSI}$$

$$\text{ANCHOR STRESS} = 0.7 \times 240$$

$$= 168 \text{ KSI}$$

$$\text{FINAL EFFECTIVE PRESTRESS} = 138.52 + 6.98$$

$$= 145.5 \text{ KSI} < 0.7 f_s = 168 \text{ KSI}$$

$$\text{AREA OF } 163 - 0.276" \phi \text{ WIRE} = 163 \times 0.597$$

$$= 9.73 \text{ in}^2$$

1.01.7/13

	MADE	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.			
	CHK'D. P.P.				
	SO. CP.				
	CP. DEF.				
	END.	WORK ORDER	SIZE	DRAWING	REV. 6
	REV. CH. APP. DATE				

$$\text{FORCE / TENDON} = 145.5 \times 9.73 \times 0.95$$

WITH ϕ FACTOR OF 0.95

$$= 1348 \text{ KIPS}$$

$$\text{NO. OF TENDONS REQD} = \frac{175,200}{1348} = 130 \leftarrow$$

TYPE II

LOSSES

$$\text{CREEP} = 5.8 \text{ KSI}$$

$$\text{SHRINKAGE} = 3.48 \text{ KSI}$$

$$\text{ELASTIC SHORTENING} = 2.92 \text{ KSI}$$

$$4\% \text{ RELAXATION} = 0.04 \times 0.6 \times 235$$

$$= 5.64 \text{ KSI}$$

$$\text{TOTAL LOSSES} = 17.84 \text{ KSI}$$

$$\text{ANCHOR STRESS} = 0.7 f'_s = 0.7 \times 235$$

$$\text{PRE} = 164.5 \text{ KSI}$$

$$\text{INITIAL EFFECTIVE STRESS} = 164.5 - 17.84$$

$$= 146.66 > 0.6 f'_s = 141 \text{ KSI}$$

$$= 141.0 \text{ KSI}$$

CREDIT FOR EXPANSION OF THE WIRES

$$\text{PRE} = 6.98 \text{ KSI}$$

$$\text{FINAL EFFECTIVE STRESS} = 141.0 + 6.98$$

$$= 147.98 \text{ KSI}$$

$$\text{AREA OF } 163 - 0.276" \phi \text{ WIRE} = 9.73 \text{ in}^2$$

$$\text{FORCE / TENDON WITH } \phi \text{ FACTOR OF } 0.95 = 147.98 \times 9.73 \times 0.95$$

$$= 1368 \text{ KIPS}$$

$$\text{NO. OF TENDONS REQD} = \frac{175,200}{1368} = 128.0 \leftarrow$$

NOTE: - TENDON REQUIREMENTS DO NOT CHANGE UNTIL 8% RELAXATION LOSSES.

1.01.7/14

CRYSTAL RIVER	MADE R.S.	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D. <i>FP</i>			
REACTOR BUILDING	EQ. CP.			
REVISED PRESTRESS REQUIREMENTS	CP. DFM.	4203-00	-7-	
	ENG.	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE	3-28-69		

PRESTRESS REQUIREMENTS IN HOOP DIRECTION

THE FOLLOWING ARE TABULATED AS STRESSES IN TYPICAL WALL.
LOADING CONDITION 0.95 D.L. + 1.5P + 1.0T
STEEL LINER CONCRETE

0.95 D.L.	0	0
OPERATING TEMP.	0	0
PRESTRESS	-17955.0	-1365.1
PRESSURE	11623.0	1424.3
ACC. TEMP.	-21800.0	194.5

REVISED STRESS IN CONCRETE DUE TO ACC. TEMPERATURE

$$= \sigma_{EAT} = \frac{36000 + \sigma_s(PBS) - 17955 \cdot \sigma_c(P.S)}{1365.1} + 194.5$$

$$= \frac{21800}{112}$$

WHERE $\sigma_c(P.S.)$ = STRESS IN CONCRETE DUE TO PRESTRESSING

$$\sigma_{EAT} = \frac{36000 + 11623.0 - 13.15 \cdot \sigma_c(P.S)}{112}$$

$$= \frac{47623.0 - 13.15 \cdot \sigma_{cps}}{112}$$

$$= 425 - 0.1175 \cdot \sigma_{cps}$$

$$\sigma_{EAT} + 0.1175 \cdot \sigma_{cps} = 425 \quad (1)$$

$$\sigma_{EAT} + \sigma_c(PBS) - \sigma_{cps} = \sqrt[3]{\frac{1}{5000}} = 212 \quad (2)$$

$$\sigma_{EAT} - \sigma_{cps} = 212 - 1424.3 = -1212.3$$

$$\sigma_{EAT} - \sigma_{cps} = -1212.3 \quad (2)$$

1.01.7/15

CRYSTAL RIVER	MADE RS	GILBERT ASSOCIATES, INC.		
	CHK'D. P.	ENGINEERS AND CONSULTANTS		
REACTOR BUILDING	SQ. CP.	READING, PENNA.		
REVISED PRESTRESS REQUIREMENTS	CP. DPH.	4203.00	-8-	
	ENG.	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE	3.28-69		

SUBTRACT ② FROM ①

$$1. 11.75 \sigma_{cps} = 1637.3 \quad 1638.3$$

$$\sigma_{cps} = \frac{1637.3}{1.1175} = \frac{1638.3}{1.1175}$$

$$= 1465 \text{ PSI}$$

$$\therefore \sigma_{cat} = 1465 - 1212.3 = 252.7 \text{ PSI}$$

$$\sigma_{sp} = 1.7955 \times 1465.0 = 19300 \text{ PSI}$$

REVISED STRESSES

	STEEL LINER	CONCRETE
0.95 D.	0	0
OPERATING TEMP	0	0
PRESTRESS	-19300	-1465
PRESSURE	11623	424.3
ACC. TEMP	-28323	251.7
	-36000	211.2
		212.0

$$\text{NO. REQD FOR PRESTRESSING} = 19300 \times \frac{3}{8} + 1465 \times 42$$

$$= 7240 + 61500$$

$$= 68740.4 \text{ /IN.}$$

$$= 68.74 \text{ KIPS /IN.}$$

$$= 824.88 \text{ KIPS /ET.} \leftarrow$$

1.01.7/16

	MADE	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D. <i>FR.</i>			
	SQ. CF.			-9-
	CF. DFM.			
	ENG.	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE			REV.

NO OF TENDONS REQUIRED IN HOOP DIRECTION.

$$\begin{aligned} \text{REQD PRESTRESSING FORCE FOR TOP 147'-0"} \\ &= 824.88 \times 147 \\ &= 121,000 \text{ KIPS} \end{aligned}$$

$$\begin{aligned} \text{REQD PRESTRESSING FORCE IN THE HAUNCH} &= \frac{824.88 \times 10}{2} \\ &= 4124.4 \text{ KIPS} \end{aligned}$$

TYPE I TOTAL = 125124.4 KIPS.

LOSSES

$$\text{CREEP} = 300 \times 10^{-6} \times 29 \times 10^6 = 8.7 \text{ KSI}$$

$$\text{SHRINKAGE} = 120 \times 10^{-6} \times 29 \times 10^6 = 3.48 \text{ KSI}$$

$$12\% \text{ RELAXATION} = 0.12 \times 0.6 \times 240 = 17.28 \text{ KSI}$$

$$\begin{aligned} \text{ELASTIC SHORTENING} &= \frac{1}{2} \times \frac{824.88 \times 29.0 \times 10^6}{42 \times 12 \times 4.08 \times 10^6} \\ &= \frac{412.44 \times 29.0 \times 10^6}{504 \times 4.08 \times 10^6} \end{aligned}$$

$$= 5.8 \text{ KSI}$$

$$\text{TOTAL LOSSES} = 8.7 + 3.48 + 17.28 + 5.8$$

$$= 35.26 \text{ KSI}$$

FRICTION LOSSES AS PER ACI 318-63-2607

$$T_o = T_x e^{(KL + k\alpha)}$$

$$k = 0.16$$

$$K = 0.0003$$

$$L = 70.75'$$

$$\alpha = 54.9^\circ \text{ OR } 0.96 \text{ RADIANS}$$

$$0.7f'_s = 0.7 \times 240 = 168.0 \text{ KSI}$$

$$0.8f'_s = 0.8 \times 240 = 192.0 \text{ KSI}$$

1.01.7/17

	MADE	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.			
	CHK'D. <i>FP</i>				
	SQ. CP.				
	CP. DPN.				
	ENG.				WORK ORDER
	REV. CH. APP. DATE				

$$\begin{aligned}
 192.0 &= T_x e (0.0003 \times 70.75 + 0.16 \times 0.96) \\
 &= T_x e (0.021 + 0.153) \\
 &= T_x e (0.174) \\
 &= T_x 1.19
 \end{aligned}$$

$$T_x = 192 / 1.19 = 161.0 \text{ KSI}$$

THE TENDON ABOVE AND BELOW IS CONSIDERED TO BE AT 168.0 KSI

$$\begin{aligned}
 \therefore \text{USE AV. VALUE} &= \frac{168.0 + 161.0}{2} \\
 &= 164.5 \text{ KSI}
 \end{aligned}$$

$$\begin{aligned}
 \text{INITIAL EFFECTIVE PRESTRESS} &= 164.5 - 35.26 \\
 &= 129.24 \text{ KSI}
 \end{aligned}$$

$$\begin{aligned}
 \text{CREDIT FOR EXPANSION OF THE WIRES} &= \frac{1.677 \times 29 \times 10^{-6}}{4.08 \times 10^{-6}} \\
 &= 11.9 \text{ KSI}
 \end{aligned}$$

$$\begin{aligned}
 \text{FINAL EFFECTIVE PRESTRESS} &= 129.24 + 11.9 \\
 &= 141.14 \text{ KSI}
 \end{aligned}$$

$$\begin{aligned}
 \text{AREA OF } 163 - 0.276" \phi \text{ WIRE} &= 163 \times 0.0597 \\
 &= 9.73 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 \text{FORCE/TENDON WITH } \phi \text{ FACTOR OF } 0.95 &= 141.14 \times 9.73 \times 0.95 \\
 &= 1305 \text{ KIPS}
 \end{aligned}$$

$$\begin{aligned}
 \text{NO OF TENDONS REQD} &= \frac{12512.4}{1305} \\
 &= 9.6
 \end{aligned}$$

$$\begin{aligned}
 \text{TOTAL NO OF TENDONS REQD.} &= 3 \times 9.6 \\
 &= 28.8
 \end{aligned}$$

1.01.7/18

	MADE	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D. ☒			
	DD. CP.			
	CP. DPN.			11
	ENG.	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE			

TYPE IILOSSES

$$\text{CREEP} = 8.7 \text{ KSI}$$

$$\text{SHRINKAGE} = 3.48 \text{ KSI}$$

$$4\% \text{ RELAXATION} = 0.04 \times 0.6 \times 235$$

$$= 5.64 \text{ KSI}$$

$$\text{ELASTIC SHORTENING} = 5.8 \text{ KSI}$$

$$\text{TOTAL LOSSES} = 23.62 \text{ KSI}$$

$$0.7 f_s' = 0.7 \times 235 = 164.5 \text{ KSI}$$

$$0.8 f_s' = 0.8 \times 235 = 188.0 \text{ KSI}$$

$$T_x = \frac{188.0}{1.19} = 158 \text{ KSI}$$

THE TENDON ABOVE AND BELOW IS CONSIDERED
TO BE AT 164.5 KSI

$$\therefore \text{USE AV. VALUE} = \frac{158 + 164.5}{2} = 161.25 \text{ KSI}$$

$$\text{INITIAL EFFECTIVE PRESTRESS} = 161.25 - 23.62 = 137.63 \text{ KSI}$$

CREDIT FOR EXPANSION OF THE WIRES

$$= 11.9 \text{ KSI}$$

$$\text{FINAL EFFECTIVE PRESTRESS} = 137.63 + 11.9$$

$$= 149.53 \text{ KSI}$$

$$\text{FORCE/TENDON WITH } \phi \text{ FACTOR OF } 0.95 = 149.53 \times 9.73 \times 0.95 = 1381 \text{ KIPS}$$

$$\text{NO OF TENDONS REQD} = \frac{12512.44}{1381} = 91$$

$$\text{TOTAL NO OF TENDONS REQD} = 91 \times 3 = 273$$


1.01.7/19

CRYSTAL RIVER	MADE	R.S.	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D.	FR.			
REACTOR BUILDING	BO. CP.		4203-00		-17-
	CP. OFN.				
	ENG.		WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE		4-21-69		

TO FIND ALLOWABLE TENSILE STRESSES
IN THE HOOP AND MERIDIONAL DIRECTION

THE CRITICAL LOADING CONDITION FOR
PRESTRESSING IN THE CYLINDRICAL WALL IS
0.95 D.L. + PRESTRESSING FORCE + 1.5 ACCIDENT
PRESSURE + TEMPERATURE ASSOCIATED WITH 1.5 ACCIDENT
PRESSURE.

THE CRITICAL LOCATION FOR DESIGN
CONSIDERATION IS AT TOP OF THE WALL.



SHEAR AT TOP OF THE WALL

0.95 DEAD LOAD = +210.3 # (CRYSTAL RIVER
OPERATING TEMP. = +518.1 # (OUTPUT)

PRESTRESSING = +4464.7 # (MET. ED)

1.5 ACC. PRESSURE = -5710.7 # ()

ACC. TEMPERATURE } -7.4.5 X 2805 = -112.0 # ()
ASSOCIATED WITH } 185
1.5 ACC. PRESSURE }

1.01.7/20


CRYSTAL RIVER	MADE R.S.	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D. F.V.			
REACTOR BUILDING	SQ. CP.	4203-00	16	
	CP. DPH.			
	ENG.	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE	4-21-69		

IT IS CONSERVATIVE TO NEGLECT THE SHEAR DUE TO OPERATING TEMPERATURE

$$\therefore \text{NET SHEAR} = 210.3 + 4464.7 - 5260.7 - 112.0$$

$$= 1147.7 \text{ \# / IN}$$

$$\text{SHEAR STRESS} = \frac{1147.7}{4.2} = 27.4 \text{ PSI}$$



THE VALUES OF THE THREE PRINCIPAL STRESSES ARE THE THREE ROOTS OF THE FOLLOWING CUBIC EQUATION

$$S^3 - (S_x + S_y + S_z) S^2 + (S_x S_y + S_y S_z + S_z S_x - S_{xy}^2 - S_{yz}^2 - S_{zx}^2) S - (S_x S_y S_z + 2 S_{xy} S_{yz} S_{zx} - S_x S_{yz}^2 - S_y S_{zx}^2 - S_z S_{xy}^2) = 0$$

GIVEN:

- $S = 212 \text{ PSI}$
- $S_x = 211 \text{ PSI}$
- $S_z = ?$
- $Q = 27.4 \text{ PSI}$

1.01.7/21

CRYSTAL RIVER	MADE R.S.	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D. <i>CP</i>			
REACTOR BUILDING	BQ. CP.	4203-00	-19-	REV.
	CP. DFM.			
	ENG.	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE	4-21-69		

$$S^3 - (S_x + S_z)S^2 + (S_z S_x - S_y^2)S + S_x S_y^2 = 0$$

$$212^3 - (211 + S_z)212^2 + (211 S_z - 27.4^2)212 + 211 \times 27.4^2 = 0$$

$$212^3 - 211 \times 212^2 - 212^2 \times S_z + 211 \times 212 S_z - 27.4^2 \times 212 + 211 \times 27.4^2 = 0$$

DIVIDE BY 212

$$212^2 - 211 \times 212 - 212 \times S_z + 211 S_z - 27.4^2 + 750 = 0$$

$$44,944 - 44,732 - S_z - 751 + 750 = 0$$

$$S_z = 211 \text{ PSI}$$



CRYSTAL RIVER

1.01.7/22

20-

REACTOR BUILDING

STRESS ANALYSIS




(a)

$$N_\phi = 211 \text{ PSI}$$

$$N_\phi = 211 \text{ PSI}$$

$$Q = 27.4 \text{ PSI}$$



(b)

1.01.7/23

-21-

(a) PRINCIPAL STRESS = 211 PSI

(b) PRINCIPAL STRESS

$$\sigma_2 = \frac{\sigma_x + \sigma_y}{2} + \sqrt{\left(\frac{\sigma_x - \sigma_y}{2}\right)^2 + \tau^2}$$

$$\sigma_2 = \frac{211}{2} + \sqrt{\left(\frac{-211}{2}\right)^2 + 274^2}$$

$$= 105.5 + \sqrt{105.5^2 + 274^2}$$

$$= 105.5 + \sqrt{11,100 + 75,076}$$

$$= 105.5 + 108.5$$

$$= 214.0 \text{ PSI} \rightarrow$$

2nd TRIAL

1.01.7/2A

~~-22-~~

$$N_p = 200 \text{ PSI}$$

$$N_o = 211 \text{ PSI}$$

$$Q = 27.4 \text{ PSI}$$

(a)

$$\begin{aligned}\sigma_1 &= \frac{211 + 200}{2} + \sqrt{\left(\frac{211 - 200}{2}\right)^2 + 0} \\ &= 205.5 + 5.5 \\ &= \underline{\underline{211 \text{ PSI}}} \quad \leftarrow\end{aligned}$$

$$\begin{aligned}(b) \sigma_1 &= \frac{200}{2} + \sqrt{\left(\frac{200}{2}\right)^2 + 27.4^2} \\ &= 100 + \sqrt{10000 + 750} \\ &= 100 + \sqrt{10750} \\ &= 100 + 103.7 \\ &= \underline{\underline{203.7 \text{ PSI}}} \quad \leftarrow\end{aligned}$$

1.01.7/25
SCHUPACK & ASSOCIATES
CONSULTING ENGINEERS

APPENDIX 5J

REPORT ON
RECOMMENDED CONCRETE CREEP AND SHRINKAGE VALUES
FOR COMPUTING PRESTRESSING LOSSES

12/15/75
UP TO DATE
6-13-77

Prepared for: Jersey Central Power & Light Co.
Parsippany, New Jersey

Prepared by: Schupack and Associates
Consulting Engineers
Stamford, Connecticut

Dated: June 1968

Project No. (67-535)

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1. SUMMARY	5J-1
2. INTRODUCTION	5J-2
3. PURPOSE OF REPORT	5J-2
4. NATURE OF SHRINKAGE AND CREEP	5J-3
4.1 Shrinkage	5J-3
4.2 Creep	5J-3
4.2.1 Evaluation of Creep	5J-4
5. REVIEW OF LITERATURE AND TEST DATA	5J-5
5.1 Shrinkage and Creep Research in General	5J-5
5.2 Research and Test Data on Influence of Size and Shape	5J-7
5.2.1 Shrinkage	5J-7
5.2.2 Creep	5J-8
5.2.3 Research on Basic Creep	5J-9
5.2.4 Effects of Bi-axial Stressing	5J-10
6. CORRELATION WITH FULL SCALE TESTS	5J-10
7. CONCLUSIONS	5J-11
8. RECOMMENDATIONS	5J-12
REFERENCES	5J-13
APPENDIX A - C	5J-14

1. SUMMARY

Grouted tendons have been selected for the containment structure at Oyster Creek Nuclear Station - Unit 2. The purpose of this report is to estimate prestress losses for these tendons due to concrete shrinkage and creep over a 50-year period at an average temperature of $85^{\circ}\text{F} \pm 10\%$.

Deformational behavior of controlled concrete similar to this structure is shown to be predictable on the basis of test data on basic creep and shrinkage, and correlation with observations on actual full size beams. For the volume/surface ratio of the concrete in this structure, basic creep is the dominating deformational component and depends primarily on the concrete's specific strength and age at loading. Shrinkage strain is shown to be approximately equal to the lower limit of possible accuracy in estimating total long-term losses.

A uni-axial creep strain of 0.40×10^{-6} inch/inch per psi, and a final shrinkage of 0.0001 inch/inch are recommended for the concrete specified for this structure.

1.01.7/28

SCHUPACK & ASSOCIATES
CONSULTING ENGINEERS

2. INTRODUCTION

The force initially imparted to prestressing tendons decreases — asymptotically with time due to:

- A. Shrinkage of concrete
- B. Creep of concrete
- C. Relaxation of prestressing steel

Grouted tendons have been selected for the containment structure in the Jersey Central Power and Light Company project. This requires a conservative evaluation of the total losses in prestressing force over a 50-year period in order to ensure the structure's satisfactory function during its entire service life.

3. PURPOSE OF REPORT

It is the object of this report to recommend a conservative estimate of probable shrinkage and creep of concrete in this structure. The evaluation applies specifically to:

- A. Steel inside-lined dome and walls with concrete 36" - 42" thick.
- B. Concrete with approximately 5,000 psi strength and of normal workability (i.e., six to seven sacks cement per cubic yard, approximately 1" to 4" slump and such normal aggregate that the concrete's modulus of elasticity is approximately equal to the ACI formula).
- C. Average ambient temperature $85^{\circ}\text{F} \pm 10\%$
- D. Bi-axial compression less than 50% of f'_c

1.01.7/29

SCHUPACK & ASSOCIATES
CONSULTING ENGINEERS

4. NATURE OF SHRINKAGE AND CREEP

4.1 Shrinkage

Shrinkage is the deformation of concrete due to other physical or chemical causes than applied load and temperature dependent volumetric changes. (i.e., variation in moisture content and hydration of cement). Shrinkage strain is time dependent and influenced by the following factors:

A. Internal properties of the concrete, as affected by:

1. Cement quality
2. Water cement ratio
3. Proportion cement-aggregate
4. Aggregate properties (expansive or permeable aggregate)
5. Admixtures
6. Degree of compaction
7. Reinforcement percentage
8. Curing methods

B. Ambient temperature

C. Ambient humidity as affected by:

1. Size and shape (volume to surface ratio) of element
2. Environment

4.2 Creep

Creep is the time dependent deformation of concrete due to load. Creep strain at any particular time is defined as the difference between total strain and the sum of initial elastic strain, shrinkage strain and strains due to temperature dependent volumetric changes at that time. Creep strain is influenced by the following factors:

- A. Internal properties of the concrete (same as for shrinkage, except A-7 above, Reinforcement percentage, that arbitrarily can be considered as an internal property or an external load factor).
- B. Ambient temperature (same as for shrinkage)
- C. Ambient humidity (same as for shrinkage)
- D. External load
 - 1. Time of loading
 - 2. Duration of loading
 - 3. Uni-or bi-axial loading

4.2.1 Evaluation of Creep

For practical evaluation and prediction, creep can be separated into two components:

- A. Drying creep results from stress-induced moisture diffusion and consequential shrinkage or swelling during the period of sustained loading. For given stress conditions, drying creep is primarily a function of the humidity factors (C) mentioned above.
- B. Basic creep is the creep of concrete not exposed to moisture diffusion. For any given concrete mix, it is a characteristic, predictable function of load and temperature alone ⁽²⁾.

The complexity of variables influencing shrinkage and creep must be viewed realistically. The property-factors, for example, are substantially the same as determine the concrete's strength and workability. For the structure in question, therefore, this set of parameters can be substituted with values typical for the specified concrete.

Similarly, the humidity factors can be limited to a single parameter for size and shape by assuming typical average environmental conditions.

1.01.7/31

SCHUPACK & ASSOCIATES
CONSULTING ENGINEERS

C

A comprehensive investigation in the range $0 - 95^{\circ}\text{C}$ ($32 - 203^{\circ}\text{F}$) of temperature effects on creep and shrinkage by D. J. Hannant ^(1A), indicates that creep increases approximately linearly with temperature ⁽²⁾. Applied to this structure, with an average temperature of $85^{\circ}\text{F} \pm 10\%$ (110°F inside, 0 to 100°F outside), the influence of the temperature range on creep is negligible. Temperature variations within this range are without measurable influence on the final shrinkage, and can also be neglected. ^(1B)

The influence of mild reinforcement is to increase the elastic resistance of the composite section and reduce creep and shrinkage effects proportionately. These recommendations will concern the concrete section alone, and give conservative values for the final shrinkage and creep.

Based on the above, a realistic estimate of creep and shrinkage for this structure can be determined by:

- C
- A. An evaluation of shrinkage and drying creep for the one significant humidity parameter - the actual volume/surface ratio.
 - B. A prediction of basic creep for the specified concrete, the given loads, and the concrete age at loading.

5. REVIEW OF LITERATURE AND TEST DATA

5.1 Shrinkage and Creep Research in General

The American Concrete Institute's publication SP-9 ⁽³⁾ presents a summary of the research done on creep up to 1964. A corresponding review of research on shrinkage has been prepared by the California Producers Committee ⁽⁷⁾ in 1966. Papers presented at the Conference on Prestressed Concrete Pressure Vessels in London in 1967 ⁽¹⁾ cover research on the special creep and shrinkage problems arising in prestressed concrete pressure vessels resembling the one in question. / >

C

Most investigations concern effects of a single, or a few, of the factors influencing shrinkage and creep and supply excellent information on the nature of these phenomena, especially for basic creep. The small scale models and laboratory specimens tested, and the comparatively short period of observation (maximum about 4 years), is, however, not representative of 50 years performance of the large concrete structural dimensions in question.

Reported observations on actual structures show the significant variation of combined shrinkage and creep effects with size and shape of member, but suffer from the impossibility of separating shrinkage and creep strain without having unloaded specimens for comparison.

The data reported on a few long-term full scale tests including unloaded companion specimens for shrinkage measurements (*), is insufficient in quantity and homogeneity to support conclusions on shrinkage and creep for this specific structure and extrapolation over 50 years.

X All test data can, however, be utilized for this estimate by separating the deformational behavior of the concrete into a primary component - basic creep, and a modifying component - drying creep and shrinkage. The investigations of size and shape influence quoted below show that the volume/surface ratio of this structure completely governs shrinkage in the possible range of prediction, and that drying creep can be neglected. Similarly, the research listed on basic creep shows that it dominates the concrete's deformational behavior on this structure. General test data applies directly to basic creep, and available information in correlation with reported observations on full scale tests is sufficient to warrant regression and extrapolation of this structure's estimated basic creep behavior during its entire service life.

(*) Notably, the AASHTO Road Test, Report 4, "Bridge Research", and Technical Report R212 from U. S. Naval Laboratories, Port Hueneme, California

5.2 Research and Test Data on Influence of Size and Shape

A. H. Mattock has investigated shrinkage and creep of precast concrete bridges ⁽⁴⁾, and Mattock and Torben C. Hansen together ⁽⁵⁾ have reported data from the first four years of an investigation in progress regarding the influence of size and shape of members on the shrinkage and creep of concrete. Based on the accumulated data and G. Pickett's theory of moisture diffusion ⁽⁶⁾, Hansen and Mattock have established a relationship between shrinkage and creep, and the volume to surface ratio (V/S inch) of a concrete member.

5.2.1 Shrinkage

The following graph shows the variation of final shrinkage with volume-surface ratio for Hansen and Mattock's main tests (Elgin gravel) and an auxiliary test on concrete made from an unusually porous crushed sandstone aggregate:




FIG. 1. VARIATION OF FINAL SHRINKAGE WITH VOLUME/SURFACE RATIO

1.01.7/34

SCHUPACK & ASSOCIATES
CONSULTING ENGINEERS

The plotted average represents a conservative prediction on the concrete specified for the structure in question, and the shrinkage at time "t" may be predicted from the given formula. Based on the underlying general theory of moisture diffusion, extrapolation of this curve is justified up to volume/surface ratios of approximately 24". Further extrapolation results in values outside the scope of accuracy possible in estimating total losses. For a volume/surface ratio of 24", the final shrinkage will be

$$\epsilon_{\infty} = 1200 \times e^{-0.10 \times 24} \times 10^{-6} = 0.0001 \text{ inch/inch}$$

All concrete in the present structure has a volume/surface ratio greater than 24", and the above value (0.0001) can be used as a conservative estimate of the final shrinkage strain.

5.2.2 Creep

Hansen and Mattock have established the following relationship between the coefficient for total (= basic + drying) creep ϕ , the coefficient of creep for sealed specimens (= basic creep) ϕ_s , and the volume/surface ratio V/S, valid for concrete similar to the structure in question:




FIG. 2. VARIATION OF CREEP COEFFICIENT WITH VOLUME/SURFACE RATIO AT DIFFERENT AGES. (ELGIN GRAVEL AGGREGATE CONCRETE CYLINDERS)

1-01.7/35

SCHUPACK & ASSOCIATES
CONSULTING ENGINEERS

Based on the above, and assuming a coefficient of basic creep $\phi_b = 1.5^{(*)}$, the drying creep component for a volume/surface ratio ≥ 6 is found to be:

$$\frac{\Delta \phi}{\phi_b} \leq \frac{1.77}{1.5} \times e^{-.54 \times 6} = 0.046$$

i.e., drying creep is less than 5% of basic creep for volume/surface ratios larger than 6, and can be neglected.

As all volume/surface ratios in the present structure are greater than 6, the size and shape of this structure makes basic creep the only significant creep component.

5.2.3 Research on Basic Creep

A summary of research on basic creep has been published by Torben C. Hansen ⁽²⁾ tabulating all work done up to 1960. Based on Powers and Brownyard's ⁽⁸⁾, and A. Hummel's ⁽⁹⁾ investigations of the properties of hardened Portland cement, Hansen has fit the accumulated data to Reiner's general rheological creep equation ⁽¹⁰⁾ and established a practical relationship between specific basic creep (i.e., basic creep per unit stress) and time. For given concrete properties the only parameter is concrete age at loading.

This fundamental rheological creep equation has been adapted to the concrete specified for the present structure, and curves for the estimated basic creep have been plotted on a graph, Appendix C, for loading ages 8 and 22 days, 1, 2, 3, 4-1/2 and 6 months. The curves are conservatively designed to over-estimate the probable basic creep by approximately 10%. For the specific conditions of this structure, the percentage deviation on the estimated creep values is expected to be approximately 14%.

Derivation of the basic creep curves and an evaluation of the accuracy of the estimate are presented in Appendix A.

(*) See Basic Creep graph (Appendix C)

1.01.7/36

SCHUPACK & ASSOCIATES
CONSULTING ENGINEERS

5.2.4 Effects of Bi-axial Stressing

Based on Arthanari and Yu's investigations (11) and the data reported to the London Conference on Prestressed Concrete Pressure Vessels by Browne (1B), Barrett and Murray (1C) and D. J. Hannant (1A), Poisson's ratio for creep under sustained multi-axial load at temperatures $85^{\circ}\text{F} \pm 10\%$ can be considered constant and equal to $1/6$. The estimated uni-axial creep strains must be evaluated separately for each member of the present structure as the creep effect due to multi-axial loading varies with the different ratios between specific uni-axial loads, and with the degree of restraint due to reinforcement.

6. CORRELATION WITH FULL SCALE TESTS

The estimated shrinkage and creep for the present structure has been checked against data from full scale tests on 22 prestressed I-section beams conducted by the U. S. Naval Engineering Laboratory, Port Hueneme, California. These 42-foot beams had a volume/surface ratio of $2.13''$ and were constructed with three proprietary systems of prestressing and designed to support a uniform load of 760 lbs. per linear foot. They were tested under different loading conditions and observations made of concrete strains over periods of 6 to 7 years. Eleven additional 21-foot non-loaded specimens were made for shrinkage measurements.

Evaluation of observations relative to the recommended shrinkage and creep strains is presented in Appendix B, and for comparison, creep curves for loading ages of 8 and 22 days derived from these observations are plotted on the graph of estimated basic creep (Appendix C).

For creep, these modified observations (apart from a minor early age discrepancy on the 8-day curve) clearly fall within the recommended values, especially for extrapolated later age conditions.

For shrinkage, the final average value observed is half of the value predicted for a volume/surface ratio of $2.13''$ by the recommended conservative formula (observed 0.0005, calculated 0.001 inch/inch).

1-01-7/37

SCHUPACK & ASSOCIATES
CONSULTING ENGINEERS

7. CONCLUSIONS

Shrinkage and creep are complex phenomena affected by a variety of factors reflecting the internal properties of the concrete, ambient temperature and humidity conditions, and the load pattern involved. Attempts to estimate long-term deformation of structures with small volume/surface ratios (say less than 2") result in a broad band of predictions. This is due to the difficulty of evaluating creep behavior when the volume/surface ratios are so small that the drying creep component predominates.

For the temperature range ($85^{\circ}\text{F} \pm 10\%$) and volume/surface ratio (larger than 24") of this structure, and the concrete properties and load conditions specified, it is, however, possible to obtain a conservative estimate of long-term deformations. This is done by separating basic creep strains from those due to drying creep and shrinkage.

Basic creep is by far the dominating deformational component and can be predicted with an accuracy of 10 - 15% based on the specified concrete strength and age at load application.

Drying creep is concluded to be negligible for the volume/surface ratio of the concrete in this structure.

Shrinkage is governed by the volume/surface ratio and is conservatively estimated to be at the lower limit of possible accuracy in predictions of total long-term losses.

For bi-axial stress conditions at the considered temperature, Poisson's ratio for creep can be assumed constant throughout the entire evaluation period. Multi-axial creep effects must, however, be evaluated separately for varying ratios of bi-axial stresses.

1.01.7/38

SCHUPACK & ASSOCIATES
CONSULTING ENGINEERS

8. RECOMMENDATIONS

The following losses due to shrinkage and creep are a reasonably conservative estimate of the values to be expected after 50 years sustained tendon loads at a temperature level of $85^{\circ}\text{F} \pm 10\%$ on the Jersey Central Power and Light Company's Prestressed Concrete Containment Structure at Oyster Creek Nuclear Station - Unit 2:

Shrinkage Strain After 50 Years:..... 0.0001 inch/inch

Uni-axial Creep Strain After 50 Years:

Concrete Age at Prestressing Months	Specific Creep Strain inch/inch per psi	Creep Coefficient ϕ_c ($E_c \times 10^6$ psi)
1.	$.45 \times 10^{-6}$	1.8
2	$.40 \times 10^{-6}$	1.6
3	$.37 \times 10^{-6}$	1.5
6	$.33 \times 10^{-6}$	1.3

Modification of Uni-axial Creep Strains for Bi-axial Stresses:

Poisson's ratio for creep can be considered constant over 50 years sustained tendon load at temperatures averaging $85^{\circ}\text{F} \pm 10\%$. The recommended value is $1/6$.

1-01.7/39

SCHUPACK & ASSOCIATES
CONSULTING ENGINEERSREFERENCES

1. Conference on Prestressed Concrete Pressure Vessels
Institution of Civil Engineers Papers #13 - #18 Group C London 1967
 - A. D. J. Hannant:
"Strain Behavior of Concrete up to 95° Under Compressive
Stresses" Paper #17 Group C
 - B. R. D. Browne:
"Properties of Concrete in Reactor Vessels"
Paper #13 Group C
 - C. N. T. Barrett and J. T. Murray:
"Creep in Pressure Vessels at Elevated Temperatures"
Paper #14 Group C
2. Torben C. Hansen: "Creep and Stress Relaxation of Concrete"
Cement and Concrete Research Institute Proceedings #31 Stockholm 1960
3. "Symposium on Creep of Concrete", ACI Publication SP-9 1964
4. A. H. Mattock: "Creep and Shrinkage Studies, Precast-
Prestressed Concrete Bridges 5"
Journal of the PCA Research and Development Laboratories
Vol. 3, #2, 32 - 66 1961
5. Torben C. Hansen and A. H. Mattock: "Influence of Size and
Shape of Member on the Shrinkage and Creep of Concrete"
ACI Journal Proceedings Vol. 63, p 267 February 1966
6. California's Producers Committee on Volume Change,
"Drying Shrinkage of Concrete" 1966
7. Gerald Pickett: "Shrinkage Stresses in Concrete"
PCA Research Department Bulletin #11 1946

"The Effects of Change in Moisture Content on the Creep of
Concrete Under a Sustained Load"
PCA Research Department Bulletin #20 1947

"Effects of Aggregate on Shrinkage of Concrete and Hypothesis
Concerning Shrinkage"
PCA Research Department Bulletin #66 1956
8. T. C. Powers and T. L. Brownyard: "Studies of the Physical
Properties of Hardened Portland Cement Paste"
PCA Research Department Bulletin #22 March 1948
9. A. Hummel: "Das Beton ABC", 5th edition 1942 ?
10. M. Reiner: Chapter on Rheology, "Elasticity and Plasticity"
Encyclopedia of Physics, Vol. VI (Springer Verlag, Berlin). 1958
11. Arthanari and C. W. Yu: "Creep of Concrete Under Uni- and
Bi-axial Stress at Elevated Temperatures"
Magazine of Concrete Research #60 1967

1.01.7/40

SCHUPACK AND ASSOCIATES
CONSULTING ENGINEERS
STAMFORD, CONN.

APPENDIX A
Basic creep

SHEET NO. A1 OF
BY CS DATE 2.5.68
CHK'D DATE

Torben C. Hansen's formulation of Reiner's general rheological creep equation is:

$$\frac{\epsilon_{\text{creep}}}{\sigma} = \beta \frac{(0.31 \cdot g(t_0) + \frac{w_0}{C}) \cdot V_1}{(N \cdot k_1 + 0.31) g(t_0)} (1 - e^{-m(t_1 - t_0)}) + \alpha_1 \frac{w_0}{C} \cdot V_1 \cdot \ln\left(\frac{t_1}{t_0}\right)$$

spec. creep delayed elasticity viscosity

- t_1 = age of concrete at time t_1 , in days
 t_0 = age of concrete when loaded, in days
 $\frac{w_0}{C}$ = water-cement ratio by weight, corrected for bleeding
 V_1 = volume concentration of cement paste in concrete
 $g(t_0)$ = degree of hydration of cement at time t_0
 k_1 = weight ratio of non-evaporable water to cement when all cement is hydrated. k_1 is a function of the proportions of cement components:
 $k_1 = 0.187(C_3S) + 0.158(C_2S) + 0.655(C_3A) + 0.213(C_4AF)$

$N = 0.75(1 + 4k)$, where

$$k = 0.230(C_3S) - 0.320(C_2S) + 0.317(C_3A) + 0.368(C_4AF)$$

α_1 , β and m are coefficients to be determined by experiment.

Hansen has fit the results of 42 test series to the equation above to determine α_1 , β and m . Powers & Brownvard's values $k_1 = .25$ and $k_1 = .23$ have been used where the cement composition was unknown, as have Hummel's values for degree of hydration with time for standard and rapid hardening Portland cement. Hansen found:

$$\beta = 1.76 \times 10^{-6}, \quad m = 0.0333, \quad \alpha_1 = 5.7 \times 10^{-6} \quad (\text{units: specific creep/kg/cm}^2)$$

The general equation for basic creep becomes: (units: sp. creep pr. psi)

$$\frac{\epsilon_{\text{creep}}}{\sigma} \times 10^6 = 0.189 \cdot \frac{(0.31 \cdot g(t_0) + \frac{w_0}{C}) \cdot V_1}{g(t_0)} (1 - e^{-\frac{t_1 - t_0}{30}}) + 0.401 \cdot \frac{w_0}{C} \cdot V_1 \cdot \ln\left(\frac{t_1}{t_0}\right) \quad [R]$$

The average percentage deviation between measured and calculated creep values was 14%, largest (16%) for 50-100 days sustained load, smallest (12%) for 900 days loading. For long term estimates, where the effect of poorly defined early age conditions is minimized, the accuracy of the equation is conservatively set at $\pm 10\%$.

Values of $r = \frac{w_i}{C}$ and V_i to be used for the specified concrete in this estimate are as follows:

$$r = 0.45, \left(\frac{\Delta r}{r}\right) = 7.5\% ; V_i = 0.29, \frac{\Delta V_i}{V_i} = 7.5\% ; \frac{\Delta g}{g} \approx 10\%$$

$$\frac{\Delta R}{R}(r) = \frac{\frac{dR}{R}}{\frac{dr}{r}} \left(\frac{\Delta r}{r}\right) = \frac{\left(\frac{.189(1-e^{-\frac{t-t_0}{30}})}{g(t_0)} + .4 \ln \frac{t}{t_0}\right) \cdot dr}{\frac{.189(1-e^{-\frac{t-t_0}{30}})}{g(t_0)} (.31g(t_0) + r) + .4r \ln \frac{t}{t_0}} \cdot \frac{r}{dr} \left(\frac{\Delta r}{r}\right) = .95 \left(\frac{\Delta r}{r}\right) = .95 \times 7.5\%$$

$$\frac{\Delta R}{R}(V_i) = \frac{\frac{dR}{R}}{\frac{dV_i}{V_i}} \left(\frac{\Delta V_i}{V_i}\right) = \frac{dV_i}{V_i} \cdot \frac{V_i}{dV_i} \left(\frac{\Delta V_i}{V_i}\right) = 1.0 \left(\frac{\Delta V_i}{V_i}\right) = 1.0 \times 7.5\%$$

$$\frac{\Delta R}{R}(g) = \frac{\frac{dR}{R}}{\frac{dg}{g}} \left(\frac{\Delta g}{g}\right) = \frac{\left(\frac{.189(1-e^{-\frac{t-t_0}{30}})}{g^2} \cdot r\right) \cdot dg}{\frac{.189(1-e^{-\frac{t-t_0}{30}})}{g} (.31g + r) + .4r \ln \frac{t}{t_0}} \cdot \frac{g}{dg} \left(\frac{\Delta g}{g}\right) \approx .09 \left(\frac{\Delta g}{g}\right) \approx .10 \times 10\%$$

[computed for: $t_0 \approx 60$ days, $t \approx 18000$ days, $g(t_0) \approx 0.85$, $r \approx 0.45$]

To be on the conservative side, the basic creep curves have been plotted for $r = 0.50$ and $V_i = 0.30$. According to the above, estimated creep values will be found about $.95 \times 10 + 1.0 \times 3 \approx 13\%$ to the safe side of the probable values, with an average deviation of approximately:

$$\sqrt{10^2 + 7.5^2 + 7.0^2} \approx 14\% \quad \left(\frac{\Delta g}{g} \text{ is already included in the } 10\%\right)$$

As $13\% \approx 14\%$, the curves will represent the upper limit of the confidence interval for equation [R]. The probable overestimation of creep values will be $\approx \frac{2}{3} \times 13 \approx 10\%$.

Curves have been plotted for $t_0 = 8, 22, 30, 60, 90, 135$ & 180 days using the corresponding values for $g(t_0)$ taken from Hummel's diagram and $r = 0.50$, $V_i = 0.30$. The equation is:

$$\frac{\xi_{\text{creep}}}{\epsilon} \times 10^n = \frac{0.18g(t_0) + .28}{g(t_0)} \left(1 - e^{-\frac{t-t_0}{30}}\right) + 0.6 \ln \left(\frac{t}{t_0}\right) \quad [S]$$

After about the first 90 days of loading, delayed elasticity has lost its effect on rate of creep and the viscous properties govern.

Shrinkage.

The maximal average shrinkage on 11 beams after 2200 days exposure was measured on bottom fibres at 445 μ inch/inch $\sim$ 0.0005.

Volume/surface ratio for these specimens was 2.13. Computed by the recommended formula, shrinkage after 2200 days being practically the same as final shrinkage, it is found:

$$\epsilon_{s,2200} \approx \epsilon_{s,\infty} = 1200 \cdot e^{-0.23} = 970 \mu\text{inch/inch} \sim 0.0010$$

Comparison of these values shows that the computed estimate is conservative, and that large percentual deviations may be expected on the prediction of small shrinkage values.

Creep.

The recorded creep observations include data on conditions governed by creep recovery, cracked section and tensile stresses, and stress patterns at so low a level as not to be comparable to the creep conditions of the structure in question. The following two cases are considered representative and have been investigated for this comparison:

A. Creep strains at center of gravity of steel (cgs) on 6 beams
Load: $DL + 0\% LL$, $t_0 = 8$ days, $E_c(8 \text{ days}) = 3.36 \times 10^6$ psi, $\sigma_c = 1330$ psi;

B. Differential creep at top fibre, 2×6 beams, Load: $(DL + 100\% LL) - DL$,
 $t_0 = 22$ days, $E_c(22 \text{ days}) = 3.36 \times 10^6$ psi, $\Delta \sigma = 1880 - 50 = 1830$ psi;

The reported observations have been averaged for 6 (or 2×6) beams and tabulated below. The following conservative approximations have been made in evaluating the basic creep component from the test data:

1. Mean values of average shrinkage have been used for shrinkage reduction.
2. No reductions have been made for plastic set.
3. The observed values (at cgs) of non linearly distributed overall creep effect (partial load removal at cgs $(DL + DL + LL)$) have been referred to cgs by being taken into account with $2/3$ of the actual values.
4. Volume/surface ratio is 1.55" for top flanges. 1.85" has been used.

Harrison & Mattock's formula determines basic creep from specific creep:

$$\phi(t/t_0) = \phi_{\text{basic}} + 1.77 e^{-0.54(t/t_0)^{1/3}}; \quad \phi_{\text{basic}} = \phi_{2.13} - 0.56 = \phi_{1.85} - 0.65$$


Specific basic creep curves as determined are plotted, see graph, appendix C.

TABULATION OF TEST DATA @ CGS. (DL+100%LL)

	8'd. (8-22)	22 days	(22-800)	800 days	(800-1600)	1600 days	(1600-2400)	2400 days	NOTES		
	¹ DL-M	² DL-M	³ 1+2	⁴ LL-C	⁵ DL+LL-M	⁶ 3+4+5	⁷ DL+LL-M	⁸ 6+7	⁹ DL+LL-M	¹⁰ 8+9	M=measured C=calculated strains in pinch/inch shrinkage values are deducted from M.
PRELOAD (CGROUTED)	480	250	730	-270	-280	180	-250	210	-280	180	
PRELOAD (NON-CROUTED)	495	295	790	-240	-280	270	-310	240	-150	400	
ROEBLING (NON-CROUTED)	475	310	795	-250	-470	65	-450	95	-430	115	
AVERAGE VALUES	485	285	770	-255 ^{a)}	-345	170 ^{a)}		180 ^{a)}		230 ^{a)}	
^{a)} Instantaneous elastic strain = $770 - 355 = 415$ ^{b)} Retained creep effect based on 2000 lb/in. dia											

^{a)} Instantaneous elastic strain = $770 - 255 = 515$.

^{a)} Retardant creep effect @ CGS of non-linear distribution of overall creep due to DL-(DL+LL).



SCHUPACK AND ASSOCIATES
CONSULTING ENGINEERS
STAMFORD, CONN.

APPENDIX B
Port Hueneme Test Data

SHEET NO. 83 OF
BY H.A. DATE 24.6.68
CHK'D CS DATE 25.6.68

Total @ C.G.S., average of 6 beams, $\frac{1}{3} = 2.13$.

CONC. AGE →	8 DAYS	22 DAYS	800 DAYS	1600 DAYS	2400 DAYS
$E_{TOT} - E_{SHRINK} \times 10^6$	485	770	1030	1065	1110
$E_{elast. instork. (1300 \text{ P.S.I.})} \times 10^6$	395	395	395	395	395
$E_{creep} \times 10^6$	0 90	375	635	670	715
$\phi_{2.13} = E_c / E_{elast.}$	0.229	0.948	1.605	1.695	1.810
$\phi_{2.13} - \phi_{BASIC}$	0.56	0.56	0.56	0.56	0.56
EQUIVALENT ϕ_{BASIC}	—	0.338	1.045	1.135	1.250
$E_{CR. / P.S.I.} = \phi_{BASIC} / E_c \times 10^6$	0	0.115	0.311	0.338	0.372


Differential creep @ top fibre, average 2x6 beams, $\frac{1}{3} \approx 1.85$

CONCRETE AGE →	22 DAYS	800 DAYS	1600 DAYS	2400 DAYS
$E_{TOT. (DIL)} - E_{SHRINK} \times 10^6$	650	1650	1810	1975
$E_{TOT. (C.D)} - E_{SHRINK} \times 10^6$	100	230	320	405
$\Delta E_{TOTAL (CL)} \times 10^6$	550	1420	1490	1570
$\Delta E_{elast. (CL)} \cdot 1830 \text{ P.S.I.} \times 10^6$	545	545	545	545
$\Delta E_{creep (CL)} \times 10^6$	5	875	945	1025
CORRECTION FOR AGE-LOADING $\times 10^6$	-5	-5	-5	-5
$\Delta E_{CREEP (CL)}$	0	870	940	1020
OTHER NON- $E_{CR(BASIC)}$ IN ΔE_{CR} VALUES	—	60	65	100
$\Delta E_{CREEP (CL)} \times 10^6$	0	810	875	920
$\phi_{1.85} = \Delta E_c / E_{elast.}$	0	1.490	1.610	1.690
$\phi_{1.85} - \phi_{BASIC}$	—	0.65	0.65	0.65
Equivalent ϕ_{BASIC}	—	0.84	0.96	1.04
$\Delta E_c / P.S.I. \times 10^6$	—	0.250	0.286	0.310

* OVERALL EFFECT OF NON-CREEP PART $\sim \frac{1}{3}$ EFFECT @ C.G.S.
(SEE STRAIN DIAG)

Basic Creep for 5000 psi Concrete

1.017 / 45.



- Total creep @ cgs Port Huenerme Tests¹⁾; age @ loading: 8 days ;
- Differential creep, top fibre, — — — — —¹⁾; — — — — — @ — — — : 22 — — — ;
- Estimated basic creep²⁾ for loading ages: 8 & 22 days and 1, 2, 3, 4, 5 & 6 months

SCHUPACK & ASSOCIATES
CONSULTING ENGINEERS - STAMFORD, CONN.
Job: Oyster Creek Unit 2
By: C.S. Date: May 10, 1968

1.01.7/46

CRYSTAL RIVER	MADE R.S.	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.	
	CHK'D. P.K.		
REACTOR BUILDING	DO. CP.		
SCHUPACK & ASSOCIATES REPORT	CP. DPM.	4203-00	23-
ON CREEP AND SHRINKAGE VALUES	ENG.	WORK ORDER	SIZE DRAWING REV.
	REV. CH. APP. DATE	4-24-69	

SUMMARY OF THE "REPORT ON RECOMMENDED
CONCRETE CREEP AND SHRINKAGE VALUES
FOR COMPUTING PRESTRESSING LOSSES" BY
SCHUPACK AND ASSOCIATES, CONSULTING ENGINEERS
STAMFORD, CONNECTICUT DATED JUNE 1968

JOB: OYSTER CREEK NUCLEAR STATION UNIT 2
TYPE TENDONS GROUTED TENDONS

CONCRETE SHRINKAGE AND CREEP OVER A
50 YEAR PERIOD AT AN AVERAGE TEMPERATURE
OF $85^{\circ}\text{F} \pm 10^{\circ}\text{F}$ TO ESTIMATE PRESTRESS LOSSES

SHRINKAGE = 0.0001 INCH/INCH
STRAIN

$$= 100 \times 10^{-6}$$

A UNI-AXIAL CREEP STRAIN = 0.4×10^{-6} / PSI

WALL

STRESS IN MERIDIONAL DIRECTION = -783.8 PSI

STRESS IN HOOP DIRECTION = -1465.0 PSI

NET CREEP STRAIN IN THE MERIDIONAL DIRECTION

$$= 0.4 \times 10^{-6} (-783.8 + \frac{1}{6} \times 1465)$$

$$= 0.4 \times 10^{-6} (-783.8 + 244.2)$$

$$= 0.4 \times 10^{-6} (-539.6)$$

$$= 216 \times 10^{-6}$$

NET CREEP STRAIN IN THE HOOP DIRECTION

$$= 0.4 \times 10^{-6} (-1465 + \frac{1}{6} \times 783.8)$$

$$= 534 \times 10^{-6}$$

1.01.7/47

CRYSTAL RIVER	MADE	RS	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D.	FL			
REACTOR BUILDING	SQ. CP.				
SCHUPACK & ASSOCIATES REPORT	CP. OFN.		4203-00212		
CONCRETE AND SHRINKAGE VALUES	ENG.		24		
	REV. CH. APP. DATE	4.24.69			

DOME

STRESS IN THE MERIDIONAL DIRECTION = 1648 PSI

STRESS IN THE HOOP DIRECTION = 1579 PSI

NET CREEP STRAIN IN THE MERIDIONAL DIRECTION

$$= 0.4 \times 10^{-6} (-1648 + \frac{1}{6} \times 1579)$$

$$= 0.4 \times 10^{-6} (-1648 + 263)$$

$$= 0.4 \times 10^{-6} \times 1385$$

$$= 554 \times 10^{-6}$$

NET CREEP STRAIN IN THE HOOP DIRECTION

$$= 0.4 \times 10^{-6} (-1579 + \frac{1}{6} \times 1648)$$

$$= 0.4 \times 10^{-6} (-1579 + 275)$$

$$= 0.4 \times 10^{-6} (-1304)$$

$$= 522 \times 10^{-6}$$

CREEP LOCATION	GAI SPEC.	SCHUPACK RECOMM.	SCHUPACK RECOMM.*
VERTICAL	200×10^{-6}	216×10^{-6}	162×10^{-6}
HOOP	300×10^{-6}	534×10^{-6}	401×10^{-6}
DOME	350×10^{-6}	554×10^{-6}	416×10^{-6}
TYPE OF STRAIN	GAI SPEC.	SCHUPACK RECOMM.	
SHRINKAGE STRAIN	120×10^{-6}	100×10^{-6}	

* BASED ON UNI-AXIAL CREEP STRAIN 0.3×10^{-6} INCH/INCH PER PSI (VALUE OBTAINED BASED ON THE ASSUMPTION CONCRETE AGE AT POST TENSIONING IS 1 YEAR)

1.01.7/48

CRYSTAL RIVER	MADE	RS.	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D.	FF.			
REACTOR BUILDING	NO. CP.		4203.00	212	25
REVISED PRE-STRESS REQUIREMENTS	CP. DFN.		WORK ORDER	SIZE	DRAWING
	ENG.		4-25-69		
	REV. CH. APP. DATE				

WALL

VERTICAL DIRECTION

TOTAL FORCE REQD = 175,200

NO OF TENDONS USED = 144

FORCE / TENDON = 1216 KIPS

AREA OF STEEL REQD = 1216

148.0 (153.6×0.95)

8.648

= 8.337 $\square$ AREA OF EACH WIRE = 0.0597 $\square$

8.648

N.O. OF WIRES REQD = 8.337 / 0.0597

144.8

= 139.6 WIRES

= 140 WIRES (SAY)

HORIZONTAL DIRECTION

145

FORCE REQD / FT = 824.9 KIPS / FT

SPACING OF TENDON = 19 1/2"

LET 'F' FORCE REQD / TENDON

F x 12 = 19.5

824.9

F = 19.5 x 824.9

12

= 19.5 x 68.74

= 1341 KIPS

AREA OF STEEL REQD = 1341

15.95 x 149.5

= 9.441 $\square$

NO OF WIRES REQD

= 9.441 / 0.0597

= 158.1 = 159 (SAY)

1.01.7/49

CRYSTAL RIVER	MADE R.S.	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D. W.J.L.			
REACTOR BUILDING	DO. CP.	4203.00		-26-
DOME PRESTRESSING	CP. DFM.			
	ENG.	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE	7-18-69		

TENDON DESCRIPTION

STABILIZED WIRE

163 - 0.276" ϕ WIRE ; $A_s = 9.73 \text{ in}^2$

f_s = ULTIMATE STRENGTH OF PRESTRESSING
STEEL = 240 KSI

LOSSES

AVERAGE AXIAL COMPRESSIVE STRESS IN DOME
= 1.53 KSI (TAKEN FROM LEININGER
CALCULATION PAGE#TMI-DT-68)

$$\text{ELASTIC SHORTENING} = \frac{1.53}{2} \times \frac{29}{4}$$

$$= 5.55 \text{ KSI}$$

CREEP

$$= 0.350 \times 10^{-6} \times 29 \times 10^6$$

SHRINKAGE

$$= 10.15 \text{ KSI}$$

$$= 0.12 \times 10^{-6} \times 29 \times 10^6$$

$$= 3.48 \text{ KSI}$$

4% RELAXATION LOSS }
BASED ON $0.6 f_s$

$$= 0.6 \times 240 \times 0.04$$

$$= 5.76 \text{ KSI}$$

TOTAL LOSSES

$$= 5.55 + 10.15 + 3.48 + 5.76$$

$$= 24.94 \text{ KSI}$$

STRESS IN WIRES AFTER LOSSES (UNDER NORMAL WORKING
CONDITION)

$$= 0.7 f_s - 24.94$$

$$= 0.7 \times 240 - 24.94$$

$$= 168.0 - 24.94$$

$$= 143.06 \text{ KSI}$$

$$0.6 f_s = 0.6 \times 240 = 144.0 \text{ KSI}$$

FORCE IN EACH TENDON AFTER LOSSES (UNDER NORMAL
WORKING CONDITION)

$$= 143.06 \times 9.73$$

$$= 1392 \text{ KIIPS}$$

1.01.7/50

CRYSTAL RIVER	MADE R.S.	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D. W.J.L.			
REACTOR BUILDING	BO. CP.	4203-00	27	27
DOME PRESTRESSING	CP. DFM.			
	ENG.	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE	7-18-69		

UNDER ACCIDENT CONDITION THE PRESTRESSING FORCE
IS INCREASED DUE TO ELASTIC ELONGATION

STRESS BEFORE ACCIDENT = 1630 PSI D+F

STRESS AFTER ACCIDENT = 56 PSI DFFTSPT₃

Δ STRESS = 1686 PSI

STRESS IN WIRE DUE TO ELASTIC ELONGATION

$$= 1.686 \times \frac{29}{4} = 12.22 \text{ KSI} \leq T_p = T_e$$

TOTAL STRESS IN WIRES DURING ACCIDENT

$$= 143.06 + 12.22 =$$

$$= 155.28 \text{ KSI} \checkmark$$

ϕ FACTOR

$$= 0.95$$

FINAL FORCE / TENDON = $0.95 \times 155.28 \times 9.73$

$$= 1435 \text{ KIPS} \checkmark$$

HORIZ. SPACING OF TENDON

(SEE LEININGER PAGE # TM1-DT69)

$$= 22.7 \times \frac{1435}{1055}$$

$$= 30.87''$$

$$= 30'' \text{ (SAY)}$$

USE 123 TENDONS (41 TENDONS IN EACH OF
3 DIRECTIONS) WITH A CONSTANT HORIZONTAL
SPACING OF 30''.


ϕ OF LAST TENDON IS AT A RADIUS 50'-0"

TANGENT POINT FOR ALL TENDONS IS AT A RADIUS

OF 55'-3"

1.01.7/51

FLORIDA POWER CORPORATION	MADE	E.S.		
	CHK'D.	P.L.		
	BO. CP.			
	CP. DFN.			
	ENG.			
CRYSTAL RIVER UNIT # 3	4203.00			28
REACTOR BUILDING	WORK ORDER	SIZE	DRAWING	REV.
CROSS SECTION THROUGH THE DOME	REV. CH. APP. DATE	8-22-69		



This copy to: R. Shanmugasundaram

1.01.7 | 52

GILBERT ASSOCIATES, INC.

READING

August 28, 1969

Chicago Bridge and Iron Company
P. O. Box 13308
Memphis, Tennessee 38113

Attn: Mr. P. Norbut
Engineering Coordinator

RE: Crystal River - Unit No. 3
Florida Power Corporation

Dear Mr. Norbut:

The stiffener angles for the dome, as shown on your design sketches, produce some interference with the tendon conduits and reinforcing bars. We wish to call this to your attention so that adjustments can be made before you transmit your drawings for approval.

The horizontal leg of C-1, C-2 and C-3 (L 8 x 6 x 3/4) causes an interference and if this leg were turned 180° so that the horizontal leg is projected toward the Q of the vessel the interference could be avoided.

The horizontal legs of C-4 (2 L's 8 x 6 x 3/4 with a 10" x 1/2" R) also cause an interference and we ask that this stiffener be revised so that any projection normal to the surface of the dome does not exceed eight (8) inches.

Enclosed please find a sketch showing the preceding, and in the event that you should have any questions please feel free to contact us.

Very truly yours,



A. G. Benyo
Structural Engineer

gu


Enclosures

cc: W. O. May (2)(w/encl)
R. B. McKnight (w/encl)
W. R. Dreyer (w/encl)
E. R. Hottenstein (2)(w/encl)
R. Villforth
S. N. Dobreff
R. Shanmugasundaram
Dept. File

FLORIDA POWER CORPORATION

CRYSTAL RIVER UNIT #3

CONTAINMENT VESSEL - SPHERICAL HEAD



CONTAINMENT VESSEL

GAI-R.S.

1.01.7/84 -1-

TO: MR. S.N. DOBREFF.
FROM: R. SHANMUGASUNDARAM
SUBJECT: CRYSTAL RIVER - REACTOR BUILDING
CHANGES REQUIRED BASED ON THE
FINAL REVISED PRESTRESS CALCULATIONS.
GAI-4203

BASED ON THE FINAL REVISED PRESTRESS
CALCULATIONS (PLEASE SEE MY MEMO
DATED APRIL 10 '69), THE REVISED ^{FINAL} REQUIREMENTS
ARE COMPARED WITH THE INITIAL REQUIREMENTS
WHICH THE PRESCON, THE PRESTRESS
CONTRACTOR HAS FOLLOWED SO FAR
IN LAYING OUT OF THE TENDONS.

PRESTRESS FORCE REQUIRED/FT

CYLINDRICAL WALL	AS SPECIFIED INITIAL REQUIREMENTS	FINAL REQUIREMENTS
VERTICAL	457.0 KIPS 11%	414.6 KIPS
HOOP	829.0 KIPS 5%	824.9 KIPS

(163 - 0.276" ϕ STABILISED WIRES)
NO. OF TENDONS REQUIRED

CYLINDRICAL WALL	INITIAL REQUIREMENTS	FINAL REQUIREMENTS
VERTICAL	144 12%	128
HOOP	282 3.1%	273

1.01.7/55 2-

IN EACH TENDON

NO OF WIRES REQUIRED, KEEPING THE NUMBER OF TENDONS SAME AS OF THE INITIAL REQUIREMENTS

CYLINDRICAL WALL	INITIAL REQUIREMENTS	FINAL REQUIREMENTS
VERTICAL	163	145
HOOP	163	159

ALL THE ABOVE CALCULATIONS ARE BASED ON THE STABILISED WIRES WITH 4% RELAXATION LOSSES AND SHRINKAGE AND CREEP LOSSES AS GIVEN IN GAI CONTRACT SPECIFICATION. INITIAL EFFECTIVE PRESTRESS IS LIMITED TO 0.6 OF THE ULTIMATE STRENGTH OF PRESTRESSING STEEL AND IS ALLOWED TO INCREASE BEYOND THE ABOVE LIMIT ONLY DURING 1.3 ACC. PRESSURE.

THE FOLLOWING IS THE COMPARISON BETWEEN THE GAI SPECIFICATIONS AND SCHUPACK & ASSOCIATES RECOMMENDATIONS ON LOSSES DUE TO CREEP AND SHRINKAGE

TYPE OF LOSSES	GAI SPEC.	SCHUPACK RECOMM.*
CREEP STRAIN		
VERTICAL	200×10^{-6}	162×10^{-6}
HOOP	300×10^{-6}	401×10^{-6}
DOME	350×10^{-6}	416×10^{-6}
SHRINKAGE STRAIN	120×10^{-6}	100×10^{-6}

1.01.7/56 -

* VALUE OBTAINED BASED ON THE
ASSUMPTION CONCRETE AGE AT
POST TENSIONING IS 1 YEAR.

IN CASE OF DOME
PRESTRESSING, THE FINAL SPACING
HAS NOT BEEN WORKED OUT FOR
CRYSTAL RIVER.

THEREFORE, THE FOLLOWING
DECISIONS ARE TO BE MADE.

- (1) LOSSES DUE TO ELASTIC
SHORTENING, CREEP AND SHRINKAGE
FOR CRYSTAL RIVER CONCRETE...
- (2) FINALISATION OF NO. OF
TENDONS IN THE WALL.

R. SHANMUGA SUNDARAM
STRUCTURAL ENGINEER.

C.C. D.K. CRONEBERGER
D.A. SKILTON.

CRYSTAL RIVER	MADE <i>ATO</i>	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D. <i>FI</i>			
	EQ. CF.			
REACTOR BLDG.	CF. DFN.			
DESIGN CHECK ON PRESCON	ENG.	WORK ORDER	SIZE	DRAWING
ANCHOR COMPONENTS CALCS	REV. OR APP. DATE 11-10-69			1.01.7/560

Check on Prescon calculations for bearing plate stresses. Prescon calculations make no allowance for square plate with a central circular hole. The following analysis is approximate, Prescon should provide more accurate calculations, which must make allowance for some of the loads etc. which occur.

Reference: Roark - "Formulas for Stress and Strain" page 221 formula 16 (free edge) & page 222 formula 21 (fixed inner edge)

Assumptions:

SIZE actual bearing plate = $24" \times 24" \times 3"$
assume bearing plate $24" \phi \times 3"$

HOLE inner hole $\phi = 11"$

outer ϕ of studs = $13\frac{1}{2}"$


assume edge of hole at $\phi = 11"$ is area of maximum stresses.

PRESSURE at 70% GUTS average bearing pressure = 3400 #/sq in
assume pressure acting uniformly under the $24" \phi$ circular bearing plate is 3400 #/sq in [hole: this gives a tension force than 70%]

POISSONS RATIO assume $\nu = \frac{1}{3}$

$$m = \frac{1}{\nu} = \frac{1}{\frac{1}{3}} = 3$$

From the above $a = 12"$ $b = 5.5"$ $t = 3"$ $m = 3$ $w = 3400 \text{ #/sq in}$



CRYSTAL RIVER	MADE <i>SS</i>	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D. <i>FR</i>			
REACTOR BLDG.	BO. CP.			
DESIGN CHECK ON PRESCON	CP. DFM.			
ANCHOR COMPONENTS CALCS	ENG.	WORK ORDER	SIZE	DRAWING
	REV. CHG. APP. DATE 11-10-69			REV. 1.01.7/57

① INNER EDGE FREE: → Refer to letter of Oct. 20, 1969

from Roark

$$S = \frac{3w}{4bt^2(a^2 - b^2)} \left[4a^4(m+1) \log \frac{a}{b} + 4a^2b^2 + b^4(m-1) - a^4(m+3) \right]$$

$$= \frac{3 \times 3400}{4 \times 3 \times 3^2 (12^2 - 5.5^2)} \left[4 \times 12^4 (3+1) 2.3026 \log_{10} \frac{12}{5.5} + 4 \times 12^2 \times 5.5^2 + 5.5^4 (3-1) - 12^4 (3+3) \right]$$

$$= \frac{3 \times 3400}{4 \times 3 \times 3^2 \times 17.5 \times 6.5} \left[7.65 \times 10^5 \times \log_{10} 2.18 + 1.74 \times 10^4 + 1.83 \times 10^3 - 1.245 \times 10^5 \right]$$

$$= 8.3 \times 10^{-1} \left[7.65 \times 0.338 \times 10^5 + 1.74 \times 10^3 + 1.83 \times 10^3 - 1.245 \times 10^3 \right]$$

$$= 8.3 \times 10^{-1} \left[259 \times 10^3 + 1.74 \times 10^3 - 1.245 \times 10^3 \right]$$

$$= 8.3 \times 10^{-1} \left[278.23 \times 10^3 - 1.245 \times 10^3 \right]$$

$$= 8.3 \times 10^{-1} \times 153.73 \times 10^3$$

$$= \underline{127,500} \text{ #/in}^2$$

② INNER EDGE FIXED:

from Roark

$$S = \frac{3w}{4t^2} \left[\frac{4a^4(m+1) \log \frac{a}{b} - a^4(m+3) + b^4(m-1) + 4a^2b^2}{a^2(m+1) + b^2(m-1)} \right]$$

$$= \frac{3 \times 3400}{4 \times 3^2} \left[\frac{4 \times 12^4 (3+1) 2.3026 \log_{10} \frac{12}{5.5} - 12^4 (3+3) + 5.5^4 (3-1) + 4 \times 12^2 \times 5.5^2}{12^2 (3+1) + 5.5^2 (3-1)} \right]$$

using arithmetic from above

$$= 283 \left[\frac{259 \times 10^3 - 1.245 \times 10^3 + 1.83 \times 10^3 + 17.4 \times 10^3}{576 + 60.5} \right]$$

$$= \frac{283 \times 153.73 \times 10^3}{636.5}$$

$$= \underline{68,300} \text{ #/in}^2$$

SUMMARY: From the above, the approx. max. stress in the bearing plate is midway between the two values, i.e. 97,900 #/in². This is greater than the min. ultimate for the C1045 steel. As this analysis is not exact, Prescon's calcs should allow for friction at back of plate; edge restraint of the bearing plate; friction and load transfer along trimpet; non-uniform pressure distribution; as well closer approximation for diameter of hole diameter.

CRYSTAL RIVER	MADE <u>SB</u>	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D. <u>F.P.</u>			
REACTOR BLDG.	SO. CP.			
"INFORMAL" DRL QUESTION 2	CP. DPN.			
FPC LETTER 10-23-69.	ENG.	WORK ORDER	SIZE	DRAWING
	REV. OR APP. DATE			REV.
	10-24-69			1.01.7/58

Level p. for prestressing wire to be used in the containment structure.

① VERTICAL TENDONS

no tendons = 144

ϕ radius = $65'-0\frac{3}{8} + 1'-9" = 66'-9\frac{3}{8} r. = 798\frac{3}{8} r.$

thickness of wall = $3'-6" = 42"$

$A_s = 9.75 \square"/\text{tendon}$

$$\therefore p = \frac{A_s}{bd} = \frac{9.75 \times 144}{2\pi \times 798\frac{3}{8} \times 42}$$

$$= 0.00667$$

say 0.0067

② HOOP TENDONS

Tendons spaced alternately at $13" \text{ \& } 26"$ c/c.

ave. spacing = $\frac{13+26}{2} = 19.5"$

$\therefore b = 19.5" \quad d = 42"$

$$\therefore p = \frac{9.75}{19.5 \times 42} = 0.0119$$

③ DOME TENDONS

no. of tendons = $3 \times 41 = 123$

at $60'-0"$ radius circle periphery = $2\pi \times 60 \times 12 = 4520" b.$

$d = 3'-0" = 36"$

$$\therefore p = \frac{123 \times 9.75}{4520 \times 36}$$

$$= 0.00737$$

say 0.0074

CRYSTAL RIVER	MADE <i>DB</i>	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D. <i>F.P.</i>			
REACTOR BLDG.	NO. CP.			
"INFORMAL" DRL QUESTION 9	CP. DPN.			
FPC LETTER 10-23-69	ENG.	WORK ORDER	SIZE	DRAWING
	REV. CH. ADD. DATE 10-24-69			1:01.7/59

Density of reinforcement in Test Block (Prescon) and Butress.

① 4' x 4' x 4' PRESCON TEST BLOCK

From page 15 of Prescon's "Tentative Test Schedule and Test Program", is taken the following quantity of rebar.

MK 1000	no = 5	size = 1 1/4"	L = 4 x 3' 9" = 15' 0"	W = 5 x 15 x 4.303 = 324 #
MK 1001	no = 12	size = 1 1/4"	L = 2 x 2' 4" + 3' 9" = 8' 5"	W = 12 x 8.42 x 4.303 = 435 #
MK 400	no = 2	size = 1/2"	L = 4 x 3' 9" = 15' 0"	W = 2 x 15 x .668 = 20 #
MK 401	no = 10	size = 1/2"	L = 2' 4" + 3' 9" + 2' 4" = 8' 5"	W = 10 x 8.42 x .668 = 56 #
MK 402	no = 2	size = 1/2"	L = 4 x 3' 9" = 15' 0"	W = 2 x 15 x .668 = 20 #
Total =				855 #

$$\therefore \text{density of rebar} [\#/\text{cu. yd.}] = \frac{855 \times 27}{4 \times 4 \times 4} = 361 \#/\text{cu. yd.}$$

② Manly 3MI dng no. E 421-031 and adjusting for 17% larger tendon on CR3, the total rebar per anchorage in the butress is: (note tendon anchorages @ 39" c/c).

#10 R 12" @ 12" c/c horiz	L = 22' 0" $\frac{39}{12}$ = 11' 0"	W = 4.303 x 11 x $\frac{39}{12}$	= 154 #
#10 R 17-4 per tendon	L = 12' 0"	W = 4.303 x 12 x 4	= 207 #
#10 R 18-1 per tendon	L = 13' 0"	W = 4.303 x 13 x 1	= 56 #
#10 13 per butress-day 5/anch	L = 3' 3"	W = 4.303 x 3.25 x 5	= 70 #
#5 spiral - 2/tendon	L = 57' 9"	W = 1.043 x 2 x 57.75	= 121 #

Total = 608 #/anch.

add 17% for larger tendon = 608 x 1.17 = 710 #

day anchorage @ 2.5' x 3.25' x 4' = 32.5 cu. ft
= 1.2 cu yds.

$$\therefore \text{density} = \frac{710}{1.2} = 592 \#/\text{cu yd} > 361 \#/\text{cu yd} \rightarrow \text{OK}$$

Density of rebar in butress > density of rebar in concrete test blocks.

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.		CLIENT <u>FLORIDA POWER CORP.</u> PROJECT <u>CR 3</u>	04-4762-016 FILING CODE <u>1.01.7A</u> W.004 PAGE <u>4207016</u> 1 OF 11																				
SYSTEM <u>REACTOR BUILDING</u>		ORIGINATOR <u>[Signature]</u> DATE <u>5/10/77</u>																					
CALCULATION FOR <u>SP-395 TENDON SURVEILLANCE / PRESTRESS LOSSES</u>		REVIEWER <u>D. Bass</u> DATE <u>10/28/77</u>																					
<u>INDEX</u> <table border="0" style="width: 100%;"> <thead> <tr> <th></th> <th style="text-align: right;">PAGE</th> </tr> </thead> <tbody> <tr> <td>OBJECTIVE</td> <td style="text-align: right;">2</td> </tr> <tr> <td>REFERENCES</td> <td style="text-align: right;">2</td> </tr> <tr> <td>DISCUSSION</td> <td style="text-align: right;">3</td> </tr> <tr> <td>METHOD</td> <td style="text-align: right;">4-5</td> </tr> <tr> <td>CALCULATIONS</td> <td style="text-align: right;">6-8</td> </tr> <tr> <td colspan="2">WIRE FORCE VS TIME CURVES</td> </tr> <tr> <td> DOME TENDONS</td> <td style="text-align: right;">9</td> </tr> <tr> <td> VERTICAL TENDONS</td> <td style="text-align: right;">10</td> </tr> <tr> <td> HOOP TENDONS</td> <td style="text-align: right;">11</td> </tr> </tbody> </table>					PAGE	OBJECTIVE	2	REFERENCES	2	DISCUSSION	3	METHOD	4-5	CALCULATIONS	6-8	WIRE FORCE VS TIME CURVES		DOME TENDONS	9	VERTICAL TENDONS	10	HOOP TENDONS	11
	PAGE																						
OBJECTIVE	2																						
REFERENCES	2																						
DISCUSSION	3																						
METHOD	4-5																						
CALCULATIONS	6-8																						
WIRE FORCE VS TIME CURVES																							
DOME TENDONS	9																						
VERTICAL TENDONS	10																						
HOOP TENDONS	11																						
		RESULTS																					

 FILING
CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT <u>FLORIDA POWER CORP</u>	FILING CODE <u>1:01.7A</u>
	PROJECT <u>CR3</u>	W.O. DV PAGE <u>4202015</u> <u>2 of 11</u>
SYSTEM <u>REACTOR BUILDING</u>		ORIGINATOR <u>J. L. Van</u>
CALCULATION FOR <u>SP.395 TENDON SURVEILLANCE / PRESTRESS LOSSES</u>		DATE <u>5/10/77</u>
<u>OBJECTIVE</u> DERIVE CURVES OF ESTIMATED PRESTRESS FORCE IN HOOP, VERTICAL, AND DOME TENDON WIRES AT TIMES OF TENDON SURVEILLANCE OVER THE PLANT LIFE. REQUIRED BY CR3 TECH. SPEC. 4.6.1.6. TO ACCOUNT FOR TENDONS WITH LESS THAN 163 WIRES, THE CURVES WILL BE FOR ONE WIRE.		REVIEWER <u>D. J. Van</u>
		DATE <u>10/28/77</u>
		RESULTS
<u>REFERENCES</u> 1) CR3 REACTOR BUILDING DOME DELAMINATION - FINAL REPORT - DECEMBER 10, 1976 SECTION 4.4.C - PRESTRESS LOSSES. 2) INSERVICE SURVEILLANCE OF UNBONDING POST TENSIONING SYSTEMS IN PRESTRESSED CONCRETE CONTAINMENT STRUCTURES. J. V. ROTZ, BECHTEL - PAPER PRESENTED AT UNIV. OF YORK, ENGLAND, 8-12 SEPTEMBER 1975. 3) SCHUPACK & ASSOC. BASIC CREEP FOR 5000 PSI CONCRETE. APPENDIX 5.J - TML-2 PSAL		

 FILING
CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT <u>FLORIDA POWER CORP</u> PROJECT <u>CR3</u>	FILING CODE <u>1101.7 A</u> W.O. # <u>9205-016</u> PAGE <u>3 OF 11</u>
SYSTEM <u>REACTOR BUILDING</u>		ORIGINATOR <u>J. L. HARRIS</u>
CALCULATION FOR <u>SP-395 TENDON SURVEILLANCE</u>		DATE <u>5/10/77</u>
REVIEWER <u>D. SKILTON</u>		DATE <u>10/28/77</u>
<u>DISCUSSION</u>		RESULTS
THE FIRST DRAFT OF SP-395 INCLUDED TENDON FORCE/TIME PLOTS BASED ON ORIGINAL DESIGN CRITERIA. THOSE CALCULATIONS WERE INFORMALLY REVIEWED BY D. SKILTON. DURING THE DOME REPAIR, THE BASIS OF TENDON PRESTRESS LOSSES WERE REEVALUATED AND INCLUDED IN REFERENCE 1). THIS INFORMATION GAVE PRESTRESS LOSSES AT THE TIME OF THE SIT (WITHIN A FEW MONTHS) AND AT 40 YEARS. AS THIS WAS PRESENTED TO THE NRC AND IS PUBLIC RECORD, IT PROPERLY SHOULD BE THE BASIS FOR DEVELOPMENT OF WIRE FORCE/TIME CURVES.		

 FILING
CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FLORIDA POWER CORP		FILING CODE	1101.7A	
	PROJECT	CR3		W.D. BY	PAGE	4203-016 4 of 11
SYSTEM				ORIGINATOR		
REACTOR BUILDING				J. E. HEN		
CALCULATION FOR				DATE 5/16/77		
SP-395 TENDON SURVEILLANCE				REVIEWER		
				D. B. S.		
				DATE 10/20/77		
METHOD				RESULTS		
PRESTRESS LOSSES CONSIDER FOUR LOSSES FROM THE INITIAL LOCK OFF OF THE TENDON AT 70% OF GUTS (240 KSI) WHICH IS 168 KSI. THOSE LOSSES ARE: 1) <u>ELASTIC SHORTENING</u> THIS IS A FUNCTION OF TENDON STRESSING SEQUENCE. THE VALUES PRESENTED IN REF. 1) ARE THE AVERAGE. THE FIRST TENDON STRESSED WOULD EXPERIENCE TWICE THE VALUE AND THE LAST WOULD EXPERIENCE NONE. THEREFORE THIS WAS INPUT INTO THE MAX., AVG., AND MIN. EXPECTED LOSSES. 2) <u>CREEP</u> CREEP IS TIME DEPENDENT, AND THE VALUES CALCULATED FOR ONE YEAR AFTER THE SIT USE REF. 1) VALUES CORRECTED BY REF. 3).						

FILING
CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FLORIDA POWER CORP		FILING CODE	1101.7A
	PROJECT	CR3		W.O. BY	PAGE
				4203-016	5 OF 11
SYSTEM	REACTOR BUILDING			ORIGINATOR	J. L. L. L.
CALCULATION FOR	SP-395 TENDON SURVEILLANCE			DATE	5/10/77
				REVIEWER	D. B. L.
				DATE	10/28/77
				RESULTS	
3) <u>STEEL RELAXATION</u> STEEL RELAXATION IS TIME DEPENDENT WITH SMALL CHANGE FROM SIT TO ONE YEAR AFTER SIT. SEE REF 1) FOR VALUES. 4) <u>SHRINKAGE</u> SHRINKAGE LOSSES IN REF 1) WERE CONSIDERED AS OCCURRING FROM PLACEMENT OF CONCRETE TO TIME OF SIT ONLY. DUE TO VOLUME / THICKNESS NOT CONSIDERED TO OCCUR OVER PLANT LIFE - REF 1).					

FILING
CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.		CLIENT <u>FLORIDA POWER CORP.</u> PROJECT <u>CR3</u>		FILING CODE <u>1:01.7A</u> W.O. NO. <u>9203-016</u> PAGE <u>6 of 11</u> ORIGINAL OF <u>1</u> DATE <u>5/10/77</u> REVIEWER <u>D. J. S.</u> DATE <u>10/28/77</u> RESULTS																																				
SYSTEM <u>REACTOR BUILDING</u>																																								
CALCULATION FOR <u>SP-395 TENDON SURVEILLANCE</u>																																								
<u>CALCULATIONS</u> <u>FROM DOME DELAMINATION REPORT</u> <u>(PAGE 4-3)</u>																																								
c. <u>Prestress Losses</u> The calculated prestress losses (ksi) and effective prestress (ksi) are given below:																																								
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Elastic Shortening</th> <th>Creep</th> <th>Steel Relaxation</th> <th>Shrinkage</th> <th>(AVG.) Total Losses (KSI)</th> </tr> </thead> <tbody> <tr> <td><u>(SIT) Present</u></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vertical</td> <td>3.6 (0-7.2)</td> <td>3.9</td> <td>2.2</td> <td>2.9</td> <td>12.6</td> </tr> <tr> <td>Hoop</td> <td>6.4 (0-12.8)</td> <td>7.0</td> <td>2.2</td> <td>2.9</td> <td>18.5</td> </tr> <tr> <td>Dome</td> <td>10.4 (0-20.8)</td> <td>11.3</td> <td>2.2</td> <td>2.9</td> <td>26.8</td> </tr> </tbody> </table>							Elastic Shortening	Creep	Steel Relaxation	Shrinkage	(AVG.) Total Losses (KSI)	<u>(SIT) Present</u>						Vertical	3.6 (0-7.2)	3.9	2.2	2.9	12.6	Hoop	6.4 (0-12.8)	7.0	2.2	2.9	18.5	Dome	10.4 (0-20.8)	11.3	2.2	2.9	26.8					
	Elastic Shortening	Creep	Steel Relaxation	Shrinkage	(AVG.) Total Losses (KSI)																																			
<u>(SIT) Present</u>																																								
Vertical	3.6 (0-7.2)	3.9	2.2	2.9	12.6																																			
Hoop	6.4 (0-12.8)	7.0	2.2	2.9	18.5																																			
Dome	10.4 (0-20.8)	11.3	2.2	2.9	26.8																																			
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Elastic Shortening</th> <th>Creep</th> <th>Steel Relaxation</th> <th>Shrinkage</th> <th>(AVG.) Total Losses (KSI)</th> <th>Effective Prestress (KSI)</th> </tr> </thead> <tbody> <tr> <td><u>ONE YR. AFTER SIT</u></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VERT</td> <td>(0-7.2)</td> <td>4.7</td> <td>2.3</td> <td>2.9</td> <td>9.9 13.5 17.1</td> <td>158.1 154.5 150.9</td> </tr> <tr> <td>HOOP</td> <td>(0-12.8)</td> <td>8.4</td> <td>2.3</td> <td>2.9</td> <td>13.6 20.0 26.4</td> <td>154.4 148.0 141.6</td> </tr> <tr> <td>DOME</td> <td>(0-20.8)</td> <td>14.9</td> <td>2.3</td> <td>2.9</td> <td>20.1 30.5 40.9</td> <td>147.9 132.5 127.1</td> </tr> </tbody> </table>							Elastic Shortening	Creep	Steel Relaxation	Shrinkage	(AVG.) Total Losses (KSI)	Effective Prestress (KSI)	<u>ONE YR. AFTER SIT</u>							VERT	(0-7.2)	4.7	2.3	2.9	9.9 13.5 17.1	158.1 154.5 150.9	HOOP	(0-12.8)	8.4	2.3	2.9	13.6 20.0 26.4	154.4 148.0 141.6	DOME	(0-20.8)	14.9	2.3	2.9	20.1 30.5 40.9	147.9 132.5 127.1
	Elastic Shortening	Creep	Steel Relaxation	Shrinkage	(AVG.) Total Losses (KSI)	Effective Prestress (KSI)																																		
<u>ONE YR. AFTER SIT</u>																																								
VERT	(0-7.2)	4.7	2.3	2.9	9.9 13.5 17.1	158.1 154.5 150.9																																		
HOOP	(0-12.8)	8.4	2.3	2.9	13.6 20.0 26.4	154.4 148.0 141.6																																		
DOME	(0-20.8)	14.9	2.3	2.9	20.1 30.5 40.9	147.9 132.5 127.1																																		
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Elastic Shortening</th> <th>Creep</th> <th>Steel Relaxation</th> <th>Shrinkage</th> <th>(AVG.) Total Losses (KSI)</th> <th>Effective Prestress (KSI)</th> </tr> </thead> <tbody> <tr> <td><u>40 YR.</u></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vertical</td> <td>3.6 (0-7.2)</td> <td>9.1</td> <td>3.4</td> <td>2.9</td> <td>15.4 19.0 22.6</td> <td>152.6 149.0 145.4</td> </tr> <tr> <td>Hoop</td> <td>6.4 (0-12.8)</td> <td>16.2</td> <td>3.3</td> <td>2.9</td> <td>22.4 28.8 35.2</td> <td>145.6 139.2 132.8</td> </tr> <tr> <td>Dome</td> <td>10.4 (0-20.8)</td> <td>26.2</td> <td>3.4</td> <td>2.9</td> <td>32.5 42.9 53.3</td> <td>135.5 125.1 114.7</td> </tr> </tbody> </table>							Elastic Shortening	Creep	Steel Relaxation	Shrinkage	(AVG.) Total Losses (KSI)	Effective Prestress (KSI)	<u>40 YR.</u>							Vertical	3.6 (0-7.2)	9.1	3.4	2.9	15.4 19.0 22.6	152.6 149.0 145.4	Hoop	6.4 (0-12.8)	16.2	3.3	2.9	22.4 28.8 35.2	145.6 139.2 132.8	Dome	10.4 (0-20.8)	26.2	3.4	2.9	32.5 42.9 53.3	135.5 125.1 114.7
	Elastic Shortening	Creep	Steel Relaxation	Shrinkage	(AVG.) Total Losses (KSI)	Effective Prestress (KSI)																																		
<u>40 YR.</u>																																								
Vertical	3.6 (0-7.2)	9.1	3.4	2.9	15.4 19.0 22.6	152.6 149.0 145.4																																		
Hoop	6.4 (0-12.8)	16.2	3.3	2.9	22.4 28.8 35.2	145.6 139.2 132.8																																		
Dome	10.4 (0-20.8)	26.2	3.4	2.9	32.5 42.9 53.3	135.5 125.1 114.7																																		

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT <u>FLORIDA POWER CORP.</u> PROJECT <u>CR3</u>	FILING CODE <u>1101.7A</u> W.O. 04 PAGE <u>7 of 11</u> 4202-D16 ORIGINATOR <u>[Signature]</u> DATE <u>5/10/77</u> REVIEWER <u>D. J. [Signature]</u> DATE <u>10/28/77</u>	
SYSTEM <u>REACTOR BUILDING</u>		RESULTS	
CALCULATION FOR <u>SP. 395 TENDON SURVEILLANCE</u>			
FORCE PLOTTED FOR ONE WIRE 7mm AREA = 0.05965 SQ. IN. TOLERANCE ON JACKING TO BE $\pm 5\%$ APPLIED TO MAX. & MIN. FORCE PLOT UPPER, AVERAGE, LOWER.			
ONE YR. APRIL SIT	$1.05 \times \text{Area} \times \text{Epp.}$ MAX.	$\text{Area} \times \text{Epp.}$ AVG.	$.95 \times \text{Area} \times \text{Epp.}$ MIN.
VERT.	9.90 K	9.22 K	8.55 K
HOOP	9.67	8.83	8.02
DOME	9.26	8.20	7.20
<u>40 YR.</u>			
VERT.	9.56	8.89	8.24
HOOP	9.12	8.30	7.53
DOME	8.49	7.46	6.50

 FILING
CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FLORIDA POWER CORP.	FILING CODE	1:01.7A
	PROJECT	CR3	W.O.	PAGE 8 OF 11
SYSTEM			ORIGINAL	DATE
REACTOR BUILDING			J. L. HEN	5/10/77
CALCULATION FOR			REVIEWER	DATE
SP 395 TENDON SURVEILLANCE			D. Bus	10/20/77
			RESULTS	
TO VERIFY USE OF STRAIGHTLINE PLOT ON SEMI-LOG PAPER, CALCULATE WIRE FORCE FOR HODP TENDON AT TEN YEARS - AVERAGE - AND COMPARE TO PLOTTED VALUE: 10 YEAR ELASTIC SHRT. (AVG.) 6.4 KSI CREEP $\frac{3.5}{2.19} \times 9.2 + 7.0 = 12.3$ STEEL LOSS, $\frac{13.22}{4} + 2.2 = 2.5$ SHRINKAGE 2.9 TOTAL 24.1 KSI WIRE FORCE = $0.05965 \times (168 - 24.1) = 8.58^k$ GRAPH READING AT 10 YEARS = 8.50^k % DIFF. = $\frac{.08}{8.50} \times 100 = 0.9\%$ CONFIRMS USE OF SEMI-LOG AND STRAIGHTLINE.				

FILING
CODE

FL 1101.7A
Page 9 of 11




FIGURE 10
WIRE FORCE VS. TIME
DOME TENDONS




FIGURE 11
WIRE FORCE VS. TIME
VERTICAL TENDONS




FIGURE 12
WIRE FORCE VS. TIME
HOOP TENDONS

memorandum



Gilbert/Commonwealth

SH. 12

AUG. 23, 1977

to: S. N. Dobreff

from: M. R. Wardrop

subject: CR#3

Request for Approval of Design Tasks Requiring Verification

The following list of Design Tasks, which identifies safety related and non-safety related items and defines those which require Design Verification, has been prepared for Crystal River Unit #3 and is hereby submitted for your approval as required by Sections 5.1 and 5.5.1 of DCP 4.2.1:

Filing Code	W. O. Number Name of Task	Safety Class (1)	Verification Required (2)	Reason for Verification (3)
1:01.7A	04-4762-016 TENDON SURVEILLANCE PRESTRESS LOSSES	SR	YES	NRC

(1) SR = Safety Related

NSR = Non-Safety Related

(2) Yes or No

(3) NRC = Nuclear Regulatory Commission

GAI = Gilbert Associates, Inc.

Distribution:

F. J. Tomazic

J. C. HERR

T. D. BISS

M. R. Wardrop JCA

M. R. Wardrop
Project Structural Engineer

Approved by:

[Signature]

Date: 8-24-77

BAI 35 12/73

memorandum



Gilbert/Commonwealth

13
SH.

August 26, 1977

to: Mr. J. E. Lisney
from: M. R. Wardrop
subject: CR#3 Tendon Surveillance
Design Review
W. O. 04-4762-016
Filing Code 1:01.7A

You have been designated as the Verifier for subject Design Review. Attached are the eleven (11) calculation pages, two (2) memorandums approving this task, and the Design Verification Record for this task.

The First Tendon Surveillance is scheduled for November, 1977. Therefore, your review should be completed by September 30, 1977.

M. R. Wardrop

M. R. Wardrop
Project Structural Engineer

MRW:km

cc: F. J. Tomazic
S. N. Dobreff
K. E. Nodland
J. C. Herr

memorandum



Gilbert/Commonwealth

SH. 14

to: S. N. Dobreff
from: M. R. Wardrop
subject: Approval of Verifier and Scope of Verification
CR#3

As required by DCP 4.2.1 and DP-0414-7, I request your approval of the sufficiency of the Verifier's independence from the Originator and the type and depth of Design Review as shown below:

Project: CRYSTAL RIVER UNIT #3
Design Task: CONTAINMENT BLDG Filing Code 1.01.7A
TENON SURVEILLANCE W.O. 04-4762-016
PRESTRESS LOSSES
Originator: J. C. HERR
Verifier: T. D. BISS
Description of Verification to be Performed:

To verify design concept and verify sufficiently the detail calculations as necessary to his satisfaction that the design intent is met. Checking of every arithmetical figure is not required.

Distribution

F. J. Tomazic
J. C. HERR
T. D. BISS
S. Dobreff

M. R. Wardrop
M. R. Wardrop
Project Structural Engineer

Approved By: S. Dobreff

Date: 10/24/77

SH. 15

memorandum



Gilbert/Commonwealth

October 24, 1977

to: T. D. Biss
from: M. R. Wardrop
subject: CR#3 Tendon Surveillance
Design Review
W. O. #04-4762-016
Filing Code: 1:01.7A

You have been designated as the Verifier for subject Design Review. Attached are the eleven (11) calculation pages, two (2) memorandums approving this task, and the Design Verification Record for this task.

The first Tendon Surveillance is scheduled to start in November, 1977. Therefore, your review should be completed as soon as possible.

This memorandum also serves to release Mr. J. E. Lisney from being the Verifier, as designated on August 26, 1977.

M. R. Wardrop
M. R. Wardrop

MRW:km

cc: F. J. Tomazic
S. N. Dobreff
J. E. Lisney
J. C. Herr

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	DEPARTMENT NAME	DEPT. NO.	FILING CODE
	Structural	0414	1:01.7A/16
	PROJECT NAME	W.O. NUMBER	PAGE
	Crystal River Unit 3	041-4203-115	21(1-11)
SUBJECT			ORIGINATOR
Tendon Surveillance - Creep rates			D. B. 155
Check creep loss values for 1 year after s.t.			DATE 10/25/77
Ref. Dome Repair Calc's Book II, section 1			VERIFIER
at time of calculation (5/76) average age of concrete was ≈ 700 days			DATE
1 year after SET: ≈ 700 days + 1 1/2 year			
≈ 1250 days			
≈ 3.4 year			
From time dependant creep curve			
$S_c = 0.17 \mu\text{in}/\text{psi}$			
for Vertical tendons			
$\Delta f_{sv} = (0.17)(997 \text{ psi})(29 \times 10^6 \text{ psi}) = 4.9 \text{ ksi vs } 4.7$			
for Hoop tendons			
$\Delta f_{sh} = (0.17)(11776)(29 \times 10^6) = 8.8 \text{ ksi vs } 8.4$			
for Dome tendons			
$\Delta f_{sd} = (0.17)(2873)(29 \times 10^6) = 14.2 \text{ ksi vs } 14.9$			
∴ values used in development of chart are as accurate as can be predicted with the given input data.			

FILING
CODE

CLIENT FLORIDA POWER CORPORATION		W.O. 04-4762-016
PROJECT CRYSTAL RIVER UNIT #3		FILING CODE 1:01.7A/17
DESIGN DOCUMENT <i>CALCULATIONS FOR SP-395</i> <i>TENOR SURVEILLANCE / PROTECT LOSS / PART-11</i>		REVISION AND DATE REV 0 5/10/77
ORIGINATOR J. C. HERR	VERIFIER T. D. BISS	

DOES THE DESIGN DOCUMENT CONTAIN ASSUMPTIONS IDENTIFIED FOR SUBSEQUENT RE-VERIFICATION WHEN THE DETAILED DESIGN ACTIVITIES ARE COMPLETED (REF. QUESTION 2, BELOW)?

NO ☒YES ☐

VERIFIERS ATTESTATION

THE (DESIGN DOCUMENT HAS) (~~REVISIONS TO THE DOCUMENT OCCURRING SINCE THE PREVIOUS VERIFICATION HAVE~~) BEEN REVIEWED BY ME TO PROVIDE ASSURANCE THAT IT MEETS THE DESIGN INPUTS. ANY FINDINGS UNCOVERED DURING THE COURSE OF MY REVIEW HAVE BEEN DIRECTED TO THE ORIGINATOR AND RESOLVED. AS A PART OF THE REVIEW, THE NINETEEN QUESTIONS LISTED HEREUNDER HAVE BEEN ADDRESSED TO JUDGE WHICH ARE APPLICABLE. THE DESIGN DOCUMENT HAS BEEN EVALUATED AGAINST THE APPLICABLE QUESTIONS.

Theodore T. Daniel Biss
VERIFIER'S SIGNATURE

10/28/77
DATE

- WERE THE INPUTS CORRECTLY SELECTED AND INCORPORATED INTO DESIGN? (SEE DCP 4.9.1)
- ARE ASSUMPTIONS NECESSARY TO PERFORM THE DESIGN ACTIVITY ADEQUATELY DESCRIBED AND REASONABLE? WHERE NECESSARY, ARE THE ASSUMPTIONS IDENTIFIED FOR SUBSEQUENT RE-VERIFICATION WHEN THE DETAILED DESIGN ACTIVITIES ARE COMPLETED?
- ARE THE APPROPRIATE QUALITY AND QUALITY ASSURANCE REQUIREMENTS SPECIFIED?
- ARE THE APPLICABLE CODES, STANDARDS AND REGULATORY REQUIREMENTS INCLUDING ISSUE AND ADDENDA PROPERLY IDENTIFIED AND ARE THEIR REQUIREMENTS FOR DESIGN MET?
- HAVE APPLICABLE CONSTRUCTION AND OPERATING EXPERIENCE BEEN CONSIDERED?
- HAVE THE DESIGN INTERFACE REQUIREMENTS BEEN SATISFIED?
- WAS AN APPROPRIATE DESIGN METHOD USED?
- IS THE OUTPUT REASONABLE COMPARED TO INPUTS?
- ARE THE SPECIFIED PARTS, EQUIPMENT, AND PROCESSES SUITABLE FOR THE REQUIRED APPLICATION?
- ARE THE SPECIFIED MATERIALS COMPATIBLE WITH EACH OTHER AND THE DESIGN ENVIRONMENTAL CONDITIONS TO WHICH THE MATERIAL WILL BE EXPOSED?
- HAVE ADEQUATE MAINTENANCE FEATURES AND REQUIREMENTS BEEN SPECIFIED?
- ARE ACCESSIBILITY AND OTHER DESIGN PROVISIONS ADEQUATE FOR PERFORMANCE OF NEEDED MAINTENANCE AND REPAIR?
- HAS ADEQUATE ACCESSIBILITY BEEN PROVIDED TO PERFORM THE IN-SERVICE INSPECTION EXPECTED TO BE REQUIRED DURING THE PLANT LIFE?
- HAS THE DESIGN PROPERLY CONSIDERED RADIATION EXPOSURE TO THE PUBLIC AND PLANT PERSONNEL?
- ARE THE ACCEPTANCE CRITERIA INCORPORATED IN THE DESIGN DOCUMENTS SUFFICIENT TO ALLOW VERIFICATION THAT DESIGN REQUIREMENTS HAVE BEEN SATISFACTORILY ACCOMPLISHED?
- HAVE ADEQUATE PRE-OPERATIONAL AND SUBSEQUENT PERIODIC TEST REQUIREMENTS BEEN APPROPRIATELY SPECIFIED?
- ARE ADEQUATE HANDLING, STORAGE, CLEANING AND SHIPPING REQUIREMENTS SPECIFIED?
- ARE ADEQUATE IDENTIFICATION REQUIREMENTS SPECIFIED?
- ARE REQUIREMENTS FOR RECORD PREPARATION REVIEW, APPROVAL, RETENTION, ETC., ADEQUATELY SPECIFIED?

