Thomas Harding Director, Licensing



R.E. Ginna Nuclear Power Plant, LLC 1503 Lake Road Ontario, New York 14519-9364 585.771.5200 585.771.3943 Fax

thomas.hardingjr@cengllc.com

September 22, 2010

U.S. Nuclear Regulatory Commission Washington, DC 20555-0001

WPLNRC-1002339

ATTENTION: Document Control Desk

SUBJECT: R.E. Ginna Nuclear Power Plant Docket No. 50-244

Transmittal of RCS Pressure and Temperature Limits Report (PTLR)

REFERENCES: (1) Letter from T. Harding, Ginna LLC to NRC Document Control Desk, Subject: Commitment Change Associated with the Submittal of a Revised Pressure Temperature Limits Report, dated February 18, 2010

> (2) Letter from T. Harding, Ginna LLC to NRC Document Control Desk, Subject: Additional Information Associated with Revised Pressure Temperature Limits Report Commitment Change, dated April 13, 2010

In accordance with the R.E. Ginna Nuclear Power Plant Improved Technical Specification 5.6.6, which requires the submittal of revisions to the PTLR, the attached report is hereby submitted.

The commitment date for submitting the attached PTLR was revised to October 1, 2010 by Reference 1. Additional information to support the revised commitment date was verbally requested by the NRC staff and provided by Reference 2.

ADO NRR

Document Control Desk September 22, 2010 Page 2

There are no new commitments being made in this submittal. If you should have any questions regarding the information in this submittal, please contact Tom Harding at (585) 771-5219 or <u>Thomas.HardingJr@cengllc.com</u>.

Very truly yours, Thomas L Harding

Attachment: Ginna PTLR, Revision 6

c: M. Dapas, NRC D.V. Pickett, NRC Resident Inspector, NRC (Ginna)

Attachment

Ginna PTLR, Revision 6

R.E. Ginna Nuclear Power Plant, LLC September 22, 2010



医子宫 医马克氏病

R.E. GINNA

NUCLEAR POWER PLANT

ALCONDER STR ţ.

RCS Pressure and Temperature Limits Report PTLR and the second second

Revision 6

Responsible Manager:

9

Effective Date:

PTLR-1 of 16

1.0 RCS Pressure and Temperature Limits Report (PTLR)

This Pressure and Temperature Limits Report (PTLR) for the R.E. Ginna Nuclear Power Plant has been prepared in accordance with the requirements of Technical Specification 5.6.6. Revisions to the PTLR shall be provided to the NRC after issuance.

The Technical Specifications addressed in this report are listed below:

3.4.3 RCS Pressure and Temperature (P/T) Limits

3.4.6 RCS Loops - MODE 4

3.4.7 RCS Loops - MODE 5, Loops Filled

3.4.10 Pressurizer Safety Valves

3.4.12 Low Temperature Overpressure Protection (LTOP) System

R.E. Ginna Nuclear Power Plant

Revision 6

1. 1

1 C

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the following subsections. All changes to these limits must be developed using the NRC approved methodologies specified in Technical Specification 5:6.6. These limits have been determined such that all applicable limits of the safety analysis are met. All items that appear in capitalized type are defined in Technical Specification 1.1, Definitions. Reference 1 calculates Pressure/ Temperature Limits out to 53 EFPY. 5 Č 化化学 磷酸化学 机化学 化分子试验 法保险 化合物 建甲基乙基甲基乙 2.1 RCS Pressure and Temperature Limits, second and second and second (LCO)3.4.3) உண்டியாட்டியிர் கடங்கள் காலைய நடன் கடங்கள் இதுகள் புகர்கள் 5 (LCO 3.4.12) Presentation (単一の) (統一の報告) (正正正正) (Free Ellipse) o to de avente o trans autores estanos a qui su are constante publica arte co 2.1.1 The RCS temperature rate-of-change limits are: to a sector a. * A maximum heatup of 60°F per hour. 1. A. the second second second by a second b. A maximum cooldown of 100°F per hour. 化糖盐 医外外的 化化合物 法法公司 网络美国人姓氏美国人姓氏德住所名称来源于古英语 ine el Statet, Marine alterna el central estatet de la Serenation de trates de la sur 2.1.2 The RCS P/T limits for heatup and cooldown are specified by Figure PTLR - 1 and Figure PTLR - 2, respectively. These curves are based on Reference 1 as modified in Reference 12 to include instrument errors. 2.1.3 The minimum boltup temperature, using the methodology of Reference 4. Enclosure 2 is 60°F (Reference 12). news to be a straight the region of Low Temperature Overpressure Protection System Enable Temperature 2.2 (Calculated in Reference 12) [44] T.T. & P. C. T.T.BREEN, Annual Constraints, Physical Activity, 2010 (2014); Medical Sciences, 2014. THE WAY TO PROPAGATE SHE (LCO 3.4.6) (LCO 3.4.7) (LCO 3:4.10) SERBAR A LA PERMIT A CONTRACT METRIC (2010) 10 MET and the second (LCO 3.4.12) 2.2.1 The enable temperature for the Low Temperature Overpressure Protection System is 322°F.

2.3 Low Temperature Overpressure Protection System Setpoints

(LCO 3.4.12)

1911

2.0

2.3.1 Pressurizer Power Operated Relief Valve Lift Setting Limits (See Reference 12)

The lift setting for the pressurizer Power Operated Relief Valves (PORVs) is \leq 410 psig (includes instrument uncertainty).

3.0 REACTOR VESSEL MATERIAL SURVEILLANCE PROGRAM

The reactor vessel material irradiation surveillance specimens shall be removed and examined to determine changes in material properties. The removal schedule is provided in Table PTLR - 1. The results of these examinations shall be used to update Figure PTLR - 1 and Figure PTLR - 2.

The pressure vessel steel surveillance program (Ref. 5 as modified by Ref. 10) is in compliance with Appendix H to 10 CFR 50, entitled, "Reactor Vessel Material Surveillance Program Requirements." The material test requirements and the acceptance standard utilize the reference nil-ductility temperature, RT_{NDT} , which is determined in accordance with ASTM E208. The empirical relationship between RT_{NDT} and the fracture toughness of the reactor vessel steel is developed in accordance with Appendix G, "Fracture Toughness Criteria for Protection Against Failure," to section XI of the ASME Boiler and Pressure Vessel Code. The surveillance capsule removal schedule meets the requirements of ASTM E185-82.

 ~ 1.4 or $\sim 10^{10}$ to (6×100) to (6×10^{10}) and (7×10^{10})

As shown by Reference 10 (Appendix D), the reactor vessel material irradiation surveillance specimens indicate that the surveillance data meets the credibility discussion presented in Regulatory Guide 199 Revision 2 where:

1. The capsule materials represent the limiting reactor vessel material.

2. Charpy energy vs. temperature plots scatter are small enough to permit determination of 30 ft-lb temperature and upper shelf energy unambiguously.

3. The scatter of ΔRT_{NDT} values are within the best fit scatter limits as shown on Table PTLR - 2 for the surveillance weld material. The scatter of ΔRT_{NDT} values are not within the best fit scatter limits as shown on Table PTLR - 2 for the Intermediate and Lower Shell Forging materials, which use RG 1.99 Rev. 2 Regulatory Position 1.1.

4. The Charpy specimen irradiation temperature matches the reactor vessel surface interface temperature within $\pm 25^{\circ}$ F.

5. The surveillance data falls within the scatter band of the material database.

这个事情,这些这些事情,这些这个事情,我们的问题,我们就是这些事情,我们的问题。

an an tha an

R.E. Ginna Nuclear Power Plant

PTLR-4 of 16

Revision 6

AND COTE

化学校 水子树枝 计

1.5

(^)

くじゅき

tion the other

A.

	4.0	
1	4.1	The RT _{PTS} value for 53 EFPY post-EPU for Ginna Station limiting beltline material is 275°F for welds and 143°F for forgings per Reference 1.
	4.2	and the main and the main and the second second Tables
	• • * # * «	Capsules, There is the object of the second second and the second of the second second second second second sec Cable PTLR - 1 contains the location and schedule for the removal of surveillance capsules, There is the second
	 	Table PTLR - 2 contains a comparison of measured surveillance material 30 ft-lb transition temperature shifts and upper shelf energy decreases with Regulatory Guide 1.99, Revision 2 predictions.
		Table PTLR - 3 shows calculations of the surveillance material chemistry factors using
		surveillance capsule data.
	QH () · · ·	Table PTER - 4 provides the reactor vesser longinness data. Galacian contract the conditional provides a summary of the fluence values used in the generation of the heatup and cooldown limit curves.
1	4 (· · · · · · · · · · · · · · · · · ·	enAction beaution of a section of the section of the ART values at 53 EFPY) for the line line line line line line line lin
	5.0	en de la Martine en la completa de l REFERENCES de la completa de la comp
	1.	WCAP-17214-NP, Revision 0, "R. E. Ginna Heatup and Cooldown Limit Curves for Normal Operation and Pressurized Thermal Shock Evaluation," dated July 2010.
	2.	WCAP-14040-A, "Methodology Used to Develop Cold Overpressure Mitigating System Setpoints and RCS Heatup and Cooldown Limit Curves," Revision 4, May 2004.
	3.	Letter from R.C. Mecredy, RG&E, to Guy S Vissing, NRC, Subject: "Application for Amendment to Facility Operating License, Revision to Reactor Coolant System (RCS) Pressure and Temperature Limits Report (PTLR) Administrative controls Requirements," dated September 29, 1997.
	4.	Letter from R.C. Mecredy, RG&E, to Guy S. Vissing, NRC, "Clarifications to Proposed Low Temperature Overpressure Protection System Technical Specification," dated June 3, 1997.
	5.	WCAP-7254, "Rochester Gas and Electric, Robert E. Ginna Unit No. 1 Reactor Vessel Radiation Surveillance Program," May 1969.

PTLR-5 of 16

6.	Letter from R.C Mecredy, RG&E, to Guy S. Vissing, NRC, "Corrections to Proposed Low Temperature Overpressure Protection System Technical Specification," October 8, 1997.
7.	WCAP-14684, "R. E. Ginna Heatup and Cooldown Limit Curves for Normal Operation," dated June 1996.
8. √ ^{∼ ′µ}	Letter from M. Korsnick, CEG, to US NRC Document Control Desk, Subject: R. E. Ginna Nuclear Power Plant, Licensee Amendment Request Regarding Extended Power Power Uprate. (Attachment 5 - Licensing Report), dated July 7, 2005.
9. at	CN-RCDA-04-149, Revision 2, "Ginna Extended Power Uprate Program Reactor Vessel Integrity Evaluations."
10.	WCAP-17036-NP, Revision 1, "Analysis of Capsule N from the R. E. Ginna Reactor Vessel Radiation Surveillance Program," dated September 2010.
11.	BAW-1803, Revision 1, "Correlations for Predicting the Effects of Neutron Radiation on Linde 80 Submerged-Arc Welds," dated May 1991.
12. And the second	DA-ME-08-020, Revision 2, "Pressure Temperature Limit Report (PTLR) Supporting Analysis," dated August 5, 2010. The three states are stated as a state of the states of the states of the state
13.	Safety Evaluation by the Office of Nuclear Reactor Regulation Related to Amendment No. 97 to Renewed Facility Operating License No. DPR-18 R. E. Ginna Nuclear Power Plant, Docket No. 50-244.
14.	LTR-AMLRS-10-26, Revision 0, "R. E. Ginna Surveillance Capsule P Withdrawal Recommendations," dated September 9, 2010.
15.	Safety Evaluation by the Office of Nuclear Reactor Regulation Related to Amendment No. 106 to Renewed Facility Operating License No. DPR-18, "R. E. Ginna Nuclear Power Plant, LLC, Docket No. 50-244," U. S. NRC, February 23, 2009.
	ان المالية معن من المعلوم بالكلاية من من من الكلاية في طلقات المعلوم العليمية العليمية العليمية العليمية العلي المعلية معتمانية في المالية العام من من المالية العلي القام وعليه المعلم المالية العليمية العام العليمية العليم المعلية العليمية من من المعلم المالية العام العليمية العليمية العليمية العليمية العليمية العليمية العليمية العل المعلية العليمية من من المعلم المالية العام العليمية العليمية العليمية العليمية العليمية العليمية العليمية العلي
5. 19. 19. 19.	。 《《》:《》:《》:《》:《》:《》:《》:《》:《》:《》:《》:《》:《》:

. 11 . 11.

(22) For ST Standard and the second standard standard standard the second for the second for the second standard st standard stand standard stand standard st standard st standard st standard stand standard stand standard stand standard stand standard stand standard standard standard sta

 ϕ_{\pm} :



Figure PTLR - 1

R. E. Ginna Reactor Coolant System Heatup Limitations (Heatup Rates up to 100°F/hr) Applicable for the First 53 EFPY (Including Normal Instrument Errors) (Reference 12)



Figure PTLR - 2

R. E. Ginna Reactor Coolant System Cooldown Limitations (Cooldown Rates of up to 100°F/hr) Applicable for the First 53 EFPY (Including Normal Instrument Errors) (Reference 12)

PTLR-8 of 16

Capsule	Vessel Location (deg.)	Capsule Lead Factor ^(b)	Removal Schedule EFPY ^(c)	Capsule Fluence E19(n/cm ²) ^(b)
۳ <mark>۷</mark>	7.7°	2.96	1.4 (removed)	0.587
••• R	257°	2.97		····· 1.02
Т	67°	1.82	6.9 (removed)	1.69
S	57°	1.79	17 (removed)	3.64
N	237°	1.82	30.5 (removed)	5.80 x 10 ¹⁹
P	247°	1.90	(d)	(d)

Table PTLR - 1 Surveillance Capsule Removal Schedule^(a)

(a) Reference 10.

٦.,

1700

12

(b) Updated in Capsule N dosimetry analysis

4 : 3

(c) EFPY from plant startup

(d) The latest Capsule P should be removed is shortly after the vessel accumulates a fluence of 39.9 EFPY, which corresponds to a maximum 80 year fluence of 76 EFPY for the Capsule. The earliest withdrawal for Capsule P should be shortly after the vessel accumulates a fluence of 33.9 EFPY. This correlates to acceptable withdrawal for Capsule P at EOC 36, 37, 38, 39, or 40 in order to fulfill the commitment of Reference 13 to pull the final capsule shortly following accumulation of 80 years of fluence. (Reference 10 and Reference 14)

лý

14.

	• · · · • 4.1"			∵ 30 lb-ft Transition (∆R1	Temperature Shift NDT)
· •••••96	Material	Capsule	(x 10 ¹⁹ n/cm ² , E > 1.0 MeV)	Predicted ^(a) (°F)	Measured ^(b) (°F)
		V	0.587	26.4	34.7
		R	1.02	31.2	57.5
· · ·	Lower Shell	т	1.69	35.5	33.6
		S	3.64	41.4	45.8
	·	N.	5,8	44.3	91.1
		V ·	0.587	37.4	0.0 ^(c)
		R	1.02	44.2	20.1
	Intermediate Shell	T Turnet and the second	1.69	50.4	0.0 (c)
		S	3.64	58.8	76.8
یک. دانی	日本では1995年1日。 の「一次10月1日日) の「一次10月1日日日	n na ser anna an anna an Na stàiteanna anna anna an An	5.8	62.9	76.4
	1996 - 1996 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1	V V	0.587	135.2	146.7
	•	R	1.02	159.7	156.2
	Weld Metal	T	1.69	181.8	149.7
		S	3.64	212.1	212.2
		N .	5.8	227.2	216.9
		V	0.587		30.7
		R	1.02		58.6
	HAZ Metal	Т	1.69		41.0
		S	3.64		38.9
•		Ν	5.8		107.7

 Table PTLR - 2

 Surveillance Material 30 ft-lb Transition Temperature Shift

R.E. Ginna Nuclear Power Plant

I

1

1

÷

;

1 .

I

eran egy de la co La canata	weight percent values of copper and nickel of the surveillance material.	J.
(b)	Calculated in Appendix C of Reference 10.	•
,	Measured ΔRT_{NDT} value was determined to be negative, but physically a reduction should not occur, therefore a conservative value of zero is used	

1		
	ਪੁੱਛ ਉਹ ਸੱਸੀ ਕਿ ਇੱਕ ਇੱਕ ਪ੍ਰਤਾਰੀ ਸ	
		:
\$		
· · ·	$ \mathbf{A} _{\mathcal{H}_{2}} = 1 + 2\sum_{i=1}^{n} \mathbf{A} ^{2} + \mathbf{A} ^{$	1
		2
•••		*
•	and the second	
:		
		ŧ
	· · · · · · · · · · · · · · · · · · ·	
	en e	
		· .
• • •		
•		:
· .		
*		
		•
·		
,		

R.E. Ginna Nuclear Power Plant PTLR-11 of 16 Revision 6

.

Material	Capsule	Capsule f ^(a)	FF ^(b)	ʿ∆ŖŦ _{NDT} (c)	Adjusted ∆RT _{NDT} ^(d)	FF*∆RT _{NDT}	FF ²	
1980 - A. 1989	sta V izitez	0.587	0.851	0.0 ^(e)		. 0	0.72	
	R	1.02	1.006	20.10		20.2	1.01	
Intermediate Shell	т	1.69	1.144	0.0 ^(e)		0	1.3 [.]	
Forging 125S255	S	3.64	1.335	76.80		102.6	1.78	
(L-C)	N	5.8	1.430	76.40		109.3	2.04	
					Sum:	232.1	6.87	
	c	F _{125S255} = 2	Σ(FF * ΔRT _N	DT) ÷ $\Sigma(FF^2)$	= (232.1) ÷ (6	6.875) = 33.8°F	:	
	v	0.587	0.851	34.70		29.5	0.72	
• •	R	1.02	1.006	57.50		57.8	1.01	
	т	1.69	1.144	33.60		38.5	1.3	
ower Shell Forging 125P666 (L-C)	S	3.64	1.335	45.80		61.2	1.78	
	N	5.8	1.430	91.10	0-94E	130.3	2.04	
					Sum:	317.3	6.87	
	CF _{125P666} = Σ(FF * ΔRT _{NDT}) ÷ Σ(FF ²) = (317.3) ÷ (6.875) = 46.2°F							
	v	0.587	0.851	146.70	157.0	133.6	0.72	
	R	1.02	1.006	156.20	167.1	168.1	1.01	
Ginna Sunveillance	Т	1.69	1.144	149.70	160.2	183.3	1.31	
Weld Metal (Heat #	S	3.64	1.335	212.20	227.1	303.2	1.78	
61782)	N	5.8	1.430	216.90	232.1	332	2.04	
					Sum:	1120.2	6.87	

R:E2-Ginna Nuclear Power Plant

ł

ľ

364

`4

Revision 6

PTLR

Table PTLR - 3												
alculation	of Che	mistry	Factors	using	R. E.	Ginna	and	Turkey	Point	Surveillance	Capsule D)ata

Material	Capsule	Capsule _f (a)	FF(b)	∆RT _{NDT} (c)	Adjusted ∆RT _{NDT} (d)	FF*∆RT _{NDT}	FF2
	Т	0.599	0.856	163.87	147.50	126.3	, 0.734
Turkey Point	V	1.223	1.056	180.77	162.09	171.2	1.115
Surveillance Weld Materiài (Heat #	×	2.897	1.282	191.06	170.98	219.2	1.644
71249)	-	i di			Sum:	516.8	3.493
· · · ·	CF	Ht. #71249 = Σ	(FF * ∆RT _{ND}	_T) ÷ Σ(FF ²) =	(516.8°F) ÷	(3.493) = 147.9	9°F

(a) $f = fluence (x 10^{19}n/cm^2, E > 1.0 MeV)$ from Table 6-6 of Reference 10 for Ginna data and Table D-5 of Reference 10 for Turkey Point Data.

(b) FF= fluence factor = $f^{(0.28 - 0.1 * \log (f))}$

С

- (c) ∆RT_{NDT} °F values are the measured 30 ft-lb shift values taken from Table 5-10 of Reference 10 for Ginna data and Table D-5 of Reference 10 for Turkey Point data.
- (d) To address the difference in chemistry factor between the surveillance weld and the Ginna vessel weld of the same heat, the surveillance weld metal ΔRT_{NDT} values have been adjusted in accordance with Appendix D of Reference 10 using the chemistry factor ratio of: 1.07 for Heat #61782, and 0.86 for Heat #71249. The chemistry factor ratio for Heat #61782 is derived from Table 2-3 of Reference 14, and for Heat #71249 the ratio is shown in Appendix D of Reference 10. Also, adjustments were made to the measured ΔRT_{NDT} Turkey Point data to account for the operating temperature differences between the Ginna and Turkey Point vessels.

(e) Measured ΔRT_{NDT} value was determined to be negative, but physically a reduction should not occur, therefore a conservative value of zero is used.

R.E. Ginna Nuclear Power Plant

Material Description	Cu (%)	NI (%)	Initial RT _{NDT} (°F)						
Reactor Upper Closure Head Flange	n/a	n/a	0						
Intermediate Shell	.07	.69	20						
Lower Shell	.05	.69	40						
IS to LS Circumferential Weld	.25	.56	-4.8						
Vessel Flange	n/a	n/a	-52						
 Nözzle Shell	0.17 ^(b)	0:68	30						
 NS to IS Circumferential Weld	0.23	0.59	10						

 Table PTLR - 4

 Reactor Vessel Toughness Table (Unirradiated) ^(a)

(a) Per Reference 1Table 2-1 and Table 2-2

(b) The nozzle shell forging weight-percent copper value of 0.17 was taken from Reference 15. Section 3.3, P-T Limits: Staff Evaluation, of Reference 15 states: "The staff determined that an appropriate Cu value for Ginna RPV nozzle forging should be close to 0.17 percent, the highest Cu content for the RPV shell and nozzle forgings of the entire domestic fleet based on the RVID."

PTLR-14 of 16

:

		TADIE FILK - 5		
Reactor Vesse	I Surface Fluence	Values at 30.5 and 53	EFPY ^(a) x 10 ¹⁹ (n/cm ²	, E > 1.0 MeV)
,		1		

C

EFPY	. 0°	15°	30°	45°
30.5	3.20	2.01	1.45	1.31
53	5.56	3.42	2.46	2.30

արտելուտ երանի երանի հարտելու է։ Առաջուտ է հարտելու է հա Առաջուտ երանի հարտելու է հարտելու է

(a) Reference 10 Table 6-2A

l

I

Parameter		Va	lues		
Operating Time		53 E	EFPY		<u>0</u>
Material	Inter. to Lower Shell Circ. Weld	Lower Shell	Inter. to Lower Shell Circ. Weld	Lower Shell	-
Location	1/4-T	1/4-T	3/4-Т	3/4-T	-
Chemistry Factor (CF), °F	162.9	46.2	162.9	46.2	-
-Fluence.(f)-10 ¹⁹ -n/cm ² ·(E->-1-0·MeV)	3.764	3.764	1.726	1.7.26	
-Fluence Factor (EF)	1.3429	1.3429	1.1501		
ΔRT _{NDT} = CF x FF, °F	218.8	62	187.3	53.1	· · · · · · · ·
Initial RT _{NDT} (I), °F	-4.8	40	-4.8	40	• •
Margin (M), °F	48.3	34	48.3	34	-
ART = I + (CFxFF) + M, °F	262	136	231	127	

Table PTLR - 6

Calculation of Adjusted Reference Temperatures at 53 EFPY for the Limiting Reactor Vessel Material^(a)

(a) Per Reference 1 Table 4-2 and 4-3