

MANUAL HARD COPY DISTRIBUTION  
DOCUMENT TRANSMITTAL 2010-40402

---

USER INFORMATION:

GERLACH\*ROSE M           EMPL#: 028401   CA#: 0363  
Address: NUCSA2  
Phone#: 254-3194

TRANSMITTAL INFORMATION:

TO:       GERLACH\*ROSE M       09/22/2010  
LOCATION:   USNRC  
FROM:     NUCLEAR RECORDS DOCUMENT CONTROL CENTER (NUCSA-2)  
THE FOLLOWING CHANGES HAVE OCCURRED TO THE HARDCOPY OR ELECTRONIC MANUAL ASSIGNED TO YOU. HARDCOPY USERS MUST ENSURE THE DOCUMENTS PROVIDED MATCH THE INFORMATION ON THIS TRANSMITTAL. WHEN REPLACING THIS MATERIAL IN YOUR HARDCOPY MANUAL, ENSURE THE UPDATE DOCUMENT ID IS THE SAME DOCUMENT ID YOU'RE REMOVING FROM YOUR MANUAL. TOOLS FROM THE HUMAN PERFORMANCE TOOL BAG SHOULD BE UTILIZED TO ELIMINATE THE CHANCE OF ERRORS.  
ATTENTION: "REPLACE" directions do not affect the Table of Contents, Therefore no TOC will be issued with the updated material.

TRM2 - TECHNICAL REQUIREMENTS MANUAL UNIT 2  
  
REMOVE MANUAL TABLE OF CONTENTS   DATE: 09/02/2010  
  
ADD     MANUAL TABLE OF CONTENTS   DATE: 09/21/2010  
  
CATEGORY: DOCUMENTS   TYPE: TRM2

A001  
NRK

ID: TEXT 3.7.3.8

ADD: REV: 9

REMOVE: REV:8

CATEGORY: DOCUMENTS TYPE: TRM2

ID: TEXT LOES

ADD: REV: 64

REMOVE: REV:63

ANY DISCREPANCIES WITH THE MATERIAL PROVIDED, CONTACT DCS @ X3107 OR X3136 FOR ASSISTANCE. UPDATES FOR HARDCOPY MANUALS WILL BE DISTRIBUTED WITHIN 3 DAYS IN ACCORDANCE WITH DEPARTMENT PROCEDURES. PLEASE MAKE ALL CHANGES AND ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX UPON COMPLETION OF UPDATES. FOR ELECTRONIC MANUAL USERS, ELECTRONICALLY REVIEW THE APPROPRIATE DOCUMENTS AND ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX.

# SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

## Table Of Contents

Issue Date: 09/21/2010

<u>Procedure Name</u>	<u>Rev</u>	<u>Issue Date</u>	<u>Change ID</u>	<u>Change Number</u>
TEXT LOES <b>Title:</b> LIST OF EFFECTIVE SECTIONS	64	09/21/2010		
TEXT TOC <b>Title:</b> TABLE OF CONTENTS	18	07/20/2010		
TEXT 1.1 <b>Title:</b> USE AND APPLICATION DEFINITIONS	0	11/19/2002		
TEXT 2.1 <b>Title:</b> PLANT PROGRAMS AND SETPOINTS PLANT PROGRAMS	1	02/04/2005		
TEXT 2.2 <b>Title:</b> PLANT PROGRAMS AND SETPOINTS INSTRUMENT TRIP SETPOINT TABLE	9	02/12/2010		
TEXT 3.0 <b>Title:</b> APPLICABILITY TECHNICAL REQUIREMENT FOR OPERATION (TRO) APPLICABILITY	4	05/23/2008		
TEXT 3.1.1 <b>Title:</b> REACTIVITY CONTROL SYSTEMS ANTICIPATED TRANSIENT WITHOUT SCRAM ALTERNATE ROD INJECTION (ATWS-ARI) INSTRUMENTATION	1	11/09/2007		
TEXT 3.1.2 <b>Title:</b> REACTIVITY CONTROL SYSTEMS CONTROL ROD DRIVE (CRD) HOUSING SUPPORT	0	11/19/2002		
TEXT 3.1.3 <b>Title:</b> REACTIVITY CONTROL SYSTEMS CONTROL ROD BLOCK INSTRUMENTATION	4	05/14/2009		
TEXT 3.1.4 <b>Title:</b> REACTIVITY CONTROL SYSTEMS CONTROL ROD SCRAM ACCUMULATORS INSTRUMENTATION AND CHECK VALVE	0	11/19/2002		
TEXT 3.2.1 <b>Title:</b> CORE OPERATING LIMITS CORE OPERATING LIMITS REPORT (COLR)	8	05/14/2009		

LDCN

4712

## SSSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.3.1	0	11/19/2002	<b>Title:</b> INSTRUMENTATION RADIATION MONITORING INSTRUMENTATION
TEXT 3.3.2	2	11/09/2007	<b>Title:</b> INSTRUMENTATION SEISMIC MONITORING INSTRUMENTATION
TEXT 3.3.3	2	11/09/2007	<b>Title:</b> INSTRUMENTATION METEOROLOGICAL MONITORING INSTRUMENTATION
TEXT 3.3.4	6	07/09/2010	<b>Title:</b> INSTRUMENTATION TRM POST-ACCIDENT MONITORING INSTRUMENTATION
TEXT 3.3.5	0	11/19/2002	<b>Title:</b> INSTRUMENTATION THIS PAGE INTENTIONALLY LEFT BLANK
TEXT 3.3.6	2	10/19/2005	<b>Title:</b> INSTRUMENTATION TRM ISOLATION ACTUATION INSTRUMENTATION
TEXT 3.3.7	1	11/09/2007	<b>Title:</b> INSTRUMENTATION MAIN TURBINE OVERSPEED PROTECTION SYSTEM
TEXT 3.3.8	1	10/22/2003	<b>Title:</b> INSTRUMENTATION TRM RPS INSTRUMENTATION
TEXT 3.3.9	3	05/14/2009	<b>Title:</b> INSTRUMENTATION LPRM UPSCALE ALARM INSTRUMENTATION
TEXT 3.3.10	1	12/14/2004	<b>Title:</b> INSTRUMENTATION REACTOR RECIRCULATION PUMP MG SET STOPS
TEXT 3.3.11	1	10/22/2003	<b>Title:</b> INSTRUMENTATION MVP ISOLATION INSTRUMENTATION
TEXT 3.3.12	0	04/16/2009	<b>Title:</b> WATER MONITORING INSTRUMENTATION

# SSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.4.1	1	04/26/2006	<b>Title:</b> REACTOR COOLANT SYSTEM REACTOR COOLANT SYSTEM CHEMISTRY
TEXT 3.4.2	1	04/16/2009	<b>Title:</b> REACTOR COOLANT SYSTEM STRUCTURAL INTEGRITY
TEXT 3.4.3	1	11/09/2007	<b>Title:</b> REACTOR COOLANT SYSTEM REACTOR COOLANT SYSTEM (RCS)
TEXT 3.4.4	2	05/14/2009	<b>Title:</b> REACTOR COOLANT SYSTEM REACTOR RECIRCULATION FLOW AND ROD LINE LIMIT
TEXT 3.4.5	1	04/26/2006	<b>Title:</b> REACTOR COOLANT SYSTEM REACTOR VESSEL MATERIALS
TEXT 3.4.6	0	07/20/2010	<b>Title:</b> REACTOR RECIRCULATION SINGLE LOOP OPERATION SLO FLOW RATE RESTRICTION
TEXT 3.5.1	1	02/04/2005	<b>Title:</b> ECCS AND RCIC ADS MANUAL INHIBIT
TEXT 3.5.2	1	11/09/2007	<b>Title:</b> ECCS AND RCIC ECCS AND RCIC SYSTEM MONITORING INSTRUMENTATION
TEXT 3.5.3	0	11/19/2002	<b>Title:</b> ECCS AND RCIC LONG TERM NITROGEN SUPPLY TO ADS
TEXT 3.6.1	0	11/19/2002	<b>Title:</b> CONTAINMENT VENTING OR PURGING
TEXT 3.6.2	0	11/19/2002	<b>Title:</b> CONTAINMENT SUPPRESSION CHAMBER-TO-DRYWELL VACUUM BREAKER POSITION INDICATION
TEXT 3.6.3	0	11/19/2002	<b>Title:</b> CONTAINMENT SUPPRESSION POOL ALARM INSTRUMENTATION

## SSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.6.4 0 11/19/2002  
**Title:** CONTAINMENT PRIMARY CONTAINMENT CLOSED SYSTEM BOUNDARIES

TEXT 3.7.1 0 11/19/2002  
**Title:** PLANT SYSTEMS EMERGENCY SERVICE WATER SYSTEM (ESW) SHUTDOWN

TEXT 3.7.2 0 11/19/2002  
**Title:** PLANT SYSTEMS ULTIMATE HEAT SINK (UHS) AND GROUND WATER LEVEL

TEXT 3.7.3.1 2 04/16/2009  
**Title:** PLANT SYSTEMS FIRE SUPPRESSION WATER SUPPLY SYSTEM

TEXT 3.7.3.2 3 04/16/2009  
**Title:** PLANT SYSTEMS SPRAY AND SPRINKLER SYSTEMS

TEXT 3.7.3.3 3 04/16/2009  
**Title:** PLANT SYSTEMS CO2 SYSTEMS

TEXT 3.7.3.4 2 04/16/2009  
**Title:** PLANT SYSTEMS HALON SYSTEMS

TEXT 3.7.3.5 2 04/16/2009  
**Title:** PLANT SYSTEMS FIRE HOSE STATIONS

TEXT 3.7.3.6 2 04/16/2009  
**Title:** PLANT SYSTEMS YARD FIRE HYDRANTS AND HYDRANT HOSE HOUSES

TEXT 3.7.3.7 1 04/26/2006  
**Title:** PLANT SYSTEMS FIRE RATED ASSEMBLIES

TEXT 3.7.3.8 9 09/21/2010  
**Title:** PLANT SYSTEMS FIRE DETECTION INSTRUMENTATION

TEXT 3.7.4 1 04/26/2006  
**Title:** PLANT SYSTEMS SOLID RADWASTE SYSTEM

# SSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.7.5.1	0	11/19/2002	<b>Title:</b> PLANT SYSTEMS MAIN CONDENSER OFFGAS HYDROGEN MONITOR
TEXT 3.7.5.2	0	11/19/2002	<b>Title:</b> PLANT SYSTEMS MAIN CONDENSER OFFGAS EXPLOSIVE GAS MIXTURE
TEXT 3.7.5.3	1	04/26/2006	<b>Title:</b> PLANT SYSTEMS LIQUID HOLDUP TANKS
TEXT 3.7.6	2	06/27/2008	<b>Title:</b> PLANT SYSTEMS ESSW PUMPHOUSE VENTILATION
TEXT 3.7.7	2	09/05/2008	<b>Title:</b> PLANT SYSTEMS MAIN CONDENSER OFFGAS PRETREATMENT LOGARITHMIC RADIATION MONITORING INSTRUMENTATION
TEXT 3.7.8	6	06/21/2007	<b>Title:</b> PLANT SYSTEMS SNUBBERS
TEXT 3.7.9	1	08/28/2006	<b>Title:</b> PLANT SYSTEMS CONTROL STRUCTURE HVAC
TEXT 3.7.10	1	12/14/2004	<b>Title:</b> PLANT SYSTEMS SPENT FUEL STORAGE POOLS (SFSPS)
TEXT 3.7.11	1	10/02/2009	<b>Title:</b> PLANT SYSTEMS
TEXT 3.8.1	2	02/04/2005	<b>Title:</b> ELECTRICAL POWER PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES
TEXT 3.8.2.1	2	11/09/2007	<b>Title:</b> ELECTRICAL POWER MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - CONTINUOUS
TEXT 3.8.2.2	2	12/14/2004	<b>Title:</b> ELECTRICAL POWER MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - AUTOMATIC

## SSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.8.3	1	04/05/2010	<b>Title:</b> ELECTRICAL POWER DIESEL GENERATOR (DG) MAINTENANCE ACTIVITIES
TEXT 3.8.4	1	02/04/2005	<b>Title:</b> ELECTRICAL POWER 24 VDC ELECTRICAL SUBSYSTEM
TEXT 3.8.5	0	11/19/2002	<b>Title:</b> ELECTRICAL POWER DEGRADED VOLTAGE PROTECTION
TEXT 3.8.6	0	11/19/2002	<b>Title:</b> ELECTRICAL POWER EMERGENCY SWITCHGEAR ROOM COOLING
TEXT 3.8.7	2	10/22/2009	<b>Title:</b> BATTERY MAINTENANCE AND MONITORING PROGRAM
TEXT 3.9.1	0	11/19/2002	<b>Title:</b> REFUELING OPERATIONS DECAY TIME
TEXT 3.9.2	0	11/19/2002	<b>Title:</b> REFUELING OPERATIONS COMMUNICATIONS
TEXT 3.9.3	0	11/19/2002	<b>Title:</b> REFUELING OPERATIONS REFUELING PLATFORM
TEXT 3.10.1	1	04/26/2006	<b>Title:</b> MISCELLANEOUS SEALED SOURCE CONTAMINATION
TEXT 3.10.2	1	04/09/2007	<b>Title:</b> MISCELLANEOUS SHUTDOWN MARGIN TEST RPS INSTRUMENTATION
TEXT 3.10.3	2	06/15/2010	<b>Title:</b> MISCELLANEOUS INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI)
TEXT 3.11.1.1	1	04/26/2006	<b>Title:</b> RADIOACTIVE EFFLUENTS LIQUID EFFLUENTS CONCENTRATION



## SSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.11.1.2	1	04/26/2006	<b>Title:</b> RADIOACTIVE EFFLUENTS LIQUID EFFLUENTS DOSE
TEXT 3.11.1.3	1	04/26/2006	<b>Title:</b> RADIOACTIVE EFFLUENTS LIQUID WASTE TREATMENT SYSTEM
TEXT 3.11.1.4	1	12/14/2004	<b>Title:</b> RADIOACTIVE EFFLUENTS LIQUID RADWASTE EFFLUENT MONITORING INSTRUMENTATION
TEXT 3.11.1.5	2	05/02/2007	<b>Title:</b> RADIOACTIVE EFFLUENTS RADIOACTIVE LIQUID PROCESS MONITORING INSTRUMENTATION
TEXT 3.11.2.1	3	04/26/2006	<b>Title:</b> RADIOACTIVE EFFLUENTS DOSE RATE
TEXT 3.11.2.2	1	04/26/2006	<b>Title:</b> RADIOACTIVE EFFLUENTS DOSE - NOBLE GASES
TEXT 3.11.2.3	1	04/26/2006	<b>Title:</b> RADIOACTIVE EFFLUENTS DOSE - IODINE, TRITIUM, AND RADIONUCLIDES IN PARTICULATE FORM
TEXT 3.11.2.4	0	11/19/2002	<b>Title:</b> RADIOACTIVE EFFLUENTS GASEOUS RADWASTE TREATMENT SYSTEM
TEXT 3.11.2.5	3	11/14/2006	<b>Title:</b> RADIOACTIVE EFFLUENTS VENTILATION EXHAUST TREATMENT SYSTEM
TEXT 3.11.2.6	4	09/16/2009	<b>Title:</b> RADIOACTIVE EFFLUENTS RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION
TEXT 3.11.3	1	04/26/2006	<b>Title:</b> RADIOACTIVE EFFLUENTS TOTAL DOSE
TEXT 3.11.4.1	3	04/26/2006	<b>Title:</b> RADIOACTIVE EFFLUENTS MONITORING PROGRAM

## SSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.11.4.2 2 04/26/2006

**Title:** RADIOACTIVE EFFLUENTS LAND USE CENSUS

TEXT 3.11.4.3 1 04/26/2006

**Title:** RADIOACTIVE EFFLUENTS INTERLABORATORY COMPARISON PROGRAM

TEXT 3.12.1 0 11/19/2002

**Title:** LOADS CONTROL PROGRAM CRANE TRAVEL-SPENT FUEL STORAGE POOL

TEXT 3.12.2 4 04/17/2008

**Title:** LOADS CONTROL PROGRAM HEAVY LOADS REQUIREMENTS

TEXT 3.12.3 0 11/19/2002

**Title:** LOADS CONTROL PROGRAM LIGHT LOADS REQUIREMENTS

TEXT 4.1 0 09/27/2003

**Title:** ADMINISTRATIVE CONTROLS ORGANIZATION

TEXT 4.2 0 09/27/2003

**Title:** ADMINISTRATIVE CONTROLS REPORTABLE EVENT ACTION

TEXT 4.3 0 09/27/2003

**Title:** ADMINISTRATIVE CONTROLS SAFETY LIMIT VIOLATION

TEXT 4.4 1 12/18/2008

**Title:** ADMINISTRATIVE CONTROLS PROCEDURES & PROGRAMS

TEXT 4.5 0 09/27/2003

**Title:** ADMINISTRATIVE CONTROLS REPORTING REQUIREMENTS

TEXT 4.6 0 09/27/2003

**Title:** ADMINISTRATIVE CONTROLS RADIATION PROTECTION PROGRAM

TEXT 4.7 0 09/27/2003

**Title:** ADMINISTRATIVE CONTROLS TRAINING

## SSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.0	4	05/23/2008	<b>Title:</b> APPLICABILITY BASES TECHNICAL REQUIREMENT FOR OPERATION (TRO) APPLICABILITY
TEXT B3.1.1	1	11/09/2007	<b>Title:</b> REACTIVITY CONTROL SYSTEM BASES ANTICIPATED TRANSIENT WITHOUT SCRAM ALTERNATE ROD INJECTION (ATWS-ARI) INSTRUMENTATION
TEXT B3.1.2	0	11/19/2002	<b>Title:</b> REACTIVITY CONTROL SYSTEM BASES CONTROL ROD DRIVE (CRD) HOUSING SUPPORT
TEXT B3.1.3	3	04/10/2007	<b>Title:</b> REACTIVITY CONTROL SYSTEM BASES CONTROL ROD BLOCK INSTRUMENTATION
TEXT B3.1.4	0	11/19/2002	<b>Title:</b> REACTIVITY CONTROL SYSTEM BASES CONTROL ROD SCRAM ACCUMULATORS INSTRUMENTATION AND CHECK VALVE
TEXT B3.2.1	0	11/19/2002	<b>Title:</b> CORE OPERATING LIMITS BASES CORE OPERATING LIMITS REPORT (COLR)
TEXT B3.3.1	0	11/19/2002	<b>Title:</b> INSTRUMENTATION BASES RADIATION MONITORING INSTRUMENTATION
TEXT B3.3.2	1	11/09/2007	<b>Title:</b> INSTRUMENTATION BASES SEISMIC MONITORING INSTRUMENTATION
TEXT B3.3.3	2	11/09/2007	<b>Title:</b> INSTRUMENTATION BASES METEOROLOGICAL MONITORING INSTRUMENTATION
TEXT B3.3.4	4	07/09/2010	<b>Title:</b> INSTRUMENTATION BASES TRM POST ACCIDENT MONITORING (PAM) INSTRUMENTATION
TEXT B3.3.5	2	11/09/2007	<b>Title:</b> INSTRUMENTATION BASES THIS PAGE INTENTIONALLY LEFT BLANK
TEXT B3.3.6	3	10/19/2005	<b>Title:</b> INSTRUMENTATION BASES TRM ISOLATION ACTUATION INSTRUMENTATION

## SSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.3.7	1	11/09/2007	<b>Title:</b> INSTRUMENTATION BASES MAIN TURBINE OVERSPEED PROTECTION SYSTEM
TEXT B3.3.8	1	10/22/2003	<b>Title:</b> INSTRUMENTATION BASES TRM RPS INSTRUMENTATION
TEXT B3.3.9	3	05/14/2009	<b>Title:</b> INSTRUMENTATION BASES LPRM UPSCALE ALARM INSTRUMENTATION
TEXT B3.3.10	2	08/09/2010	<b>Title:</b> INSTRUMENTATION BASES REACTOR RECIRCULATION PUMP MG SET STOPS
TEXT B3.3.11	1	10/22/2003	<b>Title:</b> INSTRUMENTATION BASES MVP ISOLATION INSTRUMENTATION
TEXT B3.3.12	0	04/16/2009	<b>Title:</b> WATER MONITORING INSTRUMENTATION
TEXT B3.4.1	0	11/19/2002	<b>Title:</b> REACTOR COOLANT SYSTEM BASES REACTOR COOLANT SYSTEM CHEMISTRY
TEXT B3.4.2	1	04/16/2009	<b>Title:</b> REACTOR COOLANT SYSTEM BASES STRUCTURAL INTEGRITY
TEXT B3.4.3	1	11/09/2007	<b>Title:</b> REACTOR COOLANT SYSTEM BASES HIGH/LOW PRESSURE INTERFACE LEAKAGE MONITOR
TEXT B3.4.4	0	11/19/2002	<b>Title:</b> REACTOR COOLANT SYSTEM BASES REACTOR RECIRCULATION FLOW AND ROD LINE LIMIT
TEXT B3.4.5	0	11/19/2002	<b>Title:</b> REACTOR COOLANT SYSTEM BASES REACTOR VESSEL MATERIALS
TEXT B3.4.6	0	07/20/2010	<b>Title:</b> REACTOR RECIRCULATION SINGLE LOOP OPERATION SLO FLOW RATE RESTRICTION

## SSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.5.1	0	11/19/2002
<b>Title:</b> ECCS AND RCIC BASES ADS MANUAL INHIBIT		
TEXT B3.5.2	1	11/09/2007
<b>Title:</b> ECCS AND RCIC BASES ECCS AND RCIC SYSTEM MONITORING INSTRUMENTATION		
TEXT B3.5.3	1	11/09/2007
<b>Title:</b> ECCS AND RCIC BASES LONG TERM NITROGEN SUPPLY TO ADS		
TEXT B3.6.1	0	11/19/2002
<b>Title:</b> CONTAINMENT BASES VENTING OR PURGING		
TEXT B3.6.2	0	11/19/2002
<b>Title:</b> CONTAINMENT BASES SUPPRESSION CHAMBER-TO-DRYWELL VACUUM BREAKER POSITION INDICATION		
TEXT B3.6.3	1	04/19/2007
<b>Title:</b> CONTAINMENT BASES SUPPRESSION POOL ALARM INSTRUMENTATION		
TEXT B3.6.4	1	12/14/2004
<b>Title:</b> CONTAINMENT BASES PRIMARY CONTAINMENT CLOSED SYSTEM BOUNDARIES		
TEXT B3.7.1	0	11/19/2002
<b>Title:</b> PLANT SYSTEMS BASES EMERGENCY SERVICE WATER SYSTEM (SHUTDOWN)		
TEXT B3.7.2	0	11/19/2002
<b>Title:</b> PLANT SYSTEMS BASES ULTIMATE HEAT SINK (UHS) GROUND WATER LEVEL		
TEXT B3.7.3.1	3	06/15/2010
<b>Title:</b> PLANT SYSTEMS BASES FIRE SUPPRESSION WATER SUPPLY SYSTEM		
TEXT B3.7.3.2	2	04/26/2006
<b>Title:</b> PLANT SYSTEMS BASES SPRAY AND SPRINKLER SYSTEMS		
TEXT B3.7.3.3	0	11/19/2002
<b>Title:</b> PLANT SYSTEMS BASES CO2 SYSTEMS		

## SSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.7.3.4	1	04/26/2006	<b>Title:</b> PLANT SYSTEMS BASES HALON SYSTEMS
TEXT B3.7.3.5	1	04/26/2006	<b>Title:</b> PLANT SYSTEMS BASES FIRE HOSE STATIONS
TEXT B3.7.3.6	1	04/26/2006	<b>Title:</b> PLANT SYSTEMS BASES YARD FIRE HYDRANTS AND HYDRANT HOSE HOUSES
TEXT B3.7.3.7	0	11/19/2002	<b>Title:</b> PLANT SYSTEMS BASES FIRE RATED ASSEMBLIES
TEXT B3.7.3.8	1	01/12/2004	<b>Title:</b> PLANT SYSTEMS BASES FIRE DETECTION INSTRUMENTATION
TEXT B3.7.4	0	11/19/2002	<b>Title:</b> PLANT SYSTEMS BASES SOLID RADWASTE SYSTEM
TEXT B3.7.5.1	0	11/19/2002	<b>Title:</b> PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS HYDROGEN MONITOR
TEXT B3.7.5.2	0	11/19/2002	<b>Title:</b> PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS EXPLOSIVE GAS MIXTURE
TEXT B3.7.5.3	0	11/19/2002	<b>Title:</b> PLANT SYSTEMS BASES LIQUID HOLDUP TANKS
TEXT B3.7.6	2	06/27/2008	<b>Title:</b> PLANT SYSTEMS BASES ESSW PUMPHOUSE VENTILATION
TEXT B3.7.7	2	01/31/2008	<b>Title:</b> PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS PRETREATMENT LOGARITHMIC RADIATION MONITORING INSTRUMENTATION
TEXT B3.7.8	3	06/21/2007	<b>Title:</b> PLANT SYSTEMS BASES SNUBBERS

## SSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.7.9	1	12/14/2004	<b>Title:</b> PLANT SYSTEMS BASES CONTROL STRUCTURE HVAC
TEXT B3.7.10	1	12/14/2004	<b>Title:</b> PLANT SYSTEMS BASES SPENT FUEL STORAGE POOLS
TEXT B3.7.11	2	04/14/2010	<b>Title:</b> STRUCTURAL INTEGRITY
TEXT B3.8.1	2	03/10/2010	<b>Title:</b> ELECTRICAL POWER BASES PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES
TEXT B3.8.2.1	0	11/19/2002	<b>Title:</b> ELECTRICAL POWER BASES MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - CONTINUOUS
TEXT B3.8.2.2	1	09/17/2004	<b>Title:</b> ELECTRICAL POWER BASES MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - AUTOMATIC
TEXT B3.8.3	0	11/19/2002	<b>Title:</b> ELECTRICAL POWER BASES DIESEL GENERATOR (DG) MAINTENANCE ACTIVITIES
TEXT B3.8.4	0	11/19/2002	<b>Title:</b> ELECTRICAL POWER BASES 24 VDC ELECTRICAL POWER SUBSYSTEM
TEXT B3.8.5	0	11/19/2002	<b>Title:</b> ELECTRICAL POWER BASES DEGRADED VOLTAGE PROTECTION
TEXT B3.8.6	1	02/04/2005	<b>Title:</b> ELECTRICAL POWER BASES EMERGENCY SWITCHGEAR ROOM COOLING
TEXT B3.8.7	1	06/15/2009	<b>Title:</b> BATTERY MAINTENANCE AND MONITORING PROGRAM
TEXT B3.9.1	0	11/19/2002	<b>Title:</b> REFUELING OPERATIONS BASES DECAY TIME

## SSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.9.2	0	11/19/2002	<b>Title:</b> REFUELING OPERATIONS BASES COMMUNICATIONS
TEXT B3.9.3	0	11/19/2002	<b>Title:</b> REFUELING OPERATIONS BASES REFUELING PLATFORM
TEXT B3.10.1	0	11/19/2002	<b>Title:</b> MISCELLANEOUS BASES SEALED SOURCE CONTAMINATION
TEXT B3.10.2	1	04/10/2007	<b>Title:</b> MISCELLANEOUS BASES SHUTDOWN MARGIN TEST RPS INSTRUMENTATION
TEXT B3.10.3	0	11/19/2002	<b>Title:</b> MISCELLANEOUS BASES INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI)
TEXT B3.11.1.1	0	11/19/2002	<b>Title:</b> RADIOACTIVE EFFLUENTS BASES LIQUID EFFLUENTS CONCENTRATION
TEXT B3.11.1.2	0	11/19/2002	<b>Title:</b> RADIOACTIVE EFFLUENTS BASES LIQUID EFFLUENTS DOSE
TEXT B3.11.1.3	0	11/19/2002	<b>Title:</b> RADIOACTIVE EFFLUENTS BASES LIQUID WASTE TREATMENT SYSTEM
TEXT B3.11.1.4	0	11/19/2002	<b>Title:</b> RADIOACTIVE EFFLUENTS BASES LIQUID RADWASTE EFFLUENT MONITORING INSTRUMENTATION
TEXT B3.11.1.5	0	11/19/2002	<b>Title:</b> RADIOACTIVE EFFLUENTS BASES RADIOACTIVE LIQUID PROCESS MONITORING INSTRUMENTATION
TEXT B3.11.2.1	1	12/14/2004	<b>Title:</b> RADIOACTIVE EFFLUENTS BASES DOSE RATE
TEXT B3.11.2.2	0	11/19/2002	<b>Title:</b> RADIOACTIVE EFFLUENTS BASES DOSE - NOBLE GASES



## SSES MANUAL

**Manual Name:** TRM2

**Manual Title:** TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.11.2.3	0	11/19/2002
<b>Title:</b> RADIOACTIVE EFFLUENTS BASES DOSE - IODINE, TRITIUM, AND RADIONUCLIDES IN PARTICULATES FORM		
TEXT B3.11.2.4	0	11/19/2002
<b>Title:</b> RADIOACTIVE EFFLUENTS BASES GASEOUS RADWASTE TREATMENT SYSTEM		
TEXT B3.11.2.5	4	11/14/2006
<b>Title:</b> RADIOACTIVE EFFLUENTS BASES VENTILATION EXHAUST TREATMENT SYSTEM		
TEXT B3.11.2.6	1	01/27/2004
<b>Title:</b> RADIOACTIVE EFFLUENTS BASES RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION		
TEXT B3.11.3	0	11/19/2002
<b>Title:</b> RADIOACTIVE EFFLUENTS BASES TOTAL DOSE		
TEXT B3.11.4.1	3	07/09/2010
<b>Title:</b> RADIOACTIVE EFFLUENTS BASES MONITORING PROGRAM		
TEXT B3.11.4.2	0	11/19/2002
<b>Title:</b> RADIOACTIVE EFFLUENTS BASES LAND USE CENSUS		
TEXT B3.11.4.3	0	11/19/2002
<b>Title:</b> RADIOACTIVE EFFLUENTS BASES INTERLABORATORY COMPARISON PROGRAM		
TEXT B3.12.1	1	10/04/2007
<b>Title:</b> LOADS CONTROL PROGRAM BASES CRANE TRAVEL-SPENT FUEL STORAGE POOL		
TEXT B3.12.2	0	11/19/2002
<b>Title:</b> LOADS CONTROL PROGRAM BASES HEAVY LOADS REQUIREMENTS		
TEXT B3.12.3	0	11/19/2002
<b>Title:</b> LOADS CONTROL PROGRAM BASES LIGHT LOADS REQUIREMENTS		

SUSQUEHANNA STEAM ELECTRIC STATION  
**LIST OF EFFECTIVE SECTIONS** (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 64

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
TOC	TABLE OF CONTENTS	07/15/2010
1.0	USE AND APPLICATION	
	Page TRM / 1.0-1	08/31/1998
	Page TRM / 1.0-2	10/04/2002
	Page TRM / 1.0-3	08/31/1998
2.0	PLANT PROGRAMS	
	Page 2.0-1	08/31/1998
	Pages TRM / 2.0-2 and TRM 2.0-3	01/28/2005
	Page TRM / 2.0-4	06/25/2002
	Page TRM / 2.0-5	04/12/1999
	Page TRM / 2.0-6	04/15/2009
	Page TRM / 2.0-7	05/15/2008
	Page TRM / 2.0-8	04/15/2009
	Page TRM / 2.0-9	11/15/2004
	Page TRM / 2.0-10	02/02/2010
	Page TRM / 2.0-11	11/15/2004
	Page TRM / 2.0-12	04/15/2009
	Pages TRM / 2.0-13 and TRM / 2.0-14	11/15/2004
	Page TRM / 2.0-15	11/15/2005
3.0	APPLICABILITY	
	Pages TRM / 3.0-1 and TRM / 3.0-2	04/14/2008
	Page TRM / 3.0-3	03/15/2002
	Page TRM / 3.0-4	11/30/2005
3.1	REACTIVITY CONTROL SYSTEMS	
	Page TRM / 3.1-1	10/31/2007
	Pages TRM / 3.1-2 through TRM / 3.1-5	08/31/1998
	Page TRM / 3.1-6	03/27/2007
	Page TRM / 3.1-7	04/15/2009
	Page TRM / 3.1-8	03/27/2007
	Pages TRM / 3.1-9 and TRM / 3.1-9a	02/18/1999
	Page TRM / 3.1-10	02/18/1999
3.2	CORE OPERATING LIMITS REPORT	
	Page TRM / 3.2-1	08/31/1998
	Pages TRM / 3.2-2 through TRM / 3.2-54	04/17/2009
3.3	INSTRUMENTATION	
	Pages TRM / 3.3-1 through TRM / 3.3-3	07/16/1999
	Pages TRM / 3.3-4 and TRM / 3.3-5	10/31/2007
	Page 3.3-6	08/31/1998
	Page TRM 3.3-7	10/31/2007
	Page 3.3-8	08/31/1998

**LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)**

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Pages TRM / 3.3-9 and TRM / 3.3-9a	06/30/2010
	Page TRM / 3.3-10	10/31/2007
	Pages TRM / 3.3-11 and TRM / 3.3-11a	06/30/2010
	Page TRM / 3.3-12	03/30/2001
	Page TRM / 3.3-13	09/13/2005
	Page TRM / 3.3-14	12/14/1998
	Page TRM / 3.3-15	10/22/2003
	Page TRM / 3.3-16	06/27/2001
	Page TRM / 3.3-17	06/14/2002
	Page TRM / 3.3-18	10/31/2007
	Pages TRM / 3.3-19 and TRM / 3.3-20	10/22/2003
	Page TRM / 3.3-21	04/15/2009
	Page TRM / 3.3-21a	11/15/2004
	Pages TRM / 3.3-21b through TRM / 3.3-21d	03/27/2007
	Page TRM / 3.3-22	12/03/2004
	Pages TRM / 3.3-23 and TRM / 3.3-24	05/16/2003
	Page TRM / 3.3-25	10/22/2003
	Pages TRM / 3.3-26 and TRM / 3.3-27	04/07/2009
3.4	REACTOR COOLANT SYSTEM	
	Page TRM / 3.4-1	03/31/2006
	Pages 3.4-2 through 3.4-5	10/23/1998
	Pages TRM / 3.4-6 through TRM / 3.4-8	04/01/2009
	Page 3.4-9	08/31/1998
	Page 3.4-10	10/31/2007
	Page 3.4-11	08/31/1998
	Page TRM / 3.4-12	04/17/2009
	Page TRM / 3.4-13	03/31/2006
	Page TRM / 3.4-14	07/15/2010
3.5	EMERGENCY CORE COOLING AND RCIC	
	Page TRM / 3.5-1	01/28/2005
	Pages 3.5-2 and 3.5-3	08/31/1998
	Page TRM / 3.5-4	10/31/2007
	Pages 3.5-5 through 3.5-7	08/31/1998
3.6	CONTAINMENT	
	Pages 3.6-1 through 3.6-4	08/31/1998
	Page TRM / 3.6-5	01/07/2002
	Page 3.6-6	08/31/1998
	Pages TRM / 3.6-7 through TRM / 3.6-9	12/31/2002

**LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)**

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
3.7	PLANT SYSTEMS	
	Pages TRM / 3.7-1 and TRM / 3.7-2	07/29/1999
	Page 3.7-3	08/31/1998
	Page TRM / 3.7-4	03/31/2006
	Page TRM / 3.7-5	04/07/2009
	Pages TRM / 3.7-6 through TRM / 3.7-8	08/02/1999
	Pages TRM / 3.7-9 and TRM / 3.7-10	04/07/2009
	Page TRM / 3.7-11	01/21/2000
	Page TRM / 3.7-12	08/02/1999
	Page TRM / 3.7-13	04/07/2009
	Page TRM / 3.7-14	08/09/2005
	Pages TRM / 3.7-15 and TRM / 3.7-16	08/02/1999
	Page TRM / 3.7-17	04/07/2009
	Page TRM / 3.7-18	08/02/1999
	Page TRM / 3.7-19	04/07/2009
	Pages TRM / 3.7-20 through TRM / 3.7-22	08/02/1999
	Page TRM / 3.7-23	04/07/2009
	Page TRM / 3.7-24	03/31/2006
	Pages TRM / 3.7-25 and TRM / 3.7-26	08/02/1999
	Page TRM / 3.7-27	10/31/2007
	Page TRM / 3.7-28	11/29/2006
	Page TRM / 3.7-29	01/13/2010
	Page TRM / 3.7-30	11/30/2005
	Page TRM / 3.7-31	11/16/2001
	Page TRM / 3.7-32	09/16/2010
	Page TRM / 3.7-33	10/05/2002
	Page TRM / 3.7-34	03/31/2006
	Pages TRM / 3.7-35 and TRM / 3.7-36	02/01/1999
	Pages 3.7-37 through 3.7-38	08/31/1998
	Page TRM / 3.7-39	03/31/2006
	Page TRM / 3.7-40	02/14/2005
	Page TRM / 3.7-40a	06/20/2008
	Page TRM / 3.7-41	09/04/2008
	Page TRM / 3.7-42	08/31/1998
	Pages TRM / 3.7-43 through TRM / 3.7-45	10/05/2006
	Page TRM / 3.7-46	06/07/2007
	Page TRM / 3.7-47	10/05/2006
	Page TRM / 3.7-48	06/07/2007
	Page TRM / 3.7-49	03/09/2001
	Page TRM / 3.7-50	08/16/2006
	Page TRM / 3.7-51	12/03/2004
	Page TRM / 3.7-52	04/15/2003
	Page TRM / 3.7-53	07/29/1999
	Page TRM / 3.7-54	04/01/2009
	Page TRM / 3.7-55	09/25/2009
	Page TRM / 3.7-56	04/01/2009

**LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)**

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
3.8	ELECTRICAL POWER	
	Page TRM / 3.8-1	04/02/2002
	Pages TRM / 3.8-2 and TRM / 3.8-3	01/28/2005
	Page TRM / 3.8-4	01/31/2005
	Pages TRM / 3.8-5 and TRM / 3.8-6	04/02/2002
	Pages TRM / 3.8-7 through TRM / 3.8-10	10/31/2007
	Page TRM / 3.8-11	08/10/2004
	Page TRM / 3.8-12	12/03/2004
	Page TRM / 3.8-13	03/25/2010
	Page TRM / 3.8-14	08/31/1998
	Page TRM / 3.8-15	01/28/2005
	Pages TRM / 3.8-16 and TRM / 3.8-17	04/02/2002
	Page 3.8-18	02/01/1999
	Page TRM / 3.8-19	04/02/2002
	Page TRM / 3.8-20	02/01/1999
	Pages TRM / 3.8-21 through TRM / 3.8-23	06/06/1999
	Pages 3.8-24 and 3.8-25	08/31/1998
	Page TRM / 3.8-26	05/28/2009
	Page TRM / 3.8-27	11/29/2006
	Page TRM / 3.8-28	05/28/2009
	Page TRM / 3.8-29	10/20/2009
3.9	REFUELING OPERATIONS	
	Pages 3.9-1 through 3.9-3	08/31/1998
3.10	MISCELLANEOUS	
	Page TRM / 3.10-1	03/31/2006
	Pages 3.10-2 through 3.10-4	08/30/1998
	Pages TRM / 3.10-5 and TRM / 3.10-6	03/27/2007
	Page TRM / 3.10-7	06/10/2010
3.11	RADIOACTIVE EFFLUENTS	
	Page TRM / 3.11-1	03/31/2006
	Pages 3.11-2 through 3.11-3	08/31/1998
	Page TRM / 3.11-4	03/31/2006
	Page 3.11-5	08/31/1998
	Page TRM / 3.11-6	03/31/2006
	Pages 3.11-7 through 3.11-9	08/31/1998
	Page TRM / 3.11-10	12/03/2004
	Pages 3.11-11 and 3.11-12	08/31/1998
	Page TRM / 3.11-13	04/12/2007
	Page TRM / 3.11-14	12/03/1004
	Pages 3.11-15 and 3.11-16	09/01/1998
	Page TRM / 3.11-17	03/31/2006

**LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)**

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Page 3.11-18	08/31/1998
	Page TRM / 3.11-19	08/15/2005
	Pages TRM / 3.11-20 and TRM / 3.11-21	03/31/2006
	Page TRM / 3.11-22	04/02/2002
	Page TRM / 3.11-23	11/14/2006
	Page TRM / 3.11-24	05/13/2005
	Page TRM / 3.11-25	04/12/2007
	Pages TRM / 3.11-26 and TRM / 3.11-27	01/21/2004
	Page TRM / 3.11-28	09/08/2009
	Page TRM / 3.11-29	12/03/2004
	Pages TRM 3.11-30 through TRM / 3.11-32	01/21/2004
	Page TRM / 3.11-33	03/31/2006
	Page 3.11-34	08/31/1998
	Page TRM / 3.11-35	03/31/2006
	Pages TRM / 3.11-36 through TRM / 3.11-39	11/30/2005
	Pages 3.11-40 through 3.11-44	08/31/1998
	Page TRM / 3.11-45	03/31/2006
	Page 3.11-46	08/31/1998
	Page TRM / 3.11-47	03/31/2006
3.12	LOADS CONTROL PROGRAM	
	Pages TRM / 3.12-1 through TRM / 3.12-3	02/05/1999
	Page TRM / 3.12-4	03/14/2008
	Page TRM / 3.12-5	02/05/1999
4.0	ADMINISTRATIVE CONTROLS	
	Pages TRM / 4.0-1 through TRM / 4.0-3	08/31/1998
	Page TRM / 4.0-4	12/11/2008
	Pages TRM / 4.0-5 through TRM / 4.0-8	08/31/1998

**LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)**

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
B 3.0	APPLICABILITY BASES	
	Pages TRM / B 3.0-1 through TRM / B 3.0-3	08/31/1998
	Page TRM / B 3.0-4	01/10/2007
	Page TRM / B 3.0-5	04/14/2008
	Page TRM / B 3.0-6	08/31/1998
	Page TRM / B 3.0-7	04/12/2007
	Pages TRM / B 3.0-8 through TRM / B 3.0-10	08/31/1998
	Pages TRM / B 3.0-11 and TRM / B 3.0-12	03/15/2002
	Pages TRM / B 3.0-13 and TRM / B 3.0-14	11/30/2005
	Page TRM / B 3.0-15	03/15/2002
B 3.1	REACTIVITY CONTROL SYSTEMS BASES	
	Page TRM / B 3.1-1	07/13/1999
	Pages TRM / B 3.1-2 and TRM / B 3.1-3	10/31/2007
	Page B 3.1-4	08/31/1998
	Pages TRM / B 3.1-5 through TRM / B 3.1-7	03/27/2007
	Page TRM / B 3.1-8	02/18/1999
B 3.2	CORE OPERATING LIMITS BASES	
	Page B 3.2-1	08/31/1998
B 3.3	INSTRUMENTATION BASES	
	Page TRM / B 3.3-1	04/07/2000
	Pages TRM / B 3.3-2 and TRM / B-3.3-2a	10/31/2007
	Pages TRM / B 3.3-3 and TRM / B 3.3-3a	10/31/2007
	Page TRM / B 3.3-4	06/30/2010
	Page TRM / B 3.3-5	05/30/2006
	Page TRM / B 3.3-6	06/30/2010
	Page TRM / B 3.3-7	10/31/2007
	Page TRM / B 3.3-8	06/30/2010
	Page TRM / B 3.3-9	10/31/2007
	Page B 3.3-10	08/31/1998
	Pages TRM / B 3.3-11 and TRM / B 3.3-12	09/13/2005
	Page TRM / B 3.3-13	12/03/2004
	Page TRM / B 3.3-14	06/25/2002
	Page TRM / B 3.3-14a	10/31/2007
	Page TRM / B 3.3-14b	06/14/2002
	Pages TRM / B 3.3-15 through TRM / B 3.3-17	10/22/2003
	Pages TRM / B 3.3-18 and TRM / B 3.3-19	03/27/2007
	Pages TRM / B 3.3-19a and TRM / B 3.3-19b	03/27/2007
	Page TRM / B 3.3-19c	04/17/2009
	Pages TRM / B 3.3-19d and TRM / B 3.3-19e	03/27/2007
	Pages TRM / B 3.3-20 and TRM / B 3.3-21	08/03/2010
	Page TRM / B 3.3-22	10/22/2003
	Page TRM / B 3.3-23	05/16/2003
	Pages TRM / B 3.3-24 and TRM / B 3.3-25	04/07/2009

**LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)**

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
B 3.4	REACTOR COOLANT SYSTEM BASES	
	Page TRM / B 3.4-1	08/31/1998
	Pages TRM / B 3.4-2 and TRM / B3.4-3	04/01/2009
	Pages TRM / B 3.4-4 and TRM / B 3.4-4a	10/31/2007
	Page TRM / B 3.4-5	10/15/1999
	Page B 3.4-6	08/31/1998
	Page TRM / B 3.4-7	07/15/2010
B 3.5	ECCS AND RCIC BASES	
	Pages B 3.5-1 and B 3.5-2	08/31/1998
	Pages TRM / B 3.5-3 and TRM / B 3.5-3a	10/31/2007
	Page B 3.5-4	08/31/1998
	Page TRM / B 3.5-5	10/31/2007
B 3.6	CONTAINMENT BASES	
	Page TRM / B 3.6-1	07/26/2001
	Page TRM / B 3.6-2	02/01/1999
	Page B 3.6-3	08/31/1998
	Page TRM / B 3.6-4	03/29/2007
	Page TRM / B 3.6-5	04/04/2007
	Page TRM / B 3.6-6	12/03/2004
	Pages TRM / B 3.6-7 through TRM / B 3.6-11	12/31/2002
B 3.7	PLANT SYSTEMS BASES	
	Pages B 3.7-1 and B 3.7-2	08/31/1998
	Page TRM / B 3.7-3	06/10/2010
	Page TRM / B 3.7-3a	12/27/2007
	Page TRM / B 3.7-4	03/31/2006
	Page TRM / B 3.7-5	08/02/1999
	Pages TRM / B 3.7-6 and TRM / B 3.7-6a	03/31/2006
	Pages TRM / B 3.7-7 and TRM / B 3.7-7a	08/02/1999
	Page TRM / B 3.7-8	08/02/1999
	Page TRM / B 3.7-9	03/31/2006
	Page TRM / B 3.7-10	08/02/1999
	Pages TRM / B 3.7-10a through TRM / B 3.7-11a	03/31/2006
	Pages TRM / B 3.7-12 through TRM / B 3.7-14	08/02/1999
	Pages TRM / B 3.7-14a and TRM / B 3.7-14b	01/09/2004
	Pages TRM / B 3.7-15 and TRM / B 3.7-16	02/01/1999
	Pages B 3.7-17 through B 3.7-20	08/31/1998
	Page TRM / B 3.7-21	02/14/2005
	Page TRM / B 3.7-21a	06/20/2008
	Pages TRM / B 3.7-22 and TRM / B 3.7-23	01/30/2008
	Pages TRM / B 3.7-24 through TRM / B 3.7-29	10/05/2006



**LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)**

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Page TRM / B 3.7-30	06/07/2007
	Pages TRM / B 3.7-30a and TRM / B 3.7-30b	10/05/2006
	Page TRM / B 3.7-32	03/09/2001
	Page TRM / B 3.7-33	04/15/2003
	Page TRM / B 3.7-34	12/03/2004
	Page TRM / B 3.7-35	07/05/2000
	Pages TRM / B 3.7-36 and TRM / B 3.7-37	04/01/2009
	Page TRM / B 3.7-38	09/25/2009
	Page TRM / B 3.7-39	04/01/2009
	Page TRM / B 3.7-40	04/08/2010
B 3.8	ELECTRICAL POWER BASES	
	Page TRM / B 3.8-1	04/02/2002
	Pages TRM / B 3.8-2 and TRM / B 3.8-2	01/28/2005
	Page TRM / B 3.8-2a	03/01/2010
	Page TRM / B 3.8-3	04/02/2002
	Page TRM / B 3.8-3a	04/02/2002
	Page TRM / B 3.8-4	04/02/2002
	Page TRM / B 3.8-4a	08/10/2004
	Page TRM / B 3.8-5	08/31/1998
	Pages TRM / B 3.8-6 through TRM / B 3.8-16	04/02/2002
	Page TRM / B 3.8-17	01/28/2005
	Pages TRM / B 3.8-18 through TRM / B 3.8-20	11/29/2006
	Pages TRM / B 3.8-21 through TRM / B 3.8-24	05/28/2009
B.3.9	REFUELING OPERATIONS BASES	
	Pages B 3.9-1 and B 3.9-2	08/31/1998
	Pages B 3.9-3 through B 3.9-7	10/23/1998
B 3.10	MISCELLANEOUS BASES	
	Page B 3.10-1	08/31/1998
	Pages TRM / B 3.10-2 and TRM / B 3.10-3	03/27/2007
	Pages TRM / B 3.10-4 and TRM / B 3.10-5	08/23/1999
B 3.11	RADIOACTIVE EFFLUENTS BASES	
	Pages B 3.11-1 through B 3.11-9	08/31/1998
	Page TRM / B 3.11-10	02/01/1999
	Pages TRM/B 3.11-11 and TRM/B 3.11-11a	04/07/2000
	Pages TRM/B 3.11-12 and TRM/B 3.11-13	02/01/1999
	Page TRM / B 3.11-14	12/03/2004
	Page TRM / B 3.11-15	02/01/1999
	Pages B 3.11-16 through B 3.11-19	08/31/1998
	Page TRM / B 3.11-20	04/02/2002
	Page TRM / B 3.11-20a	04/02/2002

**LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)**

---

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Page TRM / B 3.11-21	05/13/2005
	Pages TRM / B 3.11-22 and TRM / B 3.11-23	11/14/2006
	Page TRM / B 3.11-23a	05/13/2005
	Pages TRM / B 3.11-24 and TRM / B 3.11-25	01/21/2004
	Pages B 3.11-26 through B 3.11-27	08/31/1998
	Pages TRM / B 3.11-28 and TRM / B 3.11-29	11/30/2005
	Page TRM / B 3.11-30	06/30/2010
	Pages TRM / B 3.11-31 and TRM / B 3.11-32	08/31/1998
	Page TRM / B 3.11-33	06/30/2010
	Pages TRM / B 3.11-34 and TRM / B 3.11-35	08/31/1998
	Page TRM / B 3.11-36	02/12/1999
B.3.12	LOADS CONTROL PROGRAM BASES	
	Page TRM / B 3.12-1	09/19/2007
	Pages TRM / B 3.12-2 and TRM / B 3.12-3	02/05/1999

TRM2 text LOES.doc  
9/16/2010

3.7.3 Fire Protection

3.7.3.8 Fire Detection Instrumentation

TRO 3.7.3.8 The fire detection instrumentation for each fire detection zone shown in Table 3.7.3.8-1 shall be OPERABLE.

APPLICABILITY: Whenever equipment protected by the fire detection instrument is required to be OPERABLE.

ACTIONS

-----NOTE-----

1. Separate condition entry is allowed for each instrument.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. The number of OPERABLE fire detection instruments less than the Minimum Instruments Operable requirement of Table 3.7.3.8-1	A.1 Establish an hourly fire watch patrol	1 hour
	<u>AND</u> A.2.1 Inspect the accessible zone(s) with inoperable instrument(s)	Once per hour
	<u>OR</u> A.2.2 Inspect the affected area surrounding any inaccessible zones	Once per hour

TECHNICAL REQUIREMENT SURVEILLANCE

SURVEILLANCE	FREQUENCY
--------------	-----------

-----NOTE-----

When a detector is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and required Actions may be delayed for up to 15 minutes to allow for the individual detector trip to clear.

-----

TRS 3.7.3.8.1	Perform CHANNEL FUNCTIONAL TEST on accessible fire detection instruments.	12 months
TRS 3.7.3.8.2	Verify that the supervised circuits supervision associated with the detector alarms of each of the fire detection instruments listed in Table 3.7.3.8-1 are OPERABLE.	12 months
TRS 3.7.3.8.3	Perform CHANNEL FUNCTIONAL TEST on inaccessible fire detection instruments.	Prior to startup from each COLD SHUTDOWN exceeding 48 hours unless performed in the previous 12 months

**TABLE 3.7.3.8-1  
FIRE DETECTION INSTRUMENTATION**

INSTRUMENT LOCATION		ELEV.	INSTRUMENT OPERABLE						
FIRE ZONE	ROOM OR AREA		HEAT		IONIZATION		PHOTO ELECTRIC		
			TOTAL	MIN.	TOTAL	MIN.	TOTAL	MIN.	
<b>a. Control Building</b>									
0-21A	Common Equipment Room Elevator Lobby	656'-0"	NA	NA	1	1	NA	NA	
0-22A	Above Ceiling/Filter Area	687'-8"	NA	NA	10	5	NA	NA	
0-22A	Elevator Lobby	676'-0"	NA	NA	1	1	NA	NA	
0-22A	Chem Lab 0F135 High Temp. Alarm	687'-10"	2	1	NA	NA	NA	NA	
	Chem Lab DS-021	687'-10"	2	1	NA	NA	NA	NA	
	Chem Lab 0F138 High Temp. Alarm	687'-10"	2	1	NA	NA	NA	NA	
	Chem Lab DS-022	687'-10"	2	1	NA	NA	NA	NA	
	Chem Lab 0F141 High Temp. Alarm	687'-10"	2	1	NA	NA	NA	NA	
	Chem Lab DS-023	687'-10"	2	1	NA	NA	NA	NA	
	Chem Lab 0F144 High Temp. Alarm	687'-10"	2	1	NA	NA	NA	NA	
	Chem Lab DS-024	687'-10"	2	1	NA	NA	NA	NA	
0-23	Egress Corridor to South Stairwell	686'-6"	NA	NA	1	1	NA	NA	
0-24A	UPS Panel Room U-2	698'-0"	4	2	2	1	NA	NA	
0-24B	Corridor	698'-0"	NA	NA	3	2	NA	NA	
0-24B	Corridor Elevator Lobby	698'-0"	NA	NA	1	1	NA	NA	
0-24D	U1 Lower Relay Room	698'-0"	4	2	4	2	NA	NA	
0-24E	Computer Room	698'-0"	NA	NA	6	3	NA	NA	
0-24E	Computer Room (Above Ceiling)	698'-0"	12	6	4	2	NA	NA	
0-24E	Computer Room 1U720	697'-0"	NA	NA	4	2	NA	NA	
	PGCC Underfloor 1U722	697'-0"	NA	NA	4	2	NA	NA	
	1U724	697'-0"	NA	NA	4	2	NA	NA	
	1U726	697'-0"	NA	NA	4	2	NA	NA	
	2U721	697'-0"	NA	NA	4	2	NA	NA	
	2U723	697'-0"	NA	NA	4	2	NA	NA	
	2U725	697'-0"	NA	NA	4	2	NA	NA	
	2U727	697'-0"	NA	NA	4	2	NA	NA	
0-24F	Computer Maintenance Rm and Office	698'-0"	NA	NA	2	1	NA	NA	
0-24G	U2 Lower Relay Room	698'-0"	4	2	4	2	NA	NA	
0-24G	U-2 Lower Relay Room 2U704	697'-0"	11	6	6	3	NA	NA	
	PGCC Halon Panel 2U705	697'-0"	11	6	6	3	NA	NA	
	Division II 2U706	697'-0"	11	6	6	3	NA	NA	
	2U731	697'-0"	10	5	6	3	NA	NA	
	2U732	697'-0"	11	6	6	3	NA	NA	

TABLE 3.7.3.8-1								
FIRE DETECTION INSTRUMENTATION								
INSTRUMENT LOCATION			INSTRUMENT OPERABLE					
FIRE ZONE	ROOM OR AREA	ELEV.	HEAT		IONIZATION		PHOTO-ELECTRIC	
			TOTAL	MIN.	TOTAL	MIN.	TOTAL	MIN.
0-24J	South Cable Chase	698'-0"	1	1	NA	NA	NA	NA
0-24L	Center Cable Chase	698'-0"	1	1	NA	NA	NA	NA
0-24M	North Cable Chase	698'-0"	1	1	NA	NA	NA	NA
0-25A	U-2 Lower Cable Spreading Room	714'-0"	20	10	6	3	NA	NA
0-25B	South Cable Chase	714'-0"	1	1	NA	NA	NA	NA
0-25C	Center Cable Chase	714'-0"	1	1	NA	NA	NA	NA
0-25D	North Cable Chase	714'-0"	1	1	NA	NA	NA	NA
0-25E	U-1 Lower Cable Spreading Room	714'-0"	26	13	5	3	NA	NA
0-25E	U-1 Lower Cable Spreading Room Elevator Lobby	714'-0"	NA	NA	1	1	NA	NA
0-26A	Copy Room	729'-1"	NA	NA	1	1	NA	NA
0-26B	South Cable Chase	729'-1"	NA	NA	1	1	NA	NA
0-26C	Center Cable Chase	729'-1"	NA	NA	1	1	NA	NA
0-26D	North Cable Chase	729'-1"	NA	NA	1	1	NA	NA
0-26E	Locker Room	729'-1"	NA	NA	1	1	NA	NA
0-26F	Vestibule Elevator Lobby	729'-1"	NA	NA	1	1	NA	NA
0-26F	Vestibule (Under Floor)	728'-1"	NA	NA	1	1	NA	NA
0-26G	Shift Office	729'-1"	NA	NA	1	1	NA	NA
0-26G	Shift Office (Under Floor)	728'-1"	NA	NA	2	1	NA	NA
0-26H	Control Room (Under Floor Unit 1)	728'-1"	NA	NA	15	8	NA	NA
0-26H	Control Room (Under Floor Unit 2)	728'-1"	NA	NA	12	6	NA	NA
0-26H	Control Room	729'-1"	NA	NA	10	5	NA	NA
0-26H	Control Room (Above Ceiling)	729'-1"	NA	NA	9	5	NA	NA
0-26I	Operational Support Center	729'-1"	NA	NA	1	1	NA	NA
0-26I	Operational Support Center (Under Floor)	728'-1"	NA	NA	2	1	NA	NA
0-26J	Vestibule	729'-1"	NA	NA	1	1	NA	NA
0-26J	Vestibule (Under Floor)	728'-1"	NA	NA	1	1	NA	NA
0-26K	Technical Support Center	741'-1"	NA	NA	NA	NA	10	5
0-26K	Technical Support Center Elevator Lobby	741'-1"	NA	NA	1	1	NA	NA
0-26K	Technical Support Center (Above Ceiling)	741'-1"	NA	NA	5	3	NA	NA
0-26L	Conference Room	741'-1"	NA	NA	NA	NA	6	3
0-26L	Conference Room (Above Ceiling)	741'-1"	NA	NA	2	1	NA	NA
0-26M	U-1 TSC Soffit	729'-1"	NA	NA	2	1	NA	NA
0-26M	U-1 TSC Soffit	741'-1"	NA	NA	2	1	NA	NA
0-26N	U-1 Control Room Soffit	741'-1"	NA	NA	2	1	NA	NA
0-26P	U-2 Control Room Soffit	741'-1"	NA	NA	2	1	NA	NA
0-26R	U-2 TSC Soffit	729'-1"	NA	NA	2	1	NA	NA
0-26R	U-2 TSC Soffit	741'-1"	NA	NA	2	1	NA	NA

**TABLE 3.7.3.8-1  
FIRE DETECTION INSTRUMENTATION**

INSTRUMENT LOCATION			INSTRUMENT OPERABLE						
FIRE ZONE	ROOM OR AREA	ELEV.	HEAT		IONIZATION		PHOTO ELECTRIC		
			TOTAL	MIN.	TOTAL	MIN.	TOTAL	MIN.	
0-26S	South Cable Chase	741'-1"	1	1	NA	NA	NA	NA	
0-26T	Center Cable Chase	741'-1"	1	1	NA	NA	NA	NA	
0-26V	North Cable Chase	741'-1"	1	1	NA	NA	NA	NA	
0-27A	U-2 Upper Relay Room	754'-0"	4	2	3	2	NA	NA	
0-27A	U-2 Upper Relay Room	2U700	753'-0"	11	6	6	3	NA	NA
	PGCC Halon Panel	2U701	753'-0"	11	6	6	3	NA	NA
	Division I	2U702	753'-0"	11	6	6	3	NA	NA
		2U703	753'-0"	11	6	6	3	NA	NA
		2U730	753'-0"	11	6	6	3	NA	NA
0-27B	U-2 Upper Cable Spreading Room	753'-0"	24	12	5	3	NA	NA	
0-27C	U-1 Upper Cable Spreading Room	753'-0"	23	12	7	4	NA	NA	
0-27C	U-1 Upper Cable Spreading Room Elevator Lobby	754'-0"	NA	NA	1	1	NA	NA	
0-27D	Electrician's Office	754'-0"	2	1	1	1	NA	NA	
0-27E	U-1 Upper Relay Room	754'-0"	4	2	2	1	NA	NA	
0-27F	South Cable Chase	754'-0"	1	1	NA	NA	NA	NA	
0-27G	Center Cable Chase	754'-0"	1	1	NA	NA	NA	NA	
0-27H	North Cable Chase	754'-0"	1	1	NA	NA	NA	NA	
0-28A-I	Equipment Room	771'-0"	NA	NA	1	1	NA	NA	
0-28A-II	Equipment Room	771'-0"	NA	NA	3	2	NA	NA	
0-28B-I	Equipment Room	771'-0"	NA	NA	1	1	NA	NA	
0-28B-II	Equipment Room	771'-0"	NA	NA	2	1	NA	NA	
0-28B-II	Equipment Room Elevator Lobby	771'-0"	NA	NA	1	1	NA	NA	
0-28C	Battery Room	771'-0"	NA	NA	1	1	NA	NA	
0-28D	Battery Room	771'-0"	NA	NA	1	1	NA	NA	
0-28E	Battery Room	771'-0"	NA	NA	1	1	NA	NA	
0-28F	Battery Room	771'-0"	NA	NA	1	1	NA	NA	
0-28G	Battery Room	771'-0"	NA	NA	1	1	NA	NA	
0-28H	Repair Shop	771'-0"	NA	NA	2	1	NA	NA	
0-28I	Battery Room	771'-0"	NA	NA	1	1	NA	NA	
0-28J	Battery Room	771'-0"	NA	NA	1	1	NA	NA	
0-28K	Battery Room	771'-0"	NA	NA	1	1	NA	NA	
0-28L	Battery Room	771'-0"	NA	NA	1	1	NA	NA	
0-28M	Battery Room	771'-0"	NA	NA	1	1	NA	NA	

**TABLE 3.7.3.8-1  
FIRE DETECTION INSTRUMENTATION**

INSTRUMENT LOCATION			INSTRUMENT OPERABLE					
FIRE ZONE	ROOM OR AREA	ELEV.	HEAT		IONIZATION		PHOTO ELECTRIC	
			TOTAL	MIN.	TOTAL	MIN.	TOTAL	MIN.
0-28N	Battery Room	771'-0"	NA	NA	1	1	NA	NA
0-28P	South Cable Chase	771'-0"	1	1	NA	NA	NA	NA
0-28Q	Center Cable Chase	771'-0"	1	1	NA	NA	NA	NA
0-28R	North Cable Chase	771'-0"	1	1	NA	NA	NA	NA
0-28T	Battery Room	771'-0"	NA	NA	1	1	NA	NA
0-29A	Elevator Vestibule	783'-0"	NA	NA	1	1	NA	NA
0-29B	H&V Equipment Room	783'-0"	NA	NA	10	5	NA	NA
0-30A	HVAC Equipment Room	806'-0"	NA	NA	19	10	NA	NA
0-30A	Freight Elevator Lobby	806'-0"	NA	NA	1	1	NA	NA
0-30A	CREOASS 0F125A High Temp. Alarm	806'-0"	7	4	NA	NA	NA	NA
0-30A	CREOASS DS-091	806'-0"	7	4	NA	NA	NA	NA
0-30A	CREOASS 0F125B High Temp. Alarm	806'-0"	7	4	NA	NA	NA	NA
0-30A	CREOASS DS-092	806'-0"	7	4	NA	NA	NA	NA
0-30A	SGTS - 0F169A High Temp. Alarm	806'-0"	1	1	NA	NA	NA	NA
0-30A	SGTS - DS-093	806'-0"	1	1	NA	NA	NA	NA
0-30A	SGTS - 0F169B High Temp. Alarm	806'-0"	1	1	NA	NA	NA	NA
0-30A	SGTS - DS-094	806'-0"	1	1	NA	NA	NA	NA
<b>b.</b>	<b>Reactor Building</b>							
2-1A	Core Spray Pump Room	645'-0"	NA	NA	8	4	NA	NA
2-1B	Core Spray Pump Room	645'-0"	NA	NA	6	3	NA	NA
2-1B	Elevator Lobby	645'-0"	NA	NA	1	1	NA	NA
2-1C	HPCI Pump Room	645'-0"	2	1	NA	NA	7	4
2-1D	RCIC Pump Room	645'-0"	2	1	NA	NA	5	3
2-1E	RHR Pump Room	645'-0"	NA	NA	NA	NA	13	7
2-1F	RHR Pump Room	645'-0"	NA	NA	NA	NA	15	8
2-1G	Sump Room	645'-0"	NA	NA	2	1	NA	NA
2-1I	Stairwell 202	645'-818'	NA	NA	2	1	NA	NA
2-2A	Access Area and Remote Shutdown Panel Room	670'-0"	NA	NA	5	3	NA	NA
2-2A	Elevator Lobby	670'-0"	NA	NA	1	1	NA	NA
2-2B	Core Spray Pump Room	670'-0"	NA	NA	11	6	NA	NA
2-3A	Access Area	683'-0"	NA	NA	4	2	NA	NA
2-3A	Access Area Elevator Lobby	683'-0"	NA	NA	1	1	NA	NA
2-3B-N	Equipment Removal Area - North	683'-0"	NA	NA	13	7	NA	NA
2-3B-S	Equipment Removal Area - South	683'-0"	NA	NA	1	1	NA	NA
2-3B-W	Equipment Removal Area - Wraparound	683'-0"	NA	NA	2	1	NA	NA
2-3C-N	Equipment Access Area - North	683'-0"	NA	NA	NA	NA	4	2



**TABLE 3.7.3.8-1  
FIRE DETECTION INSTRUMENTATION**

INSTRUMENT LOCATION		ELEV.	INSTRUMENT OPERABLE					
FIRE ZONE	ROOM OR AREA		HEAT		IONIZATION		PHOTO ELECTRIC	
			TOTAL	MIN.	TOTAL	MIN.	TOTAL	MIN.
2-3C-S	Equipment Access Area - South	683'-0"	NA	NA	NA	NA	4	2
2-3C-W	Equipment Access Area - Wraparound	683'-0"	NA	NA	NA	NA	5	3
2-4A-N	Containment Access Area - North	719'-0"	NA	NA	11	6	3	2
2-4A-S	Containment Access Area - South	719'-0"	NA	NA	10	5	NA	NA
2-4A-S	Containment Access Area Elevator Lobby	719'-0"	NA	NA	1	1	NA	NA
2-4A-W	Containment Access Area - Wraparound	719'-0"	NA	NA	5	3	NA	NA
2-4B	Pipe Penetration Room	719'-1"	NA	NA	1	1	NA	NA
2-4C	Switchgear Room	719'-1"	NA	NA	2	1	NA	NA
2-4D	Switchgear Room	719'-1"	NA	NA	2	1	NA	NA
2-4G	Main Steam Pipeway	719'-1"	NA	NA	NA	NA	4*	2
2-4G	Exhaust Fan Room (Note: these detectors also cover el. 749'-1")	799'-1"	NA	NA	NA	NA	2	1
2-5A-N	Standby Control Systems Area	749'-0"	NA	NA	16	8	7	4
2-5A-S	General Access Area - South	749'-0"	NA	NA	5	3	2	1
2-5A-S	General Access Area Elevator Lobby	749'-0"	NA	NA	1	1	NA	NA
2-5A-W	Access Corridor - Wraparound	749'-0"	NA	NA	3	2	2	1
2-5B	Valve Access Area	761'-10"	NA	NA	NA	NA	4	2
2-5C	RWCU Backwash Tank	749'-1"	NA	NA	NA	NA	1	1
2-5D	RWCU Pumps & Heat Exchangers	749'-1"	NA	NA	NA	NA	8	4
2-5E	Penetration Room	749'-1"	NA	NA	NA	NA	2	1
2-5F	Load Center Room	749'-1"	NA	NA	2	1	NA	NA
2-5G	Load Center Room	749'-1"	NA	NA	2	1	NA	NA
2-5H	Instrument Repair Room	749'-1"	NA	NA	2	1	NA	NA
2-6A	Access Area	779'-1"	NA	NA	11	6	NA	NA
2-6B	Load Center Room	779'-1"	NA	NA	4	2	NA	NA
2-6C	Electrical Equipment Room	779'-1"	NA	NA	2	1	NA	NA
2-6D	H&V Equipment Room	779'-1"	NA	NA	12	6	NA	NA
2-6E	Hatch and Laydown Area	779'-1"	NA	NA	2	1	NA	NA
2-7A	H&V Fan & Filter Rooms	799'-1"	NA	NA	14	7	NA	NA
2-7A	HVAC Filter 2F257A High Temp. Alarm	799'-0"	7	4	NA	NA	NA	NA
2-7A	HVAC Filter 2F257A DS-281	799'-0"	7	4	NA	NA	NA	NA
2-7A	HVAC Filter 2F257B High Temp. Alarm	799'-0"	7	4	NA	NA	NA	NA
2-7A	HVAC Filter 2F257B DS-282	799'-0"	7	4	NA	NA	NA	NA
2-7A	HVAC Filter 2F217A High Temp. Alarm	799'-0"	5	3	NA	NA	NA	NA
2-7A	HVAC Filter 2F217A DS-283	799'-0"	5	3	NA	NA	NA	NA
2-7A	HVAC Filter 2F217B High Temp. Alarm	799'-0"	5	3	NA	NA	NA	NA

\* Inaccessible

**TABLE 3.7.3.8-1  
FIRE DETECTION INSTRUMENTATION**

INSTRUMENT LOCATION		ELEV.	INSTRUMENT OPERABLE					
FIRE ZONE	ROOM OR AREA		HEAT		IONIZATION		PHOTO ELECTRIC	
			TOTAL	MIN.	TOTAL	MIN.	TOTAL	MIN.
2-7A	HVAC Filter 2F217B DS-284	799'-0"	5	3	NA	NA	NA	NA
0-6G	Surge Tank Vault	779'-4"	NA	NA	2	1	NA	NA
0-8A	Refueling Floor	818'-1"	NA	NA	NA	NA	60	30
0-8A	Refueling Floor Elevators	818'-1"	NA	NA	2	1	NA	NA
<b>c.</b>	<b>ESW Pumphouse</b>							
0-51	Pump Room	685'-6"	NA	NA	6	3	NA	NA
0-52	Pump Room	685'-6"	NA	NA	6	3	NA	NA
<b>c.</b>	<b>ESW Pumphouse</b>							
0-51	Pump Room	685'-6"	NA	NA	6	3	NA	NA
0-52	Pump Room	685'-6"	NA	NA	6	3	NA	NA
<b>d.</b>	<b>Diesel Generator Building</b>		<b>HEAT</b>		<b>INFRA-RED</b>		<b>PHOTO-ELECTRIC</b>	
0-41A	Diesel Generator "A" Bay	660'-0" & 677'-0"	22	11	2	1	15	8
		710'-9"	N/A	N/A	N/A	N/A	8	4
0-41B	Diesel Generator "B" Bay	660'-0" & 677'-0"	23	12	2	1	15	8
		710'-9"	N/A	N/A	N/A	N/A	9	5
0-41C	Diesel Generator "C" Bay	660'-0" & 677'-0"	22	11	2	1	15	8
		710'-9"	N/A	N/A	N/A	N/A	8	4
0-41D	Diesel Generator "D" Bay	660'-0" & 677'-0"	22	11	2	1	15	8
		710'-9"	N/A	N/A	N/A	N/A	8	4
<b>e.</b>	<b>Diesel Generator E Building</b>		<b>HEAT</b>		<b>INFRA-RED</b>		<b>IONIZATION</b>	
0-41E	Diesel Generator Rooms	656'-6" &	1	1	NA	NA	21	11
		675'-6" &	NA	NA	6	3	3	2
		708'-0"	NA	NA	4	2	NA	NA
<b>f.</b>	<b>Outside Area</b>		<b>HEAT</b>		<b>IONIZATION</b>		<b>PHOTO-ELECTRIC</b>	
0-00	Startup Transformer (0X103) DS-014	NA	10	5	NA	NA	NA	NA
0-00	Startup Transformer (0X104) DS-015	NA	12	6	NA	NA	NA	NA
0-00	ESS Transformer – DS-016 0X201 0X 213	NA	6	3	NA	NA	NA	NA
		NA	6	3	NA	NA	NA	NA
0-00	ESS Transformer – DS-017 0X203 0X211	NA	6	3	NA	NA	NA	NA
		NA	6	3	NA	NA	NA	NA