


Calculation Cover Sheet

Project CMP Pits Electrical Resistance Heating/Soil Vapor Extraction		Calculation No. M-CLC-G-00344	Project No. 1201	
Title CMP Pits Soil Vapor Extraction (SVE) Wells Flow Analysis		Functional Classification GS	Sheet 1 of 43	
		Discipline Mechanical		
Calc Level <input checked="" type="checkbox"/> Type 1 <input type="checkbox"/> Type 2		Type 1 Calc Status <input type="checkbox"/> Preliminary <input checked="" type="checkbox"/> Confirmed		
Computer Program No. Crane Companion (EA1C-M-202V) <input type="checkbox"/> N/A		Version/Release No. 3.65		
Purpose and Objective The purpose of this calculation is to;				
<ol style="list-style-type: none"> 1. Determine the heat loss associated with the piping and the rubber hoses. 2. Determine the head loss across the CMP Pits SVE wellheads and connecting piping to the Heat Exchanger Skid. 				
Summary of Conclusion 1. The heat loss from the piping/hose arrangement will be between 46.08 and 74.48 BTU/lbm. Note: The heat loss from the piping/hose arrangement will be used to determine the potential amount of condensate that will accumulate in the piping/hoses for collection tank sizing. 2. The head loss across the system (well head to inlet of heat exchanger) will be approximately 1.55 "Hg. The pressure at the heat exchanger skid inlet will need to be 22.45 "Hg absolute to provide sufficient vacuum for system.				
ENGINEERING DOC. CONTROL - SRS  00787844				
Revisions				
Rev No.	Revision Description			
0	Initial issue			
Sign Off				
Rev No.	Originator (Print) Sign/Date	Verification/ Checking Method	Verifier/Checker (Print) Sign/Date	Manager (Print) Sign/Date
0	Chris Schilling <i>Chris Schilling 4/26/05</i>	DESIGN REVIEW	Michael Layman <i>Michael Layman 4/26/05</i>	Damon Hulley <i>Damon Hulley 4/27/05</i>
Design Authority -- (Print) N/A		Signature N/A		Date N/A
Release to Outside Agency - (Print) N/A		Signature N/A		Date N/A
Security Classification of the Calculation UNCLASSIFIED				

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 2 of 43	Rev. 0
----------------------------------	----------------------	-----------

TABLE OF CONTENTS

1.0	OPEN ITEMS	3
2.0	REFERENCES	3
3.0	ASSUMPTIONS.....	3
4.0	INPUT.....	4
5.0	ANALYTICAL METHODS AND COMPUTATIONS.....	4
6.0	RESULTS.....	39
7.0	CONCLUSION.....	40
8.0	ATTACHMENTS.....	40

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 3 of 43	Rev. 0
----------------------------------	----------------------	-----------

1.0 OPEN ITEMS

1.1 NONE

2.0 REFERENCES

- 2.1 Q-MT-L-00001, Rev. 1 Redline, Modification Traveler For Chemicals, Metals, Pesticides (CMP) Electrical Resistance Heating/Soil Vapor Extraction (U).
- 2.2 M-CLC-G-00341, Rev. 0, Fluid Analysis for 500 kW Heating Operation With a 100 Ton Cooling Tower.
- 2.3 Fundamentals of Classical Thermodynamics, John Wiley & Sons, Van Wylen et al, 4th Edition, 1994.
- 2.4 Flow of Fluids Through Valves, Fittings, and Pipe, Technical Paper No. 410, Crane Co., 1988.
- 2.5 Elements of Heat Transfer, McGraw-Hill, Bayazitoglu and Özişik, 1988.
- 2.6 2001 ASHRAE Fundamentals Handbook, Chapter 27, Climatic Design Information.

3.0 ASSUMPTIONS

- 3.1 There will be an upper and lower heating zone consisting of four discreet heating campaigns:
 - 3.1.1 Lower zone – will consist of seven electrodes. Each electrode has an upper and lower electrode plate. The lower electrode plates will be energized during the first heating campaign. The second heating campaign will involve removing the electrical wiring from the connectors of the lower electrode plates and attaching them to the upper electrode plate connectors (see Attachments 8.1 & 8.3).
 - 3.1.2 Upper zone – will consist of nine electrodes. Six electrodes will have an upper and lower electrode plates. The center electrode will only have a lower electrode plate. The remaining two electrodes will only have upper electrode plates. The remaining two heating campaigns will be similar to the lower zone with the exception of using eight electrodes when heating the soil with the upper electrode plates (see Attachments 8.1 & 8.3).
- 3.2 The new wells (defined in Ref. 2.1) not actively being heated during the four heating campaigns will be online and throttled, as necessary, in order to prevent exceeding the operational limits of the Soil Vapor Extraction (SVE) components (e.g., blower, heat exchanger, etc.) and minimize the generation of condensate in the SVE hose/piping due to mixing of steam vapor with non-heated wells.
- 3.3 The results presented in Ref. 2.2 will be used as input for the computations.
- 3.4 Heat loss computations will use an ambient temperature of 21°F and 96°F and a mean wind speed of 5 miles per hour (Ref. 2.6, Table 1A & 1B, for Augusta, GA).

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 4 of 43	Rev. 0
----------------------------------	----------------------	-----------

- 3.5 Rubber hose, CPVC pipe and carbon steel pipe have the same inside and outside dimensions.
- 3.6 The air introduced by the non-heated wells will be considered at 60°F (temperature of the ground). The steam vapor will be considered saturated at 200°F, 24" Hg absolute.

4.0 INPUT

4.1 Air

- 4.1.1 Molecular Mass (M) = 28.97, Ref. 2.3 (Table A.10E)
- 4.1.2 Specific Heat Ratio (k) = 1.400, 80°F, Ref. 2.3 (Table A.10E)
- 4.1.3 Volumetric flow rate of air (Q_a) from heated SVE wells = 213 ft³/min @ 200°F & 24" Hg abs., Ref. 2.2
- 4.1.4 Density of air (ρ_{a200}) = 0.05995 lbm/ft³, @ 29.92" Hg abs. and 200°F, Ref. 2.5 (Table B-1)
- 4.1.5 Density of air ($\rho_{a200,24}$) = $\rho_{a200} \cdot (24" \text{Hg} / 29.92" \text{Hg}) = 0.04809 \text{ lbm/ft}^3$, @ 24" Hg abs. and 200°F
- 4.1.6 Mass flow rate of air (\dot{m}_{a200}) from heated SVE wells = $Q_a \cdot \rho_{a200,24} = 10.243 \text{ lbm/min}$

4.2 Steam Vapor

- 4.2.1 Molecular Mass (M) = 18.015, Ref. 2.3 (Table A.10E)
- 4.2.2 Specific Heat Ratio (k) = 1.327, 80°F, Ref. 2.3 (Table A.10E)
- 4.2.3 Viscosity, saturated (μ_s) = 0.010 Cp, Ref. 2.4 (A-2)
- 4.2.4 Volumetric flow rate (Q_s) = 856 ft³/min @ 200°F & 24" Hg abs., Ref. 2.2, page 6
- 4.2.5 Specific volume of saturated steam (v_g) = 33.631 ft³/lbm @ 200°F & 24" Hg, Ref. 2.3 (Table A.1E)
- 4.2.6 Mass flow rate (\dot{m}_s) = $Q_s / v_g = 25.45 \text{ lbm/min}$ (1,527 lbm/hr)

5.0 ANALYTICAL METHODS AND COMPUTATIONS

5.1 Analytical methods

- 5.1.1 The heat loss of the pipe and hose will be performed using standard heat transfer methodology (i.e., hollow cylinder, convection at both boundaries). The basic pipe sizes will be 2" (carbon steel & rubber hose), 4" (CPVC) and 6" (CPVC & rubber hose) SCH 40. Only piping/hoses flowing steam will be evaluated.
- 5.1.2 The head loss calculation will be performed using the Crane Companion software (version 3.65). The piping arrangement and general drawings (Attachments 8.1 and 8.2) will be used as the source for approximate pipe/hose lengths, valves and fittings. The flow rate will be based on the results of Ref. 2.2 and the flow rate of air introduced into the system from the other SVE wells.

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 5 of 43	Rev. 0
----------------------------------	----------------------	-----------

5.2 Computations

5.2.1 Heat loss of the pipe and hose

5.2.1.1 Pipe and hose dimensions, Ref. 2.4 (pages B16 & B17)

Pipe Size (nominal)	I.D. (inches)	O.D. (inches)
2"	2.067	2.375
4"	4.026	4.500
6"	6.065	6.625

5.2.1.2 Reynolds Number for flow conditions.

The following equation will be used to determine the Reynolds Number (Re_{in}) for the steam flow in the hose and piping.

$$Re_{in} = 6.31 \left(\frac{\dot{m}_s}{I.D. \cdot \mu_s} \right) \quad \text{Ref. 2.4, equation 3-3}$$

The Reynolds Numbers for the steam flow in the various hose and pipe sizes are presented in **TABLE 1**.

Nominal Pipe Size	\dot{m}_s (lbm/hr)	I.D. (inches)	μ_s (Cp)	Re_{in} (unitless)
2"	218 ^{note 1}	2.067	0.010	66,550
4"	1,089 ^{note 2}	4.026	0.010	170,680
6"	1,525	6.065	0.010	158,660

Notes: 1. Flow rate based on seven electrodes
2. Flow rate based on five electrodes (lower zone)

The following equation will be used to determine the Reynolds Number (Re_{out21} & Re_{out96}) for the air flow around the pipe and hose. Conditions are evaluated at the film temperature (T_{f21} & T_{f96}). Results are presented in **TABLE 2**.

$$T_f = \frac{(T_w + T_\infty)}{2}$$

Where:

$$T_w = 200^\circ\text{F}$$

$$T_{\infty \text{ low temp}} = 21^\circ\text{F}, \text{ therefore, } T_{f21} = 110.5^\circ\text{F}$$

$$T_{\infty \text{ hi temp}} = 96^\circ\text{F}, \text{ therefore, } T_{f96} = 148^\circ\text{F}$$

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 6 of 43	Rev. 0
----------------------------------	----------------------	-----------

$$Re_{out} = \frac{u_{\infty} O.D.}{\nu_a} \quad \text{Ref. 2.5, equation 7-38}$$

Where:

$\nu_{a21} = 1.812 \times 10^{-5} \text{ m}^2/\text{s} = 1.950 \times 10^{-4} \text{ ft}^2/\text{s}$, Diffusivity of air @ 110°F, Ref. 2.5, Table B-1
 $\nu_{a96} = 1.978 \times 10^{-5} \text{ m}^2/\text{s} = 2.129 \times 10^{-4} \text{ ft}^2/\text{s}$, Diffusivity of air @ 148°F, Ref. 2.5, Table B-1
 $u_{\infty} = 5 \text{ miles per hour} = 7.33 \text{ ft/s}$, Assumption 3.4

Nominal Pipe Size	ν_{a21} (ft ² /s)	ν_{a96} (ft ² /s)	u_{∞} (ft/s)	O.D., (feet)	Re_{out21}	Re_{out96}
2"	1.950×10^{-4}	2.129×10^{-4}	7.33	0.1979	7,442	6,817
4"	1.950×10^{-4}	2.129×10^{-4}	7.33	0.3750	14,103	12,917
6"	1.950×10^{-4}	2.129×10^{-4}	7.33	0.5521	20,763	19,017

5.2.1.3 Convective Heat Transfer Coefficient (h), BTU/(hr*ft²*°F)

The following relationship will be used to determine h_{in} for the steam flow in the piping and hoses.

$$Nu = \frac{h_{in} \cdot I.D.}{k_s} = 0.023 \cdot Re_{in}^{0.8} \cdot Pr_s^n \quad \text{Ref. 2.5, equation 8-35}$$

Note: $n = 0.3$, due to process is cooling, Ref. 2.5, pg 253.

The following relationship will be used to determine h_{out} for the air flow over the piping and hoses.

$$Nu_m = 0.3 + \frac{0.62 Re_{out@temp}^{1/2} Pr_a^{1/3}}{\left[1 + (0.4/Pr_a)^{1/4}\right]^{1/4}} \left[1 + \left(\frac{Re_{out@temp}}{282,000}\right)^{4/5}\right]^{1/5} = \frac{h_{out} O.D.}{k_a} \quad \text{Ref. 2.5, equation 7-40}$$

Where (Ref. 2.5, Table B-1):

$k_{a21} = 0.02748 \text{ W}/(\text{m}^{\circ}\text{K}) = 0.01588 \text{ BTU}/(\text{hr}^{\circ}\text{ft}^{\circ}\text{F})$, Thermal conductivity of air @ 110°F
 $k_{a96} = 0.02908 \text{ W}/(\text{m}^{\circ}\text{K}) = 0.01681 \text{ BTU}/(\text{hr}^{\circ}\text{ft}^{\circ}\text{F})$, Thermal conductivity of air @ 148°F
 $k_s = 0.0246 \text{ W}/(\text{m}^{\circ}\text{K}) = 0.0142 \text{ BTU}/(\text{hr}^{\circ}\text{ft}^{\circ}\text{F})$, Thermal conductivity of steam @ 380K
 $Pr_{a21} = 0.704$, Prandtl number of air @ 110°F
 $Pr_{a96} = 0.700$, Prandtl number of air @ 148°F
 $Pr_s = 1.060$, Prandtl number of steam @ 380K

The values for h_{in} , h_{out21} , and h_{out96} for the various pipe/hose sizes are presented in **TABLE 3**.

Pipe size	Re_{out21}	Re_{out96}	Re_{in}	h_{out21} BTU/(hr*ft ² *°F)	h_{out96} BTU/(hr*ft ² *°F)	h_{in} BTU/(hr*ft ² *°F)
2	7,442	6,817	66,550	3.65	3.67	13.93
4	14,103	12,917	170,680	2.74	2.76	15.19
6	20,763	19,017	158,660	2.32	2.33	9.51

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 7 of 43	Rev. 0
----------------------------------	----------------------	-----------

5.2.1.4 Heat loss of piping and hoses

The following equation will be used to determine the heat loss per foot of pipe and hose.

$$\dot{q} = \frac{T_{\infty in} - T_{\infty out}}{(R_{\infty in} + R_{cyl} + R_{\infty out}) \cdot \frac{60 \text{ min}}{\text{hr}}} \quad \text{Ref. 2.5, equation 4-32}$$

Where:

$$R_{\infty in} = \frac{1}{2\pi a H h_{in}}$$

$$R_{cyl} = \frac{\ln\left(\frac{b}{a}\right)}{2\pi k_{\text{pipe or hose}} H}$$

Ref. 2.5, equations 4-33a, b & c

$$R_{\infty out} = \frac{1}{2\pi b H h_{out}}$$

Where;

b = 1/2 * O.D., ft

a = 1/2 * I.D., ft

H = length of piping or hose, ft

k_{pipe} = 52 W/(m°C) = 30 BTU/(hr*ft°F), Carbon Steel @ 100°C, Ref. 2.5, Table B-4

k_{CPVC} = 0.137 W/(m°C) = 0.0792 BTU/(hr*ft°F), CPVC @ 25°C, Attachment 8.3

k_{hose} = 0.012 W/(m°C) = 0.00693 BTU/(hr*ft°F), soft rubber @ 30°C, Ref. 2.5, Table B-6

Solving for \dot{q}/H , BTU/(ft*min), the heat loss rate per foot for the various pipe and hose sizes are presented in **TABLE 4**.

TABLE 4			
Temperature = 21°F			
Material	Nominal Pipe Size		
	2"	4"	6"
Carbon Steel Pipe	5.20	N/A	N/A
CPVC Pipe	N/A	4.59	5.03
Rubber Hose	0.79	N/A	0.85
Temperature = 96°F			
Material	Nominal Pipe Size		
	2"	4"	6"
Carbon Steel Pipe	3.04	N/A	N/A
CPVC Pipe	N/A	2.67	2.92
Rubber Hose	0.46	N/A	0.50

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 8 of 43	Rev. 0
----------------------------------	----------------------	-----------

5.2.2 Additional heat loss due to mixing

Since the air from the non-heated SVE wells will mix with the steam vapor, the amount of air will need to be throttled to prevent exceeding the blower capacity (1000 cfm). Ref. 2.2 limits the amount of dilution air to 300 cfm, Q_a . However, the SVE wells for the non-heated zone will also be drawing air. Therefore, the air from the non-heated SVE wells in the heated zone will be limited to 100 cfm, with the remaining 200 cfm for the non-heated zone SVE wells.

The first law of thermodynamics, steady flow system, will be used to determine the heat loss of the air/steam vapor mixture.

Where:

$h_{g200} = 1145.9$ BTU/lbm, enthalpy of saturated steam @ 200°F, Ref.2.3, Table A.1E

$h_{gf200} = 977.90$ BTU/lbm, latent heat of condensation @ 200°F, Ref.2.3, Table A.1E

$h_{f200} = 168.07$ BTU/lbm, enthalpy of water @ 200°F, Ref.2.3, Table A.1E

$h_{a60} = 124.383$ BTU/lbm, enthalpy of air @ 60°F, Ref.2.3, Table A.12E

$h_{a200} = 158.038$ BTU/lbm, enthalpy of air @ 200°F, Ref.2.3, Table A.12E

The mass flow rate for the air (\dot{m}_a) is as follows (continuity equation);

$$\dot{m}_a = Q_a \cdot \rho_{a200,24} = 100 \frac{\text{ft}^3}{\text{min}} \cdot 0.04809 \frac{\text{lbm}}{\text{ft}^3} = 4.81 \frac{\text{lbm}}{\text{min}}$$

Using the first law of thermodynamics, constant temperature (i.e., 200°F) the reduction in the enthalpy of the steam vapor is derived as follows.

$$\dot{q}_m = \dot{q}_s - \dot{q}_{a60 \text{ to } 200}$$

$$\dot{m}_s h_m = \dot{m}_s h_{g200} - \dot{m}_{a60} (h_{a200} - h_{a60})$$

$$h_m = \frac{\dot{m}_s h_{g200} - \dot{m}_{a60} (h_{a200} - h_{a60})}{\dot{m}_s}$$

$$h_m = \frac{(25.45 \frac{\text{lbm}}{\text{min}} \cdot 1145.9 \frac{\text{BTU}}{\text{lbm}}) - 4.81 \frac{\text{lbm}}{\text{min}} (158.038 \frac{\text{BTU}}{\text{lbm}} - 124.383 \frac{\text{BTU}}{\text{lbm}})}{25.45 \frac{\text{lbm}}{\text{min}}} = 1139.5 \frac{\text{BTU}}{\text{lbm}}$$

Note: subscripts are as follows;

m – mixture of steam and with cooler air

a – air

s – steam vapor

The change in enthalpy of the steam is $1145.9 - 1139.5 = 6.4$ BTU/lbm

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 9 of 43	Rev. 0
----------------------------------	----------------------	-----------

5.2.3 Total heat loss prior to entering the heat exchanger inlet

Based on the piping arrangement and well heads (Attachment 8.1 & 8.2) the heat loss due to convection is as follows, TABLE 5. The mass flow rates are based on the flow rates of TABLE 1. However, the flow rate through the 4" CPVC pipe, 45 foot length, is evaluated at a flow rate of 7.24 lbm/min (i.e., $25.45 - 18.18 = 7.24$ lbm/min).

TABLE 5								
Nominal Pipe Size	H, ft (Approx.)	$\dot{m}, \frac{\text{lbm}}{\text{min}}$	$\frac{\dot{q}}{H_{21}}, \frac{\text{BTU}}{\text{ft-min}}$	$\frac{\dot{q}}{H_{96}}, \frac{\text{BTU}}{\text{ft-min}}$	$\dot{q}_{21}, \frac{\text{BTU}}{\text{min}}$	$\dot{q}_{96}, \frac{\text{BTU}}{\text{min}}$	$\Delta h_{21}, \frac{\text{BTU}}{\text{lbm}}$	$\Delta h_{96}, \frac{\text{BTU}}{\text{lbm}}$
2" Carbon Steel Pipe	7	3.64	5.20	3.04	36.40	21.28	10.00	5.85
2" Rubber Hose	6	3.64	0.79	0.46	4.74	2.76	1.30	0.76
4" CPVC Pipe	51	18.18	4.59	2.67	234.09	136.17	12.88	7.49
4" CPVC Pipe	45	7.24	4.59	2.67	206.55	120.15	28.53	16.60
6" CPVC Pipe	15	25.45	5.03	2.92	75.45	43.80	2.96	1.72
6" CPVC Pipe	29	25.45	5.03	2.92	145.87	84.68	5.73	3.33
6" Rubber Hose	200	25.45	0.85	0.50	170.00	100.00	6.68	3.93
Change in Enthalpy of the steam (BTU/lbm) (line losses)							68.08	39.68
Change in Enthalpy of the steam (BTU/lbm) (mixing losses)							6.4	6.4
Total change is Enthalpy of steam (BTU/lbm)							74.48	46.08

5.2.4 Head loss from SVE well outlets to heat exchanger inlet

5.2.4.1 Mass Flow rates

Determination of the head loss in the piping and hoses will be based on the mass flow rates of air from the non-heated SVE wells and steam vapor/air from the heated SVE wells. The steam vapor mass flow rate will be 25.45 lbm/min steam vapor, section 4.2.6, and the heated air mass flow rate will be 10.243 lbm/min, section 4.1.6, divided evenly to the SVE wells being heated (total of 35.69 lbm/min). The mass flow rate of air will be 4.81 divided evenly to the non-heated SVE wells. A review of the heating campaigns (Attachment 8.3) illustrates that either of the campaigns of the lower zone will create the greatest flow for the heated and non-heated SVE wells.

5.2.4.2 Derived inputs for Crane Companion software

5.2.4.2.1 Molecular Weights

The weighted molecular weight (M_w) of the air and steam vapor in the main header, 4" & 6" pipe/hose, is as follows:

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 10 of 43	Rev. 0
----------------------------------	-----------------------	-----------

$$M_w = M_a \frac{\dot{m}_{a60} + \dot{m}_{a200}}{\sum \dot{m}} + M_s \frac{\dot{m}_s}{\sum \dot{m}} \quad (\text{conservation of mass})$$

$$M_w = 28.97 \cdot \frac{(4.81 + 10.243)}{40.503} + 18.015 \cdot \frac{25.45}{40.503} = 22.09$$

The weighted molecular weight (M_{w2}) of the air and steam vapor in the heated SVE well head pipe/hose is as follows:

$$M_{w2} = M_a \frac{\dot{m}_{a200}}{\sum \dot{m}} + M_s \frac{\dot{m}_s}{\sum \dot{m}}$$

$$M_{w2} = 28.97 \cdot \frac{10.243}{35.69} + 18.015 \cdot \frac{25.45}{35.69} = 21.16$$

5.2.4.2.2 Specific Heat Ratio (k)

The specific heat ratio for steam (assumed an ideal gas) will be as follows.

$$C_p = \left(\frac{\partial h}{\partial T} \right)_p \approx \left(\frac{\Delta h}{\Delta T} \right)_p$$

Ref. 2.3, page 110, equations 5.14 & 5.15

$$C_v = \left(\frac{\partial u}{\partial T} \right)_v \approx \left(\frac{\Delta u}{\Delta T} \right)_v$$

Where;

“h” is enthalpy,

“u” is internal energy

“T” is temperature

Evaluating at 80°F and 200°F, the following is derived (Ref. 2.3, Table A.1E).

h_{g200}	= 1145.9	BTU/lbm
h_{g80}	= 1096.4	BTU/lbm
u_{g80}	= 1037	BTU/lbm
u_{g200}	= 1074.2	BTU/lbm

$$C_p \approx \left(\frac{1145.9 - 1096.4}{200 - 80} \right)_p = 0.4125$$

$$C_v \approx \left(\frac{1074.2 - 1037}{200 - 80} \right)_v = 0.31$$

$$k = C_p/C_v = 0.4125/0.31 = \mathbf{1.331}$$

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 11 of 43	Rev. 0
----------------------------------	-----------------------	-----------

5.2.4.3 Head losses

The model that will be used to arrive at the losses in the piping/hose arrangement will consist of the following:

5.2.4.3.1 Well head carbon steel piping and 7' rubber hose with steam/air (e.g., CMA 55EB & CMA 55EC, Attachment 8.1 & 8.2)

5.2.4.3.2 Well head carbon steel piping and 13' rubber hose with only air (e.g., CMA 75ED, Attachment 8.1 & 8.2)

5.2.4.3.3 52 feet - 4" CPVC pipe (Attachment 8.1), length rounded up to nearest foot.

5.2.4.3.4 30 feet - 6" CPVC pipe (Attachment 8.1), length rounded up to nearest foot.

5.2.4.3.5 200 feet- 6" Rubber hose (Attachment 8.1), length rounded to nearest foot.

The methodology will be to maintain the SVE well head flanged connections at 6"Hg vacuum (Ref. 2.1, section 2.2.1). This will be accomplished by adjusting the C_v of the custom component (i.e., throttled globe valve) of the air only SVE well until the steam/air and air only SVE well piping/hoses head losses/pressure drop are equal.

The mass flow rate for the steam/air, ($\dot{m}_{s/a}$), SVE well will be as follows:

$$\dot{m}_{s/a} = (25.45 + 10.243) \cdot \frac{1}{7} = 5.1 \frac{\text{lbm}}{\text{min}}$$

The mass flow rate for the air only, ($\dot{m}_{a\text{ only}}$), SVE well will be as follows:

$$\dot{m}_{a\text{ only}} = 4.81 \cdot \frac{1}{4} = 1.2 \frac{\text{lbm}}{\text{min}}$$

The 4" CPVC pipe will be evaluated at 29.1 lbm/min (sum of 5 steam/air and 3 air only SVE wells). The 6" CPVC pipe and the 6" rubber hose will be evaluated at 40.5 lbm/min (total mass flow rate of steam/air and air).

The head losses, in "Hg, associated with the system components identified above will provide a conservative estimate of the pressure drop from the SVE wells to the heat exchanger inlet.

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 12 of 43	Rev. 0
----------------------------------	-----------------------	-----------

5.2.4.4 Results are presented in the following Crane Companion output files.

DF DesigNet [Ver 3]

-1-

Thu Apr 21 15:10:02 2005

ONE-PAGE SUMMARY

Branch Number: 5
Branch Name: carbon steel components Steam/Air

FLUID DESCRIPTION

Compressible - Location Not Specified
Spec. Heat Ratio (Cp/Cv): 1.327
Molecular Weight: 21.16
Specific Gravity: 0.622

HARDWARE DESCRIPTION

Number of Components: 10
Branch Inlet Diameter: 2.067 inches
Branch Outlet Diameter: 2.067 inches

Branch Elevational Change: 0.0 feet
Branch K Factor: 10.10

FLOW DESCRIPTION

Mass Flow Rate: 5.01 lb/min = 300.60 lb/hr
Std Vol. Flow Rate: 89.821 SCFM
Inlet Vol. Flow Rate: 142.31 cu ft/min = 1,064.57 US gal/min
Inlet Velocity: 101.78 ft/sec (FPS)
Inlet Mach No.: 0.071
Outlet Vol. Flow Rate: 147.41 cu ft/min = 1,102.73 US gal/min
Outlet Velocity: 105.43 ft/sec (FPS)
Outlet Mach No.: 0.074

Differential Pressure: 0.83 in Hg (32F) = 0.41 PSID

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 13 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-2-

Thu Apr 21 15:10:02 2005

FLUID DESCRIPTION - TABLE

Fluid: Ideal Gas

Units as follows:

Temperature: Fahrenheit

Pressure: in Hg (32F) abs

Specific Volume: cu ft/lb

Absolute Viscosity: centipoise

Component Name	Inlet T	Inlet P	Inl Vol	Inv Visc
INLET	200.00	23.98	28.41	
Pipe, NPS 2, sched 40, 5.00'	200.00	23.98	28.41	
{5} Tee, 2" Thru Run	200.00	23.94	28.46	
Ball valve	200.00	23.78	28.64	
Globe valve, inline	200.00	23.78	28.65	
{2} Elbow, 2" 90 Thr/SW	200.00	23.25	29.30	
OUTLET	200.00	23.15	29.42	

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 14 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-3-

Thu Apr 21 15:10:02 2005

HARDWARE DESCRIPTION - TABLE

Branch Number: 5
 Branch Name: carbon steel components Steam/Air
 Number of Components: 10

Units as follows:

Diameter: inches
 Equivalent Length: feet
 Inlet Pressure (Pin): in Hg (32F) abs
 Differential Pressure (DP): in Hg (32F)
 Head Loss (HL): feet
 Inlet Velocity: ft/sec (FPS)

Component Name	In Dia Pin	Out Dia DP	Eq Lnth HL	K Factor In Vel
INLET	2.067 23.98	0.83	91.64	10.104 101.784
Pipe, NPS 2, sched 40, 5.00'	2.067 23.98	2.067 0.04	5.00	0.551 101.784
[5] Tee, 2" Thru Run	2.067 23.94	2.067 0.15	3.44	0.380 101.974
Ball valve	2.067 23.78	2.067 0.00	0.52	0.057 102.634
Globe valve, inline	2.067 23.78	2.067 0.53	58.56	6.457 102.654
[2] Elbow, 2" 90 Thr/SW	2.067 23.25	2.067 0.10	5.17	0.570 105.001
OUTLET	23.15	2.067	91.64	10.104 105.433

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 15 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-4-

Thu Apr 21 15:10:02 2005

FLOW DESCRIPTION - TABLE

Mass Flow Rate: 5.01 lb/min = 300.60 lb/hr

Std Vol. Flow Rate: 89.821 SCFM

Units as follows:

Volumetric Flow Rate: cu ft/min

Velocity: ft/sec (FPS)

Differential Pressure: in Hg (32F)

Component Name	Inl Vel	Inl Vol	DP	Exp Fact
INLET	101.78	142.31	0.830	
Pipe, NPS 2, sched 40, 5.00'	101.78	142.31	0.045	NA
[5] Tee, 2" Thru Run	101.97	142.58	0.154	NA
Ball valve	102.63	143.50	0.005	NA
Globe valve, inline	102.65	143.53	0.532	NA
[2] Elbow, 2" 90 Thr/SW	105.00	146.81	0.095	NA
OUTLET	105.43	147.41	0.830	

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 16 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-1-

Thu Apr 21 15:10:46 2005

ONE-PAGE SUMMARY

Branch Number: 4
 Branch Name: 7 ft, 2" Rubber Hose

FLUID DESCRIPTION

Inlet Fluid Conditions

Spec. Heat Ratio (Cp/Cv): 1.331
 Molecular Weight: 21.16
 Specific Gravity: 0.731

Temperature: 200.00 Fahrenheit
 Pressure: 23.15 in Hg (32F) abs = 11.37 PSIA
 Density: 0.03 lb/cu ft
 Specific Volume: 29.424 cu ft/lb

HARDWARE DESCRIPTION

Number of Components: 2
 Branch Inlet Diameter: 2.067 inches
 Branch Outlet Diameter: 4.026 inches

Branch Elevational Change: 0.0 feet
 Branch K Factor: 1.20

FLOW DESCRIPTION

Mass Flow Rate: 5.01 lb/min = 300.60 lb/hr
 Std Vol. Flow Rate: 89.821 SCFM
 Inlet Vol. Flow Rate: 147.41 cu ft/min = 1,102.73 US gal/min
 Inlet Velocity: 105.43 ft/sec (FPS)
 Inlet Mach No.: 0.074
 Outlet Vol. Flow Rate: 147.56 cu ft/min = 1,103.81 US gal/min
 Outlet Velocity: 27.82 ft/sec (FPS)
 Outlet Mach No.: 0.019

Differential Pressure: 0.02 in Hg (32F) = 0.01 PSID

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 17 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-2-

Thu Apr 21 15:10:46 2005

FLUID DESCRIPTION - TABLE

Fluid: Ideal Gas

Units as follows:

Temperature: Fahrenheit
 Pressure: in Hg (32F) abs
 Specific Volume: cu ft/lb
 Absolute Viscosity: centipoise

Component Name	Inlet T	Inlet P	Inl Vol	Inv Visc
INLET	200.00	23.15	29.42	
Pipe, NPS 2, sched 40S, 7.00'	200.00	23.15	29.42	
Enlarger, 4 X 4" sud	200.00	23.09	29.49	
OUTLET	200.00	23.13	29.45	

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 18 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-3-

Thu Apr 21 15:10:46 2005

HARDWARE DESCRIPTION - TABLE

Branch Number: 4
 Branch Name: 7 ft, 2" Rubber Hose
 Number of Components: 2

Units as follows:

Diameter: inches
 Equivalent Length: feet
 Inlet Pressure (Pin): in Hg (32F) abs
 Differential Pressure (DP): in Hg (32F)
 Head Loss (HL): feet
 Inlet Velocity: ft/sec (FPS)

Component Name	In Dia Pin	Out Dia DP	Eq Lnth HL	K Factor In Vel
INLET	2.067 23.15	0.02	10.89	1.200 105.433
Pipe, NPS 2, sched 40S, 7.00'	2.067 23.15	2.067 0.06	7.00	0.658 105.433
Enlarger, 4 X 4" sud	2.067 23.09	4.026 -0.03	4.92	0.542 105.684
OUTLET	23.13	4.026	10.89	1.200 27.819

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 19 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-4-

Thu Apr 21 15:10:46 2005

FLOW DESCRIPTION - TABLE

Mass Flow Rate: 5.01 lb/min = 300.60 lb/hr

Std Vol. Flow Rate: 89.821 SCFM

Units as follows:

Volumetric Flow Rate: cu ft/min

Velocity: ft/sec (FPS)

Differential Pressure: in Hg (32F)

Component Name	Inl Vel	Inl Vol	DP	Exp Fact
INLET	105.43	147.41	0.023	
Pipe, NPS 2, sched 40S, 7.00'	105.43	147.41	0.055	NA
Enlarger, 4 X 4" sud	105.68	147.76	-0.032	NA
OUTLET	27.82	147.56	0.023	

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 20 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesignNet [Ver 3]

-1-

Thu Apr 21 15:11:27 2005

ONE-PAGE SUMMARY

Branch Number: 3
 Branch Name: carbon steel Well Air only

FLUID DESCRIPTION

Compressible - Location Not Specified
 Spec. Heat Ratio (Cp/Cv): 1.327
 Molecular Weight: 28.97
 Specific Gravity: 0.622

HARDWARE DESCRIPTION

Number of Components: 10
 Branch Inlet Diameter: 2.067 inches
 Branch Outlet Diameter: 2.067 inches
 Branch Elevational Change: 0.0 feet
 Branch K Factor: 317.39

FLOW DESCRIPTION

Mass Flow Rate: 1.20 lb/min = 72.00 lb/hr
 Std Vol. Flow Rate: 15.714 SCFM
 Inlet Vol. Flow Rate: 19.59 cu ft/min = 146.57 US gal/min
 Inlet Velocity: 14.01 ft/sec (FPS)
 Inlet Mach No.: 0.013
 Outlet Vol. Flow Rate: 20.32 cu ft/min = 151.98 US gal/min
 Outlet Velocity: 14.53 ft/sec (FPS)
 Outlet Mach No.: 0.013
 Differential Pressure: 0.85 in Hg (32F) = 0.42 PSID

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 21 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-2-

Thu Apr 21 15:11:27 2005

FLUID DESCRIPTION - TABLE

Fluid: Ideal Gas

Units as follows:

Temperature: Fahrenheit
 Pressure: in Hg (32F) abs
 Specific Volume: cu ft/lb
 Absolute Viscosity: centipoise

Component Name	Inlet T	Inlet P	Inl Vol	Inv Visc
INLET	60.00	24.00	16.33	
Pipe, NPS 2, sched 40, 5.00'	60.00	24.00	16.33	
[4] Tee, 2" Thru Run	60.00	24.00	16.33	
Ball valve	60.00	24.00	16.33	
Custom Component	60.00	24.00	16.33	
[2] Elbow, 2" 90 Thr/SW	60.00	23.15	16.93	
OUTLET	60.00	23.15	16.93	

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 22 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-3-

Thu Apr 21 15:11:27 2005

HARDWARE DESCRIPTION - TABLE

Branch Number: 3
 Branch Name: carbon steel Well Air only
 Number of Components: 10

Units as follows:

Diameter: inches
 Equivalent Length: feet
 Inlet Pressure (Pin): in Hg (32F) abs
 Differential Pressure (DP): in Hg (32F)
 Head Loss (HL): feet
 Inlet Velocity: ft/sec (FPS)

Component Name	In Dia Pin	Out Dia DP	Eq Lnth HL	K Factor In Vel
INLET	2.067 24.00	0.85	2878.80	317.390 14.014
Pipe, NPS 2, sched 40, 5.00'	2.067 24.00	2.067 0.00	5.00	0.551 14.014
[4] Tee, 2" Thru Run	2.067 24.00	2.067 0.01	3.44	0.380 14.015
Ball valve	2.067 24.00	2.067 0.00	0.52	0.057 14.017
Custom Component	2.067 24.00	2.067 0.84	2845.73	313.743 14.018
[2] Elbow, 2" 90 Thr/SW	2.067 23.15	2.067 0.00	5.17	0.570 14.529
OUTLET	23.15	2.067	2878.80	317.390 14.531

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 23 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-4-

Thu Apr 21 15:11:27 2005

FLOW DESCRIPTION - TABLE

Mass Flow Rate: 1.20 lb/min = 72.00 lb/hr

Std Vol. Flow Rate: 15.714 SCFM

Units as follows:

Volumetric Flow Rate: cu ft/min

Velocity: ft/sec (FPS)

Differential Pressure: in Hg (32F)

Component Name	Inl Vel	Inl Vol	DP	Exp Fact
INLET	14.01	19.59	0.854	
Pipe, NPS 2, sched 40, 5.00'	14.01	19.59	0.001	NA
[4] Tee, 2" Thru Run	14.01	19.59	0.005	NA
Ball valve	14.02	19.60	0.000	NA
Custom Component	14.02	19.60	0.844	NA
[2] Elbow, 2" 90 Thr/SW	14.53	20.31	0.003	NA
OUTLET	14.53	20.32	0.854	

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 24 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-1-

Thu Apr 21 15:11:49 2005

ONE-PAGE SUMMARY

Branch Number: 2
 Branch Name: 13 ft, 2" Rubber Hose

FLUID DESCRIPTION

Inlet Fluid Conditions

Spec. Heat Ratio (Cp/Cv): 1.400
 Molecular Weight: 28.97
 Specific Gravity: 1.000

Temperature: 60.00 Fahrenheit
 Pressure: 23.15 in Hg (32F) abs = 11.37 PSIA
 Density: 0.06 lb/cu ft
 Specific Volume: 16.930 cu ft/lb

HARDWARE DESCRIPTION

Number of Components: 2
 Branch Inlet Diameter: 2.067 inches
 Branch Outlet Diameter: 4.026 inches

Branch Elevational Change: 0.0 feet
 Branch K Factor: 1.76

FLOW DESCRIPTION

Mass Flow Rate: 1.20 lb/min = 72.00 lb/hr
 Std Vol. Flow Rate: 15.714 SCFM
 Inlet Vol. Flow Rate: 20.32 cu ft/min = 151.98 US gal/min
 Inlet Velocity: 14.53 ft/sec (FPS)
 Inlet Mach No.: 0.013
 Outlet Vol. Flow Rate: 20.32 cu ft/min = 151.99 US gal/min
 Outlet Velocity: 3.83 ft/sec (FPS)
 Outlet Mach No.: 0.004

Differential Pressure: 0.002287 in Hg (32F) = 0.00 PSID

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 25 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-2-

Thu Apr 21 15:11:49 2005

FLUID DESCRIPTION - TABLE

Fluid: Ideal Gas

Units as follows:

Temperature: Fahrenheit
 Pressure: in Hg (32F) abs
 Specific Volume: cu ft/lb
 Absolute Viscosity: centipoise

Component Name	Inlet T	Inlet P	Inl Vol	Inv Visc
INLET	60.00	23.15	16.93	
Pipe, NPS 2, sched 40S, 13.00'	60.00	23.15	16.93	
Enlarger, 4 X 4" sud	60.00	23.15	16.93	
OUTLET	60.00	23.15	16.93	

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 26 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-3-

Thu Apr 21 15:11:49 2005

HARDWARE DESCRIPTION - TABLE

Branch Number: 2
 Branch Name: 13 ft, 2" Rubber Hose
 Number of Components: 2

Units as follows:

Diameter: inches
 Equivalent Length: feet
 Inlet Pressure (Pin): in Hg (32F) abs
 Differential Pressure (DP): in Hg (32F)
 Head Loss (HL): feet
 Inlet Velocity: ft/sec (FPS)

Component Name	In Dia Pin	Out Dia DP	Eq Lnth HL	K Factor In Vel
INLET	2.067 23.15	0.00	16.00	1.764 14.531
Pipe, NPS 2, sched 40S, 13.00'	2.067 23.15	2.067 0.00	13.00	1.222 14.531
Enlarger, 4 X 4" sud	2.067 23.15	4.026 0.00	4.92	0.542 14.533
OUTLET	23.15	4.026	16.00	1.764 3.831

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 27 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-4-

Thu Apr 21 15:11:49 2005

FLOW DESCRIPTION - TABLE

Mass Flow Rate: 1.20 lb/min = 72.00 lb/hr

Std Vol. Flow Rate: 15.714 SCFM

Units as follows:

Volumetric Flow Rate: cu ft/min

Velocity: ft/sec (FPS)

Differential Pressure: in Hg (32F)

Component Name	Inl Vel	Inl Vol	DP	Exp Fact
INLET	14.53	20.32	0.002	
Pipe, NPS 2, sched 40S, 13.00'	14.53	20.32	0.003	NA
Enlarger, 4 X 4" sud	14.53	20.32	-0.001	NA
OUTLET	3.83	20.32	0.002	

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 28 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-1-

Mon Apr 25 09:41:23 2005

ONE-PAGE SUMMARY

Branch Number: 1
 Branch Name: 52 ft, 4" CPVC Pipe

FLUID DESCRIPTION

Outlet Fluid Conditions

Spec. Heat Ratio (Cp/Cv): 1.331
 Molecular Weight: 22.09
 Specific Gravity: 0.763

Temperature: 200.00 Fahrenheit
 Pressure: 11.18 PSIA
 Density: 0.03 lb/cu ft
 Specific Volume: 28.655 cu ft/lb

HARDWARE DESCRIPTION

Number of Components: 2
 Branch Inlet Diameter: 4.026 inches
 Branch Outlet Diameter: 6.065 inches

Branch Elevational Change: 0.0 feet
 Branch K Factor: 2.28

FLOW DESCRIPTION

Mass Flow Rate: 29.10 lb/min = 1,746.00 lb/hr
 Std Vol. Flow Rate: 499.749 SCFM
 Inlet Vol. Flow Rate: 6,161.11 US gal/min
 Inlet Velocity: 155.27 ft/sec (FPS)
 Inlet Mach No.: 0.110
 Outlet Vol. Flow Rate: 6,237.79 US gal/min
 Outlet Velocity: 69.27 ft/sec (FPS)
 Outlet Mach No.: 0.049

Differential Pressure: 0.28 in Hg (32F) = 0.14 PSID

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 29 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-2-

Mon Apr 25 09:41:23 2005

FLUID DESCRIPTION - TABLE

Fluid: Ideal Gas

Units as follows:

Temperature: Fahrenheit
 Pressure: in Hg (32F) abs
 Specific Volume: cu ft/lb
 Absolute Viscosity: centipoise

Component Name	Inlet T	Inlet P	Inl Vol	Inv Visc
INLET	200.00	23.05	28.30	
Pipe, NPS 4, sched 40S, 52.00'	200.00	23.05	28.30	
Enlarger, 6 X 6" sud	200.00	22.68	28.77	
OUTLET	200.00	22.77	28.66	

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 30 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-3-

Mon Apr 25 09:41:23 2005

HARDWARE DESCRIPTION - TABLE

Branch Number: 1
 Branch Name: 52 ft, 4" CPVC Pipe
 Number of Components: 2

Units as follows:

Diameter: inches
 Equivalent Length: feet
 Inlet Pressure (Pin): in Hg (32F) abs
 Differential Pressure (DP): in Hg (32F)
 Head Loss (HL): feet
 Inlet Velocity: ft/sec (FPS)

Component Name	In Dia Pin	Out Dia DP	Eq Lnth HL	K Factor In Vel
INLET	4.026 23.05	0.28	46.92	2.278 155.274
Pipe, NPS 4, sched 40S, 52.00'	4.026 23.05	4.026 0.38	52.00	1.965 155.274
Enlarger, 6 X 6" sud	4.026 22.68	6.065 -0.09	6.44	0.313 157.856
OUTLET	22.77	6.065	46.92	2.278 69.272

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 31 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-4-

Mon Apr 25 09:41:23 2005

FLOW DESCRIPTION - TABLE

Mass Flow Rate: 29.10 lb/min = 1,746.00 lb/hr

Std Vol. Flow Rate: 499.749 SCFM

Units as follows:

Volumetric Flow Rate: US gal/min

Velocity: ft/sec (FPS)

Differential Pressure: in Hg (32F)

Component Name	Inl Vel	Inl Vol	DP	Exp Fact
INLET	155.27	6161.11	0.283	
Pipe, NPS 4, sched 40S, 52.00'	155.27	6161.10	0.377	NA
Enlarger, 6 X 6" sud	157.86	6263.55	-0.094	NA
OUTLET	69.27	6237.79	0.283	

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 32 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-1-

Thu Apr 21 15:13:05 2005

ONE-PAGE SUMMARY

Branch Number: 6
 Branch Name: 30 ft, 6" CPVC Pipe

FLUID DESCRIPTION

Outlet Fluid Conditions

Spec. Heat Ratio (Cp/Cv): 1.331
 Molecular Weight: 22.09
 Specific Gravity: 0.763

Temperature: 200.00 Fahrenheit
 Pressure: 22.72 in Hg (32F) abs = 11.16 PSIA
 Density: 0.03 lb/cu ft
 Specific Volume: 28.718 cu ft/lb

HARDWARE DESCRIPTION

Number of Components: 1
 Branch Inlet Diameter: 6.065 inches
 Branch Outlet Diameter: 6.065 inches

Branch Elevational Change: 0.0 feet
 Branch K Factor: 0.70

FLOW DESCRIPTION

Mass Flow Rate: 40.50 lb/min = 2,430.00 lb/hr
 Std Vol. Flow Rate: 695.527 SCFM
 Inlet Vol. Flow Rate: 1,160.54 cu ft/min = 8,681.49 US gal/min
 Inlet Velocity: 96.41 ft/sec (FPS)
 Inlet Mach No.: 0.069
 Outlet Vol. Flow Rate: 1,163.09 cu ft/min = 8,700.57 US gal/min
 Outlet Velocity: 96.62 ft/sec (FPS)
 Outlet Mach No.: 0.069

Differential Pressure: 0.05 in Hg (32F) = 0.02 PSID

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 33 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-2-

Thu Apr 21 15:13:05 2005

FLUID DESCRIPTION - TABLE

Fluid: Ideal Gas

Units as follows:

Temperature: Fahrenheit
 Pressure: in Hg (32F) abs
 Specific Volume: cu ft/lb
 Absolute Viscosity: centipoise

Component Name	Inlet T	Inlet P	Inl Vol	Inv Visc
INLET	200.00	22.77	28.66	
Pipe, NPS 6, sched 40S, 30.00'	200.00	22.77	28.66	
OUTLET	200.00	22.72	28.72	

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 34 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesignNet [Ver 3]

-3-

Thu Apr 21 15:13:05 2005

HARDWARE DESCRIPTION - TABLE

Branch Number: 6
 Branch Name: 30 ft, 6" CPVC Pipe
 Number of Components: 1

Units as follows:

Diameter: inches
 Equivalent Length: feet
 Inlet Pressure (Pin): in Hg (32F) abs
 Differential Pressure (DP): in Hg (32F)
 Head Loss (HL): feet
 Inlet Velocity: ft/sec (FPS)

Component Name	In Dia Pin	Out Dia DP	Eq Lnth HL	K Factor In Vel
INLET	6.065 22.77	0.05	23.59	0.696 96.410
Pipe, NPS 6, sched 40S, 30.00'	6.065 22.77	6.065 0.05	30.00	0.696 96.410
OUTLET	22.72	6.065	23.59	0.696 96.622

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 35 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-4-

Thu Apr 21 15:13:05 2005

FLOW DESCRIPTION - TABLE

Mass Flow Rate: 40.50 lb/min = 2,430.00 lb/hr

Std Vol. Flow Rate: 695.527 SCFM

Units as follows:

 Volumetric Flow Rate: cu ft/min

 Velocity: ft/sec (FPS)

 Differential Pressure: in Hg (32F)

Component Name	Inl Vel	Inl Vol	DP	Exp Fact
INLET	96.41	1160.54	0.050	
Pipe, NPS 6, sched 40S, 30.00'	96.41	1160.54	0.050	NA
OUTLET	96.62	1163.09	0.050	

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 36 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-1-

Thu Apr 21 15:13:39 2005

ONE-PAGE SUMMARY

Branch Number: 7
 Branch Name: 200 ft, 6" Rubber Hose

FLUID DESCRIPTION

Outlet Fluid Conditions

Spec. Heat Ratio (Cp/Cv): 1.331
 Molecular Weight: 22.09
 Specific Gravity: 0.763

Temperature: 200.00 Fahrenheit
 Pressure: 22.35 in Hg (32F) abs = 10.98 PSIA
 Density: 0.03 lb/cu ft
 Specific Volume: 29.194 cu ft/lb

HARDWARE DESCRIPTION

Number of Components: 1
 Branch Inlet Diameter: 6.065 inches
 Branch Outlet Diameter: 6.065 inches

Branch Elevational Change: 0.0 feet
 Branch K Factor: 5.12

FLOW DESCRIPTION

Mass Flow Rate: 40.50 lb/min = 2,430.18 lb/hr
 Std Vol. Flow Rate: 695.578 SCFM
 Inlet Vol. Flow Rate: 1,163.13 cu ft/min = 8,700.85 US gal/min
 Inlet Velocity: 96.62 ft/sec (FPS)
 Inlet Mach No.: 0.069
 Outlet Vol. Flow Rate: 1,182.43 cu ft/min = 8,845.26 US gal/min
 Outlet Velocity: 98.23 ft/sec (FPS)
 Outlet Mach No.: 0.070

Differential Pressure: 0.37 in Hg (32F) = 0.18 PSID

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 37 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-2-

Thu Apr 21 15:13:39 2005

FLUID DESCRIPTION - TABLE

Fluid: Ideal Gas

Units as follows:

 Temperature: Fahrenheit

 Pressure: in Hg (32F) abs

 Specific Volume: cu ft/lb

 Absolute Viscosity: centipoise

Component Name	Inlet T	Inlet P	Inl Vol	Inv Visc
INLET	200.00	22.72	28.72	
Pipe, NPS 6, sched 40S, 200.00'	200.00	22.72	28.72	
OUTLET	200.00	22.35	29.19	

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 38 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-3-

Thu Apr 21 15:13:39 2005

HARDWARE DESCRIPTION - TABLE

Branch Number: 7
 Branch Name: 200 ft, 6" Rubber Hose
 Number of Components: 1

Units as follows:

Diameter: inches
 Equivalent Length: feet
 Inlet Pressure (Pin): in Hg (32F) abs
 Differential Pressure (DP): in Hg (32F)
 Head Loss (HL): feet
 Inlet Velocity: ft/sec (FPS)

Component Name	In Dia Pin	Out Dia DP	Eq Lnth HL	K Factor In Vel
INLET	6.065 22.72	0.37	173.55	5.117 96.625
Pipe, NPS 6, sched 40S, 200.00'	6.065 22.72	6.065 0.37	200.00	5.117 96.625
OUTLET	22.35	6.065	173.55	5.117 98.228

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 39 of 43	Rev. 0
----------------------------------	-----------------------	-----------

DF DesigNet [Ver 3]

-4-

Thu Apr 21 15:13:39 2005

FLOW DESCRIPTION - TABLE

Mass Flow Rate: 40.50 lb/min = 2,430.18 lb/hr
 Std Vol. Flow Rate: 695.578 SCFM
 Units as follows:
 Volumetric Flow Rate: cu ft/min
 Velocity: ft/sec (FPS)
 Differential Pressure: in Hg (32F)

Component Name	Inl Vel	Inl Vol	DP	Exp Fact
INLET	96.62	1163.13	0.371	
Pipe, NPS 6, sched 40S, 200.00'	96.62	1163.13	0.371	NA
OUTLET	98.23	1182.43	0.371	

5.2.4.5 Total head loss

The head losses of the evaluated components are as follows:

Well steam/Air	0.83 "Hg
7 ft rubber hose	0.02 "Hg
Well air only	0.85 "Hg
13 ft rubber hose	0.0023 "Hg
52 ft, 4" CPVC pipe	0.28 "Hg
30 ft, 6" CPVC pipe	0.05 "Hg
200 ft, 6" rubber hose	0.37 "Hg

Since the wells are in parallel the total head loss will be the sum of; either well and associated hose, 52 ft CPVC pipe, 30 ft CPVC pipe and the 200 ft rubber hose. The total head loss will be approximately 1.55 "Hg.

6.0 RESULTS

- 6.1 The heat loss from the piping/hose arrangement will be between 46.08 and 74.48 BTU/lbm.
- 6.2 The head loss across the system (well head to inlet of heat exchanger) will be approximately 1.55"Hg, pressure at the inlet will need to be 22.45 "Hg absolute to provide sufficient vacuum for system.

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 40 of 43	Rev. 0
----------------------------------	-----------------------	-----------

7.0 CONCLUSION

- 7.1 The heat loss from the piping/hose arrangement will be used to determine the potential amount of condensate that will accumulate in the piping/hoses for collection tank sizing.
- 7.2 The SVE blower must be capable of ensuring a 22.45 "Hg absolute pressure at the inlet of the heat exchanger (pressure drop from the well head to the inlet to the heat exchanger is approximately 1.55"Hg).


8.0 ATTACHMENTS

- 8.1 Piping Arrangement
- 8.2 Well Head Configuration
- 8.3 Heating Campaigns

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 41 of 43	Rev. 0
----------------------------------	-----------------------	-----------


ATTACHMENT 8.1




Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 42 of 43	Rev. 0
----------------------------------	-----------------------	-----------

ATTACHMENT 8.2



TYPICAL FOR THE FOLLOWING EXTRACTION WELL LOCATIONS:
 CMA 54EB, CMA 54EC, CMA 55EB, CMA 55EC, CMA 57EB, CMA 57EC,
 CMA 59EB, CMA 59EC, CMA 60EB, CMA 60EC, CMA 61EB, CMA 61EC,
 CMA 62EB, CMA 62EC, CMA 63EB, CMA 63EC, CMA 64EB, CMA 64EC,
 CMA 65EB, CMA 65EC, CMA 67EB, CMA 67EC



TYPICAL FOR THE FOLLOWING EXTRACTION WELL LOCATIONS:
 CMA 56EB, CMA 58EC, CMA 66EB, CMA 68ED, CMA 69ED, CMA 70ED,
 CMA 71ED, CMA 72ED, CMA 73ED, CMA 74ED, CMA 75ED

Calculation Continuation Sheet

Calculation No. M-CLC-G-00344	Sheet No. 43 of 43	Rev. 0
----------------------------------	-----------------------	-----------

ATTACHMENT 8.3

LEGEND

SA - STEAM AND AIR FROM WELL
A - ONLY AIR FROM WELL

