



1  
2 DISCLAIMER

3  
4  
5 UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
6 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

7  
8  
9 The contents of this transcript of the  
10 proceeding of the United States Nuclear Regulatory  
11 Commission Advisory Committee on Reactor Safeguards,  
12 as reported herein, is a record of the discussions  
13 recorded at the meeting.

14  
15 This transcript has not been reviewed,  
16 corrected, and edited, and it may contain  
17 inaccuracies.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
+ + + + +  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
(ACRS)  
+ + + + +  
SUBCOMMITTEE ON ESBWR  
+ + + + +  
THURSDAY  
SEPTEMBER 23, 2010  
+ + + + +  
ROCKVILLE, MARYLAND  
+ + + + +

The Advisory Committee met at the Nuclear  
Regulatory Commission, Two White Flint North, Room  
T2B1, 11545 Rockville Pike, at 8:30 a.m., Michael L.  
Corradini, Chairman, presiding.

SUBCOMMITTEE MEMBERS:

MICHAEL L. CORRADINI, Chairman  
SAID ABDEL-KHALIK, Member  
J. SAM ARMIJO, Member  
JOHN W. STETKAR, Member

CONSULTANTS:

THOMAS S. KRESS  
GRAHAM B. WALLIS

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

A G E N D A

1		
2	Opening Remarks and Objectives.....	3
3	Staff Opening Remarks.....	6
4	Chapter 3 - Section 3.8 RAIs - GEH.....	6
5	Chapter 3 - Section 3.8 RAIs - Staff.....	36
6	Chapter 3 - Design of Structures Components	
7	Equipment, Section 3.9 RAIs - GEH.....	66
8	Chapter 3 - Design of Structures Components	
9	Equipment, Section 3.9 RAIs - Staff.....	94
10	Chapter 3 - Section 3.12 RAIs - GEH.....	111
11	Chapter 3 - Section 3.12 RAIs - Staff.....	121
12	Chapter 4 - Reactor - Staff.....	128
13	Chapter 9 - Auxiliary Systems - GEH.....	131
14	Chapter 9 - Auxiliary Systems - Staff.....	223
15	Chapter 6 - Engineered Safety Features	
16	(Section 6.4) and Chapter 9	
17	(Section 9.4) - GEH.....	264
18	Chapter 6 - Engineered Safety Features	
19	(Section 6.4) and Chapter 9	
20	(Section 9.4) - Staff.....	306
21	Adjourn.....	413
22		
23		
24		
25		

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

## P R O C E E D I N G S

8:31 a.m.

Opening Remarks and Objectives

CHAIRMAN CORRADINI: The meeting will come to order. This is a meeting of the Advisory Committee on Reactor Safeguards, Subcommittee on the ESBWR reactor application. My name is Mike Corradini, chair of the Subcommittee.

Subcommittee members in attendance at this time are Dr. Said Abdel -Khalik, Sam Armijo, John Stetkar and currently our consultant, Dr. Graham Wallis, soon to be Tom Kress, and I hope soon to be Charlie Brown. The designated federal official is Christopher Brown.

The purpose of this meeting is to be briefed on the final SERs for Chapter 3, Design of Structures, Components and Equipment, Chapter 4, Reactors, Chapter 6, Engineering Safety Features, and Chapter 7, Instrumentation and Control Systems, and Chapter 9, Auxiliary Systems associated with the ESBWR design.

The Subcommittee will hear presentations by and hold discussions with representatives of the NRC staff and the ESBWR applicant, General Electric Hitachi Nuclear Energy.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1           The Subcommittee will gather information,  
2 analyze relevant issues and facts and           formulate  
3 proposed positions and actions as appropriate for  
4 deliberation by the full Committee. The rules for  
5 participation in today's meeting have been announced  
6 as part of the notice of this meeting, previously  
7 published in the *Federal Register* on August 30th,  
8 2010.

9           A portion of this meeting may be closed to  
10 protect information that is proprietary to GEH Nuclear  
11 Energy and its contractors, pursuant to 5 U.S.C.  
12 552(B)(c)(4). A transcript of the meeting is being  
13 kept and will be made available as           stated in the  
14 *Federal Register* notice.

15           It's requested that speakers first  
16 identify themselves and speak with sufficient clarity  
17 and volume, so that they can be readily heard. Also,  
18 to remind everybody, please silence your cell phones  
19 and Blackberrys and any other thing you have with you.

20           We have not received any requests from  
21 members of the public to make oral           statements or  
22 written comments. We have a phone line open, and the  
23 GEH engineers and staff are online; is that correct?

24           PARTICIPANT: That's correct, we're here.

25           CHAIRMAN CORRADINI: Okay, and if you need

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to put it on mute until we need to talk to you. Let  
2 me just remind everybody that neither the staff nor  
3 GEH plans to present any proprietary information when  
4 we're going through these chapters of 6, 7 and 9.

5 However, if we ask questions, if the  
6 members ask questions, particularly on some I&C issues  
7 and the details are proprietary, I think we're going  
8 to organize ourselves to do it in a fashion that we  
9 collect them all and do it at a particular time during  
10 the day, so we can close the session.

11 All right. Other than that, I want to  
12 remind everybody that this is our last set of  
13 subcommittee meetings on the last set of chapters.  
14 The staff has closed all open items on these chapters.

15 I know that will not deter the members from asking  
16 probing and exhilarating questions.

17 So that's the main point of this. I have  
18 already been asked by some of the members that we're  
19 going to finish on time and on budget at five o'clock  
20 tomorrow afternoon. So we will -- I will, and I  
21 apologize, sometimes move us along if we need to.

22 We've broken it down that we're going to  
23 start with Chapter 3 today, and then a small amount on  
24 Chapter 4, since most of those issues have been closed  
25 and been reviewed in past subcommittee meetings, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 finish up today with Chapter 9, regardless how long it  
2 takes.

3 So I'd like to turn it to Amy Cubbage to  
4 kind of kick us off. Amy?

5 Staff Opening Remarks

6 MS. CUBBAGE: Thank you. Just to add to  
7 what you said there, for Chapter 3, I'd just like to  
8 note that we're not covering every subsection of  
9 Chapter 3. We picked selected areas where there were  
10 significant open items, and areas of ACRS interest in  
11 previous meetings.

12 So we're going to start off with Section  
13 3.8 today and then go on to selected topics from 3.9  
14 and 3.12. If the Committee has any questions in other  
15 areas of Chapter 3, please let us know and we'll try  
16 to get the appropriate staff here to answer those  
17 questions during the course of the day. With that,  
18 I'll just turn it over to GE Hitachi to begin.

19 Chapter 3 - Section 3.8 RAIs/GEH

20 MR. NIOGI: My name is Sujit Niogi. I'm  
21 from the GE Hitachi, and I'm going to cover Chapter  
22 3.8 open items. The following the NRC RAIs will be  
23 discussed in this presentation: 3.8 -79, Seismic  
24 Category 2 issue; 3.8-94, soil-bearing capacity. 3.8-  
25 96; stability analysis of the structure; 3.8-107, SSDP

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 computer program validation; 3.8 -120, reactor shield  
2 wall; 3.8-125, impact of spent fuel rack on spent fuel  
3 pool structure.

4 NRC RAI 3.8-79, confirmed that the Seismic  
5 Category 2 and Seismic Category NS structures, which  
6 are in close proximity approximately to Seismic  
7 Category 1 structures, are designed to Seismic  
8 Category 1 requirements. The following structures are  
9 in close proximity to Category 1 structures: Seismic  
10 Category 2, reactor building, service building and  
11 ancillary diesel building. Seismic Category NS fuel  
12 building.

13 Seismic Category 2 and seismic Category NS  
14 structures listed above are designed to withstand SSE  
15 loads. The method of analysis of these structures are  
16 the same as the Seismic Category 1 structures,  
17 including the load combinations and the acceptance  
18 criteria.

19 During SSE event, the structures will not  
20 collapse and impact the Seismic Category 1 structure.

21 Also, the -- in the structures are large enough to  
22 preclude impact due to out of phase displacements  
23 during SSE events.

24 It was demonstrated that a Seismic  
25 Category 2 and Seismic Category 1 NS structures which

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 are in close proximity to Seismic Category 1  
2 structures, are designed to SSE requirements. The  
3 gaps between the structures are large enough to  
4 prelude impact during SSE event.

5 DR. WALLIS: Impact with what?

6 MR. NIOGI: Impact with another structure.

7 DR. WALLIS: Oh, another structure. Oh,  
8 particularly the Seismic Category 1.

9 MR. NIOGI: So it may be that the Seismic  
10 Category 2 are NS, doesn't matter. It's not going to  
11 impact any other structure.

12 DR. WALLIS: It's a strange structure that  
13 falls without hitting something.

14 MR. NIOGI: Beg your pardon?

15 DR. WALLIS: It's a strange structure that  
16 falls without hitting something.

17 MR. NIOGI: It's not going to fall,  
18 because are designing Category 2 as NS, not to fall at  
19 all.

20 DR. WALLIS: So the impact you're talking  
21 about isn't a falling of something?

22 MR. NIOGI: It's not the falling. It is a  
23 gap between during the out of phase displacement, the  
24 --

25 DR. WALLIS: Oh, I see. So impact you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 don't -- impact to me means something hitting  
2 something, but you mean -- you mean an influence of  
3 something. Okay, I see. Thank you.

4 MR. NIOGI: So out of phase displacement  
5 is not going to --

6 DR. WALLIS: But you're using impact in  
7 the modern way instead of the classical sense.

8 MS. CUBBAGE: I think they do mean impact,  
9 no?

10 CHAIRMAN CORRADINI: Out of phase.  
11 Graham's just asking if things are falling. Your  
12 answer is they're not designed to fall, but they're  
13 not going to out of phase bump into each other?

14 MR. NIOGI: Right.

15 DR. WALLIS: You could use the word  
16 "bump."

17 MR. NIOGI: Bump, yes bump. Contact.

18 CHAIRMAN CORRADINI: Contact.

19 MR. NIOGI: Contact.

20 DR. WALLIS: You mean they don't have any  
21 effect on the neighboring structures.

22 MR. NIOGI: Right.

23 DR. WALLIS: That's what you sort of mean.  
24 You don't mean they actually don't hit them?

25 MR. NIOGI: No, no. Okay. We have enough

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 -- between the two structures not to do that.

2 DR. WALLIS: They're independent.

3 MR. NIOGI: They're independent. NRC RAI  
4 2.8 3.8-94. Confirmed, that a soil -bearing demand is  
5 less than the soil -bearing capacity due to static and  
6 dynamic loading conditions. Provide t he technical  
7 basis for not considering the -- during an event.  
8 Bearing and sliding calculation which uses SASSI  
9 results.

10 The staff noted valleys exists between  
11 successive peaks in the site shear waves. The staff  
12 requested that these valleys should b e filled in to  
13 accommodate the expected variability in site shear  
14 wave profiles.

15 GEH used the energy balance method to  
16 calculate the soil -bearing pressure and consider both  
17 form and size. GEH demonstrated that the soil-bearing  
18 demand is less than the allowable soil -bearing  
19 pressure. The results are documented in DCD Tier 1.  
20 They're in 5.1-1 and DCD Tier 2, Table 2.0-1.

21 GEH used the energy balance method, which  
22 takes into account the effects of uplift in the linear  
23 response calculated by SASSI. We thus concluded that  
24 this simplified method provides a reasonable estimate  
25 using the linear analysis results on the amount of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 uplift displacement due to passing of the base mat  
2 dimension.

3 As shown in Figure 1, as shown in  
4 Figure 1, the extent of uplift is not extensive, and a  
5 large portion of the base mat remains in contact with  
6 the soil. GEH complied with the NRC request and  
7 filled the spectral valleys between the peaks, as  
8 shown in Figure 2. The dotted line was when the  
9 valleys are not filled on, and the solid line is when  
10 the valleys are filled in.

11 CHAIRMAN CORRADINI: The staff said the  
12 low frequency region. In fact, there isn't much of a  
13 valley in --

14 MR. NIOGI: Yes. They said there is not  
15 much, but in several cases, we do have valleys in the  
16 -- several valleys in the low frequency range.

17 CHAIRMAN CORRADINI: And that's what  
18 requires -- or that's what, that's the impetus that  
19 the staff has to fill in to do, so that you eliminate  
20 those large changes.

21 MR. NIOGI: Large changes, yes.

22 CHAIRMAN CORRADINI: Okay.

23 MR. NIOGI: It was demonstrated the soil -  
24 bearing demand is less than the soil -bearing capacity  
25 in static and dynamic loading conditions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: So this is 5g, this maximum  
2 almost?

3 MR. NIOGI: Yes, it is almost 5g.

4 DR. WALLIS: Oh.

5 MR. NIOGI: This is our analysis from the  
6 ground elevation. The technical basis for not  
7 considering the effect of uplift in the seismic demand  
8 loading in the bearing and sliding calculation, which  
9 uses SASSI analyses results have been demonstra ted.  
10 Spectral valleys between the peaks have been filled  
11 in.

12 NRC RAI 3.8 -96. Confirmed, that the  
13 Seismic Category 1 structures meet the sliding  
14 stability requirements of SRP 3.8.5. Justify, use the  
15 static correlation of friction beneath the base mat,  
16 and along the vertical surfaces of the walls.

17 Justify, use a full passive pressure at  
18 the side of the vertical surfaces of the walls in the  
19 sliding resistance. How did GEH consider other  
20 potential sliding interfaces in addition to the soil  
21 shear failure that is base mat to concrete mud mat and  
22 concrete to soil.

23 It does confirm that the Seismic Category  
24 1 structures meet the sliding stability requirements  
25 of the SRP 3.8.5, considering passive pressure

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 resistance. Resistance due to friction at the bottom  
2 of the base mat, and along the vertical surfaces of  
3 the walls. GEH used reduced friction in the vertical  
4 walls to calculate friction resistance due to passive  
5 pressure.

6 In this evaluation, passive pressure was  
7 needed to comply with SRP 3.8.5 requirements. GEH  
8 added shear keys to the reactor building, fuel  
9 building complex and service complex to increase the  
10 sliding resistance. See Figure 3.

11 In Figure 3, you can see that.

12 CHAIRMAN CORRADINI: So these were added?

13 I just want to understand. These were added because,  
14 if I remember back last time we discussed this, there  
15 was -- the staff wanted you to look at variation in  
16 the sliding coefficient, and these were added to add  
17 extra margin to -- that even if the sliding  
18 coefficient was lower, you still met the requirement?

19 MR. NIOGI: I would not say adding extra  
20 margin. I would say that yes, we needed that CRT to  
21 get that stability factor SRP against sliding 1.1.

22 CHAIRMAN CORRADINI: Okay. Thank you.

23 MR. NIOGI: By roughening the surface face  
24 of the mud mat concrete, friction resistance is  
25 increased between the mud mat and base mat. Added

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 drafts in the soil under the mud mat to increase the  
2 shear resistance. Building structures meet the  
3 sliding stability requirements of the SRP 3.8.5.

4 Static coefficient of frequency of .7  
5 beneath the base mat and the reduced coefficient of  
6 friction of 0.5 for the vertical surface of the wall  
7 is adequate to provide sliding stability. Additional  
8 reinforcement was added to the vertical walls to  
9 resist passive pressure, to increase the friction  
10 relation between the base mat, mud mat and soil.

11 NRC RAI 3.8 -107. NRC staff reviewed the  
12 SSDP computer program validation package, but found  
13 that the validation did not satisfy items of interest,  
14 such as how does SSDP apply the concrete code used the  
15 U.S., and how are the code additions that are accepted  
16 by the NRC is incorporated in SSDP to keep it current?

17 How does SSDP identify critical sections  
18 of a structure. In the RCCV structure, how does SSDP  
19 evaluate that shear stress to demonstrate compliance  
20 with the ASME code? GEH was requested to verify the  
21 equations using the SSDP by comparing the quantity  
22 results with the equations presented in the concrete  
23 textbook.

24 SSDP calculates stresses of concrete and  
25 INPO strength of force and --. Calculated stresses

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 are compared with the allowable stresses specified in  
2 applicable codes. The SSDP has supplemental  
3 subroutines for the tangential shear and transverse  
4 shear.

5 It is confirmed that the provided section  
6 satisfies the code requirements. The validation of  
7 SSDP provides confirmation that the calculation result  
8 meets the requirements of the code additions which are  
9 specified for the project.

10 The equations used in the SSDP computer  
11 codes were verified by comparing the results with the  
12 results from the equation presented in the concrete  
13 design textbook. The validation of SSDP confirms that  
14 the calculation results satisfied the requirements of  
15 the codes. The coefficients using the SSDP computer  
16 code were verified with hand calculation.

17 DR. WALLIS: How do you verify an equation  
18 by hand calculation?

19 MR. NIOGI: Well --

20 DR. WALLIS: Either the equation is right  
21 or not, it seems to me --

22 MR. NIOGI: The numbers.

23 DR. WALLIS: When you use it to calculate?

24 MR. NIOGI: Yes. You use the equation. I  
25 mean you come up with the number, the same number.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: You don't, you don't verify F  
2 equals MA by using it to calculate them?

3 MR. NIOGI: No. I think we should say the  
4 numbers are verified, yes. The computation has the  
5 same number.

6 DR. WALLIS: Well, compared with what  
7 then?

8 CHAIRMAN CORRADINI: Well, I think --  
9 well, at least the way -- maybe it's the words that  
10 you've used today. What I interpreted you to mean was  
11 that you went to handbook calculations and did a  
12 calculation and confirmed it compared to what the  
13 computer calculation.

14 DR. WALLIS: The result. You didn't  
15 compare the equation.

16 (Simultaneous discussion.)

17 DR. WALLIS: You just compared it to  
18 nothing.

19 CHAIRMAN CORRADINI: Yes. That's what I  
20 interpreted it to mean.

21 DR. WALLIS: Right, right. Well, yes.  
22 But I'm just asking him what he means.

23 MR. NIOGI: Right, yes.

24 DR. WALLIS: And you know what --

25 CHAIRMAN CORRADINI: Is my interpretation

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 correct or -- is my --

2 MR. NIOGI: Yes, your interpretation is  
3 fine. We should have said that hand calculated  
4 results, yes.

5 DR. WALLIS: You know, the predictions or  
6 something.

7 MR. NIOGI: Right, yes.

8 DR. WALLIS: Okay.

9 MR. NIOGI: Thanks for pointing it out,  
10 and it was -- yes. We should have said that, yes.  
11 NRC RAI 3.8-120. NRC indicated in their review that  
12 the material thickness for reactor shield wall in some  
13 locations is better than ten inches. ASTM 8516 is  
14 only available up to eight and a quarter inch, inches  
15 thick.

16 ASTM 8709 is only available up to four  
17 inches. NRC requested GEH to explain how reactor  
18 shield wall will be fabricated. The staff also raised  
19 a concern related to welding A -709 material to the  
20 containment steel liner and accept the report case for  
21 this type of welding.

22 GEH plans to fabricate using four inch  
23 maximum thickness steel using multi -layer vessel  
24 construction technique. Multi-layer construction has  
25 been very effective for cylindrical pressure vessels

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 more than 16 inches thick. The construction  
2 techniques allow the multi-layer shells to act as a  
3 solid wall.

4 DR. WALLIS: Well, they can't be attached  
5 all along the interface.

6 MR. NIOGI: They behave as a monolithic  
7 structure.

8 DR. WALLIS: Because of friction at the  
9 interface?

10 MR. NIOGI: Yes. We show the friction  
11 technique, you know. You can have it --. There are  
12 four different techniques discussed.

13 DR. WALLIS: To me, if they were heated  
14 sufficiently, then they would buckle out from each  
15 other, these layers.

16 MR. NIOGI: Well --

17 DR. WALLIS: Out of a fire or something.

18 MR. NIOGI: It is being used for model, to  
19 show that technique in the pressure vessel.

20 DR. WALLIS: Yes. It's all right as a  
21 pressure vessel. It's just, I can think of events  
22 which might delaminate or separate these layers?

23 MR. NIOGI: Do you want me to discuss  
24 this, bring my metal engineer?

25 DR. WALLIS: I'm not sure. I'm just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 asking you --

2 MEMBER ARMIJO: What is the shape of the  
3 shield wall?

4 MR. NIOGI: It's a cylindrical shape.

5 MEMBER ARMIJO: Well, you have -- these  
6 are nested cylinders?

7 MR. NIOGI: Yes, they're nested cylinders.

8 DR. WALLIS: As long as it's under  
9 pressure, it's fine. But it seems to me if you've got  
10 say an impingement of a steam jet on the wall or  
11 something --

12 MR. NIOGI: Right.

13 DR. WALLIS: Then it would be known that  
14 you can separate steel liners from concrete by  
15 impinging a steam jet and it's happened.

16 MR. NIOGI: Yes.

17 DR. WALLIS: So it seems to me there are  
18 situations where these layers would tend to separate  
19 from each other.

20 MR. NIOGI: Right. In the case of liner,  
21 where the jet will impinge the liner, you know, the  
22 thickness of the liner is an issue here is a --. But  
23 you're talking about an impingement, you know, that --

24 DR. WALLIS: So if it's hot enough.

25 MR. NIOGI: That's right, and also in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 case of liner, you know, it is backed by concrete.  
2 It's not backed by the steam.

3 DR. WALLIS: The shield wall blocks the  
4 gamma radiation?

5 MR. NIOGI: Yes. That's the --

6 DR. WALLIS: It's not a structural --  
7 (Simultaneous discussion.)

8 MEMBER KRESS: So its purpose wouldn't be  
9 bothered by separation or a big bond between the  
10 layers? It would still work for what it's supposed to  
11 do?

12 MR. NIOGI: Well, we don't want just to  
13 have thick steel sitting there and not doing anything,  
14 right? So we'd like to revise that material.

15 MEMBER KRESS: I see.

16 MR. NIOGI: So we do it --

17 MEMBER KRESS: To support something.

18 MR. NIOGI: --to support something, yes.  
19 Definitely, the pipe full blast steam.

20 MEMBER KRESS: Pipes and things like that,  
21 yes.

22 DR. WALLIS: During seismic events, it  
23 stays monolithic?

24 MR. NIOGI: Yes.

25 DR. WALLIS: It does?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. NIOGI: Yes, it does. Yes.

2 DR. WALLIS: How are the layers bonded?

3 Do you weld them in particular --

4 MR. NIOGI: I must talk to our engineer.

5 I want to, you know, in that case I need to have to

6 metal specialist to help me out. Do you want me to

7 bring him in?

8 MEMBER ABDEL-KHALIK: Yes, please.

9 MR. NIOGI: Okay.

10 MR. CRESS: Yes, please. My name is

11 Mirali Cress (ph). I'm the welding engineer, and

12 Sujit was talking about the multi-layers in sections.

13 Yes, we would like to do something like that and

14 probably, if you to -- if there is any fear of

15 separation or something, we can weld them in certain

16 areas, so that it will remain layer.

17 Normally, we can use press-fitting also,

18 so that it is tied, and this being just the radiation

19 shielding, you shouldn't be having any kind of

20 stresses or structure will get displaced or something.

21 So even if something happens, we could

22 weld them in some areas, where it could remain intact.

23 DR. WALLIS: Yes, if it's just a radiation

24 shield. I was bothered by the term, the statement

25 here that the multiple layers act as a solid wall,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 because I can think of situations where they might not  
2 act as a solid wall.

3 CHAIRMAN CORRADINI: In heating  
4 situations, I'd agree with you.

5 DR. WALLIS: Yes, right. But it's not  
6 those situations -- it's not designed for those  
7 situations, so therefore it's all right.

8 CHAIRMAN CORRADINI: So just to be clear,  
9 just so we're clear about it, so the situations it's  
10 designed for is structural -- is of course is the  
11 shield, but also structural support, and you said  
12 restraints were attached to it, if I remember what you  
13 had said.

14 MR. NIOGI: Restraints are attached to it.

15 DR. WALLIS: I'm looking at this. It says  
16 "pressure vessel" in the drawing. It's not a pressure  
17 vessel?

18 MR. NIOGI: It's not a pressure vessel.

19 DR. WALLIS: So it's all there. So I'm  
20 just looking. The words kind of misled me here.

21 CHAIRMAN CORRADINI: Open can.

22 MR. NIOGI: Open can, exactly. That's  
23 like BWR, you know, mark one to three. You have a  
24 shield obviously made of steel and concrete, you know.  
25 This is concrete. We reduce the phase b y using the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 shield.

2 DR. WALLIS: That's a radiation shield,  
3 okay.

4 MR. NIOGI: Yes.

5 DR. WALLIS: Well, it's big enough and  
6 strong enough. It could act as shield for other  
7 purposes.

8 (Laughter.)

9 MEMBER KRESS: I think they made that  
10 point, that t hey could do something more than just  
11 have it sit there.

12 MR. NIOGI: Our radiation technique is  
13 complying with ASME code fully utilized. Welding of  
14 dissimilar material with as similar land material has  
15 been satisfactorily addressed.

16 NRC RAI 3.8-125. Confirm that the impact  
17 of the spent fuel storage racks will not adversely  
18 impact the spent fuel pool walls.

19 DR. WALLIS: Now by "impact," you don't  
20 mean collision. You mean the effect.

21 CHAIRMAN CORRADINI: No, I think he means.

22 MR. NIOGI: I'm really meaning impact.

23 DR. WALLIS: You mean an exchange of  
24 momentum, bumping?

25 MR. NIOGI: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: Okay.

2 MR. NIOGI: Confirm that impact of spent  
3 fuel storage racks will not adversely impact the spent  
4 fuel pool walls.

5 DR. WALLIS: Second impact is -- it means  
6 effect or something, yes. The first impact is  
7 physical. The second impact is an effect.

8 MR. NIOGI: An effect.

9 DR. WALLIS: Okay.

10 MR. NIOGI: --during SSE event with may  
11 cause over-stressing of concrete walls. The free -  
12 standing spent fuel storage racks are supported on  
13 embedded place on the spent fuel pool base mat. To  
14 preclude the racks contacting the walls during an SSE  
15 event, the free -standing racks were designed to  
16 provide sufficient gap between the racks and the  
17 walls.

18 DR. WALLIS: And that's confirmed by  
19 analysis?

20 MR. NIOGI: That analysis has demonstrated  
21 that the racks will not contact the spent fuel pool  
22 walls.

23 DR. WALLIS: Now this is a bit like the  
24 PCCS seismic response, where you have structures in  
25 water moving around, right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. NIOGI: Right, yes.

2 DR. WALLIS: There's water in this spent  
3 fuel --

4 MR. NIOGI: There's water, yes.

5 DR. WALLIS: And the racks are submerged  
6 in water?

7 MR. NIOGI: Submerged in water.

8 DR. WALLIS: And the last time we met, we  
9 had some questions about how you treated the added  
10 mass for this situation?

11 CHAIRMAN CORRADINI: This was for PCCS.

12 DR. WALLIS: Yes, but I didn't see  
13 anything about PCCS in this presentation, or even in  
14 the SER.

15 MS. CUBBAGE: We came back in a separate  
16 meeting and addressed those issues.

17 DR. WALLIS: That was all resolved, was  
18 it?

19 MR. NIOGI: Yes.

20 MS. CUBBAGE: Yes.

21 CHAIRMAN CORRADINI: For PCCS.

22 DR. WALLIS: It was resolved? I thought  
23 we just had questions. It was resolved?

24 CHAIRMAN CORRADINI: Well, we had a  
25 subcommittee meeting back in November, where they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 showed us the additional calculations.

2 DR. WALLIS: I think I have questions  
3 about the validity of the calculations.

4 CHAIRMAN CORRADINI: It seem to remember  
5 at the moment you were -- I seem to remember at that  
6 moment you were satisfied.

7 DR. WALLIS: Just evaporated? Well, I  
8 read a report. Well, okay, all right.

9 CHAIRMAN CORRADINI: At the time you were  
10 satisfied.

11 DR. WALLIS: At the time, I read a report.  
12 I don't know. It just disappeared into the system.

13 CHAIRMAN CORRADINI: But this one is spent  
14 fuel.

15 MR. NIOGI: This is spent fuel.

16 DR. WALLIS: You're not going to talk  
17 about PCCS then, because that's already been resolved  
18 somewhere?

19 CHAIRMAN CORRADINI: Well, we're not going  
20 to talk about it today.

21 DR. WALLIS: Okay. I'll have to look back  
22 at what date it was that I wrote my report.

23 CHAIRMAN CORRADINI: Well, I can find it  
24 for you if you want.

25 MEMBER KRESS: Unless they used the same

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 technique for added mass here. So if he has issues  
2 with it in the PCCS, there might be issues here. It  
3 would be nice to know how they treated the added mass.

4 CHAIRMAN CORRADINI: If you want to ask  
5 the question to them, then, about your --

6 MEMBER KRESS: They might not be prepared  
7 to answer that, but --

8 DR. WALLIS: No. I mean the staff in some  
9 way is satisfied. I don't know why.

10 MEMBER KRESS: Well maybe Amy --

11 DR. WALLIS: Then we'll ask them.

12 MEMBER KRESS: --could discuss it. You  
13 were happy with what they did?

14 MS. CUBBAGE: We were happy with what they  
15 did at the time, and we left with no action items from  
16 the Subcommittee.

17 MEMBER KRESS: You're going to give us a  
18 talk after this one?

19 MS. CUBBAGE: We are.

20 DR. WALLIS: There was a time we talked  
21 about sloshing as well. I remember the time, and I  
22 was not satisfied with added mass. But anyway, let's  
23 move on.

24 CHAIRMAN CORRADINI: Yes. In this case,  
25 the racks are very submerged.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: I don't think that's as much  
2 an issue as it was -- the PCCS is a bigger issue.

3 MR. NIOGI: Right.

4 DR. WALLIS: That's a bigger issue.

5 CHAIRMAN CORRADINI: They're near -- I  
6 mean from the standpoint of submergence, these are  
7 many meters below the water level.

8 DR. WALLIS: Can't move without pushing  
9 the water around.

10 MEMBER KRESS: The water has to move that.

11 CHAIRMAN CORRADINI: The PCCS is sitting  
12 with the water level near the upper drum, if that --  
13 if my memory --

14 DR. WALLIS: It doesn't matter for added  
15 mass, and that is for sloshing.

16 MR. NIOGI: Sloshing.

17 MR. DEEVER: Right. Our racks are more  
18 than ten meters below the water surface.

19 MEMBER ARMIJO: What is the gap between  
20 the racks and the walls? Is it how many feet, inches.

21 MR. NIOGI: No. Six inches, a little less  
22 than six inches.

23 MEMBER ARMIJO: Inches, and what's the  
24 maximum amplitude of the rack?

25 MR. DEEVER: I heard that it's 42

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 millimeters, in the north-south direction, and in the  
2 east-west direction it's 60 millimeters.

3 MEMBER ARMIJO: That's not very much.

4 MR. DEEVER: Not very much.

5 MEMBER KRESS: Is each rack free-standing?

6 MR. DEEVER: They're free -standing. What  
7 we had to do --

8 MEMBER KRESS: They can impact each other?

9 MR. DEEVER: What we did is we had to  
10 couple all the racks, link them toget her. We have a  
11 base plate that they sit in that restrains the  
12 separation.

13 MEMBER KRESS: At the bottom, at the  
14 bottom there.

15 MR. DEEVER: Yes, at the bottom, and also  
16 at the top.

17 MEMBER KRESS: They're linked at the top  
18 also?

19 MR. DEEVER: They are.

20 MEMBER KRESS: So they have to move --

21 MR. DEEVER: They have to use this as a  
22 complete unit.

23 MEMBER KRESS: I see.

24 MR. DEEVER: It eliminated a lot of the  
25 complexity of impacts and non-linear analysis.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: Yes. That would make a big  
2 difference on the amplitudes too.

3 MR. DEAVER: Yes.

4 MEMBER ARMIJO: So is this sort of an egg  
5 crate structure, the entire fuel rack structure is one  
6 thing --

7 MR. DEAVER: Yes.

8 MEMBER ARMIJO: Bonded to some big plate  
9 on the bottom of the pool?

10 MR. DEAVER: It sits in a base plate that  
11 has vertical plates that restrain motion.

12 MR. NIOGI: Shear logs at the day. So  
13 there's not going to be space --

14 MEMBER ARMIJO: And that's sort of welded  
15 to the liner or --

16 MR. NIOGI: No. It's not welded to the  
17 liner.

18 MEMBER ARMIJO: It sits on the liner?

19 MR. NIOGI: No. The shear log is welded  
20 to a base plate, and the base plate is then in turn  
21 welded to the embedment plate, which is resting on the  
22 -- which is embedded into the concrete base mat.

23 So you have two layers of embedment. One  
24 is shear log welded to the base plate upper rack,  
25 which is then connected to the embedded plate, which

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is connected to the base mat of the fuel group.

2 MEMBER ARMIJO: And where is the liner?

3 MR. NIOGI: The liner is then comes and is  
4 welded on the top of the base mat, and with a leak  
5 system that the water cannot go through. I don't know  
6 if there is a --

7 MEMBER ARMIJO: If there's a sketch or  
8 somewhere later in the day, if you could just give me.

9 MR. NIOGI: Sure. The board I can draw  
10 right now, you know.

11 MEMBER ARMIJO: So I could understand.

12 MR. NIOGI: The board I can draw right  
13 now, you know.

14 MEMBER ARMIJO: I'd just like to see what  
15 it looks like.

16 DR. WALLIS: Can we dig out this PCCS?

17 CHAIRMAN CORRADINI: I'm trying.

18 DR. WALLIS: At some time in the future.

19 CHAIRMAN CORRADINI: I have your November  
20 letter. You don't mention after that any concerns  
21 there. It was mainly about hydrogen at the time.

22 DR. WALLIS: I had about three pages on  
23 added mass in one of the reports.

24 CHAIRMAN CORRADINI: That was earlier.

25 MS. CUBBAGE: It may have been in advance.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: That was earlier?

2 CHAIRMAN CORRADINI: That was earlier, and  
3 we came back -- they came back. If my memory is, I  
4 have, I'm looking. They came back with a series of  
5 calculations and varied the parameter.

6 DR. WALLIS: Maybe I wasn't here, because  
7 I don't remember it being resolved. But anyway, the  
8 staff is satisfied. That's what matters.

9 CHAIRMAN CORRADINI: I'll keep on looking,  
10 but memory is, my memory is we were in January of '09,  
11 approximately then where we were talking about added  
12 mass effects, we came back, staff came back and at the  
13 November Subcommittee meeting, and that's we --

14 You were happy about that, but we then  
15 went off, talking about the fan performance and  
16 hydrogen effects, and that's how -- that was the major  
17 open item that came out of the November meeting.

18 DR. WALLIS: Yes.

19 CHAIRMAN CORRADINI: That's what I have at  
20 this --

21 DR. WALLIS: Okay. Well, but you'll look  
22 into it and we'll figure it out.

23 CHAIRMAN CORRADINI: Okay, right.

24 MEMBER ARMIJO: Because of this way you've  
25 designed it, even though you have a very small gap,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 what is the amplitude, the maximum amplitude of this  
2 rack, moving towards the liner? Is it half an inch or  
3 a tenth of an inch?

4 (Simultaneous discussion.)

5 MR. NIOGI: Toward the wall, yes.

6 MEMBER ARMIJO: Toward the wall, yes. You  
7 say it's sufficient gap, so there's two numbers I'm  
8 interested in. What is the gap and how much of it do  
9 you use in your SSE?

10 MR. DEAVER: Yes. We just have a few  
11 millimeters of gap, but you have to consider that the  
12 pool, we're working to the minimum dimensions of the  
13 pool, and so in reality, when you get the real as-  
14 built, we're going to find --

15 MEMBER ARMIJO: I'm just looking for how  
16 much margin you have between your calculation of how  
17 much. When you say it's sufficient gap --

18 CHAIRMAN CORRADINI: What Sam's asking --  
19 what Sam's asking is when it wiggles, how much is t he  
20 open area after it wiggles?

21 MEMBER ARMIJO: Yes, right. How much is  
22 left over?

23 MEMBER KRESS: How close is this --

24 CHAIRMAN CORRADINI: How close are you  
25 going to get? That's what I guess he's asking.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: 90 percent of your gap, 80  
2 percent of your gap, ten percent?

3 MEMBER KRESS: In a pool like this, it's  
4 difficult. It's vibration motions, because you have  
5 to have some model for what happens to the water. Did  
6 you treat the water at all in these calculations?

7 MR. DEAVER: Oh yes, definitely.

8 MEMBER KRESS: You had an added mass  
9 calculation?

10 MEMBER ARMIJO: Then you have an answer  
11 somewhere.

12 MR. DEAVER: Is this -- do we want to get  
13 back to them?

14 CHAIRMAN CORRADINI: I think that's the  
15 best thing to do.

16 MR. NIOGI: Yes . I think we should get  
17 back to you with the number, because this is Chapter  
18 9.9, you know.

19 DR. WALLIS: It helps with these wordy  
20 statements if you provide a figure and some numbers.

21 CHAIRMAN CORRADINI: Yes, it would.

22 MR. NIOGI: A figure?

23 DR. WALLIS: A figure and some numbers.

24 This is the way it shakes, this is what we calculate,  
25 this is what the gap was, and this is what it is when

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it shakes. That would be very clear and we'd go away  
2 and have to be happy.

3 MR. DEEVER: What happens at the top of  
4 the rack. It will sway --

5 (Simultaneous discussion.)

6 DR. WALLIS: Yes, that's what --  
7 otherwise, we can talk forever.

8 MEMBER ARMIJO: You've got that down. I  
9 understand.

10 MR. DEEVER: Well actually, it's not  
11 totally locked down.

12 CHAIRMAN CORRADINI: So we'll take it as -  
13 - you guys will take it as an action item, and I've  
14 written it down that we'll come back. Wayne enjoys  
15 these little tasks.

16 MR. MARQUINO: It give me something to do.

17 CHAIRMAN CORRADINI: Right, okay.

18 MR. NIOGI: So that -- this is considered  
19 my presentation.

20 CHAIRMAN CORRADINI: Okay, all right.

21 Other questions on these RAIs?

22 (No response.)

23 CHAIRMAN CORRADINI: Okay. Thank you very  
24 much. I think the way we're doing this is staff is  
25 now coming up Amy?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. CUBBAGE: Yes.

2 CHAIRMAN CORRADINI: Okay.

3 MR. NIOGI: Thank you. Thank you very  
4 much.

5 CHAIRMAN CORRADINI: Thank you very much.

6 (Off mic discussions.)

7 CHAIRMAN CORRADINI: Dave, are you going  
8 to kick us off here?

9 MR. MISENHIMER: Yes.

10 CHAIRMAN CORRADINI: Okay, all right. Go  
11 ahead, I'm sorry.

12 Chapter 3 - Section 3.8 RAIs/Staff

13 MR. MISENHIMER: Okay. I've Dave  
14 Misenhimer. I'm the project manager for Chapter 3,  
15 and today Samir Chakrabarti is going to address the  
16 significant RAIs open items that are related to  
17 Section 3.8.

18 MR. CHAKRABARTI: Okay. Good morning.  
19 I'm Samir Chakrabarti. I'm the NRC technical reviewer  
20 for ESBWR Section 3.8, and we have with us here today  
21 our technical consultants from BNL, which is Joe  
22 Braverman and Rich Morante, to help us with any  
23 questions that you may have.

24 We have completed our review of Section  
25 3.8, and in the first line there's basic regulations

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and standards that we use for the review. It was a  
2 very extensive review that spanned over about fi ve  
3 years, I would say, and I also picked it up in the  
4 middle of somewhere.

5 But fortunately, BNL Consultants, they  
6 have the same guys who performed the review also, and  
7 that ensures some continuity in the relation. We had  
8 five design audits that were per formed to review  
9 calculations and discuss various issues with the  
10 applicant.

11 We have performed the confirmatory  
12 analysis of the base mat calculation --

13 DR. WALLIS: When the base mat -- you  
14 asked about whether or not it moves. Does it matter  
15 how much water is underneath it?

16 MR. CHAKRABARTI: Say that again?

17 DR. WALLIS: Does it matter how wet the  
18 soil is? So you said you confirmed analysis of this,  
19 and that you were concerned about the base mat moving  
20 in the soil, I think?

21 MR. CHAKRABARTI: Yes.

22 DR. WALLIS: Does it matter how wet the  
23 soil is?

24 MR. CHAKRABARTI: Well, that's the  
25 coefficient of friction that we used.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: But it changes a lot, doesn't  
2 it, depending on how wet it is, or does it not?

3 MR. BRAVERMAN: Yes. If you're speaking  
4 about -- this is Joe Braverman from BNL. If you're  
5 speaking about the confirmatory analysis that we  
6 performed, we primarily did independent analysis of  
7 the reactor building foundation. We were looking at  
8 three areas.

9 One of the areas was that you initially  
10 assumed the concrete base mat was one thickness, and  
11 in reality, there were two variations of that.

12 CHAIRMAN CORRADINI: Joe, I think -- Joe?  
13 I think you're going to have to get it closer to you.  
14 I don't think they're catching what you're saying.

15 MR. BRAVERMAN: Okay. I'll start again.  
16 In the confirmatory analysis that BNL performed, we  
17 were looking at three areas. One is G assumed that  
18 the concrete base mat was a constant thickness, and  
19 the reality, there's some variations in it.

20 Also, they use a thick shell element, a  
21 final element representation for the base mat which is  
22 a single like shell element that has through the  
23 thickness capability, of being able to use 3D solid  
24 element representation, because we questioned how  
25 accurate that would be.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           The third thing is they used a Naturine  
2           (ph) computer code, and BNL followed an ANSYS computer  
3           code. So we looked at those differences, and we  
4           analyzed seismic loading, dead weight, hydrostamin  
5           (ph). So it wasn't intended to study the effect of  
6           the soil and how they modeled the building.

7           DR. WALLIS: No. But the presentation we  
8           heard was about the base mat actually moving or  
9           lifting up and so on, and I just wondered what the  
10          soil was in those kind of calculations.

11          MR. BRAVERMAN: Okay, but that's not part  
12          of the confirmatory analysis.

13          DR. WALLIS: No, but I just -- but it was  
14          -- you reviewed and accepted GEH's analysis for these  
15          other phenomena.

16          MR. BRAVERMAN: Oh yes.

17          DR. WALLIS: So I'm asking if the staff  
18          understands how the wetness of the soil affects  
19          whether or not the base mat moves or lifts off or does  
20          various other things? So I'm just asking if the staff  
21          understands that, and therefore accepts what GEH  
22          submitted?

23          MR. BRAVERMAN: Yes, we did review that,  
24          and we accepted it on the following basis. The SSI  
25          analysis used the SASSI code. The SASSI code does not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have non-linear, does not have non -linear capability.

2 It cannot lift off, because the springs aren't  
3 compression -- not the springs. The contact between  
4 the soil and the base mat takes compression and  
5 tension.

6 So they did a separate calculation based  
7 on the energy balance method, and that formulation  
8 does have lift-off capability. So we have relied on  
9 that analysis to see what extent of uplift there is,  
10 and it's not significant.

11 DR. WALLIS: And in terms of the friction  
12 coefficient, is the wetness of the soil considered?

13 MR. BRAVERMAN: Well, in the lift -off  
14 analysis, friction does not enter. Friction entered  
15 in the sliding and overturns.

16 DR. WALLIS: In the sliding, right. In  
17 the sliding analysis, is the wetness of the soil  
18 considered?

19 MR. BRAVERMAN: In the sliding, the effect  
20 of the moisture content in the soil wouldn't, would  
21 not --

22 DR. WALLIS: Has no effect.

23 CHAIRMAN CORRADINI: Why doesn't it? I'm  
24 listening to Graham ask you all these questions. Now  
25 I'm curious. Why doesn't it?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: I've slid around a lot on wet  
2 soil. Now maybe I don't weigh enough to make any  
3 difference.

4 (Laughter.)

5 CHAIRMAN CORRADINI: You need to be  
6 heavier.

7 MR. NIOGI: I can answer these questions.

8 CHAIRMAN CORRADINI: Identify yourself  
9 please.

10 MR. NIOGI: This is Sujit Niogi from GE  
11 Hitachi. What we did, you know, this is what was  
12 mentioned, that if we can slide on a wet surface.  
13 Yes. So we know that situation. So what we did, we  
14 have a trough in in the soil. So the concrete mud  
15 mat, when you pour, you pour on the trough on the  
16 soil. You get these GRA resistance, like a shear key.

17 CHAIRMAN CORRADINI: They added --  
18 remember that's what he described. They added what he  
19 calls a shear key, essentially like a ring of concrete  
20 around the base.

21 DR. WALLIS: That holds it in place?

22 CHAIRMAN CORRADINI: Well, that gives you  
23 extra margin so when you wiggle it doesn't move as  
24 much.

25 DR. WALLIS: So you wiggle. When the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 soil's wet, it doesn't move?

2 MR. NIOGI: In addition to that, below the  
3 mud mat, below the mud mat we have also a trough in  
4 the soil.

5 MEMBER ARMIJO: Are these like  
6 corrugations?

7 MR. NIOGI: Yes, corrugations.

8 MEMBER ARMIJO: Okay.

9 MR. NIOGI: Right, like a tool deck.

10 MR. BRAVERMAN: Also the entire reactor  
11 building foundation is embedded in the soil, so it's  
12 not like a structure resting on the top surface that  
13 can slide.

14 DR. WALLIS: No, no. I understand that.  
15 But the forces can be pretty big when you shake the  
16 soil?

17 CHAIRMAN CORRADINI: Oh yes.

18 DR. WALLIS: And actually the shaking of  
19 the soil can change the friction coefficient itself,  
20 because if it moves the liquid around.

21 MR. CHAKRABARTI: I think question is the  
22 friction coefficient that we assumed, how it is  
23 impacted by water in the salt marsh or water in the  
24 soil. What we have assumed in this analysis, the  
25 friction coefficient is based on shear failure of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 soil, and because it has been taken as a tang ent of  
2 the angle of friction.

3 Now that value, whether it is impacted by  
4 salt water in that soil, I guess not. We have assumed  
5 tangent total frictional figure of the soil, and to  
6 make sure that the soil absorbs friction, and it does  
7 not slide on the surface.

8 DR. WALLIS: I don't know. I'm just  
9 speculating. It seems to me that if you shake a wet  
10 soil with a seismic sort of stresses, you're going to  
11 squeeze the water out of it. But I'm just curious  
12 about this, that's all, and I'm not an expert on it,  
13 except maybe in the squeezing of water out of the  
14 soil.

15 But I'm just curious how you handled it,  
16 and you can assure me that it's handled properly?

17 MR. BRAVERMAN: I have no information with  
18 me at hand.

19 CHAIRMAN CORRADINI: He's asking for a  
20 judgment.

21 DR. WALLIS: No, but I guess --

22 MR. BRAVERMAN: In my judgment, I don't  
23 think it will have a significant variation. Plus  
24 they're not relying primarily on just the friction  
25 alone, as I mentioned. They have a large frontal area

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that's embedded --

2 DR. WALLIS: So it has to sort of move a  
3 whole lot of soil.

4 MR. BRAVERMAN: Yes. It's not just  
5 friction. It's all of the resisting --

6 (Simultaneous discussion.)

7 DR. WALLIS: That probably, that probably  
8 does it. Yes, okay. Well --

9 CHAIRMAN CORRADINI: The applicant stated  
10 in the response to RAI 3.8-96 that by roughening the  
11 top surface of the mud mat concrete, friction  
12 resistance is increased between the mud mat and base  
13 mat, added troughs in the soil under the mud mat to  
14 increase shear resistance.

15 DR. WALLIS: That's right.

16 CHAIRMAN CORRADINI: Is this a skill of  
17 the CRHAV? Is there some kind of analysis that  
18 relates this to whatever friction factor you assumed,  
19 or is this just --

20 MR. NIOGI: The roughening of the concave  
21 surface, you know, for every layer of concrete, it is  
22 in the ACI (ph) code. It is accepted by the code, you  
23 know. We are just honoring the code.

24 CHAIRMAN CORRADINI: How

25 MEMBER ABDEL-KHALIK: How do you relate to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the assumed friction factor?

2 MR. NIOGI: It is -- that code will tell  
3 you that this is the number you can use, .7. We are  
4 just using the applicable standard and the code used  
5 to get this number. Coefficient of friction is always  
6 experimental, and we come to the number that will be  
7 more conservative.

8 MR. CHAKRABARTI: Yes, if I may explain.  
9 What we have shown in the evaluation is slipping at  
10 different interfaces. First is the mud mat and the  
11 soil surface. The coefficient of friction assumed,  
12 .7, is fairly high, and relies on shear failure of the  
13 soil.

14 To ensure that the soil friction shear,  
15 that's when the coefficient and then the mud mat was  
16 introduced. So that the, really the soil will shear  
17 before there is a tendency to slip at the interface.  
18 That was the basis for the coefficient.

19 And al so, we are pouring foundation  
20 concrete about the base mud mat, and this -- all  
21 concrete and new concrete, what is the coefficient of  
22 friction to assume between that? According to CIT-49,  
23 it says it could go maximum .6 coefficient of friction  
24 when you pour new concrete on old concrete.

25 But this coefficient of friction can go as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 high as one, if the surface of the interface is  
2 intentionally roughened. What is meant by  
3 intentionally roughened is you roughen so that there  
4 is at least quarter inch of depth of the roughening.  
5 If you can ensure that, you can go to as high as one  
6 as the coefficient of friction.

7 So we have gone for intentional roughening  
8 and used .7 coefficient of friction.

9 CHAIRMAN CORRADINI: Thank you.

10 MEMBER KRESS: Educate me a little. I'm  
11 not an expert in this area. It seems to me like all  
12 the seismic forces are transferred from the soil to  
13 the structures.

14 MR. CHAKRABARTI: Yes.

15 MEMBER KRESS: Now it's the structures  
16 that you worry about, so if you want to lessen the  
17 effect of the seismic event on the structures, you  
18 would like to have as much as sliding as you can --

19 (Simultaneous discussion.)

20 MEMBER KRESS: What you're doing is  
21 increasing the forces?

22 MR. CHAKRABARTI: Yes, that's right. But  
23 we have not performed our analysis --

24 (Simultaneous discussion.)

25 CHAIRMAN CORRADINI: My sense of it is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that's an innovative way that a conservative engineer  
2 will not touch with a ten-foot pole.

3 MEMBER KRESS: Oh, you want to be? You  
4 remember the Moten, I mean the liquid metal, the  
5 breeder reactor --

6 CHAIRMAN CORRADINI: Yes, yes. The Clinch  
7 River. Clinch River did that.

8 MEMBER KRESS: They did that. They did  
9 that, yes.

10 MR. CHAKRABARTI: That's a new state of  
11 the art thing that is coming up.

12 MEMBER KRESS: Yes.

13 MR. CHAKRABARTI: And base isolation is  
14 being introduced in the design. But these are  
15 conventional nuclear power plants.

16 MEMBER KRESS: This is the way -- so  
17 you're being conservative by increasing the effects of  
18 the --

19 MR. CHAKRABARTI: I understand. If it  
20 slips, it cannot transfer the --

21 DR. WALLIS: Did you lubricate the molten  
22 lead by putting water on it?

23 CHAIRMAN CORRADINI: They haven't had  
24 Graham review it. They haven't.

25 (Simultaneous discussion.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BRAVERMAN: Excuse me, excuse me. I  
2 just realized there was another consideration that may  
3 answer your question about a dry soil or saturated  
4 conditions, because really GE could have identified  
5 any fee factor which determines the coefficient of  
6 shear fail in the soil.

7 The reason for that is there's in Table 1,  
8 Table 5, a requirement that at the site, the COLA has  
9 to demonstrate that they satisfy this fee, equal, I  
10 think, 30 or 35 degrees, which gives you a .7 value.

11 So that could be confirmed later on at the  
12 site, to make sure the soil conditions, whatever it  
13 is, saturated, dry, satisfies that minimum coefficient  
14 of friction. So that's another check that can be done  
15 down the road.

16 MR. CHAKRABARTI: Yes, and like during the  
17 process of review, there have been many enhancements  
18 to the DCD from the way it was originally submitted.

19 The status of the review. All issues  
20 identified during the review have been resolved. The  
21 PCCS, we still haven't had any issue with PCCS, but  
22 this is being addressed in Section 6.2.2.

23 DR. WALLIS: It's actually in the SCR, is  
24 that?

25 MR. CHAKRABARTI: In the SCR? No, we had

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 started discussing about the PCCS because it --

2 DR. WALLIS: But it disappeared. I  
3 couldn't find it, a discussion later on.

4 MR. CHAKRABARTI: I think at the end of  
5 RAI 3.8-117, we had introduced discussion of the PCCS.  
6 But then we have referred it to Section 6.2.

7 DR. WALLIS: It seemed to be referred to  
8 early on, and then it never appeared later on in  
9 detail. But maybe I -- it was such a long document.

10 MR. CHAKRABARTI: I know. At the end of  
11 RAI 117, we had discussed the issue of PCCS, because  
12 we were reviewing at that time. But then we decided  
13 it is better to address the issue under 6.2 and close  
14 it.

15 DR. WALLIS: Oh, I see. Okay.

16 MR. CHAKRABARTI: So we moved it to 6.2.

17 DR. WALLIS: Oh, that's where you put it.  
18 Okay, okay.

19 MR. CHAKRABARTI: Yes. The way I have  
20 planned the presentation like, you know, last ACRS  
21 presentation we had talked about a few issues relative  
22 to various RAIs, and GEH, I think, did a good job in  
23 talking about the same RAIs in this more bigger scope  
24 of what the RAI was about.

25 All of these RAIs really started with many

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 questions, but I'll go over the issue that was open or  
2 that were open during the last ACRS meeting, and  
3 address those.

4 In 3.8-107, the issue that we had open on  
5 this one during the last meeting was significant non-  
6 linear behavior of the containment structure due to  
7 thermal loading.

8 What we have noticed, that the thermal  
9 stresses had caused significant cracking in the  
10 concrete sections, and we had a notion that we are  
11 using this cracked section analysis results and  
12 superimposing them with the elastically computed  
13 stressors from other mechanical loads.

14 Was it practical to do it, because all  
15 those loads will be acting together and due to thermal  
16 load cracking and the forces and moments we've  
17 computed elastically, they'll be redistributed and  
18 it's still okay.

19 GEH performed an analysis where they  
20 considered in a sample case the mechanical loading,  
21 also considered the non-linear behavior with cracked  
22 sections, and they demonstrated that in the main  
23 critical areas or in the majority of the areas, the  
24 elastic analysis superimposition was still okay.

25 There were certain areas where the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 resultant stresses were exceeded because of  
2 redistribution, but those areas were located in areas  
3 where stresses are not critical. Based on that, we  
4 accepted the method of superimposing elastic analysis  
5 results for mechanical loads with the non-linear  
6 thermal results, and -- results.

7 In RAI 3.8-79, this was about the Seismic  
8 Category 2 or non-seismic structure GEH described.  
9 They're all designed to Category 1. During the last  
10 ACRS meeting when we had, this was not involved at  
11 that time because GEH was planning to design them to  
12 meet the seismic criteria. But finally, we agreed  
13 that to demonstrate there will not be any unacceptable  
14 interaction.

15 DR. WALLIS: What kind of unacceptable  
16 seismic interaction are you thinking about?

17 MR. CHAKRABARTI: If these Category 2  
18 structures are not designed using the SSC or the  
19 seismic forces, there are a few things. First of all,  
20 the seismic input motion. If we do not follow the  
21 Category 1 design, the seismic input motion can be  
22 derived using other codes that may not be prevalent.

23 In the design approach, the Category 2  
24 structures don't need to design, need to be designed  
25 to remain stable or anything. As long as it does not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hit the other structure. By the seismic interaction,  
2 we mean like if you have a non-Category 1 structure,  
3 during a seismic event it collapses and hits the  
4 Category 1 building.

5 DR. WALLIS: Okay.

6 MR. CHAKRABARTI: So if it his the  
7 Category 1 building, it might be still okay. But we  
8 have to --

9 DR. WALLIS: There's an impact --

10 MR. CHAKRABARTI: Impact, yes. We have to  
11 take into consideration impact. It is more difficult  
12 to analyze those for with an impact than are easier to  
13 make sure they don't impact. That's what by  
14 following, by following the design methodology in  
15 which Category 2 structures will be designed, using  
16 the same criteria used for Category 1 structures.

17 DR. WALLIS: So that they won't collapse.

18 MR. CHAKRABARTI: They won't collapse.

19 DR. WALLIS: You start thinking about what  
20 happens if they actually collapse. That gets pretty  
21 difficult.

22 MR. CHAKRABARTI: It gets pretty  
23 difficult.

24 MEMBER KRESS: That raises another  
25 question. These are all done for say a shut -down

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 earthquake.

2 MR. CHAKRABARTI: Yes.

3 MEMBER KRESS: Now if you're going to do a  
4 PRA, you would look at earthquakes greater than that.

5 Did you look at what sort of earthquake might cause  
6 one of these problems to collapse and give you an  
7 issue? Did you look at the frequency of those?

8 MR. CHAKRABARTI: I'm not -- I did not  
9 really go into the --

10 MEMBER KRESS: I guess that's a PRA issue.

11 MR. CHAKRABARTI: Yes.

12 MEMBER STETKAR: They didn't do a seismic  
13 PRA. They only did a seismic margins analysis, so  
14 they don't know.

15 MEMBER KRESS: So you wouldn't know that.  
16 Okay. Thank you.

17 MR. CHAKRABARTI: So that's how we  
18 resolved this. Then RAI 3.8 -94. There were many  
19 issues in the original RAI that GEH went through, but  
20 the issue that we had open with us in the last few  
21 days, the bearing pressure demands concluded by GEH  
22 appeared to be very high, and we had questions.

23 How are these high bearing pressure  
24 demands going to be met? Like for medium soil, the  
25 bearing pressure demand was calculated to almost 150

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 gifs (ph) per square feet, and we did not think that  
2 it would have soil that could take that kind of  
3 bearing pressure.

4 So we wanted to see what was the reason  
5 for this and how are you going to account for it, and  
6 during our review, it was found that if bearing  
7 pressure demands calculated by GEH were done very  
8 conservatively, and in fact while we had accounted the  
9 vertical loading multiple times, and that's what  
10 really led to that high bearing pressure.

11 Subsequently, GEH revised the analysis.  
12 They used the SASSI result, results in computing the  
13 bearing pressure, and the bearing pressures came down  
14 significantly, like the value that was 150 gifs per  
15 square feet were in the 50 gifs per square feet,  
16 almost one-third, and those were the results.

17 In RAI 3.8 -96, this is all the sliding  
18 evaluation and GEH was really having difficulty  
19 demonstrating sliding stability. The basic reason for  
20 this was the amendment of the structure, which really  
21 was not considered, and it was attempted to  
22 demonstrate sliding stability was in friction only.  
23 That didn't work.

24 Then the amendment was considered and the  
25 passive resistance of the soil was used for sliding

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 stability, but the embedded walls were not quite  
2 designed for the passive resistance. Also, there are  
3 many issues like at one time the correlation was  
4 considered to resist sliding.

5 So we went over this, through many  
6 iterations, and finally the method that GEH just  
7 described, that is what we found and we were able to  
8 demonstrate.

9 CHAIRMAN CORRADINI: So adding the wiggle  
10 -- adding the corrugation and the key, the shear key -  
11 -

12 MR. CHAKRABARTI: The shear keys were  
13 going --

14 CHAIRMAN CORRADINI: Satisfied or gave you  
15 confidence?

16 MR. CHAKRABARTI: In addition, we took the  
17 passive resistance of the wall. Not full passive  
18 resistance, but to the extent that it is needed to  
19 demonstrate 1.1 factor of safety against sliding.

20 So with all these and considering friction  
21 on the side walls, GEH was able to demonstrate sliding  
22 stability. All of the calculation was done using the  
23 time history, like the sliding stability was  
24 calculated for each time stake. I mean you could not  
25 qualify it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMI JO: You say that the  
2 foundation walls weren't designed for full passive  
3 soil pressure. To resolve this problem, were the  
4 foundation walls thicker or --

5 MR. CHAKRABARTI: Yes. Reinforcement had  
6 to be increased.

7 MEMBER ARMIJO: Okay.

8 MR. CHAKRABARTI: Yes. I don't think we  
9 meant the walls taken out.

10 (Simultaneous discussion.)

11 MEMBER ARMIJO: Can I hear that from GEH?

12 MR. CHAKRABARTI: Yes.

13 MR. NIOGI: Thickness of the wall was not  
14 changed. We increased the reinforcement.

15 MR. CHAKRABARTI: Yes.

16 MEMBER ARMIJO: Okay.

17 DR. WALLIS: What kind of analysis did  
18 they do to show that it is acceptable? Was it  
19 computer analysis of some sort? How do all these  
20 wiggles and roughnesses and you can use whatever you  
21 called them? What sort of analysis was done? Was  
22 this some kind of a computer that analyzes how the  
23 soil responds?

24 MR. CHAKRABARTI: I do not believe it was  
25 done, based on practically, but Sujit may be able to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 explain on that.

2 MR. NIOGI: Well, we didn't do any  
3 calculation that is a practical application, and for  
4 roughening the surface of the concrete, it's bar code  
5 SCR Code 249, which will allow you to do that. But  
6 roughening of that would be -- introducing the trough  
7 in the soil is more like practicing --. We didn't do  
8 that. There's no calculation. There is no  
9 calculation.

10 DR. WALLIS: There's no calculation on it?

11

12 MR. NIOGI: No.

13 DR. WALLIS: I just wondered how you  
14 figure out that it works?

15 MR. CHAKRABARTI: I don't know if you have  
16 established the details of that one.

17 MR. NIOGI: We have not done that.

18 MR. CHAKRABARTI: Well, that can be done  
19 really. What can be done, like you design the trough  
20 spacing so that if you push against the passive  
21 resistance of each segment, and also calculate the  
22 shear failure for that portion --

23 DR. WALLIS: Determine how it fails?

24 MR. CHAKRABARTI: I mean how it fails. So  
25 the feet can be decided.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: And then this is a hand  
2 calculation?

3 MR. CHAKRABARTI: By hand calculation you  
4 can do it, yes.

5 DR. WALLIS: And you've reviewed all that?

6 MR. CHAKRABARTI: The details of the  
7 trough has not been established.

8 MR. BRAVERMAN: Samir, this is Joe  
9 Braverman. To a large extent, I think we relied,  
10 though, on the shear keys around the periphery of the  
11 foundation, because if the shear keys are low enough,  
12 that will lock in the section of soil underneath the  
13 base mats.

14 So the effectiveness of that roughening is  
15 really kind of secondary. All that ensures the  
16 roughening of the shear keys is that failure plane  
17 will, if it does occur, will occur below the shear  
18 keys.

19 DR. WALLIS: So you consider that the keys  
20 just move the whole soil with them?

21 MR. BRAVERMAN: Exactly.

22 DR. WALLIS: And then the shear that fails  
23 is below that level?

24 MR. BRAVERMAN: Exactly.

25 DR. WALLIS: And that's just a simple hand

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 calculation?

2 MR. BRAVERMAN: Yes, because one can  
3 calculate the resistant force achievable from the  
4 shear failure of the soil. As mentioned before,  
5 that's tan of fee (phi), where fee, you know, will be  
6 verified by the COLA to achieve a .7 value.

7 MR. CHAKRABARTI: I think it can be done.

8 CHAIRMAN CORRADINI: You can go ahead, if  
9 you'd like.

10 MR. CHAKRABARTI: Okay. Next is 3.8 -120.

11 The only issue we had open on this, I mean we talked  
12 about 120, the use of that material in the FSC wall  
13 and everything.

14 At the time of the last meeting, we had  
15 resolved all that, but only open issue was it was also  
16 used in containment liner, and it was not an approved  
17 material for ASME code. But since then, ASME has  
18 approved it, and the issue was closed.

19 MEMBER ARMIJO: What was their main reason  
20 for using a higher strength material for the liner?

21 MR. CHAKRABARTI: For the liner, you  
22 probably --

23 MEMBER ARMIJO: A-709.

24 MR. CHAKRABARTI: Yes, it was -- as I  
25 remember, it was used for attachment of the structural

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 beams and stuff.

2 MR. NIOGI: Right. This is Sujit Niogi  
3 again. Those structural beams are attached to this  
4 thick plate, and that's transferring the forces and  
5 moments to the wall. So we have to use a thicker  
6 plate as an embedment, and then on the top of that, we  
7 have the buttering, which is stainless steel liner on  
8 the -- surface.

9 So we need to have this higher strength  
10 code, and also weldability. 207 is weldability. We  
11 don't need to do any pre-heat treatment, you know. So  
12 we, that is the best material we found. It certainly  
13 will --

14 MR. CHAKRABARTI: And on the liner on 1380  
15 --

16 MR. NIOGI: Only the inside the areas  
17 where --

18 MR. CHAKRABARTI: Where there are  
19 attachments?

20 MR. NIOGI: Exactly, where you have the  
21 attachments, yes.

22 MR. CHAKRABARTI: And then 3.8 -125. I  
23 think we already went over these, and basically where  
24 we were trying to look at, because what we got from  
25 the analysis is the fuel racks were anchored, and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 design was changed to a free-standing. So we wanted  
2 to see how it affects this design. GEH demonstrated  
3 that from the analysis of the spent fuel racks, the  
4 dispersements and all --

5 DR. WALLIS: They're free -standing? That  
6 means they just sit there? They aren't attached?

7 MR. CHAKRABARTI: Yes.

8 DR. WALLIS: So they're very free to move  
9 around.

10 MR. CHAKRABARTI: Very free to move  
11 around, and they ran the analysis of the fuel racks,  
12 and determined the maximum dispersements that it can  
13 have. Accordingly, we made sure the base plates on  
14 which these legs are standing, they're big enough so  
15 that it will not roll over into the containment liner  
16 area, and also it does not hit the spent fuel pool  
17 wall. So that was our main concern --

18 DR. WALLIS: Would you remember the actual  
19 numbers for the displacement?

20 MR. CHAKRABARTI: I remember for the base  
21 plates, we had at least one inch margin beyond the  
22 maximum sliding, and I can't vouch, but I think for  
23 the side walls also we had similar margin, whatever is  
24 the maximum calculated, a bolt in each wall. Misty  
25 will confirm. I think GEH has an action to get back

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to you with those numbers.

2 MR. BRAVERMAN: I'd like to address a  
3 little, because a question arose a number of times  
4 about sliding. It's not as if the racks are in air,  
5 where they would likely slide a lot. They're in  
6 water, and if you have a very deep glass, the bottom  
7 portion of the water's not going to allow the racks to  
8 move too much, because it would have to push and  
9 displace the water a lot.

10 DR. WALLIS: This is the added mass  
11 effect?

12 MR. BRAVERMAN: Yes.

13 DR. WALLIS: The concern I had with the  
14 PCCS was I didn't see a correct treatment of the added  
15 mass as being a relative motion between the structure  
16 and the water. They just seemed to add some mass to  
17 the structure, which is not the way to do it.

18 MR. BRAVERMAN: We were involved to some  
19 extent a while back regarding the PCCS analysis, and  
20 my recollection, I believe, they made a finite element  
21 model at that time. It's an older analysis, and they  
22 added water as added mass to the finite element model,  
23 the PCCS, and that is an industry-accepted methodology  
24 to estimate the --

25 (Simultaneous discussion.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: --just add mass to the solid.  
2 As you were saying, the water actually helps to  
3 restrain. It's a relative motion between the  
4 structure and the water that matters.

5 MR. BRAVERMAN: Yes, but the difference is  
6 in the fuel racks, it's free to move, so you get the  
7 structure-fluid interaction.

8 DR. WALLIS: Right.

9 MR. BRAVERMAN: In the case of the PCCS  
10 that's anchored. It's restrained.

11 DR. WALLIS: Right, but it still wiggles.

12 MR. BRAVERMAN: Well, that's where the  
13 added mass --- there have been tests done that when  
14 you have a rod vibrating in air, versus a rod  
15 vibrating in water, they would vibrate an equivalent  
16 amount if you add this much mass to it.

17 DR. WALLIS: It's in an infinite pool.  
18 But if you have walls and stuff, it gets more  
19 complicated, because the waters restrain.

20 MR. BRAVERMAN: Yes.

21 DR. WALLIS: So anyway.

22 MEMBER ABDEL -KHALIK: Is this statement  
23 correct, that the spent fuel pool concrete floor is 5-  
24 1/2 meters thick?

25 MR. NIOGI: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: It is?

2 MR. DEEVER: This is Jerry Deever with  
3 GEH. I have the dimensional information on the gaps,  
4 if you would like to get that.

5 CHAIRMAN CORRADINI: Yes. This is a good  
6 time for it.

7 MR. DEEVER: Okay. We have the two  
8 directions. One direction we have -- in the north -  
9 south direction, we have full racks all the way  
10 across, and the gap between the rack to the wall is 92  
11 millimeters initially, as a minimum. And then after  
12 seismic and thermal expansion, which aren't likely to  
13 occur at the same time, we have a minimum gap of 47.5  
14 millimeters.

15 DR. WALLIS: Is it bigger?

16 MR. DEEVER: Pardon me?

17 DR. WALLIS: Bigger than it was before?

18 MR. DEEVER: No. It started with 92.

19 CHAIRMAN CORRADINI: 92 to 47.

20 DR. WALLIS: Oh, I'm sorry. I misheard  
21 you. Thank you.

22 MR. DEEVER: Okay, and then in the east-  
23 west direction, where we have latitude deceptive  
24 dimension, because we have a lot of empty space in the  
25 other end of the rack or the pool, the initial gap is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 60 millimeters and the minimum gap is 8.4 millimeters.

2 That's with seismic and thermal.

3 DR. WALLIS: That's the closer one, yes.

4 MR. DEEVER: Pardon me?

5 DR. WALLIS: That's the closer one.

6 MR. DEEVER: That's the closer one, but  
7 remember, for a different meeting where we were here,  
8 they have total freedom to put that anywhere they  
9 want, because that's the reason where they've got the  
10 open area. Remember the open area, FLUENT calculation  
11 from a couple of meetings ago?

12 DR. WALLIS: I guess yes. There's a big  
13 open area.

14 MR. DEEVER: There's a big open area.

15 DR. WALLIS: And a strange FLUENT  
16 calculation, I must say, yes.

17 MR. DEEVER: Not strange, just not as  
18 well- described as one would like. That's my  
19 characterization.

20 MEMBER ARMIJO: That's not much left to  
21 the six millimeters or nine millimeters. It's not  
22 much --

23 MR. DEEVER: 8.4, but --

24 MEMBER ARMIJO: Sounds like this --

25 MR. DEEVER: --without the thermal

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 expansions, it's 12 millimeters, so we could set that  
2 as larger, based on as-builts when we actually --

3 MEMBER ARMIJO: So that's your worse case?

4 MR. DEAVER: Right. This is worse case,  
5 minimum dimensions.

6 MR. CHAKRABARTI: Okay. So that's how we  
7 have closed all our open issues, and if there are any  
8 other questions for us?

9 CHAIRMAN CORRADINI: None?

10 (No response.)

11 CHAIRMAN CORRADINI: Okay. Thank you very  
12 much. I think we want to continue now with Section  
13 3.9, and now GEH is going to come back up to talk  
14 about 3.9, is that correct?

15 (Off mic discussions.)

16 Chapter 3 - Section 3.9 RAIs/GEH

17 MR. DEAVER: Okay. I will continue with  
18 Section 3.9, Mr. Jerry Deaver, GE -Hitachi. I'd like  
19 to go to the next slide. There were several open  
20 items, open issues in this section, but we're going to  
21 cover five of the more significant items that were  
22 resolved.

23 So going to the next slide, 3.9-75. There  
24 was an open issue related to the reactor internal  
25 classification with respect to Reg Guide 1.20, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there was some confusion about prototype versus non-  
2 prototype.

3 We initially were classifying ESBWR as a  
4 non-prototype, because there were a lot of  
5 similarities with the ABWR plant, although we  
6 recognized that the chimney and the stand-by liquid  
7 control line were new components.

8 So we were kind of mixing up the situation  
9 by classifying them as prototypes, but the others, all  
10 the other traditional components we were saying were  
11 non-prototype. That was very confusing to the staff,  
12 and so we ultimately agreed that it would be best to  
13 classify the initial reactor, ESBWR reactor internals  
14 as prototype, and then the subsequent reactor vessels  
15 and internals would be classified as non-prototype.

16 So we had clarified that in the DCD and in  
17 the LTR that we have on reactor internals. So, okay.

18 Going to the next issue, 3.9 -96, this  
19 question had a lot of different aspects to it. This  
20 was asked at a time when we were still talking about  
21 prototype and non-prototypes, and we were relying on  
22 ABWR data in some areas, particularly the bottom head  
23 area, as to why we didn't need to have  
24 instrumentation.

25 But ultimately, we agreed to the prototype

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 classification, and we provided in our response a  
2 complete description of the reactor internal vibration  
3 program, and identified the number and location of  
4 sensors that would be used.

5 We have 46 separate sensors in the  
6 program. Many of them are related to the steam dryer.

7 But we also have sensors that are on the steam  
8 separators, the chimney, the shroud and on the stand-  
9 by liquid control line. So we have a comprehensive  
10 program that includes accelerometers, pressure  
11 transducers and strain gauges to -- in key positions,  
12 to obtain the vibration data.

13 DR. WALLIS: This is a kind of full-scale  
14 experiment really?

15 MR. DEAVER: Well largely what we're doing  
16 is a confirmatory thing. We've analyzed all the --

17 MEMBER ARMIJO: For your first of a kind  
18 start-up?

19 MR. DEAVER: This is typical for Reg Guide  
20 120. It's a confirmatory --

21 DR. WALLIS: But you have certainly  
22 analyses.

23 MR. DEAVER: Yes, and we have to meet the  
24 criteria when we take the data --

25 CHAIRMAN CORRADINI: I think, if you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 remember, this was the analysis where we were asking  
2 questions relative to the difference in the structure,  
3 and then they agreed to do this to their --

4 MR. DEEVER: Okay, and we've described the  
5 methodology, you know, once we get the data, how we're  
6 going to process that data and evaluate it against the  
7 limits that have been established, and we've justified  
8 the components that will need instrumentation.

9 Some of it's confirmatory. We really  
10 established the program based on risk base, you know,  
11 where we've had problems before. But also for new  
12 components that we haven't had experience with, then  
13 we need new data to substantiate that they're going to  
14 be acceptable.

15 So we've completed our description of the  
16 program, and NRC has a good understanding of what that  
17 is now.

18 Okay. Going on to 3.9 -81, this question  
19 relates to the postulated break in the steam line and  
20 feed water lines, and is there any dynamic  
21 amplification of loads in the reactor internal core  
22 structure components, core support structures?

23 The components that are -- the core  
24 structure components that hold the fuel are the CRD  
25 housings and the control rod guide tubes in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 vertical direction, and these are modeled as axial  
2 beam elements, and they represent the assembly of the  
3 control rod housing and the guide tube in the vertical  
4 direction in this primary structural model.

5 From that model, we find that in the  
6 vertical direction, there's no frequencies,  
7 fundamental frequencies below 105.4 hertz, and the  
8 associated loads from a main steam line and feed water  
9 break do not provide any extra type excitation on  
10 those components.

11 So we -- so that actually demonstrated  
12 that no amplification would occur on these vertical --

13 DR. WALLIS: How do you predict the  
14 unsteady pressures in the break, when a break flow  
15 comes out? I mean we talked about this. You're going  
16 to do a fluid analysis of the jets that impinge on  
17 things --

18 MR. DEAVER: That's external, yes.

19 DR. WALLIS: And they had fluctuating  
20 pressures in them, don't they, which presumably would  
21 be available to excite what you're talking about here,  
22 by working back through the system. Or would they  
23 not?

24 MR. DEAVER: Well, the actual blowdown  
25 phenomena, which I think Wayne understands a bit

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 better than me.

2 (Simultaneous discussion.)

3 DR. WALLIS: Which they can't transfer  
4 back, because the mark number is bigger than one?

5 MR. MARQUINO: It's choked, right. It's  
6 choked at the nozzle and the fluctuating pressure is  
7 due to the vortices, I believe --

8 DR. WALLIS: Outside. They're all  
9 outside.

10 MR. MARQUINO: --in the discharge side.

11 DR. WALLIS: There's no way they can  
12 transfer back to the interior?

13 MEMBER KRESS: So the interior effect is  
14 just the increased flow?

15 MR. DEEVER: Right. You're going to have  
16 the initial flow and then it's going to gradually  
17 decay down. So it's going to be a more stable  
18 blowdown phenomena inside the vessel, because of the  
19 large volume that's in there.

20 Okay. So we revised the DCD to address  
21 this issue, and so we're confident that we've handled  
22 the loads properly.

23 Okay, moving on to 3.9 -177, at one point  
24 we had a COL item listed in 3.9, which required that  
25 the ASME code design specs and design reports be made

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 available for the NRC staff to audit.

2           Actually, the ASME code requires that  
3 these documents be made available at the site, that  
4 when the ship the components to the site, that these  
5 documents are required to be on site and available.

6           But we felt like with the ITAAC  
7 requirements that we were putting in Tier 1, that it  
8 was not necessary to have the COL item as a separate  
9 commitment by the applicant, because we already had it  
10 covered by an ITAAC in Tier 1, which, like I  
11 mentioned, ASME requires that reports be made  
12 available anyway.

13           The second part to it that gave the staff  
14 confidence that we were capable of preparing design  
15 specs, they had an audit where we prepared design  
16 specifications for the major reactor internals, the  
17 vessel, other ASME components including valves, and  
18 the RTNSS-type or items that were considered risk -  
19 significant.

20           So we had five binders' worth of  
21 documentation that we prepared, and so they came and  
22 audited those documents. There, we demonstrated that  
23 we covered all the requirements that would be required  
24 in a design spec. So we demonstrated our capability  
25 and largely have most of the design specs that are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 required for ASME components.

2 Okay. The last issue is 3.9 -254, and  
3 related was 255. These dealt with the qualification  
4 of piping programs for piping analysis. We have the  
5 PISYS and ANSI -7 programs that are the computer  
6 programs that we use, and there was some confusion  
7 over Reg Guide 192, Rev. 1 versus Rev. 2.

8 When we benchmarked the programs, we used  
9 Reg Guide 192 Rev. 1, because it -- associated with  
10 the Reg Guide is a NUREG 6049, which is has the cases  
11 that we've benchmarked previously to, and so we found  
12 it more convenient to use that benchmark case.

13 If we were to use the Reg Guide 192 Rev.  
14 2, we would have had to benchmark against alternate  
15 pipe cases that we hadn't established previously.

16 So we found it more convenient to work the  
17 Rev. 1, and in fact Reg Guide 192 Rev. 2 actually  
18 allows you to use Rev. 1, and the way we're using the  
19 Reg Guide 192 Rev. 1 fully complies with the --  
20 what's, you know, stipulated by Rev. 2.

21 So in the process, we have an  
22 understanding now that the qualification that we ran  
23 is acceptable. We also included environmental effects  
24 caused by or on fatigue, as stipulated by Reg. Guide  
25 1.207. These were fully incorporated into ANSI-7.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           We had an audit of both of these programs,  
2 and during the audit, there was one           comment made  
3 regarding the methodology of how to establish           the  
4 temperature coefficient, which we subsequently  
5 resolved. So the final audit of the computer programs  
6 have now been completed.

7           Also what was required by the NRC    was we  
8 had to accomplish a Level 2 status on the programs.  
9 Previous to this, we had Level 2, but it was the prior  
10 versions that, you know, were not applicable for  
11 ESBWR.

12           So the Level 2 now makes it   possible for  
13 us to run the analysis without doing alternate  
14 calculations and so forth. So those have been fully  
15 demonstrated, fully documented at this time, so we're  
16 ready to do analysis.

17           So in summary, we've demonstrated that we  
18 have a comprehensive vibration program for the reactor  
19 internals, and fully defined for the first prototype  
20 plan. And then we've also been able to demonstrate  
21 our capability to prepare and do ASME           code  
22 documentation and define requirements.

23           So that's all I have today. If you have  
24 any questions.

25           CHAIRMAN CORRADINI: So the only committee

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I have on the left side, so go ahead.

2 MEMBER STETKAR: Yes. In August, when we  
3 were talking about tech specs, I asked about  
4 functional testing of the squib valves, and I was  
5 instructed to wait until we talked about Chapter 3.  
6 So I waited. So now I'm going to ask about functional  
7 testing of the squib valves.

8 MS. CUBBAGE: Excuse me, John. The staff  
9 can't hear you.

10 MEMBER STETKAR: Oh, okay. Sorry.

11 CHAIRMAN CORRADINI: What did you say Amy?

12 MS. CUBBAGE: Staff can't hear you in the  
13 back.

14 MEMBER STETKAR: Let me repeat. In  
15 August, when we talked about technical specifications,  
16 I asked about functional testing of squib valves. At  
17 that time I was instructed to wait until we talked  
18 about Chapter 3.

19 So I have patiently waited, and now we're  
20 talking about Chapter 3. So now I'm going to ask  
21 about functional testing of squib valves . in Table  
22 3.9-8 of DCD Rev. 7, just to make sure we're on the  
23 right revision, the technical specifications  
24 explicitly state that the squib valves need not be  
25 fired as part of the surveillance requirements.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           The bases for the tech specs say that  
2 "Operability of the squib valves is           verified by  
3 continuity tests and the in -service test program for  
4 squib-actuated valves. The in           -service testing  
5 requirements in Table 3.9-8 say that squib valves for  
6 the SLC injection, GDCS injection, GDCS equalizing and  
7 GDCS deluge squib valves, and the ICPCCS full crosstie  
8 valves are fired and replaced per paragraph           ISTC-  
9 5260." Please tell me what           that functional testing  
10 does, and how frequently it's performed?

11           MR. DEAVER: Okay.

12           MEMBER STETKAR: I'm           specifically  
13 concerned also, because in the final draft, the draft  
14 final SER, there was a staff concern about possible  
15 external missile injection from -- ejection from squib  
16 valves when they're fired, and in response to an RAI,  
17 I think it was RAI, I don't have the number here.

18           I think it was 3.5 -6, but I'm not sure  
19 about that, the staff's conclusion was "The           staff  
20 finds that these squib valves are actuated by the  
21 booster assembly that causes an explosion inside the  
22 valve assembly, and the explosive pressure is just  
23 adequate to push the piston that opens           the valve  
24 outlet."

25           Now if the pressure is "just adequate," I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 want to make sure that it's adequate. In order to  
2 have the pressure adequate, I need to functionally  
3 test those valves with design differential pressures  
4 across those valves, and make sure they work.

5 MR. DEEVER: Yes.

6 MEMBER STETKAR: So that's another reason  
7 for my question about how will they be functionally  
8 tested and how frequently.

9 MR. DEEVER: Well, let me describe first  
10 of all that squib valves are largely a commodity that  
11 isn't off the shelf at this point and has to be  
12 developed. So we recognize that -- up front hat for  
13 these different valves of different sizes and  
14 different kind of arrangements, that we've got to  
15 individual qualify, have our suppliers qualify these  
16 valves.

17 And not only the igniter, but the plunger  
18 part that shears the cap, that then opens the valve  
19 up. So --

20 MEMBER STETKAR: I understand the  
21 qualification. It's the same thing we do with  
22 qualifying motor -operated valves and air-operated  
23 valves and pumps and pieces of pipe in hangars and all  
24 that kind of stuff. But we also functionally test  
25 motor-operated valves and air-operated valves and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pumps to make sure they operate under as-built, as-  
2 installed, as-maintained, as-aged conditions.

3 MR. DEEVER: Right.

4 MEMBER STETKAR: So I'm asking about the  
5 latter, not the former.

6 MR. DEEVER: Right. Well, what we're  
7 planning to do, the igniters is the commodity that is  
8 subject to shelf life and degradation over time. So  
9 we have a program that every outage we go in and we  
10 take out the igniter and replace it and test it.

11 MEMBER STETKAR: This would be like  
12 removing the motor from a motor-operated valve and  
13 putting it on a bench and make sure the motor works?

14 MR. DEEVER: It's really just the igniter  
15 part.

16 MEMBER STETKAR: No, but I mean it's  
17 logically equivalent to removing the motor from a  
18 motor-operated valve, to make sure the motor works on  
19 the bench, but you never know whether it will operate  
20 the valves.

21 MR. DEEVER: So the plan is, on a  
22 rotational basis, every outage, to remove certain  
23 igniters, take them out --

24 MEMBER STETKAR: I understand that. I'm  
25 asking about how and how frequently will you actually

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 explode a squib-operated valve under actual installed  
2 differential pressure conditions, to have some  
3 confidence that indeed the igniter will ignite, the  
4 explosive will fire, the pin will shear and indeed the  
5 valve will open? That's what I'm asking about.

6 MR. DEEVER: Okay. Well, our plan right  
7 now is not to destructively test a valve.

8 MEMBER STETKAR: Ahh. That's the answer I  
9 was hoping not to hear, but expecting to hear.

10 MR. DEEVER: Okay.

11 MEMBER ARMIJO: I think that's what --

12 MR. DEEVER: Can I ask --

13 MEMBER STETKAR: Because actually in this  
14 table, I'm led to believe that it says "fired and" --  
15 read the quote in the note here, so that I'm not  
16 misquoting something.

17 MEMBER ARMIJO: It says "fired and  
18 replaced."

19 MEMBER STETKAR: It says "fired and  
20 replaced." It doesn't say igniter bench-tested. It  
21 says the valve, "it applies to explosively-actuated  
22 valves." It's Note X in the table, parenthesis  
23 "(paragraph ISTC-5260)," and the frequency is Note E -  
24 2. It says "fired and replaced" per paragraph ISTC -  
25 5260.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Now I don't know what ISTC -5260 is, so  
2 that's why I was curious what it tells me to do.

3 MR. DEEVER: I'm not familiar with that  
4 code.

5 MEMBER STETKAR: Okay. Well since it's in  
6 the table in DCD Rev. 7, and referenced as the only  
7 reference that might pertain to any type of functional  
8 testing, I'd be really curious what it is.

9 MR. SCARBROUGH: This is Tom Scarbrough  
10 with the NRC staff. I heard your question, and you're  
11 exactly right. ICC for squib valves in the ASME code  
12 only deals with those initiators.

13 MEMBER STETKAR: Oh, is that right?

14 MR. SCARBROUGH: Yes. No effort to take  
15 the valve out, and the reason is historically, squib  
16 valves are these little things that we use in SLC  
17 systems, S-L-C, and they have very little safety  
18 significance. In the new plants, the new reactors,  
19 it's much different.

20 MEMBER STETKAR: EPV valves are 13 inches,  
21 I think, in diameters.

22 MR. SCARBROUGH: Yes. They're very large  
23 and have very large diameters.

24 MEMBER STETKAR: GDCS valves are eight  
25 inch, I think.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: Six inch.

2 MEMBER STETKAR: Six inch?

3 MR. DEEVER: But the throat part of BPVs  
4 is about eight.

5 MEMBER STETKAR: Oh, about eight? Okay.

6 MR. SCARBROUGH: So one of the things that  
7 we've been working with, because in this area the AP-  
8 1000 reactor design is ahead of ESBWR, and we're  
9 working with Westinghouse on their design. Because of  
10 the increase in size, they've had to change the design  
11 significantly for these things.

12 They've had a lot of challenges regarding  
13 that. One of the areas that we've been dealing with  
14 is how are you going to monitor these now very  
15 important valves during surveillance? So the ASME  
16 code, we've already talked to ASME about the OM code  
17 is inadequate in this area.

18 So what we've done is we recognize that  
19 because of the early design phase, and when we audited  
20 GEH, we did talk to them about their squib valves, and  
21 they indicated the design is still on the table. They  
22 really haven't decided what design they're going to go  
23 with yet.

24 CHAIRMAN CORRADINI: What does that mean,  
25 just so I understand what you mean by "on the table"?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 You mean they have various possibilities?

2 MR. SCARBROUGH: Yes. They've talked  
3 about the various ones. They're sort of monitoring  
4 what AP 1000 is doing, and there's a lot of work going  
5 on in that area. So they're sort of following that  
6 process and seeing where that leads. Because there's  
7 a couple of different designs being used by AP 1000.

8 So what we did in the SER for the ESBWR is  
9 we indicated that the fact that this, the AS -OM code  
10 only really focuses on the initiators, and it's the CO  
11 applicant will need to be -- will be responsible for  
12 establishing appropriate surveillance activities for  
13 the squib valves.

14 MEMBER STETKAR: Yes. I noted that. It  
15 says "appropriate surveillance activities." It  
16 doesn't say "functional testing," though. So --

17 MR. SCARBROUGH: Yes, because we're not  
18 quite sure, to take these large valves out and fire  
19 them, it would be very difficult. There's a lot of  
20 possibilities going on for much more specific detailed  
21 in-service monitoring, where you monitor the internals  
22 of the piston rod and different aspects of the  
23 internals of the squib valve, to make sure that it's  
24 functionally intact and ready to fire.

25 MEMBER STETKAR: I guess my concern is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that they are new valves, and if indeed there is some  
2 very careful design, as implied by the pressure as  
3 "just adequate" to break the piston loose, given our  
4 experience with, you know, 20 years of problems with  
5 things like motor -operated valves not being properly  
6 sized, designed and maintained for in-service  
7 conditions for differential pressures, discoveries  
8 that we really needed to completely re -look at not  
9 only the design criteria but how we test those valves,  
10 to make sure that they're going to work, that's sort  
11 of the genesis of my concern here.

12 MR. SCARBROUGH: Yes, and we're following  
13 the AP -1000. We're attending their design review  
14 meetings. We're watching -- we watched their blowdown  
15 test that they just did recently on their prototype.  
16 So we're monitoring what they're doing with those, and  
17 we recognize exactly where you're coming from, because  
18 they're following the QME -1007 approach for these  
19 qualifications.

20 They know they have to demonstrate that  
21 these valves are very reliable, and then after that,  
22 they're also working with the United Kingdom, because  
23 that's part of the process there, in terms of making  
24 sure that the surveillance process for these is  
25 adequate.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Until they really finalize the design,  
2 they won't really know exactly the right way to be  
3 able to monitor them.

4           MEMBER STETKAR: Until they fail.

5           MR. SCARBROUGH: But it definitely is  
6 something that is going to be followed very closely by  
7 the staff.

8           CHAIRMAN CORRADINI: So can I say it back  
9 to you a different way, just so I'm -- because I'm,  
10 I'm listening. I was expecting him to ask the  
11 question, just not now.

12           (Laughter.)

13           CHAIRMAN CORRADINI: Eventually, this  
14 question today, under Chapter 3. So what I hear you  
15 say is because these designs are paper designs and  
16 small valves have been produced, manufactured, tested,  
17 and large valves are still in the process of being  
18 precisely designed and tested, you're leaving it to  
19 the COL applicant to demonstrate, besides the firing  
20 off-line, as Jerry was explaining to John per the  
21 current code, you're expecting the COL applicant at  
22 this point to take on the responsibility to prove it  
23 for that design under those conditions?

24           MR. SCARBROUGH: Yes sir, because really  
25 the operating program is the COL applicant's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 responsibility. The design certification applicant,  
2 they include a lot of information that the CO  
3 applicant incorporates by reference in their FSAR.  
4 But the responsibility lies with the CO applicant.

5 CHAIRMAN CORRADINI: Okay, right. So  
6 that's Clarification 1. Clarification 2 is to me,  
7 let's say that the COL applicant decides to want to do  
8 what he calls functional testing on site. Is there a  
9 valve line that one can do that with this design?

10 MR. SCARBROUGH: If I understand it, your  
11 question was okay, I have a COL applicant. They're a  
12 relatively conservative bunch. They want to do it  
13 every once in a while on site, in location, and then  
14 replace all the --

15 CHAIRMAN CORRADINI: --guts of it, once  
16 they successfully do it. Is that possible, by the  
17 design as we have it?

18 MR. BEARD: Alan Beard with GE -Hitachi,  
19 and Jerry, correct me if I get this wrong. But we do  
20 include provisions in the design of the pipes that  
21 house these valves, such that we could establish the  
22 necessary differential pressure across them using test  
23 type of set-up. We could fire those and we could go  
24 in and replace the internals to that valve with the  
25 parts that have been --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Okay, and then re -  
2 establish it online. Okay.

3 MR. BEARD: I don't remember. I think  
4 there is. There are tabs when you get differences in  
5 pressures.

6 MEMBER STETKAR: There are test  
7 connections, there are isolation valves that you can  
8 close, that you can --

9 CHAIRMAN CORRADINI: Okay. I just didn't  
10 know, because I think -- I mean my point is that this  
11 is a generic question that has popped up here. I  
12 haven't looked back in AP -1000. I'm sure those  
13 previous members of ACRS that were excellently asking  
14 questions at the time asked the same sort of  
15 questions, because I would expect this is a generic  
16 thing with all of these plants.

17 And now it just -- this is since we have  
18 GE folks here that might remember the ABWR, aren't  
19 there large DPVs in the ABWR design also?

20 MR. MARQUINO: No. The answer to that is  
21 no, there are no DPVs in the ABWR.

22 (Simultaneous discussion.)

23 MEMBER STETKAR: One other observation I  
24 want to make is --

25 MEMBER ARMIJO: But smaller.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: In the SLC, yes.

2 MEMBER ARMIJO: Only in the SLC?

3 CHAIRMAN CORRADINI: They're more of the  
4 standard SLC squib valve.

5 MEMBER STETKAR: Well, that's what I was  
6 trying to understand.

7 MR. DEEVER: Right. One thing I wanted to  
8 clarify is that we did qualify or test the DPV valve  
9 in the early 90's. We had a test program where we  
10 actually built the valve and tested it. So we have  
11 that.

12 MEMBER STETKAR: No that I understood, and  
13 the DPV valve design hasn't changed?

14 MR. DEEVER: No.

15 MEMBER STETKAR: The squib valves, we used  
16 to have drawings of the squib valves in an earlier  
17 version from GE.

18 CHAIRMAN CORRADINI: I was waiting for you  
19 to say this.

20 MEMBER STETKAR: --and we don't have those  
21 anymore. So the squib valves are right at the moment  
22 basically unknown.

23 MS. CUBBAGE: What do you mean by "the  
24 squib valves"?

25 MEMBER ARMIJO: Is it a design requirement

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for these valves, that they testable and repairable?  
2 I guess replace the internal s, or is this just  
3 impractical?

4 MR. DEEVER: Well, I mean they could be  
5 physically removed and taken into a test assembly or,  
6 you know, and tested or I guess my perspective is that  
7 the plunger, the piston that comes in and shears, all  
8 of that is all mechanical, you know. It's related to  
9 material properties, degradation.

10 MEMBER STETKAR: It happened in an  
11 accident this summer.

12 MR. DEEVER: Really, we're going to use  
13 corrosion-resistant materials. So largely it's a  
14 mechanical function that, you know, if we share it and  
15 says "yes, it broke." But that's fine. We know that  
16 one broke, but what about the new one coming out?

17 MEMBER ARMIJO: So your argument is that  
18 just testing the detonators or whatever these things  
19 are called, the charges would be sufficient to ensure  
20 that these things will work, in addition to the  
21 qualification --

22 MR. DEEVER: I guess the point I'm trying  
23 to make is that if you get, establish a load from the  
24 igniter, then the mechanical parts are going to  
25 function properly.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: But I think where  
2 we're coming, where he's coming from, it's his issue,  
3 but I sense where he's coming from is when you put  
4 this sort of thing into play, there are examples in  
5 analogous industries where these things didn't work.

6 MR. DEEVER: Well, they were a little more  
7 complicated, the motor-operated valves.

8 CHAIRMAN CORRADINI: Granted, but I guess  
9 my only point is under actual pressure conditions, I  
10 think, is that where he's coming from.

11 MEMBER STETKAR: I mean we've had problems  
12 with simple solenoid -operated valves that haven't  
13 worked, you know. Plungers, you know, are -- they can  
14 get minor corrosion, they can get minor deposits,  
15 they can get, you know. You don't know what's going  
16 to happen.

17 MEMBER KRESS: A little philosophy here.  
18 To me, to test one of these valves say in place, or to  
19 even take it out and test it in little bits, is a  
20 useless test, because the replacement --

21 CHAIRMAN CORRADINI: Useless or useful?

22 MEMBER KRESS: Useless. The replacement,  
23 you don't know whether it's going to work or not,  
24 because that one doesn't tell you anything. What is  
25 needed --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Simultaneous discussion.)

2 MEMBER KRESS: In my mind, excuse me, what  
3 is needed is a bunch of tests offline and under the  
4 right conditions, to give you some reliability for a  
5 fleet of these, and use that reliability to make a  
6 judgment on how good they're going to work.

7 CHAIRMAN CORRADINI: So your argument,  
8 though, would be that would be the qualification test  
9 program, once they pick a design. That's your point?

10 MEMBER KRESS: That's right. That's my  
11 point, exactly. Whereas to test them online is just -  
12 - other than the igniters, I think that's worthwhile  
13 and but I think it's a useless test otherwise, to  
14 actually test the whole valve.

15 MEMBER ARMIJO: I think his issue is  
16 really on aging effects. A new valve is likely to  
17 work, but you know, if they've been in-service for a  
18 long time, is there other things that might happen --

19 MEMBER KRESS: You might be able to spec  
20 for aging effects. I don't know.

21 MEMBER ARMIJO: Yes. Other things that  
22 happen that will make the valve jam, you know. The  
23 powder blows, the thing breaks, but some --

24 MEMBER KRESS: Well, you might be able to  
25 make that part of your offline qualification test.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Yes. That's where I would  
2 do it.

3 MEMBER STETKAR: The only problem about  
4 qualification testing for data is the predicted  
5 reliability of these things --

6 MEMBER KRESS: You have to have a lot of  
7 data.

8 MEMBER STETKAR: You have to destroy so  
9 many valves that --

10 MEMBER KRESS: You have to have a lot to  
11 do that. Yes, that's -- that is the --

12 MEMBER STETKAR: The first ones are going  
13 to cost you an awful lot of money.

14 MEMBER KRESS: I agree with that.

15 MEMBER STETKAR: That's the problem. The  
16 *in situ* testing or the not necessarily *in situ* if you  
17 take it out and have an appropriate test bed.

18 Absolutely doesn't tell you anything about  
19 the valve, the new valve being installed. However, it  
20 does at least give you some level of confidence about  
21 if it works, i t doesn't tell you anything. But it  
22 gives you a bit of confidence.

23 If it doesn't work --

24 MEMBER KRESS: This year.

25 MEMBER STETKAR: It gives you a lot of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 information.

2 DR. WALLIS: Well, isn't one way to ensure  
3 that it's more likely to work to have a margin in this  
4 pressure, so that --

5 MEMBER STETKAR: Well, that's -- and I  
6 don't know. I think this is probably a staff  
7 paraphrase, because they're trying to justify the fact  
8 that there's no concern for external missiles. But it  
9 tells me that apparently it's some, you know,  
10 obviously it's some sort of design change.

11 Looking at the design of, I think it's the  
12 DPV valves, that you basically blow something that  
13 shears something --

14 (Simultaneous discussion.)

15 MEMBER STETKAR: Well then it flops over,  
16 kind of like a check valve, and most of the time check  
17 valves work, and sometimes they don't. Sometimes they  
18 bind up because the flopper thing kind of binds up.

19 MR. DEEVER: Yes, it's mainly the shearing  
20 effect that's going to make it work or not. The flop-  
21 over part is not that --

22 MEMBER STETKAR: The earlier design of the  
23 GDCS valves was a very different valve, because they  
24 had a more -- it was a piston driven down into a  
25 little well or something like that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: Yes. That's a case where the  
2 pressure is from one side but the flow has got to come  
3 in a different direction. We recognize that that's a  
4 different-type valve.

5 MEMBER STETKAR: So I think staff at least  
6 answered -- you know, I understand the current  
7 situation, which is what I didn 't understand in  
8 August. So --

9 MR. DEEVER: Okay.

10 CHAIRMAN CORRADINI: Questions.  
11 Additional questions for Jerry?

12 MEMBER ARMIJO: Just one last thing. Is  
13 GEH going to pursue the development of these valves  
14 with some suppliers?

15 MR. DEEVER: Oh yes.

16 MEMBER ARMIJO: It's not the COL?

17 MR. DEEVER: No, no. We will supply this  
18 equipment and we'll fully --

19 MEMBER ARMIJO: And you'll work with your  
20 valve suppliers to qualify and do all the testing?

21 MR. DEEVER: Right, right.

22 MEMBER ARMIJO: Bu t it's your current  
23 intent not to do destructive testing online on the --?

24 MR. DEEVER: That's true, right. Yes, we  
25 have there suppliers that we're currently working with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 or discussing test programs and such. Okay.

2 CHAIRMAN CORRADINI: Other questions for  
3 Jerry?

4 (No response.)

5 CHAIRMAN CORRADINI: Okay, thank you.  
6 Right. So at this point we're going to take a break  
7 until 10:30.

8 (Whereupon, a short recess was taken.)

9 CHAIRMAN CORRADINI: All right. Let's get  
10 started. David, you're up.

11 Chapter 3 - Section 3.9 RAIs/Staff

12 MR. MISENHIMER: Okay. I'll have my  
13 presenters get up here. My name's Dave Misenhimer.  
14 Again, I'm the Chapter PM for Chapter 3. We have two  
15 folks that are going to do the presentations this  
16 morning on Section 3.9, Yuke n Wong and Tuan Le, and  
17 Yuken will start out.

18 MR. WONG: My name is Yuken Wong from NRO  
19 Division of Engineering, Engineering Mechanics Branch  
20 II. I'm going to talk about the review of open items  
21 in Section 392, dynamic system analysis and testing of  
22 system component structures.

23 For Section 392.4, pre -operational flow  
24 induced vibration testing of reactor internals, the  
25 regulations and regulatory guidance are GDC -104,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Regulatory Guide 1.20 and SRP Section 392 and 392.

2 Reg Guide 1.20 is related to the re actor internals  
3 comprehensive vibration assessment program.

4 In RAI 3.9 -75, the staff asked the  
5 applicant to clarify the use of both terms "prototype"  
6 and "non-prototype" for reactor internals components  
7 in the DCD and in topical report NEDE -33259, reactor  
8 internals comprehensive assessment program report.

9 In the response, GEH clarified that  
10 prototype applies to the components that are different  
11 from the ABWR reactor internals, such as the chimney  
12 and stand-by liquid control structures. The ESBWR  
13 reactor internals as a whole are classified as non-  
14 prototype Category 2.

15 Separately, the staff questioned the  
16 classification of the ESBWR reactor internals as non -  
17 prototype Category 2, considering there's substantial  
18 differences between the ESBWR and ABWR reactor  
19 internals, and GEH agrees with the staff's finding and  
20 later reclassified the ESBWR reactor internals as  
21 prototype and supplement the response to RAI 3.9-75.  
22 This resolved the issue.

23 In RAI 3.9 -96, the staff request the  
24 applicant to explain the basi s for selecting the  
25 reactor internals components for testing for the first

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ESBWR plant. In the response, GEH provided an item  
2 by item discussion of why each component is selected  
3 for analysis and testing, or why was it was  
4 considered adequate without further analysis testing  
5 in the topical report, NEDE-33259.

6 The staff finds their response acceptable,  
7 and meets the acceptance criteria in Reg Guide 1.20,  
8 and this resolved the issue.

9 In Section 392.5, dynamic system analysis  
10 of reactor internals in the forward conditions, the  
11 regulations and regulatory guidance are GDC 214, NCFR  
12 Part 50, Appendix S, SRP Section 392 and 395, and ASME  
13 Code Section 3, subsection NG.

14 In RAI 3.9 -81, the staff asked the  
15 applicant to demonstrate there's no significant  
16 dynamic amplification of the loads on the reactor  
17 internals, as a result of the main steam line and feed  
18 waters of line breaks.

19 In the response, GEH compared the  
20 frequency of the blowdown loads to the natural  
21 frequency of the core support structures, and the  
22 spatial description of the blowdown loads to the core  
23 support structures, and concluded that there's no  
24 dynamic amplification of the blowdown loads.

25 DR. WALLIS: So when do they -- how do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they get the periods of the loads from the blowdown?  
2 I mean blowdown, there's a -- I think there's a quasi-  
3 study process, or is there a process? How do you get  
4 that, periods of the loads from a blowdown?

5 MR. WONG: In the response, GE did not get  
6 into details as to how those --

7 DR. WALLIS: Well, I noticed that they  
8 looked at the natural period of the structures. They  
9 looked to see if there was a resonance. But I'm  
10 interested in the exciting. What's the exciting  
11 mechanism from the blowdown?

12 MR. WONG: In the response, GE did not get  
13 into details on how those --

14 DR. WALLIS: How did you satisfy yourself  
15 it was okay, if they didn't get into the details?

16 MR. WONG: I would defer the reviewer, the  
17 contractors for this section.

18 DR. WALLIS: There's a contractor who  
19 reviewed this?

20 MR. WONG: Yes. I mean I took over this  
21 section recently, so I mean this review has been going  
22 on for several years, so I would --

23 DR. WALLIS: I can't remember. I know  
24 we've seen something before, but I can't remember.

25 MR. WONG: Yes, they -- Vic and Tom, are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you on the line?

2 MR. SAH: Yes. I think what we found

3 --

4 CHAIRMAN CORRADINI: Can you identify  
5 yourself please?

6 MR. SAH: This is Vic Sah (ph) at the  
7 Argonne National Lab. I think in the -- this  
8 particular section, that is, what is 3.9.2.4. I think  
9 partly we were supported by the, some of the NRC  
10 staff, and what we understand that the update  
11 components in the lower part of --, it goes much  
12 higher than 100 hertz. That was the reason that there  
13 will not be any dynamic amplification because of the  
14 blowdown.

15 DR. WALLIS: That was the conclusion. I  
16 remember that, but how do you know what the period of  
17 the loads is, the imposed loads. In order to see  
18 whether 100 hertz is okay, you have to know it was a  
19 driving force at 100 hertz or not.

20 MR. WONG: That is true. Well, what it  
21 implies that the driving force was much lower than 100  
22 hertz.

23 DR. WALLIS: How do you determine that  
24 driving force?

25 MR. WONG: I think we relied on the --if

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you recall, I think we worked with Jay Rodgen (ph)  
2 from NRC. He reviewed these.

3 CHAIRMAN CORRADINI: Yes, I remember.

4 MR. WONG: We had a discussion on that. I  
5 think what we were talking about it, the contractors.  
6 Vic Shaw on the phone now. We did not review this  
7 subsection of 392.

8 DR. WALLIS: So if GE states something,  
9 it's okay without review that it has a proper basis?

10 MS. CUBBAGE: I think what we're saying  
11 there was another staff member. Maybe we could get  
12 Jay?

13 CHAIRMAN CORRADINI: I'm sorry. Is it a  
14 staffer, is it Argonne? Is it your contractor that  
15 assisted you?

16 MR. WONG: The contractor, Vic, we just  
17 mentioned. He did not review this subsection, 392.5  
18 of the SSE, and this subsection was reviewed by a  
19 member of the staff who is no longer --

20 DR. WALLIS: Well, how do you determine  
21 the driving force from the blowdown.

22 MR. WONG: He was responsible for this  
23 section. I mean we find it acceptable, based on the  
24 evidence presented. The natural frequency of the  
25 loads and the core support structure do not coincide.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I mean I --

2 DR. WALLIS: I understand that , but  
3 there's a --

4 MR. WONG: There's a question. Why did we  
5 solve, I mean --

6 DR. WALLIS: There's a break in the steam  
7 line up here somewhere, and it sent some loads into  
8 the vessel, and it shakes things at the bottom. But  
9 you have to somehow, in or der to know how this load  
10 comes in and shakes things at the bottom, you have to  
11 know what the driving force here is up at the top here  
12 presumably.

13 MR. WONG: Yes. I think that level of the  
14 analysis, from my understanding in reading the SC, it  
15 was not audited. It's not reviewed in that detail.

16 DR. WALLIS: So it's a mystery how they --  
17 it's a mystery to me at this point how they determined  
18 the driving force?

19 MS. CUBBAGE: Okay. Unless GE has  
20 anything to offer at this time, I'd like to take this  
21 issue back and try to get you an answer.

22 CHAIRMAN CORRADINI: GEH, do you guys have  
23 something to say relative to the forcing function that  
24 was used?

25 MR. MARQUINO: This is Wayne Marquino.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We'd like to take that offline and get back to you at  
2 the break.

3 DR. WALLIS: Thank you.

4 CHAIRMAN CORRADINI: Okay. Why don't we  
5 keep on going?

6 MR. WONG: Okay.

7 DR. WALLIS: I remember some discussion on  
8 this, but I can't --

9 MR. WONG: Based on the sustainment in the  
10 GR IR response, because the periods, the frequency of  
11 the loads and the frequency of the core support  
12 structure do not coincide, and the spatial dispersion  
13 of the blowdown loads and the motion of the core  
14 structures are not compatible, therefore, you know,  
15 there's no potential for amplification of dynamic  
16 loads. This is basis for resolving this RAI. And we  
17 will take this question back and get back. This  
18 concludes my presentation.

19 CHAIRMAN CORRADINI: So just to be clear,  
20 what I'm writing down that we're going to get from  
21 staff and from GEH is the basis of the forcing  
22 function and what staff did to convince themselves  
23 that it was acceptable relative to the response, okay?  
24 Other questions for Mr. Wong? Other questions for  
25 Mr. Wong before they move on?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (No response.)

2 CHAIRMAN CORRADINI: Okay. Why don't you  
3 go ahead?

4 DR. WALLIS: Well, that's all this slide's  
5 about really isn't it?

6 CHAIRMAN CORRADINI: They're moving on to  
7 another RAI, but the question was -- go ahead.

8 MR. LE: Good morning. My name is Tuan  
9 Le. I'm the reviewer of Section 393, which is an SME,  
10 S-1, 2, 3 component, component support for support  
11 structure.

12 Today, I would like to present the RAI  
13 3.9-177, which is request, the staff request the  
14 applicant to restate the COL information item  
15 regarding the availability of the estimate design  
16 report, and the design specification. Originally  
17 listed in the DCD Section 393 and Section 399, or the  
18 applicant address the information in Item 2 of the  
19 ITAAC.

20 As a result of the staff question for this  
21 RAI, the applicant respond, and the applicant  
22 committed to develop an ITAAC for review of the design  
23 report prior to the fuel load, and a commitment of the  
24 completion of design specification for this  
25 significant component prior to the certification.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           On that, the staff in July 20, 2009, staff  
2 subsequently did the design specification audit at the  
3 GE site, and during this audit, the staff find a  
4 number of items, follow-up items to be respond for the  
5 staff, regarding the finding.

6           After that, the finding was resolved and  
7 the GE have respond to all the follow-up items. Based  
8 on the information review, the staff found that the  
9 design document review components reflect the  
10 methodology and the criteria contained in the DCD, and  
11 met the requirement of the ASME Code Section 3,  
12 Article in SE-3000.

13           Therefore, this issue was closed after  
14 resolve all the follow-up items of the audit report.  
15 This concludes my presentation for the RAI 3.9 -177.  
16 I'll be open to any questions. Any questions?

17           CHAIRMAN CORRADINI: Questions from the  
18 Committee?

19           MR. MISENHIMER: That's it for this  
20 section. I should mention that 3.9 -254, 255, we  
21 didn't talk about that yet. We will have a presenter  
22 talk about when we get to 3.12.

23           CHAIRMAN CORRADINI: Okay. Wayne, did you  
24 want to clarify or give us some information?

25           MR. MARQUINO: Yes. This is Wayne

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Marquino of GE with Jerry Deaver, and my understanding  
2 is the question was about high frequency loads on  
3 structures like the guide tubes in the lower plenum.

4 The phenomena that's causing the loads is  
5 the depressurization of the vessel, caused by a pipe  
6 break. So we have phenomena like voiding formed in  
7 the lower plenum, water moving up because of that --  
8 liquid moving up because of that voiding, and to  
9 define the differential pressure, we do calculations  
10 with the TRAC -G code, to determine the differential  
11 pressure on different parts of the internal structure.

12 But those phenomena develop over the  
13 course of seconds, not 100 hertz. So the phenomena  
14 that's producing the loading, its character is a lower  
15 frequency than the --

16 DR. WALLIS: It's way off scale. I mean  
17 it's the order of several hertz, one hertz or less or  
18 something, rather than 100. I just wondered why you  
19 were even worried about 100 hertz?

20 MR. MARQUINO: I think it's because it's  
21 the natural frequency.

22 DR. WALLIS: That's its natural frequency,  
23 but I couldn't see any mechanism that would drive that  
24 sort of frequency anyway.

25 MR. DEAVER: Right. I think -- this is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Jerry Deaver with GEH. I think, you know, the  
2 simplistic argument is that it has such a high natural  
3 frequency that you could never excite it, and the  
4 phenomena --

5 DR. WALLIS: If you would explain that the  
6 driving forces are of the order of one hertz or less.

7 MR. DEEVER: Yes.

8 DR. WALLIS: That would perhaps have  
9 helped to explain where they came from, because I  
10 thought you were thinking of this pipe up here that's  
11 break, sort of producing a sonic kind of noise, that  
12 goes down and excites stuff down below, and that's not  
13 what you're thinking about.

14 MR. DEEVER: No. This is just a mass  
15 energy release phenomena.

16 DR. WALLIS: Yes, okay.

17 MR. DEEVER: So I don't see how that  
18 frequency could -- any kind of high frequency context  
19 could enter into the vessel.

20 DR. WALLIS: So it's the voiding and the  
21 motion of the liquid?

22 MR. DEEVER: Right. It's the water level  
23 changing and BP changes that are really slow in  
24 nature.

25 DR. WALLIS: But that's lower than 100

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hertz, isn't it?

2 MR. DEEVER: Pardon?

3 DR. WALLIS: Okay, thank you.

4 CHAIRMAN CORRADINI: Okay, thank you.

5 John, I'm sorry.

6 MEMBER STETKAR: I wanted to ask the staff  
7 one thing, John, still tracking the squib valve. What  
8 assurances do I have that the COL applicant or the COL  
9 holder knows that they need to develop some type of  
10 enhanced surveillance program for these squib valves,  
11 other than firing the igniters? You know, we had the  
12 discussion. It's my understanding that right now the  
13 only requirements are that they fired the igniters.

14 If I read the SER, there's a paragraph in  
15 here, and I don't want to quote the whole paragraph.  
16 But the paragraph basically reiterates the concerns  
17 that we've heard this morning, that indeed they're  
18 large valves, they're very, very important to safety,  
19 and that the design hasn't been finalized.

20 The COL applicant -- it says "CO L  
21 applicants referencing the SBWR design will be  
22 responsible for establishing appropriate surveillance  
23 activities for squib valves." Yet in other places, it  
24 says that the general descriptions of the IST  
25 activities are acceptable, which leads me to kind of a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 gap.

2 How do I know? If we certify the design,  
3 we're certifying -- in the design, we're certifying  
4 the testing program that's specified in the design,  
5 which is only firing the igniters.

6 MR. SCARBROUGH: This is Tom Scarbrough  
7 with the staff.

8 MEMBER STETKAR: Hi Tom.

9 MR. SCARBROUGH: Yes. This is sort of the  
10 extension between the signed certification review and  
11 the CO applicant review. We actually don't approve  
12 the IST program --

13 MEMBER STETKAR: Until --

14 MR. SCARBROUGH: As part of the design  
15 certification.

16 MEMBER STETKAR: So there's no -- what I'm  
17 asking for is there's no need for specificity in an  
18 ITAAC related to the testing program at the design  
19 certification stage, to the hook dysfunctional  
20 requirement.

21 MR. SCARBROUGH: Well, a long time ago it  
22 was decided by the agency that we would not have ITAAC  
23 for operational programs. This IC is one.

24 MEMBER STETKAR: Okay, thank you.

25 MR. SCARBROUGH: So we deal with it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through the CO applicant, and they know that they need  
2 to do this and --

3 MEMBER STETKAR: I mean there's a flag in  
4 the TAC text here, you know. If people don't read the  
5 DCD 2, you know, Level 2 --

6 (Simultaneous discussion.)

7 MR. SCARBROUGH: It's there, right. For  
8 the CO applicant to know, and we've already started  
9 interactions definitely with -- for the AP-1000 with  
10 the CO applicant, and here, we'll be interacting with  
11 the CO applicant for the SP to bear as well, that they  
12 need to -- this is something that's very significant.

13 Because of the uncertainty in the design  
14 of the squib valves, they're going to need to decide  
15 exactly the debate that's going on. Do they set it up  
16 to be able to fire these valves in place, which  
17 they're designed to do multiple times, or do they have  
18 a very detailed surveillance, internal surveillance  
19 program, so they can verify the integrity, no  
20 degradation, you know, no, you know, type of oxidation  
21 or something that might cause a problem.

22 So all of that debate is something that's  
23 underway.

24 MEMBER STETKAR: Yes. That I understand.

25 For current purposes, my only question was do I need

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 some sort of additional assurance at the DCD stage in  
2 the form of ITAAC, that would, you know, more  
3 explicitly express those concerns. The answer that  
4 I've heard is no, because that's considered an  
5 operational program.

6 MS. CUBBAGE: Right, and the rule will  
7 specifically exclude operational programs from  
8 finality. To the extent they may have been described  
9 in the DCD, they still don't have finality.

10 MEMBER STETKAR: Yes, yes.

11 MS. CUBBAGE: So that there's no -- the CO  
12 applicant can't say they have finality.

13 MEMBER STETKAR: Yes, okay. I understand  
14 that. Thanks.

15 DR. WALLIS: But until you test a full  
16 valve, you don't really know the modes of failure, do  
17 you, the way in which things can go wrong? You sort  
18 of assume that by keeping it clean and all that and  
19 watching for corrosion, you can assure yourself that  
20 it won't go wrong. But you don't really know what can  
21 go wrong until you test it.

22 MR. SCARBROUGH: Yes sir. During the  
23 initial phase of the testing for the AP -1000, we're  
24 learning a lot about the valve and how things can go  
25 right and go wrong, yes sir.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: Now doesn't the explosive  
2 deteriorate with time? There's chemical effects that  
3 go on in there.

4 MR. SCARBROUGH: Well, that's what they're  
5 going to --

6 MEMBER ARMIJO: That's what they're going  
7 to test.

8 MEMBER STETKAR: Firing the igniters will  
9 do that.

10 (Simultaneous discussion.)

11 MEMBER STETKAR: The mechanical part, the  
12 *in situ* or the DP across whatever type of intern al  
13 valve design they have, with an actual DP, having had  
14 the valve sit, you know, in whatever environment it  
15 sits.

16 DR. WALLIS: If it's leaking explosive or  
17 something, which is --

18 MEMBER STETKAR: Well, or minor leakages  
19 of, you know, water or, you know, impurities.

20 DR. WALLIS: But there other ways --

21 MEMBER STETKAR: Corrosion or you don't  
22 know.

23 DR. WALLIS: There are other things like  
24 mechanical binding and so on.

25 MEMBER STETKAR: And depending on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 valve design, they may be more or less susceptible to  
2 that.

3 CHAIRMAN CORRADINI: Okay, thanks. So now  
4 we're going to have GEH come up and we're going to  
5 talk about Section 3.12; is that correct?

6 (Off mic discussions.)

7 Chapter 3 - Section 3.12 RAIs/GEH

8 MS. CUBBAGE: While we're switching, we  
9 just wanted to follow up from the previous section.  
10 Sounded like no additional on the squib valve issue.  
11 Was there additional action on the other topics, or  
12 did GE's response address that?

13 CHAIRMAN CORRADINI: We're talking about  
14 the vibration?

15 MS. CUBBAGE: Yeah.

16 CHAIRMAN CORRADINI: No, I don't think --  
17 I think we're fine.

18 MS. CUBBAGE: Okay, thank you.

19 MEMBER STETKAR: Actually Amy, I can't  
20 speak for everyone else. I'm not sure at the DCD  
21 stage now that there is additional action on the squib  
22 valves. I mean, you know, I personally certainly have  
23 a concern about them, but all I'm hearing is that it's  
24 delayed to the COL.

25 MS. CUBBAGE: I meant additional action

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for me.

2 MEMBER STETKAR: Well no.

3 MS. CUBBAGE: To satisfy --

4 CHAIRMAN COR RADINI: Go ahead. Finish  
5 what you were saying.

6 MEMBER STETKAR: Yes. I was going to say  
7 I'm uneasy, but I don't think that there's anything  
8 else at the DCD stage, for this particular activity  
9 that we're involved in here, that there's any more  
10 benefit from doing anymore.

11 MS. CUBBAGE: Okay.

12 MEMBER STETKAR: I understand the problem,  
13 and I understand that it's basically pushed off the  
14 COL, and that, you know, we'll telegraph it. We'll  
15 certainly be interested in it at the COL stage, but  
16 that's later.

17 MS. CUBBAGE: Okay, thank you.

18 MR. DEAVER: Okay. This is Jerry Deaver  
19 with GEH again. I'm going to cover the open issues  
20 associated with 3.12. Actually, we don't have a 3.12  
21 in our DCD, but topics relating to piping, pipe  
22 supports and the computer programs were covered in  
23 this series of questions.

24 We have three RAIs that I'll cover. The  
25 3.9-254 and 255 are really related to the topics in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this section, but I've already covered those.

2 The first issue is 3.12 -3. In the NUREG  
3 1061, it's very prescriptive in the use of the ISM  
4 method. It says that the absolute sum shall be used,  
5 and historically for ABWR, we had, we were allowed to  
6 use SRSS. But in looking for the records and the  
7 justification we couldn't find it.

8 So we were challenged by the staff to  
9 basically prepare justification if we were wanting to  
10 use the SRSS method. So what we did is we prepared  
11 analysis related to the main steam and feed water  
12 piping, which we were already calculating for the  
13 benchmark purposes, and what we actually did was we  
14 compared time history response methods against the  
15 response spectrum method using SRSS.

16 So the objective was to show that using  
17 the SRSS method, that the amplifications and stresses  
18 associated with that would be higher than the time  
19 history case. What we found was that virtually all  
20 cases were above the time history case, but there were  
21 six separate locations in the feed water system that  
22 did go below the time history results, and the maximum  
23 ratio was 1.08.

24 So in discussions with the staff on this,  
25 it was agreed that because of this potential of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 selected areas being worse than -- we agreed to a ten  
2 percent adder when we used this analysis. For  
3 independent support motion analysis, and this only  
4 applies to piping in containment.

5 So it 's typically piping that goes from  
6 the RPD to the containment, and where we're using the  
7 ISM method. We would do the analysis and then add a  
8 ten percent stress onto it as a conservative margin  
9 factor.

10 DR. WALLIS: You have a problem with  
11 English here, t hat I mean you have to say in all  
12 cases, the deviations above the predictions were below  
13 ten percent or something, because "in all cases were  
14 below ten percent" doesn't mean anything.

15 MR. DEEVER: Some of the wording in here  
16 is not correct.

17 DR. WALLIS: Is incomplete.

18 MR. DEEVER: Yes, yes.

19 DR. WALLIS: But what you're saying is  
20 that in the worst case, your prediction was above the  
21 data. Was below the data. The data was above the  
22 prediction by eight percent in the worst case.

23 MR. DEEVER: Right. We had the deviation  
24 of eight percent.

25 DR. WALLIS: You didn't bound it quite,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 because some of them escaped through the limit by  
2 eight percent?

3 MR. DEEVER: That's correct.

4 DR. WALLIS: And so you agreed to a ten  
5 percent correction.

6 MR. DEEVER: Added to bound any potential  
7 case.

8 DR. WALLIS: Yes.

9 MR. DEEVER: So in doing the ISM analysis,  
10 we also had discussion about how many groups of, you  
11 know, for different supports, and it was determined  
12 that we were only going to be allowed to use two  
13 support groups. One either associated with the vessel  
14 or associated with the containment, and within that  
15 structure, and we would use the limiting of response  
16 vector for the groups.

17 So with that, we added words to the DCD  
18 and this item has been resolved.

19 MEMBER ARMIJO: I guess I don't  
20 understand. If you did the analysis both ways, why  
21 don't you just use the absolute sum and --

22 MR. DEEVER: Well, the time history  
23 approach is more labor-intensive. We don't always  
24 have the data for every support point. So that's just  
25 a more labor-intensive way to do analysis.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: So you're just saying you  
2 picked a more efficient way and you just accepted a  
3 ten percent adder because --

4 MR. DEEVER: Right, and we always have the  
5 recourse to go back. I f we have real issues, we can  
6 always go back.

7 MEMBER KRESS: And you know that ten  
8 percent is good enough for every location that you  
9 worry about?

10 MR. DEEVER: Yes. That's what we --

11 MEMBER KRESS: You know why it was eight  
12 percent above your simplified analysis? You know the  
13 reasons for --

14 MR. DEEVER: I don't think we totally  
15 understand the reasons. The other significant point  
16 is that those happen to be locations that were  
17 typically low stress. So you wouldn't normally be  
18 concerned about them anyway.

19 MEMBER KRESS: I'm not too concerned about  
20 them.

21 MR. DEEVER: I mean we didn't have the  
22 combination of high stress --

23 MEMBER ARMIJO: And a high deviation.

24 MR. DEEVER: Right.

25 MEMBER ARMIJO: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: But it's not data you're  
2 talking about. You're talking about SRSS predictions,  
3 right? Because data to me implies you measured  
4 something physically.

5 MR. DEEVER: No, no.

6 DR. WALLIS: It's actually comparing two  
7 predictions.

8 MR. DEEVER: These are all calculations,  
9 yes. Okay.

10 DR. WALLIS: Correct these slides when  
11 they become part of the record.

12 MR. DEEVER: We certainly could polish it  
13 up.

14 DR. WALLIS: We probably could, to make it  
15 clearer.

16 MR. DEEVER: Okay.

17 DR. WALLIS: I don't know if you're  
18 allowed to do that. We're not allowed to correct our  
19 verbal records that he's recording over there.

20 (Laughter.)

21 DR. WALLIS: That's mistaken in some way,  
22 then we're stuck with it.

23 MR. DEEVER: I'm okay with correcting,  
24 improving it if it's allowed. Okay. We'll send that  
25 to you. Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           The next issue is 3.12-17. This topic is  
2 on the general use of SRSS for dynamic loading, and  
3 within ESBWR. There's a non-exceedance probability  
4 requirement of 84 percent that's required in NUREG  
5 0484, and typically what we found is that through the  
6 course of BWR development that basically all  
7 structures, the vessels, the buildings and such, all  
8 have relative same response characteristics.

9           And we responded to this question in two  
10 ways. One was basically a qualitative justification  
11 that load events aren't likely to combine at the same  
12 time. The peaks, you know, as such would not occur at  
13 the same time.

14           Then the randomness of the amplitudes and  
15 phasing of responses, and then just the rapid  
16 variation of plus and minus variation and short  
17 durations of peaks, such as seismic responses and so  
18 forth, and other containment loca-type responses.

19           So that was the qualitative, but then we,  
20 for Mark II, we did a detailed study. We had 291  
21 dynamic load cases that were evaluated with all the  
22 combinations of dynamic loads, and we demonstrated  
23 that there was an 84 percent non-exceedance.

24           So we met the criteria and we demonstrated  
25 for ESBWR that this prior work was applicable to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ESBWR. So in conclusion, we're in compliance with the  
2 reg, the NUREG 0484.

3 The last issue deals with the responses.  
4 In this case, we're talking about the uniform support  
5 method of analysis, and in the SRP 3.9.2, Section 22-  
6 g, it talks about using the absolute sum method or the  
7 USM method. In our DCD, we were not clear in the  
8 methodology that we were going to use for that. The  
9 simple solution in this case was that we would simply  
10 commit to the absolute sum method when we're using the  
11 USM method for analysis of piping.

12 So we have changed the DCD to clearly  
13 state that, and now we've demonstrated compliance with  
14 the SRP 392. So in summary, we've -- through I think  
15 there were like 38 RAIs in Section 3.12. Throughout  
16 the response to those and through the audits, we feel  
17 that, you know, our analysis methods and -- for both  
18 piping and supports, are consistent with the SRP  
19 requirements.

20 That's been demonstrated, and we've  
21 provided the analytical cases and such, you know,  
22 justifying the use of SRSS when it's appropriate, or  
23 the combinations.

24 DR. WALLIS: I'm trying to understand.  
25 Maybe I'm stupid or something here. You've got just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in 3.12-17, you are asked to justify using SRSS. I  
2 don't understand what GE EBWR Mark II is.

3 MR. DEEVER: That's referring to our  
4 containment design. That's --

5 DR. WALLIS: But that's not for the ESBWR,  
6 is it?

7 MR. DEEVER: They're similar.

8 DR. WALLIS: Because it's similar.

9 MR. DEEVER: It's very similar.

10 DR. WALLIS: You're arguing that it's  
11 similar, and it worked for this -- for the BWR Mark  
12 II. Therefore, it should be applied to ESBWR.

13 MR. DEEVER: Yes, it could be.

14 DR. WALLIS: That's what you're arguing.

15 MR. DEEVER: Yes.

16 DR. WALLIS: Close enough. I'm just a bit  
17 surprised that you could use BWR Mark II as an  
18 argument for justifying something about ESBWR, which  
19 is not the same thing.

20 MR. DEEVER: Well, in previous work, even  
21 the Mark I containments, which are quite different, at  
22 least as far as the suppression pool and such, even  
23 those were demonstrated to be generally similar. So  
24 that's --

25 DR. WALLIS: Are you arguing that the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 method has been qualified as being used for other  
2 systems?

3 MR. DEEVER: Right.

4 DR. WALLIS: And there's nothing peculiar  
5 about ESBWR, which would mean that it would no longer  
6 apply?

7 MR. DEEVER: Right. It's not a drastic  
8 deviation or variation of what we've done in the past.

9 DR. WALLIS: Okay.

10 CHAIRMAN CORRADINI: Other questions  
11 please, for Jerry?

12 (No response.)

13 CHAIRMAN CORRADINI: Okay. Thank you,  
14 Jerry.

15 MR. DEEVER: Thank you.

16 CHAIRMAN CORRADINI: So we'll have staff  
17 join us for 3.12.

18 Chapter 3 - Section 3.12 RAIs/Staff

19 MR. MISENHIMER: My name again is Dave  
20 Misenhimer. I'm the project manager for Section 3.  
21 We're going to talk about Section 3.12. Kaihwa Hsu  
22 will be presenting this section. Go ahead.

23 MR. HSU: I'm Kaihwa Hsu, okay. I'm the  
24 lead reviewer for the Section 3.12, okay. I'm  
25 discussing all those existing open item. The first

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 open item is related to the independent support motion  
2 measure response special method, and in the SRP 3.12  
3 recommend the acceptance criteria that's listed in the  
4 NUREG 1061, Volume 4.

5 In the original, GEH opposed. They used  
6 the SRSS method for that, for those support group  
7 combination. However, in the 1061, which is very  
8 clearly stated if, unless this support group are from  
9 the different structures, otherwise if they are in the  
10 same structure, they can be shown as the phase  
11 uncorrelated, then they are allowed to use the SRSS.

12 However, according to all those seismic  
13 response, we understand if in the same structure it's  
14 always phase correlated, and based on this phase  
15 correlated, so staff asked the question, and the GEH,  
16 okay, proposed the study. The staff reviewed that  
17 study. The staff find they do have the phase  
18 correlation, and so staff limited that, based on that  
19 phase correlation, and based on their study.

20 If they only use two group of their study,  
21 they're allowed to use the SRSS with extra ten percent  
22 margin to cover their design. As far as the rest of  
23 the combination areas, combination structure  
24 locations, they have to follow the 1061.

25 GEH proposed they are following that. So

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 GEH's final position, which means their acceptance  
2 criteria, and they're listing the NUREG 1061, Volume  
3 4.

4 So if nobody have a question, I'm going to  
5 go to the next one, which is talking about 3.12 -17,  
6 which is talking about SRSS method using the low  
7 combination of the dynamic loading, just like GEH just  
8 proposed the acceptance criteria which list in the  
9 NUREG 0464, Revision 1 for using the SRSS combination  
10 method.

11 GEH, okay, provide their justification, in  
12 their study, which means that the provisions of the  
13 NUREG 0464, Revision 1. So on that basis, open item  
14 was resolved.

15 DR. WALLIS: So what are these acceptance  
16 criteria?

17 MR. HSU: Those are non -exceedance  
18 probability of 84 percent of two independent, I mean  
19 two independent -- in time-dependent, okay, input.

20 DR. WALLIS: That's the only criteria?

21 MR. HSU: Yes. Okay, for the next IR we  
22 did n't talk about 3.47. This is load combination for  
23 seismic inertia response vector, and this one is SRP,  
24 okay, talking about you want to use the APS method.  
25 So GEH revised it from the SRSS to the APS. On the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 basis of it, this is a new staff recommendation of the  
2 SRP 392. So these open items are also resolved. No  
3 questions?

4 So I'm going to to the 3.92 -254 and 255.  
5 3.92-254 and 255 deals with the piping stress analysis  
6 computer code. So one computer code is called the  
7 PISYS, and PISYS, which performs all the static and  
8 dynamic analysis for the piping analysis, and staff  
9 asks this question, is because when the staff reviews  
10 the basic document, okay, staff finds that there's an  
11 inconsistency with the DCD, because in the PISYS, in  
12 the DCD they're talking about they use 1.92 Rev. 2.

13 But however, they are benchmarked against  
14 NUREG CR 6049, NUREG CR 6049, which is for the  
15 benchmark of the Reg Guide 192 Rev. 1, and Reg Guide  
16 1.92 Rev. 2 benchmark supposed to benchmark to the  
17 basic document for the 1.92 Rev. 2 Reg Guide NUREG,  
18 which I think is the NUREG CR 6557 or something.

19 So staff asked that question, and they  
20 identified. Actually, the computer codes are  
21 developed based on the NUREG, Reg Guide 1.91 Rev. 1.  
22 So we asked them to reflect that in their DCD. And  
23 also, the software document and QA status for computer  
24 codes were not completed.

25 So staff identified those problems and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 performed the audit, and they revised that  
2 documentation, and they revised the package, and so  
3 staff accept the PISYS 08, and otherwise NC-7 is the  
4 post-processor of the PISYS 08. And also NC -7  
5 incorporated environmental assess fatigue evaluation  
6 into their code.

7 Staff had reviewed their V&V package, and  
8 the staff noted that their computer code temperature  
9 used in the calculation for the fatigue environmental  
10 factor, FEF, which is not consistent with the  
11 procedure stated in the NUREG CR 6909.

12 So staff identified all this, and they  
13 revised all those computer codes, and staff performed  
14 the final review of their documentation and evaluation  
15 package, and find that their code is completed.

16 The software -- their completed their  
17 software design document address all the staff  
18 concerns. Therefore, this issue was closed.

19 MEMBER ARMIJO: Was that temperature non-  
20 conservative, or just a simple error?

21 MR. HSU: Just a simple error, because  
22 NUREG, okay, 6909 talking about when you have -- when  
23 you calculate it, you see the fatigue is talking about  
24 range. So the whole range, you're supposed to use the  
25 average temperature. But they're only talking about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they used the temperature, okay, for the down -  
2 trenching, and not consider about up-trenching, yes.

3 So that's not consistent with the  
4 definition of the NUREG CR 6909. On the basis, they  
5 are committed to follow the Reg Guide 1.207 and follow  
6 the 6909. So we identified all those issues.

7 DR. WALLIS: This PI SYS code, is that a  
8 GEH code?

9 MR. HSU: Both PISYS code is GEH  
10 proprietary.

11 DR. WALLIS: It's a GEH proprietary code.

12 MR. HSU: That's not a commercial code.

13 DR. WALLIS: Okay. I just wondered about  
14 that.

15 MEMBER ARMIJO: So now those have gone  
16 through the GEH Level 2 process there and verified and  
17 you're happy with it?

18 MR. HSU: Yes.

19 MEMBER ARMIJO: Okay.

20 DR. WALLIS: It's interesting that the  
21 code is there before the design documents are written  
22 and completed?

23 MR. HSU: Because --

24 DR. WALLIS: It often seems to be the case  
25 that you've got the code, and then someone figures out

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we'd better have a design document, so you write it.

2 It seems backwards to me, but that's --

3 MR. HSU: Because this is a -- this code  
4 is like a little bit conf used, okay. They have a  
5 PISYS 05, PISYS 06, PISYS 07, PISYS 08.

6 DR. WALLIS: An evolving thing.

7 MR. HSU: Yeah, and then when we look at  
8 that, okay, like ANSI 714, they say you have to use  
9 the PISYS 08 as the input. You're not taking the  
10 PISYS 07 as the input. So previously -- so that's the  
11 reason, okay, they clarify for us which version they  
12 have to be used for us.

13 DR. WALLIS: Like these documents I get  
14 from the government, which are always in some updated  
15 computer code that I can't read on my machine.

16 CHAIRMAN CORRADINI: Questions?

17 (No response.)

18 CHAIRMAN CORRADINI: Okay, thank you.  
19 What we're going to do is we're going to continue and  
20 take a topic from this afternoon, Chapter 4, and  
21 discuss it now. So --

22 MS. CUBBAGE: And it should be quick and  
23 uneventful.

24 CHAIRMAN CORRADINI: Well, let's not -- we  
25 don't want to make any --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. CUBBAGE: Right. We don't have the  
2 technical staff here. We're going to just do -- it's  
3 a high level presentation. If there are any questions  
4 on Chapter 4, we'll have the staff here at one  
5 o'clock, if need be. But we'll go ahead and do that  
6 real quick and --

7 CHAIRMAN CORRADINI: Just to remind  
8 everybody. Most of the -- most, I thought, we think,  
9 I thought all of the issues on Chapter 4 we dealt with  
10 back in May, when we went through all the topical  
11 reports again and the new issuance of them.

12 So what we're going to do is review, at a  
13 relatively high level, Chapter 4 discussion. But I  
14 hope you all have, you know, totally in your minds,  
15 the joys of May 17th and 18th that we see. Bruce?

16 MEMBER ARMIJO: Yes, I remember this  
17 stuff.

18 (Off mic discussions.)

19 CHAIRMAN CORRADINI: All set.

20 MR. BAVOL: Yep.

21 CHAIRMAN CORRADINI: Go ahead.

22 Chapter 4 - Reactor/Staff

23 MR. BAVOL: Okay. My name is Bruce Bavol.  
24 I'm the project manager for the Chapter 4 review, and  
25 everybody's had an opportunity to take a look at the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 safety evaluation for Chapter 4. Like Amy had  
2 mentioned, this is going to be very brief, high level.

3 A number of the significant RAIs and the  
4 issues that were a part of the Chapter 4 review were  
5 contained and discussed in previous Subcommittee  
6 meetings listed here on this slide here. Fuel  
7 assembly, fuel rod, control blade, mechanical design,  
8 nuclear design, gamma thermometer and back in October,  
9 critical power correlation and critical power testing.

10 Out of the approximately 258 technical  
11 RAIs that were closed for Chapter 4, and they're  
12 related to the appropriate sections here. The staff  
13 found no outstanding issues, and ACRS had no  
14 outstanding issues for us from the previous briefings.

15 So in conclusion, the staff finds that the  
16 ESBWR fuel assembly and control blade designs are  
17 acceptable, meets regulatory requirements, including  
18 applicable GDCs, and the analysis and testing has  
19 demonstrated conservative design. Like I said, this  
20 is very short, very sweet. Are there any questions  
21 for us or the staff that we can take away?

22 CHAIRMAN CORRADINI: Anything?

23 (No response.)

24 CHAIRMAN CORRADINI: Okay. John, I'm  
25 sorry. I didn't mean to -- do you have anything?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: No.

2 CHAIRMAN CORRADINI: Okay. So with that,  
3 why don't we break for lunch and be back here at  
4 12:30. Is that allowable? I'm assuming it's  
5 allowable. Amy?

6 MS. CUBBAGE: To what?

7 CHAIRMAN CORRADINI: Start at 12:30?

8 MS. CUBBAGE: That's up to you all.

9 CHAIRMAN CORRADINI: Okay, good. We're  
10 breaking for lunch. Back at 12:30.

11 (Whereupon, at 11:23 a.m., a luncheon  
12 recess was taken.)  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

## A F T E R N O O N S E S S I O N

12:31 p.m.

Chapter 9/GEH

CHAIRMAN CORRADINI: Okay. We'll come back in session, and we'll start off with Chapter 9 and GEH presentation for auxiliary systems.

MR. DEEVER: Okay. We'd like to -- this is Jerry Deaver with GEH. I'd like to kick off the Chapter 9 discussion. The agenda will cover several topics. The first one will be related to spent fuel pool to K heat, and associated analysis with racks.

Then we'll cover spent fuel uncovering. Then we'll cover gas accumulation in the FAPCS system. At this point I'll turn it over to Mike Arcaro to cover auxiliary system RTNSS functions, plant service water, RCCW, chill water system and instrument error and service error.

CHAIRMAN CORRADINI: I believe it was in one of the prior meetings where we -- there was some discussion about the heat load in the spent fuel pools, and I think there was an inconsistency that you were going to check on and get back to us, if I remember correctly.

MR. DEEVER: Well, what we found is, you know, there was this discussion about the 3 0, you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 know, using a heat load that was at the 30 day point  
2 after a restart of an outage. That comes directly out  
3 of SRP 9.1.3 Rev. 1. It talks about doing the  
4 calculation at that specific time frame.

5 So I guess at that time, we were in fact  
6 consistent with the NUREG requirements, although what  
7 we found is, and I think the implication in that SRP  
8 is that that's the limiting case. We, in our  
9 subsequent analysis, found that that is not  
10 necessarily the limiting case.

11 So as a result of that, we've now reanalyzed  
12 using the maximum loads for a full pour-off load and  
13 with the prior loads that have been discharged. So  
14 we're using the latest decay heat methodology.

15 So this is the most accurate means of  
16 calculating decay heat, in accordance with the ANSI  
17 Standard 5.1, 1994 edition. It includes all the  
18 actinide issues and the activation product issues that  
19 have been, you know, previously required for analysis  
20 purposes.

21 DR. WALLIS: So the requirement is these two  
22 together, the one full core vector and one refueling  
23 load is equal to both together.

24 MR. DEAVER: Well see that's -- that's not  
25 even very conservative, assuming you have multiple

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 loads of fuel coming out.

2 DR. WALLIS: That's right. I'm puzzled.

3 MR. DEEVER: Right. So there is a more  
4 recent SRP, which was issued in March of 2007, which  
5 you know, wasn't in effect when we docketed. But  
6 really I think in effect we're working to the latest  
7 SRP now as far as this issue is concerned, as far as  
8 doing the current methods analysis.

9 Because associated with that Rev. 1, there  
10 was a branch technical position, ASB 9-2, which  
11 provided a methodology. But it was not as rigorous as  
12 what we're doing today. So the next slide actually  
13 shows, as a --

14 MEMBER ABDEL -KHALIK: So this actually  
15 includes more than one discharge?

16 MR. DEEVER: Oh yeah. Well, in our  
17 analysis.

18 MEMBER ABDEL -KHALIK: In the current  
19 analysis. So it corresponds to essentially late in  
20 the life of this facility, where you have a lot of  
21 spent fuel accumulated in the core, and then you have  
22 a complete core offload after 36 days or something  
23 like that, plus one refueling load ignot?

24 MR. MARQUINO: Yes. It's ten years of  
25 operation, two year cycles, so five batches of spent

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fuel in the core offload.

2 MEMBER ABDEL-KHALIK: Okay.

3 DR. WALLIS: The thing that interested me is  
4 it depends how quickly you offload, doesn't it?

5 MR. DEEVER: Of course, yes.

6 DR. WALLIS: If you offload instantaneously,  
7 you've got 200 megawatts or something like that.

8 MEMBER ARMIJO: Fortunately, you can't do  
9 that. I don't think you can do that.

10 DR. WALLIS: But you have to take your time;  
11 otherwise, you're stuck with 50 megawatts or something  
12 like that, which you can't handle. So you take days  
13 to do it.

14 MR. DEEVER: Yes. That's the other part  
15 that's interesting here, is that the SRP talked in  
16 terms of 150 hours.

17 DR. WALLIS: That's right.

18 MR. DEEVER: Which is six and a quarter  
19 days. But we've always been analyzing to five days,  
20 you know, which was still a conservative early time  
21 frame to start looking at heat load.

22 DR. WALLIS: So how long does it really  
23 take?

24 MR. DEEVER: To get to the point where  
25 you're discharging --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: To offload this whole core.

2 MEMBER ARMIJO: To offload. Listen, you've  
3 got a lot of bundles in this.

4 MR. DEEVER: Well, to do a full core  
5 offload, that's 1,132 bundles, and you know, we're not  
6 going to be at a point where we're fully disassembled,  
7 you know, take the containment head off, vessel head,  
8 internals, cool down to the point where we can get  
9 1,132 bundles out in five days. That's not going to  
10 happen.

11 DR. WALLIS: When do you start to take them  
12 out when you've taken off the head and cooled down?  
13 When do you actually start to offload?

14 MR. DEEVER: As soon as the -- in our case,  
15 we'll be removing the partitions, chimney partitions.  
16 So that's after the dryer separator and chimney  
17 partitions.

18 DR. WALLIS: So you'll be -- how long after  
19 shutdown will you start to offload, actually offload  
20 fuel?

21 MR. DEEVER: Do you recall, Allen --

22 MR. BEARD: I was going to say, the best  
23 case we would look at is about 42 hours before we  
24 actually start to remove fuel from the RPD itself.

25 DR. WALLIS: Forty-two hours. The choice,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the 42 hour, you put it in. You put it in and it's  
2 decaying as you put it in. S o you've got to sort of  
3 integrate this whole thing really, if you've got a  
4 proper answer.

5 MR. DEAVER: Right. The next slide gives  
6 you a little perspective of -- well actually, it's the  
7 next one after. But this slide gives you the  
8 perspective of what the actual heat rate is in a given  
9 point in time in a cycle. So you can see that in the  
10 start of this curve, the blue line is approximately  
11 the 36 days. That represents the core offload.

12 DR. WALLIS: This is the same curve you give  
13 us for the PCCS heat removal.

14 (Laughter.)

15 DR. WALLIS: It's the same curve.

16 (Simultaneous discussion.)

17 MR. DEAVER: --I guess. But you can see  
18 that the heat load, core offload, the heat associated  
19 with the core offload increases in time, and the decay  
20 heat on the bot tom curve from the old batches is  
21 declining. So when you add the two together, you get  
22 the total and you can see that at about a year, you're  
23 not really changing the amount of total heat that  
24 could potentially be, you know, available for the  
25 cooling.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: This is the heat when you've  
2 just finished the offload, so the maximum --

3 MR. DEEVER: This is at five days. This  
4 would be the heat load at five days.

5 DR. WALLIS: It's the maximum when you  
6 actually finish the offload, or some time during the  
7 offload, because this stuff's aging as you go along?

8 CHAIRMAN CORRADINI: I think, I mean he  
9 keeps trying to ask you the same question and you're  
10 not answering it. Are you assuming once you hit five  
11 days it instantaneously appears in the spent fuel  
12 pool?

13 MR. MARQUINO: Yes.

14 DR. WALLIS: It doesn't. You're offloading  
15 it step by step.

16 CHAIRMAN CORRADINI: Yes, but if they did  
17 that, you'd ask them what's the assumption on the  
18 offload rate. So they're just saying at five days, it  
19 goes from point --

20 DR. WALLIS: They don't know that, because  
21 as you put it in, the early stuff is hotter, and then  
22 the decays --

23 CHAIRMAN CORRADINI: But it's only one -one  
24 thousandths of a full core. So what do I care?

25 DR. WALLIS: No, but it may be that half a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 core aged -- half a core aged three days is worse than  
2 the whole core at five days. I don't know.

3 CHAIRMAN CORRADINI: No, no.

4 DR. WALLIS: Have you broken it down?

5 CHAIRMAN CORRADINI: Not at that point.

6 DR. WALLIS: You've actually done the  
7 integral of all this over time?

8 CHAIRMAN CORRADINI: Well, it goes as the  
9 minus .2 power of time after about a minute.

10 DR. WALLIS: Yes, that's right.

11 MR. DEEVER: Let's go to the next slide.  
12 This gives you perspective of the decay.

13 MEMBER ABDEL-KHALIK: But before we -- how  
14 much difference has this correction made?

15 MR. DEEVER: Well, previously we were using  
16 17.3 megawatts, and now we're at, rounded up, it's  
17 18.1. So we're .8 megawatts higher in our  
18 calculations now. What we've actually done in our  
19 spent fuel pool, boil off and our rack calculations,  
20 we've actually added margin on top of that, because we  
21 didn't want to be right at the limits.

22 CHAIRMAN CORRADINI: So the difference from  
23 what we heard previously and what we had now is .8  
24 megawatts?

25 MR. DEEVER: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Okay, uh-huh.

2 MR. DEEVER: Right, okay.

3 DR. WALLIS: That takes kind of all the  
4 stuff that's in the fuel pool already?

5 MR. DEEVER: Yes.

6 DR. WALLIS: Which is fuel -- is at the  
7 bottom there. Okay.

8 (Simultaneous discussion.)

9 MR. DEEVER: Okay. Now going to the next  
10 slide, this shows you that the K rate after shutdown,  
11 and the green line, which is the bottom line, was the  
12 prior analysis at the 36 day case.

13 DR. WALLIS: So why are the old batches  
14 decaying so fast? I mean they're old batches, aren't  
15 they? Why are they decaying so fast? I would think  
16 they'd be pretty constant by then.

17 MEMBER ABDEL-KHALIK: Well, this is the core  
18 that was just offloaded.

19 DR. WALLIS: It was just offloaded? That's  
20 the old stuff that's within that core?

21 (Simultaneous discussion.)

22 DR. WALLIS: The spent fuel that was taken  
23 in the fuel pool.

24 MEMBER ABDEL-KHALIK: In the immediate prior  
25 cycle.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: It's not the stuff that's  
2 already in the fuel pool?

3 MR. DEAVER: This is the total heat.

4 CHAIRMAN CORRADINI: It's the sum of all of  
5 them.

6 DR. WALLIS: Including what's already in the  
7 fuel pool?

8 MR. DEAVER: Yes.

9 DR. WALLIS: Where is that on here?

10 MEMBER ARMIJO: On this case, it's a 20-year  
11 case. So there's several lines that contribute to  
12 this composite line.

13 CHAIRMAN CORRADINI: I think that's the  
14 point, Graham. That bottom line is the sum of maybe  
15 five batches, and most recent batch is probably  
16 dominating the other four, and that's falling off over  
17 time.

18 DR. WALLIS: How recent is it, though? It's  
19 years old, isn't it? It's been in there for some  
20 time.

21 (Simultaneous discussion.)

22 MEMBER ARMIJO: Two years.

23 DR. WALLIS: So it can't be decaying at this  
24 rate. This rate is far too rapid for any batch that's  
25 been in there for a while.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MARQUINO: So this is the accounting of  
2 different batches' contribution.

3 DR. WALLIS: So batch number --

4 MR. MARQUINO: You see the oldest batch is a  
5 small fraction of the most recent batch, and also here  
6 you can see the contribution of the spent fuel batches  
7 versus the full core discharge.

8 MEMBER ARMIJO: You can see the contribution  
9 just dropping off.

10 MEMBER STETKAR: I'm a little confused.  
11 This isn't decaying. I don't know anything about  
12 decay heat. I just know about counting years. This  
13 seems to indicate you did the analysis with ten years  
14 and five previous cycles, plus the offload, which is  
15 what you said orally.

16 The curves and the text in the DCD claim  
17 that it's done with 20 years' worth of fuel, ten  
18 cycles.

19 MR. DEAVER: Well, let me explain.

20 MEMBER ARMIJO: That's why it took 20.

21 MEMBER STETKAR: Well, this only counts up  
22 to five cycles --

23 CHAIRMAN CORRADINI: Let Jerry try to  
24 illuminate us.

25 MR. DEAVER: What we've done, and I think

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I've explained it before, but I'll go over it again,  
2 as far as the number of fuel cells that we're actually  
3 providing in this licensing submittal, it's ten years'  
4 worth. But we have a pool that will accommodate 20  
5 years.

6 So from a design perspective, we're  
7 designing our systems, the FAPCS system and our  
8 buildings and structures, to handle the full 20 years'  
9 worth of fuel. So when we're talking about a systems  
10 situation like boil-off and such, we're using 20  
11 years. But when we're talking about racks and the  
12 rack certification, then we're talking ten years.

13 And so it makes it a little confusing, but  
14 the numbers are not that much different. The  
15 contribution of the ten to twenty year is only .68  
16 megawatts. So it's not that much different. But what  
17 you're seeing on here is the ten-year batches.

18 MEMBER STETKAR: But on the slide that we  
19 jumped to this one from, your Slide No. 5 --

20 MR. DEEVER: Right. That's a 20-year.

21 MEMBER STETKAR: That's a 20-year?

22 MR. DEEVER: Yes, because this is associated  
23 with the full boil-off calculation. This is what  
24 we're using --

25 MEMBER STETKAR: For full boil-off?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: For full boil-off, from a FAPCS  
2 system perspective.

3 MEMBER STETKAR: Okay.

4 MR. DEEVER: Okay, and what just -- why  
5 don't we go back to that curve, Wayne? Okay. So what  
6 you see on this curve is the green line is the prior  
7 one, which was basically done at the 17.3 megawatts.

8 The blue line represents the new calculated  
9 value, and the red line is the bounding number that  
10 we're actually working to in our calculations. So  
11 we've got margin in our calculations at this point.

12 CHAIRMAN CORRADINI: The bounding number  
13 that you're working to. Can you say that again? I'm  
14 sorry, I don't remember what that means.

15 MEMBER ARMIJO: Is the designing capacity,  
16 you know?

17 MR. DEEVER: Well --

18 MR. MARQUINO: That's a number that has some  
19 conservatism over the EOC case.

20 MR. DEEVER: Well, it includes the 102  
21 percent power level, and so far it's got all the  
22 adders associated with it.

23 MEMBER ARMIJO: But your spent fuel pool  
24 cooling capability is at 20 megawatts or 22 or --

25 MR. DEEVER: Well, at -- we have to talk

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 about normal case and abnormal, okay. For the normal  
2 case, what we've really just got the ten years of new,  
3 you know, we discharged the current cycle and we have  
4 the five discharges. That's the normal case, and we  
5 have an 8.3 megawatt heat exchanger that can  
6 accommodate that load.

7 But when we're considering the abnormal case  
8 of a full core offload in addition, then where we're  
9 at is we're using two heat exchangers, and we're also  
10 allowed to have the pool temperature go up 20 degrees.

11 So now we really have a heat exchanger capability of  
12 more like 29 megawatts, up in that range.

13 So it's the capability of our heat exchanger  
14 system is increased significantly.

15 MR. MARQUINO: Jerry, they're asking what  
16 the number is. It's 19.1 megawatts, is the value on  
17 this curve at 150 hours. They're asking what number  
18 do you use for the design versus the ANS calculated  
19 number.

20 MR. DEAVER: Okay.

21 DR. WALLIS: So this boiling is just subcool  
22 point.

23 CHAIRMAN CORRADINI: Well wait. Let him  
24 answer this question before you give him another  
25 question.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: Yes. John Burns, I believe, is  
2 on the line. What's the actual heat load at the time  
3 that you start the boil-off calculation?

4 MR. BURNS: This is John Burns. The actual  
5 heat flow at the start of the calculation. Let's see.

6 At the 150 hour point -- hang on, I'm pulling that  
7 up. MEMBER ARMIJO: So we can read it off this

8 chart.

9 MR. DEEVER: I know at the five-day point, I  
10 believe John, you were at 20.1.

11 MR. BURNS: That's correct.

12 MR. DEEVER: But at the 150 hour point, I'm  
13 not sure what you're at. It's something lower.

14 MR. BURNS: I've got some figure s I know  
15 here.

16 MEMBER ARMIJO: It's a red curve?

17 CHAIRMAN CORRADINI: The red curve looks 19-  
18 ish to me.

19 MEMBER ARMIJO: 18 something, 19 something.

20 CHAIRMAN CORRADINI: Something like that.

21 MEMBER ARMIJO: Close enough.

22 MR. BURNS: Yes. Down around the 18 mark.

23 MR. DEEVER: Okay. Is there another  
24 question?

25 CHAIRMAN CORRADINI: Yes, Graham.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: You say "boiling." Does it  
2 actually get -- the whole pool doesn't get up to the  
3 boiling point, does it?

4 MR. DEEVER: Well, what we're assuming is  
5 that for a 72 hour period, we have no cooling. So  
6 when you cut off the FAPCS system --

7 DR. WALLIS: No pumping.

8 MR. DEEVER: Right.

9 DR. WALLIS: Okay. That's what you're  
10 assuming?

11 MR. DEEVER: Yes.

12 DR. WALLIS: So it does boil off?

13 MR. DEEVER: It does boil off.

14 MEMBER ABDEL -KHALIK: I guess I have a  
15 question about the previous Slide No. 4. I'm looking  
16 at the blue line, which corresponds to the decay heat  
17 from the core offload, and this graph starts, the  
18 first point is at 36 days, and you're plotting this as  
19 a function of time into the cycle.

20 Now tell me what this means. This curve is  
21 really at points in time at the five day cool-down  
22 point? In other words, if I offload the core at 36  
23 days, after it had been running for 36 days, and  
24 allow, give it five days to offload --

25 MR. DEEVER: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL -KHALIK: Then my decay heat  
2 from that offload would have been 14 megawatts?

3 MR. DEEVER: Yes.

4 MEMBER ABDEL -KHALIK: And if I -- if that  
5 core had been operating for 180 days instead of 36  
6 days.

7 MR. DEEVER: Yes.

8 MEMBER ABDEL -KHALIK: And I offloaded in  
9 five days, the decay heat associated with the -- would  
10 that full core that had been operating for 180 days  
11 would have been 15.8 megawatts. Is that what this  
12 means?

13 MR. DEEVER: Yes. That's exactly what it  
14 means.

15 MEMBER ABDEL -KHALIK: Okay. So these are  
16 really different scales, right?

17 MR. DEEVER: Well --

18 MEMBER ABDEL -KHALIK: Of time into the  
19 cycle. Okay. That's fine.

20 MR. DEEVER: It's time into the operating  
21 cycle, but it's consistent in that it's at five days'  
22 discharge time.

23 MEMBER ABDEL-KHALIK: Right.

24 DR. WALLIS: So this 72 hours after your  
25 core offload you're talking about, this 72 hours?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: Wait. Which one are we talking  
2 about now?

3 DR. WALLIS: The thing is boiling off.  
4 There's no water supply for 72 hours. That's after  
5 you've offloaded?

6 MR. DEEVER: Yes. At the time, 150 hours to  
7 222 hours.

8 DR. WALLIS: And there's no water flow?

9 MR. DEEVER: There's no water flow, and  
10 we're at the worse case conditions.

11 DR. WALLIS: Your FLUENT calculations seem  
12 to show water coming in all the time, the different  
13 calculations.

14 MR. DEEVER: That's the rack cooling part.

15 DR. WALLIS: Or something else.

16 MR. DEEVER: Or something else, yes. Now  
17 moving forward, now I have a slide that relates to the  
18 boil-off analysis that's performed.

19 So again, this is a system calculation, so  
20 it's at the 20 year worth of spent fuel. So we have  
21 the obligation to look at a cooling or a boil -off for  
22 72 hours, and the bounding case we find that the  
23 evaporation is 1962 cubic meters of volume of water,  
24 and this drops the water level in the pool by 10.26  
25 meters.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: That's a lot of water.

2 PARTICIPANT: That's 30 feet.

3 MEMBER STETKAR: The minimum pool level --  
4 well, let me ask you a question. Is there any way  
5 that you can drain the water down to the bottom of the  
6 slot, so that the -- between the pools? I had a  
7 question eons ago about what the height of that?

8 MR. DEEVER: Well, we have a weir that said  
9 14.35 meters in the pool. So we're always, you know,  
10 bringing water into the pool. So it's always  
11 overflowing the weir.

12 MEMBER STETKAR: Okay. Is there anyway that  
13 you can cut off the water inlet? Is there any way  
14 that you can drain water below that level?

15 MR. DEEVER: Well, we have these anti-siphon  
16 holes that are in the piping.

17 MEMBER STETKAR: Yes. I understood for the  
18 supply water.

19 MR. DEEVER: On the inlet.

20 MEMBER STETKAR: And that's the only  
21 connections? I mean t here are no other connections  
22 that you can --

23 MR. DEEVER: Right. The pool has no other  
24 connections. It has two inlets and two outlets.

25 MEMBER STETKAR: Thanks.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEAVER: That's all there is.

2 MEMBER STETKAR: Thank you.

3 MEMBER ARMIJO: What happens with all that  
4 water that boils up? Where does it --

5 MR. DEAVER: It just magically disappears.

6 MEMBER ARMIJO: It's got to go somewhere.

7 MR. DEAVER: We know it's going to condense  
8 on walls and ceilings, and it actually ends up back in  
9 the pool in some form and so this is a very --

10 MEMBER ARMIJO: That's what I was trying to  
11 get at. Do you have some sort of a passive feature  
12 that would put that back into the pool --?

13 MR. DEAVER: I mean obviously it's somewhere  
14 in the building still, and it's going to condense and  
15 it's going to end up back in the pool, you know,  
16 because you've got such a large volume of water.  
17 That's a lot of water.

18 MR. MARQUINO: And some of it would escape  
19 the building also.

20 MEMBER ARMIJO: Can it escape the building?

21 MR. DEAVER: Well, we've had a recent  
22 exchange with the NRC staff about venting and  
23 preventing the building from pressurizing.

24 DR. WALLIS: You don't want it to condense  
25 on some important equipment.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Yeah. That's what I was  
2 getting at.

3 MEMBER STETKAR: Yes, I was -- I'm going to  
4 have another question after we finish boiling water.  
5 Is the floor level, you know, whatever you call it,  
6 the refueling building floor level, where you can  
7 stare into the pool, is that leak-tight from lower  
8 elevations in the building, or can water -- we're  
9 talking about water condensing, you know, and where  
10 does it go?

11 Can it condense on building surfaces and  
12 flow to lower elevations in the building? Stairwells,  
13 access? Is there any requirement -- let me ask you  
14 this. Is there any requirement that it's leak-tight?

15 MR. DEAVER: No, no, it isn't.

16 MEMBER ARMIJO: Okay.

17 MR. DEAVER: We're at grade. Our floor, you  
18 know, our refueling floor or the fuel building floor  
19 is at grade.

20 MEMBER ARMIJO: Yes.

21 MR. DEAVER: But the water can seep down.

22 MEMBER ARMIJO: Back down into lower  
23 elevations in the buildings.

24 MR. DEAVER: To lower elevations, yes.

25 MR. MARQUINO: And we have a floor drain

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 system in the building. So the -- most of the  
2 condensate would flow to the floor drain system and be  
3 collected.

4 DR. WALLIS: Does it set off fire alarms and  
5 things like that? I expect it would, because it's  
6 steam going everywhere and --

7 MEMBER ARMIJO: It's not a smoke detector  
8 involved.

9 MR. DEAVER: I don't know. Mike, do you  
10 have -- you have that part of the question.

11 MR. ARCARO: Yeah, I would have to look at  
12 that. But I think for areas where you have steam,  
13 they use a different type of detector.

14 DR. WALLIS: Okay. Well --

15 CC I don't think the temperature is going to  
16 set it off, if that's what you're asking.

17 MEMBER STETKAR: You typically use an  
18 ionization detector or something like that.

19 MR. ARCARO: Yes, right.

20 MEMBER STETKAR: It would be a heavy  
21 humidity situation --

22 MR. DEAVER : I don't think 100 percent  
23 humidity would ever set it off.

24 DR. WALLIS: Well, it's an awful lot of  
25 water. It's going somewhere.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: Yes, that's right.

2 DR. WALLIS: That's right.

3 MEMBER ARMIJO: That's why you have some  
4 flooding somewhere, that you don't want it to flood?  
5 It all goes into these floor drains and in the tanks  
6 or other pools?

7 MR. DEEVER: Yes. It would go back into our  
8 water systems, and so we wouldn't necessary lose the  
9 water.

10 MEMBER ARMIJO: So you don't worry about any  
11 kind of flooding that would come from condensation of  
12 --

13 CHAIRMAN CORRADINI: I just want to make  
14 sure we're not deviating. This is a design basis  
15 calculation they're required to do. So I -- if we're  
16 going to ask them to be realistic.

17 MR. DEEVER: Yes. In the real case, if  
18 we're starting to lose pool water, we're going to  
19 start using fire water and other sources to refill the  
20 pool.

21 MR. MARQUINO: And also you're talking about  
22 investment protection versus safety, because --

23 MEMBER ARMIJO: Oh, I understand. I'm just  
24 curious. Right.

25 MR. DEEVER: Okay. So as a result of this,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we just recently, based on the new heat calculations,  
2 we've updated the DCD sections. We have more boil-off  
3 than we had previously, and that affected some of the  
4 tech spec requirements. But what we've shown is that  
5 even under these severe cases, we still have fuel  
6 cover.

7 MR. MARQUINO: 30 feet of water.

8 MR. DEEVER: And, you know, that we never  
9 uncover the actual stored fuel. Okay. So that's the  
10 boil-off analysis. Then we get into the rack  
11 thermohydraulic analysis.

12 DR. WALLIS: But it's boiling pretty  
13 vigorously then, if it's giving off -- I'm trying to  
14 figure out what's the sort of state of the pool. But  
15 there's quite a velocity of steam coming off that  
16 pool, isn't there?

17 I'd have to calculate it. But this huge  
18 amount of water, even in three days, it's still a  
19 pretty rapid --

20 MR. DEEVER: You're going to have some  
21 active boiling going on.

22 DR. WALLIS: It looks like the staff would  
23 be interested in what happens to all this great plume  
24 of steam and where it goes and what it does. Even  
25 though it's a design basis action, you'd be looking

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for consequences.

2 MR. DEEVER: Right, okay. Okay. As a  
3 result of the heat load calc, revised heat load calc,  
4 we also had to look at the fuel storage rack  
5 thermohydraulic analysis, and we -- in this case, it's  
6 the ten years' worth of fuel, and we assumed a heat  
7 load of 19 megawatts, which was greater than the 17.3  
8 that we previously had in our licensing topical  
9 report.

10 But what we've done is we had a prior  
11 analysis where we looked at 29 megawatts. That was a  
12 very early point in time after shutdown of the  
13 reactor, and very conservative. So we have a bounding  
14 case, is what it amounts to. So we're modifying the  
15 LTR to introduce again the 29 megawatt case, to look  
16 at the critical parameters associated with the fuel  
17 pool.

18 So we have the exit temperature is an issue,  
19 and the amount of temperature that exits the racks.

20 DR. WALLIS: What do you mean by the rack  
21 exit temperature? This is the maximum rack exit  
22 temperature?

23 MR. DEEVER: This is the maximum exit  
24 temperature, and again --

25 DR. WALLIS: There's a distribution of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 temperature. This is the maximum.

2 MR. DEEVER: Right.

3 DR. WALLIS: Okay, because it just say s  
4 "rack exit temperature." It doesn't say "maximum."

5 MR. DEEVER: Well, yes, and we assumed the  
6 worst case conditions. We put the hot bundles at the  
7 farthest point in the pool, you know, furthest away  
8 from the cooling flow. So this is the temperature  
9 coming out of the top of the racks.

10 DR. WALLIS: So this is the maximum  
11 predicted by FLUENT or something, when you look across  
12 the spectrum.

13 MR. DEEVER: The CFT program, right. So the  
14 calculated value for the 29 megawatt case was 80.9  
15 degrees Centigrade, and the limit is 121. So we have  
16 a lot of margin still in this case. The other thing  
17 we look at is the fuel cladding temperature. In the  
18 29 megawatt case, it was calculated to be 97.12  
19 degrees Centigrade.

20 So the real criteria is it has to be below  
21 100, and but again we'll be -- this is a bounding  
22 number.

23 DR. WALLIS: We'll presume it's more than  
24 100, because of the depth of water to increase the  
25 pressure. So all --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: Yes. Our real limit is  
2 something above 100.

3 DR. WALLIS: That's right.

4 MR. DEEVER: And then the -- then the last  
5 bullet is there's no condition within the fuel  
6 assembly that causes boiling. Therefore, nuclide  
7 boiling is prevented.

8 So as we've gone through this case, with  
9 this bounding point on megawatt case, we've  
10 demonstrated that this fully satisfies all the  
11 requirements that we would have at the 19 megawatt  
12 case. Okay. Any questions?

13 DR. WALLIS: I was wondering why you did the  
14 29 megawatt case, which is so much bigger?

15 MEMBER ARMIJO: They just did.

16 MR. DEEVER: That was actually an earlier  
17 point in time, a couple of years ago. So we were  
18 being very conservative at that point. Okay. Going  
19 to the next slide, last, I believe it was the last  
20 meeting or the one before, we had some discussion  
21 about the streamline effects.

22 And so when we went back to our, the people  
23 who did our analysis, what we found is that the  
24 domains in the racks were actually blocked, so that we  
25 couldn't see the flow.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: Well, the very interesting  
2 thought was not in the figure at all.

3 CHAIRMAN CORRADINI: It was calculated. It  
4 didn't go in the figure.

5 MR. DEAVER: There are three things, I  
6 think, that the comments revolved around. One was we  
7 had a hard time understanding the figures you gave us.  
8 Second was you guys told us there was some blockage  
9 factor, and third was the fact what Graham said, is  
10 that all the streamlines that were shown were outside  
11 of the racks, or patterns, whatever they are.

12 So what we've had them do is just turn on  
13 the domain where the inlet flow and one of the hottest  
14 racks is shown, as far as the streamline effects. So  
15 now you can see the cooling coming in through the  
16 bottom of the racks, and then the flow as it goes  
17 through the rack itself.

18 DR. WALLIS: There's a big vortex or  
19 something above the rack, something that swirls  
20 around?

21 MR. DEAVER: Yeah. It's probably just the  
22 normal flow of heat that's being discharged off the  
23 top of a hot source.

24 MEMBER ARMIJO: There's no cross-flow within  
25 these domains or the racks?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: No, no. The actual racks  
2 prevent flow. So these are real silos, you know, or  
3 chimneys.

4 MEMBER ARMIJO: Okay.

5 MR. DEEVER: So we think, you know, this is  
6 a much better piece of information as regarding how  
7 the flow really occurs. So we've included this  
8 already into our LTR revision, and --

9 DR. WALLIS: Now where it goes up to 73  
10 degrees, is that what I conclude from this?

11 MR. MARQUINO: Yep.

12 MR. DEEVER: Right.

13 DR. WALLIS: And that's Fahrenheit. No, no.  
14 It's C, C.

15 MR. DEEVER: That would be degrees C.

16 DR. WALLIS: Okay, uh-huh.

17 MR. DEEVER: So we think this helps explain  
18 the streamline effects, you know, and this is  
19 reasonable. Okay. Moving on to one of the RAI  
20 topics, this RAI 19.1 -128 SO-1. This dealt with the  
21 question of could we uncover fuel or have it drain  
22 down in the actual vessel cavity?

23 Our configuration is such that we have a  
24 refueling bellows that is a 360 degree structure that  
25 goes around the vessel, and it separates the upper

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 cavity from the dry well, and it protects people from  
2 down below.

3 So that's a design we've had in all of our  
4 BWRs going back, at least starting with BWR -2s. So  
5 we've had a very good history of operation with that  
6 type of bellow seal. It's got a lot of flexibility in  
7 it to accommodate vessel expansion and so forth.

8 So in this question, we address the issue  
9 of, you know, reliability of this refueling bellows.  
10 We discussed issues with plugs that we use for the  
11 steam line and IC system and so forth, and address the  
12 general issue of inadvertent drain down of valve  
13 configurations during outages and the potential for --

14 DR. WALLIS: These are the seals that leaked  
15 in some of the Mark I's that --

16 MR. DEEVER: I only know of one plant that  
17 had any leakage in the bellows, and it was very minor.

18 But they did have to address it. That happened to be  
19 in Spain. So in general, these bellows have been very  
20 reliable, and they actually have the ability to block  
21 it off. Well, we have a leak detection system that's  
22 in operation all the time.

23 DR. WALLIS: You have somewhere that if it  
24 does leak, it's directed out into a suitable drain or  
25 something?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEAVER: Right. If there's actual  
2 leakage in the bellows then yeah, there is a drain  
3 line that goes off to a sump. So we think, you know,  
4 through the addition of information in the DCS or DCD,  
5 and with the response to the questions, we've you  
6 know, adequately responded to the potential for drain  
7 down.

8 We have nothing really different than prior  
9 BWRs, and we haven't had an issue with drain down.

10 DR. WALLIS: What does this "not credible"  
11 mean? I mean I'm sure we've had this discussion  
12 before, but I'm always puzzled by what is credible.  
13 To a scientist, almost everything is credible.  
14 Without it, it would violate the second law.

15 CHAIRMAN CORRADINI: What are you looking at  
16 Graham? I'm sorry.

17 DR. WALLIS: It says "fuel uncovering is not  
18 credible." I'm just saying to a scientist, everything  
19 is credible. It's just a question --

20 CHAIRMAN CORRADINI: We're engineers,  
21 though.

22 DR. WALLIS: --of how likely it is, and even  
23 to engineers. I can conceive of it and it's  
24 believable, but I'm just -- it's very unlikely is what  
25 you mean, right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: Right.

2 DR. WALLIS: Then that calls the question of  
3 how unlikely it is.

4 MR. DEEVER: That's why they said credible.

5 DR. WALLIS: That's right, so you don't have  
6 to give a probability. There's no experience with it.

7 It hasn't happened before. Therefore, it's very  
8 unlikely to happen again. That's what you're saying.

9 MR. DEEVER: Well, I don't know many years  
10 of reactor operation we've had with this  
11 configuration, but we've never had an issue with it.

12 DR. WALLIS: That's right.

13 MR. DEEVER: And even if we had some leakage  
14 --

15 DR. WALLIS: Well, TMI was incredible until  
16 it happened.

17 MEMBER ARMIJO: You'd have to have a massive  
18 leak.

19 MR. DEEVER: Yes. I mean you'd have to be  
20 asleep while it happened.

21 DR. WALLIS: That's right.

22 MR. DEEVER: Yes. Okay, then moving onto  
23 the next RAI is 9.1 -155 SO-1. This dealt with the  
24 potential for gas accumulation in the FAPCS system,  
25 and you know, and the issues were water hammer, gas

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 binding in pumps and inadvertent leaks --

2 DR. WALLIS: Gas is what kind of gas?

3 MR. DEEVER: Well, that's part of the answer  
4 is that it's not reactor non-condensable gas, because  
5 it's not connected with the reactor system.

6 DR. WALLIS: So it's air or nitrogen or  
7 something?

8 MR. DEEVER: It would have to be that, and  
9 the most likely problem would be in servicing, where  
10 somehow you didn't fill the system, and you left a  
11 volume of air in the system, and then the system would  
12 start up.

13 DR. WALLIS: That has nothing to do with the  
14 accumulation of other gas from the reactor?

15 MR. DEEVER: No, no. We don't have that  
16 issue, and that was our response, is that it's a low  
17 pressure system. It doesn't come in, you know. It's  
18 not connected to the reactor system's primary coolant  
19 boundary, and therefore it has no ability to, you  
20 know, to collect these non-condensibles.

21 Then our second bullet is associated with  
22 the line slope of vents and drains and such, that with  
23 adequate piping of the system, then we minimize the  
24 gas accumulation. And then with maintenance  
25 procedures, then we take care of any of the --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: These vents are automatic?  
2 They automatically vent, or do they set off an alarm?

3 MR. DEEVER: No. These are all manual  
4 vents.

5 DR. WALLIS: So someone has to come and open  
6 them up?

7 MR. DEEVER: Right. I mean they're just for  
8 servicing purposes.

9 DR. WALLIS: But there is an alarm, isn't  
10 there, on the vent? I think there is an alarm on most  
11 vents like that.

12 MR. DEEVER: I don't think so. These are  
13 just manual valves.

14 DR. WALLIS: They are? You just have to  
15 remember to go and check them or something?

16 MR. DEEVER: Well, that's all part of the  
17 maintenance procedures. You've got to be able to  
18 validate the valve positions after you, you know, and  
19 the fact that the system's been vented.

20 MEMBER ARMIJO: So we've --

21 (Simultaneous discussion.)

22 DR. WALLIS: --talking about the GDCS line  
23 and stuff. There were vents there which were actually  
24 alarmed. Maybe I'm wrong.

25 MR. MARQUINO: Well, we haven't determined

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 exactly what alarms are going to be set by what  
2 conditions. That's part of our HFE commitment. We  
3 have a lot of instrumentation and indications in the  
4 plant. But in terms of what is important enough to  
5 alert the operator, that hasn't been finalized.

6 DR. WALLIS: When you are really concerned  
7 about gas, you have an alarm on the vent.

8 MR. DEEVER: Yes. The GDCS is, yes, a  
9 different situation. But with air, we mainly -- we  
10 have ITAACs now that go in and establish that the  
11 proper slopes have been established, and that's not  
12 going to change after you've built the plant. So the  
13 ITAAC should take care of any future operating  
14 conditions.

15 So at any rate, we don't think we have a gas  
16 accumulation issue. Okay.

17 MEMBER STETKAR: Before you go to RTNSS,  
18 this is a bit off the wall, but that's what your tax  
19 dollars pay me to do.

20 (Laughter.)

21 MR. DEEVER: And we appreciate it.

22 MEMBER STETKAR: And at the moment, they're  
23 not paying me to be anything, but that's a different  
24 issue. I was looking at the FAPCS system, thinking  
25 about some other things. The reason I asked things

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 about drainage of water earlier is the nice little  
2 drawing, t he one -line drawings of the fuel and  
3 auxiliary pool cooling system in the DCD, I think it's  
4 Figure 9.1-1, is not an elevational drawing.

5 The tops of the spent fuel pool floor is at  
6 great elevation, as I think you said earlier.

7 MR. DEEVER: Yes, uh-huh.

8 MEMBER STETKAR: That's the bottom of the  
9 suppression pool is at great elevation; is that right?

10 MR. DEEVER: Yes. I think that's not  
11 correct also.

12 MEMBER STETKAR: The bottoms of the GDCS  
13 pools are substantially higher than that.

14 MEMBER STETKAR: Now during normal  
15 operation, according to the system description, one  
16 train of the fuel and auxiliary pool cooling system is  
17 normally a line for cooling the, not surprisingly  
18 enough, fuel, spent fuel pool.

19 MR. DEEVER: Right.

20 MEMBER STETKAR: It says that the other  
21 train can be aligned as necessary for cooling or  
22 clean-up of the suppression or, if necessary, the GDCS  
23 pools. You can align it anywhere. If I look at the  
24 system design, and if I have the system operating with  
25 one train circulating the spent fuel pool, and I line

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 up the other train to the -- some of the other pools  
2 at a higher elevation, if I have one valving error, I  
3 can drain the suppression pool or the GDCS pool into  
4 the fuel pools, overflow the spent fuel pools, and  
5 where does the water go?

6 How fast can I do that? There's no check  
7 valve that I can find in the suction line that  
8 prevents reverse flow. So I just have a basic gravity  
9 drain through the system.

10 MR. DEEVER: But we have cross-tie valves  
11 that don't allow you to switch from one system to the  
12 other.

13 MEMBER STETKAR: Yes. I said with one valve  
14 error. I can drain -- so the question is, and if I do  
15 that, because the fuel and auxiliary cooling pumps are  
16 at the bottom elevation of the fuel building, if the  
17 fuel pools can overflow and flow down into the bottom  
18 of the building with a reasonable flow rate, they get  
19 flooded and I've lost my system, which has  
20 implications for RTNSS and, you know, also building  
21 flooding and all of that kind of stuff.

22 So I was curious. I do need either a valve  
23 failure or an operator error to do this to me?

24 MR. DEEVER: Yes.

25 MEMBER STETKAR: But I was just curious how

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fast it can happen and how far can I drain down? I'm  
2 a little bit concerned about if it does happen, how  
3 far can I drain down either the GDCS pool, if it's  
4 aligned that way, or the suppression pool, if it's  
5 aligned that way.

6 I don't know where the -- I have no, you  
7 know, isometric drawings that show where the suction  
8 lines come off those pools.

9 MR. DEEVER: Yes. I'm not sure that that's  
10 a --

11 MEMBER STETKAR: I thought there might be a  
12 check valve in the suction line that prevented that  
13 reverse flow back up into the fuel pools. But I  
14 couldn't find one.

15 MR. DEEVER: Yes. I'm not sure that that's  
16 possible when you're switching off between systems.  
17 What might be a correct check valve in one direction  
18 may not be good when you're --

19 MEMBER STETKAR: Well now you'd always want  
20 to take suction from that line.

21 MR. DEEVER: Okay.

22 MEMBER STETKAR: You know, it's the drain  
23 line out of the, whatever you call them, the skimmer  
24 overflow pool or something like that.

25 MR. DEEVER: Right, surge tanks.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: There's a -- yes. There's  
2 a drain line that goes down to the suction of the  
3 cooling pumps. You'd never want to pump water back up  
4 that line for any reason.

5 MR. BEARD: Alan Beard with GEH. At least  
6 one point that I'd like to make is that the system  
7 that we use for cooling and purifying the GDCS pools  
8 is its own dedicated system. It is part of FAPCS that  
9 it doesn't share IC stuff that --

10 MEMBER STETKAR: IC-PCC pools, according to  
11 the DCD, is its own separate system. I have a separate  
12 question about that one. That's the only single --

13 MR. BEARD: Your concern, yes.

14 MEMBER STETKAR: GDCS pool and --

15 MR. BEARD: Yes.

16 MR. DEEVER: Right. The IC system, we  
17 wanted to keep it clean.

18 MEMBER STETKAR: I'm going to ask you about  
19 that when we get to RTNSS. But I was just curious  
20 about it. I don't know the line sizes. I don't know  
21 the drainage rates.

22 MR. BEARD: What you're worried about is  
23 GDCS draining back through?

24 MEMBER STETKAR: I'm worried about a couple  
25 of things. I'm worried about either GDCS or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 suppression pool draining back through overflow. You  
2 know, what would happen is the spent fuel pools would  
3 just fill up and overflow.

4 CHAIRMAN CORRADINI: So I'm not sure. I  
5 understand the GDCS. I'm not understanding that one.  
6 That's the one I didn't understand, because I thought  
7 they were at the bottom. Both were the same.

8 MEMBER STETKAR: The bottom, I'll use the  
9 graphic. The bottom of the GDCS pool is here; the  
10 bottom of the suppression pool is here. The top of  
11 the fuel pools is here.

12 CHAIRMAN CORRADINI: Oh, I thought the  
13 bottom of the fuel pool was there.

14 MEMBER STETKAR: No, no.

15 CHAIRMAN CORRADINI: So what he said is  
16 correct?

17 (Simultaneous discussion.)

18 MEMBER STETKAR: I can gravity drain with  
19 one valving error. I can gravity drain water from  
20 here. But I don't know where the suction lines take  
21 off. I'm assuming they're close to the bottom,  
22 because I'd like them to be there. But I don't know  
23 that to be true.

24 CHAIRMAN CORRADINI: Right, okay. Now I get  
25 it. Thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: And it's a question of  
2 draining that volume, because that's water that I'd  
3 like to have for other purposes, and where does the  
4 overflow from the fuel pool go, because my fuel and  
5 auxiliary pool cooling system equipment that I'd like  
6 to have for other purposes is down in the basement.

7 I mean this is a large line. I mean I know  
8 you have floor drains and things, but --

9 MR. DEAVER: Well no, but what --

10 MEMBER STETKAR: A two-inch floor drain  
11 might not handle a ten-inch line.

12 MR. DEAVER: No, but what should happen is  
13 that any excess flow should go over the weir, and go  
14 into the surge tank. So --

15 MEMBER STETKAR: I'm coming up that way,  
16 though. That's the water -- the water is flowing out  
17 of the surge tank up. That's my water. That's my  
18 inlet. That's my source. It's coming back through  
19 the suction of the pumps.

20 I mean if you can think of, you know, the  
21 cartoon, up that line, flooding back into the skimmer  
22 lines and out over the tops of the pools. It's, you  
23 know, if you had a make-up on your swimming pool and  
24 left it on overnight, it would be what was flooding  
25 your swimming pool for you, from the suction of your

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pumps.

2 MR. DEEVER: Yes. I don't think we have an  
3 immediate answer for you on that topic, unless --

4 MEMBER STETKAR: Okay. But I mean the two  
5 concerns is how fast, you know, how fast can I drain  
6 those, the safety-related pools if you will, the GDCS  
7 pool or the suppression pool, because I don't know the  
8 line size basically.

9 CHAIRMAN CORRADINI: But you know that.  
10 What is the pipe diameter for the FAPCS?

11 MR. DEEVER: They vary throughout the  
12 system.

13 MEMBER STETKAR: They vary and I haven't  
14 found conclusive numbers, so I'm not quite sure. I  
15 think they're fairly large lines, but I'd like to know  
16 what they are.

17 And then the question is, the reason I asked  
18 earlier when we were talking about the steaming, is if  
19 we do overflow the fuel pools through, you know,  
20 flooding up over the tops of the skimmer line, where  
21 does that water go? Does it just flood over and down  
22 into the bottom of the, you know, the basement of the  
23 fuel building, in which case you'd flood out --

24 MEMBER ARMIJO: Your pumps.

25 MEMBER STETKAR: Your pumps. It's not a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 design basis, I will fully admit that.

2 MEMBER ARMIJO: It would be nice to know.

3 MEMBER STETKAR: But it's -- if I can do it  
4 with one valving error, I might be able to do it some  
5 time. Or there might be a check valve in that suction  
6 line from the skimmer, whatever you call them, the  
7 surge tanks or something like that. It just doesn't  
8 show up on the single one line.

9 MR. DEAVER: We have a relatively new system  
10 engineer working on that system.

11 DR. WALLIS: Can you trace the line --

12 MEMBER STETKAR: You might want to, you  
13 know, check back with him. I'm glad we talked about  
14 this today, because we still have tomorrow.

15 DR. WALLIS: Can you trace the line for us  
16 on Figure 36 or something, is that too hard?

17 MEMBER ARMIJO: Your backup slides.

18 MEMBER STETKAR: Oh, the backup slides? Oh.  
19 I didn't --

20 (Simultaneous discussion.)

21 MEMBER STETKAR: Yes, okay.

22 MEMBER ARMIJO: You have cooling mode and  
23 all sort of the --

24 MEMBER STETKAR: Go to that. I didn't  
25 realize there was --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: The elevations are wrong, but  
2 the lines are right.

3 MEMBER STETKAR: The elevations are wrong.  
4 I mean the problem is this is similar to the figure in  
5 the DCD. You're led to believe that the fuel pools  
6 are higher in elevation than the GDCS, which isn't  
7 true. It's actually reversed. But the flow path  
8 would be just line up the suction line from the GDCS  
9 pool or the suppression pool, coming out of this --  
10 there's two check valves. There. You have your  
11 little hand there, through those two little checks,  
12 yes, however that is.

13 Through those two little check valves, out  
14 to the suction of the pump, and then just because you  
15 can line, align either pump train to either flow path,  
16 I need to have one of those normally closed suction  
17 valves misaligned.

18 Such that I line up the suppression pool,  
19 let's call it suction flow, back through that common  
20 suction header now, because they're cross-tied, up  
21 through what's highlighted on this figure, the green  
22 line, back up -- you see there's no check valve in  
23 that line. Back up overflowing the skimmer surge  
24 tanks to the skimmer lines, and out into my building.

25 DR. WALLIS: But aren't the check valves

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that you just showed us that are in between the  
2 reactor building and the containment?

3 MEMBER STETKAR: They are. They're designed  
4 to work the way I want the water to go.

5 DR. WALLIS: Oh, so they don't help you at  
6 all? They work --

7 MEMBER STETKAR: They help me. They don't  
8 help this problem. I mean those check valves you want  
9 to work that way, because it's -- when I thought about  
10 it, if there were a similar check valve in that green  
11 suction line, such that it would allow water to flow  
12 from the skimmer surge tank to the suction of the fuel  
13 and auxiliary pool cooling system, and not allow  
14 reverse flow back up into the skimmer surge tank, I  
15 wouldn't worry about this.

16 CHAIRMAN CORRADINI: So you're saying,  
17 you're saying the -- you're saying the green line  
18 coming out of the skimmer surge tank should have a  
19 check valve, as does the suppression pool does?

20 MEMBER STETKAR: Exactly.

21 CHAIRMAN CORRADINI: I've got it.

22 MEMBER STETKAR: The suppression pool line,  
23 any way you can line up the system to something inside  
24 the containment, as a check valve to prevent reverse  
25 flow in that direction.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. GELS: This is John Gels in Wilmington.  
2 I kind of -- I have access to more detailed diagrams  
3 for the system, and I can confirm that there actually  
4 are check valves on the exit of the surge tank.

5 MEMBER STETKAR: Ahh.

6 MR. GELS: Yes. But additionally, the  
7 suction lines from the suppression pool, those lines  
8 have valves that are safety -related and normally  
9 closed. They only open when we're in the suppression  
10 cooling mode, and they will close again if the pumps  
11 trip.

12 MEMBER STETKAR: But in this case, the pumps  
13 wouldn't trip. I don't know if you were listening to  
14 the whole thing. I walked you into this during normal  
15 operation.

16 We're not talking about accident conditions  
17 or anything. Normal operation, when for some reason,  
18 you need to align one of the trains of FAPCS to either  
19 cool or clean up or whatever the suppression pool or  
20 the GDCS pools.

21 So it's not an accident condition or  
22 anything. It's just a normal operational alignment of  
23 that system, which can in fact be simultaneously  
24 operated in parallel, provided the valves are aligned  
25 correctly.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 But the answer is, though, you confirmed  
2 that there are indeed check valves in the suction line  
3 from the skimmer surge tanks?

4 MR. GELS: That is correct.

5 MR. DEEVER: Yes. This is a simplified  
6 diagram.

7 MEMBER STETKAR: Thank you. That answers my  
8 whole question.

9 MR. DEEVER: Okay.

10 MEMBER STETKAR: Thank you very much.

11 MR. DEEVER: Thanks, John.

12 DR. WALLIS: So we learned once again th at  
13 the devil's in the details. If the details aren't  
14 shown, you don't know them.

15 MEMBER STETKAR: No.

16 MEMBER ARMIJO: That's always the case.

17 MEMBER STETKAR: Thank you.

18 MR. DEEVER: I think that finishes my part.

19 I'll turn it over to Mike to go into RTNSS.

20 MR. ARCARO: Mike Arcaro. I'm the principle  
21 engineer for the balance of plant side of ESBWR. What  
22 I wanted to do today is just go through some of the  
23 auxiliary systems, and key on the RTNSS functions, and  
24 then also talk about some of the other design features  
25 associated with plant investment protection.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           The auxiliary systems support RTNSS  
2 functions. We had an RAI that talked about providing  
3 a description of those functions in Tier 1. So we did  
4 that. So in the DCD, you'll find Tier 2 descriptions  
5 of all the RTNSS functions, and corresponding Tier 1  
6 ITAAC associated with those functions. Okay, next  
7 slide.

8           Going through, this table came out of 19  
9 Alpha of the DCD, and it's got an overview of the  
10 RTNSS functions. I broke it down into just the BOP  
11 systems associated with RTNSS. So we'll go through,  
12 you know, the first couple of items there have to do  
13 with the fire protection system. Fire protection  
14 system for ESBWR is supporting the RTNSS-Bravo  
15 function, which is a safety function after 72 hours.

16           This is part of the fire protection system  
17 that's providing water to the ICPCS pools post -72  
18 hours for make-up. The piping going to the, from the  
19 CAT-1 fire protection tanks to the connections at the  
20 reactor building are CAT-1 piping in a CAT-1 trench.

21           This part of the system is completely  
22 separate from the FAPCS pool cooling system. So it's  
23 a separate.

24           MEMBER STETKAR: Quick, before you get into  
25 it. I really appreciate this presentation, by the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 way. Just to make sure I'm oriented right, anything  
2 that's RTNSS-B is in a seismic Category 2 building; is  
3 that correct?

4 MR. ARCARO: CAT-2 or better.

5 MEMBER STETKAR: Yes, CAT -2 or better. But  
6 C is non-seismic, right?

7 MR. ARCARO: C would be --

8 MEMBER STETKAR: Unless it's for other  
9 reasons in a CAT-1 or CAT-2.

10 MR. ARCARO: That's true.

11 MEMBER STETKAR: Okay.

12 MR. ARCARO: And then 19 -- there's also a  
13 table that tells you the housing for RTNSS.

14 MEMBER STETKAR: But I mean the general  
15 principle is if it's written as B, it's got to be CAT-  
16 2 or better. If it's written as C, there's no --

17 MEMBER ARMIJO: No requirement.

18 MEMBER STETKAR: There's no requirement,  
19 strictly from a RTNSS perspective.

20 MR. ARCARO: Right, that's correct.

21 MEMBER STETKAR: Okay.

22 MR. ARCARO: So the fire protection system  
23 components that we're talking about are in the fire  
24 pumping closure area, which is a CAT -1 structure. So  
25 along with the tanks, these pumps are in a CAT-1

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 structure.

2 The next function there is FAPCS. We've  
3 talked about that , fuel pool cooling. On the RTNSS  
4 side is supporting low pressure, coolant injection and  
5 spent suppression for cooling. So this RTNSS function  
6 is to support, shut down cooling, RWCU operations.

7 So if for whatever reason you don't have  
8 that, this RTNSS will get you up to the NRC goals by  
9 using this active system.

10 MEMBER STETKAR: May I ask you, we had a  
11 good lead-in earlier. There's another train that's  
12 generically associated with the FAPCS system, but it's  
13 actually a separate little cooling lops that's got its  
14 own pump and -- pumps and pipes and valves and heat  
15 exchanger, and I guess filters.

16 MR. ARCARO: Filters too.

17 MEMBER STETKAR: I don't remember where  
18 there are filters in it, but that can be aligned to  
19 cool the PCCS, the ICPCS pools. What assumptions are  
20 made as far as temperatures of the water in those  
21 pools, and doesn't matter?

22 In another words, is that system required to  
23 operable, not a legal text spec sense, but do you need  
24 that system to actually keep those pools cool during  
25 normal operation, to satisfy any design basis accident

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 assumptions on temperature of the water in pools, and  
2 in particularly obviously I'm interested in --

3 MEMBER ARMIJO: ICPCCS.

4 MEMBER STETKAR: --the ICPC, the PCC  
5 function.

6 MR. DEEVER: I don't know the answer. I  
7 think it's more of a functional thing. You don't want  
8 water boiling off and having to make up water all the  
9 time. You'd like to keep it cool enough so that you  
10 don't get that heavy evaporation, is my first guess.

11 MEMBER STETKAR: Well, but I mean your  
12 accident analyses must start with some assumed pool  
13 water temperature, right?

14 MR. DEEVER: Yes.

15 MEMBER STETKAR: And I guess my question is,  
16 is that system relied on to maintain that water at  
17 that temperature?

18 MR. DEEVER: Yes.

19 MEMBER STETKAR: So why isn't that system a  
20 RTNSS system, or that train or this train?

21 MR. MARQUINO: Because if it didn't work, it  
22 would be -- if it didn't work, it would depend on  
23 other conditions in the plant, in terms of whether you  
24 got to the tech spec LCO, and then if you got to the  
25 tech spec LCO, you'd be taking the action through

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 required actions.

2 MEMBER STETKAR: Is there a tech spec LCO on  
3 pool temperature?

4 MR. MARQUINO: Yes.

5 MEMBER STETKAR: Is there? Okay, I don't  
6 remember.

7 MR. MARQUINO: I'll check on that.

8 MEMBER STETKAR: Check that. I honestly  
9 don't remember. I mean I didn't try to dog it that  
10 far. I was just trying to think about what function  
11 this, that other little train provided, and whether or  
12 not it should be -- it certainly shouldn't be safety-  
13 related, but at least RTNSS is a support function.

14 MR. DEAVER: John Gels, do you have any  
15 comment on that?

16 MR. GELS: I'm sorry. Can you please repeat  
17 the question?

18 MR. MARQUINO: Is there a tech spec limiting  
19 condition for o peration on the PCC -IC pool  
20 temperature?

21 MEMBER STETKAR: Temperature.

22 MR. GELS: I don't know if that is an LCO,  
23 but I can check on that.

24 MR. MARQUINO: Would you please, so we can  
25 get an answer?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. GELS: Yes.

2 MS. CUBBAGE: PCCIC, not spent fuel.

3 CHAIRMAN CORRADINI: I'm sorry Amy.

4 MEMBER STETKAR: No, this is PC -- this is  
5 ICPCC.

6 MEMBER ARMIJO: Pools.

7 MEMBER STETKAR: Pools. This other little  
8 train only cools those pools. Okay, thanks.

9 MR. ARCARO: So we'll find out about that.  
10 Let's see, going through the rest of the items on this  
11 list, we talked about the fire protection water tanks,  
12 their function. Also, all the support systems that  
13 provide support, fire protection system for this  
14 RTNSS-B Bravo function are in there.

15 So the ventilation system, the diesel supply  
16 to the fuel for the diesel fire pump, those are all  
17 part of the support for that.

18 MEMBER STETKAR: Mike, in the description of  
19 the fire protection system, it talks about -- there's  
20 two, I think they're called primary fire water pumps,  
21 and two, I don't remember whether they're called  
22 secondary or two other pumps. Those other pumps and  
23 the piping aren't shown on any of the drawings in the  
24 DCD.

25 Do they tie into the primary part of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fire protection system that's shown on the DCD, or if  
2 they do, where? And how are they protected? I'm  
3 thinking about seismic failures. How are piping  
4 breaks in that obviously non-seismically qualified  
5 part of the system protected from diverting flow from  
6 this function?

7 MR. ARCARO: O kay. So this function here  
8 has its own dedicated line coming from the primary  
9 fire water storage tanks to the reactor building, to  
10 the manual valves for filling these pools. The  
11 secondary loop of fire protection is provided by the  
12 site.

13 So in the 951 of the DCD, you'll see COLA  
14 items that talk about in addition to the primary  
15 system, you have to provide a secondary system. It's  
16 550,000 gallons of fire water for the secondary loop,  
17 and that's in order to support design basis fires for  
18 the turbine building and for other buildings  
19 throughout the plant.

20 MEMBER STETKAR: And is there a requirement  
21 somewhere specified that that will normally remain  
22 isolated from this primary side, or do you simply take  
23 credit because this is a 72-hour event? I'm thinking  
24 about, you know, a seismic event, where you can break  
25 the non-seismically qualified section of piping that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 may or may not be normally connected to the primary  
2 side.

3 MR. ARCARO: Right, right.

4 MEMBER STETKAR: And can you drain your  
5 primary water stored, you know, your tanks during that  
6 interim period, 72-hour period before you need it?

7 MR. ARCARO: Right, right. If you look at  
8 Figure 951 of the DCD, it will show you the primary  
9 loop and then the secondary loop is from yard piping.  
10 And going into the nuclear island, there's check  
11 valves. So the system is designed so that you can  
12 feed from the secondary side for a fire, but not, you  
13 know, invalidate the primary loop, water provided.

14 MEMBER STETKAR: Yes, got it, got it. Thank  
15 you.

16 MR. ARCARO: Okay. I guess the other thing  
17 on this slide is the oversight and, you know, how we  
18 verify functionality of the system. So for these, all  
19 these functions here in the availability control  
20 manual, there's actual LCOs that we do to verify that  
21 the system can operate the support the function.

22 MEMBER STETKAR: LCOs in your, not tech spec  
23 LCOs?

24 MR. ARCARO: Correct, correct.

25 MEMBER STETKAR: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ARCARO: Availability LCOs.

2 MEMBER STETKAR: ALCOs, ACLCOs.

3 MR. ARCARO: So next slide, we're talking  
4 about the support systems again, ancillary diesel  
5 generators, standby diesel generators. Ancillary is  
6 supporting the Bravo function. So it's safety system  
7 functions post -72 hours. This is in a CAT -2  
8 structure.

9 This, the loads are shown in Chapter 8 of  
10 the DCD, but it's supporting the fire pump, the motor-  
11 driven fire pump, PCCS fans, control room  
12 habitability, recirc air handling units and the  
13 cooling unit. Also emergency lighting and Q -DCIS for  
14 post-accident monitoring.

15 Standby diesel generators. These are the  
16 large diesel generators that are supported by service  
17 water, RCCW. These are 15 megawatt generators. The  
18 ancillary diesel generator is a 850 to 1,700 kW  
19 diesel. So a difference in size there.

20 Standby diesel generators also have  
21 availability LCOs to ensure operation. Here we see  
22 for the ancillary diesel, the HVAC is supporting the  
23 functions, so it's also listed as a RTNSS system.  
24 Standby diesel generators are supported by the  
25 electric building HVAC. So that's also supported.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 For the systems that are normally operating,  
2 where the availability controls the maintenance role  
3 rather than availability of controls LCO.

4 MEMBER STETKAR: The standby diesels are in  
5 the electrical building?

6 MR. ARCARO: That's correct. Yes, they have  
7 separate bays in the electric building.

8 MEMBER STETKAR: Is the electrical building  
9 a non-seismic structure? I don't remember.

10 MR. ARCARO: I believe it's a CAT-2.

11 MEMBER STETKAR: Is it a CAT-2?

12 MR. ARCARO: A CAT-2 structure.

13 MEMBER STETKAR: I remember your seismic.  
14 You don't need to consider soil liquefaction under  
15 CAT-2 buildings though, right, for your seismic  
16 qualifications?

17 MR. MARQUINO: We lost our single structural  
18 representation.

19 MEMBER STETKAR: Again, thinking of  
20 earthquakes, if I have a liquefaction problem, I think  
21 there's a COL item that they have to address  
22 liquefaction under CAT-2 buildings.

23 CHAIRMAN CORRADINI: That's a COL item?

24 MEMBER STETKAR: I think so, if I recall.

25 CHAIRMAN CORRADINI: Can we save that for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the staff?

2 MEMBER STETKAR: I need to go back and look  
3 at my -- yes.

4 CHAIRMAN CORRADINI: Let's save it for the  
5 staff.

6 MEMBER STETKAR: You may want to look that  
7 up. I have to go back and look at my notes from  
8 another chapter, but I think that's true.

9 MR. ARCARO: Okay, next page. Okay. CAT or  
10 RTNSS-Charlie functions here. So now we're providing  
11 functions supporting the diesel generators, the RCCW,  
12 the cooling, that's supporting the FAPCS RTNSS-Charlie  
13 functions for suppression for cooling and low pressure  
14 injection.

15 So reactor building has functions to cool N-  
16 DCIS for a FAPCS system. Turbine building has  
17 cooling, local cooling for the FAPCS that in the  
18 turbine building, you have the RCCW pumps. RTNSS -  
19 Bravo control room habitability air handling units.  
20 So for control room habitability, RTNSS-Bravo function  
21 that is supported by the recirc air handling units and  
22 the auxiliary cooling units.

23 Then also that air handling unit and  
24 auxiliary cooler supports the post-accident monitoring  
25 heat loads in the Q-DCIS. Next slide.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Reactor component cooling water,       like we  
2       said, supports standby diesel generators, which  
3       supports the FAPCS RTNSS     -Charlie. Also, nuclear  
4       island chill water subsystem is RTNSS, and       that's  
5       supporting the building, the ventilation systems.

6           Service water is supporting the       RCCW for  
7       RTNSS, and it's also providing cooling for the turbine  
8       building component cooling water heat    loads that are  
9       plant investment protection, but not RTNSS systems.

10          Okay, so going through the       RTNSS cooling  
11       systems, the NRC conducted an audit of the cooling  
12       systems, specifically wanting to look at the,       you  
13       know, the aspects of --

14          MEMBER STETKAR: Before you get into the  
15       RAIs, because you're going to go     off, you know, on  
16       those focused things. I think I as    ked this before,  
17       and I don't recall the answer, and I couldn't find it  
18       anywhere. But why didn't the main condensate feed  
19       water systems show up as at least     a RTNSS-C-type  
20       system, you know, from the PRA perspective?

21          MR. ARCARO: I think Chapter 19 talks about  
22       that a little bit.

23          MEMBER STETKAR: Does it? Okay.

24          MR. ARCARO: From that I understand, you  
25       know, the reliability is such, you know, you have a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 triple redundant feed water system that pointed it  
2 out.

3 MEMBER STETKAR: It just didn't pop up above  
4 the screening criteria that you're using.

5 CHAIRMAN CORRADINI: I knew you were going  
6 to get to that. I was waiting.

7 MEMBER STETKAR: But those screening  
8 criteria are different than most other applicants are  
9 using. They're a factor of two to two and a half  
10 times higher, in terms of numerical importance, than  
11 essentially all the other applicants that are  
12 currently in play are using.

13 I mean we've sort of raised this general  
14 question before, but I --

15 MS. CUBBAGE: We really don't have anybody  
16 here that's --

17 MEMBER STETKAR: Yes. No, I understand  
18 that.

19 MS. CUBBAGE: That's not what we --

20 MEMBER STETKAR: I just wanted to make sure  
21 that it was -- they were screened out based on PRA  
22 considerations. You have no idea how close to the  
23 margin they were?

24 CHAIRMAN CORRADINI: We know we have to come  
25 back and discuss this.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: I just wanted to -- anyway,  
2 it's on the record.

3 CHAIRMAN CORRADINI: Got it.

4 MS. CUBBAGE: The condensate.

5 CHAIRMAN CORRADINI: The feed and condensate  
6 system?

7 MEMBER STETKAR: Yes, the condensate and  
8 feed water system primarily, and it's -- you know, the  
9 basic question is if it was screened out based on the  
10 numerical values from the PRA.

11 MS. CUBBAGE: From the perspective of  
12 reliability and availability, those are on all the  
13 time when the plant's operating. No? Yes? I'm not  
14 sure what would happen differently, to ensure  
15 availability for a system that's continually  
16 operating.

17 MEMBER STETKAR: The FAPCS system is also  
18 normally running. So I don't want to get into what's  
19 normally running and things like that. I'd be  
20 interested to see, you know, if it was screened out  
21 based on the numerical criteria, how close you were to  
22 that margin. I mean, you know, if you're a factor of  
23 five below it, I don't care.

24 MR. ARCARO: Okay. Yes, I know in the PRA  
25 it was broken up into sections for different systems.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So I think we can find those numbers.

2 MEMBER STETKAR: Okay, thanks.

3 MR. ARCARO: Okay. So RAI 9.2-24 was asking  
4 a question about RTNSS systems. These systems are  
5 relied upon to achieve cold shutdown, and are backing  
6 up passive systems. So the issue was we want to make  
7 sure that they're highly reliable and capable of  
8 achieving cold shutdowns.

9 So in that venue, we had an audit of the  
10 cooling water systems, and we spent some time with the  
11 NRC, and we went through the calculations and the  
12 design basis of the systems, and the few slides is  
13 follow up from that, from that audit.

14 Okay. The cooling water systems high level  
15 requirements, they perform non -safety functions with  
16 defense in -depth requirements. Since during normal  
17 operation, they're significant contributors to  
18 availability and plant investment protection by  
19 design.

20 They're highly reliable and provides  
21 features for plant investment and defense in -depth,  
22 including seismic ruggedness, redundancy, fire and  
23 missile protection and flood protection.

24 The RTNSS -Charlie functions provide post -72  
25 hour coolant, but cooling also have requirements

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 associated with redundant trains, separation, seismic  
2 requirements and missile and flood protection, okay.

3 The first system is service water. Just big  
4 picture, go through some of the features and the  
5 functions. The clouded area is conceptual design  
6 information. This is our heat removal facility. So  
7 the reference plant, we've got a mechanical cooling  
8 tower, mechanical draft cooling tower with a basin.

9 That basin is providing the heat removal  
10 capability for PRA for RTNSS functions, and that has  
11 an interface requirement and an ITAAC for water  
12 capacity. As you can see, the service water system is  
13 broken up into two trains.

14 So you've got two redundant 100 percent  
15 trains, two pumps on each train. You've got three  
16 rafter component cooling water, heat exchangers, two  
17 turbine component cooling water heat exchangers. Same  
18 heat exchanger. They're plate heat exchangers.

19 Also have a bypass line for cold weather  
20 operations or for providing flow while you're in  
21 minimal heat load operation. That's probably the main  
22 features of the system. It's designed as a one  
23 percent exceedance system, so the safety-related  
24 systems are zero percent exceedance. The service  
25 water is designed for one percent exceedance design

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 conditions.

2 Okay, next slide. Okay. Now we're looking  
3 at the reactor component cooling water system. Okay.

4 So again, you can see we've got redundancy, we've got  
5 separation. The pumps are powered from separate PIP  
6 buses, so there's both physical and electrical  
7 separation.

8 Normally run the system cross -connected,  
9 under a condition where you need to split the trains  
10 out. The cross -connect valves will shut. Heat  
11 exchangers, you've got three heat exchangers on each  
12 train. The heat exchangers are cooling the RCCW and  
13 then providing the water, the flow.

14 You can see the diesel generator, the  
15 standby diesel generator has its own loop. You also  
16 go into the turbine building loads for the NI  
17 chillers, and in the reactor building you're  
18 supporting loads for RWCU, shutdown cooling, sampling  
19 system, FAPCS heat exchangers we've talked about  
20 before, CRDM pump heat exchangers. So those are all  
21 in either the fuel building or the reactor building.

22 Normal operations, one pump, one heat  
23 exchanger per train. It's adjusted so that depending  
24 on the heat load, you can run multiple pumps, multiple  
25 heat exchangers. Okay, next slide.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Okay. Chill water system. Again, the  
2           redundancy and separation, you can see that. The top  
3           part of that drawing is the nuclear island chill  
4           water. The bottom part is the balance of plant chill  
5           water. So on the nuclear side, it's separated with  
6           manual valves for the balance of plant.

7           The balance of plant chill water system  
8           could be used to support the nuclear island heat  
9           removal functions, but normally it's not cross-  
10          connected and we don't credit it for any scenario.

11          Chillers, again they've got different PIP  
12          power. So electrical separation and mechanical  
13          separation. The train, redundancy is in the  
14          components. So you could see on the supplies, we're  
15          going to, you know, control building Alpha or Bravo  
16          trains, which supply ventilation systems for redundant  
17          trains also.

18          Okay. Some of the design features were  
19          service water, the design criteria a single train  
20          failure during cool down results in the highest heat  
21          load on the service water train, and that's 80.8  
22          megawatts. These are in Table 9.2 tables of the DCD.

23          To test that, during a refueling outage we  
24          could, during cool down, we could put, you know, that  
25          kind of load on a single train to do testing for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 heat exchangers. So one of the only things that we  
2 learned for service water is to provide  
3 instrumentation, and design the system so you could  
4 test it during refueling, shutdown cooling operations,  
5 to simulate the design loads.

6 Lots of margin going into the system  
7 designs. One of the points is while it's designed for  
8 one percent exceedance, we're making sure the system's  
9 capable of operating at zero percent exceedance. So  
10 one of the issues from customers was, you know, we  
11 want to make sure that there's not going to be any  
12 operational perturbations for a couple of days a year  
13 during the summer time, which has been an issue with  
14 patent systems.

15 So we have the capability of that margin in  
16 the components, to make sure we don't trip out  
17 chillers and effect the operation of the plant. We  
18 also have margin between the heat loads of the system  
19 and what the cooling towers can do.

20 So in the DCD, we provide a margin above the  
21 maximum design heat removal for the system, so that  
22 there's margin there and then, you know, the  
23 individual plant will provide additional margin on top  
24 of that.

25 Okay, next slide. The RCCW system, let's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 see. The most limiting condition here is loss of  
2 power with single train failure. We looked at that,  
3 and that's -- that operation still gives us the  
4 capacity to bring the plant to cold shutdown in 36  
5 hours.

6 MEMBER STETKAR: 36 hours is the time for  
7 that?

8 MR. ARCARO: That's correct.

9 MEMBER STETKAR: Thanks.

10 MR. ARCARO: Okay, the heat exchanger  
11 design. The limit of the heat exchanger is 59.8  
12 megawatts between two, so half of that, and one of the  
13 things we use in plate heat exchangers is we also have  
14 margin built in if we want to add additional plates.  
15 We can give ourselves a couple of degrees margin on  
16 the temperature. Again, designed for one percent  
17 exceedance, but can operate under zero percent  
18 exceedance conditions.

19 Okay, next slide. Nuclear island chill  
20 water system. Again, the criteria is 24 hours, either  
21 24 or 36 hour cool down conditions. The total heat  
22 load of the system is 19,110 kilowatts. The chillers  
23 are sized about 1320 tons per chiller, and again we're  
24 using common chillers between the balance of plant and  
25 the nuclear island site for standardization.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Two trains for the nuclear island,  
2 redundancy, separation. If you lose power for one  
3 train, the other side will pick up the loads. Again,  
4 significant margins both on the chill water side for  
5 design, and on the ventilation side. We use the  
6 ASHRAE design margins for air flow and for heat load.

7 Okay, next slide. Any questions on coolant  
8 systems? I went through that pretty fast. Okay.

9 All right. Instrumental and service error.

10 There were some issues about the ability of the  
11 system to support the loads, and you know, the impacts  
12 of operating experience on contamination of water, of  
13 effects of degradation in the air systems.

14 So some of the points that we have for ESBWR  
15 is one, the air system is designed for a three micron  
16 particulate rating, right. It's, you've got service  
17 air compressors that are oil-free, so oil's not going  
18 to be an issue with our air. Stainless steel  
19 components and piping, a three micron limit compared  
20 to the standard, which is a 40 micron limit.

21 Also, we have dew point requirements in the  
22 dryers, to maintain the dew point over minus 40  
23 degrees, to minimize corrosion due to water. Two 100  
24 percent trains. So if we lose half of the system, the  
25 other system can support the whole load. They are PIP

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 loads. They're coming off the standby diesel.

2 The receivers are sized to give you 10 to 15  
3 minutes of operation, based on past experience with  
4 plant tr ansience due to lost instrument air.

5 Instrument air and service air is not safety -related,  
6 and it's not RTNSS. So components that are required  
7 for operation, that are either air-operated or  
8 nitrogen-operated in the containment, have safety-  
9 related accumu lators or are fail safe. So -- go  
10 ahead.

11 MEMBER ARMIJO: I just had a question. Is  
12 this the same kind of system for these -- that you've  
13 used in the ABWRs, or is this upgraded from that?

14 MR. ARCARO: I'm pretty sure this is  
15 upgraded from ABWR.

16 MEMBER ARMIJO: That's my guess.

17 MR. ARCARO: Yes. We've gone through a  
18 couple of iterations of this. We started with three  
19 compressors; now we have four, four compressors, two -  
20 -

21 MEMBER STETKAR: You started with a  
22 completely different system design.

23 MR. ARCARO: Yes, right.

24 MEMBER ARMIJO: But I mean as far as the  
25 three micron particulate filters, you know. It seems

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 like a lot of improvements over what used to be the  
2 old systems.

3 MR. ARCARO: Right, and I think a lot of  
4 that is technology, too. You know, that now, you  
5 know, the compressors and the dryers and the filters  
6 are such that, you know, you can get those levels.

7 MEMBER STETKAR: Mike, were you going to  
8 talk about high pressure nitrogen?

9 MR. ARCARO: Probably not, because it's a  
10 safety-related system and you're focusing on RTNSS  
11 stuff here, or non-RTNSS in this case.

12 MEMBER STETKAR: I noticed in, I think it  
13 was DCD Rev. 6, fire revisions listed the MSIVs as a  
14 load, if I can call it that, from the high pressure  
15 nitrogen system, and DCD Rev. 6 and Rev. 7 has removed  
16 the MSIVs from that list.

17 Are they no longer, does the current design  
18 no longer have a pneumatic supply to those valves, or  
19 can you explain why they were removed?

20 MR. ARCARO: Yes, I'm not -- maybe Jerry can  
21 help me out, but they still show up in Table 9.38 of  
22 the DCD, with nitrogen demand requirements. So MSIVs,  
23 SRVs, ICS isolation valves are in the DCD.

24 MEMBER STETKAR: In Table 9.38. Huh.  
25 Because there was a list in Section 9.38 -1 that lists

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 supplies from the high pressure nitrogen system. It's  
2 kind of a bulleted list, or I don't remember whether  
3 it was a bullet or a paragraph, you know, and they  
4 weren't in there.

5 MR. ARCARO: I believe they're still loads  
6 on the high pressure nitrogen system.

7 MEMBER STETKAR: Okay, I'll find it.

8 MR. ARCARO: And I'm not sure why we got rid  
9 of those --.

10 MEMBER STETKAR: There were notable though,  
11 you know, in terms of things inside the containment.  
12 They were sort of notable in their absence. But  
13 they're in that table, so I'll find it. Thank you.

14 MR. ARCARO: I know we did, in Rev. 7 I  
15 think we went through this table and clarified some of  
16 the numbers. But this table --

17 MEMBER STETKAR: I didn't even bother  
18 looking at the table. We could, I don't know wheth er  
19 I looked at it or I missed it. Thanks.

20 MR. ARCARO: So that would be an example of  
21 a system that's got an accumulator that's sized to  
22 provide the safety function. Okay. There's the  
23 instrument air system. You could see four  
24 compressors. The interface between instrument air and  
25 service air is toward the dryer. You have 100 percent

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 redundancy on the dryer, so first you would take a  
2 dryer out. You could provide the functions, the  
3 cleaning/drying functions on the other train, and you  
4 know, this is a maintenance rule system. So it still  
5 has, you know, the requirements for maintaining the  
6 system function.

7 Okay in summary, we went through the decay  
8 heat calculations and analysis for total decay power  
9 curves, talked about the OE experience for ESBWR  
10 related to spent fuel uncovering gas accumulation for  
11 FAPCS system; talked through RTNSS functions for the  
12 balance of plan auxiliary systems; describe the  
13 overview for service water, RCCW and the nuclear  
14 island chill water system; and talked through some of  
15 the design details associated with the instrument air  
16 and service air system for ESBWR.

17 CHAIRMAN CORRADINI: Questions for Mike?

18 MEMBER ARMIJO: I don't know if it's a  
19 question for Mike or for Jerry, but in your backups,  
20 you must be careful never to include backups.

21 CHAIRMAN CORRADINI: A lot of information  
22 that you know.

23 (Laughter.)

24 MEMBER ARMIJO: But you didn't talk about  
25 it, so I'm going to ask you about Slide No. 34.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 That's my -- you probably heard from me before on  
2 hydrogen water chemistry. So I'm going to go over it  
3 now.

4 CHAIRMAN CORRADINI: Oh, Sam, Sam, Sam.

5 MEMBER ARMIJO: You included this in the  
6 package for some reason. What was it a backup to?

7 CHAIRMAN CORRADINI: This is Mike's backup.

8 MR. ARCARO: Yes this is --

9 (Laughter.)

10 MEMBER ARMIJO: Big mistake. It was to back  
11 up some other point, I guess, or some other chart, and  
12 I just wanted to see, you know.

13 MR. ARCARO: Yes. No, I know this was an  
14 issue. I was reading through the transcript. So I  
15 just wanted to have a talking paper here.

16 MEMBER ARMIJO: Okay. Well you know, I  
17 think the issue there is you've already made a  
18 decision of what you were going to include in the DCD  
19 and the certified design and the staff agreed with  
20 you. But I think there are some points here that are  
21 -- you do recommend that people use hydrogen water  
22 chemistry. That's -- the bulk of the BWRs around the  
23 world, with a few exceptions, are using hydrogen water  
24 chemistry, and GE recommends it.

25 It seems like a lukewarm recommendation. In

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 your second bullet, you say if utility prefers to  
2 begin its operating life without this hydrogen or  
3 noble chem, the consequences for the foreseeable  
4 future are likely small. I think that's an  
5 overstatement. The stress corrosion cracking is a  
6 time-dependent thing, and the assumption you're making  
7 that it's not likely to occur for some period of time.

8 But nucleation really, nobody knows exactly  
9 when it starts, and so that -- I think that's an  
10 overstatement. I think there are consequences. And  
11 you're relying on better materials and better  
12 processing and fabrication. I don't disagree with  
13 that, because I know there are better materials, but  
14 they're not immune.

15 My best example is you cite the ABWR  
16 operation in Japan. It's been successful but not too  
17 much inspection. But there have been the best  
18 materials we know how to make, 316 nuclear grade  
19 components, that have failed by stress corrosion  
20 cracking in Japanese reactors that did not use  
21 hydrogen water chemistry, and that's a shroud.

22 And they, and that's really the best  
23 material we have for BWR applications. I know they  
24 didn't fabricate it the way I would have, but you  
25 know, it's the whole idea is to have a belt and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 suspenders approach, of better materials, better  
2 fabrication and the best water chemistry you can have.

3 So I'm still, I guess I'll use the word  
4 "disappointed" that GE just doesn't take a stronger  
5 position, or the staff doesn't take a stronger  
6 position, because I think this should be the reference  
7 water for the volume water reactor.

8 I don't think -- I think the old so -called  
9 pure water chemistry is -- it should be put on the  
10 shelf as a bad experience, and not rely just on better  
11 materials. Because I know there are better materials;  
12 I helped develop them, but they're not immune, and I  
13 know there's better ways to fabricate, but people  
14 don't always make things perfect, and you've got some  
15 very important components on a long life system that  
16 is not protected with the optimum water chemistry for  
17 the BWR.

18 So I'll just leave it at that, and but I'd  
19 ask you to downplay your chart here, this thing. I  
20 don't think the consequences are small, and I suspect  
21 there might be a few people at GE that feel the same  
22 way. But --

23 MR. DEAVER: No, we're committed to  
24 hydrogen.

25 MEMBER ARMIJO: Well, whatever the customer

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you've got, you've got to turn them around. Who wants  
2 to make a multi-billion dollar bet?

3 CHAIRMAN CORRADINI: We better have a break.

4 So with that, I think John has a question. But  
5 before I allow John to ask just the one little  
6 question, the staff found the LCO on the water pool  
7 temperature. Amy, can you just --

8 MS. CUBBAGE: 110, yes. It's Surveillance  
9 Requirement 3714, verify average water temperature  
10 available, in available ICPC pools is less or equal to  
11 110 degrees Fahrenheit every 24 hours.

12 MEMBER STETKAR: That's a surveillance  
13 requirement. Is there a LCO?

14 MS. CUBBAGE: For the LCO that it feeds into  
15 would be operability of the PCC-IC pools.

16 MEMBER STETKAR: Okay, and what was the  
17 reference Amy?

18 MS. CUBBAGE: It's tech spec surveillance  
19 requirement 3.7.1.4.

20 MEMBER STETKAR: 3.7.1.4.

21 MS. CUBBAGE: Yes.

22 MEMBER STETKAR: Thank you.

23 CHAIRMAN CORRADINI: John, you're up.

24 MS. CUBBAGE: Okay, wait.

25 MEMBER STETKAR: Wait, wait. Amy?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MS. CUBBAGE: Mark Ca ruso's here to be able  
2 to try to answer some additional questions you may  
3 have on RTNSS, and Samir Chakrabarti is either back or  
4 going to come back to help talk about liquefaction.  
5 There was a question on that. So if you'd like to  
6 repeat your question to Mark.

7 MEMBER STETKAR: Liquefaction cap B.

8 MS. CUBBAGE: No, the feed water.

9 MEMBER STETKAR: The feed water? Oh, the  
10 question was -- the way I led into it is why isn't  
11 feed water listed as a RTNSS -Category C system, you  
12 know, condensate feed water from the PRA perspective,  
13 and the response was well, it was screened out as  
14 being, you know, not risk-significant according to the  
15 criteria.

16 The observation is that the ESBWR screening  
17 criteria for risk significance, if I look at plessel  
18 vesseling (ph) importance as a factor of two higher  
19 than any of the other current applicants for design  
20 certification are using, and for risk achievement  
21 worth is a factor of 2-1/2 times higher, they're using  
22 plessel vesseling importance greater than .1, and risk  
23 achievement worth greater than five, whereas other  
24 current in play applicants are using plessel vesseling  
25 importance greater than .005, and risk achievement

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 worth greater than two.

2 So the question is, my question was well,  
3 what is the inventory of SSCs that were screened out  
4 because they, essentially they lie in the difference  
5 between those numerical screening criteria to this  
6 plant? In other words, if something was screened out  
7 because it had a plessel vesseling importance of .009,  
8 let's say.

9 MR. CARUSO: Yes.

10 MEMBER STETKAR: I don't know what inventory  
11 might be.

12 MR. CARUSO: Well, plessel vesseling in raw  
13 values were not, are not screening criteria for RTNSS.

14 There's the original --

15 MEMBER STETKAR: Okay, not for RTNSS, but --

16 MR. CARUSO: But I can address feed water  
17 specifically. The staff didn't agree. There's a  
18 statement, applicant made the statement that it wasn't  
19 risk-significant. If you look, feed water was  
20 considered in C under the, you know, if the non-safety  
21 system contributes to an initiating event, you need to  
22 look at three particular criteria. One, is it -- does  
23 failure of the event affect initiating event?

24 MEMBER STETKAR: But something like  
25 initiating events. Does it make you vulnerable to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 greater than some core damage criteria?

2 MR. CARUSO: Does that failure of those  
3 initiating events, does it contribute significantly to  
4 CVF and WRF (ph), and I think, you know, we -- this  
5 woman was on the line. It was on the line in the  
6 sense of the last criteria. But we felt that -- we  
7 looked at the arguments about why you really didn't  
8 need to have it in RTNSS, and in the end, in the end  
9 there's two, there's several arguments which are good  
10 ones, I think.

11 One is that we gave them credit for the  
12 fault-tolerant design of the feed water controller,  
13 you know. They're triple fault, you know, triple  
14 redundant, fault-tolerant. They're going -- they have  
15 a commitment to maintain a mean time of failure of  
16 2,000 hours, and we factored that into their -- they  
17 have a lower initiating event frequency because of  
18 that.

19 So the initiators that take out feed water,  
20 that are most important, are losses of power, and the  
21 losses of power are in RTNSS. The diesels are in  
22 RTNSS. So we gave them credit for that. In addition,  
23 we said well, what are you going to do? Are you going  
24 to put availability controls on it? Feed water is  
25 always running.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Plus, you know, one of the big drivers of  
2 the maintenance rule was all the balance of plant  
3 failures you would get from feed water that would give  
4 you transience. Feed water is in the maintenance rule  
5 program.

6 MEMBER STETKAR: It is.

7 MR. CARUSO: Which is a big part of what the  
8 treatment is for RTNSS. So when all is said and done,  
9 I think you have a fair statement about, you know, hey  
10 why is -- this is important to risk, you know. I mean  
11 losses of feed water. But I think in the end --

12 MEMBER STETKAR: On this -- okay. On this  
13 plant, you probably have hit on it already. I just  
14 want to make sure I understand. Is the RTNSS list,  
15 and there are rules for what is RTNSS and what is not  
16 RTNSS, and then there's a reliability assurance  
17 program, which has a different set of partially  
18 related but slightly different criteria.

19 The reliability assurance program is also  
20 non-safety related equipment, but you're required to  
21 basically invoke the maintenance rule on it.

22 MR. CARUSO: Yes.

23 MEMBER STETKAR: Is the feed water system,  
24 condensate feed water system on this plant in their,  
25 the D-RAP list, for example? Or do they have the D-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 RAP list yet? I don't know. Honestly, I get  
2 confused among the different designs, and I didn't  
3 have a chance to go back and check it.

4 MR. CARUSO: Well, yes. I would be -- I  
5 can't, I don't know off the top of my head, but I  
6 would be surprised if it's not. I mean it's scoped  
7 under the maintenance rule by the fact that it causes  
8 trips.

9 MEMBER STETKAR: Okay. So it's going to be  
10 controlled under that anyway.

11 MR. CARUSO: So you know, and you know,  
12 reliability assurance program really is basically --  
13 it's implemented with all the regular operational  
14 programs. It's connected with, you know, ISI and IST  
15 and maintenance rule and all these things, so --

16 MEMBER STETKAR: It's just those lists tend  
17 to be populated through the DCD and COL stages. So  
18 what's on that reliability assurance program list  
19 tends to get handed over.

20 MR. CARUSO: To me, you know, availability  
21 is covered by the fact that feed water, you've got to  
22 have feed water to run the plant, and (b),  
23 reliability, you know, to me it's the maintenance  
24 rule. That's what it's there for. That's the main  
25 driver. So I don't know. I mean I felt like feed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 water's covered.

2 And we had a lot -- we did have a lot of  
3 discussion and arguing about this, you know.  
4 Shouldn't it get just, you know, technically,  
5 shouldn't it get thr own in, you know, according to  
6 that last, third criteria about its significance.

7 MEMBER STETKAR: Okay, thanks. That's good.

8 CHAIRMAN CORRADINI: Did you have another  
9 question?

10 MEMBER STETKAR: I don't --

11 MS. CUBBAGE: I think Samir is here to  
12 discuss liquefaction.

13 MEMBER STETKAR: Yes. I mean, yeah. I mean  
14 as long as we're answering those questions. I still  
15 have a question for GEH, but not on these topics.

16 MS. CUBBAGE: So could you maybe restate the  
17 question? Samir wasn't here.

18 MEMBER STETKAR: Yes. It was my  
19 understanding, and unfortunately my notes are over in  
20 my office on the liquefaction stuff, but it was my  
21 understanding that liquefaction must be considered for  
22 Seismic Category 1 structures, but not for Seismic  
23 Category 2 structures. Is that true?

24 MR. CHAKRABARTI: No. What we have in DCD  
25 2, Table 2.0 -1, we have addressed liquefaction

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 potential on the Seismic Category 1 structures. It  
2 says "none." Under footprint of Seismic Category 1  
3 structures, it's something from the SSE.

4 MEMBER STETKAR: Right.

5 MR. CHAKRABARTI: And then it says "Other  
6 than Seismic Category 1 structures, see Note 14."

7 MEMBER STETKAR: Yes.

8 MR. CHAKRABARTI: And Note 14 says  
9 "Localized liquefaction potential and other than  
10 Seismic Category 1 structures is addressed by SRP 254  
11 in Table 2.0-2."

12 MEMBER STETKAR: But that's by the COL  
13 applicant, right?

14 MR. CHAKRABARTI: Well, liquefaction  
15 potential is a COL issue.

16 MEMBER STETKAR: So as far as the DCD is  
17 concerned --

18 MR. CHAKRABARTI: It assumes there is no  
19 liquefaction.

20 MEMBER STETKAR: Pardon?

21 MR. CHAKRABARTI: It assumes there is no  
22 liquefaction.

23 MEMBER STETKAR: It assumes there is none?

24 MR. CHAKRABARTI: Yes.

25 MEMBER STETKAR: But it doesn't require that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there is none. Under Seis mic Category 1 buildings,  
2 the DCD essentially requires that there's no  
3 liquefaction. Is that -- that's the way I interpreted  
4 that table.

5 MR. CHAKRABARTI: Yes. For Seismic Category  
6 1 structures, it assumes there is no liquefaction  
7 potential.

8 MEMBER S TETKAR: And effectively requires  
9 that the COL applicant must prove that there is no  
10 liquefaction under --

11 MR. CHAKRABARTI: Category 1 structures.

12 MEMBER STETKAR: Category 1 structures.

13 MR. CHAKRABARTI: And for Category 2  
14 structures, it states that the liquefaction potential  
15 is requirement is stated in Table 2.0-2. There it  
16 says "COL applicant to provide site -specific  
17 information in accordance with the SRP 254 to address  
18 localized liquefaction potential under other than  
19 Seismic Category 1 structures."

20 MEMBER ARMIJO: What does that mean?

21 MEMBER STETKAR: Well, that says the DCD  
22 allows liquefaction under Seismic Category 2  
23 structures; is that correct?

24 MR. CHAKRABARTI: I don't read it that way.  
25 What I read --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: I read it that way, so  
2 that's why I was asking the question.

3 MR. CHAKRABARTI: The COL applicant will  
4 address. It may not be the same standards, but will  
5 address the liquefaction potential, localized  
6 liquefaction potential other than Seismic Category 1  
7 structures.

8 MEMBER STETKAR: But I'm now going to try to  
9 become an attorney.

10 CHAIRMAN CORRADINI: Now?

11 MEMBER STETKAR: Yes. Just because the  
12 table in the DCD, if I'm now a COL applicant, to  
13 satisfy the DCD, I must prove that I have no  
14 liquefaction under Seismic Category 1 structures.

15 MR. CHAKRABARTI: That is very, very clear,  
16 yes.

17 MEMBER STETKAR: Okay. If I have a Seismic  
18 Category 2 structure, for example, my electrical  
19 building, I am not required to prove that I have no  
20 liquefaction. I am required --

21 MR. CHAKRABARTI: Address the issue.

22 MEMBER STETKAR: Address it.

23 MR. CHAKRABARTI: Yes.

24 MEMBER STETKAR: Which means I have to -- if  
25 I have liquefaction, I guess I need to do some

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analysis or something, right?

2 MR. CHAKRABARTI: I have not really read the  
3 requirements in SRP 254. It's a different section.  
4 But that's how I read it. Yes, it will be addressed.

5 MEMBER STETKAR: But essentially any -- I'm  
6 thinking about seismic events that now fail the  
7 electrical building, because it's a Category 2  
8 structure, because of -- it's not going to fail it  
9 structurally because it's a Seismic Category 2, except  
10 for possible localized liquefaction at the site.

11 Any Category 1 structures are essentially  
12 protected by that through the design certification,  
13 the specs and the design certification that says  
14 "There will not be any liquefaction under Category 1  
15 structures."

16 MR. CHAKRABARTI: That is correct.

17 MEMBER STETKAR: The design certification is  
18 essentially silent on liquefaction under any other  
19 buildings, in the sense that it says it needs to be  
20 addressed, but it doesn't say what you need to do  
21 about it.

22 CHAIRMAN CORRADINI: You guys are going back  
23 and forth. I want to clean this up. I'm trying to  
24 understand very quickly, it's your interpretation that  
25 it's got to be addressed, but by the COL applicant?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CHAKRABARTI: That is correct.

2 CHAIRMAN CORRADINI: But as you read the  
3 same sort of thing, it's unclear to you?

4 MEMBER STETKAR: No, no, no. I just want to  
5 make sure that I understand that it's a COL applicant  
6 responsibility, and that --

7 CHAIRMAN CORRADINI: Okay.

8 MEMBER STETKAR: --this is the way it's left  
9 at the design certification stage.

10 CHAIRMAN CORRADINI: But that's how I  
11 understand staff's interpretation of it.

12 MEMBER STETKAR: That is our interpretation.

13 CHAIRMAN CORRADINI: Okay, okay.

14 MEMBER STETKAR: Thanks.

15 MR. CHAKRABARTI: It is a site -specific  
16 issues.

17 CHAIRMAN CORRADINI: And then you had  
18 something for these gentlemen.

19 MEMBER STETKAR: Yes, on something  
20 completely different.

21 CHAIRMAN CORRADINI: Thank you.

22 MEMBER STETKAR: Heavy load lifts. You can  
23 take it away and come back to your heavy load lift  
24 people if you want. I had a question on why --  
25 there's a discussion in Chapter 9 on various locations

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in the plant, where you do an evaluation of heavy load  
2 lifts and rocks, and there's a final concluding  
3 statement.

4 One of the notable areas in the plant where  
5 I have a really big crane that can lift heavy loads is  
6 the turbine building. The turbine building is not  
7 mentioned.

8 It's simply a statement that says "Outside  
9 of the containment, the main steam tunnel or the  
10 refueling floor, there are no safety -related  
11 components of one division train routed over any other  
12 portion of safety-related" yadda yadda yadda . That's  
13 yadda yadda yadda for the record.

14 "Therefore, inadvertent load drops cannot  
15 cause a release of radioactivity, a criticality  
16 accident, the inability to cool fuel within the  
17 reactor vessel spent fuel pool, or prevent safe  
18 shutdown of the reactor."

19 I'm concerned about why heavy load drops  
20 from the turbine building crane and a boiling water  
21 reactor cannot cause a release of radioactivity, if  
22 those are the criteria that you need to meet.

23 CHAIRMAN CORRADINI: We're talking in the  
24 refueling building?

25 MEMBER STETKAR: No, we're talking in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 turbine building.

2 CHAIRMAN CORRADINI: Turbine building, I'm  
3 sorry.

4 MEMBER STETKAR: Has steam lines and  
5 turbines and things that have, you know, if you've  
6 ever been in a boiling water reactor, shielding i s  
7 pervasive. So if those are one of the criteria for  
8 evaluating the potential consequences from heavy load  
9 drops, I don't, you know, any release of  
10 radioactivity. The other ones I'll grant you.

11 MR. DEEVER: Well, the traditional cases are  
12 where we're lifting components over fuel.

13 MEMBER STETKAR: Traditional --

14 MR. DEEVER: Over the core.

15 MEMBER STETKAR: Yes.

16 MR. DEEVER: And so those are readily  
17 addressed. But I'm not sure what circumstances you're  
18 thinking of in the turbine building that could  
19 actually --

20 CHAIRMAN CORRADINI: Are you asking the  
21 question is there going to be a crane movement wire at  
22 full power over the turbines themselves? Isn't that  
23 the point at hand?

24 MEMBER STETKAR: That's the point at hand,  
25 or steam lines or something that can, you know, go

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 down. I don't know what the actual turbine building  
2 configuration is. We managed to drop something at a  
3 plant I operated at, that went down through a hatch  
4 and actually hit one of the main feed water pumps, for  
5 example.

6            Luckily, it wasn't something that broke the  
7 main feed water pump, but it actually tripped the main  
8 feed water pump. So I, you know,            during plant  
9 operation. So indeed people move the turbine building  
10 crane for staging for outages and for, you know, just  
11 moving equipment around during plant operation. It's  
12 not parked like refueling cranes or things like that.

13            So the basic question is if the concern is  
14 any release of radioactivity, why isn't the turbine  
15 building crane addressed as a potential source            of  
16 heavy load drops?

17            MR. DEAVER: Well, I just don't know of any  
18 events that, you know, if we fail a piece of equipment  
19 or guillotine break a steam line, then we're into a  
20 local scenario where we're going to            isolate the  
21 containment and so forth.

22            CHAIRMAN CORRADINI: I think what John is  
23 asking, I think you want to take this one away. But  
24 what John, I think, is asking is I would have a  
25 release of the activity that's in the line.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: For example, you address  
2 things in the main steam tunnel, because app arently  
3 there's some, I don't even know what it looks like,  
4 some crane in the main steam tunnel. It's at least  
5 mentioned in this analysis.

6 CHAIRMAN CORRADINI: Without maintenance.

7 MEMBER STETKAR: But yeah. But in the main  
8 steam tunnel, a lot of your arguments about if I broke  
9 a steam line or a feed line or containment isolation  
10 valves, that would limit the amount of release.

11 MR. DEAVER: A failure in the turbine  
12 building, you have a steam leak, you have a release,  
13 and why isn't that treated?

14 MEMBER STETKAR: Why isn't that at least  
15 addressed?

16 CHAIRMAN CORRADINI: Right. That's the  
17 point.

18 MR. MARQUINO: I think we want to get the  
19 exact section that you're referring us to?

20 MEMBER STETKAR: Yes. It is section, it's a  
21 long section. I think it's 9.1.5.6, and it's --  
22 that's the -- the title is "Other Overhead Load  
23 Handling Systems," and it's the last subsection in  
24 that. It's not a numbered. It's just a paragraph.

25 CHAIRMAN CORRADINI: And they've got to come

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 back to us. Yes?

2 MR. MARQUINO: Yes.

3 CHAIRMAN CORRADINI: Okay. Other questions  
4 John?

5 MEMBER STETKAR: Nope.

6 CHAIRMAN CORRADINI: Other members of the  
7 committee?

8 (No response.)

9 CHAIRMAN CORRADINI: Hearing none, I declare  
10 a break. We'll come back at twenty of. We're still  
11 ahead of the game, because we're going to go into  
12 Chapter 6 this afternoon, just so we're clear, and  
13 staff will be back with their views of Chapter 9.

14 MEMBER ARMIJO: We're jumping ahead to  
15 tomorrow.

16 CHAIRMAN CORRADINI: We're going to six.  
17 We're going to control room habitability this  
18 afternoon. That's my plan.

19 (Whereupon, a short recess was taken.)

20 CHAIRMAN CORRADINI: Are you okay? All  
21 right. Let's get started. So Dennis will lead us off  
22 on Chapter --

23 MR. GALVIN: Nine.

24 CHAIRMAN CORRADINI: Nine.

25 MR. GALVIN: But we were going answer

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Graham's question, but Graham's not here.

2 CHAIRMAN CORRADINI: Sure.

3 MR. GALVIN: Well, I guess we can start up  
4 with the other stuff.

5 CHAIRMAN CORRADINI: Hang on one second  
6 please. You guys go out side and have your conference  
7 call, or not.

8 MR. GALVIN: We only thought this would take  
9 five minutes, and we have some research. But I guess  
10 we can go back and just --

11 MEMBER STETKAR: Yes. Did you find Graham?

12 CHAIRMAN CORRADINI: Yes. Give us a minute.  
13 We don't want to leave out Professor Wallace. He'll  
14 feel left out.

15 (Off mic discussion.)

16 CHAIRMAN CORRADINI: This is for the fuel  
17 racks?

18 MR. GALVIN: What we're doing today is we're  
19 presenting Chapter 9.

20 CHAIRMAN CORRADINI: Right.

21 Chapter 9/Staff

22 MR. GALVIN: Related to Chapter 9, we picked  
23 three sets of topics. One is essentially 9 -1, which  
24 is FAPCS and the spent fuel pool. The other, the  
25 second set of topics -- and the water systems. We've

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 also selected the instrument air system, because there  
2 a specific item on that in your letter to the  
3 Commission.

4 And we've also, we'd like to briefly talk  
5 about -- there was a question in the August 16th  
6 meeting about thermohydraulic analysis. So we're  
7 going to do that first, because we have assistance  
8 here from Research, Christopher Boyd.

9 CHAIRMAN CORRADINI: Okay.

10 MR. GALVIN: And it's just -- it should be a  
11 short presentation. So Jim Gilmer from DSRA is going  
12 to lead this discussion.

13 CHAIRMAN CORRADINI: And Graham, this is for  
14 you.

15 DR. WALLIS: This is for me?

16 MR. GILMER: So we're skipping to page 30  
17 now of the --

18 DR. WALLIS: It's not for Sam?

19 CHAIRMAN CORRADINI: It's for you.

20 MR. GILMER: Yes, and actually you talked  
21 about it earlier with Mr. Deaver, about the new figure  
22 that's in backup Slide No. 31, and that shows the  
23 streamlines with the --

24 DR. WALLIS: I thought you sorted out the  
25 fuel pool, so maybe you should do it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: They want to unsort it.

2 DR. WALLIS: They want to unsort it. They  
3 want to confuse it.

4 MR. GILMER: Since we have Dr. Boyd  
5 available, we wanted to --

6 DR. WALLIS: I saw him back there. I  
7 wondered about that.

8 MR. GALVIN: He's a new member to the team.

9 DR. WALLIS: I thought we'd already sorted  
10 that out. But anyway.

11 CHAIRMAN CORRADINI: This is for you.

12 DR. WALLIS: Okay. It's for me, so I'll  
13 listen very carefully.

14 MR. GILMER: Well, one thing I would add to  
15 Mr. Deaver's presentation is this figure will be added  
16 to the topical report --

17 DR. WALLIS: That's what they said in their  
18 presentation.

19 MR. GILMER: We just received it this week -  
20 -

21 DR. WALLIS: It makes a lot more sense than  
22 the other figures.

23 MR. GILMER: Yes, and we'll provide it to  
24 staff and ACRS.

25 DR. WALLIS: Right, thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. GALVIN: So I guess there's no need for  
2 me to walk through all the bullets. Do you have any  
3 specific questions?

4 MR. GALVIN: Jim, why don't we go to Slide  
5 31?

6 MR. GILMER: 31. Okay. Just as a  
7 refresher, we didn't talk specifically about the way  
8 the COP code was modeled. The entire region of the  
9 racks was treated as so-called porous medium, with the  
10 heat load applied. That's the reason why we saw the  
11 streamlines, which appeared to be on the --

12 DR. WALLIS: The streamlines that were  
13 originally presented in the report seemed to go all  
14 over the place. I mean they came in and they wandered  
15 all over the place many, many times before they went  
16 up.

17 MR. GILMER: Right. I have that as a backup  
18 slide, because it didn't make it onto the --

19 DR. WALLIS: And this is because of a big  
20 vortex in there or something? I was a bit confused  
21 why a few streamlines came in and wandered all over  
22 the place before they went out.

23 MR. BOYD: This is Chris Boyd from Research.  
24 On that particular issue, I think GE mentioned what  
25 happened there, and we spoke with a teleconference

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with GE. It would appear that what they did is turned  
2 off the streamlines in the rack, to make the figure  
3 clearer. They said if we turned on the streamlines in  
4 all 21 domains.

5 But by turning them off in the rack and not  
6 explaining that, it was a very confusing picture.

7 DR. WALLIS: But then the ones that didn't  
8 go through the rack seemed to go around an awful lot  
9 of times before they went out, which was a little  
10 strange. Did you have any comment on that? I mean  
11 two or three came in, and then the whole thing is full  
12 of blue lines and two or three go out?

13 MR. BOYD: Right, and you don't know --  
14 those were very low velocity. So what I would say is  
15 that this is -- when you're injecting in the bottom,  
16 you are going to set up just a slow circulation  
17 pattern in the pull. These streamlines are something  
18 that are just going to follow out through these slow  
19 velocity patterns.

20 DR. WALLIS: So it's the big -- it's the  
21 buoyancy that sets up the swirly flow?

22 MR. BOYD: The buoyancy would help set up  
23 that rotation with the steam rising and the -- but  
24 even the jets coming in from the bottom would kick the  
25 flow into a little bit of a recirculation pattern.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. GILMER: Okay. Then we also looked at  
2 the pressure drop assumed through the racks. It was  
3 based on the operating BWR spec. So that's what we  
4 were really talking about. That's a troubling model.

5 MEMBER KRESS: How did you arrive at the  
6 friction factor for the median, the appropriate  
7 friction factor?

8 MR. GILMER: That was based on the operating  
9 BWR.

10 MEMBER KRESS: Oh, you have data.

11 MR. GILMER: You have data for that.

12 DR. WALLIS: Do you have a figure then?

13 MEMBER KRESS: And it's actually  
14 conservative for the ESBWR because it was based on the  
15 -- numbers.

16 MEMBER ARMIJO: Rather than the --

17 MEMBER KRESS: Rather than the 10 foot.

18 DR. WALLIS: It looks like a very  
19 straightforward location of CFX.

20 MR. GILMER: That's right. We did not  
21 verify the calculation in a formal way, but we've done  
22 very similar calculations with data in the cask areas,  
23 and we found that these codes can do a very good job  
24 modeling fuel and predicting temperature rise through  
25 the fuel, with this porous medium approach.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: It's interesting. If you look  
2 at the figure which is supplied this time, the  
3 streamlines seem to come out of the rack and then they  
4 all go into the wall, which looks a little peculiar.

5 Maybe that's because only selected  
6 streamlines are shown, or it looks as if you've got  
7 all the streamlines going through the rack, and then  
8 they go right over to the wall. It's peculiar. You  
9 think they go straight up as a plume. That must be  
10 because of the strong vorticity. The strong vortex in  
11 there pushes them to the wall.

12 MEMBER STETKAR : That must be what's  
13 happening.

14 DR. WALLIS: Do you see what I mean Chris?

15 MR. BOYD: Yeah, I've seen things like this  
16 before. There could be, you know, some entrainment of  
17 the flow behind the -- between the plume and the wall,  
18 and then there's real ly no flow replacing that  
19 entrainment.

20 So that kind of tends to move the plume over  
21 towards the wall. I don't think it's a real -- I get  
22 the impression it's not a really strong vortex. I get  
23 the impression nothing's really strong going on --

24 DR. WA LLIS: But something really pushes  
25 that flow over to the wall, isn't it?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BOYD: It does appear that there is flow  
2 across the tops of the racks that would go on there.  
3 We'd have to look at more of their velocity in  
4 profiles.

5 MR. GALVIN: Jerry, it looks like you just  
6 have one domain turned on, as far as the streamline,  
7 right?

8 MEMBER KRESS: Yes. This is probably just  
9 through one rack.

10 MR. GALVIN: I think it's just through one  
11 rack. That's what's driving that.

12 MEMBER KRESS: If you tried to show all of  
13 them, you'd have another mess.

14 MR. GALVIN: Right.

15 MEMBER KRESS: Yes. So that's --

16 MR. DEEVER: This is Jerry Deaver with GEH.  
17 This is strictly one rack, and so it's probably  
18 showing the flow associated with one rack.

19 CHAIRMAN CORRADINI: But I would guess it's  
20 also the limiting rack, given the temperatures?

21 MR. DEEVER: It's one of the limiting ones.  
22 It's got a full supply of fresh fuel that's come out  
23 of the reactor.

24 MEMBER ARMIJO: How many assemblies in that  
25 rack? How many fuel assemblies?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: There's 180.

2 MEMBER ARMIJO: In that.

3 MR. DEEVER: Right.

4 DR. WALLIS: By one rack, you mean one of  
5 these boxes shown here?

6 MR. DEEVER: Yes.

7 DR. WALLIS: So all the flow through that  
8 box goes over to the wall pretty well, rises up the  
9 wall?

10 MEMBER KRESS: That's because there's flow  
11 coming out of the other racks to keep it open there, I  
12 think.

13 DR. WALLIS: So the flow from the other  
14 racks pushes it over there?

15 MEMBER KRESS: Yeah, I think so.

16 MEMBER ARMIJO: No, there's nothing coming  
17 out of the other racks.

18 DR. WALLIS: There's nothing coming out of  
19 the other racks.

20 MEMBER ARMIJO: Just because they just  
21 didn't show it.

22 CHAIRMAN CORRADINI: They're not just  
23 showing it. They're just simply turning on -- they're  
24 simply turning on one grouping of assemblies, to show  
25 you what's going on in one grouping.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: Right.

2 MEMBER KRESS: Now I'm intrigued by this use  
3 of porous medium. Do you have a different friction  
4 factor that's vertical compare d to horizontal, or is  
5 it the same friction factor the whole way?

6 MR. GILMER: My recollection is it was only  
7 the upflow. I could be wrong on that.

8 CHAIRMAN CORRADINI: No, but I think the --  
9 well, they should answer the question. You  
10 understand?

11 MR. BOYD: I think GEH would have to answer  
12 this. I forget the details, but typically what you  
13 either do is you put in infinitely thin walls, or you  
14 put in loss coefficients in the lateral directions  
15 that are maybe a factor of 1,000 or 10,000 higher, to  
16 keep the flow aligned. I'm not sure which approach  
17 GEH used here.

18 DR. WALLIS: Yes. I think that we've got  
19 one figure. I tend to believe CFX and all that. As  
20 soon as you have one figure like this, then you begin  
21 to raise questions, and you've got no answers, because  
22 you've only got one figure.

23 So it would be good in the future to have  
24 several figures, that sort of anticipate questions  
25 about what's going on. So there's just one figure

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 like that. But I'm prepared to accept it, since it's  
2 a straightforward standard calculation.

3 MEMBER ABDEL -KHALIK: Let me ask the  
4 question about the porous medium formulation. Is this  
5 an isotropic porous medium formulation?

6 MEMBER KRESS: Yes, that was my question.

7 MR. BOYD: No. They're not isotropic in the  
8 code --

9 (Simultaneous discussion.)

10 CHAIRMAN CORRADINI: Well, let's find out  
11 from GE.

12 MR. BOYD: Yeah. We would need to ask GEH  
13 how they applied it.

14 MR. DEAVER: One of our people on the phone  
15 would have to answer that.

16 CHAIRMAN CORRADINI: Okay.

17 MR. DEAVER: Dave Davenport, do you have the  
18 answer to that?

19 MR. DAVENPORT: I'm looking, but not  
20 immediately.

21 MR. DEAVER: Okay. You can get back to us  
22 with that. Thank you.

23 CHAIRMAN CORRADINI: So now that's one of  
24 three topics, right?

25 MR. GALVIN: Okay. So we are done with the,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I guess, the conclusions? We had the same conclusions  
2 about the natural circulation. We were just trying to  
3 explain it, why we thought the model was reasonable.  
4 So we'll go back to our first presentation here.

5 So we're going to start with a discussion of  
6 the potential storage and fuel and auxiliary full  
7 COIN systems, and our presenter is Larry Wheeler.

8 MR. WHEELER: Could I have the next slide?  
9 Regulatory guidance is found in the SRP 9.1.2, 9.1.3,  
10 which includes the relevant requirements of the GDCs,  
11 which include 245.61 and .63.

12 Next slide. In this guidance, regulatory  
13 treatment of non-safety systems is found in SECY 94-84  
14 and 95 -132, and the summary of those documents is  
15 RTNSS systems, to be highly reliable, within ES design  
16 qualities and reliability.

17 Next slide. The staff's review summary, the  
18 key open items. Rackability (ph), buffer pool on the  
19 spent fuel pool, decay heat and pool draining down.  
20 A follow-up to the RAIs. The staff previously found  
21 that the following was acceptable:

22 The potential drain pass that can drain the  
23 buffer pool or the spent fuel volume. The spent fuel  
24 pool transfer gates and buffer pools are safety -  
25 related, Seismic Category 1. Anti-siphon holes on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 submerged piping are no lower than 9.2 meters above  
2 the top of stored fuel assemblies.

3 Maximum bounding of the spent fuel pool heat  
4 loads. This was previously discussed with GE, excuse  
5 me, GEH. Bounding water make -up for the spent fuel  
6 pool is 200 gallons per minute.

7 Next slide. Pool level, the -- measures,  
8 collapsed water level. No false readings due to  
9 seeing vapor above the actual water level. The high  
10 level are key points to this summary. The buffer pool  
11 will remain --

12 DR. WALLIS: It's simply a pressure drop  
13 measurement, isn't it? The pool level measurement is  
14 simply pressure gauges, pressure sensors?

15 MR. WHEELER: I believe that's true.

16 DR. WALLIS: Right.

17 MR. WHEELER: The key points of the staff's  
18 summary is the buffer pool will remain 7.3 meters  
19 above the stored fuel assemblies during the loss of  
20 FAPCS for the 72 hours. The stored fuel in the spent  
21 fuel remains covered during the loss of FAPCS for 72  
22 hours.

23 MEMBER ABDEL -KHALIK: What is the area  
24 footprint of the spent fuel pool roughly?

25 MR. WHEELER: I do not know that answer.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Maybe GE could answer that.

2 DR. WALLIS: So it's -- sorry.

3 MR. DEEVER: Go ahead. Dave might know  
4 that.

5 MR. GELS: We can look it up. It will just  
6 take one minute.

7 CHAIRMAN CORRADINI: I estimate about 100  
8 square meters.

9 MR. DEEVER: Okay.

10 MEMBER ARMIJO: Is that 7.3 meters a staff  
11 calculation, or is that --

12 MR. WHEELER: It's a GE calculation.

13 MEMBER ARMIJO: And did you verify it by  
14 some independent calculation?

15 MR. WHEELER: There is an audit team from  
16 the NRC that did look at the methodology into those  
17 calculations.

18 DR. WALLIS: It's fallen about ten meters,  
19 according to GEH.

20 MEMBER ARMIJO: Yes. I'm a little confused.  
21 In the GEH presentation, they use minimum coverage  
22 height of 10.26 meters.

23 MR. WHEELER: What I wanted to do here is  
24 say that this is what the staff previously approved,  
25 and my next slide will go ahead and explain to you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that there's been changes.

2 DR. WALLIS: It's changed. Okay. That  
3 explains it.

4 MR. WHEELER: N ext slide. So we're on  
5 number six. August 16th of this year, ACRS  
6 Subcommittee noted the issues related to the NEDO  
7 33373, basis for the heat loads using the spent fuel  
8 thermohydraulics. GEH calculated, calculations for  
9 the decay heat were determined to be non-conservative.  
10 The spent fuel heat loads for the fuel core offload  
11 and discharge fuel decay used the 36th day into the  
12 fuel cycle.

13 The updated spent fuel heat loads for the  
14 fuel core offload and discharge fuel decay used the  
15 end of fuel cycle, an d was determined to be more  
16 conservative. Presently, the staff is looking at the  
17 new proposed tech spec for the spent fuel pool water  
18 level. So that effort is ongoing.

19 We got that information earlier this week,  
20 and the staff has not had enough time to draw a  
21 conclusion to the new numbers.

22 DR. WALLIS: Oh.

23 MR. GELS: This is John Gels from GEH. The  
24 dimensions of the spent fuel pool are 12.86 meters by  
25 14.86 meters, which comes to about 191.2 square

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 meters.

2 DR. WALLIS: Thank you.

3 CHAIRMAN CORRAD INI: A reasonably -sized  
4 house.

5 DR. WALLIS: But GE did present some numbers  
6 in their presentation, GEH, and they -- I thought  
7 that they said that the pool level dropped by ten  
8 meters?

9 MR. DEAVER: Yes, that's --

10 DR. WALLIS: And you still need ten meters  
11 above this. Don't they have about 20 meters when they  
12 start? That's an awful lot.

13 MR. WHEELER: Well, we looked at the audit  
14 and concluded that the boil-off was around 9.2 meters.  
15 With the new heat load, the new proposed number, it  
16 is closer to ten meters, and that's on their  
17 evaluation.

18 MR. DEAVER: Jerry Deaver with GEH. We used  
19 the same methodology. So the resulting number that we  
20 came up with was 10.35, as far as the total drop in  
21 water level now.

22 DR. WALLIS: And that meets your minimum  
23 coverage requirement, but not by very much?

24 MR. DEAVER: Yes, that's correct.

25 MR. GALVIN: My understanding, the drop is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 10.26 meters and your normal water level would be  
2 10.36 meters. So you have about 10 centimeters or  
3 four inches above that, above the -- level.

4 MR. DEEVER: That's the distance above the  
5 handle so, you know, if you were really considering  
6 where it would become critical, it would be down to  
7 the active fuel level, which is .55 meters is where it  
8 would really reach the fuel, the active fuel.

9 DR. WALLIS: So you're very close to the  
10 active fuel?

11 MR. DEEVER: No. We're .55 meters away  
12 under these theoretical --

13 DR. WALLIS: That's close compared with  
14 where you started from.

15 MR. WHEELER: Okay. On Slide 7, I want to  
16 talk about FAPCS and RTNSS. The staff found the  
17 following acceptable for FAPCS, for its RTNSS-B  
18 function. This is for long-term cooling. Fire  
19 protection system interfaces, which allows the  
20 isolation and condenser passive containment cooling  
21 system pools to be filled with water, to extend  
22 cooling period from 72 hours out to seven days.

23 The piping interface is safety-related, ASME  
24 Class 3, and in Seismic Category 1. And as GE has  
25 said earlier, FAPCS does have availability controls in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 3.7-2 and 3.7-3.

2 MEMBER ARMIJO: Could we go back to that  
3 prior discussion? I just want to make sure I  
4 understand. In the boil -off calculation, at what  
5 level did you start the calculation? Maybe it's for  
6 GEH. At the minimum pool level, and then you started  
7 the boil-off calculation, or at some other pool level?  
8 I mean it's not always constant.

9 MR. WHEELER: I think GE needs to answer  
10 that question. From what I remember looking at the  
11 calculation, they determined what the boil -off volume  
12 would be, and then from there, they backed up the LCL  
13 to maintain that during that 72 hour boil -off period,  
14 that the fuel assembly or the top of the bell handle  
15 would still have water to that point.

16 MEMBER ARMIJO: Yes. But there's a range at  
17 which a pool level, and I don't remember what it is.  
18 If you start the boil -off at one level, you have --  
19 you can have a different answer.

20 MR. WHEELER: From what I remember, there  
21 wasn't more than a couple of feet between normal  
22 operating range and the new number, the 7.2 number.  
23 Of course now that's been raised.

24 MEMBER ARMIJO: Ask Jerry.

25 MR. DEEVER: Yes. This is Jerry Deaver with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 GEH. We assumed the water level at the top, at the  
2 weir spillover point, which is 14.35 meters.

3 MEMBER ARMIJO: Well, that's your minimum,  
4 isn't it? Is that your minimum water level in the  
5 pool?

6 MR. DEEVER: Well, that should be your  
7 minimum, you know, considering that you have a flow  
8 over the wet weir in operation.

9 MEMBER ARMIJO: Yes, okay.

10 DR. WALLIS: So it's not much above that  
11 minimum?

12 MR. DEEVER: You can't go above --

13 DR. WALLIS: Can't go much above that?

14 MR. DEEVER: No.

15 DR. WALLIS: Because it flows over?

16 MR. DEEVER: Right.

17 DR. WALLIS: This level they're talking  
18 about is always a collapsed level? It's always a  
19 collapsed level they're talking about, when it was at  
20 boiling?

21 MR. DEEVER: Yes. It's the fundamental --  
22 during boil-off, the level is the -- with the water  
23 evaporated.

24 DR. WALLIS: The collapsed level, because  
25 you've got voids in there.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEAVER: Yes, yes.

2 DR. WALLIS: So it's actually higher. The  
3 real level is higher. The surface of the water is  
4 higher than you say here, because of the bubbles in  
5 it?

6 MEMBER ABDEL -KHALIK: This is a simple  
7 inventory calculation.

8 DR. WALLIS: It's a simple inventory  
9 calculation.

10 (Simultaneous discussion.)

11 MEMBER ABDEL -KHALIK: --for the  
12 vaporization. That's all there is to it.

13 MR. DEAVER: Yes. It's not that high tech.

14 MEMBER ARMIJO: So you're actually  
15 evaporating 4-1/2 million pounds of water?

16 DR. WALLIS: That's a huge amount, yes.

17 MR. GALVIN: You would be correct. I mean  
18 if there's voids in the water, then actually the  
19 apparent water level would be higher, right?

20 MR. DEAVER: That's a true statement, yes.

21 DR. WALLIS: Well, we asked about where it  
22 went. Is the staff concerned about where all this  
23 water goes?

24 MR. WHEELER: I don't have an answer for  
25 your question. That's something we'll have to take

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 back.

2 CHAIRMAN CORRADINI: This is a design basis  
3 calculation for the purposes of what? I'm get ting  
4 nervous about taking a conservative calculation and  
5 taking it somewhere it's not meant to go.

6 MR. WHEELER: I mean take your fuel plus the  
7 complete core offload.

8 MEMBER ARMIJO: For 72 hours.

9 MR. WHEELER: And then we add the 72 hour  
10 loss of FAPCS.

11 MS. CUBBAGE: Is there a safety concern with  
12 the steam?

13 DR. WALLIS: Well, you've got all this water  
14 going somewhere. Does it affect some other safety  
15 operation in some way?

16 MS. CUBBAGE: Well, I mean what's going on  
17 in that building is nothing, as far as --

18 DR. WALLIS: There's nothing in that  
19 building--

20 MS. CUBBAGE: You're not crediting any  
21 active make-up or cooling.

22 DR. WALLIS: There's nothing else in that  
23 building you're crediting?

24 MS. CUBBAGE: So the safety case is.

25 DR. WALLIS: That's a good answer. But

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 still, even if it fills with water, it can't do any  
2 harm?

3 MS. CUBBAGE: I'm just talking off the top  
4 of my head, but it would seem to me if we've already  
5 said that nothing active is working and we're in this  
6 worse case design basis situation where we're just  
7 steaming, I'm not sure what impact it would have.

8 MR. GALVIN: GEH told us there was no  
9 safety-related equipment in that building, so -- and  
10 they've also said that there's a -- right now, since  
11 Revision 7, they've added a, they've made events  
12 safety-related. The SRP guidance says if you allow  
13 your pools to boil, you need to have a place for the  
14 steam to go.

15 DR. WALLIS: So it doesn't affect pumps or  
16 pumps for this spent fuel pool, which are in the  
17 building?

18 MR. WHEELER: Well, there are. That's why  
19 you have the boiling --

20 DR. WALLIS: Would you start them up after  
21 72 hours, or would you --? Do you bring in some other  
22 water up to 72 hours? What do you do?

23 MR. GALVIN: The fire pumps come on, the  
24 fire pumps, yes, in a separate building.

25 DR. WALLIS: So you don't care if those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pumps work?

2 MR. GALVIN: Yes.

3 MEMBER STETKAR: Where, and this is a  
4 question of GEH or of the staff. Where are the --  
5 those are manual valves that you line up the fire  
6 protection system for make-up, is that correct?  
7 They're not motor operated or otherwise operated?

8 MR. WHEELER: I've got the simplified  
9 drawing. It appears that on their drawing that they  
10 are manual valve.

11 MEMBER STETKAR: Yes, I believe that's the  
12 case. Does the simplified drawing that I've lost show  
13 where those valves are located? Are they in the fuel  
14 building or are they outside of the fuel building?

15 MR. WHEELER: This drawing says that they  
16 are in the yard area.

17 MEMBER STETKAR: Okay, good. Thanks.  
18 That's part of the answer. Even if you flood out  
19 FAPCS, they take credit for make-up from the fire  
20 water system. As long as the valves are accessible,  
21 they can get the water in there. That's through that  
22 primary fire protection header thing, that's written  
23 as B.

24 DR. WALLIS: If you drive off all the steam  
25 and the outside temperature is below zero, you will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 get an enormous, enormous stalag types of ice forming  
2 around this pool. I don't know if that affects the  
3 operation of --

4 CHAIRMAN CORRADINI: So what are you -- I'm  
5 sorry. You're postulating a design basis action in  
6 the middle of dead of winter?

7 DR. WALLIS: Yes. Why not? It could happen  
8 at any time.

9 CHAIRMAN CORRADINI: We do a worse scenario.

10 MR. WHEELER: Now keep in mind, the FAPCS  
11 pumps are diesel-backed, so there's that reliability.  
12 That's part of their design.

13 DR. WALLIS: If you put a lot of steam out,  
14 and outside temperature is very cold, you'll make an  
15 awful lot of ice here, ice somewhere out there. This  
16 is of no concern on accessibility of the valves?

17 MEMBER ARMIJO: Not to me.

18 CHAIRMAN CORRADINI: Is that a question of  
19 staff?

20 DR. WALLIS: I'm just thinking about what  
21 might happen, if I had all this steam issuing out in  
22 the middle of winter.

23 VOICE: It would turn into snow.

24 DR. WALLIS: And wouldn't it, would it have  
25 some effect on accessibility? People have to go

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through an icy surface and an open valve's covered  
2 with ice.

3 (Simultaneous discussion.)

4 DR. WALLIS: If the fire pumps go on.

5 MR. MARQUINO: This is W ayne Marquino, GE.  
6 We do consider in our detailed design operator access  
7 to these areas, especially where there is RTNSS  
8 equipment. So we'll design platforms, steps, ladders  
9 to provide access.

10 The question about ice forming, that's a  
11 structural conc ern of the building and the roof  
12 system. It doesn't apply only to steam coming out of  
13 the building, but it would apply under winter weather  
14 conditions as well.

15 MR. GALVIN: Can we move on to the next  
16 topic?

17 MR. WHEELER: So concluding on Slide 7, we  
18 have the RTNSS-B function. Staff found the following  
19 acceptable for FAPCS and its RTNSS -C function. This  
20 is for the pressure coolant injection node. This  
21 requires a FAPCS pump to take a section from the  
22 suppression pool and pump it into the RPV by the  
23 reactor water clean -up and shutdown cooling loop,  
24 Alpha, and the feed water loop, Bravo.

25 Once again, FAPCS does have availability

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 controls. This piping system is non-safety. However,  
2 it is Seismic CAT-2. All RTNSS structure, system and  
3 components are within the scope of the D-RAP.

4 Next slide. Moving on to the next FAPCS  
5 RTNSS-C function is the suppression pool cooling node.

6 It requires water to be drawn from the suppression  
7 pool, cooled by FAPCS and returned to the suppression  
8 pool. Once again, availability controls apply.  
9 Piping is non-safety related. It is Seismic CAT -1 or  
10 2.

11 Physically separated, 100 percent cooling  
12 trays, each with one FACPS pump and heat exchanger.  
13 Procedures are to ensure avoidance of water hammer and  
14 gas binding. That is a COL item, 13.54 -Alpha.  
15 Provisions are also provided to protect FAPCS  
16 components from fire, missile-generating events,  
17 internal flooding, seismic event, and that would be  
18 the SSE.

19 Once again, all RTNSS structures, systems  
20 and components are within the scope of a D-RAP.  
21 That's for the suppression pool coolant routing.

22 DR. WALLIS: Did you analyze that the  
23 procedures to avoid water hammer and gas binding are  
24 adequate?

25 MR. WHEELER: Those are COL items.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: Oh, they're COL items, so we  
2 don't' consider them, at this point?

3 MR. WHEELER: At this point, that's correct.  
4 Slide 10. The staff found the following acceptable  
5 for FAPCS, for its RTNSS -Charlie function, that they  
6 do in fact are diesel -backed by the standby diesels,  
7 and that's availability controls 3.81 and 3.82.

8 Moving over to operating experiences, the  
9 staff found the following acceptable related to two  
10 RAIs: Gas accumulation that could enter the system  
11 and results in components or system damage was  
12 adequately addressed. The gas accumulation is  
13 possible from the high pressure interface between the  
14 reactor water clean-up and the shutdown cooling.

15 Interface through check valves and the  
16 motor-operated valves. The staff concludes that there  
17 is a pressure relief valve that is located between the  
18 check valve and the MOVs. In addition, FAPCS is not  
19 immediately placed into service for a low pressure  
20 injection, or alternate shutdown cooling nodes.

21 Therefore, there's adequate time for proper  
22 venting if there was a gas bubble in the system.

23 Moving on to the second item, the refueling  
24 cavity bellows. Postulated failures were adequately  
25 addressed. The bellows is a permanently installed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CAT-1 component, stainless steel component designed  
2 for a life of 60 years. This bellows includes a  
3 secondary seal, which is monitored for leakage. The  
4 drain down event for the refueling cavity is not  
5 likely to occur.

6 Also level indications and alarms are  
7 provided to alert operators to any leakage out of the  
8 cavity that would develop.

9 Next slide. Staff review concludes for  
10 FAPCS, for this RTNSS-Bravo and Charlie functions are  
11 highly reliable, meets the single failure criteria,  
12 and are subject to enhanced design, quality,  
13 reliability and availability provisions. Once again,  
14 the staff is still looking at the spent fuel pool heat  
15 loads, and that's considered an open item.

16 DR. WALLIS: Why are you still looking at  
17 it, when it seems such a simple calculation?

18 MR. WHEELER: Well, it just came in on  
19 Monday, and we didn't want to rush through this, just  
20 to say we had a closed item.

21 DR. WALLIS: Okay, because it does look like  
22 a pretty simple thing. It's just energy and an energy  
23 out for the thing.

24 MEMBER ABDEL-KHALIK: He's calculating the  
25 heat flow.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WHEELER: Right.

2 DR. WALLIS: The heat flow.

3 MR. GALVIN: Well, I mean since there was  
4 confusion with it the first time, and then of course  
5 there's a ten year heat load and a 20 year heat load,  
6 so we want to make sure we -- at this rate, and  
7 there's also a tech spec associated with it.

8 DR. WALLIS: That's fine, that's fine.

9 MR. WHEELER: Discussions and questions on  
10 FAPCS?

11 MR. GALVIN: We can proceed, and you can ask  
12 them all at the end. Okay.

13 CHAIRMAN CORRADINI: Keep on going.

14 MR. WHEELER: Next presentation is related  
15 to the service water system, component cooling system  
16 and the nuclear island chilled water system.  
17 Regulatory guidance is found in SRP 9.21, 9.22, which  
18 includes the relative requirements of GDC 245, 44, 45  
19 and 46.

20 Next slide. Once again, we already talked  
21 about RTNSS on the FAPCS presentation.

22 Next slide. RTNSS sea water system  
23 focus was part of the March 19th and 20th, 2009  
24 audit. That was to resolve RAI 9-224. The staff  
25 found the following acceptable: adequate design

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 margins between the cooling tower capacity and  
2 bounding heat loads for service water between the  
3 component cooling heat exchanger capacity,  
4 maximum heat loads, and between the nuclear  
5 island chilled water system and the maximum heat  
6 loads.

7 Single failure criteria has been  
8 properly addressed due to the redundancy of the  
9 design. Components have a diesel-backed  
10 availability. Components failure positions on a  
11 loss of preferred power.

12 Next slide. Service water pumps have  
13 sufficient available net positive suction head in  
14 the pump sections, located for the lowest  
15 possible water levels of the heat sink. The  
16 component cooling and the chilled water pumps  
17 have sufficient available net positive suction  
18 head at the pump suction's lowest possible water  
19 level in those surge tanks.

20 Next slide. Service water component  
21 cooling, chilled water system, RTNSS components  
22 are in fact in maintenance rule, which require  
23 performance monitoring of the ISSEs. These three  
24 system RTNSS components have adequate main  
25 control on this rotation for system monitoring,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and during loss of preferred power, these three  
2 systems, if their associated pumps fail, can be  
3 powered by the two non -safety related on -site  
4 standby diesel generators.

5 Next slide. Procedures to ensure  
6 avoidance of water hammer and gas binding. We  
7 talked about that earlier. That's a COL item.  
8 There is redundancy in the service water  
9 component cooling and the nuclear island chilled  
10 water trains. Once again, RTNSS components are  
11 within the scope of D-RAP.

12 Staff's conclusion for the service  
13 water component cooling system, nuclear island  
14 chilled water system: For the RTNSS functions,  
15 highly reliable, meets single failure criteria,  
16 are subject to enhanced design quality and  
17 reliability, and they meet applicable SRP 9.21  
18 and 9.22. Any questions?

19 (No response.)

20 MR. GALVIN: We will proceed. David  
21 Shum is going to speak about the staff's review  
22 of the instrument air system, and cover it. It's  
23 described in Section 9.36 of the SER.

24 MR. SHUM: Okay. The instrument -- the  
25 system function is to provide air, compressor

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 air, try to compress the air to all the safety -  
2 - I mean the air -operated equipments, and the  
3 instrumental control outside the containment, and  
4 to provide air to the high pressure nitrogen  
5 supply system inside of containment during the  
6 refueling outage operations.

7 The system is non -safety related, and  
8 has no -- and not needed for safety shutdown. It  
9 is RTNSS -- not RTNSS. The system was designed  
10 to meet the ANSI Standard 7.0.01, the quality  
11 standard for ISA, instrumentation air.

12 DR. WALLIS: The air is drawing after  
13 it's compressed, is it?

14 MR. SHUM: Yes.

15 DR. WALLIS: Okay.

16 MR. SHUM: And the system has two  
17 identical 100 percent filtration and dryer  
18 systems, and has a cross -tie between the  
19 distribution headers of the service system and  
20 instrumentation systems. Use it to bypass the  
21 instrumentation air system, in the event that  
22 both of them, instrumentation air and dryer  
23 trains fail.

24 MEMBER STETKAR: I don't have the  
25 drawing in front of me here, and I'm having

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 problems finding it quickly. My recollection is  
2 that that bypass line not only bypasses the  
3 dryers, but it also bypasses the filters. Is  
4 that correct?

5 MR. SHUM: Right. It comes from two  
6 headers. It come out from the service air system  
7 discharge header, d irectly to the discharge  
8 headers of the instrumentation heads.

9 MEMBER STETKAR: That's what my  
10 recollection was, and so that means if for some  
11 reason I have problems with both the air dryers,  
12 or one is out for maintenance and I have a  
13 problem with the op erating air dryer, and I need  
14 to cross-tie the system, in a sense, I'm putting  
15 direct service air into my instrument air header.

16 I'm effectively bypassing the dryer and  
17 that really small three millimeter, micron, or  
18 three whatever it was, -- that they talked about.

19 MR. SHUM: You are right. You are  
20 right. If you assume both of them are not in  
21 operations.

22 MEMBER STETKAR: Yes. Do you have any  
23 idea of the reliability of air dryer?

24 MR. SHUM: There are no moving parts.

25 MEMBER STETKAR: Oh yeah, there are.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SHUM: In the air dryers.

2 MEMBER STETKAR: Typically, you have  
3 two towers that blow down. You have a lot of  
4 moving parts there. Most plants they're out of  
5 service a reasonable fraction of the time. When  
6 I say "reasonable," I don't mean --

7 MR. SHUM: That's why you have two  
8 trains, 100 percent trains for.

9 MEMBER STETKAR: Some plants have  
10 three, and they have to occasionally bypass them.

11 MR. SHUM: I understand.

12 MEMBER STETKAR: So the question then,  
13 and I think the reason for our original concern  
14 was given the design of the system, with the  
15 bypass capability, where you bypass not only the  
16 air dryers, which is a good thing, because they  
17 are not necessarily highly reliable pieces of  
18 equipment, but also bypass the filters, what's  
19 the chance of introducing now contaminants from  
20 the service air system into the instrument air  
21 lines, which could then migrate --

22 MR. SHUM: To answer your question, you  
23 have two trains, 100 percent, okay? If both  
24 fail, they only fail during the refueling outage  
25 times.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: I'm not necessarily --

2 MR. SHUM: You only use it for that.

3 MEMBER STETKAR: Inside the containment  
4 valves.

5 MR. SHUM: Outside the containment,  
6 this system, the instrumentation air system, is  
7 not going to operate any air operated equipment  
8 in the safety system.

9 MEMBER STETKAR: Okay. Let me make  
10 sure I understand that. Maybe I might need some  
11 help from GE. Does instrument air supply outside  
12 the containment? Does instrument air supply air-  
13 operated containment isolation valves that are  
14 located outside the containment?

15 MR. ARCARO: This is Mike Arcaro, GEH.  
16 I think Chapter 6 has a list of containment  
17 isolations. I believe there is instrument air.

18 MEMBER STETKAR: Yes. I think that's  
19 the case.

20 MR. BEARD: And Alan Beard of GEH  
21 again. I'd also say that the CRD pilot valves.

22 MEMBER STETKAR: Oh, okay. I didn't  
23 even think of that.

24 MR. BEARD: So the pilot valves will  
25 get instrument air --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER STETKAR: I was just thinking.  
2           The problem, of course, has been historically  
3           that contaminants in instrument air piping, in  
4           particular oil and other contaminants, can  
5           migrate through the air piping and essentially  
6           collect at the ends of the distribution headers,  
7           which are typically solenoids for air operated  
8           valves.

9           And the problem is that the air, the  
10          valves are designed to fail closed on loss of air  
11          pressure, provided that the spool piece in the  
12          solenoid actually can physically move when the  
13          solenoid is de-energized.

14          If the spool piece is varnished in  
15          place, because you now have a normally energized  
16          solenoid that actually has heat associated with  
17          it, and a long-term accumulation of small amounts  
18          of oil perhaps. Now are all of your air  
19          compressors oil free?

20          MR. ARCARO: This is Mike Arcaro, GEH.  
21          That's correct. They are oil-free.

22          MEMBER STETKAR: That's good news. So  
23          then it would be any entrained moist, you know,  
24          any contaminants that might be entrained in  
25          moisture, for example, from the intake that got

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through the compressors. But that's less of a  
2 concern.

3 MR. ARCARO: Now one of the things we  
4 committed to Reg Guide 168, 168 has you take air  
5 samples at the full loads --

6 MEMBER STETKAR: You're going to do  
7 that down at the loads?

8 MR. ARCARO: That's correct.

9 MEMBER STETKAR: Okay, good. Thank  
10 you.

11 DR. WALLIS: The compressors presumably  
12 have a facility for removing moisture. As you  
13 compress air, you tend to condense. So they  
14 presumably remove moisture --

15 MEMBER STETKAR: They usually do have  
16 moisture separators, but they're not --

17 DR. WALLIS: --all together.

18 MEMBER STETKAR: But they're not as  
19 good as these air dryers. That's why they have  
20 them.

21 DR. WALLIS: Because there's a  
22 notorious problem with compressed air getting  
23 moisture.

24 MR. SHUM: But the compressed air,  
25 later on we will address that. The air coming

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 out of the compressor of the service air is  
2 supposed to be less than 10 microns. It's a lot  
3 less than the ANSI standard will allow. ANSI  
4 standard define, you know, specify 40 microns, I  
5 mean 40 microns.

6 MEMBER STE TKAR: Just for particulate  
7 contamination?

8 MR. SHUM: Uh-huh, so and the system  
9 continues monitors for moisture contents.

10 MEMBER STETKAR: Depends where that  
11 monitor is. If the monitor is right after the  
12 air dryer, it's not going to help you when you  
13 bypass the dryers.

14 MR. SHUM: Yes, sure. So and  
15 instrumentation air is not supposed to go to any  
16 safety-related systems.

17 MEMBER STETKAR: Well, the point is  
18 that it does go to safety -related systems. It  
19 does not provide a design basis, safety -related  
20 function in the sense of the fact that pressure  
21 must be supplied to operate that equipment. It  
22 does connect the safety -related pieces of  
23 equipment. Those are containment isolation  
24 valves.

25 MR. SHUM: The containment isolation

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 valves, that's a fail safe.

2 MEMBER STETKAR: You know, I'll tell  
3 the story from a plant that I used to operate at,  
4 that had a notoriously bad instrument air system,  
5 that supplied air -operated containment isolation  
6 valves.

7 They failed safe on loss of air  
8 pressure. When we did our quarterly containment  
9 isolation test, we always had valves that did not  
10 work because the solenoid spool pieces that were  
11 de-energized, that had to move to vent the air  
12 pressure from the valve, did not move. They were  
13 varnished in place.

14 So although air pressure, air pressure  
15 is not removed from this thing until a spool  
16 piece moves to vent the pressure off the top of  
17 the valve operator. If that spool piece doesn't  
18 move because the spool piece was varnished in  
19 place, because it was cooked, you know, you took  
20 some oil and cooked it there, you could de-  
21 energize that valve all you wanted to, and the  
22 valve would stay open. The isolation valve would  
23 stay open. That's the basic concern.

24 MS. CUBBAGE: May I interject please?  
25 Is there a recommendation the Committee would

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 like to make on this?

2 MEMBER STETKAR: No, there isn't.

3 Actually, he's defending things too quickly.

4 MS. CUBBAGE: Okay.

5 MEMBER STETKAR: But the fact that you  
6 don't have oil in your air compressors is the  
7 key.

8 MS. CUBBAGE: Okay.

9 MEMBER STETKAR: And the fact they've  
10 committed to monitoring the quality of the air at  
11 the, you know, the loads, the end of the  
12 distribution lines. Those two in parallel  
13 satisfy me that this is okay.

14 MS. CUBBAGE: All right. Let's roll.

15 MR. GALVIN: Do you want to hear the  
16 rest of our presentation on that or not?

17 MEMBER STETKAR: No.

18 MR. GALVIN: Okay. So I guess we're  
19 done with it.

20 MEMBER STETKAR: Amy, my only point was  
21 you shouldn't say that the air system does not  
22 interface with safety-related equipment, because  
23 it absolutely does.

24 MS. CUBBAGE: Okay. Point taken.

25 Thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: And that is not as a -  
2 - that is not an appropriate defense for the  
3 concern.

4 MR. GALVIN: Okay. So we were going to  
5 skip the rest of thi s. So Amy, I guess now you  
6 can ask questions. That's the end of our  
7 presentation.

8 CHAIRMAN CORRADINI: There were  
9 questions being asked.

10 MR. SHUM: Am I done?

11 (Laughter.)

12 MR. GALVIN: I don't know if they're  
13 done. I don't know if the rest of th e members  
14 want to ask you questions.

15 CHAIRMAN CORRADINI: Other questions  
16 for the staff?

17 (No response.)

18 CHAIRMAN CORRADINI: Thank you.

19 MR. SHUM: Thank you.

20 MEMBER ARMIJO: Going to do Chapter 6.

21 MR. GALVIN: We're going to do Chapter  
22 6 --

23 CHAIRMAN CORRADINI: That is our plan.  
24 We want to do Chapter 6.

25 MS. CUBBAGE: Okay, GE.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: GE is up.

2 (Off mic discussions.)

3 Chapter 6/GEH

4 MR. MARQUINO: Okay, so is John ion the  
5 line? John Gels, are you on the phone?

6 MR. GELS: Yes, I'm here.

7 MR. MARQUINO: Okay. So we have more  
8 information on our FAPCS questions from earlier  
9 today, and ability to drain via one single  
10 failure from one pool to another pool. There was  
11 a comment made by the folks in Wilmington that  
12 there wa s a check valve. Do the folks in  
13 Wilmington want to go further than that and tell  
14 us more?

15 MR. GELS: Right. The check valve I  
16 was referring to is not in fact a check valve, if  
17 I understand your question, and you're referring,  
18 I believe, to the point i mmediately exiting the  
19 surge tank?

20 MEMBER STETKAR: Yes. On the one -line  
21 drawing, the only one that I have is the one-line  
22 drawing, this single -- there's a normal, you  
23 know, a manual isolation valve shown on that  
24 line, but I didn't see any check valves.

25 MR. GELS: That's right. There is not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a check valve on that line, and if I understand  
2 your concern, it was drainage from the  
3 suppression pool through the suppression pool  
4 suction line, and then back up the surge tank  
5 suction line.

6 MEMBER STETKAR: Yeah, that's correct,  
7 and the concern, now that there aren't any check  
8 valves, just to make sure you have it clear, the  
9 concern is kind of twofold. Number one is how  
10 quickly and how far can I drain either the  
11 suppression pool or the GDCS pool, because I  
12 could be aligned to -- in principle, I could be  
13 aligned to either one of them.

14 MR. GELS: Uh-huh.

15 MEMBER STETKAR: And that's just  
16 basically line size and hydraulics, and I don't  
17 know where the suction lines connect to those  
18 particular pools, whether they're at the bottom  
19 or whether they have, you know, some other  
20 configuration.

21 So that's one question, is how quickly  
22 can I drain and how far can I drain either of  
23 those pools.

24 The second question is if I do have  
25 this alignment, where I'm now in a water transfer

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mode from one of those pools into essentially the  
2 pull pools, you know, it will go through the  
3 skimmer surge tank and back through the skimmer  
4 lines and overflow the fuel pools, where does  
5 that water go, and how much of it is there?

6 Can I flood all of the equipment in the  
7 basement of the turbine building? Not turbine  
8 building, fuel building, and in particular  
9 because the FAPCS pumps and valves and everything  
10 is down in the basement.

11 So it's kind of a twofold. It's  
12 drainage of tanks that I'd like to have water in,  
13 and a potential incapacitation of equipment that  
14 it's not safety -related, but it's at least  
15 identified as RTNSS functions.

16 MR. GELS: Okay. I can't immediately  
17 answer the question about how fast they do drain.

18 The GDCS pool is equipped with anti-siphon  
19 holes that would prevent drainage below the  
20 minimum level. The suppression pool has  
21 monitoring on it that would signal when low level  
22 has been reached.

23 But I think the more overriding feature  
24 is that there are interlocks built into the  
25 FAPCS system, such that valve alignments that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 could result in water flowing from the  
2 suppression pool to either the surge tank or the  
3 fuel pools would be prohibited by the logic.

4 MEMBER STETKAR: And that's in the  
5 suction valves?

6 MR. GELS: That's right. There is a  
7 valve bridge on the suction side of the pumps,  
8 and right.

9 MEMBER STETKAR: Yes.

10 MR. GELS: And so those valves can be  
11 configured in certain ways that allow both trains  
12 to operate. But there are also certain specific  
13 configurations that are prohibited, and one of  
14 those configurations would be one that would  
15 allow drainage from the suppression pool through  
16 the surge pipe.

17 MEMBER STETKAR: Okay. So you're  
18 basically saying that we're protected against  
19 this by the valve interlocks?

20 MR. GELS: That's correct.

21 MEMBER STETKAR: Okay. Thank you. I'd  
22 still be interested in the original questions,  
23 only because we have operating experience where  
24 people indeed have drained large pools into  
25 places that they ought not to be in similar

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 configurations that have valve interlocks that  
2 are overridden for one reason or another.

3 But thanks for the information about  
4 the interlocks. That certainly helps.

5 MR. BEARD: This is Alan Beard, and  
6 John, jump in if I get this wrong. But I think  
7 the key points he made was on the suppression  
8 pool, we are monitoring level and if it drops  
9 below a certain point, the isolation valves will  
10 close and terminate that drain down. Correct  
11 John?

12 MR. GELS: I would have to look that  
13 up.

14 MR. BEARD: Well, we'll check on that,  
15 and then the point on the GDCS pools is we are  
16 sucking off the top of the water. So it's a weir  
17 type of situation.

18 MEMBER STETKAR: Yeah, I see that. I  
19 see that on the --

20 MR. BEARD: It's not a suction from way  
21 low down in the pool. There's only so much water  
22 off the top for the drain down.

23 MEMBER STETKAR: Yes. So the bigger  
24 concern would indeed be the suppression, how far  
25 can you drain it down before you get below level.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BEARD: And I will take the action  
2 tonight to go and check on that. But I believe  
3 it's down to seven meters is where we would have  
4 the isolation point.

5 MEMBER STETKAR: I have no idea what  
6 that volume of water --

7 MR. BEARD: From 7 to 7.1 meters.

8 CHAIRMAN CORRADINI: You'd have the  
9 isolation point because of the valve logic, or  
10 you have the isolation point because of what?  
11 I'm sorry.

12 MR. BEARD: To terminate a potential  
13 drain down of the suppression pool.

14 MEMBER STETKAR: I mean on the  
15 suppression pool, you want to keep water --

16 MR. BEARD: And as far as your --

17 CHAIRMAN CORRADINI: I understand that,  
18 but I don't understand --

19 MR. BEARD: Your other thought. The  
20 pumps for the FAPCS system are located in water-  
21 tight rooms. So although the water would  
22 accumulate in the -- area of the basement of the  
23 spent fuel pool or the spent fuel building, it  
24 would not get into the room where those pumps  
25 are.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Okay, good, good.

2 Thank you.

3 CHAIRMAN CORRADINI: Thank you very  
4 much. Okay. On to Chapter 6.

5 MR. MARQUINO: With control room  
6 habitability and EO.

7 MR. ARCARO: All right. Next slide.  
8 Okay. What we wanted to talk about today was  
9 control room habitability area tech specs, talk  
10 about the heat sink temperatures.

11 Also, the passive heat sink validation,  
12 how we validate the functioning of the heat sink,  
13 and go through the bounding ESBWR standard plant  
14 site parameters, specifically the temperatures  
15 associated with Table 2.01 for site parameters on  
16 ambient temperatures. I'll also talk about the  
17 reactor building temperature monitoring  
18 requirements.

19 MR. MARQUINO: And these are mostly  
20 follow-up items from previous ACRS comments.  
21 We've got about three slides on each of the four  
22 topics that tell our story. So to get to the  
23 bottom line, you have to wait for the third  
24 slide. But we'll go quick.

25 MR. ARCARO: Okay. Passive heat sink

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 issues. The control room habitability area heat  
2 sink is maintained below the analysis values by  
3 maintaining the air temperature below the  
4 requirements in the tech specs, and there's a  
5 table in the basis that tells you the different  
6 air temperatures for the different groups or  
7 zones in the control room habitability area.

8 Permanently installed sensors will  
9 monitor temperature in various locations and  
10 elevations inside the control building, and these  
11 temperatures are what are used for the -- to  
12 contain the passive analysis used for the heat  
13 sink.

14 Tech specs say when the average  
15 temperature of one or more of the rooms is  
16 greater than the limits, we go into an action  
17 statement. Action Statement A-1 requires that we  
18 restore the air temperature within eight hours.  
19 So if air temperature in any of these rooms,  
20 zones, goes above the limit, we're in a tech  
21 spec.

22 MEMBER ARMIJO: What's the limit?

23 MR. ARCARO: There's a slide that's  
24 coming up, but it depends on the different area.

25 The control room habitability area is 74

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 degrees. The HVAC rooms are a higher  
2 temperature.

3 DR. WALLIS: Now it says here "air  
4 temperature of each heat sink." The heat sink is  
5 the wall, isn't it?

6 MR. ARCARO: That's correct.

7 DR. WALLIS: So there's no air  
8 temperature of a wall?

9 MR. ARCARO: The air temperature --

10 DR. WALLIS: The air temperature  
11 adjacent to a wall, isn't it?

12 MR. ARCARO: Yes. The average  
13 temperature of that area.

14 DR. WALLIS: Near the wall. It's the  
15 average temperature of the region beside which  
16 the wall is.

17 MR. ARCARO: Right.

18 DR. WALLIS: But you're not actually  
19 measuring anything in the wall itself?

20 MR. ARCARO: That's correct, that's  
21 correct.

22 DR. WALLIS: Right.

23 MR. MARQUINO: So we're controlling the  
24 concrete at the bottom of the heat sink  
25 temperature by monitoring the air temperature.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: That's right. It's just  
2 the wording is odd. The air temperature of each  
3 heat sink is very peculiar wording. Okay. I  
4 understand what you're doing.

5 MR. ARCARO: Right. So prior to  
6 reaching 85 degrees, and there's a basis on that  
7 number, we'll restore forced ventilation, we'll  
8 reduce loads, we'll make sure we get the  
9 temperature within spec. So we got up to that  
10 point before we end up tripping non -essential  
11 DCIS loads in the control room.

12 So at 85 degrees, we tripped the heat  
13 loads to maintain us below the parameters that  
14 were used in the analysis.

15 MEMBER STETKAR: Mike, that 85 degree  
16 set point is the same set point? That's the  
17 safety-related trip set point that you used to  
18 trip during any heat up?

19 MR. ARCARO: That's correct, right,  
20 right. Yes. It's a --

21 MEMBER STETKAR: Because that was one  
22 of my questions, is what was that temperature.

23 MR. ARCARO: Yes. The safety -related  
24 instruments trip the non -safety loads in the  
25 control room at 85 degrees, and that mimics the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analysis that we did. Okay.

2 Next slide. Okay. The other part of  
3 the tech spec action statement is A-2, which  
4 requires that the average temperature of each  
5 heat sink be restored within 24 hours. So here's  
6 -- before we were looking at air temperatures.  
7 Now we're looking at the heat sink. The average  
8 heat sinks exceed the specified limit.

9 We can verify the restoration of the  
10 heat sinks, either by administrative evaluation,  
11 considering the length of time and extend that  
12 the heat sink average air temperature went above  
13 the limits, or by direct measurement.

14 So two different cases to verify and  
15 validate that the heat sink is within the  
16 requirements of the analysis. Okay. The way you  
17 can do that, the evaluation can provide  
18 temperature profiles based on the initial  
19 conditions, and you use the air temperature to  
20 estimate, validate the concrete temperatures, the  
21 heat sink temperatures.

22 In lieu of that, you can actually go  
23 measure the heat sink temperatures. You can  
24 measure the concrete temperature at the surface,  
25 and determine what the temperature would be.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: That's probably all right.

2 But usually the radiation heat transfer  
3 coefficient is about the same as the convector in  
4 a room like this.

5 So if you had a hot light bulb here, it  
6 would heat the wall, and then the wall could  
7 conceivably be hotter than the air. You don't  
8 have that situation, I think, in the control  
9 room. You're just relying on the air, air  
10 convection to keep the wall cool?

11 MR. ARCARO: That's correct.

12 DR. WALLIS: And that's probably right.

13 But if you did have a big radiation source in  
14 there, that wouldn't be true. If the sun was  
15 shining on the wall, the wall could well be  
16 hotter than the air?

17 MR. ARCARO: That's correct, and I  
18 think that's one of the assumptions.

19 DR. WALLIS: For sun in the control  
20 room, so we're all right.

21 MR. ARCARO: Okay. Next slide.

22 DR. WALLIS: I'm just going to be sure  
23 there isn't something else coming into this.

24 MR. ARCARO: Okay. So those are the  
25 two conditions for the tech spec. If you don't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 meet either the air temperature or the heat sink  
2 temperature, requirements are to be in Mode 3 in  
3 12 hours, Mode 5 at 36 hours.

4 The way we control that, the  
5 implementation of that will be through a COL  
6 item. We have a COL item that relates to control  
7 room habitability area procedures and training,  
8 and that would be where the applicant would  
9 provide this operability evaluation for the heat  
10 sink and the relationship to the air temperature.  
11 Okay, next slide.

12 CHAIRMAN CORRADINI: So now we're onto  
13 the second topic.

14 MR. ARCARO: Okay. Second topic, why  
15 was an analysis chosen for the ITAAC method for  
16 the control room heat sink, rather than an  
17 operational test? So in Tier 1 for the control  
18 building, we validate the passive heat sink by  
19 comparing as-builts with the conditions used in  
20 the analysis.

21 So the critical parameters are the as-  
22 built heat sink dimensions, thermal properties,  
23 exposed surface area, thermal properties and  
24 materials covering parts of the heat sink. If  
25 you put posters up on the wall or painting, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the as-built heat loads.

2 So that's how we do. The way the ITAAC  
3 is written is it's a validation of the analysis.

4 An operational test that would simulate the  
5 limiting design conditions would be extremely  
6 difficult to perform. Like I said, the analysis  
7 itself is a Tier 2 star item. So in the LTR,  
8 there's a table with a list of parameters that  
9 need to be met.

10 Tier 2 star means the NRC needs to  
11 provide prior approval if we change the  
12 methodology of the test. Okay. Next slide.

13 MR. MARQUINO: Of the calculation.

14 MR. ARCARO: Of the calculation, I'm  
15 sorry.

16 MR. MARQUINO: There's a specified  
17 calculation that will be done to validate the as-  
18 built control room.

19 MR. ARCARO: Okay. So here's some  
20 bullets why analysis rather than a test. The  
21 heat capacity of the control room concrete mass  
22 will be validated in ITAAC. This is similar to  
23 other passive functions such as building  
24 structural response and, you know, by validating  
25 the components, the key parameters, that would be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 all you need to do to make sure that the function  
2 is met.

3 Limiting parameters associated with the  
4 passive heat sink could not be readily reproduced  
5 during the performance test. So to get the 117  
6 degree ambient temperature with an 86 -degree  
7 ground temperature during start-up testing in the  
8 middle of the winter would be very difficult to  
9 obtain.

10 You'd end up extrapolating outside of  
11 your normal heat loads and parameters to a  
12 condition that is beyond what you're testing to.

13 Performance tests would have to last for a  
14 period of 72 hours, to simulate the entire event.

15 MEMBER ARMIJO: Before --

16 MR. MARQUINO: I think he's got one  
17 more.

18 MEMBER ARMIJO: I'm sorry. I think  
19 you're making it awfully hard. I've just seen --  
20 I agree. Your analysis is probably --

21 (Simultaneous discussion.)

22 MEMBER ARMIJO: Let me finish asking my  
23 question. Why wouldn't you just run a limited  
24 test? You've got a prediction of time versus --  
25 temperature versus time. You don't have to take

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it up to the extremely, the extreme conditions,  
2 and say hey, we're in the ballpark. A sanity  
3 test, if nothing else.

4 MR. MARQUINO: So any test we did would  
5 not be a design basis test. It wouldn't have the  
6 exact weather conditions. In terms of the heat  
7 loads, we have enough trouble figuring out how to  
8 build the control room and get it to the pre-op  
9 test state, without scheduling in a period where  
10 the non-DCIS loads are going to be powered off,  
11 but all the safety-related loads are going to be  
12 available and powered on.

13 So in terms of the schedule for  
14 performing the start-up test and pre-op test,  
15 having this as a test would have some effect on  
16 when you had completed all of the tests.

17 CHAIRMAN CORRADINI: But I guess, I  
18 think what I hear Sam saying, I know John's going  
19 to ask you more questions. But I think what Sam  
20 is saying is as a pre-operational test, it  
21 doesn't have to be design basis in boundary  
22 condition, but it can be a way of checking your  
23 calculation that you use for your design basis  
24 calculation.

25 MEMBER STETKAR: You're relying on an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analysis and just --

2 MEMBER ARMIJO: See if the analysis is  
3 good.

4 MEMBER STETKAR: You have faith that  
5 the analysis indeed models reality, and you could  
6 in principle change the input parameters to that  
7 analysis, to be consistent with the known input  
8 parameters when you run the pre-operational test,  
9 run the test and see how well your analysis  
10 indeed models reality.

11 And if it models reality quite well,  
12 then you could have reasonable confidence that it  
13 would model reality under design basis  
14 conditions. If it doesn't model reality under  
15 the non -design basis conditions, then there's  
16 some questions.

17 MEMBER ARMIJO: Yes, and I'm not  
18 talking about cranking it up to 117 degrees or  
19 anything like that.

20 MEMBER STETKAR: Well, you can't. I  
21 mean that's outside. You can't do much with the  
22 sun.

23 MEMBER ARMIJO: You just go with what's  
24 reasonable for that, but you know, give you some  
25 experimental verification that your model has got

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 everything covered.

2 MEMBER STETKAR: I think of this as the  
3 analogy. We do a lot of design basis accident  
4 analyses that assume that we can deliver X amount  
5 of flow from injection systems, and yet we don't  
6 rely on those analyses, period. We actually run  
7 pre-op tests to make sure the pumps can put that  
8 flow out.

9 MR. ARCARO: Well, I guess a similar  
10 example would be containment air cooling testing  
11 for Generic Letter 8913. You know, there was a  
12 point where utilities were trying to simulate the  
13 design conditions for these heat exchangers, you  
14 know, and they were extrapolating on the heat  
15 loads that they had to try to get to limiting  
16 conditions.

17 And you know, a lot of utilities, you  
18 know, gave up on the testing and went to  
19 inspection, because it didn't simulate real life.

20 You couldn't get those heat loads in the  
21 containment, and it wasn't a valid test to  
22 represent what it would do under accident  
23 conditions.

24 CHAIRMAN CORRADINI: John, it's your  
25 turn.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: I don't have much more  
2 to say. I don't have much more to say.

3 MEMBER ARMIJO: I think we're in  
4 engineering space, not regulatory space, I think,  
5 and just take actuals and run a simple test.

6 CHAIRMAN CORRADINI: The only thing I  
7 guess I can appreciate where I think they're  
8 coming from is if they were to accede to a pre-op  
9 -- I call it a pre-operational test is what  
10 they're suggesting, not a --

11 (Simultaneous discussion.)

12 CHAIRMAN CORRADINI: Right. But if you  
13 were to accede to a pre-operational test, then  
14 you'd have to develop acceptance criteria for if  
15 you fall within or without. It would be the  
16 equivalent, I know you don't want to hear this,  
17 but the equivalent of a containment leak brake  
18 test. You're building the plant. I was at the  
19 same plant he was at. You shut down everything,  
20 you close everything up and you do the CLRT test.

21 It doesn't work and you come back down.  
22 You pump it back up and you do it until you  
23 match your .1 percent. But my only point is it's  
24 a pre-operational test under some acceptance  
25 criteria and operating conditions for the test.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 That's what I think --

2 MEMBER STETKAR: And the acceptance  
3 criteria would be how well the heat-up analysis -  
4 -

5 CHAIRMAN CORRADINI: Matched the model.

6 MEMBER STETKAR: Matched the model, and  
7 you would - max is the real world.

8 MR. MARQUINO: But in this case, in the  
9 leak rate test, you pump the containment up to  
10 the design pressure, so you're testing at the --

11 CHAIRMAN CORRADINI: Well, you actually  
12 pump it up to 150 percent of design pressure.

13 MR. MARQUINO: So in this case, we  
14 would have a different analysis that we would be  
15 comparing the test to.

16 CHAIRMAN CORRADINI: What I think  
17 they're suggesting, I mean and we understand  
18 where we're coming from, but I think what these  
19 two gentlemen are suggesting is what you're doing  
20 is you're showing that your modeling assumptions  
21 are being used in a controlled manner, and you  
22 can match, within acceptance criteria, for  
23 response.

24 DR. WALLIS: It's the same model. It's  
25 the same analysis.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Simultaneous discussion.)

2 MEMBER STETKAR: It's the same model,  
3 you just put different inputs.

4 DR. WALLIS: Whatever nature gives you,  
5 you put in there.

6 MEMBER STETKAR: And by the way, I'd  
7 expand this discussion to not -- we tend to be  
8 control room -centric on this, but there are  
9 really three areas of the plant. It's the  
10 control room envelope, and then the -- I've  
11 forgotten the ventilation system, but the Q -DCIS  
12 rooms in the control building. It's a different  
13 ventilation system.

14 MR. MARQUINO: Right, control building,  
15 general area.

16 MEMBER STETKAR: Right, and the reactor  
17 building, whatever, clean air ventilation system,  
18 I think, that cools the safety-related areas, you  
19 know, where you have the inverters and the power  
20 supplies and stuff out in the reactor building.  
21 Those are the three areas, I think, you would  
22 take the safety -related equipment. You take  
23 credit for 72 hour passive heat removal.

24 MR. MARQUINO: Well, we'd like to  
25 continue and then maybe cycle back on this after

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the staff has their presentation.

2 CHAIRMAN CORRADINI: That's fine. Keep  
3 on going, keep on going.

4 MR. ARCARO: Okay. So I think we  
5 talked through all the bullets on this. Next  
6 slide. Okay. This is the issue about site  
7 characteristic values. In the Table 2.01 for  
8 site-specific acceptance criteria, there's  
9 criteria that talks about the daily temperatures  
10 associated with both dry bulb temperature and  
11 then the high humidity case.

12 Next slide. So I think the last ACRS,  
13 we went through how does an applicant actually do  
14 this? How is he going to take the numbers and  
15 relate it to the conditions at the site? So in  
16 3H of the DCD, we explained the notes on the  
17 table, how the applicant would use his  
18 temperatures to determine if the passive heat  
19 sink analysis is bounding for that site.

20 So the terms that we use there, the  
21 daily temperature range for summer conditions  
22 associated with the dry bulb temperature, and the  
23 daily temperature range for winter conditions,  
24 and then there's also high humidity. So for dry  
25 bulb temperature conditions, we're looking at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sinusoidal ambient temperature response, as given  
2 by ASHRAE 2005.

3 The applicant will look at his zero  
4 percent max exceedance value, and then he'll look  
5 at -- they'll look at 24 hours either before or  
6 after, and come up with a range based on those  
7 numbers.

8 So the historical zero percent  
9 exceedance for that site, and then we'll look at  
10 a range of 24 hours before and after that, and  
11 come up with an average value based on that.

12 DR. WALLIS: Wasn't it last time we  
13 were looking at some typical curves, and it  
14 seemed to be difficult to unequivocally define  
15 what you meant by "minimum"?

16 MR. MARQUINO: Right, and we -- you  
17 probably aren't recognizing what the changes are  
18 on here, but they're very small changes, where we  
19 replaced terms like the daily value with the  
20 minimum occurring in the previous and successive  
21 24 hours.

22 The staff has -- the staff is going to  
23 bring back those actual temperature graphs, and  
24 we believe that we have a unique definition that  
25 can be used from available met data, to come up

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with the three numbers to characterize the site.

2 DR. WALLIS: What you mean by "minimum"  
3 is the lowest value over 24 hours, even though  
4 it's not necessarily the bottom of a curve? It's  
5 quite clear what you mean by "minimum"?

6 MR. MARQUINO: Yes. You define a  
7 temperature for the dry summer conditions. You  
8 define a maximum temperature, and then you look  
9 at the highest low temperature plus/minus 24  
10 hours, because we're not allowed to credit the  
11 lower of the two temperatures. It's got to be  
12 the higher of those lower temperatures.

13 MEMBER STETKAR: And I think these two  
14 are relatively easy to kind of understand what  
15 they're doing. It's the third, the high humidity  
16 calculation on the next slide that gets more  
17 convoluted.

18 MR. ARCARO: Okay. So here's the new  
19 definition for the diurnal swing with the high  
20 humidity. We took the maximum wet bulb  
21 temperature, and we looked at the coincident dry  
22 bulb temperature for that.

23 Then we looked at the minimum, the  
24 highest low for the wet bulb over -- this would  
25 be over three periods, three before and three

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 after. So that would be three 24 -hour segments.  
2 So we looked at that, and we based -- and we  
3 looked at the dry bulb associated with that  
4 high/low wet bulb temperature.

5 MEMBER STETKAR: I think for this one,  
6 we really need to see those same curves that the  
7 staff had, because this was where the confusion  
8 is, and quite honestly, even reading this and  
9 trying to think about it without those curves --

10 MS. CUBBAGE: The staff's presentation  
11 has the curves in them, so --

12 MR. MARQUINO: Okay. So keep, put a  
13 post-it note on this page. When the staff comes  
14 up, we'll read it relative to actual weather  
15 data.

16 MR. ARCARO: Okay. The next issue is  
17 talking about the as sumptions for the passive  
18 heat calculation for the reactor building. The  
19 concern is how do we -- how are the assumptions  
20 of the heat -up calculation assured?  
21 Specifically, how do we maintain the control  
22 temperatures of the areas in the reactor building  
23 associated with the passive analysis?

24 And we'll point to different sections  
25 in the DCD that show that we're maintaining,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 monitoring, alarming for those areas that have  
2 input into the passive heat -up analysis, this  
3 time for the reactor building.

4 Okay. I guess one of the issues was  
5 why don't we include an LCO for rackable and  
6 temperature monitoring, and this slide here talks  
7 about this being consistent with the standard  
8 tech specs, where other plants, previous vintages  
9 of boiling water reactors, have gotten rid of  
10 that out of tech specs.

11 MR. MARQUINO: And the justification  
12 for not having it in tech specs is that it is  
13 continuously monitored and alarmed in the plant,  
14 and ESBWR is consistent with that. We've  
15 committed in the DCD to monitor area temperature  
16 and have control room alarms on high  
17 temperatures.

18 MR. ARCARO: And I think the next slide  
19 will show a few of those examples.

20 MEMBER STETKAR: But if that  
21 temperature instrumentation was not operable, you  
22 would never get a high temperature alarm.

23 MR. MARQUINO: And you would repair the  
24 inoperable temperature indicators.

25 MEMBER STETKAR: How would you know

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it's inoperable, unless you have a continuous  
2 read-out or something?

3 MR. MARQUINO: Well, I believe the same  
4 indication is used in the A track system to  
5 control the A track system. So if the indication  
6 was wrong --

7 MEMBER STETKAR: If it's failed low, it  
8 won't turn the fans on, and you won't get a high  
9 temperature alarm.

10 MR. MARQUINO: Right, and when you went  
11 in the room, you would find it's really hot. But  
12 we're talking about one -- I think what we're  
13 talking about here is you're talking about a  
14 failure that would be detected by an operator  
15 making -- I'm talking about a failure that would  
16 be detected by an operator making his rounds, if  
17 the normal way of detecting a failure in the HVAC  
18 system didn't work.

19 MEMBER STETKAR: From what I heard you  
20 saying, you're relying -- you know, you're  
21 essentially relying on the fact that it's a  
22 normally operating system. You have alarms in  
23 the control room if temperature in the area is  
24 too high, and as a surrogate for having a tech  
25 spec requirement for operability of that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 temperature instrumentation.

2 I'm saying if the temperature  
3 instrumentation fails low, such that it does not  
4 start the normal HVAC equipment, it's failed low.

5 It won't give you any indication of high  
6 temperature in the control room. So the failure  
7 actually is a contributor to the fact that the  
8 room is heating up, and you don't know the room  
9 is heating up because you don't get the high  
10 temperature alarm.

11 MR. MARQUINO: In one room and at the  
12 same time you have the loss of offsite power, in  
13 other words, that would have to be coincident  
14 with a loss of --

15 MEMBER STETKAR: I'm not talking about  
16 necessarily accident analyses here. I'm just  
17 talking about normal plant operation. This is  
18 temperature instrumentation for those rooms. How  
19 do you verify that it indeed it is available.  
20 I'm not talking about safety-related  
21 instrumentation here necessarily.

22 MR. MARQUINO: Right.

23 MEMBER STETKAR: We're talking about  
24 safety-related rooms in the reactor building,  
25 right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MARQUINO: Also, I think we may --  
2 do you expect you'll have redundancy in the  
3 temperature indications in the HVAC system, Mike?

4 MR. ARCARO: Yes. You would have, you  
5 know, you would have multiple channels for  
6 monitoring temperature, and in the final  
7 analysis, you know, if you had a failed  
8 instrument, it would fail in a condition that  
9 would provide you --

10 MEMBER STETKAR: It depends on what  
11 kind of displays you have in the control room to  
12 tell you that. I mean if you're only relying on  
13 the high temperature without --

14 MR. ARCARO: In the control room, the  
15 reactor building area temperature high is a  
16 minimum inventory parameter. In the HVAC system,  
17 you know, we're going to be doing air flows;  
18 we're going to be doing damper positions. We're  
19 going to be doing fan speed and, you know, flow  
20 rates. We'll be doing temperatures.

21 So there's multiple parameters that  
22 will give you the validation that you're  
23 providing room cooling, you know, in addition to,  
24 you know, operators doing rounds and actually  
25 seeing what the temperatures are.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           The only difference is that it's, you  
2 know, it's not tech spec control, like in the  
3 control building.

4           MEMBER ABDEL -KHALIK: So they're  
5 monitoring. They get high temperature. What are  
6 they going to do about it?

7           MR. MARQUINO: It would fall under the  
8 maintenance rule, to -- depending on the area.  
9 If it was a RTNSS area, it would be maintenance  
10 rule.

11           MEMBER ABDEL -KHALIK: Yeah, the way  
12 they do non-safety systems now is if you had an  
13 indication that's out of spec, you know, it would  
14 fall under the maintenance rule. That would be a  
15 parameter that you would, you know, you would  
16 have an indicator for that.

17           So you would, you know, write a  
18 corrective action item to repair that.

19           MR. MARQUINO: Now if it's safety, if  
20 it's Q -DCIS room, and it's above the EQ  
21 temperature, I think that would indicate that  
22 it's inoperable and they would be forced to --  
23 they'd be forced to declare the equi pment  
24 inoperable.

25           MEMBER ABDEL -KHALIK: And then what do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they do?

2 MR. MARQUINO: And take the actions --

3 MEMBER ABDEL-KHALIK: They have to shut  
4 down within a certain time?

5 MR. MARQUINO: Right.

6 MEMBER ABDEL -KHALIK: So why -- what  
7 difference would it make, putting this in tech  
8 specs and indicating certain time lines  
9 associated with LCOs?

10 MR. MARQUINO: Well, the difference is  
11 you're monitoring -- we've incorporated this as  
12 the basic monitoring of the HVAC functions in the  
13 plant. It doesn't rise to the level of a tech  
14 spec. The difference is if it's tech spec, if  
15 there's any change made, there's an additional  
16 burden on the utility. It has to be reviewed by  
17 the NRC.

18 For example, if you change the -- if  
19 you replace the equipment, you have a different  
20 EQ qualification for the equipment. So you want  
21 to change the number in this -- in the table.  
22 There's a lot of administrative overhead in  
23 changing it, versus if it's not a tech spec, you  
24 can process the paper work internal to the  
25 utility, make the change in the alarm set point,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and satisfy it that way.

2 MEMBER STETKAR: This sounds -- this is  
3 more a question for the staff, I think, because I  
4 kind of think they're relying on legal  
5 interpretations of things. I mean I understand  
6 the reason for not wanting it in a tech spec.  
7 It's a question of without it in the tech specs,  
8 are we sacrificing any protection of high  
9 temperature in those rooms?

10 Because especially in the reactor  
11 building, you're talking about not only the fact  
12 that it's in the reactor building, but some of  
13 those rooms tend to have fairly high heat  
14 supplies. You know, you're talking about switch  
15 gear; you're talking about inverters and things  
16 out in there that could be reasonable heat  
17 sources.

18 I don't know how big your rooms are. I  
19 don't know how fast they heat up, you know. I  
20 guess your heat -up calculations say passively  
21 they don't heat up very quickly, but --

22 MR. MARQUINO: Yes, and we have to  
23 limit the heat load in the rooms in order to make  
24 that true. That's exposed in our analysis.

25 MEMBER STETKAR: But there might --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 well, I'm not going to presuppose things. There  
2 might be justification for, you know, periodic  
3 rounds detecting high temperature, but people  
4 tend not to rely on that for safety-related,  
5 especially for safety-related areas.

6 MR. MARQUINO: But I think the concern  
7 is -- if the concern is one temperature sensor  
8 failure is not going to be detected for a long  
9 period, I think we get more back with you on more  
10 information.

11 MEMBER STETKAR: Yes, I mean that's  
12 sort of the technical concern. The second bullet  
13 on there -- that was curious. You said "During  
14 development of the current standard tech specs."

15 Current standard tech specs apply to BWR-6s?

16 MS. CUBBAGE: Yes.

17 MEMBER STETKAR: You know, because  
18 before BWR-6, you basically didn't have this same  
19 kind of stuff, equipment, out in the reactor  
20 buildings. So some of the concerns about high  
21 temperatures for safety -related power supplies  
22 and you know, inverters and things were sort of a  
23 moot point up until BWR-6s.

24 MR. MARQUINO: Yes. This is the case  
25 for BWR -6 tech specs. Joe Friday and our Reg

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Affairs staff looked at, I think it was River  
2 Bend and Grand Gulf, or at least two BWR -6  
3 plants, in terms of their -- he confirmed that  
4 they didn't have this in their tech specs.

5 MEMBER STETKAR: Okay.

6 MR. ARCARO: Okay. I think we talked  
7 through these. Here's the sections of the DCD  
8 that provide flows, temperatures, indications,  
9 alarms, both for normal and design deficient.  
10 Table 3H -3 and 9 have the environmental  
11 conditions, the actual limits and the  
12 temperatures that are expected during accident  
13 conditions.

14 And then Table 18 -1 is the minimum  
15 inventory that shows that the reactor building  
16 area temperature is a parameter that's monitored  
17 in the control room.

18 In summary, we think the design meets  
19 GDC 19 habitability requirements for the control  
20 room habitability area, related to the heat  
21 removal conditions. The design validation  
22 surveillance procedures assure that the functions  
23 will be met, and the site parameters can be  
24 interpreted and implemented by COL applicants. I  
25 think when we see the staff's presentation, we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 can walk through the specifics there.

2 And then the controls we have in place  
3 for the reactor building, temperature monitoring,  
4 are in line with existing BWR practices for tech  
5 specs, and provide the same assurance for EQ life  
6 for equipment.

7 MEMBER STETKAR: Mike, before we switch  
8 to -- I know you've got a couple of other slides  
9 here.

10 CHAIRMAN CORRADINI: Those are backups.  
11 I think he's giving something to us.

12 (Simultaneous discussion.)

13 MR. MARQUINO: We have one more slide  
14 on here.

15 MR. ARCARO: I've got to talk just  
16 about Chapter 16 update.

17 CHAIRMAN CORRADINI: Okay.

18 MEMBER STETKAR: I was going to ask him  
19 sort of a 16 and sort of a control room heat-up.

20 CHAIRMAN CORRADINI: Do you want to do  
21 the update on 16 first?

22 MR. ARCARO: I think that might be  
23 best.

24 MEMBER STETKAR: Actually no. I'd  
25 rather ask my question now, while people are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thinking about control room. The question is,  
2 and it's the -- boy, I wish I could speak  
3 clearly. The control room envelope has  
4 temperature sensors that automatically de -  
5 energize non-safety related heat loads, you said,  
6 when the temperature reaches 85 degrees  
7 Fahrenheit.

8 MR. ARCARO: Right.

9 MEMBER STETKAR: And they're safety-  
10 related, four divisions, two out of four  
11 redundancy, all of that kind of stuff. Are those  
12 -- is the availability and operability of those  
13 temperature sensors controlled by the tech specs  
14 anywhere?

15 MR. ARCARO: Yes.

16 MEMBER STETKAR: Where?

17 MR. ARCARO: It could be in the  
18 instrumentation section there --

19 MEMBER STETKAR: Okay. I looked in  
20 control room HVAC, and I couldn't --

21 MR. ARCARO: It's not in 3; it's 3-7.

22 MEMBER STETKAR: It's not in 3-7.

23 MR. ARCARO: Or 3-3, I believe it is.

24 MEMBER STETKAR: Okay. If you can find  
25 a reference or somebody can, I'd appreciate it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I didn't do a thorough search, but there's a lot  
2 of stuff in the tech specs. I looked at the most  
3 likely place that I thought, but it's not there.

4 MR. ARCARO: It is.

5 MEMBER STETKAR: It is, good. It is,  
6 that's good. If you'd just give me the  
7 reference, I'd appreciate that.

8 MR. MARQUINO: Okay. We do have  
9 follow-up to one of your comments on Chapter 16.  
10 You were concerned about our staggered, well the  
11 lack of a staggered test interval for  
12 surveillances on the passive safety systems. So  
13 we had some which were simply once every ten  
14 years, and you asked why don't you test one at  
15 the first outage and another one at the second  
16 outage and so on.

17 So we've made, we discussed this with  
18 the staff, and we're in the process of making  
19 changes to the tech spec, to add more staggered  
20 test intervals, and they include the GDCS  
21 injection lines, the GDCS equalizing line, the  
22 ICPCCS pool, moisture separator flow paths, and  
23 the GDCS deluge lines.

24 So they will be set on a staggered  
25 interval, based on the old surveillance interval

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and the number of systems or divisions that can  
2 be tested.

3 MEMBER STETKAR: So essentially, you'll  
4 test each division every ten years, if that's  
5 what's the interval?

6 MR. ARCARO: Yes.

7 MEMBER STETKAR: But on a staggered  
8 basis?

9 MR. MARQUINO: Right.

10 MEMBER STETKAR: Good.

11 MR. ARCARO: So your earlier question  
12 about testing the N-DCIS, that's described in the  
13 Surveillance Requirement 3725, and the functional  
14 test is in 3372. So that's where we do the  
15 instruments.

16 MEMBER STETKAR: No, I was -- I'm  
17 sorry.

18 MR. ARCARO: This is the testing to  
19 show that the instruments will trip the N-DCIS  
20 off.

21 MEMBER STETKAR: Where is it? I'm  
22 sorry.

23 MR. ARCARO: 3372.

24 MEMBER STETKAR: 3372.

25 MR. ARCARO: That's correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: That's a surveillance  
2 requirement. Okay. But there's no operability  
3 requirement? There's no LCO for those  
4 instruments, is there?

5 MR. ARCARO: No, there is.

6 MEMBER STETKAR: Oh, is there?

7 MR. ARCARO: Right. The logic system  
8 functional tests. So we're on a --

9 MEMBER STETKAR: It's a surveillance  
10 requirement?

11 MR. ARCARO: Right.

12 MEMBER STETKAR: It's not an LCO.

13 MR. ARCARO: The LCO 3372 is the  
14 instrument test for the switches that will trip  
15 off N-DCIS.

16 MEMBER STETKAR: I don't have that.

17 MR. MARQUINO: You're looking for  
18 surveillance on the temperature sensors?

19 MR. ARCARO: Right.

20 MEMBER STETKAR: I was looking for an  
21 operability requirement on the temperature  
22 sensors, such that if you had -- you know, you  
23 could have one train inoperable indefinitely. If  
24 you had two trains inoperable, they could be  
25 inoperable for 72 hours, or something like that,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not just a surveillance requirement.

2 MR. MARQUINO: All right. Let's, we'll  
3 look while the staff is up.

4 MR. HARBUCK: This is Craig Harbuck  
5 from the Technical Specifications Branch. I  
6 could just clear that up right quick.  
7 Surveillance requirements must be met in order to  
8 meet the LCO. The LCO requires that the  
9 instrumentation functions in 3.3.7.2 be met  
10 during modes of applicability.

11 So if you don't meet that surveillance  
12 on one system functional test, you're not meeting  
13 the LCO, and you would enter the actions for the  
14 instrumentation divisions affected.

15 MEMBER STETKAR: Well, what I was  
16 curious about, and again, I'm trying to do this  
17 real-time, which is not fair, as are you, which  
18 is not fair. I see things in 3.3.7.2 that talk  
19 about actuation divisions, but I don't know --

20 In particular, I can't find anywhere in  
21 the bases document for the tech specs, I find  
22 four sets of instrumentation in the bases  
23 documents listed under control room/HVAC, none of  
24 which are these particular temperature sensors.

25 They're act uation signals for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 transferring to the EFUs. They're actuation  
2 signals for isolation. I don't find any  
3 actuation signals for turning off the non-safety  
4 heat loads. So that's -- it might be in there  
5 somewhere, but I'm having problems finding it.

6 MR. HARBUCK: Well, I'm pretty sure  
7 there's a test to verify actuation on a simulated  
8 or real signal in the CRHAVs specification in  
9 Section 372, I believe it is.

10 MR. MARQUINO: Yes. Mike found that.

11 MR. HARBUCK: So I think that's the  
12 test that covers this.

13 MR. ARCARO: The Surveillance  
14 Requirement 3.7.2.5 verifies selected main  
15 control N-DCIS electrical loads automatically de-  
16 energized on an actual or simulated initiation  
17 signal.

18 MEMBER STETKAR: I'm sorry. 3.3.7.2.5?

19 MR. ARCARO: 3.7.2.5.

20 MEMBER STETKAR: 3-7. 3.7.2.5.

21 MR. ARCARO: Right.

22 MR. HARBUCK: Plant Systems section.

23 MEMBER STETKAR: Okay.

24 MR. ARCARO: Right, and then in  
25 addition to that, you do a logic system

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 functional test for LCO 3.3.7.2. I thought that  
2 was your question.

3 MEMBER STETKAR: Well, I was looking up  
4 in 3.3.7. Let me keep the meeting going here and  
5 get the staff up, and I'll search through things  
6 here.

7 MR. ARCARO: I think that's it for our  
8 presentation, if there's no questions.

9 CHAIRMAN CORRADINI: Other questions?

10 (No response.)

11 CHAIRMAN CORRADINI: Okay, thank you.  
12 Amy, is the staff ready to talk this afternoon?

13 MS. CUBBAGE: Yes, we are.

14 CHAIRMAN CORRADINI: That would be  
15 wonderful.

16 MS. CUBBAGE: Our meteorologist is out  
17 of the office, but we're going to pinch -hit for  
18 him.

19 CHAIRMAN CORRADINI: Well, I trust you  
20 to get a good designated hitter.

21 MS. CUBBAGE: Yes. Jim O'Driscoll is  
22 going to do his very best.

23 CHAIRMAN CORRADINI: He'll do his best.

24 (Off mic discussions.)

25 CHAIRMAN CORRADI NI: You guys are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ready?

2 MR. GALVIN: We're ready.

3 CHAIRMAN CORRADINI: Okay. Have at it.

4 MR. GALVIN: All right. The staff is  
5 here today to present on the habitability area,  
6 issues related to Section 6.4 and Section 9.4,  
7 and actually, as GEH mentioned, we're following  
8 up on several issues previously identified by  
9 ACRS. So Jim?

10 Chapter 6/Staff

11 MR. O'DRISCOLL: Good afternoon. My  
12 name is James O'Driscoll, and I, along with Craig  
13 Harbuck, are here to provide the Subcommittee  
14 discussion on the remaining issues related to  
15 Section 9.4, HVAC, and Section 6.4, Control Room  
16 Habitability.

17 Next slide. In particular, this  
18 briefing will address the follow-up items from  
19 the previous briefings to the ACRS Subcommittee  
20 held on 19 May 2010 for Chapter 6.4 and 9.4, and  
21 the Subcommittee meeting held on August 17th,  
22 2010 for Chapters 2 and 16. We will also answer  
23 your questions.

24 Here's the staff team, Dennis Galvin,  
25 project manager for 9.4; Bruce Bovol is project

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 manager for 6.4; Jim O'Driscoll is a lead  
2 reviewer for Chapter 6.4 and 9.4, with Ed  
3 Forrest, Syed Haider and Shie -Jeng Peng  
4 supporting. Also Brad Harvey for Chapter 2.3 and  
5 Craig Harbuck for Chapter 16.

6 Next slide. The four issues we'll  
7 discuss today are the following. One, we will  
8 provide and discuss heat-up profiles for the  
9 three models, CONTAIN 2.0, GOTHIC and the NRC's  
10 First Principles Analysis, used to model the  
11 control room hazard heat sinks and their  
12 performance post-accident.

13 Two, we will discuss details of the  
14 tech spec surveillance on the control room  
15 habitability area heat sink's temperatures.  
16 Three, we will discuss details on verification of  
17 related site characteristics, and four, we will  
18 discuss how assumptions used in the reactor  
19 building heat-up calculation are assured.

20 Next slide. The staff's review focused  
21 on the applicant's submitted CONTAIN 2.0 analysis  
22 in two areas. One was a staff review of the  
23 suitability of the use of CONTAIN 2.0 as a method  
24 to model the ESBWR control room heat-up, as  
25 opposed to alternate analysis demonstrations,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 methods such as GOTHIC or a First Principles  
2 approach.

3 The staff did this by comparing the  
4 submitted analysis with a GOTHIC analysis that  
5 was submitted by the applicant to support RAI  
6 9.4-29, which was related to the control room  
7 habitability area mixing, that's air mixing.

8 The GOTHIC analysis was updated by the  
9 staff with the current control room habitability  
10 area load, heat loads, and EFU, emergency fan  
11 unit fan loads. In addition to this, the staff  
12 requested the applicant to provide a First  
13 Principles calculation, which was provided to the  
14 staff in September 2009.

15 Based on review of this calculation and  
16 the staff's need to perform sensitivity studies,  
17 the staff decided it would be worthwhile to  
18 perform -- the study the problem from a First  
19 Principles on its own, and it developed its own  
20 First Principles calculation of the GE/ESBWR  
21 control room habitability area.

22 Two, the second area the staff focused  
23 on was the need to understand the sensitivities  
24 in the calculations input assumptions, in order  
25 to gain insight on what parameters are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 significant to the outcome, what input parameters  
2 are significant.

3 The staff's focus was on the heat sink  
4 properties, heat sink initial temperatures and  
5 outside environmental conditions, since these  
6 things produce the most significant changes in  
7 the control room habitability area temperature  
8 and humidity. The results of these studies were  
9 discussed in earlier ACRS meetings.

10 In summary, the staff reviewed the  
11 submitted CONTAIN 2.0 analysis. The staff  
12 reviewed a GE First Principles Analysis. The  
13 staff developed its own First Principles model to  
14 study the problem. The staff also performed one  
15 run using a GOTHIC model updated by the staff, to  
16 the current heat load and EFU fan flow values.

17 Upon review of the closest in behavior  
18 of the overall heat -up, and the closeness of the  
19 final temperature results, in the base cases for  
20 the three models, and with an understanding of  
21 the remaining differences between the three  
22 models, including initial conditions that were  
23 not reconciled, the staff was satisfied that the  
24 submitted CONTAIN model could be used to model  
25 the heat of the ESBWR control room habitability

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 area.

2 Subsequently, the staff focused on the  
3 submitted CONTAIN 2.0 analysis and the staff's  
4 First Principles Analysis to perform further  
5 sensitivity studies. 24 sensitivity runs were  
6 performed using the applicant's CONTAIN 2.0  
7 analysis and the staff's First Principles  
8 Analysis.

9 Next slide. After reviewing the  
10 results of the varied sensitivity studies, using  
11 CONTAIN and the NRC First Principles Model, and  
12 the results of the updated GOTHIC analysis, the  
13 staff concluded the following:

14 One, after the effects of the remaining  
15 differences, including initial conditions are  
16 considered, the staff concluded that the heat-up  
17 rates for all models agree. This can be seen in  
18 a comparative run of the three models on the  
19 following slide. We'll get to that slide in a  
20 minute.

21 Two, CONTAIN and the staff's First  
22 Principles model behaves similarly when various  
23 parameters were changed during the 24 sensitivity  
24 runs. The staff's First Principles model was  
25 slightly higher than CONTAIN 2.0. The greatest

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 difference between the staff's First Principles  
2 model and contain on these runs was less than  
3 four degrees, most runs aver aging about 2.5  
4 degrees.

5 The staff attributes the higher control  
6 room habitability area temperatures obtained by  
7 the First Principles model to difference between  
8 the model and CONTAIN, described in the white  
9 paper submitted by the staff to the ACRS in July.

10 Briefly, these differences are the following:

11 First, more heat is assumed to enter  
12 the control room habitability area from adjacent  
13 spaces from those interior wall structures that  
14 face rooms with heat generation. The staff's  
15 First Principles model conservatively assumed  
16 that 50 percent of the heat generated in adjacent  
17 rooms enters the heat structures common room  
18 habitability area.

19 Second is the staff ignored steel  
20 structures, which are five of the 21 heat  
21 structures modeled in the applicant's CONTAIN  
22 model, in order to reduce the complexity of the  
23 model.

24 Third is that CONTAIN uses the  
25 temperature distribution in each heat structure,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 resulting from an earlier soaking phase in the  
2 initial condition. It's a three -step --  
3 structured in three steps . The initial  
4 temperature distribution used in CONTAIN ranged  
5 from 74 degrees to 79.9 degrees for all solid  
6 structures, with the exception of the wall facing  
7 the soil, with a mean initial temperature of 82.8  
8 degrees Fahrenheit.

9 The staff's First Principles model  
10 assumed an initial 80 degree uniform temperature  
11 for all heat structures. Since the soil -facing  
12 wall is only 16.6 percent of the total mass of  
13 the heat sink, overall, this is a conservative  
14 simplification with respect to CONTAIN.

15 Finally, another difference is that the  
16 staff's First Principles model did not credit  
17 one-half of the mass of that one heat structure  
18 facing the soil, in order to account for the heat  
19 absorption from the 86 degree Fahrenheit soil.

20 As previously stated, primarily due to  
21 the similarity and response to the sensitivity  
22 studies comparing the staff's model and the  
23 design basis CONTAIN model, the staff gained  
24 confidence in the applicant's treatment of the  
25 control room habitability area, and concludes

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that CONTAIN 2.0 is an acceptable means to  
2 demonstrate the passive heat sink's performance  
3 for the ESBWR control room habitability area.

4 The remaining differences in  
5 temperature results between the two models is  
6 judged to be small, and could likely be reduced  
7 further if the staff's conservative  
8 simplifications were eliminated from its First  
9 Principles model. Next slide.

10 MEMBER ABDEL-KHALIK: Now your argument  
11 is that these graphs are within two to four  
12 degrees, and that is true. But my concern is not  
13 the error in the vertical direction, but the  
14 variation in the horizontal direction. In one  
15 case, you cross the boundary after 72 hours, and  
16 in another case you cross the boundary after 48  
17 hours.

18 MR. O'DRISCOLL: That's correct. I'm  
19 going to go through why that is. The top -- I  
20 want to explain each graph.

21 The staff was asked to provide a  
22 graphical comparison of some selected runs from  
23 different models. The slide displays is their 72  
24 hour heat-up profile from CONTAIN and GOTHIC, and  
25 the staff's First Principles base case runs,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 along with one First Principles run showing the  
2 sensitivity of the changing concrete density.  
3 That's that dark blue one.

4 The bottom green line is the  
5 applicant's CONTAIN 2.0 analysis, submitted and  
6 referenced in the DCD, and that reaches a final  
7 temperature of 92.048 degrees in the control room  
8 at 72 hours. The light blue line is the staff's  
9 First Principles model, using the same values for  
10 concrete as those used in the CONTAIN 2.0 one.  
11 It's 120 pound per cubic foot concrete, and that  
12 temperature is 95.71 degrees.

13 Please note that this also includes the  
14 effects of the conservatively higher heat sink  
15 uniform temperature discussed earlier. There are  
16 higher heat sink temperatures assumed at the  
17 beginning of the analysis, which causes the heat  
18 rate to go, to rise.

19 As discussed earlier, generally these  
20 -- there was about a two to four degree  
21 difference between the staff's First Principles  
22 model and CONTAIN. Both models behaved similarly  
23 when parameters were changed, thus providing  
24 confidence to the staff that CONTAIN is a valid  
25 way of estimating the control room habitability

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 area heat -up in the ESBWR control room  
2 habitability area. For example --

3 DR. WALLIS: This dashed line, this  
4 black line is the criteria?

5 MR. O'DRISCOLL: That's the acceptance  
6 criteria, correct.

7 DR. WALLIS: And two of your models  
8 don't meet the acceptance criteria?

9 MR. O'DRISCOLL: Two of the models  
10 don't because -- but that can be explained.

11 DR. WALLIS: So why is this a  
12 confirmatory analysis, but they don't lead to --  
13 usually, you should satisfy yourself that even  
14 though you're conservative, you still meet the  
15 criteria?

16 MR. O'DRISCOLL: Right. What we had to  
17 do -- that's a good point. ? What we had to do,  
18 what I'm trying to say for this review, we had to  
19 first determine if CONTAIN is a valid tool for  
20 this application, and so we used other models to  
21 get assurance, confidence that the control room  
22 was behaving in the way we would expect.

23 So we used a multi-node code as updated  
24 by the staff, and we used a single node that we  
25 generated ourselves and created ourselves.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: The single node is  
2 the red?

3 MR. O'DRISCOLL: No. I'll continue on.  
4 I'll go through that.

5 DR. WALLIS: Blues are the single node.

6 CHAIRMAN CORRADINI: Excuse me.

7 MR. O'DRISCOLL: Okay. I'll just  
8 continue this, and we can -- I'm almost half  
9 through here.

10 DR. WALLIS: What puzzles me is that  
11 the biggest, the difference between say the green  
12 and light blue starts off right at the beginning.

13 MR. O'DRISCOLL: That's right. I can  
14 go through --

15 DR. WALLIS: It seems to be an initial  
16 condition that's somehow different, rather than  
17 the model itself?

18 MR. O'DRISCOLL: That's correct, that's  
19 correct, and --

20 MEMBER ARMIJO: And you made that point  
21 with your initial assumption.

22 MR. O'DRISCOLL: That's right. I mean  
23 one model, and the thing is is that to change and  
24 to get all the clocks to align would take an  
25 inordinate, in my opinion as a reviewer, amount

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of resources. What we're trying to do here is  
2 not to get all the clocks to read the same time,  
3 but to make sure that they're ticking at the same  
4 rate. Those differences can be explained, and we  
5 understand what they are. I believe we're at  
6 that point.

7 DR. WALLIS: But isn't the initial  
8 condition -- why is the initial condition so  
9 different? Why don't you just have them all  
10 start at the same point?

11 MR. O'DRISCOLL: Because we would have  
12 to update every single heat sink temperature in  
13 the model to do that.

14 DR. WALLIS: Nothing's happened yet at  
15 the beginning. I mean heat sinks are irrelevant  
16 at the beginning?

17 MR. O'DRISCOLL: I guess, Syed, maybe  
18 you might want to explain how much -- what  
19 mechanically would it take to align the initial  
20 conditions for, let's say, our First Principles  
21 model, and CONTAIN 2.0?

22 DR. WALLIS: Yes.

23 MR. HAIDER: Hi, Syed Haider. CONTAIN  
24 uses an initial temperature distribution that is  
25 -- that comes out of Phase 2. You know, CONTAIN

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 models the entire phenomenon in a three step  
2 process. In the first phase, it's a soaking  
3 phase. In the second phase, it's an eight hour  
4 NCO digit model while keeping the room  
5 temperature at 85 degree Fahrenheit.

6 So what happens at the end of the  
7 second phase in CONTAIN, all structures have a  
8 temperature distribution, and those temperatures  
9 are somewhere between 74 to 79 degree Fahrenheit.

10 To do that within the First Principles model  
11 would take a lot more effort. So we had to  
12 assume a uniform temperature.

13 So we assumed a uniform 80 degree  
14 Fahrenheit temperature. While to do that in  
15 First Principles model, we would have to  
16 replicate exactly what the initial conditions  
17 were coming out of this Step 2 of the CONTAIN  
18 model, and that would take a lot of time. That's  
19 why it was not done.

20 But what we assumed was conservative.  
21 That's the main point, and these individual  
22 differences are not the only -- are not the only  
23 difference. There are three more differences  
24 that --

25 DR. WALLIS: But the biggest difference

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is in the first hour. Once you've got that, then  
2 they're sort of parallel.

3 MR. O'DRISCOLL: Yes. Let me explain  
4 that. I had this question written down actually.

5 The GOTHIC model assumes, was submitted to  
6 address the RAI on thermal gradience in the  
7 control room. That's what that was for. The  
8 input deck was reviewed by the staff and we  
9 updated.

10 The model analyzed the control room in  
11 a single step. That was a one -stage model. At  
12 the beginning of that model, all heat sinks --  
13 excuse me, the air temperature of the control  
14 room was set at 87 degrees.

15 The CONTAIN 2.0 analysis consists of  
16 three steps: The output of which feeds the input  
17 of the subsequent steps. CONTAIN Step 1 consists  
18 of a soak period, where the heat sinks and  
19 sources are allowed to function, assuming the  
20 control room habitability area air temperature is  
21 stable at 74 degrees.

22 The output of this run is used as input  
23 data for an eight hour run, where the control  
24 room habitability area air temp is set up, is set  
25 to 85 degrees, simulating a control room

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 habitability area ventilation system degradation.

2 The output of this run is fed into Step 3, which  
3 is the 72 hour run, with the control room  
4 habitability area ventilation system shut off,  
5 and heat removal performed solely by the action  
6 of the heat sinks.

7 The staff's First Principles analysis  
8 is a single step model. The staff chose to use  
9 an 80 degree Fahrenheit uniform temperature for  
10 all heat sinks, conservative with respect to  
11 CONTAIN temperature distribution condition. The  
12 staff's First Principles model also set the air  
13 temperature in the room to 85 degrees at time  
14 zero, to match the CONTAIN analysis.

15 For CONTAIN, since there are -- there's  
16 already a substantial delta T between the heat  
17 sinks and the air, the heat sinks bring down the  
18 temperature of the control room until the heat  
19 input and the output rates are equal.

20 GOTHIC, on the other hand, has a  
21 similar delta T between the heat sinks and the  
22 air that started the analysis. The main control  
23 air is at 78 degrees at the start of the  
24 analysis. Thus, the room air temperature must  
25 rise to a value to where there will be enough

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 difference and potential to drive the heat sink  
2 at a rate, excuse me, drive heat into the heat  
3 sinks at a rate that matches the heat input rate.

4 For the staff's First Principles model,  
5 the difference between the heat sinks and the  
6 control room habitability area air temperature,  
7 80 and 85 degrees, respectively, causes the  
8 control room habitability air temperature to rise  
9 about a degree and a half, until the heat input  
10 and output rates are equal.

11 DR. WALLIS: So it's all in that first  
12 hour. I mean there's an adjustment that occurs,  
13 depending on the models, in the first hour. The  
14 CONTAIN goes down; the NRC models go up.

15 MR. O'DRISCOLL: That's right.

16 DR. WALLIS: And that's what the main  
17 differences between them is.

18 MR. O'DRISCOLL: Well, it's not exactly  
19 -- that is a main difference. But another main  
20 difference is we also assumed much more heat  
21 coming in from surrounding heat sources. So that  
22 will drive the rate slightly, as you go through  
23 the 72 hours, which will drive a delta as well.  
24 So that's also causing a change.

25 MEMBER ARMIJO: Why did you run 140

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pound concrete case, since that's not what the  
2 CONTAIN analysis used?

3 MR. O'DRISCOLL: The CONTAIN analysis  
4 used 140, 120 pound concrete as their  
5 conservative submitted analysis. The DCD  
6 specifies 150 pound concrete to build this  
7 control room.

8 So what we did is we said let's do a  
9 sensitivity study of more denser concrete, but  
10 one that is still conservative with respect to  
11 what is specified in Tier 2, and that's put there  
12 to show the benefit of the higher dense, of more  
13 dense concrete.

14 MEMBER ARMIJO: Sure. In one case it's  
15 converging; in the other case, that initial delta  
16 stays the same.

17 CHAIRMAN CORRADINI: I guess I  
18 understand what you're trying to do, but I'm not  
19 sure if you're helping your case or hurting your  
20 case by the calculation. I think what Professor  
21 Wallace is asking is a fair point, which is your  
22 green and your light and your dark blue curves  
23 are going two different directions.

24 You're saying, if I understand your  
25 argument, that that's because in one case CONTAIN

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 soaks it at one temperature, and then turns on  
2 the transient and for eight hours to get it to  
3 another temperature, but that's not enough time  
4 to get all the concrete to the different  
5 temperatures.

6 So you create an internal temperature  
7 difference, because when you turn on the long-  
8 term calculation, the concrete continues to cool  
9 down the room. So that's the --

10 MS. CUBBAGE: I just want to interject  
11 for a moment on the reason we did these analyses.

12 We we re trying to inform our review, do  
13 sensitivities, find out what was important, find  
14 out and explore margins, and then at the request  
15 of the Committee, we plotted these, because you  
16 wanted to see them together.

17 CHAIRMAN CORRADINI: Right, correct.

18 MS. CUBBAGE: So I think you need to be  
19 careful about what message we're trying to give  
20 you here.

21 MR. O'DRISCOLL: We had a choice of  
22 giving you something new, but we want to give you  
23 what you saw already in the white paper, and talk  
24 to that.

25 CHAIRMAN CORRADINI: That's fine.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. O'DRISCOLL: That dark blue line is  
2 a sensitivity run.

3 CHAIRMAN CORRADINI: Right, but let me  
4 just finish my question. I think what I observed  
5 is correct, which is the green line goes down  
6 because I have a gradient in temperatu re in the  
7 solid, which is cooling the room.

8 The light blue and the dark blue lin  
9 got up, and that's what I think you said, but I  
10 didn't catch.

11 MR. O'DRISCOLL: Okay, okay, sure.  
12 We're talking initial conditions again. The  
13 reason why the green line goes down is because at  
14 the start of Phase 3 in the applicant's submitted  
15 analyses, the room is at this 85 degree  
16 temperature, but you have very cool heat sinks.

17 So what that acts -- it's not an  
18 official condition, and it's pulling down -- it  
19 doesn't need that much of a delta T.

20 DR. WALLIS: I thought the heat sinks  
21 were supposed to come into equilibrium with the  
22 room? They don't do that.

23 (Simultaneous discussion.)

24 MR. O'DRISCOLL: What the applicant did  
25 is they did their analysis in three steps. Phase

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 zero is when the put the heat sinks in  
2 equilibrium with the room. Then what they wanted  
3 to do is they wanted to simulate a control room  
4 air conditioning system malfunction, but  
5 something that it would -- something at the worse  
6 case, but would still allow you to operate for  
7 eight hours, which is the limit of the allowed  
8 time, before they started their accident period.  
9 So conservatism.

10 CHAIRMAN CORRADINI: And just to,  
11 because that's a good point. But just to make  
12 sure, did we know that before? That's a piece, I  
13 guess, that maybe I missed.

14 MR. O'DRISCOLL: Well, we did discuss  
15 that before.

16 CHAIRMAN CORRADINI: Okay.

17 MR. O'DRISCOLL: And the other thing to  
18 point is that you see, if you did this -- what we  
19 found out is the room rapidly rises to 85 degrees  
20 or so. But it's really -- you really want to say  
21 that there's about a ten degree delta T between  
22 the heat sinks and the heat sources before the  
23 heat input is matched to the heat output.

24 MR. MARQUINO: This is Wayne Marquino  
25 for GE. Yes, I want to confirm that for a long

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 time, we've had this Step 2 in the analysis, and  
2 the reason is to provide some -- to provide in  
3 the 72 hour coping period a temperature that's  
4 above normal, so that if we lose HVAC in the  
5 control room, we don't have to immediately scram  
6 or take compensatory actions.

7 So we have a low temperature that's in  
8 the tech spec, and then we have an eight hour LCO  
9 that's in the tech spec, and we've included that  
10 eight hours in our heat-up analysis.

11 CHAIRMAN CORRADINI: From a  
12 conservative standpoint?

13 MR. MARQUINO: Yes.

14 CHAIRMAN CORRADINI: Okay, thank you.

15 DR. WALLIS: But still, I mean  
16 everything depends on what happens in the first  
17 few minutes or something, to the green and blue  
18 curves. Therefore, they're kind of power levels.

19 So what you're telling me is everything is  
20 sensitive to what you do in your second  
21 condition.

22 MEMBER STETKAR: Let me ask just a  
23 simple question, because I don't understand all  
24 of this stuff. How do these analyses account for  
25 the non safety related heat sources in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 control room?

2 MR. O'DRISCOLL: The analysis assumes  
3 that those non -safety heat sources are not in  
4 operation. There's 9630 watts of sensible heat  
5 assumed. That number is in Tier 2, and that  
6 number is also in the design basis heat -up calc.  
7 That's the Tier 2 star information.

8 So the applicant must verify. That's  
9 one of the things they must verify that the end,  
10 when they -- in their as -built plant, that  
11 they're not going to have safety and un --

12 MEMBER STETKAR: In the real world,  
13 they will be operating until they're shut off.  
14 The time at which they're shut off depends on the  
15 time at which -- I originally thought it was two  
16 hours, because in the design basis vent, the non -  
17 safety stuff maintains power for two hours. This  
18 obviously is shutting them off earlier, I think.

19 MR. MARQUINO: This is Wayne Marquino.

20 MEMBER STETKAR: This is like shutting  
21 them off at time zero, which is curious.

22 MR. MARQUINO: This is Wayne Marquino,  
23 GE. We have provided for eight hours of all of,  
24 basically all of the non -safety DCIS loads are in  
25 our analysis for eight hours, provided that the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 control room temperature is below 85. If it gets  
2 to 85, then those loads have to be tripped, and  
3 they are tripped.

4 MEMBER STETKAR: It's automatic.

5 MR. MARQUINO: Beyond that, I have to  
6 check on this, but there's a limited amount of  
7 non-safety loads that will be powered by a  
8 battery for a short period of time, and they're  
9 in the analysis.

10 MEMBER ABDEL-KHALIK: What's time zero  
11 on this graph?

12 MR. MARQUINO: Time zero is --

13 MEMBER ABDEL-KHALIK: On this graph.

14 MR. MARQUINO: Okay. Time zero is the  
15 complete loss of cooling in the control room,  
16 following eight hours at 85 degrees.

17 MEMBER ABDEL-KHALIK: So time zero is  
18 plus eight?

19 MR. MARQUINO: Yes.

20 MEMBER STETKAR: No, no, no. Minus  
21 eight on this is the control room staffed, the  
22 control room air temperature stepped from its  
23 normal temperature, which is around 74 to 85  
24 degrees. So there was some degradation of the  
25 HVAC system.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: Look at the green curve  
2 when -- why is it when you turn off the cooling,  
3 it gets colder?

4 MR. BARRETT: This is Antonio Barrett  
5 from GEH, and the reason why it gets colder is  
6 because the concrete temperature is very cold,  
7 but the air temperature is very high. The air  
8 temperature at that exact moment is 85 degrees  
9 Fahrenheit, and the concrete temperature is  
10 something a lot lower.

11 DR. WALLIS: But this has been going on  
12 --

13 MR. BARRETT: And the heat capacity of  
14 the air is very low.

15 DR. WALLIS: But this has been going on  
16 before though.

17 MR. MARQUINO: For eight hours, and  
18 then at eight hours you trip these loads, so you  
19 reduce -- you actually reduce the heat load at  
20 time zero by tripping the non-safety loads.

21 MEMBER STETKAR: By tripping those  
22 loads. I'm not a code guy, and I don't  
23 understand how the codes work. I'm sort of a  
24 simple-minded engineer. Is it possible to run  
25 one of these codes with an initial condition that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 says I'm starting at a temperature that is within  
2 the normal tech spec operating temperature, and  
3 the air temperature is equalized with the  
4 concrete temperature, which is a fundamental  
5 assumption in the heat sinks?

6 And from that T zero condition, then  
7 turn off normal ventilation and allow the control  
8 room to heat up, at the point at which the normal  
9 non-safety loads would trip off as a function of  
10 temperature, remove that heat input.

11 If there's some residual non-safety  
12 loads that, you know, some small input that  
13 remain for some additional time, keep that input  
14 and do the simulation for 72 hours.

15 DR. WALLIS: That's more realistic.

16 MEMBER ARMIJO: That's what they did.

17 DR. WALLIS: No, it isn't.

18 MEMBER STETKAR: No, it isn't.

19 (Simultaneous discussion.)

20 MEMBER STETKAR: There are some  
21 artificial conditions on temperatures and DTs.

22 CHAIRMAN CORRADINI: So now Antonio, go  
23 ahead.

24 MR. BARRETT: So that's initially what  
25 we did, and so back before we put in the eight

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hour LCO, that's exactly how we had our analysis,  
2 except where we started, and if you look at that  
3 red curve they had, which is their GOTHIC  
4 analysis, that's basically what they're doing.

5 But what they did instead there is they  
6 have a higher heat sink temperature. They're  
7 starting at 78 instead of 74. So the very  
8 original analysis that we had did exactly what  
9 was stated. Now the later analysis that we have  
10 is more conservative, in that we exposed the  
11 concrete to 85 degrees for eight hours, and then  
12 started the transient.

13 So we did exactly what you said, and  
14 then later, we exposed the concrete. So we  
15 started at a higher concrete temperature and a  
16 higher air temperature. But one difference I  
17 have note that we did make from the old analysis  
18 to the new analysis is we decreased the starting  
19 temperature from 78 degrees to 74 degrees, which  
20 is reducing the starting concrete temperature  
21 from 78 degrees to 74 degrees.

22 MS. CUBBAGE: That's because you  
23 lowered the tech spec limit.

24 MR. BARRETT: Right. We lowered the  
25 tech spec from 78 to 74, which in effect is, you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 know, lowering the heat sink temperature from 78  
2 to 74, and then so like I said, we did the  
3 analysis exactly as was suggested by -- I don't  
4 know who it was. But then we added some  
5 additional conservatism by artificially  
6 increasing the air temperature to 85 degrees for  
7 eight hours, and then starting the transient --

8 DR. WALLIS: It would help if you  
9 showed the prediction for that eight hours, so we  
10 could see what's going on in that eight hours on  
11 the ground.

12 MR. MARQUINO: If you look in the  
13 backup, GEH backup slide, I think it's 22, is  
14 that right? It's labeled the "Asset Heat Sink  
15 Issues." It's got steps on it.

16 DR. WALLIS: I didn't understand that.  
17 Maybe you can explain that.

18 MEMBER STETKAR: What chart number?

19 DR. WALLIS: The one at the very back.

20 MR. MARQUINO: Slide 22, I think.

21 MEMBER STETKAR: 22?

22 DR. WALLIS: At the very back, 22.

23 MEMBER STETKAR: Yes.

24 MR. MARQUINO: So you see Step 1 is the  
25 soak period that the staff referred to, and --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: That's the eight hours  
2 there.

3 MR. MARQUINO: And Step 2 is a step  
4 increase in the control room air temperature to  
5 85 F.

6 DR. WALLIS: How does that happen?

7 MEMBER ARMIJO: It's assumed.

8 DR. WALLIS: It can certainly happen.

9 MR. MARQUINO: It's assumed. So for  
10 this change, this change was made about 18 months  
11 ago, and the reason for the change is without  
12 this, the operators would have to take  
13 compensatory measures immediately on the loss of  
14 HVAC. So we looked at that situation.

15 We said we don't want the plant to have  
16 to immediately begin shutting down if we lose  
17 HVAC in the control room. We want to at least be  
18 able to accommodate a small temperature heat -up.

19 So we added the minus eight hours in the  
20 analysis.

21 CHAIRMAN CORRADINI: So one  
22 clarification, Wayne. I think this is an  
23 excellent graph personally. Maybe no body else  
24 likes it, but I like it.

25 DR. WALLIS: What's Step 1?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: So when are you  
2 stopping the internal heat loads, would be John's  
3 question.

4 MEMBER STETKAR: Non-safety.

5 CHAIRMAN CORRADINI: Non -safety heat  
6 loads would be John's question, at zero?

7 MEMBER STETKAR: The beginning of Step  
8 3.

9 MR. MARQUINO: At time zero.

10 MR. BARRETT: This is Antonio Barrett  
11 of GEH, and so in the control room at time zero,  
12 all the non -safety loads get shut off. Not all  
13 of them, but most of the non -safety loads get  
14 shut off, with some small non -safety loads still  
15 operating.

16 But in the rest of the control  
17 building, the non -safety loads continue to  
18 operate for two hours.

19 CHAIRMAN CORRADINI: Thank you.

20 DR. WALLIS: Is that why you get the  
21 step drop in the temperature?

22 MR. MARQUINO: Yes.

23 DR. WALLIS: Where do you get the step  
24 rise in the temperature at minus eight hours? I  
25 didn't get --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MARQUINO: Because that's an  
2 assumed? That's assumed for them to bound the  
3 fact that if they lost air conditioning, they  
4 would have to not shut down. They'd have to be  
5 able to sustain it.

6 DR. WALLIS: It could be as hot as  
7 that.

8 MR. MARQUINO: It could be as hot as  
9 that.

10 DR. WALLIS: And the eight hours is an  
11 arbitrary number, because you don't show the  
12 concrete temperature here.

13 MR. MARQUINO: It's not completely  
14 arbitrary. It's written in the tech specs.

15 DR. WALLIS: So because you were doing  
16 this, you've got a different starting kick to  
17 everything than the staff does?

18 MR. MARQUINO: No.

19 DR. WALLIS: The staff does something  
20 that when they switch off the load, the thing  
21 heats up, which is rather odd at the beginning.

22 CHAIRMAN CORRADINI: Well, I think  
23 Graham, I think just to answer, from a  
24 clarification standpoint. I think the staff  
25 understands what they did. Then the staff went

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 off and did a series of sensitivities to see the  
2 effect of some of these assumptions, which  
3 created the light blue, the dark blue, and the  
4 red.

5 DR. WALLIS: And they got confidence,  
6 because they're almost parallel. If they bring  
7 them down to the GEH assumptions, they'll  
8 probably get the same answer.

9 MR. O'DRISCOLL: That's right, and we  
10 have to decide when do we get the -- you know,  
11 what's the benefit, and you find that it's --  
12 we're convinced, and we want to focus on the  
13 sensitivities of changing the concrete and see  
14 how the model behaves.

15 But let me just talk about that one  
16 sensitivity, and we'll get back on track. Let me  
17 get the slide. The staff did a sensitivity run  
18 in CONTAIN, using 140 pound concrete. This is  
19 not shown here, okay. This is -- what we did is  
20 we took their model, okay, and put 140 pound  
21 concrete in it.

22 This is not shown here. The final  
23 control room habitability air temperature in this  
24 run was 89.9 degree Fahrenheit, or almost three  
25 degrees lower than CONTAIN 2.0. When we did it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on ours, we got about three degrees. So they're  
2 doing the same thing. Does that make sense?

3 MEMBER ARMIJO: Yes. To me it does.

4 MR. O'DRISCOLL: The top red line is  
5 the GOTHIC analysis that was performed by the  
6 applicant in response to the RAI, and we talked  
7 about that already. It was updated per the  
8 latest values of the EFU, fan flows and the  
9 control room habitability area sensible heat  
10 load.

11 As can be seen on the graph, the heat-  
12 up rate of these models are similar to CONTAIN  
13 and the staff's First Principles model. This  
14 run, the GOTHIC run also was about three degrees  
15 higher than CONTAIN's run.

16 I discussed in the earlier ACRS  
17 presentation, that although some heat load  
18 assumptions were updated, the heat sink initial  
19 temperatures and the initial control room  
20 habitability area temperatures in that model were  
21 not updated by the staff.

22 In addition, the GOTHIC model assumed a  
23 78 degree control room habitability area air  
24 temperature, and the initial temperature of the  
25 walls are not the same as those used in either

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CONTAIN or First Principles model. Is there any  
2 other questions on this slide?

3 DR. WALLIS: Well, I think GEH said  
4 they did this strange Step 1 in order to be  
5 conservative, and yet their values are less than  
6 yours. So your lack of conservative. You're  
7 overly-conservative compared with them.

8 MR. O'DRISCOLL: I attribute the rise  
9 of ours to the initial conditions that we talked  
10 about.

11 DR. WALLIS: The initial conditions,  
12 right. That's right.

13 MR. O'DRISCOLL: Plus the fact that we  
14 have made different assumptions for heat rate or  
15 heat input over time into the room. There's  
16 also, I mean we can go through those assumptions  
17 again, but there's about four differences in  
18 those models.

19 DR. WALLIS: The reason that there is  
20 acceptable whereas yours would not be is that you  
21 think their assumptions are more realistic?

22 MR. O'DRISCOLL: We think that their  
23 input assumptions are adequate. Those inputs --  
24 we had no problems with either CONTAIN, the way  
25 it was performed, or the input assumptions used.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We think they're reasonable, and therefore we  
2 find basically that CONTAIN, or for that matter  
3 GOTHIC, or our First Principles model, it could  
4 be either could be used. Any one of those models  
5 could be used to demonstrate this room.

6 Therefore, CONTAIN 2.0 is adequate as  
7 any. Therefore, and their input conditions are  
8 adequate, and they seem to have performed it the  
9 right way. We checked their input deck.  
10 Therefore, their result of 92 degrees in 72 hours  
11 is valid.

12 DR. WALLIS: But this jump, this sudden  
13 jump to 85 degrees is really a very unphysical  
14 thing.

15 MR. O'DRISCOLL: That's correct,  
16 because they -- what they're doing is they're  
17 artificially holding the room at a high  
18 temperature, which wouldn't -- if you shut off  
19 all the AC, you wouldn't get -- it wouldn't go  
20 that high that fast.

21 DR. WALLIS: That's right. So it's  
22 very strange --

23 MEMBER ARMIJO: If it had been a  
24 calculation from the very beginning, the time  
25 they shut off the air, then it would have been a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 rise in the air temperature, and you wouldn't  
2 have these strange --

3 DR. WALLIS: Everything would be  
4 continuous. You wouldn't get these jumps and  
5 things.

6 MEMBER ARMIJO: Except when you turn  
7 off the heat.

8 DR. WALLIS: Except when you turn off  
9 the heat.

10 MR. O'DRISCOLL: That's not what was  
11 provided by, to the staff to review.

12 DR. WALLIS: Well, I guess your  
13 judgment is that everything is okay.

14 MEMBER STETKAR: I mean Antonio said  
15 that GEH originally ran essentially that  
16 analysis.

17 CHAIRMAN CORRADINI: But I think -- I  
18 don't think the staff would have accepted that  
19 original analysis, because that essentially takes  
20 credit for the fact that you were at your  
21 starting condition. They essentially assumed the  
22 worse case starting condition by essentially  
23 going to their limiting, their LCO for eight  
24 hours. Unless I misunderstood what Wayne said.

25 MR. MARQUINO: This is Wayne Marquino.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I believe the history is we didn't have a tech  
2 spec on the control room air temperature, and the  
3 staff asked us to put a tech spec in that was our  
4 analysis initial temperature. We said wait a  
5 minute. If we lock in this temperature, they're  
6 going to be shutting the plant down as soon as  
7 they lose HVAC.

8 At that time, we said we have to change  
9 the analysis to accommodate some duration of loss  
10 of HVAC.

11 MS. CUBBAGE: And to make up some of  
12 that. That's when they changed the tech spec  
13 temperature.

14 MEMBER ARMIJO: Sorry.

15 MS. CUBBAGE: Go ahead.

16 MEMBER ARMIJO: Why did you use the 120  
17 pound concrete when your design is 150 pounds,  
18 and NRC picked 140? If there's any, you know. I  
19 just wondered why you'd make this problem  
20 tougher. You ought to be able to tell how much  
21 your concrete weighs.

22 MR. MARQUINO: Right, but it's just a  
23 little bit of conservatism that we added in the  
24 analysis, that lighter concrete has less heat  
25 capacity.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: So you're saying maybe  
2 over time it may not be as good of a conductor?

3 MR. MARQUINO: No.

4 MS. CUBBAGE: It provides them some  
5 cushion.

6 MR. MARQUINO: We're sure that because  
7 there's a structural spec on the concrete, I  
8 think we would be justified in using 150 pound  
9 concrete in this analysis. But the person who  
10 did it initially chose to put that as a  
11 conservatism, and we haven't -- we haven't found  
12 a reason to remove that conservatism.

13 DR. WALLIS: Well, I think if you had  
14 found your exceeded your criteria, you would have  
15 gone back and put in a realistic value.

16 CHAIRMAN CORRADINI: Now, now, now.

17 DR. WALLIS: So the reason the staff is  
18 happy is that the trends are about the same, and  
19 if you put in this realistic concrete, it comes,  
20 everything comes down by about the margin by  
21 which the staff is over the criteria.

22 MR. O'DRISCOLL: Yes. That's correct.

23 DR. WALLIS: So this concrete thing is  
24 important in reassuring us that everything is  
25 okay, right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MARQUINO: Yes.

2 DR. WALLIS: Otherwise, I think I might  
3 still have doubts, because it seems to me you can  
4 wiggle these things by how you sort of shake the  
5 whip at the beginning, and then it goes off and  
6 does its wiggle.

7 CHAIRMAN CORRADINI: Yes. I think it's  
8 called an initial value problem.

9 DR. WALLIS: Well.

10 MEMBER STETKAR: Well, I don't  
11 understand the undulation.

12 (Simultaneous discussion.)

13 MEMBER STETKAR: There are two  
14 different kinds of the two different models.

15 MEMBER ABDEL-KHALIK: Could you please  
16 put Slide 22, GE Slide 22 up? Let's look at that  
17 eight hour period initially. The air temperature  
18 is pretty much constant. It varies very  
19 slightly, right.

20 MEMBER STETKAR: Pretty much.

21 MEMBER ABDEL -KHALIK: What does that  
22 tell you?

23 MR. MARQUINO: Can you say the question  
24 again?

25 MEMBER ABDEL -KHALIK: Air temperature

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is pretty much constant during that eight hour  
2 period.

3 MR. MARQUINO: Yes.

4 MEMBER ABDEL -KHALIK: What does that  
5 tell you?

6 MR. MARQUINO: That the control room is  
7 above normal.

8 MEMBER ABDEL -KHALIK: In terms of  
9 energy balance on the air within the control  
10 room. That means that whatever heat input you're  
11 putting in is --

12 MR. MARQUINO: Oh. Now let me clarify.  
13 So in that eight hour period, there's some --  
14 there would be some HVAC function, we expect.  
15 But we've just put a boundary condition, air  
16 temperature, in of 85 degrees. And you were  
17 asking why did we assume it steps up versus come  
18 up over time?

19 MEMBER ABDEL -KHALIK: No, no, no. I  
20 was just looking at what happens during that time  
21 period of eight hours.

22 MR. MARQUINO: Something happened to  
23 the HVAC system, and we assumed that it stepped  
24 the temperature up to 85 and then held it there.  
25 Because we don't know what's going to happen.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 All we're trying to do is provide for 85 degrees  
2 as an upper limit. As long as it doesn't go  
3 above 85, you can keep going for eight hours.

4 MEMBER STETKAR: They're not modeling  
5 reality or anything during that T zero to T minus  
6 --

7 DR. WALLIS: You are modeling  
8 something. You're modeling the concrete  
9 temperature, aren't you?

10 CHAIRMAN CORRADINI: Right. That's all  
11 they're doing. That's all they're doing.

12 DR. WALLIS: So if you're imposing 85  
13 degrees on the concrete temperature, you know,  
14 you're not worry about the heat balance for the  
15 room itself.

16 MEMBER STETKAR: Correct.

17 MR. MARQUINO: Yeah. We're imposing 85  
18 on the air, and then the concrete is heating up  
19 in this eight hours, and then at time zero, we  
20 stop all heat removal and trip most of the non-  
21 safety loads.

22 MEMBER ABDEL-KHALIK: And let the air  
23 and concrete float.

24 MR. MARQUINO: Yes.

25 MR. GALVIN: You also have, of course,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the boundary condition of, at least the peak, 117  
2 degree air coming into the room.

3 MEMBER ABDEL-KHALIK: Right, which is  
4 the blue line.

5 MR. GALVIN: Which is the blue line.

6 DR. WALLIS: And this is only on the  
7 worse day of the year?

8 MR. MARQUINO: Yes. 117 would be the  
9 worst time of the year.

10 (Simultaneous discussion.)

11 DR. WALLIS: So we are looking at some  
12 extreme condition?

13 MR. MARQUINO: Yes. This is their --

14 (Simultaneous discussion.)

15 MR. O'DRISCOLL: Dennis, why don't we  
16 go back to the staff's presentation?

17 (Simultaneous discussion.)

18 MR. ARCARO: This is Mike Arcaro. To  
19 clarify what I did on that chart, all I did is  
20 put a forcing function on the chart that already  
21 exists, that showed the response. So you know,  
22 before the zero point on there, it's all made up.

23 It's just a forcing function that shows what the  
24 model does for air at 85 degrees.

25 MR. HARBUCK: Okay. This slide may

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 look familiar because we presented it at the  
2 Chapter 16 briefing in August, and it simply  
3 reiterates what was already presented by GEH,  
4 explaining that the temperature specification is  
5 not just for the main control room, but for heat  
6 sinks in adjacent areas in the control building.

7 And just as a thought, I understand  
8 that all the other spaces stay within their EQ  
9 limits for the 72 hours also. So we've been  
10 focused on the control room, but I think the  
11 other spaces are also adequately maintained at  
12 temperature rises above these that are  
13 acceptable, and I don't know what those are.

14 And so the conclusion is that the  
15 analysis shows that the passive heat sinks will  
16 keep the control room at or below 93 degrees over  
17 the course of the 72 hour period post-DBA.

18 DR. WALLIS: This is according to the  
19 GEH analysis?

20 MR. O'DRISCOLL: Say again?

21 DR. WALLIS: According to the GEH  
22 analysis.

23 MR. O'DRISCOLL: According to the  
24 design basis analysis submitted.

25 DR. WALLIS: Submitted by GEH?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. O'DRISCOLL: That's correct.

2 MR. HARBUCK: All right, and then the  
3 CRHAV spec itself, the LCO is really focused, you  
4 know, it says heat sink temperatures have to be  
5 this, but as has already been explained, we're  
6 assuming there's this equilibrium established  
7 between the air that's enclosed by the heat  
8 sinks. So we focused on what the air  
9 temperatures are and based the actions and  
10 conditions on that.

11 So there is this Action A, which as was  
12 previously explained, you get eight hours to get  
13 the air temperature back. The thought is that  
14 the temperatures of the heat sinks, having  
15 previously been equilibrium and a lower  
16 temperature, would not be significantly affected  
17 by that.

18 I think it's also -- well, if you just  
19 were to assume that the cooling units turned off,  
20 and the internal recirculation turned off. Then  
21 the rise in the temperature of the air over  
22 eight hours is also not that significant. If it  
23 got up to 85, of course it would trip off the N -  
24 DCIS load. So okay.

25 And of course the question is then is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 how do we do the surveillance requirement? How  
2 do we determine if we have our heat sink  
3 temperatures are satisfied at 24 hours and that  
4 also was discussed in the two bullets there. You  
5 do some evaluation or you do a direct temperature  
6 measurement, make some inferences from that.

7 However, those are things for the  
8 licensee to work out in procedures, and I think,  
9 as they mentioned, they were going to have  
10 procedures for this.

11 DR. WALLIS: So this bulk average has  
12 to be calculated?

13 MR. O'DRISCOLL: It has to be  
14 justified. The spec is based on the average  
15 temperature of the heat sink. So either by  
16 direct measurement or by calculation, they have  
17 to say what's the temperature inside that heat  
18 structure.

19 DR. WALLIS: So they may have to cool  
20 the control room below normal temperatures in  
21 order to recover from a high temperature  
22 transient, in order to get this back to --

23 MR. O'DRISCOLL: I don't think that's  
24 necessary.

25 DR. WALLIS: Calculate the transient in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the wall?

2 MR. O'DRISCOLL: If they restored their  
3 normal cooling, the room would soak at that  
4 temperature and become -- the bulk temperature  
5 would be satisfactory.

6 DR. WALLIS: Concrete relaxes to th e  
7 room temperature in 24 hours?

8 MR. O'DRISCOLL: Well, if you assume an  
9 eight hour excursion and only an eight hour  
10 excursion, you know, your LCO, Action Statement 1  
11 requires you to restore the air temperature fast,  
12 eight years.

13 DR. WALLIS: Right. That's right.

14 MR. O'DRISCOLL: And then it allows you  
15 a longer period of time to restore the bulk  
16 average temperature of the heat sink to wherever  
17 it was.

18 DR. WALLIS: You've got some kind of  
19 wave that goes through the concrete?

20 MR. O'DRISCOLL: That could be  
21 developed through procedures.

22 DR. WALLIS: Is that you expect them to  
23 do, calculate that?

24 MR. O'DRISCOLL: That's one way of  
25 handling this surveillance.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HARBUCK: Or rather this action  
2 requirement.

3 MR. O'DRISCOLL: This action  
4 requirement.

5 MEMBER ABDEL -KHALIK: So in the  
6 calculations that we were shown, this graph here  
7 --

8 MR. O'DRISCOLL: Yes.

9 MEMBER ABDEL-KHALIK: During this eight  
10 hour soaking period, whatever you called it, what  
11 was the assumption as far as the temperature  
12 distribution within the concrete?

13 MR. MARQUINO: It was not an  
14 assumption. It was calculated, so that the eight  
15 hour period --

16 MEMBER ABDEL -KHALIK: No. At time  
17 minus eight on this graph, what was the  
18 temperature distribution in the concrete?

19 MR. MARQUINO: It's actually given on  
20 the next slide. So Slide 23 shows the  
21 temperature after Step 1, which is the normal  
22 operating soak period, and the temperature at the  
23 end of Step 2, which is the eight hour abnormal  
24 high control room temperature, and the  
25 temperature at the end of 72 hours, without

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 cooling and without safety-related loads.

2 MEMBER ARMIJO: So okay. So the  
3 outside temperature was 76 degrees?

4 DR. WALLIS: That leaps up?

5 MR. O'DRISCOLL: No. You're looking at  
6 one heat structure. I believe it's the worse  
7 case heat structure. It's the ceiling of the  
8 control room.

9 You have a very hot room above it, a Q,  
10 excuse, me, an N-DCIS room, I believe, are above  
11 the control room, and that's the heat structure  
12 that was chosen by GE -Hitachi to show h ere.  
13 That's not the outside of the --

14 MEMBER ABDEL -KHALIK: That's not the  
15 outside level?

16 MR. O'DRISCOLL: That's not the outside  
17 in the air. That's an adjoining room.

18 DR. WALLIS: Which is hotter somehow.

19 MEMBER ABDEL -KHALIK: But within the  
20 concrete, the temperature at the beginning on the  
21 concrete control room air interface, the  
22 temperature was what, 74 degrees?

23 MR. MARQUINO: Yes. The air  
24 temperature was 74 degrees, right.

25 MEMBER ABDEL -KHALIK: Okay, and at the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 other side of the concrete, the temperature was  
2 what, of the concrete?

3 MR. O'DRISCOLL: 76.

4 MR. MARQUINO: Yes.

5 MEMBER ABDEL-KHALIK: It looks like 76  
6 something. Is that what you would expect, even  
7 in the concrete that's in contact with the soil?

8 MR. O'DRISCOLL: No, no, no . That's  
9 only one heat sink. There's one structure. If  
10 you think about it, it's just one wall. So this  
11 particular wall has got a heat source.

12 It's got some equipment that's pumping  
13 some heat into that piece of concrete. So for  
14 that particular wall , that's the expected soaked  
15 profile, unless I'm mistaken, what you'd see  
16 through that wall.

17 MR. MARQUINO: That's right, and to get  
18 back to the original question, you said what's  
19 the temperature after eight hours?

20 MEMBER ABDEL-KHALIK: No, no, no. I'm  
21 just trying to understand --

22 MEMBER STETKAR: The graph.

23 MEMBER ABDEL -KHALIK: The assumptions  
24 that you're making in doing this calculation.

25 MR. MARQUINO: Right. It was a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 calculation of the concrete temperature. The  
2 concrete temperature was not an input.

3 MEMBER ABDEL -KHALIK: But the results  
4 of all this analysis depends on what you assume  
5 as far as the initial temperature distribution  
6 within the concrete, because that will determine  
7 the initial average temperature for the concrete,  
8 and that's what I'm trying to get to.

9 MR. O'DRISCOLL: Yes.

10 MEMBER ABDEL-KHALIK: And let's look at  
11 a concrete wall that's in contact with the soil.

12 MR. O'DRISCOLL: Okay.

13 MEMBER ABDEL -KHALIK: Okay. At time  
14 minus eight in this analysis, which is the  
15 beginning of your soaking period, on the inside  
16 surface of the concrete, the temperature is 74  
17 degrees. What is the temperature on the outside  
18 surface that is in contact with the hot source?

19 MR. MARQUINO: Well, you're asking  
20 about the soil? It would be the soil  
21 temperature. Is it 86 degrees?

22 MR. O'DRISCOLL: 86 degrees is what was  
23 assumed as soil temperature. The uniform soil  
24 temperature of 86 degrees. So for that one wall,  
25 you have one side of it touching 86 degree soil;

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the other side, 74 degrees air, correct.

2 MR. HARBUCK: Not necessarily what  
3 group heat sink is that?

4 MR. O'DRISCOLL: That's a different  
5 group. The heat sinks --

6 MR. HARBUCK: So it's going to be the  
7 temperature for the limit on that group?

8 MR. O'DRISCOLL: That's correct.

9 MR. HARBUCK: Which could be 78, 104,  
10 whichever it is.

11 MR. O'DRISCOLL: Right.

12 CHAIRMAN CORRADINI: I think what  
13 Syed's asking, I know where he's going with it,  
14 he's trying to understand the situation going in,  
15 and I guess I'm guessing that the situation going  
16 in is what you said for the soil temperature.  
17 But everywhere on the building, because you have  
18 active HVAC, it's cold.

19 But somewhere out there, you've got  
20 damn hot air in the atmosphere that's then  
21 eventually, once you get through your eight hours  
22 of some artificial heat-up, it has to penetrate  
23 through all of this to essentially heat up the  
24 room.

25 MR. MARQUINO: That's right. So the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 situation going in is all the rooms are at their  
2 maximum tech spec temperature, even though it's  
3 117 degrees out side. But all the HVAC is  
4 working, at least within its specified value.

5 And then something happens to the  
6 control room HVAC, and the control room  
7 temperature goes up to 85 degrees, and now we  
8 calculate for it at the end of eight hours, what  
9 are the concrete temperatures, what's the  
10 concrete temperature distribution, and now we  
11 lose off site power and we start a 72 hour heat -  
12 up from that point.

13 MEMBER ARMIJO: What fraction of the  
14 total surface area that you're dumping heat to is  
15 the outside wall? Is it a fourth of it or an  
16 eighth or you know I know you've got a lot of  
17 walls.

18 MR. MARQUINO: The control room  
19 habitability area itself is, doesn't touch the  
20 ground on the outside.

21 MEMBER ARMIJO: It's totally surrounded  
22 by internal walls?

23 MR. MARQUINO: Right.

24 CHAIRMAN CORRADINI: But I think the  
25 key thing is that I think John said it privately.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1       Because of emergency air so nobody's  
2 asphyxiated, the infiltration is high. That's  
3 the biggest heat source in       the surrounding,  
4 that's causing this whole thing to go up. Then  
5 they have the swing of that       stuff as it goes  
6 through the time period.

7               MEMBER ARMIJO: Right.

8               MR. MARQUINO: Antonio, did you want to  
9 add something?

10              MR. BARRETT: I was just going to, a  
11 small clarification. This is Antonio at G   EH,  
12 that there is a small portion that's -- of the  
13 control room habitability area that is in contact  
14 with the soil. But it's not --

15              MEMBER ARMIJO: It's not much.

16              MR. BARRETT: It's a smaller portion.  
17 Most of it is contained by other rooms. They're  
18 surrounded by other rooms and a hallway.

19              MEMBER ARMIJO: Okay, thank you.

20              MEMBER STETKAR: Craig, I've got a  
21 question of the tech specs. I've been searching,  
22 you know, thanks to GEH, I found the surveillance  
23 requirement for verifying that indeed       the  
24 temperature sensors turn off the non       -safety  
25 related loads. That's performed once every two

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 years.

2 I still cannot understand whether or  
3 not there is an LCO on operability of those  
4 temperature sensors, because you know, LCOs are  
5 different from surveillance requirements. Why  
6 can't I take out --

7 MR. HARBUCK: The LCO is on the  
8 automatic function, to turn off the NDCIS loads.

9 MEMBER STETKAR: But I don't --

10 MR. HARBUCK: And that surveillance  
11 requirement verifies that function.

12 MEMBER STETKAR: Where is the LCO on  
13 that function?

14 MR. HARBUCK: Up in the beginning  
15 section of Chapter 3, the tech specs, there is an  
16 LCO, I mean a surveillance requirement called SR -  
17 302. It says if you don't meet a surveillance  
18 requirement, you don't meet the LCO.

19 MEMBER STETKAR: But that presumes that  
20 since I'm only performing that surveillance once  
21 every two years, it presumes that those things  
22 are always operable.

23 MR. HARBUCK: There is a presumption of  
24 operability.

25 MEMBER STETKAR: Well, but it says that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I can't take them out of service for maintenance.

2 Suppose one fails during normal operation? What  
3 do I do?

4 MR. HARBUCK: Okay, there's three  
5 divisions required. So you take one of the  
6 divisions out. You would go to the actions of  
7 the LCO, to see -- now I think the control room  
8 habitability area is, it's got two trains. So  
9 but I'm not sure about exactly how the  
10 instrumentation is.

11 MEMBER STETKAR: That's the thing I'm  
12 struggling with because again, I'm trying to do  
13 this real-time and in fairness to every one, I've  
14 not been able to -- I'm trying to flip back and  
15 forth between the actual LCO statements and the  
16 basis documents, to see --

17 The basis documents discuss the  
18 function of de-energizing the non-safety loads.  
19 But everything that I read in the LCO statements  
20 is with respect to other functions, you follow  
21 me? It's for things like isolation. It's for  
22 things like starting. It's, you know, the two  
23 trains of ventilation and things like that.

24 It's, you know, the items you have  
25 identified here on Slide 9, the temperatures and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 things like that. I don't -- if I'm an operator,  
2 I don't see how my operation is limited, if for  
3 example I remove two of these particular  
4 temperature sensors from service, for whatever  
5 reason.

6 MR. HARBUCK: I'm sure you're familiar  
7 with RIS 2005 -20, that was updated in 2008,  
8 dealing with degraded non-conforming conditions  
9 and talks about operability, and you know,  
10 operability is something that you -- it's  
11 determined not, say outside the tech specs.

12 And then if you determine that you're  
13 not operable, then you do what the tech specs  
14 tell you to do.

15 So in this case, if you don't meet this  
16 surveillance requirement for one or more of the  
17 divisions, or one or more channels, one or more  
18 of the detectors, then you take the actions that  
19 are specified in the associated LCO. In this  
20 case, you would be looking at the operability of  
21 the CRHAVs.

22 MEMBER STETKAR: That's the point that  
23 I'm struggling with, because --

24 MR. HARBUCK: Right. So if you  
25 determine that the way the tech spec is written,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 if you determine that this automatic securing of  
2 non-safety loads at 85 degrees was not  
3 functioning, either through the sensors being  
4 inoperable or the logic being inoperable, then  
5 you would have to declare both trains of CRHAVs  
6 inoperable, because you could not meet the  
7 surveillance requirement, and you'd be shutting  
8 down.

9 That's, in this case the tech specs are  
10 rather severe, I think.

11 MEMBER STETKAR: As long as that's a  
12 uniform interpretation. You see, I look at other  
13 parts of the SBW R tech specs, where they do have  
14 explicit LCO statements for instrumentation, and  
15 also surveillance requirements for the  
16 instrumentation.

17 So I have both of those established.  
18 If I have an instrument channel out of service  
19 for 12, you know, I can have it out of service  
20 for 12 hours. I only require three, but I  
21 basically can have two out of service for 12  
22 hours, and then I must shut down.

23 In this particular case, I don't have  
24 that type of statement. That's why I was curious  
25 about that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HARBUCK: Right.

2 MEMBER STETKAR: Because it's -- I  
3 wouldn't be so concerned, but it's a pretty  
4 important function in these room heat-up  
5 analyses.

6 If I don't actually shut off those non -  
7 essential loads at 85 degrees Fahrenheit, I'll  
8 get a different response. I have no -- like I  
9 said, I don't know how these things work, but I  
10 have no idea what that response will look like,  
11 but certainly the end point temperature will be  
12 higher.

13 So it's a pretty important function. I  
14 just want to make sure that people opera ting the  
15 plant recognize the importance of that function,  
16 and that if I happen to take two of those  
17 particular temperature sensors out of service,  
18 that I have -- I may have a problem. I don't  
19 read that in the tech specs.

20 MR. HARBUCK: I would have to defer to  
21 the instrumentation experts regarding the  
22 specific design, the number of sensors and how  
23 those are computed in the average temperatures  
24 and how --

25 MEMBER STETKAR: Best as I can tell,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it's four, in the two out of four.

2 MR. HARBUCK: But how the -- you know,  
3 is it -- I mean I'm just not sure exactly how  
4 it's done, but --

5 MEMBER STETKAR: Well maybe -- you  
6 know, we're running long here.

7 MR. HARBUCK: But I stand by my  
8 statement. I think it's clear from the way the  
9 tech specs are structured and written, that you'd  
10 have to declare both trains inoperable.

11 MEMBER STETKAR: I understand if they  
12 don't, if they run the surveillance and it fails.

13 MS. CUBBAGE: That wasn't what he said.

14 MEMBER STETKAR: I understand what I  
15 have to do as an operator under those conditions.  
16 That's really clear. What I'm talking about is  
17 I perform the surveillance, everything works.

18 A month later, for whatever reason, Joe  
19 comes into the control room and says hey, we want  
20 to do some painting and those temperature sensors  
21 are in the way. Can you de-energize them for the  
22 next three hours or six hours or two days?

23 If I'm an operator, what do I  
24 understand about that?

25 MR. HARBUCK: There's SR-301 up in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 front says that surveillance requirements have to  
2 be met whenever the LCO is within its  
3 applicability, all right. So whether -- so  
4 meeting a surveillance is not just when you  
5 perform it, but it's all the time.

6 So whatever criteria you have to  
7 satisfy to meet the surveillance, if you have  
8 reason to believe that criteria is no longer met,  
9 which you wouldn't be if you took it out of  
10 service and de-energized it.

11 Then you would say hey, you know, I'm  
12 inoperable. Now you have to figure out what is  
13 the impact on the systems that are supported.

14 MEMBER STETKAR: Okay.

15 MR. HARBUCK: I'll just make this  
16 comment. I think there are probably other ways  
17 to write the tech specs for this particular  
18 function, and the actions. You could be perhaps  
19 more specific to this function and that sort of  
20 thing. But that's not what GEH has proposed.

21 MEMBER STETKAR: Well, you know, I'm  
22 just questioning. I understand what they  
23 proposed, and I understand the desire to keep as  
24 much equipment as possible out of the technical  
25 specifications. I also understand the desire to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 make sure that the operators don't inadvertently  
2 place the plant in a vulnerable condition,  
3 because they aren't -- because the tech specs  
4 might be somewhat convoluted, and it's not clear,  
5 you know, how they would interpret that  
6 configuration.

7 MS. CUBBAGE: All right. Could I  
8 interject here please? Craig Harbuck is our  
9 technical specification expert. He is an expert  
10 in how tech specs are interpreted, etcetera,  
11 etcetera. He's well-known with the staff for an  
12 expert in this area.

13 He has told you how this would be  
14 interpreted. If you have disagreement with us on  
15 that, we'll have to take that up. But this is  
16 our position.

17 MEMBER STETKAR: Okay.

18 MR. HARBUCK: We'll go to the next one.

19 MR. O'DRISCOLL: I'll do this. I'm  
20 presenting the following slide on behalf of Brad  
21 Harvey. Brad is our meteorologist in the Siting  
22 and Accident Consequence Branch or SAC. My name  
23 is Jim O'Driscoll.

24 Within the division of -- well, Brad is  
25 a meteorologist in the Siting and Accident

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Consequence Branch within the Division of Site  
2 and Environmental Reviews, the SER. I'll be  
3 discussing the addition of the three new site  
4 temperature site parameters to support the  
5 control room habitability area heat -up analysis  
6 that was presented during the August ACRS  
7 meeting.

8 In particular, I would like to address  
9 the concern expressed during the August ACRS  
10 meeting that unequivocal methodology should be  
11 specified regarding how COL applicants are to  
12 determine their site characteristic values, that  
13 correspondence to the control room habit ability  
14 area heat-up analysis site parameter values.

15 The applicant has made a change to its  
16 definition of the control room habitability area  
17 heat-up analysis site parameter values, which  
18 they presented to you earlier this afternoon.  
19 The staff believes these changes will help  
20 alleviate the ACRS' concern.

21 My goal this afternoon is to (1),  
22 describe the basis for the three control room  
23 habitability area heat -up analysis site  
24 parameters, (2) describe the revised methodology  
25 to be used by the COL applicant in deriving the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 corresponding site characteristic values.

2 I will also used the revised control  
3 room habitability area heat-up analysis site  
4 parameter definitions to review the three example  
5 site-specific cases presented during the August  
6 ACRS meeting. I mean we can do one, if that's  
7 satisfactory.

8 The table -- next slide please. That's  
9 right. The table in the slide before you lists  
10 the ambient site temperature site parameters that  
11 are to be included in the ESBWR DCD. The three  
12 site parameters listed in bold at the bottom of  
13 this table are the new set of ambient design  
14 temperature site parameters related to the  
15 control room habitability area heat-up analysis.

16 Also note that a zero percent  
17 exceedance maximum dry bulb of 117 degrees  
18 Fahrenheit, the zero percent exceedance non -  
19 coincident maximum wet bulb of 88 degrees  
20 Fahrenheit, and the zero percent exceedance  
21 minimum dry bulb of minus 40 degrees Fahrenheit  
22 remain as site parameters, as these values are an  
23 important input to the control room habitability  
24 area heat-up analysis.

25 If I can just -- as the person who has

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reviewed this, I can talk a little bit about  
2 sensitivities, in case you have questions about  
3 what happens if, let's say, things are different  
4 than what they proposed. Next slide.

5 DR. WALLIS: Is this different from  
6 what we saw last time?

7 MR. O'DRISCOLL: The slides themselves  
8 are slightly different. But the key thing, I  
9 think, I believe it was you that requested or  
10 brought up the point that the three day period,  
11 the terminology they used, three days, was kind  
12 of ambiguous.

13 DR. WALLIS: That was the problem, yes.  
14 But this chart is the same, this table that we  
15 just saw.

16 MR. O'DRISCOLL: Yes, yes, exactly the  
17 same.

18 DR. WALLIS: So nothing has changed?

19 MR. O'DRISCOLL: That's correct.

20 MR. GALVIN: So do we want to just skip  
21 the three-day thing?

22 CHAIRMAN CORRADINI: No, no. Let's  
23 just continue.

24 MR. GALVIN: Okay. Just keep going  
25 through it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. O'DRISCOLL: Okay. The 103.5  
2 degree Fahrenheit value for the site parameter  
3 was derived by averaging the zero percent  
4 exceedance maximum dry bulb site parameter value  
5 of 117 degrees Fahrenheit, and the dry bulb  
6 temperature resulting from a daily temperature  
7 range of 27 degrees Fahrenheit.

8 The correspondence site characteristic  
9 value is determined by averaging the site  
10 specific zero percent exceedance maximum dry bulb  
11 temperature and the dry bulb temperature that  
12 corresponds to the higher of the two low dry bulb  
13 temperatures occurring within 24 hours before and  
14 after the zero percent exceedance maximum dry  
15 bulb temperature.

16 DR. WALLIS: Now this first thing,  
17 103.5, I think, is 117 minus a half of 27. Isn't  
18 that what it is?

19 MR. O'DRISCOLL: Yes. It's 103.5 minus  
20 half of 27.

21 DR. WALLIS: But it's not the average  
22 of 117 and 27. The words are strange in the  
23 slide. It's actually the mean. It's 117 minus a  
24 half of 27. So it's assuming that it's a  
25 symmetrical curve. But the words are strange.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 It's not the average of 117 and 27. But I  
2 understand what you did. It's just the words  
3 don't make sense. They don't seem to be  
4 consistent with what was done.

5 CHAIRMAN CORRADINI: Can you just go  
6 back to the definition again, and just let us  
7 maybe stare at it for a minute, so we get clear  
8 on it?

9 DR. WALLIS: I understand. The 103.5  
10 is 117 minus a half of 27. So it's simply the  
11 average when you take a curve, which oscillates  
12 between 117 and 90, whatever it is.

13 MR. O'DRISCOLL: Right. I mean what we  
14 had to do here, I mean we know what we're doing.  
15 What we're trying to do here is give an  
16 applicant, who is somebody -- a COL applicant who  
17 is looking at sites, a box.

18 DR. WALLIS: I understand that. It's  
19 just the words don't seem to correspond to what  
20 you did. That's all.

21 MR. GALVIN: It could have been written  
22 in a better way.

23 MEMBER ARMIJO: Yes. It's not --

24 MR. O'DRISCOLL: So that's the site  
25 parameter value, and determining the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 corresponding site characteristic value below,  
2 looking at that definition.

3 CHAIRMAN CORRADINI: So is the  
4 corresponding site characteristic value is what  
5 the COL applicant would have to do at their site  
6 to compare to the 103?

7 MR. O'DRISCOLL: That's correct.

8 CHAIRMAN CORRADINI: Thank you.

9 MR. O'DRISCOLL: Yes, that's correct.

10 CHAIRMAN CORRADINI: Okay, thank you.

11 That's all I wanted to know.

12 MR. O'DRISCOLL: Okay. Next slide.

13 Here's an example. As an example, the blue line  
14 in this slide before you shows a plot of hourly  
15 dry bulb temperatures that occurred from 36 hours  
16 before to 36 hours after occurrence of a zero  
17 percent exceedance maximum dry bulb temperature  
18 of 110.

19 So here we have a site. Here's some  
20 met data. We found our hottest zero percent  
21 exceedance point, and we have the time between,  
22 before and after. The higher of the two low  
23 temperatures occurring within 24 hours before and  
24 after the zero percent exceedance maximum dry  
25 value, dry bulb temperature is 77 degrees.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 That's the dark black one.

2 The maximum average dry bulb  
3 temperature for the zero percent exceedance  
4 maximum temperature day is therefore an average  
5 of 110 and 77, which is 93.5, which is below 103.

6 Next slide. This is basically the same  
7 thing, but for the winter case. The minus 26.5  
8 degree Fahrenheit value of the site parameter was  
9 derived by averaging the zero percent exceedance  
10 minimum dry bulb site parameter value of minus  
11 40, and the dry bulb temperature resulting from a  
12 daily temperature range of 27 degrees.

13 The corresponding site characteristic  
14 value is determined by averaging the site -  
15 specific zero percent exceedance dry bulb  
16 temperature and the dry bulb temperature that  
17 corresponds to the lower of the high dry bulb  
18 temperatures occurring within 24 hours before and  
19 after the zero percent exceedance minimum dry  
20 bulb temperature.

21 As an example, the blue line in this  
22 slide before you shows a plot of hourly dry bulb  
23 temperature that occurred from 36 hours before to  
24 36 hours after the occurrence of a zero percent  
25 exceedance minimum dry bulb temperature of minus

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 17 degrees Fahrenheit.

2 The lower of the two high temperatures  
3 occurring within 24 hours before and after the  
4 zero percent exceedance minimum dry bulb  
5 temperature is zero degrees Fahrenheit.

6 The minimum average dry bulb  
7 temperature for the zero percent exceedance  
8 minimum temperature day is therefore an average  
9 of minus 17 degrees Fahrenheit and zero degrees  
10 Fahrenheit, which is minus 8.5 degrees  
11 Fahrenheit.

12 MEMBER ABDEL-KHALIK: Well, isn't it  
13 the average of minus 17 and minus 7, if I look at  
14 this graph?

15 MR. O'DRISCOLL: Minus 17 and minus  
16 what?

17 MEMBER ABDEL-KHALIK: Minus 7, which is  
18 the minimum immediately prior to the minus 17  
19 minimum, rather than the zero.

20 MR. O'DRISCOLL: We assume a -- we're  
21 trying to figure out a diurnal swing. So we're  
22 saying -- we're assuming generally that the day  
23 gets -- during the day it's warmer; during the  
24 night it's cooler. So when we look at the peaks  
25 and we try to find the peak, and then determine -

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 - that will determine a diurnal swing.

2 DR. WALLIS: But doesn't it depend on  
3 where you draw the black lines, the vertical  
4 lines? I mean how do you define this diurnal?

5 MR. O'DRISCOLL: We look for the --  
6 it's based on the zero exceedance low.

7 DR. WALLIS: So from 12 o'clock to 12  
8 o'clock or what?

9 MR. O'DRISCOLL: No. It's based on the  
10 time of the low occurring.

11 DR. WALLIS: Time of the minus 17?

12 MR. O'DRISCOLL: That's correct.

13 CHAIRMAN CORRADINI: So they looked, if  
14 I -- just to say it back to you so I get it  
15 right. You looked where you got over a plus or  
16 minus, a 48 hour period the lowest, and then you  
17 went 24 hours behind and ahead and took the  
18 lowest of the two highs?

19 MR. O'DRISCOLL: That's correct.

20 DR. WALLIS: This is an effort to make  
21 it unequivocal. You center yourself on that  
22 minus 17?

23 MR. O'DRISCOLL: That's right.

24 DR. WALLIS: Okay.

25 CHAIRMAN CORRADINI: Oh, I see. All

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 right.

2 MR. O'DRISCOLL: Okay, next slide.

3 CHAIRMAN CORRADINI: Now the one.

4 MR. O'DRISCOLL: Yes. First --

5 DR. WALLIS: Now that number is not  
6 necessarily the peak of the curve. It's the  
7 maximum throughout the day, which could be at the  
8 end of it?

9 MEMBER STETKAR: Which is what that  
10 curve said.

11 DR. WALLIS: Okay. That was the  
12 problem we had before too. Thank you.

13 MR. O'DRISCOLL: Okay. First recall  
14 that the wet bulb globe temperature, WBGT index  
15 is defined, for this case, for the ESBWR control  
16 room in this analysis, as 0.7 times the wet bulb  
17 temperature, plus 0.3 times the coincident dry  
18 bulb temperature.

19 This 86.5 degree Fahrenheit value is a  
20 site parameter. Site parameter was derived by  
21 averaging the wet bulb glow temperature index for  
22 the zero percent exceedance maximum wet bulb site  
23 parameter value of 88 degrees Fahrenheit, and  
24 assuming a coincident dry bulb temperature of 92  
25 degrees.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           The wet bulb globe temperature       index  
2       resulting from the high humidity diurnal dry bulb  
3       temperature swing is eight degrees.       That is a  
4       dry bulb temperature of 84 degrees,       assuming a  
5       coincident wet bulb temperature of 84 degrees.  
6       That's what was assumed in the analysis.

7           DR. WALLIS:  It's 100 percent humidity?

8           MR. O'DRISCOLL:  Yes, 100 percent.

9       That's what the applicant assumed as a worse case  
10      wet day, wet conditions.  So we have to now  
11      compare our site, our picked site to this number,  
12      this site parameter.

13           The corresponding site characteristic  
14      value is determined by averaging the wet bulb  
15      globe temperature index coincident with the site-  
16      specific zero percent exceedance maximum wet bulb  
17      temperature, and the wet bulb globe temperature  
18      index coincident with the wet bulb temperature  
19      that corresponds to the highest of       the six low  
20      wet bulb temperatures occurring in each of the  
21      three 24 hour periods before and after that zero  
22      percent exceedance maximum wet bulb temperature.

23           So in this case, we're trying to,       you  
24      know, a lower diurnal swing is worse.  If you  
25      have -- if you stay, for this particular

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analysis, if you stay close to very high unit  
2 conditions, you'll end up with a more stressful  
3 effective temperature in the control room.

4 Okay. This is the Slide 16. As an  
5 example, the green line in this slide before you  
6 shows a plot of hourly wet bulb temperatures that  
7 occurred from 84 hours before to 84 hours after  
8 the occurrence of a zero percent exceedance  
9 maximum wet bulb temperature of 75 degrees.

10 DR. WALLIS: All pinned on the 75?

11 MR. O'DRISCOLL: That's correct.

12 DR. WALLIS: Right.

13 MR. O'DRISCOLL: Similarly, the blue  
14 line shows a plot of coincident hourly dry bulb  
15 temperatures for the same time period. Notice  
16 that the dry bulb temperatures coincident with  
17 the zero percent exceedance maximum wet bulb  
18 temperature is 95 degrees.

19 This results in a wet bulb globe  
20 temperature index of 81 degrees Fahrenheit for  
21 the hour when the zero percent exceedance maximum  
22 wet bulb temperature occurred. The highest of  
23 the six low wet bulb temperatures occurring in  
24 each of the three 24-hour periods before and  
25 after the zero percent exceedance maximum wet

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bulb temperature is 59 degrees.

2 DR. WALLIS: No, because these six  
3 minimums you've shown here are all actually  
4 minimums of curves. But they could be minimums  
5 of the extreme of the day.

6 MR. O'DRISCOLL: Right.

7 DR. WALLIS: Because that was a point  
8 we had, trouble we had before. If say the curve  
9 where you show a 56, if that curve had actually  
10 gone down, so that it was a 53 at the end of the  
11 day, you've picked the 53?

12 MR. O'DRISCOLL: That's correct, that's  
13 correct.

14 DR. WALLIS: Right. So it's the  
15 absolute lowest one throughout that period?

16 MR. O'DRISCOLL: That's correct.

17 DR. WALLIS: It's not the bottom of a -  
18 -.

19 MR. O'DRISCOLL: Right. Okay.

20 MEMBER ARMIJO: Sort of like the 59,  
21 right?

22 MR. O'DRISCOLL: Okay.

23 DR. WALLIS: It's clear to me that  
24 you've got a clearer definition. Why you have  
25 this as a definition, I have no idea.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. O'DRISCOLL: I'll get to that. The  
2 coincident dry bulb temperature is 68 degrees for  
3 that wet bulb temperature, resulting in a wet  
4 bulb globe temperature index of 61.7 degrees for  
5 that point. The maximum high humidity average  
6 wet bulb globe temperature index with a zero  
7 percent exceedance maximum wet bulb temperature  
8 days.

9 Therefore, the average of 81 degrees  
10 and 61.7 degrees Fahrenheit, which is 71.4 degree  
11 Fahrenheit. That's one example of how to do  
12 this. Now is there --

13 CHAIRMAN CORRADINI: Go ahead.

14 MEMBER STETKAR: Another example of how  
15 to do this is if I look at your plot there, and I  
16 look at the right-hand vertical dash line, which  
17 is actually the maximum dry bulb temperature,  
18 which looks to be about 103 degrees Fahrenheit,  
19 and the coincident wet bulb temperature obviously  
20 must be a little lower than 75, or else you would  
21 have identified it. So let's call it 74.

22 I back up 48 hours from that, and I  
23 look at the other peak over there, which looks  
24 like a dry bulb temperature of 80 degree  
25 Fahrenheit, with a wet bulb of let's call it 60.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 You know, I get an average of 74.4 degrees or  
2 three degree higher than yours.

3 So the point is there are other ways of  
4 calculating this, and your method doesn't  
5 necessarily, and I'm not trying to necessarily  
6 maximize the temperature. I might be able to  
7 maximize it, you know, by doing some other  
8 manipulations of this particular set of data.

9 MR. O'DRISCOLL: Right.

10 MEMBER STETKAR: The question is if I'm  
11 looking to an applicant now, a COL applicant, to  
12 confirm that their meteorological conditions are  
13 bounded by the DCD calculation of whatever it is,  
14 86.6, and if they're close to that margin, the  
15 way that you tell them to calculate that, you  
16 know, if I'm a plant in the southeastern United  
17 States.

18 If I'm close to that margin, the way  
19 that I calculate this, those rules that you're  
20 establishing there, might not lead to an  
21 appropriate result.

22 MR. O'DRISCOLL: Right, and I think I  
23 have an answer for that. I can give you an  
24 answer to that, and this might, may or may not  
25 help. But we did a sensitivity run. As an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 example, the staff performed a CONTAIN run where  
2 the extreme combination of dry bulb and wet bulb  
3 temperatures were used, with no swing.

4 Okay, this was 100. We used 116  
5 degrees Fahrenheit dry bulb, and 33 percent  
6 relative humidity, resulting in 88 degree  
7 Fahrenheit coincident wet bulb. Now these  
8 parameters are well outside the applicant's  
9 design envelope, and are not realistic for any  
10 sites, in my opinion.

11 The temperature was not allowed to  
12 vary, so there's no swing.

13 MEMBER STETKAR: So just to make sure I  
14 understand, 72 hours, 88 degrees wet bulb.

15 MR. O'DRISCOLL: Wet bulb. 116 degree  
16 dry bulb, okay? The resulting CONTAIN results  
17 was 93.1, okay. This is the applicant's CONTAIN  
18 analysis. It was .1 degrees above their  
19 acceptance criteria, okay, in the main control  
20 room, with an 86.4 degree wet bulb global  
21 temperature index.

22 So for that case, they're actually  
23 below their acceptance criteria, which is 89  
24 degrees.

25 DR. WALLIS: Even though there are no

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 swings at all?

2 MR. O'DRISCOLL: No swings at all.

3 MEMBER STETKAR: This is flat.

4 MR. O'DRISCOLL: Right. They  
5 calculated --

6 (Simultaneous discussion.)

7 MR. O'DRISCOLL: I won't ask that one.

8 MEMBER STETKAR: That's a pretty good  
9 calculation.

10 MR. O'DRISCOLL: Okay. We also did a  
11 run --

12 DR. WALLIS: Bounding calculation.

13 CHAIRMAN CORRADINI: I guess I -- can  
14 you just say it again slower?

15 MR. O'DRISCOLL: Okay. I'm going to  
16 talk about two sensitivity analyses on this.

17 CHAIRMAN CORRADINI: That's fine. But  
18 just do the one you just did again.

19 MR. O'DRISCOLL: Okay. As an example,  
20 the staf f performed a CONTAIN run where the  
21 extreme combination of dry bulb and wet bulb  
22 temperatures were used, with no swing.

23 This was 116 degrees Fahrenheit dry  
24 bulb, and 33 percent relative humidity, which  
25 results in an 88 degree Fahrenheit coincident wet

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bulb. This input parameters are well outside the  
2 applicant's design envelope, and are not  
3 realistic for any site, in my opinion.

4 The temperature was not allowed to  
5 vary. The resulting CONTAIN results was 93.1  
6 degrees dry bulb in the main control room, with  
7 an 86.4 degree wet bulb globe temperature index.

8 The calculated wet bulb globe temperature index  
9 is still within the ITAAC acceptance criteria.

10 We also did a run with the worse case  
11 non-coincident wet bulb allowed with no swing.  
12 In order to maximize the humidity in the control  
13 room, we made the coincident dry bulb 88.

14 The resulting CONTAIN results was 90  
15 degrees Fahrenheit in the control room, with a  
16 wet bulb globe temperature index of 88.32  
17 degrees. The calculated wet bulb globe  
18 temperature index is more than one degree lower  
19 than the applicant's proposed ITAAC acceptance  
20 criteria for the wet bulb globe temperature  
21 index.

22 Based on these examples, it can be  
23 reasoned that a failure to select the correct  
24 high site -specific wet bulb globe temperature  
25 index temperature result results in low risk that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a site would be selected that has environmental  
2 parameters that would result in failure to meet  
3 the ITAAC acceptance criteria.

4 That is, an error in the calculation in  
5 the site-specific magnitude of the daily average  
6 dry bulb swing for use in the high humidity case,  
7 would result in very low risk of failure to meet  
8 the ITAAC acceptance criteria for the as -built  
9 plant.

10 MEMBER STETKAR: Essentially what  
11 you're saying is it doesn't make too much  
12 difference precisely how you specify those --

13 DR. WALLIS: You did a bounding  
14 calculation, bounding the worst you could  
15 possibly be. So I don't understand why you deal  
16 with all these wiggles on that.

17 CHAIRMAN CORRADINI: Because the  
18 wiggles are real, so they've got to --

19 MEMBER STETKAR: Well, the wiggles are  
20 real. You still, you know, Jim was careful to  
21 say in his opinion, those conditions would never  
22 be exceeded at a site, if you have some place in  
23 the swamps of Lord knows where.

24 CHAIRMAN CORRADINI: Brazil.

25 MEMBER STETKAR: That might be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 exceeded.

2 DR. WALLIS: Oh, I see.

3 MEMBER STETKAR: So you still have --  
4 the COL applicant still has to do some sort of  
5 confirmation, that indeed --

6 DR. WALLIS: So it's more 116 degrees  
7 on the average or something?

8 MR. MARQUINO: This is Wayne Marquino.  
9 Maybe I can wrap this up. GE has done similar  
10 calculations, and we agree with the staff that --  
11 we found that it's the high temperature that's  
12 most important, and the low temperature and the  
13 swing is not very important.

14 In terms of why didn't we do the  
15 analysis that way? Number one, we didn't know  
16 that when we started. Number two, if we had done  
17 it that way, people would say everyone knows the  
18 temperature drops at night. Why didn't you  
19 include that in your analysis?

20 DR. WALLIS: Because you were being  
21 conservative.

22 MR. MARQUINO: So we have an analysis  
23 with something similar to the sinusoid variation  
24 in temperature. You see weather data which isn't  
25 very sinusoidal, but the staff has worked out a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 parameter that characterizes the real weather,  
2 and it seems to be adequate to me.

3 MEMBER ARMIJO: And that's the index?

4 MR. MARQUINO: Yes, that's that index.

5 CHAIRMAN CORRADINI: I might be  
6 speaking too much for the rest of the Committee,  
7 but I don't think we want any more examples.

8 DR. WALLIS: Well, I'm just happy that  
9 5046 is simpler.

10 (Laughter.)

11 MEMBER ARMIJO: This is a lot like IRS  
12 inspections.

13 (Laughter.)

14 MR. HARBUCK: Okay. Why don't we go to  
15 the language of the --.

16 (Simultaneous discussion.)

17 MR. HARBUCK: This sort of revisiting  
18 the issue of the temperature monitoring in spaces  
19 outside the control room, and why don't we have  
20 an LCO on that. So first, let me address why we  
21 have an LCO on the heat sink temperature for  
22 CRHAVs. I'll be not as explicit as could be. We  
23 do it through a surveillance requirement.

24 But the CRHAVs meet CLCL (ph) Criterion  
25 3, and its passive cooling function depends on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the heat sink initial temperatures, and it's also  
2 part of the primary success path for a mitigated  
3 condition that you would have.

4 And then you deviated where you lost  
5 power, so you didn't have the normal cooling  
6 function, and because it supports control room  
7 habitability to meet GDC -19. So that's why we  
8 have CRHAVs.

9 Now going back to this o ther, in the  
10 past, we did have technical specifications on  
11 area temperature monitor and also on systems that  
12 were in place to maintain temperatures, that  
13 latter being Hatch Unit 1, which had custom tech  
14 specs, and the Hatch Unit 2, which had the old  
15 standard tech specs, and these are BWR -4, with a  
16 Mark I containment.

17 In the BWR standard tech specs, it's  
18 Grand Gulf Unit 1. It had an area temperature  
19 monitoring tech spec. Now when we -- when the  
20 interim policy statement in 1987 established the  
21 criteria for what you have to have an LCO for,  
22 the industry was asked to go and take a look at  
23 the standards at the time, and specifically base  
24 it on existing plant's tech specs, and for BWRs,  
25 Hatch Unit 2 and Grand Gulf Unit 1 were chosen.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Hatch Unit 1 was chosen also, but it  
2 didn't appear in the initial report from GE, the  
3 topical report, which you may have heard  
4 mentioned.

5 And the conclusion of that analysis was  
6 that the area temperature monitors did not meet  
7 the criterion, and also, when we did the  
8 conversion of the Hatch Unit 1 tech specs to the  
9 standard, we came to the conclusion that the room  
10 air coolers also did not meet the criteria.

11 Because the purpose of both of these  
12 flavors of tech specs was simply to maintain  
13 equipment qualification, and indeed the action  
14 requirements simply stated well, as long as  
15 temperature's not too high, just write a report.

16 If it is higher than say 30 degrees, write a  
17 report, but also shut down the plant.

18 So in the Hatch tech spec, the custom  
19 tech specs say to say hey, if the room coolers  
20 aren't working, shut down the plant, you know.  
21 that was the action requirement, was to shut  
22 down. So with the criteria for what needs to be,  
23 we need to have an LCO for, we -- what am I  
24 trying to say is that the issue here is equipment  
25 qualification.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           If the temperature of the room is not  
2 what it's normally supposed to be, then you  
3 evaluate what's the impact on operability of any  
4 equipment in the room. And you do that using the  
5 guidance that's been provided by the staff in RIS  
6 2005-20.

7           There's still lots of things that go  
8 into the operability of a piece of equipment, and  
9 equipment qualification is one. So there's -- I  
10 have summarized the criteria there's that  
11 -- because to address this temperature  
12 monitoring, because we don't usually include  
13 monitoring instrumentation or indication -- only  
14 instrumentation in tech specs, with the exception  
15 of those that are used to detect degradation of  
16 the reactor pump pressure boundary.

17           These temperature monitors are not in  
18 the primary success path for any accident, and  
19 the monitors are also not in initial conditions  
20 for any DBA, or the temperature is not initial  
21 conditions for any design basis action.

22           However, if in your operability  
23 assessment, upon having a high temperature in the  
24 room, you determine that that equipment can no  
25 longer be considered operable, then you would

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 take the appropriate LCO actions. So the  
2 conclusion is is that 5036 does not require an  
3 LCO for the temperature monitors on the heat  
4 sinks or the temperatures themselves.

5 DR. WALLIS: Do I go back to Jim? I  
6 don't understand what you said. We saw these  
7 curves with these diurnal variations, and we saw  
8 the response of the control room. At night, the  
9 rate of increase decreased, by the way.

10 I thought you said that you did a run  
11 where you kept the temperature 116 all the time,  
12 without cooling down at night? Is that what you  
13 said?

14 CHAIRMAN CORRADINI: That's what he  
15 said.

16 DR. WALLIS: And you still met the  
17 criteria, which is sort of hard to believe, when  
18 you look at this curve, and the night has a big  
19 effect.

20 MR. O'DRISCOLL: Well, we were above --  
21 I mean we were 93.1. So the applicant's analysis  
22 was 93.1

23 MEMBER STETKAR: That was a GE CONTAIN  
24 analysis, not the staff's analysis.

25 MR. O'DRISCOLL: Right. We did it on -

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 - once we were satisfied with CONTAIN 2.0, we did  
2 these on CONTAIN 2.0.

3 DR. WALLIS: Well, what is the -- but  
4 the CONTAIN analysis, G analysis for this one is  
5 pretty close to 93, isn't it?

6 MR. O'DRISCOLL: Okay. I can compare  
7 the two runs. I've got them here.

8 DR. WALLIS: It's 92, right, and you've  
9 got one degree more?

10 MR. O'DRISCOLL: Yes.

11 DR. WALLIS: You got one degree more.

12 MR. O'DRISCOLL: You have, let's see,  
13 92.04. You have about 1.0, something, not even -  
14 - a little bit of a smidgen over a degree.

15 DR. WALLIS: Well it's hard to believe,  
16 when you look at how much this heats up during  
17 the day, and how much it doesn't heat up during  
18 the night.

19 MR. O'DRISCOLL: Well because, you  
20 know, your EFU has got 460 -- there's only a  
21 small amount of air coming in. All that air is  
22 coming in from that emergency fan unit. The  
23 control room is buried inside the control  
24 building, but it's getting this hot air coming  
25 in, and that heat that's used in the model is the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sensor wall heat and the humidity that's  
2 contained in the air that's being pumped into the  
3 room.

4 DR. WALLIS: I think the humidity may  
5 do it, because the humidity -- the water content  
6 stays constant, whether you cool down or not.

7 MR. O'DRISCOLL: The biggest concern  
8 when we look at it generally was humidity issues,  
9 and the human performance impact. We were much  
10 closer to acceptance criteria on humidity for  
11 this room. If the room gets very humid, it gets  
12 --

13 DR. WALLIS: That could be what's doing  
14 it, because I think when you cool down at night ,  
15 you don't change the water content of the air.  
16 The water doesn't disappear. The water just gets  
17 a high humidity level.

18 MR. O'DRISCOLL: That's right, that's  
19 correct.

20 DR. WALLIS: Wet bulb doesn't change  
21 that much.

22 MR. O'DRISCOLL: That's right. The  
23 water content stays in. The relative humidity  
24 goes up when the --

25 DR. WALLIS: Well, it's still a little

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hard to believe.

2 CHAIRMAN CORRADINI: I think John has a  
3 question.

4 MEMBER STETKAR: No, I don't.

5 CHAIRMAN CORRADINI: Oh, I thought you  
6 did.

7 DR. WALLIS: It's hard to believe.

8 MR. GALVIN: Okay. So this one wasn't  
9 actually -- this goes down to 20 percent at --

10 (Simultaneous discussion.)

11 MR. GALVIN: 93 humidity. It's a  
12 different case.

13 MR. O'DRISCOLL: Yes.

14 CHAIRMAN CORRADINI: This is a 20  
15 percent relative humidity case. This is nice dry  
16 air.

17 MR. O'DRISCOLL: This is a separate  
18 analysis entirely from what I've shown here.

19 MEMBER STETKAR: Okay. So this is -- I  
20 should take this.

21 MR. O'DRISCOLL: Yes, please.

22 CHAIRMAN CORRADINI: Other questions?  
23 Okay. You guys did an absolutely excellent job.  
24 I figure we'd never come to a good understanding  
25 of this. But excellent job.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. O'DRISCOLL: Thank you.

2 DR. WALLIS: Excellent job. Still,  
3 they still have to use some engineering judgment  
4 to decide whether it's okay or not.

5 CHAIRMAN CORRADINI: Thank God we need  
6 engineers.

7 DR. WALLIS: It certainly will be nicer  
8 if it would -- well, for me, it would be nicer if  
9 it's more clear-cut and didn't depend upon these  
10 odd initial conditions and things like that.  
11 Maybe I should just say I rely on your judgment  
12 and I don't have to assert my own.

13 MR. GALVIN: I mean I think like what  
14 Mike Arcaro said. It's somewhat of an artifact  
15 of the way this analysis was performed and  
16 developed over time.

17 DR. WALLIS: It's also the worse  
18 condition. I mean it's the worse day of the year  
19 and everything else.

20 MR. GALVIN: I have to do an  
21 operability analysis if it gets -- if you don't  
22 choose the worse day of the year.

23 MS. CUBBAGE: All right, so we're done.

24 CHAIRMAN CORRADINI: So I think --  
25 should I go through and ask people's opinions, or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 wait until we get through the glories of Chapter  
2 7? I have a series of comments. Maybe we should  
3 take about five minutes and go past everybody  
4 without Chapter 7, and see if there's key things.

5 I have things written down, but maybe I  
6 should add to my list. Dr. Cress.

7 MEMBER KRESS: Well, let's talk about  
8 squib valves first.

9 CHAIRMAN CORRADINI: Oh good. I have  
10 that on my list. Go ahead.

11 MEMBER KRESS: Okay. I still think  
12 that you don't do an in situ test. I think the  
13 process of inspection and testing the igniters is  
14 what you need. I think they need some sort of  
15 innovative way to inspect, and they need to be  
16 thinking about how to do that.

17 I also think you need a significant  
18 qualification program outside, that is  
19 statistically relevant. You know, that sounds  
20 very hard and expensive to me, so I don't know  
21 what the trade-off is there. That's number one.

22 Number two, seismic effects on Category  
23 1 components from Category 2 and 3. Seismic  
24 effects.

25 CHAIRMAN CORRADINI: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER KRESS: I know they showed that  
2 the Category 2 components and 3 wouldn't collapse  
3 under this earthquake, and I still worry about  
4 what earthquake would make them collapse, which  
5 is a PRA issue and they did a seismic margins  
6 PRA, which doesn't really capture that. So I  
7 worry just a little bit about me missing  
8 something there.

9           CHAIRMAN CORRADINI: Just to push back  
10 a little bit though, but my understanding is the  
11 seismic margin is an acceptable approach.

12           MEMBER KRESS: Oh yes, yes. I mean  
13 there's lots of acceptable approaches that leave  
14 me worried.

15           CHAIRMAN CORRADINI: Okay.

16           MEMBER KRESS: Added mass I'd like to  
17 talk a little more about, for spent fuel pools.  
18 My view of the shaking of spent fuel pools is  
19 that you don't shake the racks; you're shaking  
20 the wall, and it's approaching the racks, and how  
21 close the wall approaches the racks depends on an  
22 added mass that's brought about by moving the  
23 water at the wall, up, down and down the other  
24 wall.

25           That's a different kind of added mass

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 than you normally think of with an array of  
2 bundles. I don't know what they used. We didn't  
3 see the details of the calculation.

4 So I think we need to look a little  
5 more about whether those walls are going to  
6 impact those racks or not, and how did they do  
7 the added mass part of it. So I'd like to see a  
8 little more about that.

9 I was all right with the blow down  
10 effects on the internal structures. I thought at  
11 first it was going to be a flow-induced  
12 vibration, because you've got higher flows. But  
13 that wasn't what they did, and I don't really  
14 think that's important to those internal  
15 structures. So I was all right with that.

16 I was intrigued with the comment that  
17 they did the calculations for the spent fuel pool  
18 using an equivalent porous medium.

19 CHAIRMAN CORRADINI: This is staff now  
20 we're talking?

21 MEMBER KRESS: Yes, staff and GE. They  
22 both did the same thing. But, you know, if I  
23 look at a spent fuel pool and think about how the  
24 flow travels through the bundles, I've got flow  
25 resistances that are not isotropic. They differ

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in all different directions, and I don't know how  
2 they account for that.

3 I would like to see more about how they  
4 did the equivalent flow resistance to put into a  
5 porous medium.

6 CHAIRMAN CORRADINI: That's an open  
7 item I think they'll provide.

8 MEMBER KRESS: Okay. It's an open  
9 item.

10 MR. GALVIN: No, we were going to do  
11 the open item on the temperatures.

12 MEMBER ABDEL-KHALIK: No. GE was going  
13 to come back to us with that information.

14 MR. GALVIN: Oh, okay.

15 MEMBER KRESS: Yes, and there was  
16 somebody suggested that go to -- when you get  
17 into the operational stage, to actually use  
18 thermal models for the control room, and then  
19 just any old day and see if you can calculate  
20 what's going on there as they check on the  
21 models.

22 I think I'd support that. That doesn't  
23 sound like too tough a thing to do, and I don't  
24 know where you'd require this or how you'd put in  
25 with a rule. But that's all the things I have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on my list.

2 CHAIRMAN CORRADINI: Okay, thank you.  
3 Graham.

4 DR. WALLIS: Yes. I think they'll have  
5 to look back on PCCS. We still have this added  
6 mass thing for the PCCS in my mind, where it may  
7 be more important than for the fuel pools.  
8 Certainly, you can't just add some mass. You've  
9 got a coupling, an inertial coupling as you  
10 jiggle the water such that it can't respond, and  
11 you can't just add mass to the structure.

12 You've go to look at the way in which  
13 there's a term in -- or is in the motion of both  
14 the fluid and the structure, which represents the  
15 reaction between them as a result of relative  
16 acceleration. I haven't seen that expressed  
17 properly. Otherwise, I thought the questions of  
18 fuel pool heating and cooling and boiling off and  
19 so on were satisfactory.

20 Tom, I think the porous medium thing is  
21 probably okay. It's been used before.

22 MEMBER KRESS: Well, I think it's okay.  
23 I'd just like to see a little more --

24 DR. WALLIS: And then the flow is  
25 mostly in one direction. There isn't much cross -

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 flow in there.

2 CHAIRMAN CORRADINI: I mean just to  
3 make sure we're clear. The maximum temperatures  
4 are still very low.

5 DR. WALLIS: Very low.

6 CHAIRMAN CORRADINI: I think from a  
7 quantitative standpoint they could be --

8 MEMBER KRESS: I don't think there's a  
9 problem. I just --

10 (Simultaneous discussion.)

11 DR. WALLIS: I think this boy has  
12 enough experience for this and CFX is a normal  
13 thing to use. So I'm satisfied with that. This  
14 control room heat -up is extra ordinarily  
15 complicated, and you have to use some judgment  
16 when you look at all the evidence supplied.

17 I'm inclined to say that it's okay, but  
18 I am puzzled by how if you keep the temperature  
19 up all the time, looking at the amount of wiggle  
20 you get when you don't keep it up all the time,  
21 that it can not have a bigger effect. So I think  
22 that's puzzling to me.

23 What also we talked about, I guess  
24 where the water goes when you boil off the spent  
25 fuel pool. Even if it all lands in the building,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it doesn't matter, because there's nothing left  
2 there that you're concerned about from a safety  
3 point of view, and if it goes outside, then  
4 presumably it's no worse than having a bad  
5 snowstorm, and that's protected against by roofs  
6 and so on. So probably that is all right.

7 Again, I'd be interested to have the  
8 staff make the decision rather than me, to give a  
9 case about why it's all right. What else was  
10 there?

11 CHAIRMAN CORRADINI: Well, the one  
12 thing --

13 DR. WALLIS: Oh seismic. I was a  
14 little puzzled by some of the answers about  
15 seismic, but I didn't push them too much, because  
16 it's not really my subject. But I didn't really  
17 understand some of those things about  
18 coefficients of friction.

19 Okay, squib valve testing. Well  
20 enough's been said about that, I think, already.

21 This is a tough thing to do. New device, you  
22 can't test a great number of them to get  
23 assurance. You can't test them in situ; it  
24 doesn't tell you anything. It's hard for me to  
25 see how you really get that really high percent

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 probability that they won't fail. I'm not quite  
2 sure how you do that.

3 I'll write some other stuff on the  
4 other issues.

5 CHAIRMAN CORRADINI: Okay.

6 DR. WALLIS: I think we do need to know  
7 what equations were used in these added mass  
8 models, for both the PCCS -2 and the spent fuel  
9 pool.

10 CHAIRMAN CORRADINI: Sam.

11 MEMBER ARMIJO: Okay. On the squib  
12 valves, I think it's a tough development program,  
13 and it all depends on the requirements that are  
14 put into the development program. In addition to  
15 having them work one time, they have to work over  
16 a period, you know, with aging.

17 I think a number of severe tests in the  
18 development program, as opposed to hundreds of  
19 tests, would probably be more practical. I think  
20 they'll work, and I don't think it's practical to  
21 test them in a plant at all.

22 As far as the boil-off stuff, pretty  
23 straightforward. I didn't have any problem. I  
24 don't think there's a big problem with -- I don't  
25 see a problem with the seismic and impact of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 racks with the pool wall. I think they're  
2 awfully tight in some dimensions. But just from  
3 an engineering standpoint, I'd put a little more  
4 room, where you've got like eight millimeters or  
5 something.

6 DR. WALLIS: They're not tied down, are  
7 they?

8 MEMBER ARMIJO: Oh yeah. They're  
9 bolted down to the floor of the --

10 DR. WALLIS: That's what I didn't get.  
11 I got the impression that they just moved  
12 around.

13 MEMBER ARMIJO: I was shown a sketch  
14 during off time. So I don't think there's a real  
15 problem there. I think the --

16 DR. WALLIS: They were said to be free-  
17 standing. Doesn't that mean they're not tied  
18 down?

19 MEMBER ARMIJO: They're bolted to the  
20 floor, to the floor of fuel pool.

21 (Simultaneous discussion.)

22 MR. GALVIN: The spent fuel pool,  
23 they're free-standing. The buffer pool, they're  
24 bolted down.

25 DR. WALLIS: They're not bolted down?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: The racks are bolted.

2 MR. GALVIN: No. In the spent fuel  
3 pool, they're not. They're free-standing.

4 DR. WALLIS: It could be a piece of  
5 furniture.

6 MEMBER ARMIJO: And they're just  
7 sitting there in place?

8 MR. GALVIN: Yes, like a piece of  
9 furniture.

10 MEMBER ARMIJO: Yes. Okay, what --  
11 where are the bolted ones?

12 MR. GALVIN: The buffer pool.

13 MEMBER ARMIJO: In the buffer pool?

14 MR. GALVIN: Yes.

15 MEMBER ARMIJO: Okay.

16 MR. GALVIN: In the reactor building.

17 MEMBER ARMIJO: Okay. Well then I'd  
18 better back off on my conclusion that nothing  
19 much is going to happen.

20 DR. WALLIS: Why aren't they bolted  
21 down? It seems to be a simple thing to do. I  
22 mean if you're worried about --

23 MR. GALVIN: It's an installation  
24 problem, I think. That's what Wayne would tell  
25 you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: It seems strange that  
2 in the buffer pool they'd be bolted; in the spent  
3 fuel pool, they wouldn't.

4 MR. GALVIN: There's not many racks in  
5 a buffer pool.

6 MS. CUBBAGE: This is not a novel  
7 design, right?

8 MEMBER ARMIJO: I think it's different.

9 MR. GALVIN: Well no, not terribly.

10 MEMBER ARMIJO: I think this is a  
11 typical design. Okay. As far as the control  
12 room habitability, thermal analysis, I think it's  
13 pretty -- the two independent models and the  
14 sensitivity studies convinced me there's, you  
15 meet the requirements. So I don't see any  
16 problem there.

17 I'll just, as far as the index  
18 calculation, I was totally confused. That is  
19 very similar to filling out your tax forms when  
20 you have a complicated thing to do. I'm glad it  
21 only has to be done by somebody else. That's all  
22 I have.

23 CHAIRMAN CORRADINI: Okay.

24 MEMBER STETKAR: I think other folks --  
25 by the way, I'd like to thank both the staff and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 GEH. I thought the presentations today were  
2 really good, and the discussions were really  
3 good. They closed out a lot of kind of open  
4 concerns. I'll come down on the side, would  
5 advocate functional testing of the squib valves,  
6 meaning to verify that they operate under design,  
7 you know, pressure differential and things like  
8 that.

9 It's difficult to do, but it's a new  
10 piece of equipment. You can't develop statistics  
11 to predict that they're going to fail ten to the  
12 minus five for demand, but you might discover  
13 something that you didn't expect. That's the  
14 concern. It's a confidence builder, not a  
15 reliability quantifier.

16 I'd also advocate a pre-op test to  
17 verify that the passive cooling system, namely  
18 the concrete in the control room works, or that  
19 more accurately, that indeed the observed  
20 behavior of that system is adequately represented  
21 by these models, you know, whatever best model  
22 you can decide on.

23 And in all deference to the tech spec  
24 experts, I'd really like to see a tech spec on an  
25 LCO, specifically for the temperature sensors

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that turn off the non -safety heat loads in the  
2 control room, because --

3 MS. CUBBAGE: That would be difficult  
4 to justify under 5036.

5 MEMBER STETKAR: Well, you know, I  
6 don't know what 5036 is. I'll admit ignorance  
7 there.

8 (Simultaneous discussion.)

9 MEMBER STETKAR: Hear me out for a  
10 second. I'm staring at tech specs for the ESBWR,  
11 that specifically applied to the neutron  
12 monitoring system, and I have an LCO that says  
13 one or more functions with one require d division  
14 inoperable. I have a 12 hour completion time to  
15 do something, and I have a separate surveillance  
16 requirement to verify functional operability once  
17 every 24 months on a staggered test basis.

18 I'm assuming that these technical  
19 specifications satisfy 50 whatever it was.

20 MS. CUBBAGE: 5036, Criterion 2, I  
21 believe.

22 MEMBER STETKAR: And I don't understand  
23 why the analogous conditions don't apply for  
24 these temperature monitor that do something to  
25 verify a safety function, mainly control room

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 cooling, that I meet those room heat up things.

2 To me, I don't understand why they're different.

3 MR. HARBUCK: I believe that the  
4 requirements we currently have in the tech specs  
5 were, they evolved from questions from the staff,  
6 from changing from the EBASS (ph) system to go to  
7 CRHAVs. But as I described in my presentation,  
8 the way the rules of the tech specs were, that  
9 function that you're talking about actually is  
10 the subject of an LCO.

11 It's not as straightforward or as clear  
12 as it could be, and that might be something we  
13 should look into.

14 MEMBER STETKAR: My concern is, you  
15 know, I come from an operational background. My  
16 concern is if I go look at the tech specs for the  
17 neutron monitoring instrumentation, it's really  
18 clear to me --

19 MS. CUBBAGE: Those directly pertain to  
20 one of the criteria in 5036 for a fission product  
21 barrier.

22 (Off mic comment.)

23 MEMBER STETKAR: Well, but don't the --  
24 doesn't shutting off the non-safety heat loads in  
25 the control room directly apply to control room

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 habitability for a design basis accident  
2 scenario?

3 MR. HARBUCK: In the tech specs, that's  
4 addressed by the functioning of the CHRAVs, and  
5 it's also addressed by the instrumentation  
6 functions that cause automatic -- cause different  
7 configurations or starting the syst em  
8 automatically on certain parameters.

9 MEMBER STETKAR: The only thing is,  
10 Craig, that these particular temperature sensors  
11 don't do any of that things that you just said.

12 MR. HARBUCK: It's a fairly  
13 straightforward, simple function that --

14 MEMBER S TETKAR: That's a message.  
15 Think about it from an operational sense, in  
16 terms of consistency in the way that  
17 instrumentation LCOs and surveillance  
18 requirements are specified in these technical  
19 specifications, and try --

20 If you're confident that indeed the  
21 protection of not exceeding a required, you know,  
22 plant configuration, if indeed you're convinced  
23 that the current technical specifications provide  
24 that protection and the way that they might be  
25 interpreted.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Also think whether or not the owner  
2 operator of the plant, reading the           technical  
3 specifications, could easily understand how that  
4 function is met, you know,           in particular for  
5 those temperature sensors. Because of the  
6 protection is there and there's no down side of  
7 putting an LCO on them. In othe   r words, your  
8 assertion is there's already an LCO.

9           MR. HARBUCK: I think perhaps, you  
10 know, if I hear what you're saying, is that there  
11 needs to be perhaps more explicit appropriate  
12 action requirements.

13           CHAIRMAN CORRADINI: I think he's  
14 bringing some clarity.

15           MEMBER STETKAR: I'm looking for  
16 clarity in the same way as I look at, for  
17 example, the neutron monitoring system. If I'm  
18 an operator, if I have two trains of neutron  
19 monitoring, two channels down, it's very clear  
20 that I need to do something, an   d I have a  
21 specific time window.

22           MS. CUBBAGE: I think we need to take a  
23 timeout on this. We need to caucus.           I'm not  
24 proposing that we're going to ask GE to make any  
25 changes in this area.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Okay.

2 CHAIRMAN CORRADINI: Others, John?

3 MEMBER STETKAR: No. I have no  
4 additional comments.

5 CHAIRMAN CORRADINI: So I can put your  
6 initials anywhere on the list?

7 MEMBER STETKAR: Right.

8 CHAIRMAN CORRADINI: Okay, all right.  
9 I do have three or four action items. No, I take  
10 it back. Three action items that we have. Heavy  
11 load lifting, to be answered relative --

12 MS. CUBBAGE: GE plans to get back  
13 tomorrow on that topic.

14 CHAIRMAN CORRADINI: Right. The open  
15 item on -- I thought it was more to the staff  
16 than it was to GE, on the iso tropic versus non-  
17 isotropic, I call them friction factors or form  
18 factors relative to flow in the spent fuel pool  
19 cooling.

20 MEMBER ARMIJO: Either one of them.

21 CHAIRMAN CORRADINI: Well, I think  
22 Chris was answering your question, but I thought  
23 we left it with staff. But I'm sure you would  
24 love to explain it to us.

25 MR. GALVIN: You're going to have to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 get an answer from GE.

2 CHAIRMAN CORRADINI: Okay, that's fine.  
3 That's right. You're not on the docket. You're  
4 just checking the docket.

5 MR. MARQUINO: An answer on what?

6 CHAIRMAN CORRADINI: On your modeling  
7 of --

8 (Simultaneous discussion.)

9 CHAIRMAN CORRADINI: When you're  
10 modeling the porous medium, when you're flowing,  
11 let's say, perpendicular to the bundle or  
12 parallel to the bundle, what is your form losses?  
13 How are you modeling the form losses.

14 And then the third one was that at  
15 first we thought there was no check valve, then  
16 we thought there was a check valve. Now it's a  
17 matter of valve wind-up relative to the FAPCS.

18 MEMBER STETKAR: I think I'm okay on  
19 that, except I'd still -- just to kind of, it's a  
20 curiosity issue, to follow up on the size of the  
21 pipe and the rate at which it would drain, if for  
22 some reason you could get into that lineup.

23 CHAIRMAN CORRADINI: Good. So with  
24 that, the decks are clear tomorrow for Digital  
25 Inc. and we are siked (ph).

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. GALVIN: All right. Is Charlie  
2 going to be here tomorrow?

3 CHAIRMAN CORRADINI: God, I hope so.

4 MR. GALVIN: That's an excellent  
5 question.

6 (Simultaneous discussion.)

7 CHAIRMAN CORRADINI: We're adjourned.  
8 Thank you.

9 (Whereupon, at 6:17 p.m., the meeting  
10 was recessed, to reconvene on Friday, September  
11 24, 2010 at 8:30 a.m.)

12

13

14

15

16

17

18

19

20

21

22

23

24

25

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701


GE Hitachi Nuclear Energy

# ESBWR Chapter 3: Design of Structures, Components, Equipment, and Systems

Advisory Committee on  
Reactor Safeguards

Sujit Niogi

September 23, 2010



**HITACHI**

# Introduction

The following NRC RAIs will be discussed in this presentation:

- 3.8-79 (Seismic II/I Issue & Seismic Gaps Between Structure)
- 3.8-94 (Soil Bearing Capacity & Enveloping FRS with Valleys Filled)
- 3.8-96 (Stability Analysis of the Structure due to Sliding)
- 3.8-107 (SSDP Computer Program Validation)
- 3.8-120 (Reactor Shield Wall)
- 3.8-125 (Impact of Spent Fuel Rack on Spent Fuel Pool Structure)



# NRC RAI 3.8-79

## Summary from RAI question:

Confirm that the Seismic Category II and Seismic Category NS structures, which are in close proximity to Seismic Category I structures, are designed to Seismic Category I requirements.

## Response:

The following structures are in close proximity to Category I structures:

- Seismic Category II: TB, SB & Ancillary Diesel Building
- Seismic Category NS: RW

Seismic Category II & Seismic Category NS structures listed above are designed to withstand SSE loads. The method of analysis of these structures are the same as the Seismic Category I structures including the load combinations and acceptance criteria. During SSE event, these structures will not collapse and impact a Seismic Category I structure. Also, the gaps between the structures are large enough to preclude impact due to out-of phase displacements during SSE event.

(cont'd)



**HITACHI**

# NRC RAI 3.8-79

## Conclusion:

- It was demonstrated that the Seismic Category II and Seismic Category NS structures, which are in close proximity to Seismic Category I structures, are designed to SSE requirements.
- The gaps between the structures are large enough to preclude impact during SSE event.

# NRC RAI 3.8-94

## Summary from RAI question:

- Confirm that the soil bearing demand is less than the soil bearing capacity due to static and dynamic loading conditions.
- Provide the technical basis for not considering the effect of uplift during SSE event in the bearing and sliding calculation which uses SASSI analysis results.
- The staff noted that “valleys” exist between successive peaks in the low frequency region. The staff requested that the these valleys should be filled-in to accommodate the expected variability in site shear wave profiles.

(cont'd)

# NRC RAI 3.8-94

## Response:

- GEH used the energy balance method to calculate the soil bearing pressure and considered both uniform and layered sites. GEH demonstrated that the soil bearing demand is less than the allowable soil bearing pressure. Results are documented in DCD Tier 1 Table 5.1-1 & DCD Tier 2 Table 2.0-1.
- GEH used the energy balance method which takes into account the effects of uplift in the linear response calculated by SASSI. It was concluded that this simplified method provides a reasonable estimate using the linear analysis results when the amount of uplift is less than 50% of the basemat dimension. As shown in Figure 1, the extent of uplift is not extensive and a large portion of the basemat remains in contact with the soil.
- GEH complied with the NRC request and filled the spectral valleys between the peaks as shown in Figure 2.

(cont'd)

# NRC RAI 3.8-94




Figure 1  
Plan View of RB/FB Complex Basemat  
Extent of Uplift for Maximum Bearing Capacity (DL + Buoyancy)  
(cont'd)



**HITACHI**

# NRC RAI 3.8-94




Figure 2  
Floor Response Spectra with Valleys Filled-In

(cont'd)



HITACHI

# NRC RAI 3.8-94

## Conclusion:

- It was demonstrated the soil bearing demand is less than the soil bearing capacity due to static and dynamic loading conditions.
- The technical basis for not considering the effect of uplift in the seismic demand loading in the bearing and sliding calculation which uses SASSI analysis results has been demonstrated.
- Spectral valleys between the peaks have been filled-in.

# NRC RAI 3.8-96

## Summary from RAI question:

- Confirm that the Seismic Category I structures meet the sliding stability requirements of the SRP 3.8.5.
- Justify use of static coefficient of friction beneath the basemat and along the vertical surfaces of the walls.
- Justify use of full passive pressure at the side of the vertical surfaces of the walls in the sliding resistance.
- How did GEH consider other potential sliding interfaces in addition to soil shear failure (i.e., basemat to concrete mudmat, concrete to soil)?

(cont'd)

# NRC RAI 3.8-96

## Response:

- It was confirmed that the Seismic Category I structures meet the sliding stability requirements of the SRP 3.8.5 by considering passive pressure resistance, resistance due to friction at the bottom of the basemat and along the vertical surfaces of the walls.
- GEH used reduced coefficient of friction in the vertical walls to calculate friction resistance due to passive pressure. In this evaluation passive pressure was needed to comply with the SRP 3.8.5 requirement.
- GEH added shear keys to the RB/FB complex and FWSC to increase the sliding resistance. See Figure 3.
- By roughening the top surface of the mudmat concrete, friction resistance is increased between the mudmat and basemat. Added troughs in the soil under the mudmat to increase shear resistance.




Figure 3

# NRC RAI 3.8-96 (cont'd)

## Conclusion:

- Seismic Category I structures meet the sliding stability requirements of the SRP 3.8.5.
- Static coefficient of friction of 0.7 beneath the basemat and a reduced coefficient of friction of 0.5 for the vertical surface of the wall is adequate to provide sliding stability.
- Additional reinforcement was added to the vertical walls to resist the passive pressure.
- Added requirements to increase the friction resistance between the basemat, mudmat and soil.

# NRC RAI 3.8-107

## Summary from RAI question:

NRC staff reviewed the SSDP computer program validation package but found that the validation did not satisfy items of interest, such as:

- How does SSDP apply the concrete codes used in the US and how are the code editions that are accepted by the NRC incorporated in SSDP to keep it current?
- How does SSDP identify critical sections of a structure?
- In the RCCV structure, how does SSDP evaluate the tangential shear stress to demonstrate compliance with the ASME code?
- GEH was requested to verify the equations used in the SSDP by comparing the quantitative results with the use of the equations presented in a concrete textbook.

(cont'd)



**HITACHI**

# NRC RAI 3.8-107

## Response:

- SSDP calculates stresses of concrete and reinforcements for forces and moments. Calculated stresses are compared with the allowable stresses specified in the applicable codes. SSDP has supplemental subroutines for the tangential shear and transverse shear, and it is confirmed that the provided sections satisfy the code requirements. The validation of SSDP provides confirmation that calculation results meet the requirements of code editions which are specified for the project.
- The equations used in the SSDP computer code were verified by comparing the results with the results from the equations presented in the concrete design text book.

(cont'd)

# NRC RAI 3.8-107

## Conclusion:

- The validation of SSDP confirmed that calculation results satisfy the requirements of the codes.
- The equations used in the SSDP computer code were verified with hand calculation.

# NRC RAI 3.8-120

## Summary from RAI question:

- NRC indicated in their review that the material thickness for the Reactor Shield Wall (RSW) in some locations is greater than 10 inches.
  - ASTM A-516 is only available up to 8¼ inches thick.
  - ASTM A-709 is only available up to 4 inches thick.
- NRC requested GEH to explain how RSW will be fabricated.
- The staff also raised a concern related to welding A-709 material to the containment steel liner and the acceptability of a code case for this type of welding.

(cont'd)



**HITACHI**

# NRC RAI 3.8-120

## Response:

- GEH plans to fabricate using 4 inch maximum thickness steel using multiple-layer vessel construction technique. Multiple layer construction has been very effective for cylindrical pressure vessels more than 16 inches thick. The construction techniques allow the multiple layer shells to act as a solid wall. There are four common types of layered construction used in the pressure vessel industry. These are identified in Section VIII of the ASME code.
- GEH provided a justification for dissimilar material welding with A-709 material as part of GEH's response to NRC RAI 6.1-12.

(cont'd)

# NRC RAI 3.8-120

## Conclusion:

- Fabrication technique in compliance with ASME code will be utilized.
- Welding of dissimilar materials with A-709 material has been satisfactorily addressed.



# NRC RAI 3.8-125

## Summary from RAI question:

Confirm that impact of the spent fuel storage racks will not adversely impact the spent fuel pool walls during SSE event which may cause overstressing of the concrete walls.

## Response:

The free-standing spent fuel storage racks are supported on embedded plates on the spent fuel pool basemat. To preclude the racks contacting the walls during an SSE event the free-standing racks were designed to provide sufficient gap between the racks and the walls.

## Conclusion:

Analysis has demonstrated that the racks will not contact the spent fuel pool walls.




GE Hitachi Nuclear Energy

# ESBWR Chapter 3: Section 3.9 Design of Structures, Components, Equipment, and Systems

Advisory Committee on  
Reactor Safeguards

Jerry Deaver

September 23, 2010



**HITACHI**

# Introduction

## Review of Selected Chapter 3 SER Open Issues:

- 3.9-75
- 3.9-96
- 3.9-81
- 3.9-177
- 3.9-254/255

# Open Issue 3.9-75

## Summary from SER Open Item:

The use of the terms “prototype” and “non-prototype” in DCD, Tier 2, Section 3.9.9.1, and NEDE-33259P are contradictory. The staff asked the applicant to revise Section 3.9.9.1 using RG 1.20, including the information on startup testing that will be provided to the NRC.

## Response:

GEH agreed to reclassify the ESBWR as a prototype, in accordance with Revision 3 of RG 1.20, for the reactor internals vibration program

## Conclusion:

GEH revised applicable sections of the DCD and NEDE-33259P to reflect this change in classification



**HITACHI**

# Open Issue 3.9-96

## Summary from SER Open Item:

The staff asked the applicant to explain why the testing for the first ESBWR plant is restricted to only those aspects that are perceived to demonstrate that the FIVs expected during operation do not cause damage. It was requested that GEH identify the differences in the tests that were conducted on the plant that are considered to be prototypical of the ESBWR reactor internals design, and those tests that are proposed to conduct on the reactor internals of the first ESBWR plant.

## Response:

- GEH provided a description of the reactor internals that were in the startup testing program and the number and location of sensors that would be used.
- The methodology of how the data would be evaluated was also provided
- Justification for components that do not need instrumentation was provided

## Conclusion:

A comprehensive vibration testing program has been established for the first ESBWR that is classified as a prototype plant



**HITACHI**

# Open Issue 3.9-81

## Summary from SER Open Item:

The staff requested that the applicant provide the analytical results to demonstrate that there is no significant dynamic amplification of the loads on the reactor internals CS structures as a result of the postulated break in the main steam line (MSL) or feedwater (FW) line

## Response:

- The only reactor internals vertical core support structure, are the control rod guide tubes/control rod drive housings (CRGTs/CRDHs).
- An assemblage of axial beam elements represents the CRGTs/CRDHs fuel vertical inertia load path in the vertical primary structure model.
- There is no vertical natural frequency, below 105.4 Hz.
- Blowdown loads associated with the MSL and FW line breaks do not excite the CRGTs/CRDHs.

## Conclusion:

- There can be no dynamic amplification of the blowdown loads through the CRGTs/CRDHs load path
- GEH revised DCD Tier 2, Section 3.9.2.5, Revision 5, to address this issue.



**HITACHI**

# Open Issue 3.9-177

## Summary from SER with Open Items:

GEH was requested to reinstate a COL item requiring that the ASME code design specifications and reports for equipment be made available to the NRC staff for audit

## Response:

- GEH responded by adding component ITAAC requirements to Section 2 of Tier 1 requiring that ASME code reports be made available for review.
- GEH prepared design specifications for ASME and Risk Significant mechanical components that were audited by the NRC staff.

## Conclusion:

Since GEH demonstrated their capability to prepare component design specifications and has implemented ITAAC commitments for ASME component design documentation



**HITACHI**

# Open Issue 3.9-254/255

## Summary from SER Open Item:

These open issues dealt with the qualification and use of the PISYS and ANSI7 computer codes that are used for the ESBWR piping analysis, and compliance with RG 1.92

## Response:

- GEH resolved open technical issues
  - Environmental effects on fatigue per RG 1.207 were incorporated into ANSI7 and implementation was audited
  - RG 1.92 rev 1 is used and computer codes were benchmarked using NUREG/CR-6049, which is permitted by RG 1.92 rev 2
- Level 2 qualification for each of these computer codes was completed and audited by NRC staff.

## Conclusion:

PISYS08 and ANSI7 version 14 are now fully qualified to perform piping analysis for ESBWR



**HITACHI**

# Summary

- The reactor Internals vibration program has been fully defined for the prototype plant
- GEH sufficiently demonstrated that it is capable of defining requirements and documentation that are required for the ASME code



**HITACHI**


GE Hitachi Nuclear Energy

# ESBWR Chapter 3: Section 3.12 Design of Structures, Components, Equipment, and Systems

Advisory Committee on  
Reactor Safeguards

Jerry Deaver

September 23, 2010



**HITACHI**

# Introduction

Review of Selected Chapter 3 SER Open Issues:

- 3.12-3
- 3.12-17
- 3.12-27

# Open Issue 3.12-3

## Summary from SER Open Item:

In RAI 3.12-3, the staff requested that the applicant either follow the recommendations in NUREG-1061 for the ISM method of analysis or provide the technical justification for an alternative method.

## Response:

- For Independent Support Motion (ISM), GEH prepared a representative calculations for the main steam and feedwater piping within containment to demonstrate that SRSS is an acceptable method to combine loads
- The comparison of Absolute Sum vs. SRSS showed that the majority of the SRSS data were bounded and in all cases were below 10%

## Conclusion:

It was agreed that for ISM analysis with 10% being added for piping stresses and support loads, the inertial and seismic anchor motion can be combined by SRSS when there are only two support groups



**HITACHI**

# Open Issue 3.12-17

## Summary from SER Open Item:

Justification for using SRSS should be demonstrated by showing that the non-exceedance probability of 84% or higher is satisfied per NUREG-0484

## Response:

### **Technical basis for GE BWR Mark II**

*The justification is based on probability theory, and qualitatively justified based on:*

- *The unlikelihood of load events*
- *Randomness of the amplitude and phasing of the responses*
- *Rapid + and – variation and very short duration of the peak responses A  
GE*

### BWR Mark II study:

- *291 dynamic load cases were evaluated that provides the quantitative technical basis that is representative of ESBWR dynamic events*

## Conclusion:

*Compliance with NUREG-0484 has been demonstrated*



**HITACHI**

# Open Issue 3.12-27

## Summary from SER Open Item:

SRP 3.9.2 Section II.2.g states that responses due to inertial effect and relative displacement for multiply-supported equipment and components should be combined by the absolute sum method (ABS). The staff requested that GEH provide a technical justification for using the SRSS combination of the inertial and SAM responses for the Uniform Support Method (USM) of analysis

## Response:

GEH provided a revision to DCD, Tier 2, Section 3.7.3.12, which requires that inertia and SAM responses be combined by the absolute sum method for piping support design using the USM method of analysis

## Conclusion:

The DCD is compliant with SRP 3.9.2



**HITACHI**

# Summary

- The analysis methods used for piping and piping supports is consistent with the SRP requirements
- For specific analytical cases, GEH has provided adequate justification for using the SRSS method for load combination

GE Hitachi Nuclear Energy


# ESBWR Chapter 9: Auxiliary Systems

Advisory Committee on  
Reactor Safeguards

Jerry Deaver

Mike Arcaro

September 23, 2010



**HITACHI**

# Agenda

- Spent Fuel Pool Decay Heat Calculation and associated analyses
- Spent Fuel Uncovery- Operating Experience Considerations
- Gas Accumulation in FAPCS- Operating Experience Considerations
- Auxiliary System Regulatory Treatment of Nonsafety- Related Systems (RTNSS) Function Overview
- Plant Service Water System (PSWS) Design Overview
- Reactor Component Cooling Water System (RCCWS) Design Overview
- Nuclear Island Chilled Water System (NICWS) Design Overview
- Instrument Air / Service Air (IA/SA) System Overview
- Summary




**HITACHI**

# Basis for Decay Heat Calculation

- SRP 9.1.3 rev 1 paragraph III.1.h.iii states:  
“The spent fuel pool cooling system should have the capacity to remove the decay heat from one full core at equilibrium conditions after 150 hours (6.25 days) decay and one refueling load at equilibrium conditions after 36 days decay, without spent fuel pool bulk water boiling.”
- The SRP assumed that this was the point in time that the maximum heat load occurs; however, ESBWR specific analysis shows that the maximum heat load occurs at the end of the operating cycle
- GEH has now reanalyzed using the maximum power vs. time input as a basis, and has used a bounding total decay power curve to provide design margin
- Latest Decay Heat Methodology used (audited by NRC staff):
  - **ANSI/ANS-5.1-1994 with  $2\sigma$  uncertainty**
  - **Includes misc actinides and activation products**




# SFP Decay Heat as a Function of Irradiation Time



**HITACHI**

# Energy Curves Used in Analyses



\*The boil-off period is from 150 hours to 222 hours based on NUREG-0800, 1981 Version.



**HITACHI**

# Spent Fuel Pool Boil-off Analysis Results

(Abnormal Condition = Full Core Offload + 20 Years of Spent Fuel)

- ESBWR safety-related spent fuel pool cooling method is attributed to pool boiling for 72 hours
- For the bounding case, a free volume of 1962 m<sup>3</sup> and minimum coverage height of 10.26 m over top of stored fuel assemblies (top of bail handle) is required
- Analyzed at a bounding 72 hour heat load of  $4.562 \times 10^6$  MJ, which is derived from an extrapolated power curve that applies to 20 years worth of fuel storage at 102% power
- NRC audit responses and impacted DCD sections have been updated to include these results

## Conclusion:

Under the bounding boil-off condition after 72 hours, water remains over the top of stored fuel assemblies



**HITACHI**

# Fuel Storage Rack Thermal-Hydraulic Analysis

(Abnormal Condition = Full Core Offload + 10 Years of Spent Fuel)

- An evaluation was performed considering a bounding abnormal heat load of 19 MW and compared with results from a prior ESBWR analysis that used 29 MW
- The rack exit temperature for the 19 MW case was determined to be less than the temperature for the 29 MW case, 80.9°C (limit is 121 °C)
- The maximum fuel cladding temperature for the 19 MW case is <97.12°C which is associated with the 29 MW case
- There is no condition within the fuel assembly that causes boiling, therefore, nucleate boiling is prevented

## Conclusion:


Evaluation of the bounding thermal-hydraulic case using 19 MW meets all of the design requirements



**HITACHI**

# Spent Fuel Pool Thermal Hydraulic Streamlines

- In LTR NEDO 33373 rev 4, the streamline figures shown have the rack domains in the rack disabled so that the streamlines can not be seen inside the racks
- The figure below shows flow from inlet #1, and the associated flow through the domain of only one of the spent fuel storage racks (#5)
- Racks are modeled as porous domains with characteristic pressure drop
- This clearly shows the expected flow path through a rack and the associated temperatures
- This figure has been added to rev 5 of the LTR



HITACHI

## Spent Fuel Uncovery - Operating Experience

### Summary from RAI 9.1-128S01 question:

(IE) Bulletin 84-03 and (IN) 84-93, were issued to address the potential failure of refueling cavity seals, failures associated with other seals, and draining of refueling cavities due to and as a consequence of valve misalignments to assure that fuel uncovery while refueling remains an unlikely event.

### Response:

DCD revision 7 provided additional details regarding design features associated with the refueling cavity bellows seal (DCD S.6.2.1.1.2 and F 6.2-35), DPV/IC nozzle plugs (DCD S 9.1.4.8 and S13.5.2) and refueling operation features provided to mitigate inadvertent drain down of the reactor cavity (DCD S12.4.4).

### Conclusion:

ESBWR design has addressed OE associated with refueling seals that assures that fuel uncovery during refueling is not credible

# Gas Accumulation in FAPCS- Operating Experience

## Summary from RAI 9.1-151S01 question:

Gas accumulation in nuclear power plant systems has been known to cause water hammer, gas binding in pumps, and inadvertent relief valve actuation that may damage pumps, valves, piping, and supports and may lead to loss of system operability. Address operating experience in the DCD for the FAPCS system which is categorized as a RTNSS system

## Response:

- FAPCS is a low pressure system that does not handle reactor coolant and is not subject to accumulation of any amount of non-condensable gas from the reactor
- The piping in this system is designed (line sloop, vents and drain placement) to minimize the risk of gas accumulation, and plant maintenance procedures are required to assure venting

## Conclusion:

ESBWR design has adequately addressed OE associated with gas accumulation in FAPCS.



**HITACHI**

# ESBWR Auxiliary System RTNSS Functions

## Summary from RAI question:

RAI 22.5-1-DCD Section 14.3.7.3 states that RTNSS systems shall have Tier 1 inputs that include design descriptions and ITAAC. The staff finds that the above position is not implemented consistently throughout the DCD.

## Response:

ESBWR Auxiliary Systems with RTNSS functions have been implicitly described in DCD Tier 2 and Tier 1 ITAAC have been included for all RTNSS functions.

## Conclusion:

ESBWR Auxiliary Systems described in DCD Chapter 9 provide RTNSS functions and RTNSS requirements are described for each RTNSS system.

# Auxiliary System RTNSS Function Overview

RTNSS Function	Description	Availability Controls
FPS Diesel Driven Pump	B - Long Term Core Cooling: RPV At-Power and Spent Fuel Pool; Long Term Containment Integrity	ACLCO 3.7.1
FPS Motor Driven Pump	B - Long Term Core Cooling: RPV At-Power and Spent Fuel Pool; Long Term Containment Integrity	ACLCO 3.7.1
FPS to FAPCS Connection Piping	B - Long Term Core Cooling: RPV At-Power and Spent Fuel Pool; Long Term Containment Integrity	ACLCO 3.7.1
FAPCS (LPCI, SPC Modes)	C - Focused PRA (Uncertainty)	ACLCO 3.7.2 ACLCO 3.7.3
FPS Water Tank	B - Supports core cooling for refill of pools	ACLCO 3.7.1
FPS Diesel Fuel Oil Tank	B - Supports Diesel Driven FPS pump	ACLCO 3.7.1



# Auxiliary System RTNSS Function Overview

RTNSS Function	Description	Availability Controls
Ancillary Diesel Generators	B - Supports FPS Motor Driven Pump, PCCS Vent Fans, CRHAVS AHUs, Emergency Lighting, Q-DCIS	ACLCO 3.8.3
Standby Diesel Generators	C - Supports FAPCS operation	ACLCO 3.8.1, ACLCO 3.8.2
Ancillary Diesel Building HVAC	B - Supports Ancillary Diesel Generators	Maintenance Rule
Electrical Building HVAC Area Cooling	C - Supports PIP Buses, N-DCIS for FAPCS	Maintenance Rule
Fuel Building HVAC Local Cooling	C - Supports FAPCS, N-DCIS for FAPCS	Maintenance Rule



# Auxiliary System RTNSS Function Overview

RTNSS Function	Description	Availability Controls
Reactor Building HVAC Local Cooling	C - Supports N-DCIS for FAPCS	Maintenance Rule
Turbine Building HVAC Local Cooling	C - Supports FAPCS	Maintenance Rule
CRHAVS Air Handling Units	B - Long-term control room habitability	ACLCO 3.7.6
CRHAVS Air Handling Unit auxiliary heaters and coolers	B - Cooling for post-accident monitoring heat loads	ACLCO 3.7.6



# Auxiliary System RTNSS Function Overview

RTNSS Function	Description	Availability Controls
RCCWS	C - Supports Standby Diesel Generators (supports FAPCS) and Nuclear Island Chilled Water Subsystem (NICWS)	Maintenance Rule
Nuclear Island Chilled Water	C - Building HVAC	Maintenance Rule
PSWS	C - Supports RCCWS	Maintenance Rule



# ESBWR Cooling Water System Design

## Summary from RAI question:

RAI 9.2-24 -Nonsafety-related (NSR) active systems are relied upon to achieve cold shutdown conditions in accordance with Technical Specification requirements. These systems should be highly reliable and capable of achieving and maintaining cold shutdown conditions with no single failure that would result in inability to terminate use of the passive safety-related systems and achieve cold shutdown.

## Response:

ESBWR Cooling Water System Audit conducted March 19 and 20, 2009 and response to RAI 9.2-24 submitted.

## Conclusion:

ESBWR cooling water systems conform to NRC policies that have been established with respect to the applicable RTNSS functions.



**HITACHI**

# ESBWR Cooling Water System Design

- PSWS, RCCWS and NICWS High Level Requirements
  - Performs Nonsafety-Related Functions with defense-in-depth requirements

Because these cooling water systems are also significant contributors to plant availability and plant investment protection (PIP), design requirements for defense-in-depth and PIP (seismic ruggedness, redundancy fire and missile, and flood protection) may be more restrictive than the system RTNSS requirements

- RTNSS C function to provide cooling (post 72 hour)

Redundant Trains

Physical and Electrical Separation of Trains


Seismic Requirements –IBC-2003 & Position C.2 of RG 1.29 as required

Ability to Withstand Cat 5 Hurricane Missiles and Flood




**HITACHI**

# DCD Section 9.2 – Water Systems-PSWS




# DCD Section 9.2 – Water Systems-RCCWS




**HITACHI**

# DCD Section 9.2 – Water Systems

## Chilled Water System (CWS)



- NOTES:**
1. Refer to subsection 3.2 for additional information and to Appendix 19A for RTNSS requirements.
  2. A, B, C, D = QUALITY GROUP A, B, C, OR D  
 I, II = SEISMIC CATEGORY I OR II  
 NS = NON-SEISMIC



# ESBWR Cooling Water System Design- PSWS

- Single train failure during cooldown results in the greatest heat load per PSWS train at 80.8 MW
- Significant margins and conservative assumptions are applied to the heat loads for the PSWS

While the PSWS is designed for 1% exceedance conditions, the system is capable of operating under 0% exceedance

- Significant margins and conservative assumptions are applied to the design of the heat removal facility (conceptual design information) for the PSWS

Margin applied to the design heat load for the mechanical draft cooling towers reflects the difference between the maximum PSWS train design heat load (Single Train Failure Cooldown) listed in DCD Table 9.2-1 and PSWS Cooling Towers and Basins heat load listed in DCD Table 9.2-2 (3.3% margin)



# ESBWR Cooling Water System Design- RCCWS

- Loss of Preferred Power Cooldown with Single Train Failure is the most limiting system heat removal design condition for the RCCWS

This mode of operation provides sufficient cooling capacity to bring the plant to cold shutdown condition within 36 hours

- The most limiting condition for RCCWS heat exchanger design is a Single Train Failure Cooldown without a LOPP; which has a design heat load of 59.8 MW divided between two heat exchangers
- Significant margins and conservative assumptions are applied to the heat loads for the RCCWS

While the RCCWS is designed for 1% exceedance conditions, the system is capable of operating under 0 % exceedance

- Significant margins are applied to the RCCWS during the design process to account for uncertainties, component wear and aging effects and fouling of heat transfer surfaces

RCCWS design temperatures and pressures include a margin of 10°F added to the operating temperature and a margin of 25 psig added to the operating pressure



# ESBWR Cooling Water System Design- NICWS

- There is no specific NICWS alignment specified for the 24 hour or 36 hour cool down conditions
- The CWS chiller heat load is 4850 Kw with a total system heat load of 19,110 kW [ref DCD Table 9.2-11]
- NICWS and BOPCWS Chillers will be sized for a heat load of 4,638 kW (1,319 tons) per chiller with a 1380 ton chiller size assumed
- The NICWS consists of two trains with two 50% chillers in each train resulting in a total NICWS heat load of 9.3MW
- Significant margins will be applied to the NICWS during the design process to account for uncertainties

A corrosion margin is applied to NICWS piping to account for aging and degradation

All building HVAC systems include a 15% margin for projected heating/cooling load and 15% margin for airflow (Ref URD Chapt 9 Sect 8.2.1.1.12)




**HITACHI**

# Instrument Air / Service Air System Overview

- Compressed air operated components having safety-related or RTNNS required functions, either have safety-related accumulators or are fail-safe and do not rely on any of the compressed air systems to perform these functions [ DCD S9.3.1]
- IAS Air Quality Concerns [RAI 9.3-41 and RAI 10.2-18S03]  
SS piping and components, oil free, 3 micron particulate, -40 F dewpoint
- Upon failure of IAS dryer, other dryer can accommodate 100% IAS demand
- Separate from the integrated system Instrument and Service Air  
Preoperational tests, individual components will be tested for proper “failure” (open, close, or as is) to both instantaneous (pipe break) and slow (plugging or freezing) simulated air losses [DCD S14.2.8.1.19]



# Section 9.3 – Process Auxiliaries- Air Systems



# Summary

- Provided revised decay heat calculation and associated analysis using bounding bounding total decay power curve to show water remains over active fuel and all thermal requirements are met
- Illustrated how OE experience applied to ESBWR design for spent fuel uncover and gas accumulation in FAPCS
- Described Aux System RTNSS functions and robustness of system design
- Described PSWS design overview
- Described RCCWS design overview
- Described NICWS design overview
- Described Instrument Air / Service Air System Overview



# End of Basic Presentation



**HITACHI**

# BACKUP SLIDES



**HITACHI**

# ESBWR Spent Fuel Pool Decay Heat

- ANSI/ANS-5.1-1994 with  $2\sigma$  uncertainty (7.4% at 5 days)
- GEH Decay heat also considers:
  - Actinides (in addition to those in ANS 5.1)
  - Activation products in structural materials
  - Fission power from delayed neutron-induced fission
- Fuel data is generated with lattice physics code TGBLA
- An Equilibrium cycle is assumed (no credit for initial fuel only operated 1 cycle)

NRC conducted an audit of the containment analysis in December 2006, reviewed the NRC procedure and issued RAI's 6.3-61, 6.3-62, 6.3-62 S01 related to GEH decay heat calculations (the same method is used in the containment and spent fuel pool decay heat calculations.) GEH responded with information which closed the NRC concern.



**HITACHI**

# ESBWR Spent Fuel Pool Decay Heat

	Core	Batch N-1	Batch N-2	Batch N-3	Batch N-4	Batch N-5	Total Old Batches	Total SFP
Decay time (y)	0	2	4	6	8	10		
No. of bundles	1132	476	476	476	476	476	2380	3512
Decay heat* (MW) – EOC case	16.79 (0.373% rated)	0.52	0.27	0.18	0.15	0.14	1.27	18.06**
Decay heat* (MW) – 36-day irradiation	13.90 (0.309% rated)	2.31	0.49	0.26	0.17	0.15	3.39	17.29

\*5 days post shutdown

\*\* 18.42 MWt at 102% rated

EOC case is bounding as most heat load comes from the core and core decay heat increases with exposure and irradiation time

Slight difference (~1%) in core decay heat, 0.373% vs. 0.378% from core decay heat calculation for containment analysis due to

- Multi-batch vs. single batch model
- More conservative inputs in exposure and irradiation time for ANS 5.1 calculation for core decay heat




**HITACHI**

# Fuel Decay Heat Input

Decay Heat Contributor	Decay Power at 5 days after shutdown (MW)	
End Of Cycle Full Core Offload	16.79	
Five Refuel Batches (0 to 10 years)	1.27	
Margin	0.94	
Total	19	Used for Fuel Building Spent Fuel Storage Rack Design (Full core offload + 10 years prior offload batches)
Five Refuel Batches (10 to 20 years)	0.68	
102% Power Adjustment	0.39	
Total	20.1	Used for Fuel Pool Boil-off Calculation (Full core offload + 20 years prior offload batches)

# Spent Fuel Pool Thermal Hydraulic Streamlines

- In LTR NEDO 33373 rev 4, the streamline figures shown have the rack domains in the rack disabled so that the streamlines can not be seen inside the racks
- The figure below shows flow from inlet #1, and the associated flow through the domain of only one of the spent fuel storage racks (#5)
- This clearly shows the expected flow path through a rack and the associated temperatures
- This figure has been added to rev 5 of the LTR



HITACHI

# Plant Service Water Basin Sizing Considerations

- PSWS Interface Requirements [Tier 1 S4.1]

The volume of water shall be sufficient such that no active makeup shall be necessary to remove  $2.02 \times 10^7$  MJ ( $1.92 \times 10^{10}$  BTU) over a period of seven days. Additionally, the PSWS pumps must have sufficient available net positive suction head at the pump suction location for the lowest probable water level of the heat sink [ref DCD Tier 1 S4.1]

- PSWS basin sizing to meet PRA (Single Active Failure w/LOPP for 7 days) with decay heat removal by ICS (1st 34 hours) then using containment forced cooling and spent fuel pool cooling requiring PSWS operation (for 7 days) [Total 2.3 M gallons]
- PSWS heat loads considered include combined core and spent fuel decay heat loads and heat load due to Diesel Generators and NI Chillers
- TCCW loads auto sequence on SDG at LOOP but loads are within the margin of the analysis




# Hydrogen Water Chemistry- Optional ESBWR System

- ESBWR has a reduced risk of cracking through the numerous mitigating actions taken or under consideration (e.g., post-weld anneal of higher risk components)
- Therefore, if a utility prefers to begin its operating life without the addition of hydrogen/ NobleChem™, the consequences for the foreseeable future are likely small
- Nonetheless, GE recommends the application of HWC at startup
- ESBWR, as presently configured, reflects a lower risk than previous US-based designs with the risk of SCC in the ESBWR similar to the ABWR because it uses similar material and process selections (ten years of ABWR operation results in no evidence of stress corrosion cracking, although inspections have been limited)
- ESBWR will include provisions to easily accommodate hydrogen, zinc, and online NobleChem applications (as well as for oxygen)
- The customer may choose not to implement at startup, but these options can be easily implemented at any time.




# Fire Protection System




**HITACHI**

# FAPCS Schematic



**HITACHI**

# FAPCS – IC/PCCS Subsystem




Clean & Contaminated Water Kept Separate



HITACHI


# FAPCS – Fuel Pool Cooling Mode



HITACHI

# FAPCS – LPCI Mode

Non-  
safety  
related  
LPCI  
mode



HITACHI



# **Presentation to the ACRS Subcommittee**

ESBWR Design Certification Review  
Section 3.12 – Piping Design  
Kaihwa Hsu - NRO/DE/EMB1

September 23, 2010

# ACRS Subcommittee Presentation ESBWR Design Certification Review

## RAI 3.12-3

- Independent Support Motion (ISM) Response Spectrum Method.
- SRP 3.12 recommends the acceptance criteria that is listed in NUREG-1061, Vol. 4.
- GEH's final position meets the acceptance criteria. OI was resolved.

# ACRS Subcommittee Presentation ESBWR Design Certification Review

## RAI 3.12-17

- SRSS method used in the load combination of dynamic loadings.
- Acceptance Criteria listed in NUREG-0484, Rev.1 for using SRSS combination method.
- GEH provided justification that meets the provision of NUREG-0484, Rev.1. OI was resolved.

# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### RAI 3.12-27

- Load Combination of Seismic Anchor Movement (SAM) and Seismic Inertia response.
- GEH revised DCD to state that the ABS method is used to combine the inertia and SAM results for both piping and piping support design in USM piping analysis.
- This position meets the recommendation in SPR 3.9.2. OI is resolved.

# ACRS Subcommittee Presentation ESBWR Design Certification Review

## RAI 3.9-254/255

- piping analysis PISYS08 Computer Code.
- PISYS08 post-processor and environmental assisted fatigue evaluation ANSI714 Computer Code
- Software design documents and QA status for PISYS08/ANSI714 Computer Code were not completed.
- The staff identified that inconsistency of PISYS08 and DCD description for the piping analysis method related to RG 1.92.

# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### RAI 3.9-254/255 (Continued)

- During audit ANSI714 V&V package, the staff noted that the temperature used in the calculation for fatigue environmental factor (Fen) is not consistent with the procedure in NUREG/CR-6909.
- GEH revised PISYS08 test report, DCD and completed software design documents to address staff's concern. The issue was closed.
- GEH revised the ANSI714 computer code and completed software design documents to address staff's concern. This issue was closed.



# **Presentation to the ACRS Subcommittee**

ESBWR Design Certification Review

Section 3.9

Yuken Wong – NRO/DE/EMB2

Tuan Le – NRO/DE/EMB1

September 23, 2010

# ACRS Subcommittee Presentation ESBWR Design Certification Review

## Section 3.9.2.4 – Preoperational Flow-Induced Vibration Testing

### Regulations and Regulatory Guidance

- GDC 1 and 4
- Regulatory Guide 1.20, Rev. 3
- SRP Sections 3.9.2 and 3.9.5

# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Section 3.9.2.4 – Preoperational Flow-Induced Vibration Testing (cont'd)

#### RAI 3.9-75

- Clarify the use of both terms “prototype” and “non-prototype” for reactor internals components
- GEH clarified that “prototype” applies to chimney and standby liquid control structures. The ESBWR reactor internals as a whole is classified as non-prototype Category II
- This resolves RAI 3.9-75

#### Classification of Reactor Internals

- The staff questioned the classification of the ESBWR reactor internals as non-prototype Category II considering the major differences between the ESBWR and ABWR reactor internals
- GEH reclassified ESBWR reactor internals as prototype
- This resolves the issue

# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Section 3.9.2.4 – Preoperational Flow-Induced Vibration Testing (cont'd)

#### RAI 3.9-96

- Explain the basis for selecting the reactor internals components for testing for the first ESBWR plant
- GEH provided an item by item discussion of why each component was selected for further analysis and testing or why it was considered adequate without further detailed analysis or testing
- This resolves RAI 3.9-96

# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Chapter 3.9.2.5 – Dynamic System Analysis of Reactor Internals under Faulted Conditions

#### Regulations and Regulatory Guidance

- GDC 2 and 4, and 10 CFR Part 50, Appendix S
- SRP Sections 3.9.2 and 3.9.5
- ASME Code Section III, Subsection NG

#### RAI 3.9-81

- Demonstrate that there is no significant dynamic amplification of the loads on the reactor internals as a result of the postulated break in the MSL and FW line
- GEH stated that a comparison is made of the periods of the loads and the natural period of the core support structures, and determined that there is no significant dynamic amplification of the blowdown loads
- This resolves RAI 3.9-81

**ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Section 3.9.3 – ASME Code Class 1, 2, and 3 Components and  
Component Supports, and Core Support Structures**

RAI 3.9-177:


- Staff requested that the applicant reinstate the COL information item regarding the availability of design reports and design specification originally listed in DCD Section 3.9.9.4 (Revision 3), in DCD Section 3.9.9 or address the information item through an ITAAC.

In response to this RAI, the applicant committed to:

- ITAAC for review of Design Reports
- Completion of Design Specifications for risk significant components prior to Certification.

# ACRS Subcommittee Presentation ESBWR Design Certification Review


## Section 3.9.2 – Backup Slide – ABWR Reactor Internals



- 1 - Vessel flange and closure head
- 2 - Vent and head spray assembly
- 3 - Steam outlet flow restrictor
- 4 - RPV stabilizer
- 5 - Feedwater nozzle
- 6 - Forged shell rings
- 7 - Vessel support skirt
- 8 - Vessel bottom head
- 9 - RIP penetrations
- 10 - Thermal insulation
- 11 - Core shroud
- 12 - Core plate
- 13 - Top guide
- 14 - Fuel supports
- 15 - Control rod drive housings
- 16 - Control rod guide tubes
- 17 - In-core housing
- 18 - In-core guide tubes and stabilizers
- 19 - Feedwater sparger
- 20 - High pressure core flooder (HPCF) sparger
- 21 - HPCF coupling
- 22 - Low pressure flooder (LPFL)
- 23 - Shutdown cooling outlet
- 24 - Shroud head and steam separator assembly
- 25 - Steam dryer assembly
- 26 - Reactor internal pumps (RIP)
- 27 - RIP motor casing
- 28 - Core and RIP differential pressure line
- 29 - Fine motion control rod drives
- 30 - Fuel assemblies
- 31 - Control rods
- 32 - Local power range monitor

# ACRS Subcommittee Presentation ESBWR Design Certification Review



## Section 3.9.2 – Backup Slide – ESBWR Reactor Internals



# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Section 3.9.2 – Backup Slide – ABWR vs. ESBWR



# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Section 3.9.2 – Backup Slide – ABWR vs. ESBWR

Description	ABWR	ESBWR	Difference
Power (MWt)	3926	4500	14.6%
Main steam flow (ton/hr)	7640	8757	14.6%
Core coolant flow rate (Mlb <sub>m</sub> /hr)	115.1	76.0	-34.0%
Feedwater flow rate (Mlbm/hr)	16.8	19.3	14.6%
Vessel height (m)	21.1	27.6	30.9%
Fuel Bundles	872	1132	29.8%
Core diameter (m)	5.2	5.9	13.9%
Fuel assembly length (in)	176	149	-15.3%
Main steam pipe diameter (in)	28	30	7.1%
Chimney	No	Yes	N/A
Standby liquid control lines	No	Yes	N/A
High pressure core flooder coupling/spargers	Yes	No	N/A



## **Presentation to the ACRS Subcommittee**

ESBWR Design Certification Review  
Chapter 3.8 – Seismic Category I Structures  
Samir Chakrabarti – NRO/DE/SEB2

September 23, 2010



# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Section 3.8 – Seismic Category I Structures

#### Regulations, Regulatory Guidance, and Key Industry Codes & Standards

- Appendix A to 10 CFR Part 50, GDC 1, 2, 4, 5, 16, and 50
- Appendix B to 10 CFR Part 50, “Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants”
- SRP 3.8.1, 3.8.2, 3.8.3, 3.8.4, and 3.8.5
- Regulatory Guides 1.94, 1.57, 1.136, 1.142, 1.143, 1.199
- ASME Section III, Division 2, Subsection CC, “Code for Concrete Reactor Vessels and Containments”
- ASME Section III, Division 1, Subsection NE, “Class MC Components”
- ACI 349, “Code Requirements for Nuclear Safety-Related Concrete Structures”
- ANSI/AISC N690, “Specification for Safety-Related Steel Structures for Nuclear Facilities”



# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Section 3.8 – Seismic Category I Structures

#### Review Highlights

- Staff performed five design audits to review design reports, review calculations, and discuss open issues
- Staff performed confirmatory analysis of nuclear island foundation base mat
- Majority of the review questions required additional technical information which resulted in significant enhancement of the DCD content

#### Review Status

- All issues identified during review have been resolved
- Resolution of PCCS Hydrogen Detonation Issue Included in Section 6.2.2



# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Section 3.8 – Seismic Category I Structures

#### Closure of Open Items Discussed in Last ACRS Meeting

##### **RAI 3.8-107**

In view of significant nonlinear behavior of containment structure due to thermal loading, the staff questioned the appropriateness of combining results from thermal analysis with the elastically calculated results for other loads by linear superposition.

- **Resolution:** GEH performed an additional study
  - Study used detailed 3D ABAQUS/ANACAP FEM
  - Two cases analyzed:
    - (1) A linear analysis for pressure combined with nonlinear cracking analysis for thermal (ESBWR design approach)
    - (2) A nonlinear analysis for both pressure and temperature with concrete cracking
  - Results: Comparisons of stresses show that the ESBWR design approach is generally conservative. Where not, the resulting stresses/strains are still less than Code limits
- **Disposition:** RAI resolved.



# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Section 3.8 – Seismic Category I Structures

#### Closure of Open Items Discussed in Last ACRS Meeting

##### **RAI 3.8-79**

The staff requested GEH to demonstrate that there would be no unacceptable seismic interaction between seismic category (SC) I structures and adjacent non-safety-related structures, e.g., Turbine Building, Service Building, and Radwaste Building.

- **Resolution:** GEH revised their seismic criteria for non-safety-related structures
  - Seismic criteria for analysis and design included in updated DCD
  - Method of analysis is the same as a SC I structure
  - Will utilize stick model or FEM using procedures described in DCD 3.7.2.3
  - Soil structure interaction (SSI) analysis will be performed using soil spring/dashpot approach or FEM approach in accordance with DCD App. 3A
  - Seismic gap criteria between adjacent structures are to show gaps are greater than calculated maximum relative displacements considering out-of-phase motion
  - ITAAC were revised to state that analysis and design of SC II structures are the same as for SC I structures, including load combinations and acceptance criteria
- **Disposition:** RAI resolved.



# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Section 3.8 – Seismic Category I Structures

#### Closure of Open Items Discussed in Last ACRS Meeting

#### **RAI 3.8-94**

The staff requested GEH to explain why the extremely large bearing capacities reported in the DCD are considered reasonable values which can be met at potential plant sites.

- **Resolution:**
  - Earlier analysis was based on a conservative method which did not account for embedment, and considered vertical load in each of the three seismic directions (i.e., N-S+V, E-W+V, and V)
  - GEH revised the analysis approach for calculating maximum soil-bearing pressures using more realistic SASSI (computer code) SSI forces as input into the “Modified Energy Balance” (MEB) method that includes effects of uplift.
  - As a check, GEH demonstrated that the MEB calculated soil pressures are higher than the maximum SASSI calculated soil pressure results.
- **Disposition:** RAI resolved.



# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Section 3.8 – Seismic Category I Structures

#### Closure of Open Items Discussed in Last ACRS Meeting

#### **RAI 3.8-96**

The staff requested GEH to explain some of the assumptions made in the evaluation for sliding stability of plant structures to satisfy the factors of safety in SRP 3.8.5

#### **Key Technical Issues**

- Use of static coefficient of friction beneath the foundation along with full passive pressure at the side of the foundation to resist sliding; static versus dynamic coefficient of friction
- Use of cohesion resistance at bottom of basemat
- Need to consider other potential sliding interfaces in addition to soil shear failure (i.e., basemat to concrete mud mat, concrete to soil)
- Foundation walls not designed for full passive soil pressure
- Use of 100-40-40 seismic combination method for a two dimensional stability evaluation



# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Section 3.8 – Seismic Category I Structures

#### Closure of Open Items Discussed in Last ACRS Meeting

##### **RAI 3.8-96 Technical Resolution**

GEH revised their approach for evaluating sliding stability

- Full passive pressure and cohesion of soil no longer relied upon for sliding resistance
- Shear keys added beneath foundations to increase sliding resisting areas
- Require roughening of mud mat top surface
- Use of reduced coefficient of friction for concrete to soil interface
- Sliding resistance relied upon static friction at the bottom of basemat, lateral soil pressures on embedded walls and shear keys (perpendicular to the direction of motion), and friction at basemat and shear key vertical edges (parallel to the direction of motion)
- Design of foundation walls adequate for lateral soil resisting pressures used for sliding stability evaluation
- Factor of safety calculated as a function of time throughout the SSE time history, considering the phasing between the vertical and horizontal seismic force components - shown to meet SRP 3.8.5 criteria

**Disposition:** RAI resolved.



# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Section 3.8 – Seismic Category I Structures

#### Closure of Open Items Discussed in Last ACRS Meeting

#### **RAI 3.8-120**

GEH proposed to use ASTM A-709 HPS 70W material for containment liner as an alternate to ASME SA-516, Gr.-70, which was not yet approved by ASME or endorsed by NRC. Additionally, the staff requested GEH to explain how the change to this material affects the analysis and design of the containment.

- **Resolution:** ASME approval of ASTM A-709 HPS 70W material was subsequently given in ASME Code Case N-763. The staff has accepted this code case for use in the ESBWR (SER Section 6.1.1.3.1, RAI 6.1-12). GEH also explained that use of this new higher strength material has no significant effect on the analysis and design of the containment.
- **Disposition:** RAI resolved.



# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Section 3.8 – Seismic Category I Structures

#### Closure of Issue Subsequent to Last ACRS Meeting

#### **RAI 3.8-125**

During the staff's review of DCD Section 3.8, the design of the spent fuel racks was revised such that they are no longer anchored to the pool floor. The racks are evaluated as free-standing racks on the pool floor and thus can slide and tip. GEH was requested to demonstrate adequacy of the spent fuel pool (SFP) structure (walls, floor, and liner plate) to resist structural loads imposed by free-standing fuel storage racks (FSRs).

- **Resolution:** Analysis performed by GEH demonstrates that FSRs do not impact pool walls under SSE loads. The mass of the FSRs was included in the Fuel Building seismic analysis. Spent fuel pool concrete floor is 5.5 m thick and is adequate to withstand FSR loads. To transfer impact loads at the locations of the FSR legs, the design provides bearing pads that rest on embedded plates in the SFP basemat. Sliding of FSR legs are within boundary of bearing pad dimensions and the edges of the embedment plates.
- **Disposition:** RAI resolved.



Presentation to the ACRS Subcommittee

**ESBWR Design Certification Review**

**Section 9.4, “Heating, Ventilation, and Air Conditioning,”  
and  
Section 6.4, “Control Room Habitability System”**

**September 24, 2010**

# Purpose

- **Brief the Subcommittee on the staff's review of the ESBWR design certification application, Chapter 9.4, "Heating, Ventilation, and Air Conditioning," and Section 6.4, "Control Room Habitability System"; ventilation issues**
  - Address follow up items from the previous briefing on this issue held on May 19, 2010.
  - Address related follow up items from briefings held on August 17, 2010
- **Answer the Subcommittee's questions**

# Project and Technical Review Team

- **Project Managers**
  - Dennis Galvin, Project Manager (9.4)
  - Bruce Bavol, Project Manager (6.4)
- **Technical Reviewers**
  - Jim O’Driscoll (6.4, 9.4.1 - 9.4.8) – Lead
  - Ed Forrest
  - Syed Haider
  - Shie-Jeng Peng
  - Brad Harvey (2.3)
  - Craig Harbuck (16)

# Staff Follow-Up Items

- **Provide and discuss heat up profiles for three models; CONTAIN 2.0, GOTHIC, and NRC First Principles Model (FPM)**
- **Discuss details of the Tech Spec Surveillance on Control Room Habitability Area (CRHA) heat sink temperatures**
- **Discuss details of verification of related site characteristics**
- **Discuss how assumptions used in the Reactor Building heat up calculation are assured**


# Confirmatory Analyses

- **Staff review focus:**
  - **Suitability of applicant's approach using CONTAIN**
  - **Understanding of sensitivities**
    - **Heat sink properties**
    - **Heat sink initial temperature**
    - **Outside environmental conditions**
- **Summary of work performed:**
  - **Review of Applicants CONTAIN analysis**
  - **1 Run using updated GOTHIC model.**
  - **Review of GEH FPM / Development of Staff FPM**
  - **Over 24 sensitivity runs performed using CONTAIN and NRC FPM of GEH ESBWR CRHA.**

# Confirmatory Analyses

- **Summary of findings:**
  - Heat up rates of all models agree.
  - **CONTAIN and FPM behave similarly in sensitivity studies.**
  - **FPM sensitivity result are 2 to 4 °F higher than CONTAIN due to:**
    - **More heat is assumed to enter CRHA from adjacent rooms in FPM**
    - **Steel structures not modeled in FPM**
    - **Higher initial temperature of FPM heat sinks**
    - **½ Mass of concrete touching soil modeled in FPM**
  - **Staff conclusion is that there is no benefit to reconcile models further. Studies support use of CONTAIN. Applicants initial conditions are appropriately conservative. Difference in models results are small.**

# NRC Staff Confirmatory Analysis of ESBWR CRHA



# Details of CRHA Heat sink TS Surveillance

- **LCO 3.7.2 requires maintaining heat sink temperature “within established design limit” (SR 3.7.2.1) (CRHA thermal analysis)**
  - **$\leq 74$  °F for CRHA**
  - **$\leq 78$  °F for Q-DCIS & N-DCIS equipment rooms**
  - **$\leq 104$  °F for HVAC equipment rooms and safety portions of Control Room Habitability Area Ventilation System (CRAVS)**
- **CRHA boundary passive heat sinks limit the CRHA temperature to the acceptance criterion of 33.9°C (93°F) for 72 hours post-DBA with no internal forced air recirculation or cooling.**

# Technical Specification 3.7.2 “CRHAVS”

- **LCO 3.7.2 ensures that CRHA**
  - Average air temperatures will be maintained within acceptable limits for 72 hours following an event that includes loss of CRHAVS cooling, and
  - Heat sink bulk average temperatures are within design-basis analysis assumptions.
- **LCO 3.7.2 bases state that the CRHA heat sinks are operable when the air and heat sinks in the CRHA and adjacent spaces are maintained within the average temperature limits of SR 3.7.2.1.**
- **LCO 3.7.2 Required Action A.2 requires restoring the bulk average temperature of each CRHA heat sink to within limits within 24 hours.**
  - The 24-hour Completion Time is based on engineering judgment. Staff considers that 24 hours is reasonable and consistent with staff analysis.
  - Restoration of CRHA heat sink bulk average temperatures to within limits may be verified by
    - administrative evaluation considering the duration and extent of the CRHA average air temperature excursion outside limits, and/or
    - direct temperature measurement of CRHA heat sink structural materials.
  - Determination of CRHA heat sink bulk average temperatures is the subject of licensee procedures.

# Ambient Design Temperature Site Parameters

2% Annual Exceedance	Max	DB	96 °F
		MCWB	79 °F
		WB	81 °F
	Min	DB	-10 °F
1% Annual Exceedance	Max	DB	100 °F
		MCWB	79 °F
		WB	82 °F
	Min	DB	-10 °F
<b>0% Exceedance</b>	<b>Max</b>	<b>DB</b>	<b>117 °F</b>
		MCWB	80 °F
		<b>WB</b>	<b>88 °F</b>
	<b>Min</b>	<b>DB</b>	<b>-40 °F</b>
<b>Max Avg DB for 0% Exceedance Max Temp Day</b>			<b>103.5 °F</b>
<b>Min Avg DB for 0% Exceedance Min Temp Day</b>			<b>-26.5 °F</b>
<b>Max HH Avg WBGT Index for 0% Exceedance Max WB Day</b>			<b>86.6 °F</b>

# Maximum Average Dry Bulb Temperature for 0% Exceedance Maximum Temperature Day

Site Parameter Value: 103.5 °F

- Defined as the average of:
  - 0% exceedance maximum dry bulb site parameter value of 117 °F
  - Dry bulb temperature resulting from a daily temperature range of 27 °F


Determining the Corresponding Site Characteristic Value:

- Defined as the average of:
  - Site-specific 0% exceedance maximum dry bulb
  - Dry bulb temperature that corresponds to the higher of the two lows occurring within 24 hours before and after the 0% exceedance maximum dry bulb

# Verification of Related Site Characteristics

## Example Calculation #1

- **Maximum Average Dry Bulb Temperature for 0% Exceedance**  
**Maximum Temperature Day: 93.5 °F**



# Minimum Average Dry Bulb Temperature for 0% Exceedance Minimum Temperature Day

Site Parameter Value: -26.5 °F

- Defined as the average of:
  - 0% exceedance minimum dry bulb site parameter value of -40 °F
  - Dry bulb temperature resulting from a daily temperature range of 27 °F


Determining the Corresponding Site Characteristic Value:

- Defined as the average of:
  - Site-specific 0% exceedance minimum dry bulb
  - Dry bulb temperature that corresponds to the lower of the two highs occurring within 24 hours before and after the 0% exceedance minimum dry bulb

# Verification of Related Site Characteristics

## Example Calculation #2

- **Minimum Average Dry Bulb Temperature for 0% Exceedance**  
**Minimum Temperature Day: -8.5 °F**



# Maximum High Humidity Average Wet Bulb Globe Temperature Index for 0% Exceedance Maximum Wet Bulb Temperature Day

**WBGT Index =  $0.7 \times \text{WB} + 0.3 \times \text{DB}$**

**Site Parameter Value: 86.6 °F**

- **Defined as the average of:**
  - **WBGT index for the 0% exceedance wet bulb site parameter value of 88 °F (and a concurrent dry bulb value of 92 °F)**
  - **WBGT index resulting from a high humidity diurnal dry bulb temperature swing of 8 °F (dry bulb temperature of 84 °F and concurrent wet bulb temperature of 84 °F)**


**Determining the Corresponding Site Characteristic Value:**

- **Defined as the average of:**
  - **WBGT index for the site-specific 0% exceedance wet bulb**
  - **WBGT index resulting from wet bulb temperature that corresponds to the highest of the six low wet bulb temperatures occurring in each of the three 24-hour periods before and after the 0% exceedance wet bulb**

# Verification of Related Site Characteristics

## Example Calculation #3 (sheet 1 of 3)


- Maximum High Humidity Average WBGT Index for 0% Exceedance Maximum Wet Bulb Temperature Day: 71.4 °F



# Verification of Related Site Characteristics

## Example Calculation #3 (sheet 2 of 3)


- Maximum High Humidity Average WBGT Index for 0% Exceedance Maximum Wet Bulb Temperature Day: 71.4 °F



# Verification of Related Site Characteristics

## Example Calculation #3 (sheet 3 of 3)


- Maximum High Humidity Average WBGT Index for 0% Exceedance Maximum Wet Bulb Temperature Day: 71.4 °F



# Verification of Related Site Characteristics

## Example Calculation #4 (Sheet 1 of 3)


- Maximum High Humidity Average WBGT Index for 0% Exceedance Maximum Wet Bulb Temperature Day: 82.2 °F



# Verification of Related Site Characteristics

## Example Calculation #4 (sheet 2 of 3)


- Maximum High Humidity Average WBGT Index for 0% Exceedance Maximum Wet Bulb Temperature Day: 82.2 °F**



# Verification of Related Site Characteristics

## Example Calculation #4 (sheet 3 of 3)

- **Maximum High Humidity Average WBGT Index for 0% Exceedance Maximum Wet Bulb Temperature Day: 82.2 °F**



# Assurance of RB Heat Up Analysis Assumptions

- **Staff reviewed the need for a reactor building heat sink temperature LCO similar to control building heat sink temperature LCO 3.7.2, “CRHAVS”**
  - CRHAVS meets LCO criterion 3; its passive cooling function depends on heat sink initial temperatures and is part of primary success path for DBA mitigation by supporting CR habitability required by GDC 19
- **1988 letter from NRR to Owners Groups (OGs) (“Split Report”) - Staff’s review of the BWROG’s LTR regarding the application of the LCO criteria of the 1987 Commission Interim Policy Statement on TS improvements to the**
  - BWR4 custom TS (Hatch 1) and standard TS (Hatch 2), and
  - BWR6 standard TS (Grand Gulf 1)
- **Staff agreed with relocation of LCOs for**
  - ECCS and RCIC pump room air coolers from pilot plant custom TS (Hatch 1)
  - Area temperature monitors from pilot plant standard TS (Grand Gulf 1).
- **Purpose of these LCOs was to maintain equipment qualification (§50.49)**
  - LCOs should not duplicate regulations;
  - Improved STS do not include LCOs on **monitoring instrumentation** except for post-accident monitoring; **area temperature monitors are not in primary success path for accident mitigation and are not used to detect degradation of reactor coolant pressure boundary; equipment room temperatures are not initial conditions for any DBA**
- **OPERABILITY definition → necessary support system functions**
  - RIS 2005-20, Rev. 1; operability assessment of degraded or nonconforming equipment
  - EQ is one factor in determining equipment operability
- **Conclusion: §50.36 requires no LCO for reactor building heat sink temperatures**



Presentation to the ACRS Subcommittee

# **Staff's Review of Spent Fuel Storage and Fuel and Auxiliary Pools Cooling System (FAPCS)- Sections 9.1.2 and 9.1.3**

Presented by

Larry Wheeler & Raul Hernandez- NRO/DSRA/SPB

September 23, 2010

# Regulatory Guidance

- Standard Review Plan (SRP) 9.1.2 (New and Spent Fuel Storage)
- SRP 9.1.3 (Spent Fuel Pool Cooling and Cleanup System)

# RTNSS Guidance

- Regulatory Treatment of Nonsafety Systems (RTNSS)
  - SECY 94-084 and SECY 95-132
    - Highly reliable
    - Enhanced design quality & reliability

# Staff Review Summary

- **Key open item - Reactor Building Buffer Pool and Spent Fuel Pool (SFP) decay heat and pool drain-down (follow-up to RAIs). The staff previously found the following acceptable.**
  - No potential drain paths that can drain the buffer pool or SFP volume
    - SFP transfer gates and buffer gates are safety related, seismic category I
    - Anti-siphon holes on submerged piping are no lower than 9.2 m (30.2') above the top of stored fuel assembly (TSFA)
  - Maximum bounding SFP heat load
  - Bounding water makeup to the SFP is 200 gallons per minute (GPM) (post 72 hours), calculated is 159 GPM.

# Staff Review Summary

- **Buffer Pool and SFP (continued)**
  - Pool level instrumentation measures collapsed water level (no false reading due to steam vapors above the actual water level)
  - **Buffer pool will maintain 7.3 m (24') above TSFA during a loss of FAPCS for 72 hours**
  - **Stored fuel in the SFP remains covered during a loss of FAPCS for 72 hours**

# Staff Review Summary

- **August 16, 2010 ACRS Subcommittee noted an issue related to NEDO-33373; basis for the heat loads used in the SFP thermal-hydraulic. GEH calculations for decay heat were determined to be non-conservative.**
  - The SFP heat load for the full core offload and discharged fuel decay used 36 days into fuel cycle
  - The updated SFP heat load for the full core offload and discharged fuel decay uses end of fuel cycle and is determined to be more conservative
  - Staff presently performing review of a new Technical Specification SFP water level

# Staff Review Summary

- **The staff found the following acceptable for FAPCS and its RTNSS 'B' function**
  - **Long term core cooling**
    - Fire protection system interface which allows Isolation Condenser/Passive Containment Cooling System (IC/PCCS) pools to be filled with water to extend cooling period from 72 hours to 7 days
    - Piping interface is safety related ASME III Class 3, Seismic Category I
    - Availability Controls (AC 3.7.2/3.7.3)

# Staff Review Summary

- **The staff found the following acceptable for FAPCS and its RTNSS ‘C’ functions**
  - Low pressure cooling injection mode
    - Requires FAPCS pump to take a suction from the suppression pool and pump it into the RPV via Reactor Water Cleanup/Shutdown Cooling (RWCU/SDC) loop A and then Feedwater loop B
    - Availability Controls (AC 3.7.2/3.7.3)
    - Piping is non safety related, Seismic Category II
    - All RTNSS structures, systems and components are within the scope of the ESBWR Design Reliability Assurance Program (D-RAP)

# Staff Review Summary

- **The staff found the following acceptable for FAPCS and its RTNSS 'C' functions (continued)**
  
- **Suppression pool cooling mode**
  - Requires water to be drawn from the suppression pool, cooled by the FAPCS, and returned to the suppression pool
  - Availability Controls (AC 3.7.2/3.7.3)
  - Piping is non safety related, Seismic Category I or II
  - Two physically separated 100 % cooling trains, each with one FAPCS pump and heat exchanger
  - Procedures to assure avoidance of water hammer and gas binding
  - Provision are provided to protect FAPCS components from fire, missile generating events, internal flooding, or seismic event up to and including a safe shutdown earthquake (SSE )for fuel pool cooling function
  - All RTNSS structures, systems and components are within the scope of the ESBWR Design Reliability Assurance Program (D-RAP)

# Staff Review Summary

- **The staff found the following acceptable for FAPCS and its RTNSS 'C' functions (continued)**
  - Standby diesel generators provide backup AC power to FAPCS post 72 hours (AC 3.8.1/3.8.2)

# Staff Review Summary

- **Operating Experiences (OE).** The staff found the following acceptable (RAIs 9.1-128 and 9.1-151).
  - Gas accumulation that could enter a system and result in component or system damage was adequately addressed
  - Refueling cavity bellows seal (RCBS) postulated failures were adequately addressed

# Conclusions

- **Staff's review concludes for FAPCS:**
  - RTNSS 'B' and 'C' functions are highly reliable and meets single failure criteria and are subject to enhanced design, quality, reliability, and availability provisions
  - Staff reviewing the new SFP heat load (**open item**)



ACRS Subcommittee Presentation  
ESBWR Design Certification Review

# Discussion/Committee Questions



Presentation to the ACRS Subcommittee

**Staff's Review of Plant Service Water System (PSWS),  
Reactor Component Cooling Water System (RCCWS),  
and Nuclear Island Chilled Water System (NICWS)  
Sections 9.2.1, 9.2.2 and 9.2.7**

Presented by

Larry Wheeler - NRO/DSRA/SPB

September 23, 2010

# Regulatory Guidance

- SRP 9.2.1 (Station Service Water System)
- SRP 9.2.2 (Reactor Auxiliary Cooling Water System)

# RTNSS Guidance

- Regulatory Treatment of Nonsafety Systems (RTNSS)
  - SECY 94-084 and SECY 95-132
    - Highly reliable
    - Enhanced design quality & reliability

# Staff Review Summary

- **RTNSS ‘C’ Water Systems focus of March 19-20, 2009 audit (RAI 9.2-24). The staff found the following acceptable.**
  - Adequate design margin between the cooling tower capacity and the bounding heat loads (PSWS), between the RCCWS heat exchanger capacity and the maximum heat loads, and between the nuclear island chilled water system (NICWS) chiller capacity and the maximum heat loads
  - Single failure considerations have been properly addressed due to the redundancy of the design, components emergency power supply availability, and components failure position on a loss of preferred power (LOPP)

# Staff Review Summary

- **March 19-20, 2009 audit (RAI 9.2-24) (continues)**
  - PSWS pumps must have sufficient available net positive suction head at the pump suction location for the lowest probable water level of the heat sink
  - RCCWS and NICWS pumps must have sufficient available net positive suction head at the pump suction location for the lowest probable water level of the surge tank

# Staff Review Summary

- **March 19-20, 2009 audit (RAI 9.2-24) (continues)**
  - PSWS, RCCWS, NICWS RTNSS components are in the Maintenance Rule, 10 CFR 50.65, which requires performance monitoring of SSCs
  - PSWS, RCCWS, NICWS RTNSS components have adequate MCR instrumentation for system monitoring
  - During a LOPP, PSWS, RCCW, NICWS pumps and valves and can be powered from the two non safety-related on-site standby diesel generators

# Staff Review Summary

- **March 19-20, 2009 audit (RAI 9.2-24) (continues)**
  - Procedures to assure avoidance of water hammer and gas binding
  - Redundant PSWS, RCCWS, and NICWS trains
  - All RTNSS structures, systems and components are within the scope of the ESBWR Design Reliability Assurance Program (D-RAP)

# Conclusions

- **Staff's review concludes for PSWS, RCCWS, & NICWS:**
  - RTNSS function is highly reliable and meets single failure criteria and which are subject to enhanced design, quality, and reliability.
  - Meets applicable SRP 9.2.1/9.2.2 guidance



United States Nuclear Regulatory Commission

*Protecting People and the Environment*

ACRS Subcommittee Presentation  
ESBWR Design Certification Review

## Discussion/Committee Questions



Presentation to the ACRS Subcommittee

# **Staff's Review of Instrument Air System (IAS)- Section 9.3.6**

Presented by

David Shum- NRO/DSRA/SPB

September 23, 2010

# Instrument Air System

## System Description

- Provides dry, oil free, filtered compressed air to pneumatically operated valve operators, instrumentation, and components in non-safety-related systems located outside containment, and to HPNSS loads inside containment during refueling operations.
- Non-safety-related system, not needed for safe shutdown.
- Not RTNSS.
- Meets the requirement of (ANSI/ISA) 7.0.01, “Quality Standard for Instrument Air.”
- Has no air compressors of its own, receives compressed air from the SAS.
- Has two identical 100% capacity filtration/dryer trains in parallel
- Has a cross-tie between the distribution headers of the SAS and IAS used to bypass the IAS in the unlikely event that both IAS dryer trains failed simultaneously.

## Concern Raised during ACRS 2007 Subcommittee and 2008 Full Committee Meetings

- Based on earlier operating experience gained from operating plants, an issue concerning impacts of moisture and contamination of the instrument air resulting from the bypass of lower quality/contaminated SAS was raised.

# Operating Experience

In July 1981, Generic Issue 43, “Contamination of Instrument Air Lines,” was initiated.

- In December 1987, NUREG-1275, Volume 2, “Operating Experience Feedback Reported - Air Systems Problems,” was published.
- In August 1988, Generic Letter 88-14, “Instrument Air Supply System Problems Affecting Safety-Related Equipment,” was issued to request each licensee/applicant to review NUREG-1275, Volume 2, and to perform a design and operations verification of the IAS to verify that:
  - Actual instrument air quality is consistent with the manufacturer's recommendations for individual components served.
  - Maintenance practices, emergency procedures, and training are adequate to ensure that safety-related equipment will function as intended on loss of instrument air.
  - The design of the entire IAS including air or other pneumatic accumulators is in accordance with its intended function.

# Operating Experience (Continued)

- Also, the staff in Generic Letter 88-14 requested each licensee/applicant to provide a discussion of their program for maintaining proper instrument air quality.
- The staff assessed the effectiveness of Generic Issue 43 and Generic Letter 88-14.
- In October, 2005, the staff published its findings in NUREG-1837, “Regulatory Effectiveness Assessment of Generic Issue 43 and Generic Letter 88-14,” and in general, concluded that licensee and agency activities, such as the Maintenance Rule, Generic Letter 88-14, design-basis reconstitution, and others, have significantly improved air system and component performance and, thereby, resulted in improved reactor safety.
- SRP 9.3.1 endorsed the use of ANSI/ISA-S7.3-R1981 which was superseded by ANSI/ISA 7.0.01-1996 in November, 1996 that establishes the following design guidelines for IAS:
  - System design including components such as filters, compressors, air treatment systems, air receivers, drain traps, aftercoolers and moisture separators, pressure regulators, pressure-relief devices, and valves and piping.
  - Air quality standard including pressure dew point, particle size, lubricant content and contaminants.
  - Air supply pressure.
  - Initial start-up test and periodical tests to verify the system performance and the above cited air quality.

# Staff Review

## Staff's Review of ESWR IAS and SAS

The staff reviewed and verified that the ESBWR IAS and SAS designs meet or exceed the guidelines of ANSI/ISA 7.0.01, specifically:

- Size of air particle from SAS is less than 10 microns.
- Size of air particle in IAS is less than 3 microns.
- Moisture content is continuously monitored.
- The IAS is tested periodically

(ANSI/ISA 7.0.01 defines instrument quality air as having a maximum 40 micron particulate size.)



**U.S.NRC**

United States Nuclear Regulatory Commission

*Protecting People and the Environment*

# Conclusions

Overall, since the air quality of the ESBWR IAS and SAS designs meet or exceed the guidance of ANSI/ISA 7.0.01; the operation of the IAS bypass occurs only in an unlikely event that both IAS dryer trains would fail simultaneously during refueling outage; and staff's favorable findings of Regulatory Effectiveness Assessment of Generic Issue 43 and Generic Letter 88-14, the staff concludes that the above cited issue raised during previous ACRS meetings concerning the impact of moisture and contaminants from the SAS on IAS is resolved.



Presentation to the ACRS Subcommittee

**Staff Presentation of Thermal-Hydraulic  
Analysis for ESBWR Fuel Racks (NEDO-  
33373)**

Presented by

James Gilmer - NRO/DSRA/SRSB

September 23, 2010

# Open Item Description

- The CFD (CFX Code) results for the storage rack temperature presented at the August 16, 2010 meeting do not show flow through the individual racks are cooled.
  - Figure 5-10 from topical report illustrated streamlines from SFP inlets to outlets, but appeared to bypass the heated rack location in the pool.
  - This is a presentation issue related to not selecting the streamlines in the rack zones to make the figure less cluttered.
- Figure 5-10a has been added to Revision 5 of the report showing streamline flow and vertical temperature distribution in an individual rack.

# CFD Model Discussion

- GEH used a porous media model for the spent fuel racks. Fuel bundles are not modeled individually. Heat is added directly to the flow.
- GEH used a conservative pressure drop to determine the loss coefficients used in the porous media formulation. Mass flow through the racks is determined from the balance of the buoyancy driving forces and the pressure drop through the racks.
- The approach used by GEH is reasonable and consistent with common practices for modeling fuel bundle flows under these types of conditions.

# Conclusions

(unchanged from previous presentation)

- Rack design allows adequate natural circulation cooling of spent fuel
- Significant thermal margin will exist between the calculated fuel temperature and the design allowable temperature
- Staff review concludes that the thermal-hydraulic analyses and design of racks meets applicable GDC 61 requirements and SRP 9.1.2 guidance



United States Nuclear Regulatory Commission

*Protecting People and the Environment*

ACRS Subcommittee Presentation  
ESBWR Design Certification Review

## Discussion/Committee Questions



# **Presentation to the ACRS Subcommittee**

## **ESBWR Design Certification Review Chapter 7, “Instrumentation and Controls”**

September 24, 2010



# Chapter 7 Review Team

- Technical Review Staff
  - Ian Jung, Branch Chief, ICE2
  - Hulbert Li
  - Joseph Ashcraft
  - Dinesh Taneja
  - Deanna Zhang
  - Eugene Eagle
  - Sang Rhow
  - Kimberley Corp
- Project Manager
  - Dennis Galvin

# Chapter 7 Overview

The staff is required to evaluate safety of the I&C system design in accordance with the Commission's regulations by following SRP guidance

The staff's safety evaluation is based on the design information provided in the design control document (DCD) and the referenced technical reports. The staff's evaluation is documented in the SER as follows:

## 7.1 Overview of I&C systems, including:

- Conformance to regulations – GDCs, IEEE-603, TMI Action Items
- Software development activities – LTRs NEDE-33226P and NEDE-33245P
- Diversity and defense-in-depth – LTR NEDO-33251
- Setpoint methodology – LTR NEDE-33304P
- Data communication
- Secure development and operational environment (SDOE) – LTR NEDE-33295P

# Chapter 7 Overview (cont.)

- 7.2 Reactor Trip System
- 7.3 Engineered Safety Features Systems
- 7.4 Safe Shutdown Systems
- 7.5 Information System Important to Safety
- 7.6 Interlock Logic
- 7.7 Control Systems
- 7.8 Diverse Instrumentation and Control Systems

# General Finding

- The staff has evaluated safety of the I&C system design and finds the design to be safe and in compliance with applicable regulations
- I&C design follows safe design principles:
  - **Independence**
  - **Determinism**
  - **Redundancy**
  - **Diversity and Defense-in-Depth**
- Safety-related I&C design employs **Simplicity** in many aspects
- I&C systems are designed to conform with the following applicable regulatory requirements:
  - 10 CFR Part 52
  - 10 CFR Part 50, including 50.55a(h) (IEEE Std. 603)
  - 10 CFR Part 50 Appendix A (GDC)
  - 10 CFR Part 50 Appendix B (QA)
  - 10 CFR Part 50.34 (TMI items)

# Independence

- The staff found that the I&C system design provides sufficient independence in compliance with IEEE-603 (10 CFR 50.55a(h)) and GDC 21
  - Safety-related platforms are organized into four physically separated and electrically isolated divisions
  - Communication independence is achieved using following design features:
    - Inter-divisional data communication in safety-related systems is limited to:
      - Voting logic
      - Bypass
      - Data authentication
    - Inter-divisional data communication in RTIF/NMS platform is point-to-point unidirectional via optical fibers. Faulty or loss of data communication is interpreted as a trip signal (fail safe)
    - Inter-divisional data communication in SSLC/ESF platform uses redundant Ethernet networks for 2/4 voting logic. Networks are doubly buffered to prevent data corruption to adversely impact both networks

# Independence (cont.)

- ICP platforms do not use multiplexing for data communication, I/O is hard wired
  - Data communication from safety to non-safety related I&C systems is unidirectional
- Any failure in a division does not prevent other redundant safety divisions from performing their intended safety function
  - Diverse and independent diverse protection system (DPS) is provided as a defense-in-depth feature to cope with an unlikely scenario of a primary system malfunction (CCF or multiple independent failures)

# Determinism

- Determinism means that a required safety function is always accomplished within the required time period specified by Chapter 15 DBA analyses
- Based on the following, the staff found that the real time performance of the safety-related I&C systems is deterministic and conforms to IEEE-603 (10 CFR 50.55a(h)) and BTP HICB-21:
  - Q-DCIS data communication protocols are deterministic
  - RTIF/NMS platform performs a cyclic real-time execution. The operating system is clock-driven and not event-driven, and it does not incorporate “interrupts”
  - SSLC/ESF platform runs cyclic programs that include both the application and diagnostics and do not incorporate “interrupts”
  - ICP platforms do not have an operating system
  - All platforms always react in the same way according to the order of events occurring at the point in time of plant conditions

# Redundancy

- The staff found that the I&C system design provides sufficient redundancy in compliance with IEEE-603 (10 CFR 50.55a(h)) and GDC 21
  - All safety-related platforms are organized into four redundant divisions
    - 4 redundant divisions of RTIF/NMS platforms
    - 4 redundant divisions of SSLC/ESF platforms
    - 4 redundant divisions of ICP platforms
  - Each division has its own set of sensors, and no sharing of sensors between safety divisions is allowed
  - DPS utilizes 2/4 voting logic

## Redundancy (cont.)

- RTIF/NMS platform uses dual redundant communication rings for intra-divisional data communication
- SSLC/ESF platform uses doubly buffered redundant networks for 2/4 voting logic
- Within each SSLC/ESF division, triply modular redundant (TMR) controllers are used for high reliability
- N-DCIS platforms use double or triple redundant controllers for high reliability and availability

# Diversity and Defense-in-Depth

- The staff found that the I&C system design provides sufficient diversity in compliance with 10 CFR 50.62 for ATWS mitigation
- The I&C system design also provides diverse backup for RTIF/NMS and SSLC/ESF to address software CCF concern in accordance with the SRM to SECY-93-87, item II.Q
- LTR NEDO-33251, “ESBWR I&C Diversity and Defense-in-Depth,” provides I&C system architecture and the analysis in conformance with BTP HICB-19 guidance
- DPS design is based on different technology, equipment, design personnel, signals, and functionality
- Diversity is provided both within Q-DCIS (three platforms RTIF/NMS , SSLC/ESF, and ICP are diverse from each other) and externally by a non-safety DPS
- DPS is classified as RTNSS and is developed via a rigorous, highly structured process similar to ones used for safety systems

# Simplicity

- The staff found that the I&C system design employs simplicity in many aspects, which contribute to the staff's safety finding:
  - Each Q-DCIS division is independently monitored and controlled from its dedicated redundant set of safety related VDUs
  - Safety related components cannot be controlled from the non-safety related VDUs
  - Data communication from safety to non-safety related I&C systems is unidirectional
  - I&C system design meets “Independence – Isolation – Separation” requirements
  - Inter and intra-divisional communication is limited
  - ESBWR is a passive plant and the safety-related ESF functions are limited
  - Maintenance tool is not continuously connected

# Logic Diagrams

- DCD contains adequate control logic design information for the staff to make a reasonable safety assurance finding
- Information described in the DCD will be used to develop logic diagrams
- Logic diagrams are produced and used during the I&C development life-cycle process
- Logic diagrams are finalized during the hardware/software design specification phase of the I&C system development lifecycle

# Conclusion

- The staff has evaluated safety of the I&C system design and finds the design to be safe
- I&C systems are in conformance with the applicable regulatory requirements:
  - 10 CFR Part 52
  - 10 CFR Part 50, including 50.55a(h) (IEEE Std. 603 requirements)
  - 10 CFR Part 50 Appendix A (GDC)
  - 10 CFR Part 50 Appendix B (QA)
  - 10 CFR Part 50.34 (TMI items)
- I&C implementation DAC/ITTAC provided in Tier 1 are acceptable
- DCD Revision 8:
  - Provides clarity of I&C design information
  - No impact on I&C design
  - No impact on safety finding

# Chapter 7 ACRONYMS

- ATWS Anticipated Transient Without Scram
- CCF Common Cause Failure
- DBA Design Basis Accident
- DCD Design Control Document
- DPS Diverse Protection System
- ESF Engineered Safety Feature
- GDC General Design Criteria
- ICP Independent Control Platform
- I&C Instrumentation and Control
- I/O Input and Output
- IEEE Institute of Electrical and Electronics Engineers
- LTR Licensing Technical Report
- N-DCIS Non Safety-related Distributed Control and Information System
- NMS Neutron Monitoring System
- QA Quality Assurance
- Q-DCIS Safety-related Distributed Control and Information System

## Chapter 7 ACRONYMS (cont.)

- RG Regulatory Guide
- RTIF Reactor Trip and Isolation Function
- RTNSS Regulatory Treatment of Non-Safety System
- SER Safety Evaluation Report
- SSLC Safety System Logic and Control
- TMR Triply Modular Redundant
- VDU Video Display Unit



# **Presentation to the ACRS Subcommittee**

## **ESBWR Design Certification Review Chapter 7, “Instrumentation and Controls”**

September 24, 2010



# Chapter 7 Review Team

- Technical Review Staff
  - Ian Jung, Branch Chief, ICE2
  - Hulbert Li
  - Joseph Ashcraft
  - Dinesh Taneja
  - Deanna Zhang
  - Eugene Eagle
  - Sang Rhow
  - Kimberley Corp
- Project Manager
  - Dennis Galvin

# Chapter 7 Overview

The staff is required to evaluate safety of the I&C system design in accordance with the Commission's regulations by following SRP guidance

The staff's safety evaluation is based on the design information provided in the design control document (DCD) and the referenced technical reports. The staff's evaluation is documented in the SER as follows:

## 7.1 Overview of I&C systems, including:

- Conformance to regulations – GDCs, IEEE-603, TMI Action Items
- Software development activities – LTRs NEDE-33226P and NEDE-33245P
- Diversity and defense-in-depth – LTR NEDO-33251
- Setpoint methodology – LTR NEDE-33304P
- Data communication
- Secure development and operational environment (SDOE) – LTR NEDE-33295P

# Chapter 7 Overview (cont.)

- 7.2 Reactor Trip System
- 7.3 Engineered Safety Features Systems
- 7.4 Safe Shutdown Systems
- 7.5 Information System Important to Safety
- 7.6 Interlock Logic
- 7.7 Control Systems
- 7.8 Diverse Instrumentation and Control Systems

# General Finding

- The staff has evaluated safety of the I&C system design and finds the design to be safe and in compliance with applicable regulations
- I&C design follows safe design principles:
  - **Independence**
  - **Determinism**
  - **Redundancy**
  - **Diversity and Defense-in-Depth**
- Safety-related I&C design employs **Simplicity** in many aspects
- I&C systems are designed to conform with the following applicable regulatory requirements:
  - 10 CFR Part 52
  - 10 CFR Part 50, including 50.55a(h) (IEEE Std. 603)
  - 10 CFR Part 50 Appendix A (GDC)
  - 10 CFR Part 50 Appendix B (QA)
  - 10 CFR Part 50.34 (TMI items)

# Independence

- The staff found that the I&C system design provides sufficient independence in compliance with IEEE-603 (10 CFR 50.55a(h)) and GDC 21
  - Safety-related platforms are organized into four physically separated and electrically isolated divisions
  - Communication independence is achieved using following design features:
    - Inter-divisional data communication in safety-related systems is limited to:
      - Voting logic
      - Bypass
      - Data authentication
    - Inter-divisional data communication in RTIF/NMS platform is point-to-point unidirectional via optical fibers. Faulty or loss of data communication is interpreted as a trip signal (fail safe)
    - Inter-divisional data communication in SSLC/ESF platform uses redundant Ethernet networks for 2/4 voting logic. Networks are doubly buffered to prevent data corruption to adversely impact both networks

# Independence (cont.)

- ICP platforms do not use multiplexing for data communication, I/O is hard wired
  - Data communication from safety to non-safety related I&C systems is unidirectional
- Any failure in a division does not prevent other redundant safety divisions from performing their intended safety function
  - Diverse and independent diverse protection system (DPS) is provided as a defense-in-depth feature to cope with an unlikely scenario of a primary system malfunction (CCF or multiple independent failures)

# Determinism

- Determinism means that a required safety function is always accomplished within the required time period specified by Chapter 15 DBA analyses
- Based on the following, the staff found that the real time performance of the safety-related I&C systems is deterministic and conforms to IEEE-603 (10 CFR 50.55a(h)) and BTP HICB-21:
  - Q-DCIS data communication protocols are deterministic
  - RTIF/NMS platform performs a cyclic real-time execution. The operating system is clock-driven and not event-driven, and it does not incorporate “interrupts”
  - SSLC/ESF platform runs cyclic programs that include both the application and diagnostics and do not incorporate “interrupts”
  - ICP platforms do not have an operating system
  - All platforms always react in the same way according to the order of events occurring at the point in time of plant conditions

# Redundancy

- The staff found that the I&C system design provides sufficient redundancy in compliance with IEEE-603 (10 CFR 50.55a(h)) and GDC 21
  - All safety-related platforms are organized into four redundant divisions
    - 4 redundant divisions of RTIF/NMS platforms
    - 4 redundant divisions of SSLC/ESF platforms
    - 4 redundant divisions of ICP platforms
  - Each division has its own set of sensors, and no sharing of sensors between safety divisions is allowed
  - DPS utilizes 2/4 voting logic

## Redundancy (cont.)

- RTIF/NMS platform uses dual redundant communication rings for intra-divisional data communication
- SSLC/ESF platform uses doubly buffered redundant networks for 2/4 voting logic
- Within each SSLC/ESF division, triply modular redundant (TMR) controllers are used for high reliability
- N-DCIS platforms use double or triple redundant controllers for high reliability and availability

# Diversity and Defense-in-Depth

- The staff found that the I&C system design provides sufficient diversity in compliance with 10 CFR 50.62 for ATWS mitigation
- The I&C system design also provides diverse backup for RTIF/NMS and SSLC/ESF to address software CCF concern in accordance with the SRM to SECY-93-87, item II.Q
- LTR NEDO-33251, “ESBWR I&C Diversity and Defense-in-Depth,” provides I&C system architecture and the analysis in conformance with BTP HICB-19 guidance
- DPS design is based on different technology, equipment, design personnel, signals, and functionality
- Diversity is provided both within Q-DCIS (three platforms RTIF/NMS , SSLC/ESF, and ICP are diverse from each other) and externally by a non-safety DPS
- DPS is classified as RTNSS and is developed via a rigorous, highly structured process similar to ones used for safety systems

# Simplicity

- The staff found that the I&C system design employs simplicity in many aspects, which contribute to the staff's safety finding:
  - Each Q-DCIS division is independently monitored and controlled from its dedicated redundant set of safety related VDUs
  - Safety related components cannot be controlled from the non-safety related VDUs
  - Data communication from safety to non-safety related I&C systems is unidirectional
  - I&C system design meets “Independence – Isolation – Separation” requirements
  - Inter and intra-divisional communication is limited
  - ESBWR is a passive plant and the safety-related ESF functions are limited
  - Maintenance tool is not continuously connected

# Logic Diagrams

- DCD contains adequate control logic design information for the staff to make a reasonable safety assurance finding
- Information described in the DCD will be used to develop logic diagrams
- Logic diagrams are produced and used during the I&C development life-cycle process
- Logic diagrams are finalized during the hardware/software design specification phase of the I&C system development lifecycle

# Conclusion

- The staff has evaluated safety of the I&C system design and finds the design to be safe
- I&C systems are in conformance with the applicable regulatory requirements:
  - 10 CFR Part 52
  - 10 CFR Part 50, including 50.55a(h) (IEEE Std. 603 requirements)
  - 10 CFR Part 50 Appendix A (GDC)
  - 10 CFR Part 50 Appendix B (QA)
  - 10 CFR Part 50.34 (TMI items)
- I&C implementation DAC/ITTAC provided in Tier 1 are acceptable
- DCD Revision 8:
  - Provides clarity of I&C design information
  - No impact on I&C design
  - No impact on safety finding

# Chapter 7 ACRONYMS

- ATWS Anticipated Transient Without Scram
- CCF Common Cause Failure
- DBA Design Basis Accident
- DCD Design Control Document
- DPS Diverse Protection System
- ESF Engineered Safety Feature
- GDC General Design Criteria
- ICP Independent Control Platform
- I&C Instrumentation and Control
- I/O Input and Output
- IEEE Institute of Electrical and Electronics Engineers
- LTR Licensing Technical Report
- N-DCIS Non Safety-related Distributed Control and Information System
- NMS Neutron Monitoring System
- QA Quality Assurance
- Q-DCIS Safety-related Distributed Control and Information System

## Chapter 7 ACRONYMS (cont.)

- RG Regulatory Guide
- RTIF Reactor Trip and Isolation Function
- RTNSS Regulatory Treatment of Non-Safety System
- SER Safety Evaluation Report
- SSLC Safety System Logic and Control
- TMR Triply Modular Redundant
- VDU Video Display Unit



Presentation to the ACRS Subcommittee

# **ESBWR Design Certification Review**

## **Chapter 4 – Reactor Design**

Presented by

James Gilmer - NRO/DSRA/SRSB

September 23, 2010

# Topical Report Briefings

The following topical reports have been approved by the staff:

- May 2010 Subcommittee meeting
  - NEDC-33240P - GE14E Fuel Assembly Mechanical Design Report
  - NEDC-33242P - GE14E Fuel Rod Thermal-Mechanical Design Report
  - NEDE-33243P – Control Blade Nuclear
  - NEDE-33244P – Control Blade Mechanical Design
  - NEDC-33239P – Nuclear Design Report
  - NEDC-32197P – Gamma Thermometer
- October 2009 Subcommittee meeting
  - NEDC-33237P – Critical Power Correlation
  - NEDC-33413P – Critical Power Testing

# Summary of Technical Issues

- Approximately 258 technical RAIs were closed for Chapter 4 and related topical reports
  - Section 4.2 – 34 RAIs
  - Section 4.3 – 32 RAIs
  - Section 4.4 – 92 RAIs
  - Section 4.5 – 32 RAIs
  - Section 4.6 – 39 RAIs
  - Section 4.8 – 17 RAIs
  - Section 4.9 – 12 RAIs
- No outstanding issues from ACRS from previous briefings

# Conclusion

Staff finds the ESBWR fuel assembly and control blade design to be acceptable

- Meets regulatory requirements including applicable GDCs
- Analyses and testing demonstrating conservative design



United States Nuclear Regulatory Commission

*Protecting People and the Environment*

ACRS Subcommittee Presentation  
ESBWR Design Certification Review

## Discussion/Committee Questions