CHAPTER 4

4.0 TRANSMISSION SYSTEM ALTERNATIVES – AFFECTED ENVIRONMENT AND ENVIRONMENTAL CONSEQUENCES

This chapter includes a description of the affected environment and expected direct, indirect, and cumulative impacts associated with proposed transmission system improvements described in Section 2.6 and shown in Figure 2-15. Transmission infrastructure, including corridors and switchyards, to support operation of a nuclear plant at the BLN site was identified, reviewed, and evaluated in the earlier environmental review documents prepared by TVA and the AEC for the original facility encompassing BLN 1&2. The AEC subsequently approved and issued a construction license for BLN 1&2 and the supporting transmission infrastructure into and at the site (TVA 2008a). The approved transmission system was constructed before the plant entered deferred status.

The 11 transmission lines that would need to be upgraded or reenergized to support operation of a single nuclear unit at the BLN site are listed in Table 2-1. Nine of the lines need to be reconductored or uprated. Sections of two 500-kV lines need to be connected and energized; ROW vegetation management on those deenergized segments will be brought back to current TVA standards. The Widows Creek-Bellefonte and Bellefonte-Scottsboro 161-kV lines would not need to be changed to support operation of a single nuclear unit at the BLN site. Additional description of proposed transmission line upgrades is provided in Section 2.6. As described in Section 2.6, no new transmission lines would be needed under either Action Alternative, and therefore no additional ROW would be required. In addition, the existing 500-kV switchyard would be refurbished.

The methods used to manage the infrastructure and maintain ROW for the lines would be unchanged. Prior to these activities, TVA archaeologists and biologists would conduct an SAR of the transmission line area (including the ROW) to identify any resource issues that may occur along that transmission line. These reviews are conducted on a recurring basis that coincides with the maintenance cycle, to ensure that the most current information is provided to the organizations conducting maintenance on these transmission lines. A summary of the SAR process is provided in Appendix D.

Only minor editorial changes have been made to Chapter 4 in the FSEIS. There were no comments on the DSEIS related to the proposed transmission system upgrades.

4.1. Surface Water

4.1.1. Affected Environment

The project areas of the proposed transmission line improvements drain to the Tennessee River and its tributaries at the following locations: (1) Guntersville and Wheeler reservoirs in Alabama, (2) at Nickajack and Chickamauga reservoirs in southeast Tennessee and northwest Georgia, and (3) upstream and downstream of Normandy Dam on the Duck River in central Tennessee. Table 4-1 identifies the major streams within the project area and their state designated use classification and 303(d) use impairment listing. Streams on a state 303(d) list do not fully support one or more of their designated uses and are included in a state program to eliminate the water quality impairment.

Line/Stream-Reservoir	State	Classification ¹	303(d) Listed/Reason
Browns Ferry-Trinity 161-kV (ID: 10)	<u> </u>		
Tennessee River-Wheeler	Ala.	S, F&W	No
Bakers Creek	Ala.	F&W	No
	7 110.		
Browns Ferry-Athens 161-kV (ID: 11)	Ala.		· · · · · · · · · · · · · · · · · · ·
Tennessee River-Wheeler	Ala.	S, F&W	No
Round Island Creek	Ala.	F&W	No
Swan Creek	Ala.	F&W, A&I	Yes - nutrients
Town Creek	Ala.	F&W	No
Widows Creek-Bellefonte #1 500-kV ² (ID: 6); Bellefonte-Madison 500-kV ² (ID: 7)			
Tennessee River-Guntersville	Ala.	PWS, S, F&W	No
Town Creek	Ala.	F&W	No
Mud Creek	Ala.	F&W	No
Crow Creek	Ala.	F&W	No
Big Coon Creek	Ala.	F&W	No
Little Coon Creek	Ala.	F&W	No
Widows Creek	Ala.	S, F&W	No
Widows Creek-Bellefonte #2 500-kV ³ (ID: 8); Bellefonte-East Point 500-kV ³ (ID: 9) Tennessee River-Guntersville	Ala. Ala.	PWS, S, F&W	No
Coon Creek	Ala.	S, F&W	No
Cooli cieek		5,100	NO
Widows Creek-Oglethorpe #2 161-kV ⁴ (ID: 4)	Ala.	· · ·	
Tennessee River-Guntersville	Ala.	PWS, S, F&W	No
Widows Creek	Ala.	S, F&W	No
Long Island Creek	Ala.	PWS, S, F&W	No
Widows Creek-Oglethorpe #3 161-kV ⁴ (ID: 5)	Ala.		
Tennessee River-Guntersville	Ala.	PWS, S, F&W	No
Long Island Creek	Ala.	PWS, S, F&W	No
Guest Creek	Ala.	F&W	No
Tennessee River-Nickajack	Tenn.	DWS, IWS, FAL, REC, LWW, IRR, NAV	Yes – dioxins, PCBs
Cole City Creek	Ga.	Fishing	No
Lookout Creek	Ga.	Fishing	Yes – nonpoint source pollution
Chattanooga Creek	Ga.	Fishing	Yes – nonpoint source pollution
Rock Creek	Ga.	Fishing, Trout Stream	No
Dry Creek	Ga.	Fishing	Yes – nonpoint source pollution
S. Chickamauga Creek	Tenn.	IWS, FAL, REC, LWW, IRR	Yes – <i>E. coli</i> , nutrients, other anthropogenic habitat loss

Table 4-1. State Classification and 303(d) Listing of Major Streams Crossed

Final Supplemental Environmental Impact Statement

Line/Stream-Reservoir	State	Classification ¹	303(d) Listed/Reason
W. Chickamauga Creek	Ga.	Fishing	Yes – nonpoint source pollution
Widows Creek-Raccoon Mountain #2 161-kV (ID: 3)			
Tennessee River-Guntersville	Ala.	PWS, S, F&W	No
Long Island Creek	Ala.	PWS, S, F&W	No
Guest Creek	Ala.	F&W	No
Tennessee River-Nickajack	Tenn.	DWS, IWS, FAL, REC, LWW, IRR, NAV	Yes – dioxins, PCBs
Cole City Creek	Ga.	Fishing	No
Lookout Creek	Tenn.	IWS, FAL, REC, LWW, IRR	No
Sequoyah-Widows Creek 500-kV (ID: 2)			
Tennessee River-Guntersville	Ala.	PWS, S, F&W	No
Sequatchie River	Tenn.	DWS, IWS, FAL, REC, LWW, IRR	No
Tennessee River-Nickajack	Tenn.	DWS, IWS, FAL, REC, LWW, IRR, NAV	Yes – dioxins, PCBs
Suck Creek	Tenn.	FAL, REC, LWW, IRR	No
South Suck Creek	Tenn.	FAL, REC, LWW, IRR	Yes – loss of biological integrity
North Suck Creek	Tenn.	FAL, REC, LWW, IRR	Yes - pH
N. Chickamauga Creek	Tenn.	FAL, REC, LWW, IRR, TS	Yes – pH, physical substrate habitat problems
Tennessee River-Chickamauga	Tenn.	DWS, IWS, FAL, REC, LWW, IRR, NAV	No
Wartrace-N. Tullahoma Tap 161-kV (ID: 1)			<u> </u>
Tennessee River-Kentucky	Tenn.	DWS, IWS, FAL, REC, LWW, IRR, NAV	No
Duck River-Normandy	Tenn.	DWS, IWS, FAL, REC, LWW, IRR	No
Carroll Creek	Tenn.	FAL, REC, LWW, IRR	No
Duck River- Below Normandy	Tenn.	DWS, FAL, REC, LWW, IRR, TS	Yes – E. coli

:

Line/Stream-Reservoir	State	Classification ¹	303(d) Listed/Reason
Doddy Creek	Tenn.	FAL, REC, LWW, IRR	Yes – habitat loss from erosion, flow alteration
Garrison Fork	Tenn.	DWS, IWS, FAL, REC, LWW, IRR	No
Wartrace Creek	Tenn.	FAL, REC, LWW, IRR	Yes – E. coli

¹ Abbreviations for designated use classifications for **Alabama**: PWS—Public Water Supply, S—Swimming and Other Whole Body Water-Contact Sports, F&W—Fish and Wildlife. For **Tennessee**: DWS—Domestic Water Supply, IWS—Industrial Water Supply, FAL—Fish and Aquatic Life, REC—Recreation, LWW—Livestock Watering and Wildlife, IRR—Irrigation, NAV—Navigation, TS—Trout Stream

² Portions of the Widows Creek-Bellefonte #1 and Bellefonte-Madison 500-kV lines share a common ROW.

³ Portions of the Widows Creek-Bellefonte #2 and Bellefonte-East Point 500-kV lines share a common ROW.

⁴ The Widows Creek-Oglethorpe #2 and #3 161-kV lines are co-located.

4.1.2. Environmental Consequences

No Action Alternative

Under the No Action Alternative, because much of the subject lines are located on existing ROW, vegetation maintenance would continue to occur periodically, including the use of herbicides, which could possibly have an impact on groundwater resources. During ROW maintenance, the vegetation management guidelines and procedures as described in Appendix L would be followed. With the implementation of BMPs and routine precautionary measures, no additional impacts to surface water would likely occur related to the ongoing maintenance activities under the No Action Alternative.

Action Alternative

Soil disturbances associated with the use of or maintenance of access roads or transmission line upgrading activities could potentially result in adverse water quality impacts. Soil erosion and sedimentation can clog small streams and threaten aquatic life. Continued removal of the tree canopy along stream crossings can increase water temperatures and algal growth, decrease dissolved oxygen levels, and cause adverse impacts to aquatic biota. However, TVA routinely includes precautions in the design of its transmission line projects to minimize these potential impacts (see Appendices L and M [SOPs]). In the unlikely event that any new permanent stream crossings are necessary, these crossings would be designed to avoid impeding runoff patterns and the natural movement of aquatic fauna. Temporary stream crossings and other upgrading and maintenance activities would comply with appropriate state permit requirements and TVA requirements as described in Muncy (1999). Canopies in all streamside management zones (SMZs) would be left undisturbed unless there were no practicable alternative (see Appendix N). Proper implementation of these controls is expected to result in only minor temporary impacts to surface waters. Any cumulative impacts to surface water quality are anticipated to be minor and insignificant.

4.2. Groundwater

4.2.1. Affected Environment

The affected transmission lines for the Action Alternative span several geographical areas. The geology and the groundwater contained within these areas are diverse, and for the purposes of this review, have been broken into geographic sections according to the physiographic province in which the transmission lines occur.

Northeast Alabama, Southeast Tennessee, and Northwest Georgia Sections The six transmission lines proposed for upgrades in this section are Sequoyah-Widows Creek 500-kV (ID: 2); Widows Creek-Oglethorpe #2 161-kV (ID: 4); Widows Creek-Oglethorpe #3 161-kV (ID: 5); Widows Creek-Bellefonte #1 500-kV (ID: 6); Widows Creek-Bellefonte #2 500-kV (ID: 8); and Widows Creek-Raccoon Mountain #2 161-kV (ID: 3). These transmission lines are located across two physiographic provinces, i.e., the Valley and Ridge, and the Appalachian Plateaus.

The Valley and Ridge aquifer consists of folded and faulted carbonate, sandstone, and shale. Soluble carbonate rocks and some easily eroded shales underlie the valleys in the province, and more erosion-resistant siltstone, sandstone, and cherty dolomite underlie ridges. The arrangement of the northeast-trending valleys and ridges are the result of a combination of folding, thrust faulting, and erosion. Compressive forces from the southeast have caused these rocks to yield, first by folding and subsequently by repeatedly breaking along a series of thrust faults. The result of the faulting is that geologic formations are repeated several times across the region. Carbonate-rock aquifers in the Chickamauga, the Knox, and the Conasauga groups are repeated throughout the Valley and Ridge Physiographic Province (Miller 1990).

Groundwater in the Valley and Ridge aquifers primarily is stored in and moves through fractures, bedding planes, and solution openings in the rocks. These aquifers are typically present in valleys and rarely present on the ridges. Most of the carbonate-rock aquifers are directly connected to sources of recharge, such as rivers or lakes, and solution activity has enlarged the original openings in the carbonate rocks. In the carbonate rocks, the fractures and bedding planes have been enlarged by dissolution of part of the rocks. Slightly acidic water dissolves some of the calcite and dolomite that compose the principal aquifers. Most of this dissolution takes place along fractures and bedding planes where the largest volumes of acidic groundwater flow.

Groundwater movement in the Valley and Ridge Province is localized, restricted by the repeating lithology created by thrust faulting. Older rocks, primarily the Conasauga Group and the Rome Formation, have been displaced upward over the top of younger rocks (the Chickamauga and the Knox groups) along thrust fault planes thus forming a repeating sequence of permeable and less permeable hydrogeologic units. The repeating sequence, coupled with the stream network, divides the area into a series of adjacent, isolated, shallow groundwater flow systems. The water moves from the ridges, where the water levels are high, toward lower water levels adjacent to major streams that flow parallel to the long axes of the valleys. Most of the groundwater is discharged directly to local springs or streams (Miller 1990).

Aquifers of the Appalachian Plateaus Physiographic Province consist of permeable stratigraphic units of Paleozoic sedimentary rocks. Major aquifers in the Appalachian Plateaus Province are in limestone units of Mississippian age covered by sandstone of the Pennsylvanian Pottsville Formation. Flow in the Appalachian Plateaus aquifers is affected

primarily by topography, structure, and the development of solution openings in the rocks. A thick sequence of shale, sandstone, and coal overlies Mississippian limestone. Recharge to the aquifers is by precipitation on the flat, mesa-like plateau tops. Water then percolates downward through the Pennsylvanian sandstone (Pottsville Formation), primarily along steeply inclined joints and fractures. Some water leaks downward across the interbedded shale into the underlying limestone aquifer. Sandstone of the Pottsville Formation varies greatly in its water-producing capabilities. A thick black shale (the Chattanooga Shale) forms a confining unit for the Appalachian Plateaus aquifer (Miller 1990).

Public drinking water is supplied by both groundwater and surface water sources for the counties in which the ROWs are located (EPA 2009). Sequoyah-Widows Creek 500-kV (ID: 2) intersects a State Designated Source Water Protection Area, which is the recharge area for the Hixson, Tennessee, Utility District in Hamilton County; other State Designated Source Water Protection Areas may occur. Private wells occur throughout the area.

Middle Tennessee Section

The ROW of the Wartrace-N. Tullahoma Tap 161-kV (ID: 1) transmission line proposed for upgrading in this section is underlain by aquifers, from the Ordovician and Mississippian Periods, in the Interior Low Plateaus Physiographic Province. These aquifers are separated by a confining unit. These carbonate rocks are the principal aquifers in large areas of central Tennessee and are part of the Central Basin aquifer system. The carbonate rock aquifers consist of almost pure limestone and minor dolostone and are interlayered with confining units of shale and shaly limestone. Limestone is susceptible to erosion, which produces fissures, sinkholes, underground streams, and caverns forming vast karst areas.

The middle Ordovician, Stones River Group contains the most important carbonate-rock aquifers in the project area. The calcareous siltstones of the middle Ordovician Nashville Group yield small volumes of water, but these units are not considered to be principal aquifers. The lower Ordovician Knox Group is a major aquifer where dolostone contains freshwater (Lloyd and Lyke 1995).

Highland Rim aquifer system from the Mississippian Period consists of flat-lying carbonate rocks. The formations that make up the Highland Rim aquifer within this section of the project area are the Monteagle Limestone, the St. Genevieve Limestone, the St. Louis Limestone, the Warsaw Limestone, and the Fort Payne Formation (Lloyd and Lyke 1995). The bedrock formations weather to form a thick chert regolith, which stores and releases groundwater into fractures and solution openings in the bedrock (TDEC 2002).

Precipitation is the primary source of recharge in the Interior Low Plateaus Province. Most of the precipitation becomes overland runoff to streams, but some percolates downward through soil to the underlying bedrock. In the consolidated rocks, however, most of the water moves through and is discharged from secondary openings, such as joints, fractures, bedding planes, and solution openings. As a result, groundwater discharge from springs is common throughout the Interior Low Plateaus Province (Lloyd and Lyke 1995).

The carbonate rocks that form the Highland Rim aquifer are typical of karst systems. The term karst refers to carbonate rocks (limestone and dolostone) in which groundwater flows through solution-enlarged channels and bedding planes within the rock. Karst topography is characterized by sinkholes, springs, disappearing streams, and caves, as well as by rapid, highly directional groundwater flow in discrete channels or conduits. Because of the

Final Supplemental Environmental Impact Statement

connections between surface and underground features, water in karst areas is not distinctly surface water or groundwater.

Karst systems are readily susceptible to contamination, as the waters can travel long distances through conduits with no chance for natural filtering processes of soil or bacterial action to diminish the contamination. Consequently, the groundwater sources in karst aquifers considered most vulnerable to contamination are those that are under the direct influence of surface water.

Public drinking water for Coffee and Bedford counties in Tennessee is supplied by both surface water and groundwater sources (EPA 2009). Privately owned wells supply water to area restaurants, schools, and marinas in the county. Residential wells are likely to occur near the subject ROWs.

North Alabama Section

The Browns Ferry-Trinity 161-kV (ID: 10) and Browns Ferry-Athens Alabama, 161-kV (ID: 11) transmission lines proposed for upgrading are also underlain by the Highland Rim aquifer system, which is part of the Interior Low Plateaus Physiographic Province. However, the aquifer is known locally as the Tuscumbia-Fort Payne aquifer. The formations that make up this aquifer are the Fort Payne Chert, the Tuscumbia Limestone, and the Monteagle Limestone. The Chattanooga Shale is at the base of the Tuscumbia-Fort Payne aquifer and acts as a confining unit. The upper bedrock formations weather to form a thick regolith that covers the surface of the Fort Payne. The regolith may be as thick as 100 feet and is mostly clay, but may contain significant layers of chert rubble.

Like the rest of the Mississippian Highland Rim aquifer, fractures and solution openings have formed a network of interconnected caves, sinkholes, and springs throughout these formations.

The regolith⁷ and underlying bedrock are hydrologically connected. Recharge to the aquifer is largely from precipitation infiltrating and moving through the regolith. Focused recharge also occurs from surface drainage into sinkholes or losing stream reaches that intersect the aquifer (Kingsbury 2003). Like the rest of the Highland Rim aquifer system, the aquifer is readily susceptible to contamination and is considered vulnerable to contamination.

Public drinking water for Limestone County, Alabama, is supplied by both surface water and groundwater sources. Public water for Morgan County, Alabama, is supplied by surface water (EPA 2009). Privately owned wells supply water to area restaurants, schools, and marinas in the county. Residential wells likely occur near the subject ROW.

4.2.2. Environmental Consequences

No Action Alternative

Under the No Action Alternative, vegetative maintenance would occur periodically, including the use of herbicides that could possibly have an impact on groundwater resources. During future revegetation and maintenance activities, application of herbicides and fertilizers would be avoided in the areas along the ROWs where sinkholes, caves, and State Designated Source Water Protection Areas occur to prevent groundwater contamination. Any herbicides applied to the ROWs during periodic maintenance would be applied

⁷ Regolith refers to the layer of loose rock resting on bedrock, constituting the surface of most land.

according to the manufacturer's label. During ROW maintenance, the vegetation management guidelines and procedures as described in Appendix L would be followed. With the implementation of BMPs (Muncy 1999) and routine precautionary measures, potential impacts to groundwater under the No Action Alternative would be insignificant.

Action Alternative

Under the Action Alternative, anticipated impacts on existing ROWs from maintenance would be similar to those occurring under the No Action Alternative. Potential impacts to groundwater from upgrades of the transmission lines could result if sediments from disturbed soil enter or clog karst features, or from the transport of herbicides and fertilizers or other contaminants into sinkholes and caves. BMPs and routine precautionary measures, as described in the No Action Alternative, would be used during ROW maintenance and transmission line upgrades to control sediment infiltration from storm water runoff and to avoid contamination of groundwater in the project areas. Therefore, potential impacts to groundwater from the Action Alternative would be insignificant.

4.3. Aquatic Ecology

4.3.1. Affected Environment

As described in Section 4.1 (Surface Water) above, the surface water drainage from the proposed transmission line improvements drain to the Tennessee River and its tributaries at the following locations: (1) Guntersville and Wheeler Reservoirs (Jackson, Limestone, and Morgan counties in Alabama); (2) at Nickajack and Chickamauga Reservoirs in southeast Tennessee (Hamilton, Marion, and Sequatchie counties) and northwest Georgia (Catoosa, Dade, and Walker counties); and (3) upstream and downstream of Normandy Dam on the Duck River in central Tennessee (Bedford and Coffee counties).

TVA routinely monitors streams and reservoirs in the Tennessee River drainage as part of its Reservoir VS monitoring program, and various water quality initiatives. While not all streams potentially affected by transmission line activities have been assessed, those that have been assessed contain diverse aquatic communities (i.e., fish and invertebrates) representative of streams and reservoirs in the Cumberland Plateau, Eastern Highland Rim, Outer Nashville Basin, Plateau Escarpment, Sequatchie Valley, Southern Table Plateaus and Southern Limestone/Dolomite Valleys and Low Rolling Hills ecoregions.

4.3.2. Environmental Consequences

No Action Alternative

Routine maintenance (including vegetative maintenance) is ongoing on the ROWs of the transmission lines currently in service. Maintenance of access roads and transmission facilities can potentially expose soil and increase erosion that can lead to adverse impacts to water quality and aquatic biota. Improper use of herbicides to control vegetation could result in runoff to streams and subsequent aquatic impacts. TVA routinely includes precautions in maintenance of its transmission line projects to minimize these potential impacts (Muncy 1999).

ROW maintenance employs manual and low impact methods within SMZs wherever possible, and these practices would continue (see Appendix N). In areas requiring chemical treatment, only EPA-registered herbicides would be used in accordance with label directions designed in part to restrict applications in the vicinity of receiving waters and to prevent unacceptable aquatic impacts. Proper implementation of these controls is expected to result in only minor direct and indirect impacts to surface waters or aquatic habitats and the aquatic communities they support. No cumulative impacts are expected.

Action Alternative

The currently inactive 500-kV transmission lines would be reenergized as described in Section 2.6, and routine vegetation and access maintenance would be reestablished for their ROWs. The other transmission lines that would be upgraded are already in service. These lines undergo environmental review as part of TVA's vegetation maintenance program. Because these transmission lines are already in service and being maintained, upgrades associated with operation of a single unit at BLN would have no additional effects above those presently seen on these transmission ROWs. Existing data indicate that no important aquatic resources would be affected by reestablishing maintenance activities of the 500-kV lines or upgrading the other transmission lines currently in service. Field reviews will be conducted prior to vegetation clearing or line upgrade activities to confirm these findings. Appropriate SMZs would be established and maintained per TVA guidelines (Muncy 1999) (also see Appendices L, M, and N). Proper implementation of these controls is expected to result in only minor temporary impacts to surface waters. No direct, indirect, or cumulative impacts to aquatic communities or instream habitat are anticipated.

4.4. Vegetation

4.4.1. Affected Environment

The proposed transmission line upgrades would occur across seven Level IV Ecoregions including the Cumberland Plateau, Eastern Highland Rim, Outer Nashville Basin, Plateau Escarpment, Sequatchie Valley, Southern Table Plateaus and Southern Limestone/Dolomite Valleys and Low Rolling Hills (Figure 4-1). The natural vegetation, along with geologic strata and predominant land use, varies considerably across the project area (Griffith et al. 1998; Griffith et al. 2001). Vegetation in the subject transmission line ROWs included in the proposed project is characterized by two main types: herbaceous vegetation and forest.

Herbaceous vegetation occurs on about 95 percent of the subject transmission line ROWs. Herbaceous vegetation is characterized by greater than 75 percent cover of forbs and grasses and less than 25 percent cover of other types of vegetation, and it is typical of existing transmission line ROWs due to the repeated treatment of woody vegetation to maintain reliability of the transmission system. The type of herbaceous vegetation found in transmission line ROWs can vary, ranging from heavily disturbed areas with high cover of nonnative plants to dry sites dominated by native species that resemble prairie remnants. Some sections of transmission line occurring in areas with low relief likely contain wetland vegetation. Although the percent cover of native species varies considerably across the project area, the high level of disturbance typical of ROWs suggests many areas likely contain a large proportion of nonnative, invasive species.

Forest cover, which occupies 5 percent or less of the subject ROWs is likely deciduous in composition. Deciduous forest is characterized by trees with overlapping crowns where deciduous species account for more than 75 percent of the canopy cover. Deciduous forest occurs only in areas of ROW where the transmission line crosses very steep terrain and in areas where vegetation on existing, deenergized lines has not been maintained for some years. In forested areas with steep terrain the conductor is sometimes high enough above canopy trees such that regular removal of woody species is not necessary to maintain reliability




Figure 4-1. Level IV Ecoregions Crossed by Transmission Lines Requiring Upgrades or Actions to Support Operation of a Single Nuclear Unit at the BLN Site

Final Supplemental Environmental Impact Statement

of the transmission system. Because these spanned areas (i.e., those areas of high relief where the transmission is high above the canopy such that ROW clearing is not necessary) often contain relatively undisturbed forest, they are typically dominated by native species indicative of the region. Conversely, those forested areas within unmaintained ROWs along deenergized transmission lines are typically early successional and usually contain a greater proportion of nonnative, invasive species. These areas are typically dominated by saplings and/or small pole-sized trees.

4.4.2. Environmental Consequences

No Action Alternative

Under this alternative, the existing transmission lines would not be upgraded and the area within the ROWs would remain in its current condition. Methods used to manage vegetation along the ROW and maintain transmission infrastructure would be unchanged. Vegetation maintenance of the ROWs would continue, and portions of the ROW could be periodically disturbed by minor activities related to maintaining transmission infrastructure. TVA standard operating procedure of revegetating any disturbed areas with noninvasive species would help prevent introduction and spread of invasive species in the project area (Muncy 1999). Thus, adoption of the No Action Alternative would not affect plant life in the area of the proposed ROWs. The structure and composition of the vegetation would not be appreciably altered, under the No Action Alternative.

Action Alternative

Under this alternative, the existing transmission lines would be upgraded, and the methods used to manage vegetation along the ROWs and to maintain transmission infrastructure would be comparable to what currently occurs. However, botanical surveys of the ROWs that would occur as part of the process (see Subsection 2.6.4) could identify more federally listed or state-listed plants along those ROWs. If rare plants are observed, no aerial application of herbicide would take place along parts of the ROW inhabited by listed species. In areas that currently receive aerial applications of herbicides, local changes to vegetation structure and composition would likely occur if the application was suspended. These changes would have little ecological impact because any shifts in species composition would not change the early successional nature of the plant community.

Adoption of this alternative would not require new clearing of forest, although areas of herbaceous vegetation may need to be cleared to facilitate upgrading activities. Effects to herbaceous vegetation in the existing ROWs would be temporary and would not likely persist for more than approximately one year after activities cease. TVA standard operating procedure of revegetating with noninvasive species would help prevent introduction and spread of invasive species in the project area (Muncy 1999). Adoption of the Action Alternative would not significantly affect the botanical characteristics of the area in which the subject ROWs are located.

4.5. Wildlife

4.5.1. Affected Environment

Two types of terrestrial habitat occur in the transmission line ROWs associated with proposed generation at BLN. These include early-successional, i.e., herbaceous habitat, which occupies about 95 percent of the subject ROWs and forested habitat, which occupies the remaining 5 percent. A more detailed description of vegetation is provided in Subsection 4.4.1.

Early successional habitat occurs along most of the existing transmission line ROWs. Within this habitat type, the ROWs cross agricultural fields (occupying about 40 percent of the coverage), herbaceous or scrub-shrub (about 40 percent of the coverage), and maintained lawns or fields (approximately10 percent of the coverage). Some sections of the subject transmission line ROWs occur in areas with minor topographical relief. Such areas likely contain early successional emergent wetland habitat.

Birds commonly observed in early successional habitat include the Carolina wren, American robin, northern mockingbird, northern cardinal, eastern towhee, eastern bluebird, brown thrasher, field sparrow, eastern meadowlark, and European starling. Red-tailed hawk and American kestrel also forage along ROWs. Mammals frequently observed in this type of habitat include Virginia opossum, eastern cottontail, striped skunk, white-tailed deer, eastern mole, woodchuck, white-footed mouse, and hispid cotton rat. Coyote, bobcat, red fox, and gray fox also use ROWs that cross forest as corridors for travel and foraging. Common reptiles found along ROWs include black racer, black rat snake, milk snake, and garter snake. Wetlands within early successional habitats provide habitat for amphibians such as American toad, green frog, northern cricket frog, upland chorus frog, and red-spotted newt.

Forested habitat present within the existing ROWs is likely upland deciduous forest. Deciduous forest occurs only in areas where the transmission line crosses very steep terrain. In these spanned areas, the conductor is high enough above canopy trees that regular removal of woody species is not necessary to maintain reliability of the transmission system.

Deciduous forests provide habitat for wild turkey, downy woodpecker, pileated woodpecker, white-breasted nuthatch, and American crow, as well as neotropical songbirds such as wood thrush, blue-gray gnatcatcher, red-eyed vireo, and ovenbird. White-tailed deer and gray squirrel are frequently found in deciduous forests, and scattered rock outcrops within these forests provide habitat for a variety of small mammals. Northern zigzag salamander and slimy salamander also inhabit the forest floor of deciduous forests. Common reptiles include eastern box turtle, northern ringneck snake, black rat snake, and northern copperhead.

Unique and important terrestrial habitats, such as caves, occur near the corridors. The TVA Natural Heritage database contains records of 215 caves within 3 miles of the existing transmission line ROWs. The closest cave records are approximately 0.25 mile from the Widows Creek-Raccoon Mountain #2 161-kV (ID: 3) transmission line in Marion County, Tennessee. All other known cave locations are greater than 0.5 mile from the ROWs.

Twelve heron colonies are reported within 3 miles of, but greater than 0.25 mile from, the subject ROWs. Except for seasonal aggregations of waterfowl along the Tennessee River, no other aggregations of migratory birds occur in the project area.

4.5.2. Environmental Consequences

No Action Alternative

Under the No Action Alternative, early-successional and forested habitat within the ROWs would be maintained at current proportions and thus would not result in changes to wildlife habitat. Methods used to manage vegetation along the ROW and maintain transmission infrastructure would be unchanged. Clearing of the ROWs for vegetation maintenance would continue to occur, and portions of the ROWs would be periodically disturbed by minor activities related to maintaining transmission infrastructure. Selection of the No Action Alternative would not result in adverse direct, indirect, or cumulative impacts to terrestrial animals.

Action Alternative

Adoption of the Action Alternative would not require new clearing of forest, although areas of vegetation within some ROWs may need to be recleared to facilitate maintenance activities. Some ROWs likely have undergone secondary succession, resulting in establishment of young trees. The removal of the taller vegetation within these areas may temporarily displace larger, animals. Some smaller animals occupying the areas, such as mice, shrews, frogs, and salamanders, also may move into adjacent areas during upgrading and maintenance activities. Following the upgrading and reestablishing maintenance activities of any sites, wildlife favoring edge and early successional habitats would reoccupy these areas.

There are records of 215 caves and 12 heron colonies within 3 miles of the ROWs. However, because caves and heronries are greater than 0.25 mile from the ROWs, adoption of the Action Alternative would not result in adverse impacts to these resources. TVA biologists would perform field surveys to confirm these findings prior to reclearing the ROWs for the 500-kV lines and upgrading the transmission lines currently in service. If previously undocumented resources are identified within these ROWs during the surveys, appropriate protective buffers would be placed around those resources. Most work would be restricted to areas immediately surrounding existing ROWs. Because known terrestrial animal resources within the ROWs are regionally abundant and protective measures would be taken to protect newly discovered sensitive resources, selection of the Action Alternative would not result in adverse direct, indirect, or cumulative impacts to terrestrial animals.

4.6. Endangered and Threatened Species

In accordance with Section 7 of the ESA, TVA has prepared a BA of potential effects to federally listed animals and plants from proposed completion/construction and operation of a nuclear plant at the BLN site, including the proposed transmission system improvements (TVA 2009d). Fifty-two plants and animals federally listed as endangered, threatened, candidate for listing, or protected under the Bald and Golden Eagle Protection Act potentially occur in potentially affected areas. Results of the analysis prepared for the BA indicate proposed actions along transmission lines are not likely to adversely affect any federally listed species or adversely modify critical habitat. TVA received concurrence with these determinations from the USFWS in a letter dated December 7, 2009 (See Appendix H).

4.6.1. Aquatic Animals

4.6.1.1. Affected Environment

As described in Section 4.1 of this document, the project areas of the proposed transmission line improvements drain to the Tennessee River and its tributaries at the following locations: (1) Guntersville and Wheeler Reservoirs (Jackson, Limestone, and Morgan counties in Alabama); (2) at Nickajack and Chickamauga Reservoirs in southeast Tennessee (Hamilton, Marion, and Sequatchie counties) and northwest Georgia (Catoosa, Dade, and Walker counties); and (3) upstream and downstream of Normandy Dam on the Duck River in central Tennessee (Bedford and Coffee counties).

Federally listed aquatic species known to be present in streams in counties in the areas crossed by one or more of these transmission lines are listed in Table 4-2. State-listed animal species are provided in Appendix O, Table O-1.

Common Name	Scientific Name	Federal Status
Snails	· · · · · · · · · · · · · · · · · · ·	I
Anthony's river snail*#	Athearnia anthonyi	LE
Armored snail	Pyrgulopsis pachyta	LE
Owen spring limnephilid caddisfly	Glyphopsyche sequatchie	С
Royal marstonia	Pyrgulopsis ogmorhaphe	LE -
Slabside pearlymussel	Lexingtonia dolabelloides	С
Slender campeloma*	Campeloma decampi	LE
Mussels		
Alabama lampmussel#	Lampsilis virescens	LE
Alabama moccasinshell	Medionidus acutissimus	LT
Birdwing pearlymussel	Lemiox rimosus	LE
Cracking pearlymussel	Hemistena lata	LE
Cumberland bean	Villosa trabalis	LE .
Cumberland combshell	Epioblasma brevidens	LE
Cumberland monkeyface	Quadrula intermedia	LE
Cumberland pigtoe	Pleurobema gibberum	LE
Dromedary pearlymussel	Dromus dromas	LE
Fine-lined Pocketbook	Lampsilis altilis	LT
Fine-rayed Pigtoe#	Fusconaia cuneolus	LE
Fluted kidneyshell	Ptychobranchus subtentum	С
Orange-foot Pimpleback	Plethobasus cooperianus	LE
Pale lilliput#	Toxolasma cylindrellus	LE
Pink mucket*#	Lampsilis abrupta	LE
Ring pink	Obovaria retusa	LE
Rough pigtoe*	Pleurobema plenum	LE
Sheepnose	Plethobasus cyphyus	C '
Shiny pigtoe pearlymussel#	Fusconaia cor	LE
Slabside pearlymussel*	Lexingtonia dolabelloides	С
Southern pigtoe	Pleurobema georgianum	LE
Spectaclecase	Cumberlandia monodonta	С
Tan riffleshell	Epioblasma florentina walkeri	LE
Tuberculed blossom pearlymussel	Epioblasma torulosa torulosa	LE
Turgid blossom pearlymussel	Epioblasma turgidula	LE
Fish		· · · · · · · · · · · · · · · · · · ·
Boulder darter	Etheostoma wapiti	LE
Palezone shiner#	Notropis albizonatus	LE
Slackwater darter	Etheostoma boschungi	LT

Table 4-2.Federally Listed Aquatic Animal Species Present in CountiesAffected by Proposed Transmission Line Upgrades

Final Supplemental Environmental Impact Statement

Common Name	Scientific Name	Federal Status
Snail darter	Percina tanasi	LT
Spotfin chub	Cyprinella monacha	LT
Yellowfin madtom	Noturus flavipinnis	LT

Species that are known to occur in watersheds directly affected by construction activities are indicated by (*).

Species reported from Jackson County, Alabama are indicated by (#)

Status Codes: LE = Listed endangered; LT = Listed threatened; C = Candidate for Federal Listing

4.6.1.2. Environmental Consequences

No Action Alternative

Under the No Action Alternative, because the proposed project is on existing ROW, no impacts to federally listed or state-listed aquatic organisms would result from transmission infrastructure upgrades or ongoing routine maintenance that would continue.

Action Alternative

The currently inactive 500-kV transmission lines would be reenergized as described in Section 2.6, and routine vegetation and access maintenance would be reestablished for their ROWs. The other transmission lines that would be upgraded are already in service. These lines undergo environmental review as part of TVA's vegetation maintenance program. Because these transmission lines are already in service and being maintained, upgrades associated with operation of a single unit at BLN would have no additional effects above those presently seen on these transmission ROWs.

Routine maintenance of access roads and transmission facilities can potentially expose soil and increase erosion that could lead to adverse impacts to water quality, thereby affecting aquatic biota. Improper use of herbicides to control vegetation could result in runoff to streams and subsequent aquatic impacts. TVA routinely includes precautions in maintenance of its transmission line projects to minimize these potential impacts (Muncy 1999).

ROW maintenance would employ manual and low-impact methods within SMZs wherever possible (see Appendix N). In areas requiring chemical treatment, only EPA-registered herbicides would be used in accordance with label directions designed in part to restrict applications in the vicinity of receiving waters and to prevent unacceptable impacts to aquatic life impacts. Broadcast aerial application of herbicides adjacent to streams containing federally listed species would be prohibited.

Existing data indicate that no important aquatic species would be affected by reestablishing maintenance of the 500-kV lines or upgrading the other transmission lines currently in service. Field reviews will be conducted prior to vegetation clearing or line upgrade activities to confirm these findings. If habitats for any federally or state-listed animal species occur, measures to avoid and/or minimize impacts would be taken such that no significant impacts to sensitive aquatic species or their habitats occur. With the proper implementation of these controls no direct, indirect, or cumulative impacts on federally or state-listed aquatic species or their habitats are anticipated.

4.6.2. Plants

4.6.2.1. Affected Environment

Review of the TVA Natural Heritage database (queried September 2009) indicates that 12 occurrences of nine state-listed species and one occurrence of one federally listed species have been documented within the transmission ROWs subject to proposed upgrades (see Table 4.3 and Appendix O, Table O-2). Additionally, five federally listed, one candidate for federal listing, and 108 state-listed plant species occur within 5 miles of the proposed transmission line upgrades. Five other federally listed and one other candidate for federal listing are known from counties where the transmission line upgrades would occur, but are greater than 5 miles away from the ROWs. No designated Critical Habitat for plant species occurs in the project area.

Table 4-3.	Federally Listed Terrestrial Plant Species Known Within and Near
	(Within 5 Miles) the ROWs Subject to Upgrades/Actions and From
	the Counties Where Work Would Occur

Common Name	Scientific Name	Federal Status
Price's potato-bean	Apios priceana	THR
American Hart's-tongue fern ²	Asplenium scolopendrium var. americanum	THR
Morefield's leather-flower ²	Clematis morefieldii	END
Leafy prairie-clover ²	Dalea foliosa	END
Small whorled pogonia	Isotria medeoloides	THR
Fleshy-fruit gladecress ²	Leavenworthia crassa	С
Mohr's Barbara's Buttons	Marshallia mohrii	THR
Monkey-face orchid	Platanthera integrilabia	С
Green pitcher plant ²	Sarracenia oreophila	END
Large-flowered skullcap ¹	Scutellaria montana	THR
Chaffseed ²	Schwalbea americana	END
Virginia spiraea	Spiraea virginiana	THR

Status codes: C = Candidate; END = Endangered; THR = Threatened.

¹Federally listed plant species documented from the ROWs where work would occur.

²Federally listed species occurring within the county where work would occur, but not within 5 miles of the project area.

The federally listed large-flowered skullcap has been documented from the ROW of the Sequoyah-Widows Creek 500-kV (ID: 2) transmission line and the surrounding forests. According to the TVA Natural Heritage database, the most recent survey of the site was a 2002 visit when one individual plant was observed in the transmission line ROW. The large-flowered skullcap plant documented from the ROW is likely an aberrant and ephemeral individual; it is widely accepted that the preferred habitat for the species is forest (NatureServe 2009; USFWS 2002; Bridges1984). The state-listed rose-gentian and fame-flower have also been observed along the Sequoyah-Widows Creek 500-kV ROW. Two separate occurrences of rose-gentian have been documented along the transmission line. The species preference for open areas suggests that more occurrences of the species likely occur along the ROW, which provides one of the largest sources of consistently open habitat in that section of the Cumberland Plateau. Rose-gentian is endemic to the Cumberland Plateau and adjacent foothills of the Ridge and Valley physiographic province and is considered rare and imperiled across its range (NatureServe 2009).

During a 2008 botanical survey of the Widows Creek-Oglethorpe #2 and #3 161-kV (ID: 4 and ID: 5) transmission line ROWs, TVA botanists observed multiple, previously unreported occurrences of state-listed species. Yellow giant-hyssop (two occurrences), dwarf larkspur, Dutchman's breeches, American columbo, Barrens St. Johnswort, and Eggleston's violet were all observed in portions of the ROW underlain by limestone-derived soils. With exception of Dutchman's breeches, which was found in a spanned section of ROW with a forest overstory, all species occurred in open parts of the ROW dominated by herbaceous species. Between 500 and 1000 Small's stonecrop were estimated to occur in an area of exposed sandstone along the ROW. All occurrences of state-listed species observed along the Widows Creek-Oglethorpe #2 and #3 161-kV transmission lines appeared healthy and viable, and all have been exposed to periodic vegetation clearing associated with ROW maintenance.

One population of fame-flower was also observed along the Widows Creek-Raccoon Mountain #2 161-kV (ID: 3) transmission line ROW. This occurrence contained about 100 plants and was last observed in 2004.

Habitat for the majority of the species listed in Table 4-3 and Appendix O (Table O-2) potentially occurs in the subject transmission line ROWs. Rare plant species that inhabit forested areas may occur in the spanned sections of ROW where woody vegetation has not been removed and species capable of occupying open areas with higher light conditions could inhabit multiple locations along the ROW. TVA botanists would perform appropriately timed field surveys for federally and state-listed plant species along the affected ROWs before any upgrading or maintenance activities begin.

4.6.2.2. Environmental Consequences

No Action Alternative

Under the No Action Alternative, the existing transmission lines would not be reenergized or upgraded, and methods used to manage vegetation along the ROWs and maintain transmission infrastructure would be unchanged. Aerial application of herbicide would continue to be prohibited in areas where federally listed and state-listed species occur or potentially occur in existing ROWs. Known locations of rare plants would also continue to be avoided during routine maintenance of transmission infrastructure. Therefore, adoption of the No Action Alternative would have no significant impacts on endangered, threatened, and rare plant species.

Action Alternative

Under the Action Alternative, the proposed upgrades to the transmission lines would require some level of vegetation disturbance on existing ROWs. Federally listed and state-listed species have been previously documented along small portions of these ROWs. It is reasonably likely that additional listed species would be identified in the project area during the appropriately timed botanical surveys that would be conducted prior to any ground-disturbing work. During these surveys, all sites where species have been previously reported would be resurveyed to determine if the rare species are still present and the full extent of the plants in the ROW. If, after botanical surveys, rare plants are identified in the project area, the following mitigation measures would be used to reduce or eliminate impacts to the species:

 Areas with federally listed plant species would be included in the transmission line and access road engineering design specification drawings used during the planning and implementation of the upgrades. TVA botanists would help fence these areas to ensure construction crews would avoid the sites. Depending on the species present,

Final Supplemental Environmental Impact Statement

273

construction may be timed so work takes place during the dormant season when plants are less likely to be harmed by construction. Any new structures would be placed to avoid impacting these areas. Additionally, access roads and the associated vehicle traffic would be excluded from these areas.

Areas where state-listed species occur in the project area would be avoided unless there
is no practical alternative. Avoidance measures would be comparable to those used for
federally listed plants.

Any federally listed or state-listed plant species observed during field surveys most likely occupy either relatively undisturbed, spanned portions of ROW where woody vegetation has not been cleared, or areas where vegetation is maintained regularly to ensure that woody species do not interfere with the transmission lines. The proposed actions would not require clearing in areas that are currently spanned. Thus, with the implementation of the above mitigation measures, the habitat where listed species occur would not be appreciably different under the Action Alternative. Therefore, the proposed actions under the Action Alternative are not likely to adversely affect federally listed species and would not significantly impact state-listed species.

4.6.3. Wildlife

4.6.3.1. Affected Environment

The TVA Natural Heritage database indicated that three federally listed terrestrial animal species (gray bat, Indiana bat, red-cockaded woodpecker), one federally protected bird (bald eagle), and 14 state-listed terrestrial animal species have been reported within 3 miles of the subject ROWs (Table 4-4 and Appendix O, Table O-3). Populations of six uncommon species tracked by the Alabama or Tennessee Natural Heritage Programs were also reported (Table 4-5). No designated Critical Habitat for terrestrial animals occurs within the ROWs of the subject transmission lines.

Table 4-4.Federally Listed Terrestrial Animals Reported From Jackson,
Limestone, and Morgan Counties, Alabama; Dade, Catoosa,
and Walker Counties, Georgia; and Bedford, Coffee, Hamilton,
Marion, and Sequatchie Counties, Tennessee

Common Name	Scientific Name	Federal Status	
Birds			
Bald eagle	Haliaeetus leucocephalus	_1	
Red-cockaded woodpecker	Picoides borealis	LE	
Mammals			
Gray bat	Myotis grisescens	LE	
Indiana bat	Myotis sodalis	LE	

Status abbreviation: LE = Listed Endangered

¹Federally protected by the Bald and Golden Eagle Protection Act

Table 4-5.Number of Federally Listed or State-Listed Species of Terrestrial Animals,
Caves, and Migratory Bird Aggregations Within 3 Miles of Each
Transmission Line Associated With the Action Alternative

Transmission Line Identification Number	Number of Federal Species ¹	Number of State Species (Tracked Species ²)	Number of Caves Within 3 Miles	Number of Migratory Bird Aggregations Within 3 Miles
1 ·	2	3 (1)	10	0
10	0	1 (1)	6	0
11	0	0 (0)	0	0
4, 5	2	4 (2)	39	2
3	3	7 (3)	27	3
7	2	0 (1)	115	2
2	3	8 (3)	16	10
9	. 1	3 (0)	11	3
6, 8	1	0 (2)	69	1

¹Includes federally protected species (i.e., bald eagle)

²Species tracked by Alabama, Georgia, or Tennessee State Natural Heritage Programs

Gray bats roost in caves year-round and typically forage over streams, rivers, and reservoirs. Foraging habitat exists along the Tennessee River and associated riparian corridors throughout the project area. Numerous populations of gray bats exist throughout the region. The closest known occurrence of gray bats is approximately 0.25 mile from the Widows Creek-Raccoon Mountain #2 161-kv (ID: 3) transmission line. A second population is reported 0.5 mile from the Wartrace-N. Tullahoma Tap 161-kV (ID: 1) transmission line. Numerous caves occur in the vicinity of the existing transmission line corridors and offer potential gray bat roosting habitat (Table 4-5). However, gray bats have not been reported from these caves.

Indiana bats roost in caves during the winter and typically roost under the bark of dead or dying trees during the summer (Menzel et al. 2001). Optimal summer roosts occur in forests with an open understory and available roost trees, usually near water (Romme et al. 1995). Indiana bats forage primarily in forested habitats. The closest record of Indiana bats occurs in a cave approximately 1.1 mile from Sequoyah-Widows Creek 500-kV (ID: 2) transmission line. Although no other records of Indiana bats occur in the project area, other caves may provide suitable hibernacula⁸, and mature forested habitat in the area provides suitable summer habitat for this species.

Habitat for red-cockaded woodpecker consists of open, mature pine woodlands, and rarely deciduous or mixed pine-hardwoods located near pine woodlands. Optimal habitat is characterized as a broad savanna with a scattered canopy of large pines and a dense groundcover containing a diversity of grass, forb, and shrub species, historically maintained by fire. Nesting and roosting occur in tree cavities (USFWS 1980). Historical records for red-cockaded woodpecker exist in Walker County, Georgia, approximately 1.8 miles from the Widows Creek-Oglethorpe #3 161-kV (ID: 5) transmission line. Suitable habitat does not exist within the transmission line ROWs. The species is thought to be extirpated from Walker County, and does not exist in the ROWs.

Bald eagles were removed from the endangered species list in June 2007, but are still protected by *Migratory Bird Treaty Act* and the *Bald and Golden Eagle Protection Act*. This species

⁸ Hibernacula are places, e.g., caves or other protected areas, where bats hibernate during the winter.

Final Supplemental Environmental Impact Statement

275

typically nests near large bodies of waters including lakes, rivers, and riparian wetlands. Bald eagles are fairly common within the region, especially near the Tennessee River. Bald eagles are vulnerable to disturbance during courtship, nest building, egg laying, incubation, and brooding. The closest active bald eagle nest is located at Raccoon Mountain Pumped Storage Facility, less than 0.12 mile from a transmission line ROW. Nesting and foraging habitat exists near (less than 0.5 mile) portions of the existing ROWs.

Barking tree frogs occur in wetlands, and a population is known from New Hope, Tennessee. This record is approximately 2 miles northwest of the closest associated transmission line ROW for Sequoyah-Widows Creek 500-kV (ID: 2) transmission line. Emergent wetlands within the ROW may offer moderately suitable habitat for this species.

Green salamanders primarily inhabit shaded rock outcrops in moist forests between 500 and 1,300 meters in elevation. Breeding females require cool, clean, and moist horizontal crevices or narrow chambers in which to suspend their eggs from an overhead substrate (NatureServe 2009). This habitat is abundant along the numerous stretches of escarpment along the Cumberland Plateau and Sand and Lookout mountains in the area. Records for green salamander exist within 3 miles of five different transmission lines: Widows Creek-Raccoon Mountain #2 161-kV (ID: 3); Widows Creek-Oglethorpe #2 161-kV (ID: 4); Widows Creek-Oglethorpe #3 161-kV (ID: 5); Widows Creek-Bellefonte #2 500-kV (ID: 8); and Bellefonte-East Point 500-kV (ID: 9).

Hellbenders inhabit medium-sized to large free-flowing streams in the Tennessee and Cumberland River drainages. Inhabited streams possess large rocks or logs that provide shelter and breeding sites. Records for hellbender are located in Morgan County, Alabama, and Bedford and Marion counties, Tennessee. Limited suitable habitat exists within the project area.

Tennessee cave salamanders occur in caves with streams free of sedimentation (Cooper 1968). One known locality exists approximately 0.5 mile away from the closest transmission line, the Wartrace-N. Tullahoma Tap 161-kV (ID: 1). There also are historical records of this salamander from Nickajack Cave before it was flooded by Nickajack Reservoir. Suitable habitat still exists in portions of Nickajack Cave beyond the influence of the reservoir. Suitable habitat for this species does not exist within the power line corridors.

Bachman's sparrows inhabit early successional, old field habitat that contains a high density of grasses and forbs, scattered trees and shrubs with an open understory (Dunning and Watts 1990). Although this species uses the beginning stages of early successional habitat, this habitat only remains suitable for a short time. The species may temporarily use early successional habitats along the existing transmission line ROWs within the project area as they are periodically cleared.

Cerulean warblers have been reported from Marion County, Tennessee, within 3 miles of the Widows Creek-Raccoon Mountain #2 161-kV (ID: 3) transmission line. The species occurs largely in contiguous, mature deciduous forests, particularly along floodplains or along moist ridge tops. Mature forest adjacent to existing ROWs within the project area may provide habitat for this species. With the possible exception of the forested portions of ROWs on steep hillsides, suitable habitat for this species does not exist within project ROWs.

Ospreys typically nest along rivers, lakes, and reservoirs. The species nests in trees or on manmade structures (i.e., transmission towers, channel markers, bridges, mooring cells) within or over water (NatureServe 2009). Ospreys nest throughout the study area, primarily along the Tennessee River.

Peregrine falcons have been reported from the ROWs of the subject transmission lines area. The species typically nests on exposed cliffs in undisturbed areas, near water, and close to plentiful prey (Burleigh 1958). Suitable habitat for peregrine falcons exists along exposed escarpment on Sand, Lookout, and Cumberland mountains.

The subject ROWs are located within the northern edge of the breeding range of Swainson's warbler, a neotropical songbird. Breeding habitat for this species ranges from deciduous floodplain and swamp forests to moist lower slopes of mountain ravines at elevations to 900 meters. Swainson's warblers typically require areas with deep shade from both canopy and understory cover (NatureServe 2009). The species has been reported along Lookout Creek, near Chattanooga, Tennessee. Suitable habitat for this species within the existing ROWs is unlikely.

Allegheny woodrats occur in rocky bluffs, caves, and other rocky habitats (Whitaker and Hamilton 1998). Numerous caves and small rock outcrops within the project area provide suitable habitat for this species.

Common shrews occupy most terrestrial habitats excluding areas with very little or no vegetation. Thick leaf litter in damp forests may represent favored habitat, although this species appears adaptable to major successional disturbances. Suitable habitat is abundant both within the project area and throughout the region.

Eastern big-eared bats roost in caves, abandoned buildings, or in hollow trees. The species has been reported from a cave in Marion County, Tennessee, that is greater than 1 mile from a ROW. Other caves in the project area offer suitable habitat for big-eared bats.

Eastern small-footed bats roost in rock crevices, caves, bridges, and other rocky habitats. The species has been reported from Nickajack Cave in Marion, Tennessee. Although no other records of eastern small-footed bats occur in the project area, caves in the project area provide suitable habitat for the species.

4.6.3.2. Environmental Consequences

No Action Alternative

Under the No Action Alternative, no impacts to federally listed or state-listed terrestrial animal species would occur as a result of the proposed transmission infrastructure upgrades. Under this alternative, the existing transmission lines would not be upgraded, and the methods used to manage vegetation along the ROW and maintain transmission infrastructure would be unchanged. Routine maintenance would continue.

Action Alternative

Under the Action Alternative, the proposed upgrades to the transmission lines would require some level of disturbance on existing ROWs. Federally listed and state-listed species and their habitat have been previously documented near some ROWs. Listed terrestrial animal species could be identified in the project area during field surveys associated with future maintenance and upgrading activities. If listed terrestrial animals or their associated habitat are observed in the existing ROWs, the following mitigation measures would be used to reduce or eliminate impacts to listed species:

- Depending on the species present, timing restrictions on construction may be implemented. For example, work may be timed to take place outside of the breeding season (such as for nesting bald eagles or ospreys) when species are less likely disturbed by the activity.
- Buffers may be placed around suitable habitat restricting clearing activities within a
 protective radius (e.g., a 200-foot radius around cave openings, hand clearing only).

The proposed project would not require clearing in areas that are currently spanned. Any listed terrestrial animal species identified within these forested ROWs would not be impacted. With implementation of the above mitigation measures, the habitat where listed species occur would not be appreciably different after upgrading takes place. Therefore, the proposed actions under the Action Alternative are not likely to adversely affect federally or state-listed species.

Prior to energizing the transmission lines associated with BLN, TVA will investigate presence of osprey nests on substation and transmission line structures in the BLN project area. Should nests exist, they would be removed to insure that ospreys are not harmed when the transmission lines are energized. Removal of these nests would be coordinated with the USFWS and/or the U.S. Department of Agriculture, Animal and Plant Health Information Service (APHIS). Removal would be conducted outside the breeding/nesting periods (March – July). Impacts to ospreys are considered insignificant given the abundance of nesting habitat around the BLN site.

4.7. Wetlands

4.7.1. Affected Environment

Wetland areas are likely located within the length of the transmission line corridors proposed to transmit power from the BLN site (Figure 2-15). These corridors cross a landscape dominated by agricultural fields and scattered residential, commercial, and industrial properties between prominent ridge lines, river valleys, associated tributaries, and wetland floodplain complexes. These corridors cross five large-scale watersheds (Guntersville Reservoir, Chickamauga Reservoir, Duck River, Sequatchie River, and Wheeler Reservoir) and 37 local watersheds, all within the Tennessee River Basin. The wetland areas located within these watersheds provide necessary wetland functions for flood abatement, sediment retention, pollutant absorption, and wildlife habitat. The transmission lines proposed for upgrade cross the following significant wetland floodplain complexes: Round Island Creek and associated tributaries, Poe Branch, Chickamauga Creek, Raccoon Creek, Glover Creek, Mud Creek, and Robinson Creek. Based on NWI Data, Soil Survey Geographic Data (USDA-NRCS 2009), USGS topographic maps, and aerial photography, a conservative estimate of 150 acres of potential wetland area occurs on the ROWs proposed for upgrade activities. Because of previous and ongoing ROW maintenance, the majority of wetland habitat within the transmission line corridor, previously mapped or unmapped, would be comprised of emergent or scrub-shrub habitat. Forested wetlands potentially occur along the edges of the ROWs.

Actual wetland acreage within the ROWs will be confirmed and delineated by field surveys prior to upgrades that have the potential to impact wetlands within the ROWs. Wetland delineations would be performed according to USACE standards (Environmental Laboratory 1987), which require documentation of hydrophytic (i.e., wet site) vegetation (USFWS 1996), hydric soil, and wetland hydrology (Environmental Laboratory 1987; Reed 1997; U.S. Department of Defense and EPA 2003). Broader definitions of wetlands, such as provided in EO 11990 (Protection of Wetlands), Alabama state regulations, the USFWS (Cowardin et al. 1979), and the TVA

Environmental Review Procedures (TVA 1983b) would also be considered in making the delineations.

4.7.2. Environmental Consequences

Activities in wetlands are regulated under Sections 401 and 404 of the CWA and are addressed by EO 11990. In order to conduct specific activities in jurisdictional wetlands, authorization would be obtained under a Section 404 Permit from the USACE and under Section 401 from the respective state regulatory agency. In addition, proposed activities would comply with EO 11990, which requires all federal agencies to minimize the destruction, loss, or degradation of wetlands and to preserve and enhance the natural and beneficial values of wetlands in carrying out their responsibilities.

No Action Alternative

Under the No Action alternative, current ROW maintenance and operations of the subject transmission lines would continue. However, no alterations or improvements would be made to the existing transmission lines for the purpose of transmitting power generated from BLN. Therefore, no additional direct, indirect, or cumulative effects to wetlands would occur under this alternative.

Action Alternative

Under the Action Alternative, initial improvements to upgrade approximately 222 miles of existing transmission lines would take place. This would include some reestablishment of ROW vegetation management, filling associated with structure replacement, and vehicular access along the ROWs. Any improvement activities conducted within a wetland would be performed under specific wetland BMPs (TVA 1992) to minimize wetland impacts. This includes conducting work in dry conditions, use of low ground pressure equipment or ground mats, broadcast spray of herbicides approved for aquatic environments, installation of silt fence as needed, and reseeding disturbed areas with native wetland species. Ongoing maintenance would be conducted using similar BMPs and measures to protect wetlands and conserve wetland functions.

Prior to all proposed upgrade activities, TVA would conduct a ground survey to determine the exact extent of any wetland areas located within the corridors proposed for upgrade. Based on this review, specific measures may be implemented to ensure no significant impacts or loss of wetland function occurs as a result of the transmission line upgrade activities. These commitments would result in avoidance strategies, minimization measures, or mitigation should wetland functions be compromised. Mitigation would be provided if substantial quality and quantity of forested wetland would be cleared to accommodate a wider ROW, if fill is proposed for switching-station construction, or for any other activity that reduces the functional capacity of a specific wetland. BMPs would be in place for upgrade activities, and ground surveys would take place to identify wetland areas where avoidance, minimization, or mitigation measures would be required. Therefore, no significant impacts to potentially affected wetland areas within the ROWs are anticipated from the transmission line upgrades.

4.8. Floodplains

4.8.1. Affected Environment

The transmission line routes cross numerous 100-year floodplain areas in several counties in Alabama, Tennessee, and Georgia. The 161-kV and 500-kV switchyards existing on the BLN site are located on the Town Creek embayment side. With respect to Town Creek, the 100-year floodplain is the area lying below elevation 601.4 feet msl. The Flood Risk Profile (FRP)

elevation is 603.1 feet msl. The FRP is used to control flood damageable development for TVA projects, and residential and commercial development on TVA lands. At this location, the FRP elevation is equal to the 500-year flood elevation. The existing switchyards are located outside of the 100-year floodplain and above the FRP elevation.

4.8.2. Environmental Consequences

No Action Alternative

Under the No Action Alternative, the proposed switchyards and transmission lines would not be reenergized or upgraded. Methods used to manage vegetation along the ROWs and maintain transmission infrastructure would be unchanged, and routine maintenance would continue. Therefore, no additional effects to floodplains are likely.

Action Alternative

Consistent with EO 11988, an overhead transmission line and related support structures are considered to be a repetitive action in the 100-year floodplain. Activities conducted within existing switchyards would occur outside the 100-year floodplain. If any new substations, switchyards, or other support facilities need to be constructed to support these transmission lines they would be evaluated prior to construction to ensure compliance with EO 11988. Therefore, any activities occurring in the substations would be consistent with EO 11988 and floodplains would not be affected.

4.9. Natural Areas

4.9.1. Affected Environment

A review of the TVA Natural Heritage database indicated that the transmission lines proposed for reenergizing or upgrading would cover 11 counties in three states, and the lines are within 3 miles of, or cross, 68 natural areas and three Nationwide Rivers Inventory (NRI) streams.

This section addresses natural areas that are crossed by, immediately adjacent to, or within 3 miles of BLN associated transmission line upgrades. Natural areas include managed areas, ecologically significant sites, and streams listed on the NRI.

- Managed areas include lands held in public ownership that are managed by an entity (e.g., TVA, U.S. Department of Agriculture Forest Service (USFS), State of Tennessee, Jackson County) to protect and maintain certain ecological and/or recreational features.
- Ecologically significant sites are either tracts of privately owned land that are recognized by resource biologists as having significant environmental resources or identified tracts on TVA lands that are ecologically significant but not specifically managed by TVA's Natural Areas Program.
- Streams listed on the NRI are free-flowing segments of rivers recognized by the National Park Service (NPS) as possessing remarkable natural or cultural values.

Nine managed areas and ecologically significant sites and two NRI-listed streams are crossed by the existing transmission lines proposed for upgrades associated with operation of a single nuclear unit at the BLN site and are described below. Two NRI-listed streams are within 3 miles of the proposed transmission line upgrades and are described below. The remaining 58 natural areas located within 3 miles of the proposed transmission line upgrades/actions are listed in Table 4-6 by transmission line ID number or grouping of transmission line ID numbers within nearest proximity.

Line ID Number	Natural Area	Steward	Distance from Line (miles)
10, 11	Mallard Fox Creek State Wildlife Management Area (WMA)	ADCNR	0.7 west
	Swan Creek State WMA	ADCNR	1.7 east
1 () () () () () () () () () (· · · · · · · · · · · · · · · · · · ·		
4, 5, 9	Bellefonte Island TVA Small Wild Area (SWA)	TVA	1.2 west
	Mud Creek State WMA	ADCNR	1.6 west
,	Crow Creek Refuge State WMA	ADCNR	0.4 west
<u> </u>	Chickamauga and Chattanooga National Military Park	NPS	0.6 southeast and northeast
	Glades and Barrens of Chickamauga Battlefield	NPS	2.1 southeast
· · ·	Lulu Falls/Eagle Cliff Potential National Natural Landmark (PNNL)	NPS	0.57 south
6, 8	Neversink Pit PNNL	NPS	0.5 east
	Robinson Spring PNNL	NPS	1.1 west
	Section Bluff TVA SWA	TVA	2.6 south
	Tumbling Rock Cave PNNL	NPS	2.4 west
)			*
3	Bill McNabb Gulf	Ecologically significant site on Tennessee River Gorge Lands*	2.5 northwest
	Blowing Springs Branch. Chesnutt Bridge Protection Planning Site (PPS)	Ecologically significant site on Tennessee River Gorge Lands*	2.2 northwest
	Bluff Point /Hicks Mountain	Ecologically significant site on Tennessee River Gorge Lands*	0.62 north
	Cummings Lake	Ecologically significant site on Tennessee River Gorge Lands*	1.05 north
	Ellis Spring	Ecologically significant site on Tennessee River Gorge Lands*	2.1 north
	Hicks Gap Designated State Natural Area (SNA)	TDEC	1.1 west
	Huff Branch TVA Habitat Protection Area (HPA)	TVA	0.74 north
	Kelly's Ferry Slopes	Tennessee River Gorge Trust	1.06 west
	Lassiter Property	Tennessee River Gorge Trust	1.5 north
	Nickajack River State Mussel Sanctuary	TWRA	1.9 northwes
	Parker Gap Cove	Ecologically significant site on Tennessee River Gorge Lands*	2.6 north
	Piney Branch Bottomland	Ecologically significant site on Tennessee River Gorge Lands*	1.4 northwest
	Pot Point	Tennessee River Gorge Trust	1.1 north
	Renfro Property	Tennessee River Gorge Trust	0.4 north
	Shortleaf Pine Flat PPS	Ecologically significant site on USFS lands*	1.55 northwest

Table 4-6.Natural Areas Within 3.0 Miles of the Transmission Lines Proposed for
Reenergizing or Upgrade

Line ID Number	Natural Area	Steward	Distance from Line (miles)
2	Chickamauga State WMA	TWRA	2.1 north
	Chigger Point TVA HPA	TVA	1.18 east
	Cumberland Trail State Park	Tennessee State Parks	3.0 east, 0.1 north
	Dry Creek Ravine	Ecologically significant site on Tennessee River Gorge Lands*	2.6 east
	Hamilton County Park	Hamilton County	2.3 south
	Harrison Bay State Recreation Park	TDEC	1.44 south
-	Little Cedar Mountain TVA SWA/HPA	TVA	1.14 east
	Marion Bridge TVA HPA	TVA	1.9 west
	Marion County Park	Marion County	1.4 southeas
	Mile 434 Oaks	Ecologically significant site on Tennessee River Gorge Lands*	2.7 east
	Montlake/Walden Ridge PNNL	NPS	0.2 northeas
	Nickajack Cave TVA HPA	TVA	0.1 east
	Nickajack Cave State Wildlife Observation Area (WOA)	TVA/TWRA	0.1 east
	Nickajack Oak Wetland and TVA HPA	TVA	0.1 west
	North Chickamauga Creek Pocket Wilderness	Bowaters Paper Company Southern	0.2 north
	Prentice Cooper State Forest	USFS	0.8 east
	Pryor Property	Tennessee River Gorge Trust	1.2 east
	Sequatchie Cave Designated SNA	TDEC	2.5 west
	Shellmound Road Bluff TVA HPA	TVA	1.7 south
	Smith Property	Tennessee River Gorge Trust	0.6 east
	Soddy Creek and TVA HPA	TVA	1.8 north
	Tennessee River Blueway	TVA	0.3 east
	Ware Branch Bend TVA HPA	TVA	2.4 north
	University of Tennessee Friendship Forest	University of Tennessee Forestry Experiment Station	1.4 east
4			
1	Normandy State WMA	TWRA	0.4 northeas
	Bedford State Fishing Lake	TWRA	1.4 northeas
	Rutledge Falls	Tennessee River Gorge Trust	2.4 east
	Short Springs Designated SNA	TDEC	0.5 south
	Short Springs TVA SWA	TVA	0.65 southeast
	Yell Cave	Ecologically significant site on private land*	0.36 northeast

*ESS sites occur on the lands identified but are not managed by these entities.

Guntersville Reservoir State Mussel Sanctuary is crossed by a segment of the Sequoyah-Widows Creek 500-kV (ID: 2) transmission line at the section of the reservoir located in Marion County, Tennessee. The mussel sanctuary extends from the section of the Tennessee River from Nickajack Dam (TRM 424.7) downstream to the Tennessee-Alabama state line (TRM 416.5) and is designated as a sanctuary in which the taking of aquatic mollusks by any means, and/or the destruction of their habitat is prohibited at all times. This mussel sanctuary is managed by the Tennessee Wildlife Resources Agency (TWRA) Region III office.

Coon Gulf TVA Small Wild Area (SWA) is located in Jackson County, Alabama, approximately 1.0 mile northeast of BLN property boundary and is crossed by a segment of the Bellefonte-East Point 500-kV (ID: 9) transmission line. Coon Gulf SWA comprises approximately 2,366 acres managed by TVA and features a forested cove on Guntersville Reservoir. Coon Gulf provides habitat for federally listed and state-listed endangered species.

Raccoon Creek State Wildlife Management Area (WMA) is located in Jackson County, Alabama, approximately 3.0 miles northeast of BLN property boundary and is crossed by a segment of the Bellefonte-East Point 500-kV (ID: 9) transmission line. Raccoon Creek WMA comprises approximately 7,080 acres managed by ADCNR Division of Wildlife and Freshwater Fisheries for waterfowl and small game hunting.

Crow Creek State WMA is located in Jackson County, Alabama, approximately 1.8 miles north of Cedar Grove and is crossed by a segment of the Widows Creek-Bellefonte #1 500-kV (ID: 6) transmission line. Crow Creek WMA comprises 2,161 acres managed by ADCNR Division of Wildlife and Freshwater Fisheries for waterfowl and small game hunting.

Raccoon Mountain Pumped Storage State Wildlife Observation Area (WOA) is located in Marion County, Tennessee, approximately 3.0 miles west of Chattanooga and is crossed by a segment of the Widows Creek-Raccoon Mountain #2 161-kV (ID: 3) transmission line. Raccoon Mountain WOA comprises approximately 860 acres managed by TVA in cooperation with TWRA. This large pumped-storage lake on top of Raccoon Mountain is surrounded by mature forests and open areas and provides habitat for many bird species, including wintering bald eagles, hawks, falcons, common loons, and vultures.

Tennessee River Gorge is located in Marion and Hamilton counties, Tennessee, approximately 5.0 miles west of Chattanooga. The southern edge of the Tennessee River Gorge boundary is crossed by a segment of the Widows Creek-Raccoon Mountain #2 161-kV (ID: 3) transmission line. The protected area of the Tennessee River Gorge comprises 16,777 acres of the total 27,000-acre gorge. This gorge is the fourth largest canyon in the eastern United States. This ecologically significant site is managed by The Tennessee River Gorge Trust and has an unusually concentrated diversity of land forms and provides habitat for several varieties of plants, ferns, trees, grasses, and flowers, as well as a rich wildlife population. There are federally listed plant and animal species located throughout the gorge.

Grant Property is located in Marion County, Tennessee, approximately 5.0 miles southwest of Chattanooga within the boundary of the Tennessee River Gorge. The southern edge of the Grant Property is crossed by a segment of the Widows Creek-Raccoon Mountain #2 (ID: 3) transmission line. This area is owned in fee by the Tennessee River Gorge Trust in cooperation with the University of Tennessee-Chattanooga for research purposes. The Grant Property comprises approximately 888 acres and contains wooded slopes, mixed mesophytic forest and cove hardwood forest, with land forms characterized by karst topography exhibiting numerous sinkholes and caves. There are federally listed plant and animal species located on the property.

North Chickamauga Creek Gorge and Designated State Natural Area is located in Hamilton County, Tennessee, approximately 7.0 miles west of SQN and is crossed by the Sequoyah-Widows Creek 500-kV (ID: 2) transmission line. The North Chickamauga Creek Gorge consists

Final Supplemental Environmental Impact Statement

of approximately 39,000 acres, and the Designated State Natural Area comprises approximately 3,700 acres of the total acreage. This area is managed by the Tennessee Department of Environment and Conservation (TDEC) in cooperation with the North Chickamauga Creek Conservancy, and includes a rugged steep gorge cut by Chickamauga Creek into a sandstone plateau. River-side shoals and stream bars provide habitat for several listed plants.

Duck River State Mussel Sanctuary is located in Bedford and Coffee counties, Tennessee, and is crossed by the Wartrace-N. Tullahoma tap (ID: 1) at the section of Normandy Reservoir Reservation. The mussel sanctuary, managed by TWRA, extends from Kettle Mills Dam (Duck River Mile 105.6) upstream to the headwaters of the Duck River, including the section impounded by Normandy Dam

The Sequatchie River, an NRI-listed stream, is located in Marion and Sequatchie counties, Tennessee. The Sequatchie River Mile (SRM) 0, its confluence with Tennessee River, to SRM 109 in its headwaters approximately 10 miles south of Homestead is the segment listed on the NRI. This segment is crossed at six locations by the Sequoyah-Widows Creek 500-kV (ID: 2) transmission line proposed for upgrades associated with BLN site operations. The NPS recognizes this 109-mile segment for its scenic, recreational, geologic, fish, and wildlife values, and it is noted as a clean, pastoral float stream that flows through a narrow scenic valley. The first crossing point of the river north of the BLN site is located approximately 0.4 miles north of the town of Ebenezer and west of State Route 27. The second stream crossing occurs 2.07 miles east of Nickletown and west of State Route 27. The third stream crossing occurs at 1.8 miles northeast of Nickletown and west of State Route 27. The fourth, fifth, and sixth stream crossings occur north of the town of Oak Grove at 0.4 mile, 0.8 mile, and 1.6 miles, respectively.

The segment of the North Chickamauga River located in Hamilton and Sequatchie counties, Tennessee, from SRM 13 (its confluence with Falling Water Creek southeast of Falling Water) to SRM 31 (the headwaters north of Lone Oak) is listed on the NRI. This river is crossed at two locations by the existing Sequoyah-Widows Creek 500-kV (ID: 2) transmission line proposed for upgrades associated with BLN site operations. The NPS recognizes this 18-mile segment for its scenic, recreational, geologic, fish, wildlife, historical, and cultural values, and it is noted as a spring-fed, crystal clear mountain stream featuring a variety of flora and an abundance of wildlife. The first crossing point of the river north of the BLN site is located approximately 3.7 miles north of the town of Fairmont on the Sequatchie and Hamilton county line. The second stream crossing occurs approximately 0.5 mile northeast of the town of Mile Straight at Dayton Pike Road.

Little Sequatchie River, located in Marion County, Tennessee, is designated as an NRI-listed stream from river mile 0, at the confluence with the Sequatchie River, to river mile 25 near the headwaters west of Palmer. This stream is located approximately 1.2 miles west of the Sequoyah-Widows Creek 500-kV (ID: 2) transmission line proposed for upgrades associated with BLN site operations. The NPS recognizes this 25-mile segment for its scenic, recreational, fish, and wildlife values, and it is noted as a scenic stream that supports game fishery.

4.9.2. Environmental Consequences

No Action Alternative

Under the No Action Alternative, no alterations or improvements would be made to existing facilities for the purpose of nuclear power generation including associated upgrades of transmission lines. Methods used to manage vegetation along the ROWs and maintain

transmission infrastructure would be unchanged, and routine maintenance would continue. Therefore, there would be no additional effects to natural areas under this alternative.

Action Alternative

Nine natural areas and two NRI streams crossed by the transmission lines would be directly affected by disturbance of vegetation within the area and at stream crossings from heavy equipment associated with the upgrades. Activities necessary to upgrade transmission lines are short term and occur on existing ROW with no new clearing beyond the ROW. BMPs and other routine measures would be implemented to mitigate impacts. Managers of the natural areas crossed by the transmission lines would be notified prior to beginning proposed work. Because the proposed work is confined to existing ROW and because appropriate BMPs would be implemented, direct impacts to natural areas crossed by the transmission lines to natural areas crossed by the transmission lines would be minor. The other natural areas listed in Table 4-6 would not be directly or indirectly affected. Impacts associated with implementation of this alternative would not result in cumulative adverse impacts to natural areas.

4.10. Recreation

4.10.1. Affected Environment

Some low-density dispersed recreation activity such as hunting or wildlife observation may currently take place within these existing transmission line corridors. Two developed recreation areas occur adjacent to the transmission line corridors. A segment of the Sequoyah-Widows Creek 500-kV (ID: 2) transmission line crosses Nickajack Dam Reservation and passes within a few hundred feet of a boat ramp and fishing berm on the right bank and a fishing pier on the left bank below the dam. The Wartrace-N. Tullahoma 161-kV (ID: 1) transmission line crosses Normandy Dam Reservation and passes within 200 feet of Duck River access facilities maintained by TVA as part of the reservation.

4.10.2. Environmental Consequences

No Action Alternative

Methods used to manage vegetation along the ROWs and maintain transmission infrastructure would be unchanged, and routine maintenance would continue. Routine maintenance of these transmission lines and ROWs would have minor impacts on any informal recreation use or developed recreation within the area, and no mitigation would be required.

Action Alternative

Minor impacts on informal and developed recreation could occur during routine maintenance of lines and ROWs, as described in the No Action Alternative. Actions related to upgrading these transmission lines and ROWs could have a minor affect on any informal recreation use that currently occurs. Because these lines already exist and do not directly cross over developed recreation facilities on Nickajack and Normandy Reservations, any impacts on developed recreation facilities should be minor. Further, any impacts on dispersed recreation should be negligible and no mitigation required.

4.11. Land Use

4.11.1. Affected Environment

The transmission lines that would be upgraded cross land with a wide variety of land uses: agriculture, residential, commercial, and forest.

4.11.2. Environmental Consequences

No Action Alternative

Methods used to manage vegetation along the ROWs and maintain transmission infrastructure would be unchanged, and routine maintenance would continue. However, no additional changes in land use would occur under the No Action Alternative.

Action Alternative

Some temporary disruption of some land uses particularly agriculture could occur during upgrade activities. TVA would appropriately compensate land owners for any damage including damage to growing crops. Under this alternative, upgrades to transmission lines in the existing ROWs would not change any existing land use.

4.12. Visual Resources

4.12.1. Affected Environment

The physical, biological, and man-made features seen in the landscape provide any selected geographic area with particular visual qualities and aesthetic character. The varied combinations of natural features and human alterations that shape landscape character also help define their scenic importance. The presence or absence of these features along with aesthetic attributes such as uniqueness, variety, pattern, vividness, and contrast make the visual resources of an area identifiable and distinct. The scenic value of these resources is based on human perceptions of intrinsic beauty as expressed in the forms, colors, textures, and visual composition seen in each landscape.

The existing transmission line routes traverse a variety of topography through several counties in Alabama, Tennessee, and Georgia. The existing 161-kV and 500-kV switchyards are located on the BLN site. The existing transmission lines and associated structures can be seen in the foreground distance (within 0.5 mile of the observer), middleground distance (between 0.5 and 4 miles), and background distance (4 miles to the horizon) by area residents and motorists along local roads. In some areas, views of the transmission lines and structures provide discordant contrast when seen as a focal point and standing alone. In other areas, the line route is visually similar to other transmission structures seen in the landscape.

4.12.2. Environmental Consequences

No Action Alternative

Under the No Action Alternative, the existing switchyards and transmission line ROWs would not be upgraded. Methods used to manage vegetation along the ROWs and maintain transmission infrastructure would be unchanged, and routine maintenance would continue. Thus, there would be no change in visual character, and visual resources would not be affected.

Action Alternative

Under the Action Alternative, the existing switchyards and transmission lines would be upgraded. For residents along Town Creek near BLN, upgrade of the existing switchyards and transmission lines would be visually insignificant. Views of the upgrades would be visually similar to existing views residents now have from foreground distances.

For residents, motorists, and lake-users along the existing line routes, most visual impacts would be temporary and minor. These groups would likely notice an increase in traffic and personnel along local roads and access roads. New conductors, structures, and height

Final Supplemental Environmental Impact Statement

extensions would add to the number of discordantly contrasting elements seen in the landscape. Visual impacts would likely decrease as viewing positions increase, in distance, from the transmission line upgrades. Details of views from background distances tend to merge into broader patterns and details become weak.

Upgrades to the transmission line route would require some limited reclearing of vegetation. These activities could include the use of heavy machinery and would increase the number of personnel seen in the area. These minor visual obtrusions would be temporary until the existing ROW and laydown areas have been restored through the use of TVA standard BMPs (Muncy 1999). Any nighttime lighting required would be temporary during the upgrade period and would be insignificant. There may be some minor visual discord during the upgrade period due to an increase in personnel and equipment and the use of laydown and materials storage areas. This would be temporary until all activities are complete.

4.13. Archaeological Resources and Historic Structures

4.13.1. Affected Environment

TVA's procedure for reviewing the operations and maintenance of transmission lines is called a Sensitive Area Review (SAR) (see Appendix D). Under this review procedure, all transmission line corridors, where routine operation and maintenance occur, are reviewed by TVA Cultural Resource staff for the potential to effect historic properties on or eligible for the National Register of Historic Places (NRHP). The regulatory guidance for the SAR concerning cultural resources is the same guidance for all cultural resource assessments: 36 CFR Part 800. Prior to conducting specific upgrades and other activities along the ROWs, TVA would determine the need for consultation with the respective State Historical Preservation Officer (SHPO) and, if needed, define an APE in coordination with the SHPO. That requirement would range from no investigations (area already surveyed) to resurvey (if past surveys were not deemed sufficient) to site avoidance, data recovery, or monitoring if a previously or newly identified cultural resource within the APE was determined eligible or potentially eligible for inclusion in the NRHP.

The archaeological record of the Tennessee River valley has documented five major prehistoric occupational periods that began with the Paleo-Indian (14,000 to 8000 B.C.); the Archaic (8000 to 900 B.C.); the Woodland (900 B.C to A.D. 1000); the Mississippian (A.D. 1000 to 1630); and Historic (1630 to present) periods. Prehistoric land use and settlement patterns vary during each period, but short- and long-term habitation sites are generally located on floodplains and alluvial terraces along rivers and tributaries. Specialized campsites tend to be located on older alluvial terraces and in the uplands. European interactions with Native Americans in this area began in the 17th and 18th centuries. European settlements vary throughout the regions in this study, but in general, Euro-American settlement increased in the early 19th century as the Historic tribes were forced to give up their land. Sites belonging to each period are differently distributed in the landscape of Tennessee, Alabama, and Georgia, but generally, habitation sites are found on floodplains and alluvial terraces along rivers and alluvial terraces along rivers and tributaries campsites tend to be found on older alluvial terraces along rivers and tributaries, while specialized campsites tend to be found on older alluvial terraces along rivers and tributaries.

For the proposed transmission line upgrades associated with construction of a single BLN unit, the archaeological APE is all lands upon which the existing transmission line would be upgraded and includes all associated infrastructure, including the transmission line ROW, access roads, and staging areas. The APE for architectural studies includes a 0.8-kilometer (0.5-mile) buffer surrounding the subject transmission line ROWs.

Based on available data of previously recorded cultural resources, 25 archaeological sites are located within the APE. One of these sites located in Alabama (1MG785) is no longer extant. Seven sites, all located in Alabama (1MG116, 1MG115, 1MG667, 1MG758, 1MG757, 1JA304, 1JA694), were previously determined not eligible for inclusion on the NRHP. Two sites, one in Alabama (1MG735) and one in Georgia (9WA164) have been previously determined potentially eligible for the NRHP. The remaining 15 sites in Alabama (1JA637, 1JA650, 1JA453, 1JA452, 1JA304, 1JA377, 1JA518, 1JA532, 1JA524, 1JA617, 1JA558) and Tennessee (40MI246, 40MI247, 40HA0089, 40MI248) have not been assessed for NRHP eligibility. In Alabama, one previously recorded historic district (the City of Bridgeport) falls within the architectural APE. A portion (8 percent, 2.5 miles) of one transmission line proposed for upgrading, the Widows Creek-Oglethorpe #3 161-kV (ID: 5), has been subjected to a systematic cultural resources survey (Cleveland et al. 1995). This cultural resource survey identified one NRHP-eligible historic archaeological site (9WA164), one eligible Historic District (Happy Valley Farms in Walker County, Georgia) and two eligible historic structures (WA-WA-114 and WA-WA-642).

4.13.2. Environmental Consequences

No Action Alternative

Under the No Action Alternative, the transmission line upgrades would not take place, and there would be no additional impacts to cultural resources from ongoing maintenance of existing transmission lines and ROWs.

Action Alternative

Portions of the transmission line ROWs proposed for upgrading are located in areas having a potential for archaeological resources. In addition, 17 previously recorded archaeological sites have been determined eligible or have not been assessed for eligibility for the NRHP. Under the Action Alternative, the upgrade of the existing transmission lines and the construction and/or use of associated infrastructure (e.g., access roads, laydown areas) have the potential to affect archaeological resources located within the APE that may be eligible for the NRHP. The placement of new structures or project-related clearing within the existing transmission line ROW could potentially have a visual effect on historic structures eligible for the NRHP.

In letters dated September 10, 2009, TVA initiated consultation with the Tennessee, Alabama, and Georgia SHPOs regarding the proposed transmission line upgrades. Should the Action Alternative be selected, pursuant to Section 106 of the NHPA and its implementing regulations at 36 CFR Part 800 TVA would conduct surveys to better identify and evaluate historic properties (archaeological sites, historic structures, and historic sites) eligible for listing in the NRHP. The cultural resources investigations would be guided by MOAs with Georgia SHPO (executed April 29, 2010) and Alabama SHPO (pending). Instead of an entering into an MOA, the Tennessee SHPO has requested that TVA follow procedures to conduct a phased identification and evaluation of historic properties pursuant to 36 CFR Part 800.4(b)(2).

4.14. Socioeconomics

Socioeconomics is the combination of social and economic factors related to the proposed action. Socioeconomic impacts may be positive, such as increased income, or negative, such as traffic congestion or temporary increases in demand for medical services.

4.14.1. Affected Environment

The transmission lines proposed for upgrades associated with operations of the BLN site would cover 11 counties in three states, as shown in Figure 2-15.

4.14.2. Environmental Consequences

No Action Alternative

Methods used to manage vegetation along the ROWs and maintain transmission infrastructure would be unchanged, and routine maintenance would continue. Selection of the No Action Alternative would not affect local socioeconomic conditions because there would be essentially no change in current conditions.

Action Alternative

The actions required to reenergize the existing 500-kV lines and switchyard are discussed in the CLWR FEIS (DOE 1999), Subsection 5.2.3.9.1; the Conversion FEIS (TVA 1997); Subsection 4.2.18.2; and the COLA ER (TVA 2008a), Subsection 3.7.2.2. The transmission upgrades and refurbishments would be a small piece of the total construction effort for BLN, accounting for only a small share of expenditures and employment. In addition, as discussed in Subsection 2.6.2, these activities would be confined to the existing transmission line ROWs. Therefore, these impacts are considered to be minor.

Post-construction effects of reenergizing the 500-kV line and switchyard are discussed in the CLWR FEIS (DOE 1999), Subsection 5.2.3.9.1, and the Conversion FEIS (TVA 1997), Subsection 4.2.18.2. They are also discussed in the COLA ER (TVA 2008a), Subsections 5.8.1.4 and 5.6.3. Measures would be undertaken (see Subsection 2.6.2) to prevent or mitigate induced electric current and noise impacts, and to minimize public exposure to electric and magnetic fields. Therefore, these potential impacts are considered to be minor and insignificant.

4.15. Environmental Justice

4.15.1. Affected Environment

Environmental justice implies that low-income or minority populations will not incur a disproportionate share of adverse effects. Environmental justice analysis is mandated by EO 12898 Federal Actions to Address Environmental Justice in Minority Populations and Low-Income Populations. TVA is not subject to this EO, but it assesses the impact of its actions on minority communities and low-income populations in the NEPA process as a matter of policy.

4.15.2. Environmental Consequences

No Action Alternative

Under the No Action Alternative there would be no upgrades to the subject transmission lines. Methods used to manage vegetation along the ROWs and maintain transmission infrastructure would be unchanged, and routine maintenance would continue. There would be no impacts on businesses, industries, and residences in the area. Therefore, no significant disproportionate impacts to low-income or minority populations would occur under this alternative.

Action Alternative

All work would involve existing facilities and ROWs. No businesses, industries, and residences in the area not already affected by the existing transmission system would be affected beyond the minor and temporary effects. Therefore, no significant disproportionate impacts to low-income or minority populations would occur should the Action Alternative be implemented.

4.16. **Operational Impacts**

4.16.1. Electric and Magnetic Fields

4.16.1.1. Affected Environment

Transmission lines, like all other types of electrical wiring, generate both electric and magnetic fields (EMF). The voltage on the conductors of the transmission line generates an electric field that occupies the space between the conductors and other conducting objects such as the ground, transmission line structures, or vegetation. A magnetic field is generated by the current (i.e., the movement of electrons) in the conductors. The strength of the magnetic field depends on the current, design of the line, and distance from the line.

The fields from a transmission line are reduced by mutual interference of the electrons that flow around and along the conductors and between the conductors. The result is dissipation of the already low energy. Most of this energy is dissipated on the ROW, and the residual very low amount is reduced to background levels near the ROW or energized equipment.

Magnetic fields can induce currents in conducting objects. Electric fields can create static charges in ungrounded, conducting materials. The strength of the induced current or charge under a transmission line varies with (1) the strength of the electric or magnetic field, (2) the size and shape of the conducting object, and (3) whether the conducting object is grounded. Induced currents and charges can cause shocks under certain conditions by making contact with objects in an electric or magnetic field.

The transmission lines subject to upgrades, like other transmission lines, have been designed to minimize the potential for such shocks. This is done, in part, by maintaining sufficient clearance between the conductors and objects on the ground. Stationary conducting objects, such as metal fences, pipelines, and highway guard rails that are near enough to the transmission line to develop a charge would be grounded by TVA to prevent them from being a source of shocks.

Under certain weather conditions, high-voltage transmission lines, such as 500-kV and 161-kV lines, may produce an audible low-volume hissing or crackling noise. This noise is generated by the corona resulting from the dissipation of energy and heat as high voltage is applied to a small area. Under normal conditions, corona-generated noise is not audible. The noise may be audible under some wet conditions, and the resulting noise level off the ROW would be well below the levels that can produce interference with speech. Corona is not associated with any adverse health effects in humans or livestock.

Other public interests and concerns have included potential interference with AM radio reception, television reception, satellite television, and implanted medical devices. If interference occurs with radio or television reception, it would be due to unusual failures of power line insulators or a poor alignment of the radio or television antenna and the signal source. Both conditions are correctable and would be repaired if reported to TVA.

Implanted medical devices historically had a potential for power equipment strong-field interference when they came within the influence of low-frequency, high-energy workplace exposure. However, the older devices and designs (i.e., more than five to 10 years old) have been replaced with different designs and different shielding that eliminate the potential for interference from external field sources up to and including the most powerful magnetic resonance imaging medical scanners. Unlike high-energy radio frequency devices that can still interfere with implanted medical devices, low-frequency, and low-energy powered electric or

Final Supplemental Environmental Impact Statement

290

magnetic devices no longer potentially interfere (Journal of the American Medical Association 2007).

Research has been done on the effects of EMF on animal and plant behavior, growth, breeding, development, reproduction, and production. This research has been conducted in the laboratory and under environmental conditions, and no adverse effects on health or the above considerations have been reported for the low-energy power frequency fields (World Health Organization [WHO] 2007a). Effects associated with ungrounded, metallic objects and static charge accumulation and discharge in dairy facilities have been found when the connections from a distribution line meter have not been properly installed on the farm side of a distribution circuit.

There is some public concern as to the potential for adverse health effects that may be related to long-term exposure to EMF. A few studies of this topic have raised questions about cancer and reproductive effects on the basis of biological responses observed in cells or in animals or on associations between surrogate measures of power line fields and certain types of cancer. Research has been ongoing for several decades.

The consensus of scientific panels reviewing this research is that the evidence does not support a cause-and-effect relationship between EMF and any adverse health outcomes (e.g., American Medical Association [AMA] 1994; National Research Council 1997; National Institute of Environmental Health Sciences [NIEHS] 2002). Some research continues of the statistical association between magnetic field exposure and a rare form of childhood leukemia known as acute lymphocytic leukemia. A review of this topic by the WHO (International Association for Research on Cancer 2002) concluded that this association is very weak, and there is inadequate evidence to support any other type of excess cancer risk associated with exposure to EMF.

TVA follows medical and health research related to EMF, along with media coverage and reports that may not have been peer-reviewed by scientists or medical personnel. No controlled laboratory research has demonstrated a cause-and-effect relationship between low-frequency electric or magnetic fields and health effects or adverse health effects even when using field strengths many times higher than those generated by power transmission lines. Statistical studies of overall populations and increased use of low-frequency electric power have found no associations (WHO 2007b).

Neither medical specialists nor physicists have been able to form a testable concept of how these low-frequency, low-energy power fields could cause health effects in the human body where natural processes produce much higher fields. To date, there is no agreement in the scientific or medical research communities as to what, if any, electric or magnetic field parameters might be associated with a potential health effect in a human or animal. There are no scientifically or medically defined safe or unsafe field strengths for low-frequency, low-energy power substation or line fields.

The current and continuing scientific and medical communities' position regarding the research and any potential for health effects from low-frequency power equipment or line fields is that there are no reproducible or conclusive data demonstrating an effect or an adverse health effect from such fields (WHO 2007c). In the United States, national organizations of scientists and medical personnel have recommended no further research on the potential for adverse health effects from such fields (AMA 1994; DOE 1996; NIEHS 1998).

Although no federal standards exist for maximum EMF strengths for transmission lines, two states (New York and Florida) have promulgated EMF regulations. Florida's regulation is the more restrictive of the two, with field levels being limited to 150 milligauss (mG) at the edge of the ROW for lines of 230-kV and less. The expected magnetic field strengths at the edge of the proposed ROW would fall well within these standards.

4.16.1.2. Environmental Consequences

No Action Alternative

Under the No Action Alternative, no new EMFs would be created from the proposed upgrading of the transmission lines; therefore, there would be no impacts to the environment.

Action Alternative

Magnetic fields would continue be produced along the length of the existing 161-kV transmission lines and new magnetic fields would be produced along the length of the reenergized 500-kV lines. The proposed transmission line upgrades would allow the subject line to carry higher current levels as system conditions require. The strength of the magnetic fields within and near the ROW would vary with the electric load on the line as well as with the terrain. Because line voltages would not change, there would be no increase in electric field strength. Some of the proposed upgrades would result in increased line height above ground during most system conditions, thus reducing the electric field levels. Public exposure to EMF would change over time after the line work is completed as adjacent land uses change. No significant impacts from EMF are anticipated from the upgrade, reenergizing, and operation of the transmission lines.

4.16.2. Lightning Strike Hazard

4.16.2.1. Affected Environment

TVA transmission lines are built with overhead ground wires that lead a lightning strike into the ground for dissipation. Thus, a safety zone is created under the ground wires at the top of structures and along the line for at least the width of the ROW. The National Electrical Safety Code is strictly followed when installing, repairing, or upgrading TVA lines or equipment. Transmission line structures are well grounded, and the conductors are insulated from the structure. Therefore, touching a structure supporting a transmission line poses no inherent shock hazard.

4.16.2.2. Environmental Consequences

No Action Alternative

Under the No Action Alternative, no new lighting strike hazards would be created from the proposed upgrading of the transmission lines; therefore, there would be no impacts to the environment.

Action Alternative

Transmission line structures are well grounded, and the conductors are insulated from ground. Therefore, touching a structure supporting a 161-kV transmission line poses no inherent shock hazard. Additionally, TVA transmission lines are built with overhead ground wires that would lead a lightning strike into the ground for dissipation. Thus, a safety zone is created under the ground wires at the top of structures and along a line for at least the width of the ROW. The National Electrical Safety Code is strictly followed when installing, repairing, or upgrading TVA lines or equipment. None of the proposed actions would alter line grounding. Therefore, there would be no additional hazards from lightning strikes.

4.16.3. Noise and Odor

4.16.3.1. Affected Environment

During the proposed upgrade of the transmission lines, equipment would generate noise above ambient levels, for short periods of time. In the more densely populated areas along the ROW, techniques would be used to limit noise as much as possible. In residential areas, the need for periodic ROW vegetation maintenance, i.e., mowing, would be limited or nonexistent.

4.16.3.2. Environmental Consequences

No Action Alternative

Under the No Action Alternative, no new noise and odors would be created from the proposed upgrading of the transmission lines; therefore, there would be no impacts to the environment.

Action Alternative

Because of the general lack of nearby sensitive receptors and the short work period, noiserelated effects are expected to be temporary and insignificant. For similar reasons, noise related to periodic line maintenance is also expected to be insignificant. Upgrading, reenergizing, and operating the lines are not expected to produce any noticeable odors.

Additionally, no significant long-term impacts related to noise are expected as a result of the operation of the transmission lines. None of the proposed upgrades would result in any increase in the potential for noise produced by the lines.

Page intentionally blank

CHAPTER 5

5.0 OTHER EFFECTS

5.1. Unavoidable Adverse Environmental Impacts

This section describes principal unavoidable adverse environmental impacts for which mitigation measures are either considered impractical, do not exist, or cannot entirely eliminate the impact. Specifically, this section considers unavoidable adverse impacts that would occur for either of the Action Alternatives, i.e., completing and operating one partially completed B&W reactor or constructing and operating one Westinghouse AP1000 reactor at the BLN site, in addition to maintaining and operating associated transmission facilities. These unavoidable construction and operational effects are identified in Table 5-1.

Table 5-1. Construction- and Operation-Related Unavoidable Adverse Environmental Impacts

Issue Construction	Unavoidable Adverse Impact
Land Use	The BLN site is approximately 1600 acres in total. Approximately 400 acres of the 1600-acre BLN site were previously disturbed for the partially constructed BLN 1&2 and associated plant structures. Completion of a B&W unit would require reclearing and grading of previously disturbed ground. Construction of an AP1000 unit and associated structures is expected to require clearing and blasting of about 50 acres of forested land, and reclearing and grading of previously disturbed ground. There would be a long-term commitment of land for the existing transmission corridors.
	Potential for unanticipated disturbances to historic, cultural, or paleontological resources is mostly or entirely mitigated.
	Some land would be dedicated to long-term disposal of construction debris and not available for other uses.
	A small amount of water is consumed during construction activities.
Hydrologic & Water Use	Ground-disturbing activities along river banks or stream banks (in the case of the transmission line maintenance), on a short-term basis, introduce minor amounts of sediments and potentially chemicals into water bodies.
Aquatic Ecology	Construction at river's edge may cause direct, short-term, and minor loss of some organisms and temporary degradation of habitat. Existing transmission lines that cross streams may continue to cause minor disruption of some organisms and degradation of habitat.
Terrestrial Ecology	Operation of a BLN unit and transmission corridor would continue minor alterations to habitat and the suite of species which inhabit them. Construction, clearing, and grading of the BLN site could directly harm or displace a few animals. Construction noises may startle or scare animals. These minor impacts are intermittent and would continue throughout the construction phase.
	Construction workers and local residents would be exposed to elevated levels of traffic through the course of the construction phase.
Socioeconomics and Environmental Justice	The influx of construction workforce would cause short-term, minor effects on local housing, infrastructure, land use, and community services such as fire or police protection. In the short-term, there may be school crowding. Increased tax revenue would mitigate much of this impact.
	Construction workers and local residents would be exposed to elevated levels of dust, exhaust emissions, and noise from construction and equipment. These constitute minor unavoidable impacts. No unavoidable adverse construction impacts to minority populations are anticipated.

1

Issue Operational	Unavoidable Adverse Impact
Land Use	The commitment of land use described above would continue over the operational life of this project. Some of the land would be returned to its former state following the end of construction.
	The Uranium Fuel Cycle of a BLN unit would increase radioactive and nonradioactive wastes that would require land to be dedicated for the long-term disposal of hazardous and nonhazardous materials in permitted disposal facilities or permitted landfills. This land would not be available for most other uses.
	The viewscape of the BLN site and transmission facilities would continue to be impacted over the operational period, but no more so than at the present.
	Normal plant operations result in discharge of small amounts of chemicals and radioactive effluents to Guntersville Reservoir throughout the life of a BLN unit. Compliance with the NPDES permit; applicable water quality standards; storm water pollution prevention (SWPPP) and SPCC plans; and discharge of radioactive effluents in compliance with applicable regulatory standards would ensure that the result would be little or no unavoidable adverse impacts.
Hydrologic & Water Use	Discharge of cooling water results in a thermal plume in Guntersville Reservoir throughout the operational life of a BLN unit. The differences between plume temperature and ambient water temperature are maintained within limits set in the NPDES permit. Cooling towers mitigate much of the heat that would otherwise be discharged to the reservoir. Use of closed-cycle cooling would result in only minor adverse impacts.
	Water lost to evaporation represents consumption of water that would not be available for other uses. The maximum consumptive use of surface water, which would continue throughout the operational life of the plant, is less than 1 percent of 7Q10.
	The effects of entrainment or impingement result in a loss of fish and other aquatic species. Because a closed-loop cooling system that substantively reduces the loss of fish and aquatic species is used, the impacts of entrainment or impingement on aquatic species would be minor and insignificant.
Aquatic Ecology	Routine maintenance activities may result in rare episodic chemical or petroleum spills near water that could, in turn, affect aquatic life. Preparation and adherence to the SPCC plan would avoid/minimize contamination from any such spills.
	Although within NPDES permit limits, discharge of small amounts of chemicals to Guntersville Reservoir from outine plant operations could result in minor insignificant effects on aquatic life over the operational life of this project.
	Birds may periodically collide with the cooling towers or the existing transmission lines. Such occurrences are anticipated to be minor.
Terrestrial Ecology	Some minor clearing, maintenance, and upgrading of transmission lines could result in short- term disruption of wildlife, but no long-term changes would be expected from existing habitat conditions.
	Periodic noise, such as maintenance at the site or along the existing transmission line, may cause temporary and minor impacts to nearby wildlife over the operational life of this project.
	Minor unavoidable adverse impacts are expected over the life of operating a unit at BLN.
Socioeconomics	The transmission lines are built in accordance with applicable regulations and codes to minimize the risk of electric shock. However, over the life of the plant, the transmission line has the potential to produce electric shock to people working near the line or from fallen lines.
and Environmental	Operation and outages of a BLN unit would increase traffic on local roads during shift change.
Environmental Justice	Although emissions would be maintained within limits established in permits, air emissions from diesel generators and equipment, and vehicles would have a minor impact on workers and local residents over the operational life of this project.
	Unavoidable adverse operational impacts to minority populations are not expected to occur.

Final Supplemental Environmental Impact Statement

.

Issue – Operational (continued)	Unavoidable Adverse Impact		
Small radiological doses to workers and members of the public from releases to water would occur over the operational life of this project. Releases are well be limits. Effluents are treated according to applicable regulatory standards before discharged into Guntersville Reservoir. While employees are potentially exposi- term, adherence to applicable regulatory standards, radiological safety procedu and safety measures reduce this exposure to a negligible impact.			
Radiological	High-level radioactive spent fuel is stored and isolated from the biosphere for thousands of years. The impacts of high-level radioactive waste and spent fuel are reduced through specific plant design features in conjunction with a waste minimization program. Impacts are further reduced through employee safety training programs and work procedures, and by strict adherence to applicable regulations for storage, treatment, transportation, and ultimate disposal of this waste in a geological repository, or reprocessing. The mitigation measures reduce the risk of radioactive impacts, but there is still some residual risk. Waste disposal constitutes a commitment of land that continues for thousands of years into the future.		
	Low-level radioactive and nonradioactive waste would be stored, treated, and disposed. Disposal of these materials represents a commitment of land for hundreds or thousands of years. The impacts of low-level radioactive and nonradioactive hazardous waste are reduced through waste minimization programs, employee training programs, and strict adherence to work procedures and applicable regulations.		
· · · · · · · · · · · · · · · · · · ·	Diesel generators and equipment would contribute to minor air emissions over the course of this project. Burning of any material associated with maintaining transmission line rights-of way would contribute to short-term air pollution.		
Atmospheric & Meteorological	As described in Chapter 3, minor radioactive emissions would occur from the proposed unit during normal operations. Compliance with permit limits and regulations for installing and operating air emission sources and monitoring of those air emissions would result in little or no adverse impacts.		
	Cooling towers would emit a plume of water vapor resulting in a limited obstructed view of the sky, causing a shadowing effect on the ground that has a small effect on vegetation. The plumes present little environmental effect on humans or biota.		

5.2. Relationship Between Short-Term Uses and Long-Term Productivity of the Human Environment

One of NEPA's basic EIS requirements is to describe "the relationship between local short-term uses of man's environment and the maintenance and enhancement of long-term productivity." Unavoidable adverse impacts of construction and operation are discussed in Section 5.1, and the irreversible and irretrievable commitments of resources are discussed in Section 5.3. This section focuses on and compares the significant short-term benefit (e.g., principally generation of electricity) and uses of environmental resources which have long-term consequences on environmental productivity. Table 5-2 summarizes the proposed action's short-term uses and benefits versus the long-term consequences on environmental productivity. For the purposes of this section, the term "short term" represents the period from start of construction to end of plant life, including prompt decommissioning. In contrast, the term "long-term" represents the period extending beyond the end of plant life, including the period up to and beyond that required for delayed plant decommissioning. This discussion applies to the general ramifications of implementing either Action Alternative.

The short-term beneficial impacts of usage outweigh the adverse impacts on long-term environmental productivity. The principal short-term benefit from a BLN unit would be the production of a relatively clean and stable form of electrical energy. With respect to long-term

benefits, nuclear energy avoids carbon dioxide emissions that may have a significant long-term detrimental effect on global climate. Nuclear energy also reduces the depletion of fossil fuels. Chapter 3 describes effects associated with uranium fuel use. These impacts include radioactive waste, spent fuel storage, and transportation of radioactive materials. Subsection 5.2.2 and Section 5.3 describe the effects of mining and in-situ leaching, conversion, enrichment of uranium, fabrication of nuclear fuel, use of fuel, and disposal of the spent fuel.

There are two key long-term adverse impacts on productivity. Both of these environmental liabilities are governed by the half-lives of the respective radioisotopes. The first involves long-term radioactive contamination of the reactor vessel, equipment, and other material that are exposed to radioactive isotopes. The second involves irradiated fuel and high-level waste that must be safeguarded and isolated from the biosphere for thousands of years, or reprocessed for use as fuel.

5.2.1. Short-Term Uses and Benefits

There are a number of short-term benefits that are derived from construction and operation of a single nuclear generating unit at BLN. These short-term uses and benefits, as summarized below include the following:

- Electricity generation
- Fuel diversity
- Avoidance of air pollution and greenhouse gas emissions
- Land use
- Aquatic and terrestrial biota
- Socioeconomic changes and growth

As described in Chapter 1, the principal short-term benefit of a BLN unit would be the generation of electricity to meet the growing demand for electricity in TVA's power service area. Energy diversity is also an element fundamental to the objective of achieving a reliable and affordable electrical power supply system. Over-reliance on any one fuel source leaves consumers vulnerable to price spikes and supply disruptions. A BLN unit furthers the goal of creating new nuclear base load generating capacity. Operation of a reactor at BLN also advances the Congressional goal of obtaining a diversified mix of electrical generating sources. Upgrading the existing transmission lines would increase the short-term and long-term capacity and reliability of the power supply in TVA's service area.

Natural gas, and in particular, coal-fired electricity generating plants produce substantive amounts of air pollutant emissions. Fossil fuel air emissions, particularly carbon dioxide, are believed by many in the scientific community to contribute to the greenhouse effect and, consequently, global climate change. Beyond steam and water vapor, modern nuclear reactors produce virtually no air emissions during operation, and only very minor levels of radioactive emissions. The generation of significant air emissions is avoided by foregoing construction of a comparably sized coal- or gas-fired alternative, and instead constructing or completing a single unit at BLN. Even with contributions from the UFC, the net benefits of reduced emissions from nuclear over those of natural gas or coal-fired facilities are substantive.

Issue	Short-Term Uses and Benefits	Relationship to Maintenance and Enhancement of Long-Term Environmental Productivity
.Land Use	Continued commitment of land use at the existing site. Some potential loss in agricultural productivity, or natural habitats and woodlands.	No long-term loss as the land could be released for other uses or returned to its natural state after the reactor is decommissioned.
Terrestrial and Aquatic Ecology	Disrupts or destroys some flora and fauna on and near the BLN site, and along the transmission corridor. No significant effect to species or habitats is expected to occur. After construction, some flora and fauna may recover in areas that are no longer affected by construction or plant operations.	No significant long-term detrimental disturbance to biota or their habitats.
Socioeconomic Growth	Injection of tax revenues, plant expenditures, and employee spending contributes to the growth of the local economy. In the short term, this growth may strain local infrastructure and services.	Tax revenues, plant expenditures, and employee spending leads to some long-term direct and secondary growth in the local economy, infrastructure, and services that may continue after the reactors are decommissioned.
Irradiated Spent Fuel	Provides a short-term supply of relatively clean energy.	Managed as a High-Level Radioactive Waste, and either reprocessed or isolated from the biosphere for thousands or tens of thousands of years. Long-terr commitment of the local storage area and the underground geological repository.
Other Radioactive Waste	The radioactively contaminated reactor vessel and equipment are required for the short term production of nuclear energy.	Contaminated waste must be managed and isolate from the biosphere for hundreds or thousands of years.
Potential for Accident	Potential security consequences of a reactor accident could range from small to large. However, the probability or likelihood of a severe accident is deemed to be very remote. Because the probability or likelihood of such an event is so small, the overall risk of a nuclear accident is, likewise, considered to be so small as not to constitute a potentially significant impact upon the human environment.	In the advent of an accident, the impacts could be long-term and substantial.

Table 5-2. Summary of the Proposed Action's Principal Short-Term Benefits Versus the Long-Term Impacts on Productivity

299

Issue	Short-Term Uses and Benefits	Relationship to Maintenance and Enhancement of Long-Term Environmental Productivity
Depletion of Uranium	As a reactor fuel, the uranium provides a short-term supply of relatively clean energy.	Construction and operation of a BLN unit contributes to the long-term cumulative depletion of the global uranium supply.
Offset Usage of Finite Fossil Fuel Supplies	During operation, a BLN unit avoids the consumption of fossil fuels, albeit with some increase in the use of uranium. Consumption of fossil fuels in the UFC is substantively less than would occur for equivalently sized fossil fuel based generation.	Reduces the cumulative long-term depletion of global fossil fuel supplies.
Materials, Energy, and Water	In the short term, the energy used in operating the reactors results in far more electrical power generation than was used in their construction. The use of materials in constructing the BLN is also critical to the goal of producing a clean and reliable supply of electrical power. A relatively modest quantity of cooling water is lost through evaporation and drift.	Construction and operation of a BLN unit contributes to the cumulative long-term irretrievable use of materials, energy, and water used in the construction and operation of the reactors. However, the reactor provides far more energy than is consumed in its construction.
Air Pollution	Operation of a BLN unit avoids air pollutants that would likely be produced by fossil fuel plants if the reactor was not constructed.	Operation of the unit results in a long-term cumulative avoidance of greenhouse emissions that would likely be produced by fossil fuel plants if the unit were not constructed.
Social Changes	The project stimulates economic growth and productivity in the local area. In the short- term, however, this growth may strain local infrastructure and services, resulting in problems such as overcrowding of schools and traffic congestion. However, revenue derived from this project may fund increased infrastructure and social services.	Payments made in lieu of taxes by TVA, and wages spent by the operational staff may inject significant revenues into the local economy that have long- lasting economic growth and development effects, which may continue after a BLN unit is decommissioned. Socioeconomic changes such as transformation in the nature and character of the community likely continue long after a BLN unit has been decommissioned.

1.....

The construction and operation of a single unit at the BLN site would result in the continued commitment of land use at the existing site, as well as for the transmission corridor (i.e., there are not "new" long-term effects on land use within the existing rights-of-way). Land required for the corridor results in the continued loss of some agricultural or pastureland from transmission structures, or undeveloped habitats and woodlands. In the short term, the project results in some potential loss in agricultural productivity, or natural habitats and woodlands. However, this loss does not represent a long-term loss, as the land may be released for other uses or returned to its natural state after the BLN unit has been decommissioned. Construction and operation of a single unit at the BLN site also disrupts or destroys some flora and fauna on and near the site, as does maintenance along the transmission corridor. However, no significant effect to species or habitats is expected to occur. After construction is completed, some flora and fauna may recover in areas that are no longer affected by construction or plant operations.

Construction of a BLN unit is expected to stimulate economic growth and productivity in the local area. Wages spent by workers are expected to provide an economic boost locally and regionally. The construction and operation of a BLN Unit may also spur indirect or secondary socioeconomic growth. In the short-term, however, this growth may strain some local infrastructure and services, resulting in problems such as overcrowding of schools and increased traffic. However, tax revenue derived from this project may fund increased infrastructure and social services. TVA payments made in lieu taxes and wages spent by the operations staff would inject revenue into the local economy that may have long-lasting economic growth and developmental effects. In the long-term, some of this growth may continue even after the unit has been decommissioned. Socioeconomic changes brought about by the operation of the unit may also continue long after the plant has been decommissioned. This increased growth leads to long-term changes in the nature and character of the community that some may regard to be adverse.

5.2.2. Maintenance and Enhancement of Long-Term Environmental Productivity

Potential long-term effects on the productivity of the human environment are described below and summarized in Table 5-2. The assessment of long-term productivity impacts does not include the short-term effects related to construction and operation of a BLN unit.

Some of the adverse environmental impacts may remain after practical measures to avoid or mitigate them have been taken. As described in Chapter 1, the BLN site was originally designated for construction of nuclear reactors; therefore, siting and operating a single nuclear unit there represents a continuation of the originally planned land use of the site. After the reactor is shutdown, and the BLN unit is decommissioned to NRC standards, this land would be available for other industrial or nonindustrial uses. Therefore, land use impacts are not expected to constitute a long-term productivity issue. Similarly, impacts such as air emission, water effluents, and other impacts described in Chapter 3, but not specifically mentioned in this section are insignificant.

Exposure to Hazardous and Radioactive Materials and Waste

Workers may be exposed to low doses of radiation and trace amounts of hazardous materials and waste. Workplace exposures are carefully monitored to ensure that radioactive exposure is within regulatory limits. Local nonworkers also receive a very small incremental dose of radiation. Radiological monitoring and impacts related to operation of a BLN unit are described in Chapter 3. The persistence of radionuclides depends on the half-life of the radionuclides. The doses are in compliance with applicable regulatory standards and permits and do not significantly affect humans, biota, or air or water resources.

Radiological emissions are not expected to contaminate BLN property or the surrounding land. Once the plant ceases to operate and is decommissioned, radiological releases also cease. No future issues associated with the radiological emissions from operation of a nuclear unit are expected to affect the long-term uses of the BLN site.

Potential for Nuclear Accident

The risk of a potential accident is the product of the potential consequences, and the probability or likelihood that an event occurs. The potential consequences of an accident could range between small to large. However, the probability or likelihood of a major accident is very remote. Because the probability or likelihood of such an event is so small, the overall risk of a nuclear accident is likewise so small as not to constitute a potentially significant impact upon the human environment. The results of TVA's analysis in Section 3.19 indicate that the environmental risks due to postulated accidents are exceedingly minor.

Uranium Fuel Cycle and Depletion of Uranium

The principal use of uranium is as a fuel for nuclear power plants. With approximately 440 nuclear reactors operating worldwide, these plants currently produce approximately 16 percent of the world's electrical power generation. Global uranium fuel consumption is increasing as nuclear power generation continues to expand worldwide. A BLN unit would contribute to a small incremental increase in the depletion of uranium. The World Nuclear Association studies uranium supply and demand issues, and states that there is currently a 50-year supply of relatively low-cost uranium. Higher prices are expected to induce increased uranium exploration and production. A doubling in market price from the 2003 level might increase the supply of this resource tenfold. The introduction of fast breeder reactors and other technologies could further reduce the gap between supply and demand.

Offset Usage of Finite Fossil Fuel Supplies

Fossil fuels represent a finite geological deposit, the use of which constitutes a cumulative irreversible commitment of a natural energy resource. The construction and operation of a BLN unit helps offset the cumulative depletion of this limited resource.

Use of Materials, Energy, and Water

Construction and operation of a BLN unit result in the long-term, irreversible use of materials and energy for the construction and operation of the reactors. However, in the short-term, the reactors provide far more energy than is consumed in their construction. A small amount of water is consumed in the construction of a BLN unit. A relatively modest quantity of cooling water is also consumed as loss to the atmosphere through evaporation and drift.

5.3. Irreversible and Irretrievable Commitments of Resources

This section describes anticipated Irreversible and Irretrievable (I&I) commitments of environmental resources that would occur in either the construction and operation of an AP1000 advanced passive reactor, or the completion and operation of a partially completed B&W reactor at the BLN site. The I&I commitments are summarized in Table 5-3 below.

For the purposes of this analysis, the term "irreversible" applies to the commitment of environmental resources (e.g., permanent use of land) that cannot by practical means be reversed to restore the environmental resources to their former state. In contrast, the term "irretrievable" applies to the commitment of material resources (e.g., irradiated steel, petroleum) that, once used, cannot by practical means be recycled or restored for other uses.

Environmental and Material Resource Issues	Irreversible	Irretrievable
Socioeconomic Changes	The project results in both short-term and long-term changes in the population and nature and character of the local community, and the local socioeconomic structure. Some impacts on infrastructure and services are temporary, while other changes represent a permanent and irreversible change in socioeconomic infrastructure.	None
Disposal of Hazardous and Radioactively Contaminated Waste	The generation of radioactive, hazardous, and nonhazardous waste that needs to be disposed. Land committed to the disposal of radioactive and nonradioactive wastes is an irreversible impact because it is committed to that use, and is largely unavailable for other purposes.	None
Commitment of Underground Geological Resources for Disposal of Radioactive Spent Fuel	High-level waste and spent nuclear fuel is isolated from the biosphere for thousands or tens of thousands of years in a deep underground geological repository. This long- term commitment makes the surrounding geological resources unusable for thousands or tens of thousands of years.	None
Destruction of Geological Resources During Uranium Mining and Fuel Cycle	None	Uranium mining can result in contamination and destruction of geological resources, and pollution of lakes, streams, underground aquifers, and the soil.
Contaminated and Irradiated Materials	None	Some of the materials used in the construction of a BLN unit are contaminated or irradiated over the life of the plant. Much of this material is not reused or recycled, and must be isolated from the biosphere for hundreds or thousands of years.
Land Use	None	The range of available land uses for the BLN site and existing transmission line ROW are now restricted for the life of the project and transmission lines, resulting in irretrievable lost production or use of
		renewable resources such as timber, agricultural land, or wildlife habitat during the period the land is used.

Table 5-3. Summary of Irreversible and Irretrievable Commitment of Environmental Resource

Environmental and Material Resource Issues	Irreversible	Irretrievable
Water Consumption	None	Relatively small amounts of potable water are used during construction and operation of a BLN unit. A small fraction of the cooling water taken from Guntersville Reservoir is lost through evaporation. The impact to surface water resources is relatively small, but represents a natural resource that is no longer readily available for use.
Consumption of Energy	None	Nonrenewable energy in the form of fuels (gas, oil, and diesel) and electricity is consumed in construction and to a lesser extent, operation of the BLN.
Consumption of Uranium Fuel	None	A BLN reactor would contribute a relatively small increase in the depletion of uranium that is used to fuel the reactors.

5.3.1. Irreversible Environmental Commitments

Irreversible environmental commitments resulting from the BLN project would relate primarily to those of the UFC: (1) land disposal of equipment and materials contaminated by hazardous and low-level radioactive waste and (2) UFC effects that include commitment of underground geological resources for disposal of high-level radioactive waste and spent fuel, and destruction of geological resources during uranium mining. Implementation of either Action Alternative would also result in both short-term and long-term minor changes in the population, the nature, and character of the local community, and the local socioeconomic infrastructure. Once the unit ceases operations, and the nuclear plant is decontaminated and decommissioned in accordance with NRC requirements, the land that supports the facility may be returned to other industrial or nonindustrial uses. However, the land may continue to be committed to use for other future electrical projects or other purposes.

Uranium Fuel Cycle

The UFC is defined as the total of those options and processes associated with the provision, utilization, and ultimate disposition of fuel for nuclear power reactors. Environmental effects are contributed from uranium mining and milling, the production of uranium hexafluoride, isotopic enrichment, fuel fabrication, use of the fuel, possible future reprocessing of irradiated fuel, transportation of radioactive materials, disposal of used (spent) fuel and management of low-level and high-level wastes.

The BLN unit would generate radioactive, hazardous, and nonhazardous wastes that require disposal. This waste is disposed of in permitted hazardous, mixed, or radioactive landfills or disposal facilities. Land committed to the disposal of radioactive and hazardous wastes represents an irreversible impact because it is committed to that use, and can be used for few other purposes.

Table 5.7-2 in the COLA ER (TVA 2008a) presents environmental data on the UFC. The UFC effects noted in Table 5.7-2 as permanent or comprising emissions for fuel production or storage of spent fuel would be considered irreversible. That ER analysis, which is herein incorporated by reference, described the UFC environmental effects from both a single 1,000-MW nuclear power reactor and two 1,150-MWe units operating at the BLN site. As described in the ER, the approach taken by NRC in estimating effects was intended to ensure that the actual environmental effects were less than the quantities shown for the 1,000 MWe reference plant and to envelope the widest range of operating conditions for light water reactors. That analysis concluded all resource impacts were small (i.e., not detectable or are so minor that they neither destabilize nor noticeably alter any important attribute of the resource). The effects from either of the current Action Alternatives for completing or constructing and operating a single 1,100 MWe unit at the BLN site are bounded by that analysis. As such, impacts would be even less than the two-unit analysis, which concluded only small effects.

5.3.2. Irretrievable Environmental Commitments

Irretrievable environmental commitments resulting from a BLN unit include the following:

- Construction and irradiated materials
- Water consumption
- Consumption of energy
- Consumption of uranium fuel
- Land Use
- Destruction of geological resources during uranium mining and fuel cycle

Construction and Irradiated Materials

Common irretrievable commitments of materials used either for completion of a partially completed B&W reactor (BLN Unit 1 or Unit 2) or construction of an AP1000 reactor include concrete, rebar, structural steel, power cable, small bore piping and large bore piping. A portion of these materials used in the construction of either type of reactor become contaminated or irradiated over the life of BLN operation. Much of this material cannot be reused or recycled, and must be isolated from the biosphere for hundreds or thousands of years. However, because some of this material may be reused (if uncontaminated) or decontaminated for future use, the recycled portion does not constitute an irretrievable commitment of resources. The estimated quantities of materials needed to construct an AP1000 reactor at BLN are concrete (77, 200 cu. yds.), rebar (10,000 T.), structural steel (6,400 T.), power cable(810,000 linear ft.), small bore piping (230,000 linear ft.) and large bore piping (68,000 linear ft.). Because the B&W units are partially complete, proportionally smaller amounts of materials would be needed to complete one of them compared to an AP1000 unit. Additionally, smaller amounts of materials would be required to complete Unit 1 than to complete Unit 2.

While the amount of construction materials is large, use of such quantities in large-scale construction projects such as nuclear reactors, hydroelectric and coal-fired plants, and many large industrial facilities (e.g., refineries and manufacturing plants) represents a relatively small incremental increase in the overall use of such materials. Even if this material is eventually disposed of, use of construction materials in such quantities has a small impact with respect to the national or global consumption of these materials. An additional irretrievable commitment of resources includes materials used during normal plant operations, some of which are recovered or recycled.

Irreversible commitments of resources generally occur through the use of nonrenewable resources that have few or no alternative uses at the termination of the proposed action. Transmission line reconductoring and upgrades also would require the irretrievable commitment of fossil fuels (diesel and gasoline), oils, lubricants, and other consumables used by construction equipment and by workers commuting to the site. Other materials used for construction of the proposed facilities would be committed for the life of the facilities. Some of these materials, such as ceramic insulators and concrete foundations, may be irretrievably committed, while the metals used in conductors, supporting structures, and other equipment could be and would likely be recycled. The useful life of the transmission structures is expected to be at least 60 years.

Water Consumption

Relatively small amounts of potable water are used during construction and operation of a BLN unit. Some of the cooling water taken from Guntersville Reservoir is lost through the cooling towers by way of drift and evaporation. The impact to surface water resources is relatively small, but represents a natural resource that may no longer be available for use. However, as part of the natural hydrologic cycle, this water is eventually recycled through the ecosystem.

Consumption of Energy Used in Constructing the Reactors

Nonrenewable energy in the form of fuels (gas, oil, and diesel) and electricity are consumed in construction and, to a much smaller extent, in the operation of a BLN unit. Beyond ancillary (e.g., vehicles, equipment) usage, nuclear reactors do not consume fossil fuels such as petroleum or coal.

The total amount of energy consumed during construction or operation of a BLN unit is very small in comparison to the total amount consumed within the United States. On net balance, the reactor produces far more energy (as measured in British Thermal Units) than is consumed in its construction and operation. For this reason, one of the key considerations related to the I&I requirement is that operation of a BLN unit helps conserve or helps avoid the consumption of finite fossil fuel supplies.

Uranium Fuel Cycle and Depletion of Uranium

The principal use of uranium is as a fuel for nuclear power plants. With approximately 440 nuclear reactors operating worldwide, these plants currently produce approximately 16 percent of the world's electrical power generation. Global uranium fuel consumption is increasing, as nuclear power generation continues to expand worldwide. A BLN reactor would contribute a relatively small increase in the depletion of uranium. Sources of uranium include primary mine production as well as secondary sources. Nuclear reactor uranium consumption now exceeds the supplies produced through mining. The resulting shortfall has been covered by several secondary sources including excess inventories held by producers, utilities, other fuel cycle participants, reprocessed reactor fuel, and uranium derived from dismantling Russian nuclear weapons.

The limited availability of uranium fuel may affect the future expansion of nuclear power. DOE uranium estimates indicate that sufficient resources exist in the United States to fuel all operating reactors and reactors being planned for the next 10 years at a U3O8 cost (1996 dollars) of \$30.00/lb or less. The resource categories designated as reserves and estimated additional resources can supply these quantities of uranium. The World Nuclear Association studies supply and demand for uranium and states that the world's present measured resources of uranium, in the cost category somewhat above present spot prices and used only in conventional reactors, at current rates of consumption, are sufficient to last for some 70 years. Very little uranium exploration occurred between 1985 and 2005, so the significant increase in exploration that is currently being witnessed might double the known economic reserves. On the basis of analogies with other metal minerals, a doubling in price from present levels could be expected to create about a tenfold increase in measured resources over time. The introduction of fast breeder reactors and other technologies may also reduce the supply-demand gap. The addition of a BLN unit increases worldwide consumption of uranium by about 0.5 percent. Thus, the addition of BLN by itself does not create a significant impact on uranium resources.

5.4. Energy Resources and Conservation Potential

The total amount of energy consumed during construction or operation of the BLN is very small in comparison to the total amount consumed within the United States. On net balance, the reactor would produce far more energy (as measured in British Thermal Units) than would be consumed in its construction and operation. For this reason, one of the key considerations related to the I&I requirement is that operation of a BLN unit helps conserve or helps avoid the consumption of finite fossil fuels supplies.

Nonrenewable energy in the form of fuels (gas, oil, and diesel) and electricity would, however, be consumed in construction and, to a much smaller extent, in the operation of any of the Action Alternatives for the BLN site. An AP1000 reactor would require more offsite fabrication of components, transport of components, and on-site construction, and therefore more energy to build, than completing either the partially built BLN Unit 1 or Unit 2. Because the existing Unit 1 is more complete than Unit 2, of the two units, Unit 1 would require less energy to build.

Beyond ancillary (e.g., vehicles, equipment) usage and that required to support the UFC, nuclear reactors do not consume fossil fuels such as petroleum or coal during operation. Processing of nuclear fuel is, however, an energy-intensive activity. Existing uranium enrichment facilities are large and each facility services several nuclear generating plants. For comparative purposes, the energy required to process or enrich uranium using gaseous diffusion sufficient to fuel a single 1000-MW pressurized boiling water reactor nuclear plant (slightly smaller than the Action Alternatives for a single BLN unit) would be approximately that of the output from a 50-MW fossil-fueled (coal-fired) facility operating at 75 percent capacity factor. Newer technologies (e.g., centrifuge or atomic vapor laser isotope separation) currently, or becoming, commercially available for enrichment, utilize only 4-15 percent as much power as this gaseous diffusion example. As it is anticipated that these new, less energy intensive technologies will eventually become the norm for production of nuclear fuel, the processing portion of the UFC would likely use even less energy and become even more "carbon-friendly" in the future. The DOE has also released the Draft Programmatic EIS for the Global Nuclear Energy Partnership (GNEP) (DOE 2008) with the identified preferred alternative of implementing a "closed" cycle for nuclear fuel management in the United States (i.e., select among nuclear fuel reprocessing alternatives). If selected and implemented by DOE, this approach for GNEP could both expand the availability of nuclear fuel and potentially stabilize or reduce the worldwide GHG releases associated with mining and milling of uranium as a fuel source.

.

Page intentionally blank

. . .

.

CHAPTER 6

6.0 LIST OF PREPARERS

6.1. NEPA Project Management

Amy Burke Henry

Position: Education: Experience:

NEPA Specialist

M.S., Zoology and Wildlife; B.S., Biology 12 years in Biological Surveys, Natural Resources Management Planning, and Environmental Reviews NEPA Compliance and Document Preparation

Involvement:

Ruth M. Horton

Position: Education: Experience:

Involvement:

Anita E. Masters

Position: Education: Experience:

Involvement:

Loretta McNamee

Position: Education: Experience: Involvement:

Charles P. Nicholson Position: Education:

Experience:

Involvement:

Bruce L. Yeager

Position: Education: Experience:

Involvement:

Senior NEPA Specialist B.A., History 30 years in Public Policy and Planning, including 12 years in Environmental Impact Assessment NEPA Project Manager

Senior NEPA Specialist M.S., Biology/Fisheries; B.S., Wildlife Management 22 years in Fisheries Biology/Aquatic Community and Watershed Assessments, Protected Aquatic Species and Habitat Monitoring, and NEPA Compliance NEPA Compliance and Document Preparation

Contract Biologist B.S., Biology 1 year NEPA Compliance Document Preparation and Comment Management

NEPA Program Manager Ph.D., Ecology and Evolutionary Biology; M.S., Wildlife Management; B.S., Wildlife and Fisheries Science 31 years in Zoology, Endangered Species Studies, and NEPA Compliance NEPA Compliance and Document Preparation

NEPA Program Manager

M.S., Zoology (Ecology); B.S., Zoology (Aquatic Ecology) 33 years in Environmental Compliance for Water, Air, and Land Use Planning; Environmental Business Services NEPA Compliance, Climate Change, Other Effects

6.2. Other Contributors

Anne M. Aiken Position: Education:

Experience:

Involvement:

John G. Albright Position: Education:

Experience:

Involvement:

Nolan D. Baier Position: Education: Experience: Involvement:

Jessica M. Baker Position: Education: Experience:

Involvement:

Hugh S. Barger Position: Education: Experience:

Involvement:

John (Bo) T. Baxter Position:

Education: Experience:

Involvement:

Senior Environmental Engineer M.S., Environmental Engineering; B.A., Environmental Studies 19 years in Water Quality and Environmental Engineering

Services

Surface Water and Industrial Wastewater

Civil Engineer B.S., Civil Engineering 29 years in Transmission Line Design/Construction, Fossil Waste Planning and Disposal, Fossil Site and Environmental Design, Fossil and Hydro Environmental Permitting, Fossil Railroad Inspection and Upgrade, Gas Transmission Pipeline Design, NEPA Environmental Reviews Transportation

Senior Specialist B.S., Civil Engineering; MBA 10 years Energy Industry Analytics Need for Power Analysis and Preparer

Resource Planning Specialist M.B.A. and B.B.A., Finance 8 years in Risk Management, Price Forecasting and Long-Term Planning Need for Power

Environmental Engineering Specialist B.S., Engineering 36 years in Transmission Line Planning and Preparation of Environmental Review Documents Project Coordination, Purpose and Need, Description of Alternatives

Specialist, Aquatic Endangered Species Act Permitting and Compliance M.S. and B.S., Zoology 19 years in Protected Aquatic Species Monitoring, Habitat Assessment, and Recovery; 11 years in Environmental Review Aquatic Ecology/Threatened and Endangered Species

Francine Beck Position:

Education: Experience:

Involvement:

Ralph Berger

Education: Experience: Involvement: Technical Specialist, ENERCON Ph.D. and M.A., Geography; B.S. Land Use 3 years in BLN COLA preparation; 9 years in Program Development/Project Management; 6 years in Technical Editing Document Preparation; Contributing Author for AP1000 Information, Socioeconomics, Spent Fuel, and Chemical Additives

Position:

Technical Specialist, ENERCON P.E., Ph.D., M.S. and B.S., Mechanical Engineering 28 years in Nuclear Utility Industry Cooling Tower Plume Impacts, Control Room Habitability, and Severe Accident Consequences

Susan H. Biddle

Position: Education: Experience: Involvement: Senior Manager, Long-Term Resource Planning M.S., Environmental Engineering, B.S., Civil Engineering 14 years in Reservoir Operations and Power Supply Planning Need for Power

Gary S. Brinkworth, P.E. Position:

Education: Experience:

Involvement:

W. Nannette Brodie, CPG

Position: Education: Experience:

Involvement:

Michael G. Browman, P.E. Position: Education:

Experience:

Involvement:

Senior Manager, New Generation and Portfolio Optimization System Planning (Strategy and Business Planning) M.S. and B.S., Electrical Engineering 28 years Electric Utility Experience (System Planning, DSM Analysis, Forecasting, and Rate Analysis) Need for Power, Alternative Energy Sources

Senior Environmental Scientist B.S., Environmental Science; B.S., Geology 14 years in Environmental Analyses, Surface Water Quality, and Groundwater Hydrology Evaluations Groundwater/Surface Water

Environmental Engineer Specialist Ph.D., M.S., and B.S., Soil Science; M.S., Environmental Engineering 27 years in Environmental Control Technology Development and Environmental Impact Analysis Groundwater and Surface Water Resources; Wastewater; Solid and Hazardous Waste

Jennifer M. Call			
Position:	Meteorologist		
Education:	M.S. and B.S., Meteorology/Geosciences		
Experience:	7 years in Meteorological Forecasting, Air Quality Monitorin		
	Data Analysis, and Air Quality Research		
Involvement:	Air Resources		
James S. Chardos			
Position:	Program Manager, Tritium Production, TVA Nuclear, WBN		
Education:	B.S., Physics; Executive MBA		
Experience:	6 years in U.S. Nuclear Submarine Service; 40 years in		
•	Nuclear Plant Project Management		
Involvement:	Site Manager and Plant Technology		
Edward L. Colston			
Position:	Senior Manager, Market & Program Analysis, Energy		
	Efficiency & Demand Response		
Education:	B.S., Mechanical Engineering		
Experience:	31 years in Design, Demonstration, Implementation, and		
	Evaluation of Energy Efficiency and Demand Response		
	Technologies and Programs, as well as Market Research		
Involvement:	Energy Conservation		
nivolvement.			
Patricia B. Cox			
Position:	Botanist, Specialist		
Education:	Ph.D., Botany (Plant Taxonomy and Anatomy); M.S. and		
	B.S., Biology		
Experience:	31 years in Plant Taxonomy at the Academic Level; 6 years in		
	Environmental Assessment and NEPA Compliance		
Involvement:	Threatened and Endangered Species Compliance, Invasive		
	Plant Species, and Terrestrial Ecology		
Elizabeth A. Creel			
Position:	General Manager, Resource Planning		
Education:	B.S., Mathematics		
Experience:	33 years in System Planning and Bulk Power Trading Areas		
Involvement:	Need for Power Review		
mvolvement.	Need for tower neview		
Thomas Cureton Jr.			
Position:	Civil Engineer		
Education:	M.S., Civil Engineering		
Experience:	34 years in Power Plant Design and Inspection and		
	Transmission Line and Substation Siting		
Involvement:	Project and Siting Alternatives		

Final Supplemental Environmental Impact Statement

Adam J. Dattilo Position: Education:

Experience:

Involvement:

Eric J. Davis, C.F.A. Position: Education:

Experience: Involvement:

David C. DeLoach Position: Education:

Experience: Involvement:

Britta P. Dimick Position: Education: Experience:

Involvement:

James H. Eblen Position: Education:

Experience: Involvement:

David A. Hankins

Position: Education: Experience: Involvement:

Michelle S. Harle

Position: Education: Experience: Involvement:

Botanist

M.S., Forestry; B.S., Natural Resource Conservation Management 8 years in Ecological Restoration and Plant Ecology; 5 years in Botany Threatened and Endangered Plant Species, Botany, Plant Ecology, and Invasive Plant Species

Program Manager, Investment Trusts M.B.A., General Management; B.S., Economics and Finance; A.S., Business Administration 10 years in Treasury-Finance Decommissioning

Electrical Engineer B.S., Electrical Engineering 9 years in Bulk Transmission Planning Transmission and Construction Power Supply

Wetlands Biologist M.S., Botany-Wetlands Ecology Emphasis; B.A., Biology 11 years in Wetlands Assessments, Botanical Surveys, Wetlands Regulations, and/or NEPA Compliance Wetlands

Contract Economist

Ph.D., Economics; B.S., Business Administration 41 years in Economic Analysis and Research Socioeconomics and Environmental Justice

Geographic Analyst B.S., Fish and Wildlife Management 29 years in Geographic Information and Engineering GIS Maps

Contract Archaeologist ABD, M.A., B.A. in Anthropology 11 years in Archaeology Cultural Resource Analysis

Heather M. Hart Position: Education:

Experience:

Involvement:

Jeffrey W. Head Position: Education: Experience: Involvement:

Travis Hill Henry Position: Education: Experience:

Involvement:

John M. Higgins, P.E. Position: Education:

Experience:

Involvement:

Paul N. Hopping Position: Education:

Experience: Involvement:

Charles S. Howard Position: Education: Experience:

Involvement:

Nathan D. Jackson Position: Education: Experience:

Involvement:

Contract Natural Areas Biologist M.S., Environmental and Soil Science; B.S., Plant and Soil Science 7 years in Surface Water Quality, Soil and Groundwater

Investigations, and Environmental Reviews Managed Areas

Nuclear Engineer, ENERCON B.S., Nuclear Engineering 2 Years in Nuclear Power Modifications and Analysis Transportation of Radioactive Materials, Atmospheric Dispersion. Radioactive Waste, Gaseous Doses

Terrestrial Endangered Species Specialist M.S., Zoology; B.S., Wildlife Biology 20 years in Zoology, Endangered Species, and NEPA Compliance Terrestrial Ecology, Threatened and Endangered Species

Water Quality Specialist Ph.D., Environmental Engineering; B.S. and M.S., Civil Engineering 36 years in Environmental Engineering and Water Resources Management Surface Water and Wastewater

Technical Specialist Ph.D., Civil and Environmental Engineering; M.S. and B.S, Civil Engineering 26 years in Hydrothermal and Surface Water Analysis Hydrothermal and Surface Water Analysis

Aquatic Endangered Species Biologist M.S., Zoology (Aquatic Ecology); B.S., Biology 17 years in Aquatic Ecology Research, Consulting, and Impact Assessment Specializing in Freshwater Mussels Aquatic Threatened and Endangered Species (Mollusks)

Nuclear Engineer, ENERCON B.S., Nuclear Engineering 1 year in BWR Reactor Engineering, 4 months in Nuclear Power Modifications and Analysis Design Basis Accident Doses, Gaseous Doses

Final Supplemental Environmental Impact Statement

314

Walter M. Justice II Position: Education: Experience:

Involvement:

T A Keys Position: Education:

Experience: Involvement:

Holly G. Le Grand Position: Education: Experience:

Involvement:

Eric D. Loyd Position: Education:

Experience: Involvement:

Robert A. Marker

Position: Education: Experience: Involvement:

Norman M. Meinert, P.E.

Position: Education: Experience:

Involvement:

Roger A. Milstead, P.E.

Position: Education: Experience: Involvement: BLN Site Engineering Manager B.S., Mechanical Engineering 27 years in Commercial Nuclear Power, Engineering, and Analysis B&W Plant Technology

Manager, Nuclear Fuel Supply M.S., Nuclear Engineering; M.S., Engineering Administration; B.S., Physics 32 years in Nuclear Fuel-Related Activities Spent Fuel Storage

Biologist/Zoologist M.S., Wildlife; B.S., Biology 6 years in Biological Surveys, Natural Resource Management, and Environmental Reviews Terrestrial Ecology and Threatened and Endangered Species

Mechanical Engineer, Design B.S., Mechanical Engineering; working toward M.S., Mechanical Engineering 4 years in Mechanical Engineering Performed Hydrothermal Simulations Using CORMIX

Contract Recreation Planner B.S., Outdoor Recreation Resources Management 37 years in Recreation Resources Planning and Management Recreation Resources

Project Manager, ENERCON B.S., Mechanical Engineering 15 years Project Management and 10 years Mechanical Design and Analysis Project oversight and SEIS Review

Program Manager, Flood Risk B.S., Civil Engineering 34 years in Floodplain and Environmental Evaluations Floodplains

Jared Monroe Position: Education:

Involvement:

Experience:

Todd C. Moore Position: Education: Experience:

Involvement:

Joanne Morris Position: Education: Experience: Involvement:

Marvin Morris Position: Education: Experience: Involvement:

Jeffrey W. Munsey Position: Education: Experience:

Involvement:

Duane T. Nakahata Position: Education:

Experience:

Involvement:

Mechanical Engineer, ENERCON B.S., Mechanical Engineering 3 Years in Health Physics, Meteorology, and Mechanical Engineering Routine Doses and Meteorology

Civil Engineering Siting and Environmental M.S. and B.S., Civil Engineering 7 years in Civil Design, 4 years in Fossil Plant Maintenance; 4 years in Transmission Line Siting Transmission Lines

Supervisor Mechanical Engineering, ENERCON M.S., Mechanical Engineering, B.A., Physics 25 years in Nuclear Utility Industry Design Basis Accident Doses, Gaseous Doses, Liquid Doses, and Control Room Habitability

Supervisor Safety Analysis, ENERCON B.S., Mathematics; M.S. Physics 30 years in Nuclear Utility Industry Design Basis Accident Doses, Gaseous Doses, Liquid Doses, Cooling Tower Plume impacts, Transportation, Control Room Habitability, and Severe Accident Consequences

Civil Engineer M.S. and B.S., Geophysics 24 years in Geophysical and Geological Studies and Investigations, including Applications to Environmental Assessments Seismology

Senior Technical Specialist, ENERCON Ph.D., Environmental Engineering; M.S., Nuclear Engineering; B.S., Chemical Engineering 25 years in Thermal-Hydraulic, Nuclear and Radiological Analyses Normal Liquid Doses and Atmospheric Dispersion Factor Analyses

R. Michael Payne

Position: Education: Experience:

Involvement:

W. Chett Peebles, RLA; ASLA

Position: Education: Experience:

Involvement:

Erin E. Pritchard Position: Education: Experience: Involvement:

William L. Raines Position: Education: Experience:

Involvement:

Jerry I. Riggs

Position: Education: Experience: Involvement:

Helen Robertson

Position: Education: Experience:

Involvement:

Rick Rogers Position: Education:

Experience: Involvement: Chemistry Program Manager, Technical Programs Reliability B.S., Chemistry 6 years as Chemistry Program Manager; 4 years as Technical Services Analyst; 10 years as Field Technical Representative to the Chemical, Metals, and Paper Industries Evaluation of Chemical Additives to Raw Water

21 years in Site Planning, Design, and Scenic Resource Management; 4 years in Architectural History and Historic Preservation Visual Resources and Historic Architectural Resources

Specialist, Landscape Architect Bachelor of Landscape Architecture

Archaeologist M.A., Anthropology 10 years in Archaeology and Cultural Resource Management Cultural Resources

Technical Specialist Ph.D., Chemistry (Nuclear/Radiochemistry) 30 years in Radiological Environmental Monitoring and Radioanalytical Analysis Radiological Environmental Monitoring Program

GIS Specialist, ENERCON B.S., Biochemistry; M.A., Geography 5 years Nuclear Utility Industry GIS, Socioeconomic Analysis, and Environmental Justice

Technical Specialist, ENERCON Ph.D., Geography 8 years Geographic Research and Teaching; 7 years Technical Writing, Editing, and Graphic Design Socioeconomic Analysis

Mechanical Engineer, ENERCON B.S., Mechanical Engineering 2 years in Dose Analysis Severe Accident and Design Basis Accident Analyses

Jeffrey W. Simmons

Position: Education: Experience: Involvement:

Thomas E. Spink Position: Education: Experience:

Involvement:

Kim Stapleton

Position: Education: Experience: Involvement:

Andrea L. Sterdis Position:

Education:

Experience:

Involvement:

Kevin M. Stewart

Position: Education: Experience: Involvement:

Jan K. Thomas

Position: Education: Experience:

Involvement:

Aquatic Zoologist M.S., Biology; B.S., Wildlife and Fisheries Science 8 years in Aquatic Species (crayfish, fish, mussels, snails) Aquatic Biology

Licensing Project Manager, Units 3 and 4 M.S. and B.S., Nuclear Engineering 36 years in Nuclear Licensing, Engineering, Quality Assurance, Materials and Project Management, and Power System Planning NGDC Project Manager

Technical Specialist M.S and B.S., Geography 6 years in GIS and Socioeconomics Socioeconomic Analysis

Senior Manager, NGD Project Development and Environmental M.S., Engineering and Public Policy; B.S., Electrical Engineering 29 years in Nuclear Plant Safety Analysis, Licensing, Regulatory, and Engineering; 8 years in Management Bellefonte Project Coordination and Management Review

Water Resources Engineer M.S. and B.S., Civil and Environmental Engineering 7 years in Hydrothermal and Surface Water Analysis Hydrothermal and Surface Water Analysis

Contract Natural Areas Specialist M.S., Human Ecology 11 years in Health and Safety Research, Environmental Restoration, Technical Writing; 6 years in Natural Area Reviews Natural Areas

Rachel E. Turney-Work

Position:	
Education:	
Experience:	

Involvement:

Christopher D. Ungate Position:

Education: Experience: Involvement:

Kenneth G. Wastrack

Position: Education: Experience: Involvement:

Cassandra L. Wylie Position:

Education: Experience:

Involvement:

W. Richard Yarnell Position:

Education: Experience: Involvement: Senior Technical Specialist M.A. and B.A., Geography 8 years in Geography, GIS, Socioeconomic and Land Use Analyses Socioeconomic Analysis

Senior Principal Management Consultant, S&L B.S., M.S., Civil Engineering; MBA 35 years Engineering, Planning, and Consulting Need for Power, Energy Alternatives

Meteorologist M.B.A.; B.S., Meteorology 34 years in Meteorology Tornado Risk and General Meteorology

Atmospheric Analyst M.S., Forestry and Statistics; B.S., Forestry 21 years in Atmospheric Modeling and Effects of Air Pollution on Forests; 9 years in Noise Analysis Noise Impacts

Archaeologist B.S., Environmental Health 38 years, Cultural Resource Management Cultural Resources

Page intentionally blank

CHAPTER 7

7.0 DISTRIBUTION OF FSEIS

7.1. List of Agencies, Organizations, and Persons to Whom Copies of the FSEIS Were Sent and to Whom an E-Link was Provided

Following is a list of agencies, organization, officials, libraries and individuals to whom either published copies (bound or compact disc [CD]) of the FSEIS were provided, or Web links to an active TVA web site from which the document can be accessed were sent. Those names with an asterix (*) received copies of both the FSEIS and DSEIS.

Federal Agencies Receiving the FSEIS (Hard Copy or CD)

Natural Resources Conservation Service, Alabama State Conservationist*

Natural Resources Conservation Service, Georgia State Conservationist*

U.S. Army Corps of Engineers, Mobile District*

U.S. Army Corps of Engineers, Nashville District*

U.S. Army Corps of Engineers, Savannah District*

U.S. Department of the Interior*

U.S. Environmental Protection Agency*

U.S. Fish and Wildlife Service, Cookeville Field Office*

U.S. Fish and Wildlife Service, Daphne Field Office*

U.S. Fish and Wildlife Service, Refuge Office*

U.S. Fish and Wildlife Service, Southeast Region Office*

U.S. Forest Service, Chattahoochee-Oconee National Forests*

U.S. Forest Service, Region 8*

U.S. Nuclear Regulatory Commission*

National Park Service, Chickamauga-Chattanooga National Military Park National Park Service, Southeast Region Office*

State Agencies Receiving the FSEIS (Hard Copy or CD)

<u>Alabama</u>

Alabama Department of Conservation and Natural Resources* Alabama Department of Environmental Management* Alabama Department of Environmental Economic and Community Affairs* Alabama Historical Commission* North-Central Alabama Regional Council of Governments* Top of Alabama Regional Council of Governments*

<u>Georgia</u>

Economic Development Administration* Georgia Department of Natural Resources, Environmental Protection Division* Georgia Department of Natural Resources, Historic Preservation Division* Georgia Department of Natural Resources, Wildlife Resources Division* Georgia State Clearing House*

Tennessee

Southeast Tennessee Development District* South Central Tennessee Development District* Tennessee Department of Economic and Community Development* Tennessee Department of Environment and Conservation, Division of Air Pollution Control*

Tennessee Department of Environment and Conservation, Division of Ground Water Protection* Tennessee Department of Environment and Conservation, Division of Water Supply* Tennessee Department of Environment and Conservation, Resource Management Division* Tennessee Historical Commission* Tennessee Wildlife Resources Agency*

Federally Recognized Tribes (E-mail notification of availability)

Eastern Band of Cherokee Indians* United Keetoowah Band of Cherokee Indians in Oklahoma* Cherokee Nation* Chickasaw Nation* Muscogee (Creek) Nation of Oklahoma* Thlopthlocco Tribal Town* Kialegee Tribal Town* Alabama-Quassarte Tribal Town* Alabama-Coushatta Tribe of Texas* Eastern Shawnee Tribe of Oklahoma* Shawnee Tribe* Absentee Shawnee Tribe of Oklahoma* Seminole Tribe of Florida* Jena Band of Choctaw Indians* Poarch Band of Creek Indians*

Receiving Notification and FSEIS (Hard copy or CD)

David Bednar Jr. Fort Smith, Arkansas

James E. Blackburn Hollywood, Alabama

Faye and Wayne Bynum Scottsboro, Alabama

Henry Cannon Scottsboro, Alabama

Ken Ferrell Scottsboro, Alabama

Professor Paul Friesema Evanston, Illinois

Louise Gorenflo Sierra Club Tennessee Chapter

The Honorable Parker Griffith Alabama State Representative Washington, DC

James Guthrie Scottsboro, Alabama Charles Jones Knoxville, Tennessee

Donald Kennamer Scottsboro, Alabama

Larry E. Kirkland Chamber of Commerce Scottsboro, Alabama

Harley Martin Aliceville, Alabama

B.J. Mitchell Guntersville, Alabama

Garry Morgan Scottsboro, Alabama

Everett Reed Scottsboro, Alabama

Michelle Robertson Scottsboro, Alabama

Goodrich A. Rogers Jackson County EDA Scottsboro, Alabama

Don Safer Tennessee Environmental Council Nashville, Tennessee

James Sandlin Scottsboro, Alabama

Fred L Schaum Alabama Development Office Montgomery, Alabama

Lyle Sosrbee Scottsboro, Alabama

Receiving Notification of Availability

Gary Baran Scottsboro, Alabama

Sara Barczak Southern Alliance for Clean Energy Savannah, Georgia

Mayor Virginia Bergman City of Hollywood, Alabama

Jimmy D. Blevins Scottsboro, Alabama

Ken Bonner Scottsboro, Alabama

Tommy Bryant Stevenson, Alabama

Laura Bundy Fort Payne, Alabama

Jessie W. Craig, I.B.E.W Henagar, Alabama

Wayne Cummins Sand Mountain Concerned Citizens Ider, Alabama

Frank DePinto Chattanooga, Tennessee

Phil Dutton Hollywood City Council Hollywood, Alabama

Daryl Eustace Scottsboro, Alabama William Stiles Scottsboro, Alabama

Louise A. Zeller Blue Ridge Environmental Defense League Glendale Spring, North Carolina

John W. Woodall Scottsboro, Alabama

George W. York Dutton, Alabama

John Gay Scottsboro, Alabama

Stewart Horn New Hope, Alabama

Norman C. Johnson Scottsboro, Alabama

Therrel Jones Scottsboro, Alabama

Frances Lamberts Jonesborough, Tennessee

Jack Livingston Scottsboro, Alabama

Ross McCluney Chattanooga, Tennessee

Robert McMaster Marietta, Georgia

Mike Paris Hollywood, Alabama

The Honorable Melton Potter Mayor of Scottsboro Scottsboro, Alabama

Tereia Sandifer Dutton, Alabama

Shelia Sheppard Jackson County EDA Scottsboro, Alabama

Jimmy R. Spires Scottsboro, Alabama

Gary Spradlin Scottsboro, Alabama

David Thornell Dutton, Alabama

David Trenkle Huntsville, Alabama

Shonda Wall Scottsboro, Alabama Richard Warr Hollywood City Council Hollywood, Alabama

Coleman Wilkinson Scottsboro, Alabama

Tony D. Williams Meridionville, Alabama

Libraries

Scottsboro Public Library Scottsboro, Alabama

Stevenson Public Library Stevenson, Alabama

Lena Cagle Public Library Bridgeport, Alabama

Huntsville-Madison County Public Library Huntsville, Alabama

Decatur Public Library Decatur, Alabama Rainsville Public Library Rainsville, Alabama

Cecil B. Word Learning Center Northeast Alabama Community College Rainsville, Alabama

Beene-Pearson Public Library South Pittsburg, Tennessee

Chattanooga-Hamilton County Public Library Chattanooga, Tennessee

7.2. DSEIS Press Release

TVA

NEWS RELEASE

TVA Seeks Comments on Draft Bellefonte Environmental Statement

SCOTTSBORO, Ala. – TVA will hold an open house Tuesday, Dec. 8, in Scottsboro to receive public comments on the environmental review of alternatives for completing and operating a nuclear reactor at the Bellefonte Nuclear Plant site near Hollywood, Ala.

TVA is asking for public comments on three proposed alternatives outlined in a draft supplemental environmental impact statement -- completing one of the existing units, building a new reactor or taking no action.

The environmental review also addresses transmission improvements required to support electric generation at the Bellefonte site. All transmission work would be on existing rights of way.

In 2007, TVA submitted applications to the Nuclear Regulatory Commission for construction and operation of two advanced technology Westinghouse AP1000 reactors at Bellefonte and is currently studying the feasibility of finishing partially constructed units at the site.

The open house will be held from 4 to 8 p.m. at the Goose Pond Civic Center, 876 Ed Hembree Drive in Scottsboro. During the open house, TVA staff will be available to discuss the alternatives and potential environmental impacts of completing and operating a nuclear unit at Bellefonte.

Under provisions of the National Environmental Policy Act, TVA prepared the draft supplemental environmental impact statement using reports previously prepared for the construction of the units, as well as new information.

Along with the detailed engineering and feasibility study, the environmental review will help TVA decide whether to complete one of the existing unfinished units at the plant or construct a new nuclear unit.

The draft supplemental environmental impact statement is available for review and comment online at www.tva.gov/environment/reports/blnp/index.htm. Comments may also be mailed to Ruth Horton, 400 Summit Hill Drive (WT-11D), Knoxville, TN 37902 or faxed to (865) 632-3451. All written comments must be received by Dec.28.

TVA is the nation's largest public power provider and is completely self-financing. TVA provides power to large industries and 158 power distributors that serve

7.3.

Information Open House Paid Advertisement


Notice of Public Meeting

TVA Open House on Bellefonte Nuclear Site Environmental Statement

TVA will hold an open house in Scottsboro, Alabama, to discuss the draft supplemental environmental impact statement (SEIS) for the possible completion of an existing nuclear unit or construction of a new reactor at Bellefonte Nuclear Plant site.

The public is invited to stop by anytime during the open house to provide comments or ask questions about the draft SEIS. Copies of the document will be available at the open house and are also available on the TVA website at the address below.

Three proposed alternatives are outlined in the draft document: completing one of the existing units, building a new reactor,



or taking no action. The environmental review also addresses transmission system improvements that would be needed on existing rights of way to support power generation at Bellefonte.

Comments about the draft SEIS can be submitted during the open house or anytime before December 28, 2009. These comments will be considered and addressed in the final SEIS. Any comments received, including names and addresses, will become part of the administrative record and will be available for public inspection.

Along with the detailed engineering and feasibility study currently in progress, this environmental review will help TVA decide if one of the alternatives should be selected to meet the growing base-load power demand.

WHAT: Public Open House

DATE: Tuesday, December 8, 2009

TIME: 4 p.m. to 8 p.m. CST

LOCATION: Goose Pond Civic Center 876 Ed Hembree Drive, Scottsboro, Alabama

The draft SEIS was made available for public review on November 4, 2009. It can be viewed and comments submitted at www.tva.gov/environment/reports/blnp. Comments may also be submitted by mail, fax, or e-mail to:

Ruth Horton, Senior NEPA Specialist 400 Summit Hill Dr., WT-11D, Knoxville, TN 37902 865-632-3719 Fax: 865-632-3451 blnp@tva.com

If you have special needs, please call Ruth Horton at least five days prior to the open house. You may also e-mail or call her to request a printed copy of the draft SEIS.

Newpapers That Published the Paid Advertisement

Wednesday, December 2, 2009 Chattanooga Times Free Press Guntersville Advertiser Huntsville Times

<u>Thursday, December 3, 2009</u> Rainesville Weekly Post Scottsboro Daily Sentinel

<u>Friday, December 4, 2009</u> Chattanooga Hamilton County Herald

Monday, December 7, 2009 Stevenson North Jackson Progress

7.4. Open House Handout

Information Open House Final Supplemental Environmental Impact Statement Single Nuclear Unit at the Bellefonte Site Goose Pond Civic Center, Scottsboro, AL December 8, 2009

Meeting Purpose

Thank you for attending our information open house. The purpose of this meeting is to provide the opportunity for you to ask questions about the draft supplemental environmental impact statement (SEIS) and to make comments on TVA's analysis of the potential for environmental effects from completing or constructing, and operating a single nuclear unit at the Bellefonte Nuclear Plant (BLN) site in Jackson County, Alabama.

The following information stations are available to visit in the meeting room:

NEPA Process

- Transmission Upgrades
- Socioeconomics /Air Quality & Meteorology
- Project Description
- Need for Power
- Water Quality
- Nuclear Plant Operation/Nuclear Plant Safety and Security
- Aquatic and Terrestrial Ecology

Under provisions of the National Environmental Policy Act (NEPA), TVA prepared the draft SEIS to supplement and update environmental documents previously prepared for the construction and operation of a nuclear power plant at the Bellefonte site. The TVA Board will use this information along with a detailed engineering and feasibility study currently underway as well as input provided by reviewing agencies and the public to make an informed decision about whether or not to complete an existing nuclear unit or to construct a new reactor. A decision is anticipated in spring 2010.

How to Comment

TVA encourages you to submit comments on the draft SEIS. Please note that to be included in the official project record, comments must be received by TVA during the 45-day comment period that began on November 13, 2009. *Comments must be received no later than December 28, 2009.*

At today's meeting, comments can be made either orally to the court reporter, in writing on the attached comment form, or on TVA's Web site using one of our laptop computers. Comments can also be submitted at any time during the comment period through TVA's Web site, <u>www.tva.gov/blnp</u> by e-mail at <u>blnp@tva.com</u>, by fax to 865-632-3451, or by U.S. mail to the address below. All comments received, including names and addresses, will become part on the administrative record and will be available for public inspection.

Ruth Horton TVA NEPA Compliance 400 West Summit Hill Drive (WT-11D) Knoxville, TN 37902 Using any of these methods, you may also request to be notified of the publication of the Final SEIS on the TVA Web site or to receive a copy of it. The Final SEIS is expected to be available in February 2010.

Proposed Action

TVA proposes to complete or construct, and operate a single approximately 1,100 to 1,200 megawatt (MW) nuclear generating unit at the BLN site. TVA may choose to complete and operate one of the partially constructed Babcock and Wilcox (B&W) pressurized light water reactors, or to construct and operate a new Westinghouse AP1000 advanced pressurized light water reactor (AP1000), or to take no action. Under either of the Action Alternatives, construction activities would incorporate existing facilities and structures and use previously disturbed ground within the BLN site where possible. The existing transmission system would need to be upgraded to prevent overloading while transmitting electricity generated by a new reactor at the BLN site. No new electric transmission lines are proposed.

TVA is making this proposal to meet the need for additional baseload power capacity on the TVA system, maximize the use of existing assets and licensing processes, avoid larger capital expenses by using those existing assets and avoid the environmental impacts of siting and construction new power generating facilities elsewhere. The considerable work that has been accomplished toward licensing the B&W and AP1000 technologies at the BLN site will reduce the time and cost of bringing a single unit on line.

Background

The BLN site is located on a 1,600-acre peninsula on the western shore of Guntersville Reservoir at Tennessee River mile 392, near Hollywood, Alabama.

Construction on the B&W Units 1&2 began in 1974 and continued until 1988 when the Nuclear Regulatory Commission (NRC) granted BLN deferred status. At that time, Unit 1 was approximately 90 percent complete and Unit 2 was approximately 58 percent complete.

BLN Units 1&2 were maintained in deferred status until the project was cancelled and TVA's construction permits were relinquished in 2006. In August 2008, in response to changes in power generation economics, TVA requested reinstatement of the Unit 1&2 construction permits. NRC reinstated the construction permits in March 2009.

Additionally, in 2006 TVA joined NuStart Energy Development, LLC, a consortium consisting of utilities and reactor vendors, with the goal of demonstrating NRC's new combined license application (COLA) process. NuStart chose the BLN site as the demonstration site for the AP1000 technology and TVA submitted a COLA to NRC in October 2007.

TVA forecasts additional baseload generation will be needed in the 2018 to 2020 time frame. Using new nuclear generation will help TVA to meet its goal to have at least 50 percent of its generation portfolio comprised of low- or zero-carbon-emitting sources by the year 2020.

TVA is also currently updating its Integrated Resource Plan (IRP) for future power needs. TVA is proceeding with a decision for new generation at the BLN site because waiting until 2011 for the completion of the IRP before starting evaluation of Bellefonte options could delay availability of baseload generation when needed. Preparing this SEIS for evaluating nuclear options at Bellefonte does not limit the alternatives considered in the IRP.

Fact Sheet

Characteristics		Generation Alternative		
		A – No Action	Alternative B – B&W Unit	Alternative C – AP1000 Unit
Plant Design	Electrical output	Not applicable	At least 1,200 MW	At least 1,100 MW
	Number of fuel assemblies		205	157
	Lifespan		40 years	60 years
	Engineered safety features		Active shutdown and cooling system powered by AC generators.	Passive core cooling system based upon gravity, natural circulation, and compressed gasses.
	Cooling system		Closed-cycle	Closed-cycle
	Ultimate heat sink		Guntersville Reservoir	Atmosphere
Construction	Duration of construction	Not applicable	7.5 years	6.5 years
	Peak on-site workforce		3,015	2,933
	Plant footprint (approximate)	400 acres. Negligible clearing or regrading	400 acres – Minor re- clearing and grading of previously disturbed ground.	585 acres – 185 acres previously undisturbed ground cleared. Minor re-clearing and grading of previously disturbed ground.
	Completion or construction of facilities	No change – routine maintenance.	Activities include: replace steam generators, refurbish or replace instrumentation and various equipment, upgrade barge unloading dock, upgrade cooling tower. No major buildings demolished.	Off-site construction of modules delivered to BLN via barge and completed on site. Several buildings demolished, including turbine building and administration complex.
	Dredging	None	11,100 cubic yards dredged from 1,960 feet of intake channel.	10,000 cubic yards dredged from 1,200 feet of intake channel, and 240 cubic yards from barge unloading dock.
Operation	Typical amount of water withdrawn from Guntersville Reservoir for plant cooling	None withdrawn. Approximately 400,000 gallons per quarter year released.	34,000 gpm ¹ withdrawn 22,650 gpm released	23,953 gpm withdrawn 7,914 gpm released
	Number of on-site staff	200	849	650
	Radiological effects of normal operations	None	Doses to the public from discharge of radioactive effluents would be a small fraction of the dose considered safe by the NRC. (10 CFR Part 50, Appendix I)	
	Number of fuel assemblies needed for 40-year operation	None	2,285	1,821
	Number of containers needed for long-term storage of spent fuel	None	96	76
Cost	Construction	Not applicable	\$3,120 - \$3,360/kWe ²	\$3,300 – \$4,900/kWe
	Operation and maintenance	Not applicable	\$.0132/k5Wh ³	\$.0126/kWh

 1 gpm = gallons per minute 2 kWe = kilowatt electric, i.e. cost per unit of power capacity 3 kWh = kilowatt hour, i.e. cost expressed per unit of power generated

COMMENTS:	
	· · ·
	/
	· · · · · · · · · · · · · · · · · · ·
· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·
	· · · · · · · · · · · · · · · · · · ·
	······································
	· · · · · · · · · · · · · · · · · · ·
· · · · · · · · · · · · · · · · · · ·	
	continued on back
Please fold page alor	ng dotted line before mailing.
	e Bellefonte Site Draft SEIS nent Card
FROM (please print clearly)	
Name Mr./Ms./Mrs.	
Name	TO: Ruth Horton
Name Mr./Ms./Mrs.	TVA NEPA Compliance
Name Mr./Ms./Mrs. Organization:	

Please fold flap along dotted line before mailing and tape.

i

Telephone:

Final Supplemental Environmental Impact Statement

,

Chapter 7

COMMENTS continued:

· · · · · · · · · · · · · · · · · · ·					
· · · · · · · · · · · · · · · · · · ·					
· · ·					
· · · · · · · · · · · · · · · · · · ·					
· · · · · · · · · · · · · · · · · · ·					
I would like to be notified by e-mail or U.S. mail (select one) when the FSEIS is available on the TVA website.					
E-mail address					
For U.S. mail, please provide your name and address on the front side of this comment card					
I would like to receive a printed copy of the FSEIS by U.S. mail.					
I would like to receive a copy of the FSEIS on compact disc by U.S. mail.					

Final Supplemental Environmental Impact Statement

CHAPTER 8

8.0 LITERATURE CITED

- Advanced National Seismic System. 2010. ANSS Catalog Search. Retrieved from http://www.ncedc.org/anss/catalog-search.html (accessed March 25, 2010).
- Alabama Department of Environmental Management (ADEM). 1998. Alabama Department of Environmental Management Permit Rationale, Tennessee Valley Authority Bellefonte Nuclear Plant. Prepared by David Butts, September 9, 1998.
 - —. 2008. 2008 Integrated Water Quality Monitoring & Assessment Report. Retrieved from <http://www.adem.state.al.us/waterdivision/WQuality/305b/WQ305bReport.htm> (accessed October 21, 2009).
- Alabama Department of Industrial Relations. 2010. Jackson County Civilian Labor Force. Retrieved from http://www2.dir.state.al.us/LAUS/CLF/cntybyyear.aspx?area=000071 (accessed April 23, 2010).
- Alabama Department of Transportation (ALDOT). 2006. Five Year Plan (includes Fiscal Years 2006 through 2010). Retrieved from http://www.dot.state.al.us/TransPlanning/FYPlan/> (accessed November 17, 2006).

_____. 2009a. Transportation Planning, Alabama Traffic Monitoring Division, General Information, Construction Bulletin. Retrieved from <http://www.dot.state.al.us/Docs/Bureaus/Transportation+Planning/Traffic+Data/Index. htm> (accessed January 23, 2010).

- ____. 2009b. Five Year Plan (includes Fiscal Years 2008 through 2012). Retrieved from http://cpmsweb2.dot.state.al.us/TransPlan/FiveYearPlan/FiveYearPlan.aspx (accessed January 19, 2010).
- Alabama Invasive Plant Council. 2006. *Alabama's 10 Worst Weeds*. Retrieved from http://www.se-eppc.org/eddMapS/alabama.cfm> (accessed September 1, 2009).
- Algermissen, S. T., and G. A. Bollinger, eds. 1993. *Hazard Assessment.* Monograph 1 presented at the 1993 National Earthquake Conference, Memphis, Tennessee, May 2-5.
- American Medical Association. 1994. "Effects of Electric and Magnetic Fields." Chicago, III.: AMA, Council on Scientific Affairs (December 1994).

American Meteorological Society. 1959. Glossary of Meteorology. Boston, Mass.

- AREVA NP, Inc. 2009a. Representation of the Coolant Reactor System for a Babcock & Wilcox Pressurized Light Water Reactor. Provided by P. Opsal, AREVA NP, Inc.
- ____. 2009b. Bellefonte Plant Site-Specific Seismic Assessment Report: 20004-015. Document No.: 51-9115097-000-Proprietary. August 14, 2009.
- Arkansas Nuclear One (ANO). 2000. Environmental Report, Attachment G, Severe Accident Management Alternatives Analysis.

Final Supplemental Environmental Impact Statement

- Best, T. L., W. S. Cvilikas, A. B. Goebel, T. D. Haas, T. H. Henry, B. A. Milam, L. R. Saidak, and D. P. Thomas. 1995. Foraging Ecology of the Endangered Gray Bat (Myotis grisescens) at Guntersville Reservoir, Alabama. Joint Agency Guntersville Project Aquatic Plant Management.
- Bohac, C. E., and M. J. McCall. 2008. Water Use in the Tennessee Valley for 2005 and Projected Use in 2030. Retrieved from <http://www.tva.gov/river/watersupply/watersupply_report_to_2030.pdf> (accessed October 21, 2009)
- Bridges, E. 1984. Element Stewardship Abstract for *Scutellaria Montana*. Tennessee Natural Heritage Program files. Nashville, Tennessee.

Brown, M. A., J. A. Laitner, S. Chandler, E. D. Kelly, S. Vaidyanathan, V. McKinney, C. Logan, and T. Langer. 2009. "Energy Efficiency in Appalachia: How Much More is Available and at What Cost, and by When?" Appalachian Regional Commission. Prepared by Southeast Energy Alliance in partnership with the Georgia Institute of Technology, American Council for an Energy-Efficient Economy and Alliance to Save Energy. March 2009, revised May 2009. Retrieved from http://www.arc.gov/research/researchreportdetails.asp?REPORT_ID=70 (accessed May 4, 2010).

Brown, M. A., E. Gumerman, X. Sun, Y. Baek, J. Wang, R. Cortes, and D. Soumonni. 2010. "Energy Efficiency in the South." Atlanta, Ga: Southeast Energy Efficiency Alliance. April 12, 2010. Retrieved from <http://www.seealliance.org/se_efficiency_study/full_report_efficiency_in_the_south.pdf> (accessed May 4, 2010).

Burleigh, T. D. 1958. Georgia Birds. Norman, Okla.: University of Oklahoma Press.

- Center for Invasive Plant Management. 2009. Weed Management: Prevention. Retrieved from http://www.weedcenter.org/index.html (accessed September 1, 2009).
- CE-QUAL-W2, 1995. A Two-Dimensional, Laterally Averaged, Hydrodynamic and Water Quality Model, Version 2.0: Users Manual. Edited by T. M. Cole and E. M. Buchak. Vicksburg, Miss.: USACE Waterways Experiment Station, Instruction Report EL-95-1.
- Chandler, S., and M.A. Brown. 2009. "Meta-Review of Efficiency Potential Studies and Their Implications for the South." Georgia Tech, Ivan Allen College, School of Public Policy, Working Paper #51. Atlanta, Ga.: Georgia Institute of Technology. August 2009. Retrieved from http://www.spp.gatech.edu/faculty/workingpapers/wp51.pdf> (accessed May 4, 2010).
- Cleveland, M. T., R. W. Stoops, and J. Holland. 1995. Archaeological and Architectural Surveys for the Proposed Widows Creek-Oglethorpe #3 Transmission Line, Walker County, Georgia. Report submitted to Tennessee Valley Authority, Knoxville, Tennessee, by Garrow and Associates.
- Cooper, J. E. 1968. "The Salamander *Gyrinophilus palleucus* in Georgia, With Notes on Alabama and Tennessee Populations." *Journal of the Alabama Academy of Science* 39:182-185.

Final Supplemental Environmental Impact Statement

- Cowardin, L. M., V. Carter, F. C. Golet, and E. T. LaRoe. 1979. *Classification of Wetland and Deepwater Habitats of the United States.* Washington, D.C.: U.S. Fish and Wildlife Publication FWS/OBS-79/31.
- Christy, J. R. 2009. "Comments on Electric Power Research Institute's 'Potential Impact of Climate Change on Natural Resources in the Tennessee Valley Authority Region'" (November 2009).
- Deter-Wolf, A. 2007. *Phase I Archaeological Survey of 606 Acres at the Bellefonte Nuclear Site, Jackson County, Alabama.* Report submitted to Tennessee Valley Authority, Knoxville, Tennessee, by TRC Inc.
- Dunning, J. B., Jr., and B. D. Watts. 1990. "Regional Differences in Habitat Occupancy by Bachman's Sparrow." *Auk* 107:463-72.
- "EIS No. 20090385, Draft Supplement, TVA, AL, Bellefonte Site Single Nuclear Unit Project, Proposes to Complete or Construct and Operate a Single 1,100–1, 200 MW Nuclear Generation Unit, Jackson County, AL." *Federal Register* 74:58626 (13 November 2009).
- Electric Power Research Institute (EPRI). 2002. *Site Selection and Evaluation Criteria for an Early Site Permit Application.* Palo Alto, California: EPRI Technical Report 1006878.
 - _. 2009a. "Assessment of Achievable Potential from Energy Efficiency and Demand Response Programs in the U.S. (2010-2030)." Technical Report 1016987. January 2009.
 - ___. 2009b. "Potential Impact of Climate Change on Natural Resources in the Tennessee Valley Authority Region." Palo Alto, CA.
- Environmental Laboratory. 1987. Corps of Engineers Wetland Delineation Manual. Vicksburg: U.S. Army Corps of Engineers Waterways Experiment Station, Technical Report Y-87-1.
- Federal Interagency Committee on Noise. 1992. Federal Agency Review of Selected Airport Noise Analysis Issues. Fort Walton Beach, Fla.: Spectrum Sciences and Software Inc., August 1992.
- Geological Survey of Alabama. 2003. "Fort Payne Earthquake, April 29, 2003." *Earthquakes in Alabama*. Retrieved from http://www.gsa.state.al.us/gsa/geologichazards/earthquakes/ftpayne.html (accessed January 2009).
- Global Climate Change Impacts in the United States. 2009. Karl, T. R, J. M. Melillo, and T. C. Peterson, (eds.). Cambridge University Press.
- Griffith, G. E., J. M. Omernik, and S.H. Azevedo. 1998. Ecoregions of Tennessee. (two-sided color poster with map, descriptive text, summary tables, and photographs). Reston, Virginia, U.S. Geological Survey (map scale 1:940,000).

- Griffith, G. E., J. M. Omernik, J. A. Comstock, S. Lawrence, G. Martin, A. Goddard, V. J. Hulcher, and T. Foster. 2001. Ecoregions of Alabama and Georgia, (color poster with map, descriptive text, summary tables, and photographs): Reston, Virginia, U.S. Geological Survey (map scale 1:1,700,000).
- Hickman, G. H., and T. A. McDonough. 1996. "Assessing the Reservoir Fish Assemblage Index—a Potential Measure of Reservoir Quality" in *Reservoir Symposium*— *Multidimensional Approaches to Reservoir Fisheries Management*. Edited by D. DeVries. Bethesda, Md.: American Fisheries Society, Southern Division, Reservoir Committee.
- Highlands Medical Center. 2010. Highlands Health & Rehab. Retrieved from http://www.highlandshealthandrehab.com/> (accessed February 23, 2010).
- Intergovernmental Panel on Climate Change (IPCC). 2007. Climate Change 2007: Synthesis Report.
- International Association for Research on Cancer. 2002. "Non-Ionizing Radiation, Part 1; Static and Extremely Low-Frequency (ELF) Electric and Magnetic Fields." *Monographs on the Evaluation of Carcinogenic Risks to Humans*. IARC, Working Group on the Evaluation of Carcinogenic Risks to Humans.
- International Atomic Energy Agency (IAEA). 1992. Effects of Ionizing Radiation on Plants and Animals at Levels Implied by Current Radiation Standards, Technical Report Series No. 332.
- International Commission on Radiological Protection (ICRP). 1959. *Report of Committee II on Permissible Dose for Internal Radiation*. ICRP Publication 2. New York: Pergamon, Adopted July 1959.
- Jenkins, E. 2008. *Historic Resource Survey for the Bellefonte Nuclear Site in Jackson County, Alabama.* Report submitted to Tennessee Valley Authority, Knoxville, Tennessee, by TRC, Atlanta.
- Jennings, M. J., L. S. Fore, and J. R. Karr. 1995. *Biological Monitoring of Fish Assemblages in Tennessee Valley Reservoirs.* Regulated Rivers: Research and Management.
- Jirka, G. H., R. L. Doneker, and S. W. Hinton. 2007. User's Manual for CORMIX: A Hydrodynamic Mixing Zone Model and Decision Support System for Pollutant Discharges into Surface Waters. Washington, D.C.: U.S. Environmental Protection Agency, EPA-823-K-07-001, Dec. 2007.
- Journal of the American Medical Association. 2007. "Implantable Cardioverter-Defibrillators." JAMA 297(17), May 2, 2007.
- Julian, H. E. 1996. Assessment of Groundwater Impacts from Releases of Diesel Fuel Oil at Bellefonte Nuclear Plant. Norris, Tenn.: Tennessee Valley Authority, Engineering Laboratory, Report No. WR28-1-88-120.
 - —. 1999. Natural Attenuation of Diesel Fuel Oil at Bellefonte Nuclear Plant. Norris, Tenn.: Tennessee Valley Authority, Engineering Laboratory, Report No. WR99-2-88-122.

Final Supplemental Environmental Impact Statement

- Keiser, E. D., G. O. Dick, and R. M. Smart. 1995. *Turtle Populations in Guntersville Reservoir, Alabama.* Joint Agency Guntersville Project Aquatic Plant Management.
- Kim, W. 2009. Lamont-Doherty Earth Observatory of Columbia University, New York, New York. 29 April 2003 Fort Payne, Alabama Earthquake Page. Retrieved from http://www.ldeo.columbia.edu/LCSN/Eq/20030429/20030429_0859.html> (accessed November 2, 2009).
- Kingsbury, J. A. 2003. Shallow Groundwater Quality in Agricultural Areas of Northern Alabama and Middle Tennessee, 2000-2001. U.S. Geological Survey Water-Resources Investigations Report 2003-4181.
- Lindquist, K. 1990. Bellefonte Groundwater Impacts of Trisodium Phosphate Land Application. Norris, Tenn.: Tennessee Valley Authority, Engineering Laboratory, Report No. WR28-1-88-112.
- Loyd, E. 2009. Bellefonte Nuclear Plant Plant Discharge Diffuser Hydrothermal Analysis for the Evaluation of Alternatives Presented in the Supplemental Environmental Impact Statement for Single Unit Operation at the Bellefonte Site. Tennessee Valley Authority, Office of Environment and Research.
- Lloyd, O. B., Jr., and W. L. Lyke. 1995. *Groundwater Atlas of the United States,* Segment 10. Reston, Va.: United States Geological Survey.
- McDonough, T. A., and G. D. Hickman. 1999. "Reservoir Fish Assemblage Index Development: A Tool for Assessing Ecological Health in Tennessee Valley Authority Impoundments," 523-540 in Assessing the Sustainability and Biological Integrity of Water Resources Using Fish Communities. Edited by T. P. Simon. Boca Raton, Fla.: CRC Press.
- Meier, P. J. 2002. Life-Cycle Assessment of Electricity Generation Systems and Applications for Climate Change Policy Analysis. Fusion Technology Institute of University of Wisconsin.
- Menzel, M. A., J. M. Menzel, T. C. Carter, W. M. Ford, and J.W. Edwards. 2001. Review of the Forest Habitat Relationships of the Indiana Bat (Myotis sodalis). Newton Square, Pa.: U.S. Department of Agriculture, Forest Service, Northeastern Research Station, Gen. Tech. Rep. NE-284.
- Miller, B. A., V. Alavian, M. D. Bender, D. J. Benton, L. L. Cole, L. K. Ewing, P. Ostrowski, et al. 1993. Sensitivity of the TVA Reservoir and Power Supply Systems to Extreme Meteorology. Norris, Tenn.: Tennessee Valley Authority, Engineering Laboratory, Report No. WR28-1-680-111. June 1993
- Miller, J. A. 1990. Groundwater Atlas of the United States. U.S. Geological Survey Hydrologic Investigations Atlas 730-G.
- Miller, N. E., R. D. Drobney, R. L. Clawson, and E. V. Callahan. 2002. "Summer Habitat in Northern Missouri," 165-171 in *The Indiana bat: Biology and Management of an Endangered Species*. Edited by A. Kurta and J. Kennedy. Austin, Tex.: Bat Conservation International.

- Muncy, J. A. 1999. A Guide for Environmental Protection and Best Management Practices for Tennessee Valley Authority Transmission Construction and Maintenance Activities, revised edition. Edited by C. Austin, C. Brewster, A. Lewis, K. Smithson, T. Broyles, and T. Wojtalik. Norris: Tennessee Valley Authority, Technical note TVA/LR/NRM 92/1.
- National Climate Data Center (NCDC). 2010. Storm Events, Jackson County, Alabama. Retrieved from http://www4.ncdc.noaa.gov/cgi-win/wwcgi.dll?wwEvent-Storms (accessed February 22, 2010).
- National Institute of Environmental Health Sciences (NIEHS). 1998. Report on Health Effects From Exposure to Power Line Frequency Electric and Magnetic Fields. Research Triangle Park: NIEHS, Publication No. 99-4493.
- ———. 2002. Electric and Magnetic Fields Associated With the Use of Electric Power. Retrieved from http://www.niehs.nih.gov/about/visiting/index.cfm (n.d.)
- National Renewable Energy Laboratory. 2005. A Geographic Perspective on the Current Biomass Resource Availability in the United States. NREL/TP 560-39181, December 2005.
- National Research Council. 1997. Possible Health Effects of Exposure to Residential Electric and Magnetic Fields. NRC, Committee on the Possible Effects of Electromagnetic Fields on Biologic Systems. Washington National Academy Press.
- NatureServe. 2009. NatureServe Explorer: An Online Encyclopedia of Life, Version 7.1. Arlington, Va.: NatureServe. Retrieved from http://www.natureserve.org/explorer (accessed September 4, 2009).
- Nuclear Energy Institute (NEI). 2002. Aircraft Crash Impact Analyses Demonstrate Nuclear Power Plant's Structural Strength.
 - ____. 2007. Final Industry Ground Water Protection Initiative Final Guidance Document. August 2007.
- . 2008. Generic FSAR Template Guidance for Life-Cycle Minimization of Contamination. December 2008.
- Oakley, C. B. 1972. An Archaeological Survey of the Bellefonte Power Plant. Report on file at TVA Cultural Resources Office, Knoxville, Tennessee.
- Osborne, W. E., M. W. Szabo, T. L. Neathery, and C. W. Copeland Jr. 1988. Geologic Map of Alabama, Northeast Sheet, Geological Survey of Alabama Special Map 220.
- Reed, P. B., Jr. 1997. *Revised National List of Plant Species That Occur in Wetlands: National Summary*. U.S. Fish and Wildlife Service Biological Report 88(24).
- Romme, R. C., K. Tyrell, and V. Brack Jr. 1995. "Literature Summary and Habitat Suitability Index Model: Components of Summer Habitat for the Indiana Bat, *Myotis sodalis*" in 3/D *Environmental*, Federal Aid Project E-1-7, Study No. 8.

- "Safety Goals for the Operations of Nuclear Power Plants." *Federal Register* 51:28044 (04 August 1986).
- SERC Reliability Corporation (SERC). 2008. SERC Power System Stabilizer Guideline. Revision 1. November 15, 2008.
- Simmons, J. W. and C. F. Walton. 2009. Results of Biological Monitoring in the Vicinity of Bellefonte Nuclear Plant During Spring and Summer 2009, with an Analysis of Fish Species Occurrences in Guntersville Reservoir- A Comparison of Historic and Recent Data. TVA Aquatic Monitoring and Management, Chattanooga. 47 pp +appendix.
- Spencer, R. W. 2008. Global Warming as a Natural Response to Cloud Changes Associated with the Pacific Decadal Oscillation. Retrieved from http://www.droyspencer.com/research-articles/global-warming-as-a-natural-response/ (accessed April 13, 2010).
- "Supplemental Environmental Impact Statement for a Single Nuclear Unit at the Bellefonte Site." Federal Register 74:40000 (10 August 2009).
- Tennessee Department of Environment and Conservation (TDEC). 2002. *Tennessee Groundwater 305b Water Quality Report*. TDEC, Division of Water Supply.
- "Tennessee Valley Authority (Bellefonte Nuclear Plant, Units 1 and 2), Receipt of Application for Facility Operating Licenses; Availability of Applicant's Environmental Report; and Consideration of Issuance of Facility Operating Licenses and Opportunity for Hearing." *Federal Register* 43:30628 (17 July 1978).
- Tennessee Valley Authority (TVA). 1974a. Final Environmental Statement, Bellefonte Nuclear Plant Units 1 and 2.
 - 1974b. Effects of Widows Creek Steam Plant on the Fish Populations of Guntersville Reservoir. Division of Forestry, Fisheries, and Wildlife Development, Norris, Tennessee. 36 p.
 - ------. 1975a. Final Environmental Statement, Hartsville Nuclear Plants.
- 1975b. Impingement at Widows Creek Steam Plant. Division of Forestry, Fisheries, and Wildlife Development, Norris, Tennessee.
 - —. 1976. Bellefonte Nuclear Plant Units 1 and 2, Environmental Report, Operating License Stage, Tennessee Valley Authority, Volume 1, January 1, 1976.
- ———. 1977a. Environmental Report, Phipps Bend Nuclear Plant Units 1 and 2.
 - ——. 1977b. Submerged Multiport Diffuser Design for Bellefonte Nuclear Plant. TVA Report No. 81-13, September 1977.
- ——. 1977c. Diffuser Mixing Zone and Far Field Dispersion Bellefonte Nuclear Plant. TVA Report No. WM28-2-88-002, November 1977.
 - —. 1978a. Bellefonte Nuclear Plant Final Safety Analysis Report, Amendment 16.

Final Supplemental Environmental Impact Statement

——. 1978b. Final Environmental Statement, Yellow Creek Nuclear Plant Units 1 and 2.

- ------. 1978c. Environmental Radioactivity Levels, Bellefonte Nuclear Plant, Annual Report, 1977. TVA Radiological Health Staff.
- ------. 1979. Environmental Radioactivity Levels, Bellefonte Nuclear Plant, Annual Report, 1978. TVA Radiological Health Staff.

——. 1980a. Final Safety Analysis Report, Bellefonte Units 1 and 2, Amendment 19.

——. 1980b. Environmental Radioactivity Levels, Bellefonte Nuclear Plant, Annual Report, 1979. TVA Radiological Health Staff.

------ 1981a. Final Environmental Impact Statement, Coal Gasification Project. July 1981

——. 1981b. Environmental Radioactivity Levels, Bellefonte Nuclear Plant, Annual Report, 1980. TVA Radiological Health Staff.

—. 1982a. Predicted Effects for Mixed Temperatures Exceeding 30°C (86°F) in Guntersville Reservoir, Alabama, in the Vicinity of the Diffuser Discharge, Bellefonte Nuclear Plant. TVA Report No. TVA/ONR/WRF 82/5, February 1982.

——. 1982b. Environmental Radioactivity Levels, Bellefonte Nuclear Plant, Annual Report, 1981. TVA Radiological Health Staff.

——. 1982c. Final Safety Analysis Report, Bellefonte Units 1 and 2. Amendment 22

-----. 1983a. Environmental Radioactivity Levels, Bellefonte Nuclear Plant, Annual Report, 1982. TVA Radiological Health Staff.

--. 1983b. Procedures for Compliance with the National Environmental Policy Act: Instruction IX Environmental Review. Retrieved from http://www.tva.gov/environment/reports/pdf/tvanepa procedures.pdf> (n.d.).

—. 1983c. First Preoperational Assessment of Water Quality and Biological Resources of Guntersville Reservoir in the Vicinity of the Proposed Murphy Hill Coal Gasification Project. Office of Natural Resources, Division of Air and Water Resources. Knoxville, Tennessee.

-. 1984. Environmental Radioactivity Levels, Bellefonte Nuclear Plant, Annual Report, 1983. TVA Radiological Health Staff.

. 1985a. Bellefonte Nuclear Plant Construction and Operational Employee Survey Results and Mitigation Summary April 30, 1984. Knoxville, Tenn.: Tennessee Valley Authority, June 1985.

 -. 1985b. Preoperational Assessment of Water Quality and Biological Resources of Guntersville Reservoir in the Vicinity of Bellefonte Nuclear Plant, 1974 Through 1984.
 Office of Natural Resources and Economic Development, Division of Air and Water Resources.

-. 1986. Final Safety Analysis Report, Bellefonte Units 1 and 2. Amendment 27.

Final Supplemental Environmental Impact Statement

 . 1991. Bellefonte Nuclear Plant Units 1 and 2 Final Safety Analysis Report, Amendment 30.

-. 1992. A Guide for Environmental Protection and Best Management Practices for Tennessee Valley Authority Transmission Construction and Maintenance Activities. Norris, Tenn.: TVA.

-. 1993a. Environmental Impact Statement Review, Bellefonte Nuclear Plant White Paper. March 1993.

— 1993b. Sensitivity of the TVA Reservoir and Power Supply Systems to Extreme Meteorology. TVA Report No. WR28-1-680-111, June 1993.

——. 1995. Energy Vision 2020 - Integrated Resource Plan and Final Programmatic Environmental Impact Statement and Record of Decision. December 1995.

-. 1997. *Final Environmental Impact Statement for the Bellefonte Conversion Project.* October 1997.

-. 2000. Record of Decision and Adoption of the Department of Energy Final Environmental Impact Statement for the Production of Tritium in a Commercial Light Water Reactor. May 19, 2000.

 2001. Guntersville Reservoir Land Management Plan, Jackson and Marshall Counties, Alabama, and Marion County, Tennessee. August 2, 2001.

—. 2004. Reservoir Operations Study Final Programmatic Environmental Impact Statement and Record of Decision. Prepared in cooperation with the U.S. Army Corps of Engineers and the U.S. Fish and Wildlife Service, May 19, 2004.

—. 2006. Final Environmental Assessment Bellefonte Plant Redress, Jackson County, Alabama. January 2006.

-. 2007a. Final Supplemental Environmental Impact Statement, Completion and Operation of Watts Bar Nuclear Plant Unit 2, Rhea County, Tennessee. June 2007.

-. 2007b. Fish Impingement at Widows Creek Fossil Plants A and B During 2005 Through 2007. Aquatic Monitoring and Management, Knoxville, Tennessee. 18 p.

—. 2008a. Bellefonte Nuclear Plant, Units 3&4, COL Application, Part 3, Environmental Report, Revision 1.

 2008b. Activities at Bellefonte Nuclear Plant Related to Future Site Use, Jackson County Alabama. July 2008.

-. 2008c. Descriptions of Existing Facilities and Infrastructure for Alternative Sites to the Selected Bellefonte Site. White paper submitted to NRC, dated June 26, 2008.

-. 2008d. *Criteria and Basis for Comparative Ratings Among Alternative Brownfield and Greenfield Sites, Rev 1*. White paper submitted to NRC, dated August 22, 2008.

-. 2008e. Site Screening Process: Information Complementary to Section 9.3.2 of the Bellefonte Nuclear Plant, Units 3 and 4, COLA Applicant's Environmental Report. White paper submitted to NRC, dated August 12, 2008.

 2008f. Bellefonte Nuclear Plant Environmental Justice Impact Assessment Methodology and Findings. Bellefonte Nuclear Plant (BLN – Response to Environmental Report (ER) Sufficiency Review Comments. Letter submitted to NRC, dated May 2, 2008.

-. 2008g. Supplemental Environmental Assessment for the Potential Upgrade of the Tenaska Site for Establishing a Simple-Cycle or Combined-Cycle Electric Generation Facility. TVA, Knoxville, TN.

——. 2009a. Bellefonte Nuclear Plant, Units 3 & 4, COL Application, Final Safety Analysis Report, Revision 1.

—. 2009b. Interconnection System Impact Study Report for Bellefonte Nuclear Plant Unit 1. August 2009.

-. 2009c. Biological Assessment: Effects of Condenser Cooling Water Withdrawal on the Larval Fish Community Near Bellefonte Nuclear Plant Intake, 2009. Tennessee Valley Authority Aquatic Monitoring and Management. Knoxville, TN.

-. 2009d. Biological Assessment: Proposed Single Unit Nuclear Plant Development at Bellefonte Nuclear Site and Associated Transmission Line Upgrades, Alabama, Tennessee, and Georgia. Office of Environmental and Research, Environmental Permitting & Compliance. November 2009.

 2010a. Detailed Scoping, Estimating, and Planning Ground Water Intrusion Assessment, Unit 0. Performed by Sargent and Lundy LLC, Project 12054. Feb. 9, 2010.

-. 2010b. Bellefonte Combined License Application – Revision to Part 2 – Final Safety Analysis Report Section 2.4. Letter Submitted to NRC and Enclosure Providing Voluntary Revisions to TVA's COL Application, dated January 15, 2010.

- Thomas, D. P., and T. L. Best. 2000. "Radiotelemetric Assessment of Movement Patterns of the Gray Bat (*Myotis grisescens*) at Guntersville Reservoir, Alabama." Occasional Papers of the North Carolina Museum of Natural Sciences and the North Carolina Biological Survey, 12:50-66.
- U.S. Atomic Energy Commission (AEC). 1972. The Environmental Survey of Transportation of Radioactive Materials to and from Nuclear Plants. WASH-1238.

_. 1974. Final Environmental Statement Related to Construction of Bellefonte Nuclear Plant Units 1 and 2. Docket Nos. 50-438 and 50-439, June 4, 1974.

U.S. Census Bureau (Census), 2000a. *Total Population*. Retrieved from ">http://factfinder.census.gov/home/saff/main.html?_lang=en> (accessed October 9, 2009).

. 2000b. *Minority Population by Race*. Retrieved from <http://factfinder.census.gov/home/saff/main.html?_lang=en> (accessed October 9, 2009 and April 21, 2010).

-. 2000c. *Poverty Status*. Retrieved from <http://factfinder.census.gov/home/saff/main.html?_lang=en> (accessed April 21, 2010).

--. 2000d. QT-H1. General Housing Characteristics: 2000. Census 2000 Summary File 1 (SF-1) 1000 Percent Data, Jackson County, Alabama. Retrieved from <http://www.factfinder.census.gov/servlet/QTTable?_bm=y&-geo_id=05000US01071&qr_name=DEC_2000_SF1_U_QTH1&-ds_name=DEC_2000_SF1_U&-redoLog=false> (accessed November 29, 2006).

——. 2008a. State and County QuickFacts, Jackson County, Alabama. Last revised February 23, 2010. Retrieved from <http://quickfacts.census.gov/qfd/states/01/01071.html> (accessed April 21, 2010).

-----. 2008b. People and Households, Small Area Income and Poverty Estimates. Estimates for Alabama Counties, 2008. Final release date: November 2009. Retrieved from http://www.census.gov/cgi-bin/saipe/saipe.cgi (accessed April 20, 2010).

-. 2009. County Population Estimates, Annual Estimates of the Resident Population for Counties: April 1, 2000 to July 1, 2009. Release date: March 2010. Retrieved from http://www.census.gov/popest/counties/CO-EST2009-01.html (accessed 4/21/10).

-. 2010. Selected Housing Characteristics: 2006-2008, 2006-2008 American Community Survey 3-Year Estimates, Jackson County, Alabama. Retrieved from <http://factfinder.census.gov/servlet/DatasetMainPageServlet?_program=ACS> (accessed February 20, 2010).

- U.S. Department of Agriculture (USDA). 2007. *Invasive and Noxious Weeds.* Retrieved from http://plants.usda.gov/java/noxiousDriver> (accessed September 1, 2009).
- U.S. Department of Agriculture, Natural Resource Conservation Service (USDA-NRCS). 2009. Soil Survey Geographic Database (SSURGO). Retrieved from http://soils.usda.gov/survey/geography/ssurgo/ (accessed September 13, 2008).
- U.S. Department of Commerce, Bureau of Economic Analysis (BEA). 2010a. Regional Economic Information System (REIS), April 2010. Personal Income and Employment Summary, Jackson County, Alabama, 1999-2008. Retrieved from http://www.bea.gov/regional/reis/> (accessed April 23, 2010).

_____. 2010b. Total Full-Time and Part-Time Employment by NAICS, Jackson County, Estimates for 2007 and 2008. Regional Economic Information System (REIS), April 2010. Retrieved from http://www.bea.gov/regional/reis/ (accessed April 23, 2010).

Final Supplemental Environmental Impact Statement

____. 2010c. Regional Economic Information System (REIS), April 2010. Economic data estimates for 2008. Retrieved from http://www.bea.gov/regional/reis/ (accessed April 22, 2010).

Total Full-Time and Part-Time Employment by NAICS Industry for Jackson County, Alabama, and the United States (2008 data).

Personal Income by Major Source and Earnings by NAICS Industry for Jackson County, Alabama, and the United States (2008 data).

- U.S. Department of Defense and U.S. Environmental Protection Agency. 2003. "Advance Notice of Proposed Rulemaking on the Clean Water Act Regulatory Definition of Waters of the United States." *Federal Register* 68:9613 (15 January 2003).
- U.S. Department of Energy (DOE). 1996. "Questions and Answers; EMF in the Workplace." *Electric and Magnetic Fields Associated With the Use of Electric Power*. National Institute for Occupational Safety and Health, National Institute of Environmental Health Sciences, Report No. DOE/GO-10095-218, September 1996.
 - ___. 1999. Final Environmental Impact Statement for the Production of Tritium in a Commercial Light Water Reactor. Washington, D.C.: DOE EIS 0288, March 1999.

-. 2006. Feasibility Assessment of the Water Energy Resources of the United States for New Low Power and Small Hydro Classes of Hydroelectric Plants. U.S. Department of Energy, Energy Efficiency and Renewable Energy, Wind and Hydropower Technologies. DOE-ID-11263, January 2006. Retrieved from

<http://www1.eere.energy.gov/windandhydro/pdfs/doewater-11263.pdf> (accessed April 22, 2010).

2010. Office of Energy Efficiency and Renewable Energy, Wind and Water Power Program, Wind Powering America, Tennessee Wind Map and Resource Potential. Retrieved from

<http://www.windpoweringamerica.gov/wind_resource_maps.asp?stateab=tn> (accessed April 26, 2010).

. 2008. Global Nuclear Energy Partnership, Draft Programmatic Environmental Impact Statement. October 2008.

- U.S. Department of Labor, Bureau of Labor Statistics. 2010. Local Area Unemployment Statistics, Unemployment Rates for States. Retrieved from http://www.bls.gov/lau/lastrk09.htm> (accessed April 23, 2010).
- U.S. Environmental Protection Agency (EPA). 1971. Noise From Construction Equipment and Operations, Building Equipment, and Home Appliances. Washington, D.C.: EPA Office of Noise Abatement and Control.

 1997. Area Designations for 1997 Fine Particle (PM2.5) Standards, 1997 PM 2.5 Standards – Region 4 State Designations. Retrieved from <http://www.epa.gov/pmdesignations/1997standards/final/region4desig.htm> (accessed May 3, 2010).

-. 2006. Area Designations for 2006 24-Hour fine Particle (PM2.5) Standards. Retrieved from <http://www.epa.gov/pmdesignations/2006standards/final/region4.htm> (accessed October 21, 2009).

 2008a. "Oil Pollution Prevention." Code of Federal Regulations, Chapter 40, Part 112. Washington, D.C.: U.S. Government.

 2008b. Ground-level Ozone Standards – Region 4 Recommendations and EPA Responses. Retrieved from <http://www.epa.gov/ozonedesignations/2008standards/rec/region4R.htm> (accessed)

ccessed October 21, 2009).

- 2009. Local Drinking Water Information. Retrieved from http://www.epa.gov/safewater/dwinfo/index.html (accessed October 23, 2009)
- U.S. Fish and Wildlife Service (USFWS). 1980. Selected Vertebrate Endangered Species of the Seacoast of the United States: The Red-Cockaded Woodpecker. Washington, D.C.: U.S. Fish and Wildlife Laboratory, FWS/OBS 80/01.7.

—. 1996. National List of Vascular Plant Species That Occur in Wetlands: 1996 National Summary.

-. 2002. "Reclassification of *Scutellaria Montana* (Large-Flowered skullcap) from Endangered to Threatened." *Federal Register* 67:1662 (14 January 2002).

U.S. Forest Service (USFS). 2007. Southern Research Station Timber Product Output Report. Retrieved from http://srsfia2.fs.fed.us/php/tpo_2009/tpo_rpa_int1.php (accessed May 4, 2010).

_____. 2008. *Eastern Forest Environmental Threat Assessment: Invasive Plants*. Retrieved from http://www.forestthreats.org/invasive-plants> (accessed June 11, 2009).

- U.S. Geological Survey (USGS). 2003. Poster of the Fort Payne, Alabama Earthquake of 29 April 2003 - Magnitude 4.6. Retrieved from http://earthquake.usgs.gov/eqcenter/eqarchives/poster/2003/20030429_image.php (accessed January 5, 2009).
- _____. 2010. Earthquake Hazards Program, Glossary of Terms on EQ Maps. Retrieved from http://earthquake.usgs.gov/earthquakes/glossary.php (accessed March 28, 2008).
- U.S. Nuclear Regulatory Commission (NRC). 1973. *Design Response Spectra for Seismic Design of Nuclear Power Plants, Revision 1.* Regulatory Guide 1.60. Directorate of Regulatory Standards, December 1973.
 - ——. 1975. Environmental Survey of Transportation of Radioactive Materials To and From Nuclear Power Plants, Supplement 1. NUREG-75/038.

———. 1976. Calculation of Releases of Radioactive Materials in Gaseous and Liquid Effluents from Pressurized Water Reactors. Washington, D.C.: Office of Standards Development, NUREG-0017.

-: 1977a. Calculation of Annual Doses to Man From Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance With 10 CFR Part 50, Appendix I, Revision 1. Regulatory Guide 1.109. October 1977.

—. 1977b. Methods for Estimating Atmospheric Transport and Dispersal of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors, Revision 1. Regulatory Guide 1.111. Office of Standards Development, July 1977.

—. 1982a. Atmospheric Dispersion Models for Potential Accident Consequence Assessments at Nuclear Power Plants, Revision 1. Regulatory Guide 1.145. Office of Nuclear Regulatory Research, November 1982.

——. 1982b. XOQDOQ: Computer Program for the Meteorological Evaluation of Routine Effluent Releases at Nuclear Power Stations. NUREG/CR-2919, September 1982.

——. 1986, LADTAP II - Technical Reference and User Guide. NUREG/CR-4013, PNL-5270, April 1986.

----. 1987. GASPAR II—Technical Reference and User Guide. NUREG/CR-4653, March 1987.

—. 1990. Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants, Final Summary Report. NUREG-1150. Washington, D.C.: Office of Nuclear Regulatory Research.

----. 1996. Generic Environmental Impact Statement for License Renewal of Nuclear Plants. NUREG-1437, Washington, D.C.

———. 1998. Code Manual for MACCS2. NUREG/CR-6613, SAND97-0594. May 1998.

——. 1999. Environmental Standard Review Plan. NUREG 1555. October 1999.

----. 2002. Subpart D - Radiation Dose Limits for Individual Members of the Public. 10 CFR Part 20.1301. October 2002. Retrieved from http://www.nrc.gov/reading-rm/doccollections/cfr/part020/part020-1301.html> (n.d.).

 2007a. A Performance-Based Approach to Define the Site-Specific Earthquake Ground Motion. Regulatory Guide 1.208. Office of Nuclear Regulatory Research, March 2007.

. 2007b. Numerical Guides for Design Objectives and Limiting Conditions for Operation to Meet the Criterion "As Low as is Reasonably Achievable" for Radioactive Material in Light-Water-Cooled Nuclear Power Reactor Effluents. Appendix I to 10 CFR Part 50. Retrieved from http://www.nrc.gov/reading-rm/doc-collections/cfr/part050/part050-appi.html (accessed October 21, 2009).

____. 2007c. Additional Comments on SECY-06-0219, Final Rulemaking to Revise 10 C.F.R. 73.1, Design Basis Threat Requirements, NRC Commissioner McGaffigan. January 29, 2007.

Final Supplemental Environmental Impact Statement

2008. Supplemental Environmental Impact Statement for the Combined License (COL) for North Anna Power Station Unit 3. NUREG-1917, Washington, D.C.

_____ 2010. Office of Public Affairs Fact Sheet: Buried Pipes at Nuclear Reactors. February 2010.

Westinghouse Electric Company (WEC). 2008. AP1000 Design Control Document, APP-GW-GL-700, Revision 17.

__. 2009. Representation of the Westinghouse AP1000 Simplified Design. Retrieved from <http://www.ap1000.westinghousenuclear.com/ap1000_glance.html> (accessed May 2, 2010).

Whitaker, J. O., Jr. and W. J. Hamilton. 1998. *Mammals of the Eastern United States*, 3rd edition. Ithaca, N.Y.: Cornell University Press.

World Health Organization (WHO). 2007a. *Electromagnetic Fields and Public Health.* WHO EMF Task Force Report, WHO Fact Sheet No. 299, March 2007.

----. 2007b. *Extremely Low Frequency Fields*. Environmental Health Criteria Monograph No. 238, August 2007.

-. 2007c. Electromagnetic Fields and Public Health Exposure to Extremely Low Frequency Fields. WHO Fact Sheet No. 322, June 2007.

Page intentionally blank

· ·

GLOSSARY

A-weighted decibel (dBA) - A unit of weighted sound pressure level, measured by the use of a metering characteristic and the "A" weighting specified by American National Standard Institute SI.4-1971(R176). (See decibel).

Accident - One or more unplanned events involving materials that have the potential to endanger the health and safety of workers and the public. An accident can involve a combined release of energy and hazardous materials (radiological or chemical) that might cause prompt or latent adverse health effects.

Accident sequence - With regard to nuclear facilities, an initiating event followed by system failures or operator errors, which can result in significant core damage, confinement system failure, and/or radionuclide releases.

Ambient air - The surrounding atmosphere as it exists around people, plants, and structures. Air quality standards are used to provide a measure of the health-related and visual characteristics of the air.

Archaeological sites (resources) - Any location where humans have altered the terrain or discarded artifacts during either prehistoric or historic times.

Area of potential effects (APE) - Geographic area or areas within which an undertaking may directly or indirectly cause changes in the character or use of historic properties, if such properties exist. For this SEIS, the archaeological APE is the same as the "Bellefonte Project Area" as identified on the B&W and AP100 site plans.

Artifact - An object produced or shaped by human workmanship of archaeological or historical interest.

As Low as Reasonably Achievable (ALARA) - A concept applied to ensure the quantity of radioactivity released to the environment and the radiation exposure of onsite workers in routine operations, including "anticipated operational occurrences," is maintained as low as reasonably achievable. It takes into account the state of technology, economics of improvements in relation to benefits to public health and safety, and other societal and economic considerations in relation to the use of nuclear energy in the public interest.

Background radiation - lonizing radiation present in the environment from cosmic rays and natural sources in the Earth; background radiation varies considerably with location.

Baseline - A quantitative expression of conditions, costs, schedule, or technical progress to serve as a base or standard for measurement during the performance of an effort; the established plan against which the status of resources and progress of a project can be measured. For this environmental impact statement, the environmental baseline is the site environmental conditions as they exist or have been estimated to exist in the absence of the proposed action.

Base Load - The minimum amount of electric power or natural gas delivered or required over a given period of time at a steady rate. The minimum continuous load or demand in a power system over a given period of time usually not temperature sensitive.

Base load capacity - The generating equipment normally operated to serve loads on an around-the-clock basis.

Basemat - Reinforced concrete foundation. The AP1000 basemat meets the functional requirements of a building foundation by providing the strength and stability necessary for design loads to transmit safely from the structure onto the underlying rock and soil substrata.

Benthic - Plants and animals dwelling at the bottom of oceans, lakes, rivers, and other surface waters.

Benthic macroinvertebrate - Organisms that are large enough to be seen without the aid of magnification and that live in close association with bottom of flowing and nonflowing bodies of water.

Best management practices (BMP) - A practice or combination or practices that is determined by a state (or other planning agency) after problem assessment, examination of alternative practices, and appropriate public participation to be the most effective, practicable means of preventing or reducing the amount of pollution generated by nonpoint sources to a level compatible with air or water quality goals.

Beta particle - A charged particle emitted from the nucleus of an atom during radioactive decay. A negatively charged beta particle is identical to an electron; a positively charged beta particle is called a "positron."

Beta radiation - Consists of an elementary particle emitted from a nucleus during radioactive decay; it is negatively charged, is identical to an electron, and is easily stopped by a thin sheet of metal.

Block groups - U.S. Bureau of the Census term describing a cluster of blocks generally selected to include 250 to 550 housing units.

Blowdown - A maintenance procedure to remove sediment in power plant components.

Burnup - The total energy released through fission by a given amount of nuclear fuel; generally measured in megawatt-days.

CE-QUAL-W2 - Two-dimensional, laterally averaged, hydrodynamic and water quality model for reservoirs

Cancer - The name given to a group of diseases characterized by uncontrolled cellular growth with cells having invasive characteristics such that the disease can transfer from one organ to another.

Capacity factor - The ratio of the annual average power production of a power plant to its rated capacity.

Canister - A stainless-steel container in which nuclear material is sealed.

Cladding - The metal tube that forms the outer jacket of a nuclear fuel rod or burnable absorber rod. It prevents the release of radioactive material into the coolant. Stainless steel and zirconium alloys *are* common cladding materials.

Final Supplemental Environmental Impact Statement

Consumptive water use - The difference in the volume of water withdrawn from a body of water and the amount released back into the body of water.

Container - With regard to radioactive wastes, the metal envelope in the waste package that provides the primary containment function of the waste package and is designed to meet the containment requirements of 10 CFR Part 60.

Containment structure - A gas-tight shell or other enclosure around a nuclear reactor to confine fission that otherwise might be released to the atmosphere in the event of an accident. Such enclosures are usually dome-shaped and made of steel-reinforced concrete.

Containment design basis - For a nuclear reactor, those bounding conditions for the design of the containment, including temperature, pressure, and leakage rate. Because the containment is provided as an additional barrier to mitigate the consequences of accidents involving the release of radioactive materials, the containment design-basis may include an additional specified margin above those conditions expected to result from the plant design-basis accidents to ensure that the containment design can mitigate unlikely or unforeseen events.

Conductors - A wire or combination of wires not insulated from one another, suitable for carrying electric current.

Cooling water - Water pumped into a nuclear reactor or accelerator to cool components and prevent damage from the intense heat generated when the reactor or accelerator is operating.

CORMIX – Cornell Mixing Zone Expert System (CORMIX), an EPA-supported mixing zone model for assessment of regulatory mixing zones resulting from steady, continuous point source discharges.

Cultural resources - Archaeological sites, historical sites, architectural features, traditional use areas, and Native American sacred sites.

Cumulative impacts/effects - In an environmental impact statement, the impact on the environment which results from the incremental impact of the action when added to other past, present, and reasonably foreseeable future actions, regardless of what agency (Federal or nonfederal), private industry, or individual(s) undertakes such other actions. Cumulative impacts can result from individually minor but collectively significant actions taking place over a period of time (40 CFR §1508.7).

Current - The movement of electrons in the conductors or transmission lines.

Decay heat (radioactivity) - The heat produced by the decay of certain radionuclides.

Decay (radioactive) - The decrease in the amount of any radioactive material with the passage of time due to the spontaneous transformation of an unstable nuclide into a different nuclide or into a different energy state of the same nuclide; the emission of nuclear radiation (alpha, beta, or gamma radiation) is part of the process.

Decibel (dB) - A logarithmic unit of sound measurement which describes the magnitude of a particular quantity of sound pressure power with respect to a standard reference value, in general, a sound doubles in loudness for every increase of 10 decibels.

Decibel, A-weighted (dBA) - A unit of frequency-weighted sound pressure level, measured by the use of a metering characteristic and the "A" weighting specified by the American National Standards Institute (ANSI) Si .4-1983 (RI 594), that accounts for the frequency response of the human ear.

Decommissioning - The removal from service of facilities such as processing plants, waste tanks, and burial grounds, and the reduction or stabilization of radioactive contamination. Decommissioning includes decontamination, dismantling, and return of the area to original condition without restrictions or partial decontamination, isolation of remaining residues, and continuation of surveillance and restrictions.

Decontamination - The actions taken to reduce or remove substances that pose a substantial present or potential hazard to human health or the environment, such as radioactive or chemical contamination from facilities, equipment, or soils by washing, heating, chemical or electrochemical action, mechanical cleaning, or other techniques.

Depleted uranium - A mixture of uranium isotopes where uranium-235 represents less than 0.7 percent of the uranium by mass.

Derate - Reduction in operating power production level.

Design-basis accident - For nuclear facilities, information that identifies the specific functions to be performed by a structure, system, or component and the specific values (or ranges of values) chosen for controlling parameters for reference bounds for design. These values may be (I) restraints derived from generally accepted state-of-the-art practices for achieving functional goals; (2) requirements derived from analysis (based on calculation and/or experiments) of the effects of a postulated accident for which a structure, system, or component must meet its functional goals; or (3) requirements derived from Federal safety objectives, principles, goals, or requirements.

Design-basis events - Postulated disturbances in process variables that can potentially lead to design-basis accidents.

Distribution (electrical) - The system of lines, transformers, and switches that connect the transmission network and customer load. The transport of electricity to ultimate use points such as homes and businesses. The portion of an electric system that is dedicated to delivering electric energy to an end user at relatively low voltages.

Dose - The energy imparted to matter by ionizing radiation. The unit of absorbed dose is the rad.

Dose equivalent - The product of absorbed dose in rad (or Gray) and a quality factor, which quantifies the effect of this type of radiation in fissue. Dose equivalent is expressed in units of rem or Sievert, where 1 rem equals 0.01 Sievert.

Dose rate - The radiation dose delivered per unit time (e.g., rem per year).

Dosimeter - A small device (instrument) carried by a radiation worker that measures cumulative radiation dose (e.g., film badge or ionization chamber).

Drift - Effluent mist or spray carried into the atmosphere from cooling towers.

Final Supplemental Environmental Impact Statement

Drinking water standards - The level of constituents or characteristics in a drinking water supply specified in regulations under the Safe Drinking Water Act as the maximum permissible.

Effective dose equivalent - The sum of the products of the dose equivalent received by specified tissues of the body and a tissue-specific weighting factor. This sum is a risk-equivalent value and can be used to estimate the health effects risk to the exposed individual. The tissue-specific weighting factor represents the fraction of the total health risk resulting from uniform whole-body irradiation that would be contributed by that particular tissue. The effective dose equivalent includes the committed effective dose equivalent from internal deposition of radionuclides, and the effective dose equivalent due to penetrating radiation from sources external to the body. Effective dose equivalent is expressed in units of rem or Sievert.

Effluent - A gas or fluid discharged into the environment.

Endangered species - Any species which is in danger of extinction throughout all or significant portions of its range. The Endangered Species Act of 1973, as amended, establishes procedures for placing species on the Federal lists of endangered or threatened species.

Endangered Species Act of 1973 - The Act requires Federal agencies, with the consultation and assistance of the Secretaries of the Interior and Commerce, to ensure that their actions likely will not jeopardize the continued existence of any endangered or threatened species, or adversely affect the habitat of such species.

Engineered safety features - For a nuclear facility, features that prevent, limit, or mitigate the release of radioactive material from its primary containment.

Entrainment - The involuntary capture and inclusion of organisms in streams of flowing water; a term often applied to the cooling water systems of power plants/reactors. The organisms involved may include phyto-and zooplankton, fish eggs and larvae (ichthyoplankton), shellfish larvae, and other forms of aquatic life.

Environment - The sum of all external conditions and influences affecting the life, development, and ultimately the survival of an organism.

Environmental justice - The fair treatment of people of all races, cultures, incomes, and educational levels with respect to the development, implementation, and enforcement of environmental laws, regulations, and policies. Fair treatment implies that no population of people should be forced to shoulder a disproportionate share of the negative environmental impacts of pollution or environmental hazards due to a lack of political or economic influence.

Exposure to radiation - The incidence of radiation on living or inanimate material by accident or intent. Background exposure is the exposure to natural background ionizing radiation. Occupational exposure is the exposure to ionizing radiation that occurs at a person's workplace. Population exposure is the exposure to a number of persons who inhabit an area.

Exposure pathway - The course a chemical or physical agent takes from the source to the exposed organism. The pathway describes a unique mechanism by which an individual or population is exposed to chemicals or physical agents at or originating from the site. Each exposure pathway includes a source or release from a source, an exposure point, and an exposure route. If the exposure point differs from the source, a transport/exposure medium (e.g., air) is included.

Fission (fissioning) - The splitting of a nucleus into at least two other nuclei and the release of a relatively large amount of energy. Two or three neutrons are usually released during this type of transformation.

Fission products - Nuclei formed by the fission of heavy elements (primary fission products); also, the nuclei formed by the decay of the primary fission products, many of which are radioactive.

Floodplain - The lowlands adjoining inland and coastal waters and relatively flat areas.

Fuel assembly - A cluster of fuel rods (or plates), also called a fuel element. Approximately 200 fuel assemblies make up a reactor core.

Fuel rod - Nuclear reactor component that includes the fissile material.

Gamma rays - High-energy, short-wavelength, electromagnetic radiation accompanying fission and either emitted from the nucleus of an atom or emitted by some radionuclide or fission product. Gamma rays are very penetrating and can be stopped only by dense materials (such as lead) or a thick layer of shielding materials.

Habitat - The environment occupied by individuals of a particular species, population, or community.

Hazardous material - A material, including a hazardous substance, as defined by 49 CFR §171.8, which poses a risk to health, safety, and property when transported or handled.

Hazardous/toxic air pollutants - Air pollutants known or suspected to cause serious health problems such as cancer, poisoning, or sickness, and may have immunological, neurological, reproductive, developmental, or respiratory effects.

Hazardous waste - Any solid waste (can also be semisolid or liquid, or contain gaseous material) having the characteristics of ignitability, corrosivity, toxicity, or reactivity, defined by the Resource Conservation and Recovery Act, and identified or listed in 40 CFR Part 261 or by the Toxic Substances Control Act.

Heat exchanger - A device that transfers heat from one fluid (liquid or gas) to another.

High efficiency particulate air filter (HEPA) - A filter used to remove very small particulates from dry gaseous effluent streams.

High(ly) enriched uranium - Uranium that is equal to or greater than 20 percent uranium-235 weight. Many of the fuels discussed in this EIS are based primarily on highly enriched uranium.

Historic resources - Archaeological sites, architectural structures, and objects produced after the advent of written history dating to the time of the first Euro-American contact in an area.

Hybernacula - Places, e.g., caves or other protected areas, where bats hibernate during the winter.

Icthyoplankton - The early life stages of fish (eggs and larvae) that spend part of their life cycle as free-floating plankton.

Final Supplemental Environmental Impact Statement

Impingement - The process by which aquatic organisms too large to pass through the screens of a water intake structure become caught on the screens and are unable to escape.

Interim storage - Safe and secure storage for spent nuclear fuel and radioactive wastes until the materials are treated and/or disposed of).

Ion - An atom that has too many or too few electrons, causing it to be electrically charged; an electron that is not associated (in orbit) with a nucleus.

Ion exchange - A unit physiochemical process that removes anions and cations, including radionuclides, from liquid streams (usually water) for the purpose of purification or decontamination.

Ionizing radiation - Alpha particles, beta particles, gamma rays, neutrons, high-speed electrons, high-speed protons, and other particles or electromagnetic radiation that can displace electrons from atoms or molecules, thereby producing ions.

Irradiation - Exposure to radiation.

Isotope - An atom of a chemical element with a specific atomic number and atomic mass. Isotopes of the same element have the same number of protons, but different numbers of neutrons and 'different atomic masses. Isotopes are identified by the name of the element and the total number of protons and neutrons in the nucleus. For example, plutonium-239 is a plutonium atom with 239 protons and neutrons.

Laydown - Area of construction site used to sort and store construction materials.

Licensee amendment - Changes to an existing reactor's operating license that are approved by the U.S. Nuclear Regulatory Commission.

Light water - The common form of water (a molecule with two hydrogen atoms and one oxygen atom, H_20) in which the hydrogen atom consists completely of the normal hydrogen isotope (one proton).

Light water reactor - A nuclear reactor in which circulating light water is used to cool the reactor core and to moderate (reduce the energy of) the neutrons created in the core by the fission reactions.

Long-term lay-up - The shutdown of a generating facility to store or reserve for future use.

Low-level waste - Waste that contains radioactivity, but is not classified as high-level waste, transuranic waste, spent nuclear fuel, or by-product material as defined by Section lie (2) of the Atomic Energy Act of 1954, as amended. Test specimens of fissionable material irradiated for research and development only, and not for the production of power or plutonium, may be classified as low-level waste, provided the concentration of transuranic waste is less than 100 nanocuries per gram. Some low-level waste is considered classified because of the nature of the generating process and/or constituents, because the waste would tell too much about the process.

Macrophyte - An aquatic plant that grows in or near water and is emergent, submergent, or floating.

Makeup water - Replacement for water lost through drift, blowdown, or evaporation (as in a cooling tower).

Man-rem - Unit of radiation dose to an individual.

Maximally exposed individual - A hypothetical person who could potentially receive the maximum dose of radiation or hazardous chemicals.

Megawatt (MW) - A unit of power equal to 1 million watts. "Megawatt-thermal" is commonly used to define heat produced, while "megawatt-electric" defines electricity produced.

Millirem - One thousandth of a rem.

Minority population - A population classified by the Bureau of the Census as Black, Hispanic, Asian and Pacific Islander, American Indian, Eskimo, Aleut, and other nonwhite persons, the composition of which is at least equal to or greater than the state minority average of a defined area of jurisdiction.

National Ambient Air Quality Standards (NAAQS) - Uniform, national air quality standards established by the Environmental Protection Agency under the authority of the Clean Air Act that restrict ambient levels of criteria pollutants to protect public health (primary standards) or public welfare (secondary standards), including plant and animal life, visibility, and materials. Standards have been set for ozone, carbon monoxide, particulates, sulfur dioxide, nitrogen dioxide, and lead.

National Historic Preservation Act (NHPA) - This Act provides that property resources with significant national historic value be placed on the national Register of Historic Places. It does not require any permits, but, pursuant to Federal code, if a proposed action might impact an historic property resource, it mandates consultation with the proper agencies.

National Pollutant Discharge Elimination System (NPDES) - Federal permitting system required for water pollution effluents under the Clean Water Act, as amended.

National Register of Historic Places (NRHP) - A list maintained by the Secretary of the Interior of districts, sites, buildings, structures, and objects of prehistoric or historic local, state, or national significance under Section 2(b) of the Historic Sites Act of 1935(16 U.S.C. 462) and Section IOI(a) (1) (A) of the National Historic Preservation Act of 1966, as amended.

Nuclear reactor - A device that sustains a controlled nuclear fission chain reaction, which releases energy in the form of heat.

Nuclear Regulatory Commission (NRC) - The Federal agency that regulates the civilian nuclear power industry in the United States.

Nuclide - A species of atom characterized by the constitution of its nucleus and, hence, by the number of protons, the number of neutrons, and the energy content.

Outfall- The discharge point of a drain, sewer, or pipe as it empties into a body of water.

Peaking capacity - The capacity of facilities or equipment normally used to supply incremental gas or electricity under extreme demand conditions. Peaking capacity is generally available for a limited number of days at a maximum rate.

Peak load - The maximum load consumed or produced by a unit or group of units in a stated period of time.

Pellets - One configuration of the reactive material in a target rod.

Person-rem - The unit of collective radiation dose to a given population; the sum of the individual doses received by a population segment.

Plume - A flowing, often somewhat conical, trail of emissions from a continuous point source.

Plume immersion - With regard to radiation, the situation in which an individual is enveloped by a cloud of radiation gaseous effluent and receives an external radiation dose.

Pressurized water reactor - A light water reactor in which heat is transferred from the core to an exchanger by water kept under pressure in the primary system. Steam is generated in a secondary circuit. Many reactors producing electric power are pressurized water reactors.

Primary system - With regard to nuclear reactors, the system that circulates a coolant (e.g., water) through the reactor core to remove the heat of reaction.

Probabilistic risk assessment - A comprehensive, logical, and structured methodology to identify and quantitatively evaluate significant accident sequences and their consequences.

Probabilistic safety assessment - A systematic and comprehensive methodology of determining the risks associated with the operation of a nuclear plant.

Probable maximum flood - The hypothetical flood (peak discharge, volume, and hydrograph shape) that is considered to be the most severe reasonably possible, based on comprehensive hydrometeorological application of Probable Maximum Precipitation, and other hydrologic factors favorable for maximum flood runoff, such as sequential storms and snowmelt.

Probable maximum precipitation - The theoretically greatest depth of precipitation for a given duration that is physically possible over a particular drainage area at a certain time of year. (Reference: American Meteorological Society, 1959).

Processing (of spent nuclear fuel) - Applying a chemical or physical process designed to alter the characteristics of the spent fuel matrix.

Project area - The area within the BLN site where all construction activity would occur for either Alternative B or C. The project area includes the south security check point on Bellefonte Road shown in the map inset. The project area for the nuclear generation alternatives is shown on the B&W and AP1000 site plans (Figures 2-1 and 2-12, respectively).

Radiation - The emitted particles or photons from the nuclei of radioactive atoms. Some elements are naturally radioactive; others are induced to become radioactive by bombardment in a reactor. Naturally occurring radiation is indistinguishable from induced radiation.

Radiation shielding - Radiation-absorbing material that is interposed between a source of radiation and organisms that would be harmed by the radiation (e.g., people).

Radioactive waste - Materials from nuclear operations that are radioactive or are contaminated with radioactive material and for which use, reuse, or recovery are impractical.

Radioactivity - The spontaneous decay or disintegration of unstable atomic nuclei, accompanied by the emission of radiation.

Radiological - Related to radiology, the science that deals with the use of ionizing radiation to diagnose and treat disease.

Radwaste - Radioactive materials at the end of their useful life or in a product that is no longer useful and requires proper disposal.

Raw water – Untreated water from the plant intake supplied to the circulating water system and the service water system to make up for water which has been consumed and discharged as part of the system operations.

Reactor - A device or apparatus in which a chain reactor of fissionable material is initiated and controlled; a nuclear reactor.

Reactor accident - See "design basis accident; severe accident."

Reactor coolant system - The system used to transfer energy from the reactor core either directly or indirectly to the heat rejection system.

Reactor core - In a heavy water reactor: the fuel assemblies including the fuel and target rods, control assemblies, blanket assemblies, safety rods, and coolant/moderator. In a light water reactor: the fuel assemblies including the fuel and target rods, control rods, and coolant/moderator. In a modular high-temperature gas-cooled reactor: the graphite elements including the fuel and target elements, control rods, and other reactor shutdown mechanisms, and the graphite reflectors.

Reactor facility - Unless it is modified by words such as containment, vessel, or core, the term reactor facility includes the housing, equipment, and associated areas devoted to the operation and maintenance of one or more reactor cones. Any apparatus that is designed or used to sustain nuclear chain reactions in a controlled manner, including critical and pulsed assemblies and research, tests, and power reactors, is defined as a reactor. All assemblies designed to perform subcritical experiments that could potentially reach criticality are also to be considered reactors.

Record of decision (ROD) - A document prepared in accordance with the requirements of the Council on Environmental Quality and National Environmental Policy Act regulations 40 CFR §1505.2, that provides a concise public record of the decision on a proposed Federal action for which an environmental impact statement was prepared. A Record of Decision identifies the alternatives considered in reaching the decision, the environmentally preferable alternative(s), factors balanced in making the decision, whether all practicable means to avoid or minimize environmental harm have been adopted, and if not, why they were not.

Regolith - A layer of loose, heterogèneous material covering solid rock.

Final Supplemental Environmental Impact Statement

Repository - A place for the disposal of immobilized high-level waste and spent nuclear fuel in isolation from the environment.

Reprocessing (of spent nuclear fuel) - Processing of reactor-irradiated nuclear material (primarily spent nuclear fuel) to recover fissile and fertile material, in order to recycle such materials primarily for defense programs or generation of electricity. Historically, reprocessing has involved aqueous chemical separations of elements (typically uranium or plutonium) from undesired elements in the fuel.

Resin - An ion-exchange medium; organic polymer used for the preferential removal of certain ions from a solution.

Risk - In accident analysis, the probability-weighted consequence of an accident, defined as the accident frequently per year multiplied by the dose. The term "risk" also is used commonly in other applications to describe the probability of an event occurring.

Risk assessment (chemical or radiological) - The qualitative and quantitative evaluation performed in an effort to define the risk posed to human health and/or the environment by the presence or potential presence and/or use of specific chemical or radiological materials.

Runoff - The portion of rainfall, melted snow, or irrigation water that flows across the ground surface and eventually enters streams.

Safety analysis report (SAR) - A safety document that provides a complete description and safety analysis of a reactor design, normal and emergency operations, hypothetical accidents and their predicted consequences, and the means proposed to prevent such accidents or mitigate their consequences.

Safety evaluation report - A document prepared by the U.S. Nuclear Regulatory Commission that evaluates documentation (i.e., technical specifications, safety analysis reports, and special safety reviews and studies) submitted by a reactor licensee for its approval. This ensures that all of the safety aspects of part or all of the activities conducted at a reactor are formally and thoroughly analyzed, evaluated, and recorded.

Scoping - The solicitation of comments from interested persons, groups, and agencies at public meetings, public workshops, in writing, electronically, or via fax to assist in defining the proposed action, identifying alternatives, and developing preliminary issues to be addressed in an environmental impact statement.

Secondary system - The system that circulates a coolant (water) through a heat exchanger to remove heat from the primary system.

Seismic Category I - Safety-related structures, systems, and components that are designed and built to withstand the maximum potential earthquake stresses for the particular region where a nuclear plant is sited, without loss of capability to perform their safety functions.

Seismicity - The tendency for earthquakes to occur.

Severe accident - An accident with a frequency rate of less than 106 per year that would have more severe consequences than a design-basis accident, in terms of damage to the facility, off-

site consequences, or both. Also called "beyond design-basis reactor accidents" for this environmental impact statement.

Shutdown - For a U.S. Department of Energy (DOE) reactor, that condition in which the reactor has ceased operation and DOE has declared officially that it does not intend to operate it further (see DOE Order 5480.6, - Safely of Department of Energy-Owned Nuclear Reactors).

Source term - The estimated quantities of radionuclides or chemical pollutants released to the environment.

Spanned - Those areas of high relief where the transmission is high above the canopy such that ROW clearing is not necessary.

Spent nuclear fuel - Fuel that has been withdrawn from a nuclear reactor following irradiation, the constituent elements of which have not be separated.

Threatened species - Any species designated under the Endangered Species Act as likely to become an endangered species within the foreseeable future throughout all or a significant portion of its range.

Tier - To link to another in a hierarchical chain. An upper-tier document might be programmatic to the entire DOE complex of sites; a lower-tier document might be specific to one site or process.

Transient - A change in the reactor coolant system temperature, pressure, or both, attributed to a change in the reactor's power output. Transients can be caused by (1) adding or removing neutron poisons, (2) increasing or decreasing electrical load on the turbine generator, or (3) accident conditions.

Tritiated (liquid) - Tritiated liquid is water that contains tritium. The most common form of tritium is in water, because both radioactive tritium and nonradioactive hydrogen react with oxygen in the same way to form water. When this happens, tritium replaces one of the stable hydrogens in the water molecule, H2O, creating tritiated water, which is colorless, odorless, and radioactive.

Tritium - A radioactive isotope of the element hydrogen with two neutrons and one proton. Common symbols for the isotope are "H-3" and "T." Tritium has a half-life of 12.3 years.

Underbuilt - When one or more lines are strung on an existing transmission structure.

Uprate – The process of increasing the maximum power level a commercial nuclear power plant may operate.

Uranium - A heavy, silvery-white metallic element (atomic number 92) with several radioactive isotopes that is used as fuel in nuclear reactors.

Vault - A reinforced concrete structure for storing strategic nuclear materials used in national defense or other programmatic purposes, or for disposing of radioactive or hazardous waste.

Wetlands - Land or areas exhibiting the following: hydric soil conditions, saturated or inundated soil during some portion of the year, and plant species tolerant of such conditions; also, areas

Final Supplemental Environmental Impact Statement

that are inundated or saturated by surface water or groundwater at a frequency and duration sufficient to support, and that under normal circumstances do support, a prevalence of vegetation typically adapted for life in saturated soil conditions. Wetlands generally include swamps, marshes, bogs, and similar areas.

Whole-body dose - With regard to radiation, the dose resulting from the uniform exposure of all organs and tissues in a human body. (Also see effective dose equivalent.)

 χ /Q (Chi/Q) - The relative calculated air concentration due to a specific air release and atmospheric dispersion; units are (seconds per cubic meter). For example (Curies per cubic meter)/(Curies per second)= (seconds per cubic meter) or (grams per cubic meter)/(grams per second) = (seconds per cubic meter).

Page intentionally blank

INDEX

accident S-9, iv, vii, viii, xii, xiv, 32, 33, 47, 48, 52, 53, 67, 83, 88, 195, 203, 204 246, 247, 248, 249, 250, 251, 252, 299, 302, 311, 314, 316, 317, 334, 346, 349, 33 357, 358, 359, 360	
air quality S-9, iv, xv, 11, 20, 59, 60, 62, 63, 64, 83, 144, 146, 184, 192, 204, 203 349, 356	
airborne effluent	201
airborne release	
aquatic resource	
archaeological resource	
area of potential effect (APE)xi, 158, 15	9, 287, 288, 349
as low as reasonably achievable (ALARA)xi, 214, 219, 221, 223, 22	8, 232, 233, 349
atmospheric dispersion ix, xvii, 195, 200, 201, 203, 204, 221, 225, 245, 246, 31	4, 316, 346, 361
Babcock & Wilcox (B&W) S-1, S-2, S-3, S-4, S-5, i, vi, vii, viii, ix, xi, 1, 2, 4, 6, 18 28, 29, 31, 32, 34, 37, 38, 40, 41, 44, 53, 54, 68, 69, 71, 76, 77, 78, 79, 86, 87, 88, 97, 98, 99, 100, 101, 102, 104, 109, 110, 111, 112, 113, 114, 115, 116, 117, 118, 127, 129, 131, 132, 139, 140, 145, 147, 149, 150, 154, 155, 158, 159, 162, 163, 16 183, 188, 193, 195, 196, 198, 201, 202, 203, 207, 210, 211, 214, 215, 217, 219, 22 223, 224, 225, 227, 228, 229, 230, 232, 234, 235, 236, 237, 238, 239, 240, 242, 24 246, 247, 249, 250, 251, 253, 295, 302, 305, 315, 329, 330, 333, 349, 357	, 89, 91, 93, 96, 119, 125, 126, 54, 173, 182, 20, 221, 222, 43, 244, 245,
base caseS-2, viii, 11, 13, 14, 15, 16, 17	
base load	
base load capacity	
Baseline	
best management practices (BMPs)xi, 74, 91, 96, 126, 133, 144, 145, 149, 150 285, 287, 338, 341, 350	0, 260, 264, 279,
biological assessment (BA)xi, 146, 14	
biological opinion (BO)	
biomass	2, 113, 208, 338
	7 000 000 004
biota S-9, vii, 83, 116, 214, 224, 225, 260, 264, 271, 29	7, 298, 299, 301
blowdown S-3, S-5, ix, xii, xvi, 34, 52, 53, 54, 79, 86, 87, 97, 100, 104, 105, 107 111, 112, 113, 115, 117, 118, 119, 120, 150, 212, 224, 234, 350, 356	
blowdown S-3, S-5, ix, xii, xvi, 34, 52, 53, 54, 79, 86, 87, 97, 100, 104, 105, 107	7, 108, 109, 110,
 blowdown S-3, S-5, ix, xii, xvi, 34, 52, 53, 54, 79, 86, 87, 97, 100, 104, 105, 107, 111, 112, 113, 115, 117, 118, 119, 120, 150, 212, 224, 234, 350, 356 Browns Ferry Nuclear Plant (BFN)xi, 56, capacity S-1, S-2, i, vii, viii, 1, 4, 6, 7, 9, 10, 11, 12, 13, 14, 16, 18, 21, 22, 27, 35, 59, 60, 61, 62, 63, 64, 69, 70, 72, 91, 139, 173, 174, 176, 182, 183, 186, 18, 211, 213, 228, 236, 237, 242, 243, 279, 298, 307, 329, 330, 350, 357 	7, 108, 109, 110, 65, 66, 235, 237 3, 45, 52, 55, 56, 37, 188, 210,
 blowdown S-3, S-5, ix, xii, xvi, 34, 52, 53, 54, 79, 86, 87, 97, 100, 104, 105, 107, 111, 112, 113, 115, 117, 118, 119, 120, 150, 212, 224, 234, 350, 356 Browns Ferry Nuclear Plant (BFN)xi, 56, capacity S-1, S-2, i, vii, viii, 1, 4, 6, 7, 9, 10, 11, 12, 13, 14, 16, 18, 21, 22, 27, 357, 58, 59, 60, 61, 62, 63, 64, 69, 70, 72, 91, 139, 173, 174, 176, 182, 183, 186, 18, 211, 213, 228, 236, 237, 242, 243, 279, 298, 307, 329, 330, 350, 357 capacity factor	7, 108, 109, 110, 65, 66, 235, 237 3, 45, 52, 55, 56, 37, 188, 210, 4, 211, 307, 350
 blowdown S-3, S-5, ix, xii, xvi, 34, 52, 53, 54, 79, 86, 87, 97, 100, 104, 105, 107, 111, 112, 113, 115, 117, 118, 119, 120, 150, 212, 224, 234, 350, 356 Browns Ferry Nuclear Plant (BFN)xi, 56, capacity S-1, S-2, i, vii, viii, 1, 4, 6, 7, 9, 10, 11, 12, 13, 14, 16, 18, 21, 22, 27, 35, 59, 60, 61, 62, 63, 64, 69, 70, 72, 91, 139, 173, 174, 176, 182, 183, 186, 18, 211, 213, 228, 236, 237, 242, 243, 279, 298, 307, 329, 330, 350, 357 	7, 108, 109, 110, 65, 66, 235, 237 3, 45, 52, 55, 56, 37, 188, 210, 4, 211, 307, 350
 blowdown S-3, S-5, ix, xii, xvi, 34, 52, 53, 54, 79, 86, 87, 97, 100, 104, 105, 107, 111, 112, 113, 115, 117, 118, 119, 120, 150, 212, 224, 234, 350, 356 Browns Ferry Nuclear Plant (BFN)xi, 56, capacity S-1, S-2, i, vii, viii, 1, 4, 6, 7, 9, 10, 11, 12, 13, 14, 16, 18, 21, 22, 27, 33, 57, 58, 59, 60, 61, 62, 63, 64, 69, 70, 72, 91, 139, 173, 174, 176, 182, 183, 186, 18, 211, 213, 228, 236, 237, 242, 243, 279, 298, 307, 329, 330, 350, 357 capacity factorS-1, ix, xii, 1, 14, 17, 22, 115, 204, 207, 208, 209, 211, 234, 29 carbon cycle 	7, 108, 109, 110, 65, 66, 235, 237 3, 45, 52, 55, 56, 37, 188, 210, 4, 211, 307, 350 8, 307, 329, 356
blowdown	7, 108, 109, 110, 65, 66, 235, 237 3, 45, 52, 55, 56, 37, 188, 210, 4, 211, 307, 350 8, 307, 329, 356
blowdown S-3, S-5, ix, xii, xvi, 34, 52, 53, 54, 79, 86, 87, 97, 100, 104, 105, 107, 111, 112, 113, 115, 117, 118, 119, 120, 150, 212, 224, 234, 350, 356 Browns Ferry Nuclear Plant (BFN)xi, 56, capacity S-1, S-2, i, vii, viii, 1, 4, 6, 7, 9, 10, 11, 12, 13, 14, 16, 18, 21, 22, 27, 33, 57, 58, 59, 60, 61, 62, 63, 64, 69, 70, 72, 91, 139, 173, 174, 176, 182, 183, 186, 18, 211, 213, 228, 236, 237, 242, 243, 279, 298, 307, 329, 330, 350, 357 capacity factorS-1, ix, xii, 1, 14, 17, 22, 115, 204, 207, 208, 209, 211, 234, 29, carbon cycle	 7, 108, 109, 110, 65, 66, 235, 237 3, 45, 52, 55, 56, 37, 188, 210, 4, 211, 307, 350 8, 307, 329, 356
blowdown	 7, 108, 109, 110, 65, 66, 235, 237 45, 52, 55, 56, 7, 188, 210, 4, 211, 307, 350 8, 307, 329, 356 207, 208 39, 47, 192, 359 5, 139, 150, 151, 53, 355, 356, 7, 118, 119, 317
blowdown S-3, S-5, ix, xii, xvi, 34, 52, 53, 54, 79, 86, 87, 97, 100, 104, 105, 107, 111, 112, 113, 115, 117, 118, 119, 120, 150, 212, 224, 234, 350, 356 Browns Ferry Nuclear Plant (BFN)xi, 56, capacity S-1, S-2, i, vii, viii, 1, 4, 6, 7, 9, 10, 11, 12, 13, 14, 16, 18, 21, 22, 27, 33, 57, 58, 59, 60, 61, 62, 63, 64, 69, 70, 72, 91, 139, 173, 174, 176, 182, 183, 186, 18, 211, 213, 228, 236, 237, 242, 243, 279, 298, 307, 329, 330, 350, 357 capacity factorS-1, ix, xii, 1, 14, 17, 22, 115, 204, 207, 208, 209, 211, 234, 29, carbon cycle	 7, 108, 109, 110, 65, 66, 235, 237 3, 45, 52, 55, 56, 37, 188, 210, 4, 211, 307, 350 8, 307, 329, 356

-	12, 113, 207, 208, 209, 210, 212, 213, 309, 335, 336, 337
	iv, 20, 192
306, 307, 340	8, 27, 56, 59, 61, 62, 63, 64, 67, 208, 211, 262, 298, 305,
	xii, 21, 23, 93, 116, 165, 166, 167, 168, 170, 171, 172, 83, 187, 188, 227, 236, 237, 238, 239, 240, 241, 253,
-	xi, 70, 72, 74, 75, 265, 268, 286, 290, 292, 306, 351
	06, 104, 216, 217, 220, 226, 227, 240, 296, 300, 302, 304,
containment viii, xi, xii, xiv, 28, 32, 40 248, 249, 252, 351, 353, 358), 45, 46, 47, 48, 52, 53, 88, 127, 163, 201, 220, 232, 247,
	4, 35, 45, 52, 53, 54, 68, 77, 86, 87, 97, 99, 100, 104, 105, 20, 145, 146, 150, 158, 159, 160, 162, 163, 164, 165, 806, 330, 352, 356
140, 212, 213, 296, 300, 302, 304, 306, 3	
cost of power	
cultural resource	59, 63, 67, 70, 71, 287, 288, 313, 317, 319, 338, 351
cumulative effect 5, 6, 7, 22, 76, 79, 80, 141, 144, 146, 149, 150, 151, 155, 156, 1	81, 93, 104, 112, 119, 120, 127, 129, 130, 131, 139, 140, 59, 165, 183, 184, 189, 190, 203, 279
decay 33, s	53, 201, 202, 216, 232, 233, 239, 243, 350, 351, 354, 358
decibel (dB)	xii, 163, 164, 351, 352
decommissioning	iv, 20, 21, 186, 208, 211, 253, 254, 255, 297, 313, 352
decommissioning plan	
Demand Side Management (DSM)	xii, xiii, 7, 27, 56, 311
demand-side	
	23, 31, 59, 62, 68, 93, 116, 130, 131, 133, 139, 141, 145, 227, 236, 238, 239, 241, 243, 244, 253, 289, 291, 306,
derate	
design basis	
Detailed Scoping, Estimating, and Plann	ing (DSEP)xiii, 27, 37, 38, 41, 44, 188, 342
diesel 9, 24, 28, 33, 35, 44, 47, 52, 62, 307, 336	83, 88, 115, 119, 121, 126, 206, 207, 296, 297, 304, 306,
diffuser	97, 100, 105, 107, 108, 109, 110, 111, 112, 337, 339, 340
100, 101, 102, 103, 104, 105, 107, 108, 1	5, 27, 32, 33, 34, 46, 53, 54, 68, 78, 79, 86, 87, 88, 96, 97, 109, 110, 111, 112, 113, 114, 115, 116, 117, 120, 127, 217, 218, 220, 224, 226, 227, 232, 236, 239, 242, 243, 356, 357
discharge limit	
díspersion	
dissolved oxygen (DO)	xii, 94, 95, 108, 111, 112, 113, 260

Final Supplemental Environmental Impact Statement

dose S-9, vii, viii, xiv, xvi, xvii, 33, 78, 83, 195, 200, 201, 202, 203, 204, 214, 215, 216, 217, 219, 220, 221, 222, 223, 224, 225, 226, 227, 238, 240, 241, 244, 245, 246, 247, 248, 250, 251, 254, 297, 301, 314, 316, 317, 330, 336, 345, 346, 352, 353, 356, 357, 359, 361

dose equivalent xvii, 204, 223, 352, 353, 361 earthquakevii, 20, 37, 47, 190, 191, 192, 252, 333, 335, 337, 345, 346, 359 effluent...... vii, 34, 78, 104, 105, 108, 109, 110, 112, 113, 119, 150, 173, 193, 195, 201, 203, 214, 216, 217, 219, 220, 221, 222, 223, 224, 225, 226, 232, 244, 246, 296, 297, 301, 330, 345, 346, 352, 353, 354, 356, 357 Electric Power Research Institute (EPRI) xiii, 56, 57, 58, 64, 111, 117, 119, 209, 213, 252, 335 electricity.......S-1, S-3, 1, 4, 6, 7, 8, 9, 21, 56, 59, 60, 61, 64, 89, 114, 208, 211, 297, 298, 304, 306, 307, 329, 337, 352, 356, 357, 359 emissionS-1. S-9. vi. ix. 11. 14. 15. 16. 18. 24. 25. 62. 63. 83. 93. 155. 204. 206. 207. 208. 209. 210, 211, 228, 232, 241, 295, 296, 297, 298, 300, 301, 302, 305, 351, 357, 358 endangered speciesxiii, 24, 90, 151, 152, 275, 283, 309, 310, 314, 337, 345, 353, 360 Energy Efficiency and Demand Response (EEDR).... S-2, ix, xiii, 11, 12, 13, 14, 15, 16, 17, 18, 56. 57, 58, 312, 335 environmental impact statement (EIS)...... S-3, xii, xiii, xvi, 4, 18, 21, 22, 23, 55, 59, 67, 68, 170, 171, 255, 297, 307, 328, 335, 337, 339, 341, 344, 346, 354 environmental justice S-7, S-11, v, 20, 59, 67, 81, 85, 169, 170, 171, 289, 295, 296, 313, 317, 342, 353 essential raw cooling water (ERCW) xiii, 32, 113, 116, 117, 119 exclusion area boundary (EAB) viii, ix, xiii, 34, 36, 53, 195, 196, 197, 201, 202, 203, 204, 215, 225, 246, 247, 248 Executive Order (EO)S-10, xiii, 25, 26, 128, 129, 130, 131, 142, 278, 279, 280, 289 federally listed S-6, S-10, vii, viii, 24, 80, 84, 90, 91, 146, 147, 148, 149, 150, 151, 152, 153, 154, 155, 267, 269, 270, 271, 272, 273, 274, 275, 277, 283 final environmental impact statement (FEIS) xii, xiii, xvi, 21, 22, 23, 55, 67, 93, 116, 127, 141, 165, 166, 167, 168, 170, 171, 172, 173, 174, 175, 176, 177, 178, 179, 182, 183, 186, 187, 188, 213, 227, 236, 237, 238, 239, 240, 241, 253, 289, 340, 341, 344 final environmental statement (FES).... S-1, S-2, xi, xiii, 1, 4, 7, 18, 21, 23, 27, 28, 53, 64, 66, 67, 89, 93, 104, 116, 120, 127, 141, 154, 165, 166, 167, 170, 171, 172, 173, 174, 176, 177, 178, 179, 182, 183, 184, 185, 190, 191, 192, 204, 206, 207, 214, 215, 216, 220, 221, 227, 228, 232, 236, 241, 245, 247, 253, 254, 339, 340, 342 Final Safety Analysis Report (FSAR) .xii, xiii, 4, 5, 6, 23, 28, 46, 116, 118, 120, 127, 129, 190, 191, 192, 217, 218, 221, 227, 228, 234, 242, 245, 246, 247, 248, 338, 339, 340, 341, 342 fish passage......139

Final Supplemental Environmental Impact Statement

365

fission	
floodS-5, ii, xiii, 19, 33, 45, 47, 54, 79, 94, 97, 127, 128, 12	29, 130, 194, 278, 279, 315, 357
flood risk	5, 79, 127, 128, 129, 130
floodplainS-5, S-10, ii, 25, 79, 84, 127, 128, 129, 276, 27	77, 278, 279, 280, 287, 315, 354
forecast	3, 9, 11, 210, 310, 311, 312, 329
fossil 1, 2, 4, 6, 11, 13, 21, 56, 59, 61, 62, 63, 64, 135, 165, 186 302, 306, 307, 310, 316	6, 208, 210, 211, 212, 298, 300,
fuel assembly2	2, 31, 48, 88, 236, 237, 244, 354
fuel cost	11, 13, 17, 18
fuel cycle	210, 305, 306
fuel price	2, 8, 10, 18
fuel rod	
garden	201, 202, 214, 221, 226, 227
gas-fired	12, 13, 14, 59, 63, 210, 298
generating capacity	21, 27, 55, 63, 64, 89, 210, 298
global climate change (GCC)iv, xiii, 20, 9	93, 192, 207, 209, 210, 298, 335
global warming	
gray bats	
greenhouse	
greenhouse gas (GHG)xiii, 6	63, 207, 208, 210, 211, 298, 307
groundwater S-5, S-10, ii, iv, ix, 19, 38, 79, 84, 120, 121, 124, 128 261, 262, 263, 264, 311, 314, 336, 337, 339, 361	5, 126, 127, 130, 189, 226, 260,
hazardous waste	38, 189, 190, 297, 304, 354, 360
heat dissipation	
heat load	
herons	45, 160, 214, 224, 225, 268, 269
Hollywood	77, 180, 184, 322, 323, 324, 329
housingS-4, S-7, S-11, iii, xiv, 81, 85, 90, 163, 170, 171, 172, 173 358	3, 178, 182, 237, 295, 343, 350,
human health	
hybernacula	354
hydrologic11	12, 128, 295, 296, 306, 337, 357
hydrologyS-5, S-10, ii, 79, 84, 93, 108, 111, 12	20, 126, 127, 131, 226, 278, 311
hydropower	11, 62, 344
hydrothermal ii, 22, 93, 10	04, 108, 113, 314, 315, 318, 337
icthyoplankton	
impingement	40, 150, 151, 296, 339, 341, 355
income S-7, S-11, iii, vii, 81, 85, 166, 167, 168, 16	59, 170, 171, 288, 289, 343, 344
Indiana bats6, 80, 90, 15	52, 153, 154, 274, 275, 337, 338
instream temperatures	
intake S-3,S- 6, ix, 5, 27, 28, 32, 34, 45, 52, 53, 54, 68, 77, 78, 80, 103, 104, 105, 109, 110, 111, 112, 119, 129, 130, 136, 139, 140, 14, 330, 342, 358	
intake channel 3, 6, 32, 34, 45, 53, 54, 77, 78, 80, 86, 97, 99, 100 150, 330	0, 110, 129, 130, 139, 141, 149,
intake flows	

Final Supplemental Environmental Impact Statement

366

Integrated Resource Management Plan (IRP)	
irradiation	
Jackson County S-1,S- 4, vii, ix, x, 1, 2, 23, 90, 100, 113, 119, 1 149, 151, 152, 153, 155, 158, 165, 166, 167, 168, 170, 171, 172, 179, 180, 181, 182, 183, 194, 204, 206, 207, 271, 280, 283, 322, 341, 343, 344	173, 174, 175, 176, 177, 178,
landfill 61, 62, 184, 1	
life cycle	
light water reactorS-1, S-2, i, ix, xi, xvi, 1, 4, 15, 21, 27, 28, 31, 333, 355, 357, 358	46, 47, 68, 86, 87, 241, 305, 329,
Limestone County	
liquid effluents	
liquid radwaste	
load forecast	
long-term lay-up	
low-level radwaste	
meteorological x, 34, 53, 55, 104, 112, 127, 193, 195, 200, 2 250, 297, 312, 333, 346, 357	
meteorology iv, 20, 108, 110, 111, 192, 193, 195, 209, 213, 2 341	
methane	
microbiological	
minimum flow	
minorityS-7, S-11, iii, 81, 85, 168, 169, 1	
mitigation S-3, S-4, S-6, S-10, ii, 19, 25, 27, 71, 74, 76, 80, 8 172, 182, 183, 211, 246, 255, 273, 274, 277, 278, 279, 285, 295,	
mixing zone	
Morgan County	
mussel sanctuary	
mussels 4, 6, 80, 113, 115, 116, 138, 139, 147, 148, 149, 150, 7	
National Environmental Policy Act (NEPA) S-3, i, vi, xv, 2, 1 184, 185, 186, 289, 297, 309, 310, 312, 313, 314, 328, 340, 358	
National Historic Preservation Act (NHPA)	
National Pollutant Discharge Elimination System (NPDES) vi 104, 105, 106, 107, 108, 110, 111, 112, 115, 117, 119, 120, 139,	149, 150, 213, 296, 356
National Register of Historic Places (NRHP)	
National Wetlands Inventory (NWI)	
natural area S-7, S-10, ii, v, viii, xvi, 19, 67, 70, 71, 81, 84, 154, 1 318	
natural gas 10, 12, 13, 14, 15	
near-field effects	
Noise S-4, S-7, S-11, iii, v, xiv, 20, 81, 85, 90, 154, 155, 156, 1 296, 319, 335, 344	63, 164, 165, 289, 290, 293, 295,
nonhazardous25, 78, 4	
nonradiological	126, 184, 185, 188, 189, 190
nontritiated	
NPDES permit	117, 119, 120, 149, 150, 213, 296

nuclear capacity	
nuclear expansion	
nuclear generation S-2, S-3, ii, 2, 13, 16, 18, 27, 55, 59 158, 210, 329, 335, 357	9, 62, 64, 65, 66, 68, 71, 75, 76, 93, 146,
nuclear reactor 65, 66, 135, 184, 214, 240, 252, 298, 301, 357, 358, 360	
peak load	
peaking capacity	
permit limits	
photovoltaic (PV)	xvi, 60, 61
pink mucket4	, 6, 80, 90, 147, 148, 149, 150, 151, 270
plume 7, 78, 81, 108, 110, 112, 131, 133, 139, 150, 162, 311, 316, 357	
population growth	
poverty level	
power purchase agreement (PPA)	
Preliminary Safety Analysis Report (PSAR)	xvi, 127
pressurized water reactor	
probabilistic risk assessment (PRA)	
probabilistic safety assessment (PSA)	
probable maximum flood (PMF)	
probable maximum precipitation (PMP)	
radiation xiv, xvi, 24, 33, 52, 60, 195, 214, 216, 219, 220, 241, 244, 252, 254, 301, 336, 346, 349, 350, 351, 352, 35	, 221, 222, 223, 224, 226, 233, 238, 240
radioactive waste 20, 86, 126, 227, 228, 232, 233, 234, 355, 358	
radiological effect	
radiological impact	
radiological release	·
radionuclides	
radwastevii, ix, xvi, 20, 47, 48, 127, 220, 227	
raw water	
reactor coolant pump	
reactor coolant system (RCS)31, 32, 33, 47,	
reactor core	
reconductoring	
record of decision (ROD)S-	•
recreation	
recreational	
renewable	
reserve capacity	
Reservoir Operations Study (ROS)	
residence	
285, 293, 338	
Resource Conservation and Recovery Act (RCRA)	xvi, 24, 25, 28, 185, 354

Final Supplemental Environmental Impact Statement

[,]368

Index

	iii, 171, 178, 179, 300, 301
	37, 56, 63, 76, 79, 88, 91, 126, 127, 128, 129, 144, 3, 279, 291, 296, 297, 299, 302, 310, 315, 319,
safety S-5, iv, xv, xvi, 2, 6, 20, 21, 28, 32, 33, 3	7, 39, 44, 46, 47, 48, 52, 53, 67, 70, 72, 76, 77, 79, 213, 214, 221, 223, 224, 238, 244, 245, 248, 249,
251, 252, 292, 297, 316, 318, 328, 330, 339, 34	· · ·
	6, 23, 28, 46, 70, 71, 116, 118, 120, 127, 129, 190, 5, 246, 247, 248, 257, 287, 338, 339, 340, 341,
Safety Evaluation Report	
schoolsS-4, S-7, iii, 8	81, 90, 171, 176, 177, 178, 263, 295, 300, 301, 334
Scottsboro 2, 20, 34, 67, 69, 99, 121, 160, 165 217, 257, 322, 323, 324, 327, 328	, 166, 170, 172, 173, 174, 175, 176, 177, 180, 184,
security iv, 20, 27, 34, 35, 38, 45, 76, 93, 100 357	, 166, 180, 182, 244, 251, 252, 253, 254, 299, 328,
seismicS-9, xi, 3	32, 37, 38, 39, 47, 82, 190, 191, 192, 333, 345, 359
seismology	S-9, iii, 20, 82, 190, 316
Sequoyah Nuclear Plant (SQN) xvii, 56, 65, 66	6, 188, 189, 227, 235, 236, 237, 238, 239, 240, 283
severe accident	
sheepnose mussel	
	54, 182, 187, 233, 235, 242, 243, 244
socioeconomicsS-7, S-11, iii, v, 1, 20, 59, 63 295, 296, 298, 299, 300, 301, 303, 304, 311, 31	, 67, 81, 85, 93, 165, 170, 171, 183, 184, 288, 289, 3, 317, 318, 319, 328
solar	S-2, xii, 10, 60, 62, 63, 64, 112
solid waste	28, 78, 184, 185, 186, 187, 188, 189, 234, 254, 354
spent fuel	3, 239, 242, 243, 244, 297, 298, 304, 305, 330, 357
state-listed 4, 6, 10, 80, 84, 90, 91, 146, 149 273, 274, 277, 278, 283	, 150, 151, 152, 153, 154, 155, 267, 269, 271, 272,
steam generator` 31, 37, 44, 45, 46, 48, 54, 207, 234, 330	77, 86, 97, 113, 114, 115, 118, 163, 164, 187, 204,
207, 234, 330	77, 86, 97, 113, 114, 115, 118, 163, 164, 187, 204,
207, 234, 330 storage module	
207, 234, 330 storage module supply-side	
207, 234, 330 storage module supply-side surface water 5, 10, 79, 84, 96, 99, 100, 112 263, 264, 265, 296, 297, 304, 306, 350, 361 sustainable switchyard S-3, viii, 5, 27, 28, 34, 40, 45, 4 279, 280, 286, 289 tax revenue	
207, 234, 330 storage module supply-side	
207, 234, 330 storage module supply-side	
207, 234, 330 storage module	
207, 234, 330 storage module supply-side	
207, 234, 330 storage module supply-side	
207, 234, 330 storage module supply-side	

÷

tornado.....x, xiii, 32, 47, 194, 319 traffic S-4, S-7, xi, 81, 90, 91, 159, 160, 162, 163, 170, 179, 180, 182, 183, 184, 188, 206, 207, 274, 286, 288, 295, 296, 300, 301, 333 transmission.... S-2, S-3, S-4, S-10, i, ii, iv, vi, viii, ix, x, xvii, 2, 5, 6, 7, 8, 18, 20, 27, 34, 45, 48, 53, 54, 56, 62, 63, 65, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 84, 86, 89, 90, 91, 97, 129, 146, 147, 153, 160, 178, 184, 257, 260, 261, 262, 263, 264, 265, 266, 267, 268, 269, 270, 271, 272, 273, 274, 275, 276, 277, 278, 279, 280, 281, 282, 283, 284, 285, 286, 287, 288, 289, 290, 291, 292, 293, 295, 296, 297, 298, 299, 301, 303, 306, 310, 312, 313, 316, 328, 329, 334, 338, 341, 342, 351, 352, 360 transportationS-7, iii, iv, xi, xii, 20, 54, 55, 67, 81, 90, 93, 144, 151, 166, 170, 172, 179, 180, 182, 183, 241, 242, 243, 244, 252, 297, 298, 304, 310, 314, 316, 333, 342, 345 tritiumxii, 21, 23, 68, 121, 126, 127, 180, 186, 237, 312, 341, 344, 360 turbine ... vii, viii, 4, 6, 10, 13, 21, 28, 32, 35, 37, 38, 40, 41, 44, 47, 48, 52, 53, 56, 59, 60, 62, 63, 77, 86, 114, 115, 118, 162, 184, 189, 201, 202, 203, 220, 222, 232, 330, 360 U.S. Fish and Wildlife Service (USFWS) S-4, xvii, 19, 24, 90, 131, 142, 147, 150, 151, 154, 269, 272, 275, 278, 321, 338, 341, 345 visualS-7, S-10, iii, v, 20, 39, 48, 81, 84, 121, 127, 158, 159, 160, 162, 286, 287, 288, 317, 349 wastewater....S-3, S-7, iii, 5, 25, 27, 46, 61, 62, 81, 97, 100, 104, 105, 113, 119, 121, 173, 174, 185. 310, 311, 314 water guality S-5, S-10, ii, xii, 20, 25, 79, 84, 93, 94, 96, 97, 105, 108, 111, 112, 116, 117, 119, 120, 126, 130, 138, 139, 149, 257, 260, 264, 271, 296, 310, 311, 314, 328, 333, 334, 339, 340, 350 water supplyS-5, S-7, iii, 10, 22, 67, 79, 81, 93, 94, 104, 126, 173, 174, 226, 260, 322, 339, 353 water use...... S-5, S-10, ii, vi, 59, 79, 84, 87, 93, 99, 104, 113, 156, 173, 216, 240, 295, 296, 300, 334, 351 Watts Bar Nuclear Plant (WBN) xvii, 19, 56, 65, 66, 140, 150, 227, 235, 236, 312, 341 wetlandS-4, S-6, S-10, ii, v, ix, x, 19, 25, 26, 67, 70, 74, 80, 84, 90, 91, 130, 131, 132, 133, 134, 145, 146, 153, 265, 268, 276, 278, 279, 282, 313, 335, 338, 345, 360 Widows Creek Fossil Plant (WCF) xvii, 69, 99, 111, 112, 136, 137, 138, 140, 162, 341 wildlife .. S-6, S-10, ii, v, xvii, 80, 84, 94, 145, 146, 152, 153, 154, 155, 156, 260, 267, 268, 269, 274, 278, 281, 282, 283, 284, 285, 296, 303, 309, 313, 314, 315, 318, 321, 322, 335, 339, 345 wind S-2, xiii, 6, 10, 11, 13, 14, 32, 55, 56, 59, 60, 62, 63, 64, 128, 129, 130, 193, 194, 195, 207, 226.344

Final Supplemental Environmental Impact Statement

370

Document Type: Index Field:

EIS-Administrative Record Final Environmental Document Single Nuclear Unit at the Bellefonte Site 2009-22

Project Name: Project Number:

VOLUME 2: APPENDICES

FINAL SUPPLEMENTAL ENVIRONMENTAL IMPACT STATEMENT

SINGLE NUCLEAR UNIT AT THE BELLEFONTE PLANT SITE Jackson County, Alabama

PREPARED BY: TENNESSEE VALLEY AUTHORITY

MAY 2010

Page intentionally blank

TABLE OF CONTENTS – VOLUME 2

Appendix A – TVA August 2009 Letter requesting deferred status and NRC January 2010 Letter Authorizing BLN Units 1 and 2 Deferred Status	A-1
Appendix B – NRC Reports on 2009 BLN Inspection for Transition to Deferred Status	A-19
Appendix C – Responses to Agency and Public Comments	A-47
Appendix D – Sensitive Area Review Process	A-125
Appendix E – CORMIX Modeling Results	A-139
Appendix F – Wetlands Field Delineation and Habitat	A-149
Appendix G – Reservoir Fish Assemblage	A-191
Appendix H – Agency Consultation	A-207
Appendix I – BLN Meteorological Tower Data,	A-279
Appendix J – BLN Meteorological Tower Data, Comparison of Data From Different	
Periods	A-287
Appendix K – Tornadoes in Jackson County, Alabama, 1980 to 2008	A-293
Appendix L – Power System Operations	A-297
Appendix M – Tennessee Valley Authority	A-305
Appendix N – Tennessee Valley Authority Transmission Construction Guidelines Near Streams	A-313
Appendix O – State-Listed Animal and Plant Species Present in Areas Affected by Transmission Line Work	

LIST OF MATERIAL IN VOLUME 1

- 1.0 PURPOSE OF AND NEED FOR ACTION
- 2.0 ALTERNATIVES INCLUDING THE PROPOSED ACTION
- 3.0 NUCLEAR GENERATION ALTERNATIVES ON THE BELLEFONTE SITE AFFECTED ENVIRONMENT AND ENVIRONMENTAL CONSEQUENCES
- 4.0 TRANSMISSION SYSTEM ALTERNATIVES AFFECTED ENVIRONMENT AND ENVIRONMENTAL CONSEQUENCES
- 5.0 OTHER EFFECTS
- 6.0 LIST OF PREPARERS
- 7.0 DISTRIBUTION OF FSEIS
- 8.0 LITERATURE CITED
- GLOSSARY

INDEX

Page intentionally blank

APPENDIX A – TVA AUGUST 2009 LETTER REQUESTING DEFERRED STATUS AND NRC JANUARY 2010 LETTER AUTHORIZING BLN UNITS 1 AND 2 DEFERRED STATUS

Page intentionally blank

Tennessee Valley Authority, 1101 Market Street, LP 5A, Chattanooga, Tennessee 37402-2801

August 10, 2009

10 CFR 50 54 (a) 10 CFR 50.55 (I)

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

In the Matter of **Tennessee Valley Authority** ì Docket No. 50-438 and 50-439

TENNESSEE VALLEY AUTHORITY (TVA) - BELLEFONTE NUCLEAR PLANT (BLN) UNITS 1 (CPPR-122) AND 2 (CPPR-123) - TRANSITION TO DEFERRED STATUS

References: 1) Letter from A. Bhatnagar (TVA) to Eric Leeds (NRC) dated August 26 2008, Bellefonte Nuclear Plant Units 1 and 2-Request to Reinstate Construction Permits CPPR-122 (Unit 1) and CPPR-123 (Unit 2).

- 2) Letter from L. Raghavan (NRC) to A. Bhatnagar (TVA), Bellefonte Nuclear Plant, Units 1 and 2-Order Granting Reinstatement of Construction Permits Nos. CPPR-122 and CPPR-123 (TAC Nos. MD9564 and MD9565, dated March 9, 2009.
- 3) Letter from Masoud Bajestani (TVA) to NRC, TVA Implementation of the NRC Order Granting Reinstatement of Construction Permits Nos. CPPR-122 and CPPR-123, dated May 12, 2009.

In response to TVA's request for the reinstatement of the BLN Construction Permits for Units 1 (CPPR-122) and 2 (CPPR-123) (Reference 1), NRC issued an Order (Reference 2) granting reinstatement of the BLN Construction Permits returning the facility to a "terminated plant" status under Section III.B of the Commission's Policy Statement on Deferred Plants (52 FR 38077, October 14, 1987). Shortly thereafter, TVA acknowledged the NRC's reinstatement of the Construction Permits stating that TVA had placed the units in terminated status and that TVA had revised its Nuclear Quality Assurance Plan (NQAP) to address that fact (Reference 3). In Reference 3, TVA also committed to address the elements of the Commission's Policy Statement that applied to plants in deferred status and to transition to such status as soon as practicable.

U. S. Nuclear Regulatory Commission Page 2 August 10, 2009

The purpose of this letter is to confirm that TVA has established the necessary programs, policies and procedures to warrant BLN 1&2 being placed in deferred status consistent with the Policy Statement.

TVA's Bellefonte plant is located near Scottsboro, Alabama, and consists of two substantially complete Babcock and Wilcox pressurized water reactors. BLN Units 1&2 were first placed in the deferred status in 1988 and were actively maintained in that status prior to the withdrawal of the Construction Permits in 2006. Up to the time of withdrawal, NRC performed periodic inspections of the preservation and maintenance program activities and documented the results in inspection reports, indicating that the preservation and maintenance activities were being performed in an acceptable manner. During active construction and through the period of construction deferral, the Bellefonte site successfully maintained a high rating under the NRC's Systematic Assessment of Licensee Performance (SALP) Program, and the BLN construction project was specifically excluded in the September 1985 letter issued to TVA under 10 CFR 50.54(f).

Before TVA requested that NRC reinstate the Construction Permits, TVA began assessing the deferred plant programs and procedures as well as the preservation and maintenance activities that were in place while the BLN units were deferred. With this baseline of work and considering lessons-learned from the Watts Bar Unit 2 deferred plant program, TVA has developed and implemented the set of programs and procedures deemed appropriate for application to BLN Units 1&2 in deferred status. Since reinstatement of the Construction Permits in March 2009, TVA has resumed preservation and maintenance activities aimed at protecting selected plant assets. Work performed during the deferral period will support such preservation and maintenance activities and at no time during such period will work be performed which would further plant construction or completion.

TVA has examined the provisions of the Deferred Plant Policy and has addressed each of its elements to ensure continued compliance. For instance, TVA will make certain that the current Construction Permits will not expire. The expiration dates for Construction Permit Nos. CPPR-122 and CPPR-123 are October 1, 2011, and October 1, 2014, respectively. In accordance with Section III.A.2 of the Policy Statement, TVA will make a timely request for renewal of the permits in accordance with NRC's regulations.

In accordance with Section III.A.3 of the Deferred Plant Policy, TVA has established the necessary programs and procedures to maintain and preserve equipment as well as to retain and protect plant records. As mentioned above, TVA has instituted a quality assurance program under 10 CFR Part 50, Appendix B, commensurate with the level of activities at a deferred plant. Also, NRC Regulatory Guides endorsing the ANSI N45.2 series of standards, "Quality Assurance Requirements for Nuclear Power Plants," are applicable to plants under construction including Regulatory Guides 1.28, 1.37, 1.38,

Appendix A

U. S. Nuclear Regulatory Commission Page 3 August 10, 2009

1.58, 1.88 and 1.118. The Enclosure to this letter addresses with greater specificity the elements of Section III.A.3 as they apply to BLN 1&2 in deferred plant status.

TVA recognizes the need to address the lapse in quality assurance oversight that occurred in the period from withdrawal of the Construction Permits through March 2009 when the NQAP was reestablished as described above. TVA has identified the key impacts to be addressed and has entered them into the BLN Corrective Action Program. TVA's current NQAP addresses those elements of the Deferred Plant Policy applicable to BLN, as well as the regulatory requirements that continue to apply to plants in the deferred status. TVA has also implemented work process controls to prevent construction-related activities from being conducted until the provisions of the policy regarding resumption of construction have been successfully addressed.

TVA also reviewed the new regulatory requirements that have been issued since the June 1988 deferral through July 2009. No new regulatory requirements were deemed applicable to BLN which would affect activities to be undertaken during the period of deferral.

During the deferral period and consistent with the licensing process being used at Watts Bar Unit 2, TVA plans to develop and submit a BLN Units 1&2 Key Assumptions letter for NRC's review and consideration. This Key Assumptions letter will formally document the initial licensing basis for the BLN Units based on the findings of the original BLN Construction Permits and the consideration of applicable new regulations.

As TVA stated in Reference 1, any future decision to resume BLN construction activities would require approval by the TVA Board of Directors. Should TVA decide to move forward with completion activities, it would follow the notice of resumption of construction activities included in the Deferred Plant Policy. This would include submitting a letter notifying the NRC Director of Nuclear Reactor Regulation a minimum of 120 days in advance of the intent to resume construction, along with the other information listed in Section III.A.6 of the policy.

In the event of such a decision to move forward with construction, TVA will develop a detailed Regulatory Framework for BLN 1&2. This will include review of previously issued Generic Letters, Bulletins, Circulars, and Information Notices for applicability and appropriate disposition. The Regulatory Framework would also contain a review of new standards, guidance and regulation for applicability to BLN, and review of previous commitments and open items related to licensing. NRC's formal license review would follow TVA's submittal of an updated Operating License application, including an amendment to the Bellefonte Units 1&2 Final Safety Analysis Report (FSAR) and an updated Environmental Report. NRC's review of the Operating License application would be expected to include, among other things, a review of the Probable Maximum Flood (PMF) calculation for the Bellefonte site.

U. S. Nuclear Regulatory Commission Page 4 August 10, 2009

TVA understands if a decision is made to begin construction, the NRC staff will thereafter also determine the acceptability of structures, systems, and components (SSCs) important to safety under 10 CFR Part 50, Appendix A. TVA recognizes that the limited activities performed while the plant is in deferred status, as well as NRC inspections performed during that period, will be utilized to determine the acceptability of SSCs important to safety. At the appropriate time, TVA intends to develop programs for BLN 1&2 similar to those that are being implemented at Watts Bar Unit 2 for the configuration control process and the corresponding programs to evaluate, refurbish, restore or replace SSCs.

Efforts to transition BLN Units 1&2 to deferred plant status do not affect, in any way, TVA's ability or current plans to pursue a Combined License for BLN Units 3&4 under 10 CFR Part 52, and the licensing information submitted to the NRC for the purpose of supporting the Combined License Application remains valid. The transition to deferred plant status has always been considered as a necessary step in TVA's assessment of the viability of BLN Units 1&2 as a baseload generation option. Should TVA decide to reactivate construction in the future, TVA will address the resulting impacts on the BLN Unit 3&4 Combined License Application.

In Reference 1, TVA described the Environmental Assessment which it conducted in connection with its request for reinstatement of the BLN Units 1&2 Construction Permits and returning the plant to deferred status. TVA concluded that the limited consequences of reinstating the Construction Permits in deferred status would not have a significant effect on the quality of the human environment. The NRC Staff prepared an "Environmental Assessment and Finding of No Significant Impact" (74 FR 9308, March 3, 2009) in which it determined that reinstating the Construction Permits and placing the facility in terminated status will not have a significant impact on the environment. TVA has reconfirmed that the limited activities to be conducted during the deferral period remain bounded by the limited impacts to the environment described in the NRC's Environmental Assessment.

TVA has identified those Federal, State and local license and permit requirements that are applicable to the BLN Units 1&2 in deferred status. TVA confirmed that the applicable licenses and permits remain current and that renewal processes are being included in the integrated project schedule.

In conclusion, TVA has taken the necessary actions to address those elements of the Commission's Policy Statement for Deferred Plants to allow BLN 1&2 to be placed in deferred status. In order to confirm compliance with the policy, TVA performed a multi-level readiness assessment which included internal and external reviews by nuclear Quality Assurance and licensing experts, as well as a formal TVA Nuclear Quality

U. S. Nuclear Regulatory Commission Page 5 August 10, 2009

Assurance Audit performed in accordance with TVA NQAP requirements. The results of these assessments are documented and any necessary follow-up actions are being addressed under the BLN Corrective Action Program. In accordance with the NRC's Order reinstating the Construction Permits, TVA respectfully requests that NRC authorize placement of BLN Units 1&2 in deferred plant status.

If you have questions or require additional information, please do not hesitate to contact Andrea Sterdis, Manager, Nuclear Generation Development and Construction Licensing. Andrea can be reached via email at andreasterdis@tva.gov or by phone at 423-751-7119.

Ashok Bhatnagar Senior Vice President Nuclear Generation Development & Construction

Enclosure cc: See page 8

U. S. Nuclear Regulatory Commission Page 6 August 10, 2009

ENCLOSURE

BELLEFONTE NUCLEAR POWER PLANT UNITS 1 AND 2 TRANSITION TO DEFERRED STATUS

In accordance with NRC's Policy Statement on Deferred Plants, TVA has addressed the elements of the policy which apply to the maintenance and preservation of equipment as well as the retention and protection of plant records at BLN Units 1&2. (Section III.A.3)

TVA has implemented a Quality Assurance Program that complies with the applicable requirements of 10 CFR 50, Appendix B for BLN Units 1&2 as documented in Appendix G of the TVA Nuclear Quality Assurance Program (NQAP). TVA has also established an organization and management team that is well qualified and experienced to carry out their responsibilities for site activities. The management team includes a Project Director (who reports directly to the Vice President of Nuclear Generation Development) and experienced, senior managers within the disciplines of engineering, training, construction, licensing, project controls and nuclear operations. In addition, a Project Nuclear Assurance Manager has been appointed and reports to the General Manager for Nuclear Generation Development and Construction Oversight. In accordance with 10 CFR Appendix B and the TVA NQAP, the Bellefonte Nuclear Assurance Manager is independent of the Bellefonte Project Management organization.

Under the terms of the Bellefonte Quality Assurance Program, necessary programs and procedures have been re-established and implemented to address the maintenance, preservation, and documentation of equipment provisions of the Deferred Plant Policy as they apply to deferral-related activities that are being performed at the site. These activities include the following:

- Preventative maintenance and layup activities are being performed under established programs and procedures which limit physical work on plant systems, structures and components (SSCs) as appropriate. Controls preventing active construction activities are in place.
- Asset preservation activities are being performed under established programs and procedures which limit physical work on plant SSCs to that which is necessary for maintenance and preservation of plant assets. Controls preventing active construction activities are in place.
- Plant documentation is preserved and maintained under records control programs which include physical security, access, change management and environmental controls.
- A Corrective Action Program has been established which describes processes and responsibilities for documenting and resolving problems, including conditions adverse to quality and significant conditions adverse to quality, pertaining to site activities in the deferred plant status. The BLN Corrective Action Program meets the requirements of the TVA NQAP and is similar to the programs implemented at the TVA operating units and at Watts Bar 2.

U. S. Nuclear Regulatory Commission Page 7 August 10, 2009

 Prompt identification, documentation, evaluation, and correction of adverse conditions, including the reporting requirements of 10 CFR 21, 10 CFR 50.55(e) and 10 CFR 50.71 are addressed through re-established reportability programs. Initial screening of deficiencies for reportability is performed as part of the Problem Evaluation Report initiation process within the Corrective Action Program.

Housekeeping, equipment protection and materials handling activities are performed in a manner consistent with standards contained in ANSI N45.2 per the commitments in the TVA NQAP. Housekeeping activities include the inspections, initiation of corrective actions, and documentation and assignment of responsibilities for general housekeeping in plant areas used for the performance of work activities which could affect nuclear quality. Site programs and procedures also define the requirements and establish controls for the storage and handling of materials received at the BLN site.

 A security program has been established which provides protective measures to prevent unauthorized intrusion as well as the positive control of materials and equipment at the BLN site.

 TVA has developed a plan for resolving hardware and records issues resulting from the lapse in QA oversight during the period when the Construction Permits were withdrawn and TVA began an investment recovery program. The construction status for BLN Units 1&2 at the time that the Construction Permits were withdrawn was documented in the plant's Engineering, Construction, Monitoring and Documentation (ECM&D) Database. Prior to Construction Permit withdrawal, the construction status, including documentation, was controlled under the NQAP and was the subject of successful TVA Nuclear Quality Assurance Audits and NRC inspections. In 2008, and after investment recovery activities were halted, TVA began construction status verification activities in order to identify and document deviations from the previously established construction status. These verification activities focused on the impacts of the investment recovery program and included detailed engineering walk downs and documentation of the affected areas. To consolidate the resulting documentation changes, the ECM&D database is currently being updated.

 TVA has planned additional activities to address plant-wide configuration control as well as the re-establishment of required design qualifications for plant SSCs. Detailed system walk downs will be conducted to verify and document plant configuration plant SSCs. The programs that are being developed are similar to those that are being implemented at Watts Bar Unit 2 for configuration control as well as to evaluate, refurbish, restore or replace SSCs.

U. S. Nuclear Regulatory Commission Page 8 August 10, 2009

ALS:LDC

cc: Mr. R. William Borchardt Executive Director for Operations U. S. Nuclear Regulatory Commission One White Flint North, 16E15 11555 Rockville Pike Rockville, Maryland 20852-2738

> Eric Leeds, Director Office of Nuclear Reactor Regulations U.S Nuclear Regulatory Commission One White Flint North, 13 D13 11545 Rockville Pike Rockville, Maryland 20852-2738

> Ms. Karen D. Cyr, General Counsel U. S. Nuclear Regulatory Commission One White Flint North, 15D21 11555 Rockville Pike Rockville, Maryland 20852-2738

> Mr. Michael Johnson, Director Office of New Reactors U. S. Nuclear Regulatory Commission Two White Flint North, 6F13 11545 Rockville Pike Rockville, Maryland 20852-2738

> Mr. David B. Matthews, Director Division of New Reactor Licensing U. S. Nuclear Regulatory Commission Two White Flint North, 6F27 11545 Rockville Pike Rockville, Maryland 20852-2738

Frank Akstulewicz U.S. Nuclear Regulatory Commission Two White Flint North, 6C34 11545 Rockville Place Rockville, Maryland 20852-2738 U. S. Nuclear Regulatory Commission Page 9 Aŭgust 10, 2009

> Mr. Luis A. Reyes, Regional Administrator U. S. Nuclear Regulatory Commission Region II Sam Nunn Atlanta Federal Center

61 Forsyth Street, SW, Suite 23T85 Atlanta, Georgia 30303-8931

Stephanie Coffin U. S. Nuclear, Regulatory Commission Two White Flint North, 7E18 11545 Rockville Pike Rockville, Maryland 20852-2738

John G. Lamb, Senior Project Manager U.S. Nuclear Regulatory Commission One White Flint North, MS 8 B1A 11555 Rockville Pike Rockville, Maryland 20852-2738

Patrick D. Milano, Project Manager U.S. Nuclear Regulatory Commission One White Flint North, 8C2 11545 Rockville Pike Rockville, Maryland 20852-2738

Lakshminarasimh Raghavan U. S. Nuclear Regulatory Commission One White Flint North, 8H4A 11555 Rockville Pike Rockville, Maryland 20852-2738

NRC Senior Resident Inspector Watts Bar Nuclear Plant Unit 2 1260 Nuclear Plant Road Spring City, Tennessee 37381-2000

Robert Haag US Nuclear Regulatory Commission Region II Sam Nunn Atlanta Federal Center, 23 T85 61 Forsyth Street SW Atlanta, GA 30303-8931

Loren Plisco US Nuclear Regulatory Commission Region II Sam Nunn Atlanta Federal Center, 23 T85 61 Forsyth Street SW Atlanta, GA 30303-8931



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555-0001

January 14, 2010

Mr. Ashok Bhatnagar Senior Vice President Nuclear Generation Development and Construction Tennessee Valley Authority 6A Lookout Place 1101 Market Street Chattanooga, TN 37402-2801

SUBJECT: BELLEFONTE NUCLEAR PLANT, UNITS 1 AND 2-REQUEST TRANSITION TO DEFERRED PLANT STATUS (TAC NOS. ME1904 AND ME1905)

Dear Mr. Bhatnagar:

By letter dated August 10, 2009 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML092230594), the Tennessee Valley Authority (TVA), holder of Construction Permit (CP) Nos. CPPR-122 and CPPR-123 for the construction of Bellefonte Nuclear Plant (BLN), Units 1 and 2, respectively, requested that the U.S. Nuclear Regulatory Commission (NRC) authorize placement of BLN, Units 1 and 2, into "deferred plant" status. The Commission's Policy Statement on Deferred Plants, as published in the *Federal Register* (FR) on October 14, 1987 (52 FR 38077), outlines the NRC's regulatory provisions for deferring and preserving a deferred nuclear power plant until such time as it may be reactivated.

Currently, BLN, Units 1 and 2, are in "terminated plant" status. (The Commission's policy statement defines a "deferred plant" as one "at which the licensee has ceased construction or reduced activity to a maintenance level, maintains the construction permit (CP) in effect, and has not announced the termination of the plant." A "terminated plant" is one "at which the licensee has announced that construction has been permanently stopped, but which still has a valid CP.") TVA has not requested any amendment to the CPs for BLN, Units 1 and 2.

The NRC staff has reviewed information that TVA submitted in its August 10, 2009, letter. The NRC staff conducted an inspection of TVA activities associated with the "deferred plant" status. Based on its review of the TVA submittal and the inspection results, the NRC staff has completed its assessment of TVA's construction deferral program and its implementation.

Background

In an order issued on March 9, 2009, reinstating the CPs for the construction of BLN, Units 1 and 2, and returning the facility to "terminated plant" status, the NRC specified the following:

Should TVA choose to pursue placement of the facility in a deferred plant status, it shall ensure to the satisfaction of the NRR [Office of Nuclear Reactor Regulation] Director that it has complied with the guidance and provisions under Section III.A, "Deferred Plant," of the Commission's Policy Statement on Deferred Plants. When the results of its evaluation and inspection are satisfactory, the

A. Bhatnagar

- 2 -

NRR Director may then authorize placement of the facility in a deferred plant status.

Staff Assessment

The Commission's policy statement identifies the areas of consideration should a facility be placed in a "deferred plant" status: On this basis, the NRC staff considered the following items in conducting its review:

- the notification of plant deferral
- the extension of the CPs
- the maintenance, preservation, and documentation (MPD) of equipment
- the conduct of review during deferral
- the applicability of new regulatory requirements during the period of deferral

In addition, on October 5, 2009, the staff issued "Bellefonte Nuclear Plant Units 1 and 2—Staff Plan for Assessment of Transition to Deferred Plant Status" (Bellefonte Assessment Plan or the Plan) (ADAMS Accession No. ML092740149) to provide guidance for its assessment of TVA's request related to these areas. In addition, to the requirements in the Commission's policy statement, the Plan identified other areas for consideration. These areas involved the TVA plans for resolving a hydrology issue; proposed site activities during the period of deferral to ensure that these activities remain bounded by the environmental impact statement for the CPs; status of other Federal, State, and local government requirements; and implications for the review of the combined license application for BLN, Units 3 and 4.

The following provides the basis for the NRC staff's determination.

1.0 Notification of Plant Deferral

In addition, to informing the NRC when a plant is to be deferred, the Commission's policy statement indicates that information be made available that includes the reason for deferral; expected reactivation date, if known; whether it will submit an extension to the CPs; and its plans for fulfilling the requirements of the CPs, including MPD. TVA provided the information in its August 10, 2009, letter and informed the NRC of its plan to place BLN, Units 1 and 2, in "deferred plant" status.

TVA has not determined a date for reactivating the construction of BLN, Units 1 and 2. However, TVA indicated that, should it decide to reactive construction, it would submit a letter 120 days before resuming construction and provide the required information in accordance with the Commission's policy statement. Further, on November 4, 2009, TVA published a draft supplemental environmental impact statement to inform decision makers, agencies and the public about the potential for environmental impacts that would result from a decision to complete or construct and operate a single nuclear generating unit at the BLN site. TVA considered the action alternatives of completion and operation of a Babcock and Wilcox pressurized light water reactor or construction and operation of a Westinghouse AP1000 advanced pressurized light water reactor.

TVA's plans for fulfilling the requirements of the CPs will be verified through periodic NRC inspection.

A. Bhatnagar

- 3 -

Thus, the NRC staff finds that TVA has provided sufficient information to meet the provisions for notification of plant deferral in the Commission's policy statement.

2.0 Extension of Construction Permits

CP No. CPPR-122 for BLN, Unit 1, will expire on October 1, 2011, and CP No. CPPR-123 for BLN, Unit 2, will expire on October 1, 2014. TVA has not requested any changes to these dates. Thus, the NRC staff finds that TVA has provided sufficient information to meet this provision of the Commission's policy statement.

3.0 Maintenance, Preservation, and Documentation of Equipment

The Commission's policy statement addresses the regulations and guidance applicable to deferred and terminated plants, quality assurance (QA) requirements, MPD requirements for deferred plants, and the application of new regulatory requirements to deferred plants upon reactivation and other general administrative considerations. The QA program implemented during the deferral should include a description of the planned activities; organizational responsibilities and procedural controls that apply to the verification of construction status; MPD of equipment and materials; and retention and protection of QA records. For plants in a deferred status, Section III.A.3 of the Commission's policy statement states that an applicant may modify its commitments related to the regulatory requirements (i.e., those that apply to plants under construction) commensurate with the expected activities during deferral.

In its enclosure to the August 10, 2009, letter, TVA addressed these elements of the Commission's policy statement.

TVA's nuclear quality assurance program (NQAP) covers both the operating plants and those under construction, including MPD. Appendix G to the NQAP, which was provided to the NRC in Revision 20, addresses the QA requirements related to the construction of BLN, Units 1 and 2. It describes and establishes the administrative controls needed to meet the requirements of Appendix B to 10 CFR Part 50, the Commission's policy statement, and the NRC's order reinstating the CPs for BLN. Units 1 and 2.

The staff determined that TVA has reestablished the necessary QA programs and procedures in accordance with its NQAP. As discussed in NRC Inspection Report Nos. 05000438/2009601 and 05000439/2009601, dated December 2, 2009 (ADAMS Accession No. ML093370083), the staff assessed the TVA QA activities, including organizational responsibilities; programs and procedural controls that apply to the verification of construction status; MPD of equipment and materials; retention and protection of QA records; the reporting of deficiencies in design, construction, and QA; and the reporting of defects and noncompliances during deferral. The NRC staff concludes that TVA's QA activities and actions associated with MPD of equipment satisfy the criteria in the Commission's policy statement. The NRC performs inspections periodically to examine implementation of the program to determine compliance with commitments and overall program effectiveness.

A. Bhatnagar

- 4 -

4.0 Conduct of Review during Deferral

TVA tendered its application for an operating license (OL) for BLN, Units 1 and 2, on February 1, 1978. The NRC completed its acceptance review and docketed the application on June 6, 1978. Because of TVA's prior decision to terminate construction of BLN, Units 1 and 2, there are no ongoing reviews of the OL application. In addition, TVA has not requested any modification to the CPs, which would require NRC review and approval. Thus, the NRC staff does not plan to conduct the review of any licensing actions during the period of deferral. The staff finds that the provisions of the Commission's policy statement in this area have been met.

In the event that it decides to resume active construction, TVA will notify the NRC of its decision in a letter that it will submit 120 days before it resumes construction and will provide the other information listed in Section III.A.6 of the Commission's policy statement, including key assumptions and a detailed regulatory framework for reactivating construction. These documents will address the plant's status related to previously issued generic letters, bulletins, circulars, and information notices for applicability, new standards, guidance and regulation for applicability to BLN, and commitments and open items related to licensing. TVA will also submit an updated OL application, including an amendment to the BLN, Units 1 and 2, final safety analysis report and updated environmental report.

5.0 Applicability of New Regulatory Requirements during Deferral

In its August 10, 2009, letter, TVA indicated that it has reviewed the new regulatory requirements that have been issued since plant deferral (in June 1988) through July 2009 and determined that there are no new applicable regulatory requirements that would affect activities during the period of deferral. Thus, the staff finds that TVA satisfies the criteria in the Commission's policy statement.

6.0 Additional Considerations

As described in the assessment plan dated October 5, 2009, the NRC staff addressed certain additional considerations, which were not needed for determining compliance with the provisions of the policy statement related to transition to "deferred plant" status. However, the staff assessed them to ensure that these items would not create other issues after the staff makes its determination on deferral status. The staff found that TVA has established procedural controls to ensure maintenance activities performed while in a terminated or deferred plant status do not advance construction of the plants. The NRC staff verified that TVA's controls are adequate to ensure that proposed site activities do not advance construction and do not affect the conclusions in the environmental impact statement for the CPs. By letter, dated December 2, 2009, TVA confirmed that the National Pollutant Discharge Elimination System permit and other Federal, State, and local licenses and permits are current. The NRC staff finds that TVA has confirmed that applicable licenses and permits remain current and a renewal process is included in project schedule.

A. Bhatnagar

- 5 -

7.0 Inspections

From October 19 to October 23, 2009, the NRC staff conducted an inspection of BLN, Units 1 and 2. NRC Inspection Report Nos. 50-438/2009601 and 50-439/2009601, dated December 2, 2009, document the results of the inspection.

The NRC staff conducted the inspection to identify the status of the applicable program areas specified in Section III.A of the Commission's policy statement. Within these areas, the inspection consisted of selected examinations of procedures and representative records, interviews with personnel, equipment status verification, and observations of program and process implementation.

The inspection verified that TVA had properly implemented the NRC-approved QA program and established processes and controls necessary to comply with regulatory requirements associated with its CPs. The inspection determined that TVA's QA organizational structure and functional relationships were clear and that the equipment covered under the QA plan are properly identified and scoped. The inspection found that TVA's audits and self-assessments conducted to assess readiness to transition to a deferred plant status were of good quality. The inspection reviewed BLN procedures for the reporting of 10 CFR 50.55(e) construction deficiencies and 10 CFR 21.21, "Notification of Failure To Comply or Existence of a Defect and Its Evaluation," defects and noncompliances and verified the program was effectively implemented. Issues were appropriately entered into the corrective action program, and the corrective actions taken were sufficient to correct the identified conditions. Through the review of a sample of documents, the inspection verified that TVA properly prepared, approved, stored, and controlled documents in accordance with its QA requirements. Through discussions with TVA personnel and a review of procedures and documentation, the inspection determined that TVA has adequately addressed the impact of investment recovery activities without proper QA control on the SSCs. TVA considers the condition of all onsite SSCs to be indeterminate. Therefore, the preventive maintenance activities currently identified are those deemed necessary for investment protection. At a later date, TVA plans to individually assess the condition and safety classification of all SSCs. The inspection reviewed controls established for work activities performed during deferred construction and determined that specific guidance is provided that prohibits any work that could be identified as furthering plant construction or completion.

The NRC inspection concluded that TVA has developed programs and procedures and is properly implementing related activities to support transition to deferred status. As specified in the Commission's policy statement, the NRC staff plans to perform future inspections of TVA's QA activities during deferred construction.

Assessment Conclusion

Based on the above discussions and the inspection results, the NRC staff has determined that TVA has addressed those elements of the Commission's policy statement to allow BLN, Units 1 and 2, to be placed in "deferred plant" status. The NRC will continue to periodically inspect the implementation of TVA's QA program and site activities during deferral to determine TVA's compliance with commitments and overall program effectiveness. Should information subsequently become available that the NRC did not consider during its review or that conflicts

A. Bhatnagar

- 6 -

with earlier information, the NRC will evaluate the information to determine what effects it may have on this conclusion.

Therefore, I authorize placement of BLN, Units 1 and 2, into "deferred plant" status in accordance with the Commission's direction in Staff Requirements Memorandum COMSECY-08-0041, "Staff Recommendation Related to Reinstatement of the Construction Permits for Bellefonte Nuclear Plant, Units 1 and 2," dated February 18, 2009 (ADAMS Accession No. ML090490838).

Sincerely,

Eric J/Leeds, Director Office of Nuclear Reactor Regulation

Docket Nos. 50-438 and 50-439

A. Bhatnagar

-6-

with earlier information, the NRC will evaluate the information to determine what effects it may have on this conclusion.

Therefore, I authorize placement of BLN, Units 1 and 2, into "deferred plant" status in accordance with the Commission's direction in Staff Requirements Memorandum COMSECY-08-0041, "Staff Recommendation Related to Reinstatement of the Construction Permits for Bellefonte Nuclear Plant, Units 1 and 2," dated February 18, 2009 (ADAMS Accession No. ML090490838).

Sincerely,

/RA/

Eric J. Leeds, Director Office of Nuclear Reactor Regulation

Docket Nos. 50-438 and 50-439

DISTRIBUTION:

PUBLIC LP-WB Reading File RidsNrrOd RidsNrrDorl RidsNrrDorlLpwb RidsNrrAdro RidsNrrAdes RidsNrrPMWattsBar2 RidsNrrLABClayton (hard Copy) RidsRgn2MailCenter R. Haag, R-II RidsOpaMailCenter RidsOcaMailCenter RidsAcrsAcnw&mMailCtr RidsOgcRp S. Burnell, OPA D. Diaz-Toro, OEDO

ADAMS	ADAMS No.: ML093420915				*via e-mail		
OFFICE	LPWB\BC	LPWBLA	TechEd*	DIRS\D	NRO/DCIP	RA\R-II*	DORLID
NAME	LRaghavan	BClayton	KKribs	FBrown	ACampbell	RCroteau	JGiitter
DATE	01/08/10	01/11/10	12/07/09	12/16/09	12/16/09	01/11/10	12/18/09
OFFICE	OGC	NRR\D			· ·		
NAME	EWilliamson	ELeeds	ľ				
DATE	01/08/10	01/14/10					

OFFICIAL AGENCY RECORD

APPENDIX B – NRC REPORTS ON 2009 BLN INSPECTION FOR TRANSITION TO DEFERRED STATUS

Page intentionally blank

Appendix B



UNITED STATES NUCLEAR REGULATORY COMMISSION REGION II SAM NUNN ATLANTA FEDERAL CENTER 61 FORSYTH STREET, SW, SUITE 23T85 ATLANTA, GEORGIA 30303-8931

December 2, 2009

Mr. Ashok S. Bhatnagar Senior Vice President Nuclear Generation Development and Construction Tennessee Valley Authority 6A Lookout Place 1101 Market Street Chattanooga, TN 37402-2801

SUBJECT: BELLEFONTE NUCLEAR PLANT UNITS 1 (CPPR-122) AND 2 (CPPR-123) -TRANSITION TO DEFERRED STATUS - NRC INSPECTION REPORT 05000438/2009601 AND 05000439/2009601

Dear Mr. Bhatnagar:

On October 23, 2009, the Nuclear Regulatory Commission (NRC) completed an inspection at your Bellefonte Nuclear Plant, Units 1 and 2 associated with transition to a "Deferred Plant" status, as defined by the Commission Policy Statement on Deferred Plants. The enclosed report documents the inspection results which were discussed on October 23, 2009, with yourself and other members of your staff.

The purpose of the inspection was to identify the status of the applicable program areas, specified in Section III.A, "Deferred Plant", of the Commission Policy Statement on Deferred Plants (52 FR 38077), currently established at the Bellefonte Nuclear Plant. Primarily, the NRC recognized the need to address the lapse in Quality Assurance (QA) oversight and investment recovery consequences that occurred in the period from withdrawal of the site's Construction Permits until when the QA program was reestablished. Specific actions were taken to evaluate if Tennessee Valley Authority (TVA) had properly implemented the NRC-approved QA program, adequately addressed the status and quality of currently installed and stored equipment, and established associated processes and controls necessary to comply with regulatory requirements associated with your construction permits. Specific areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selected examinations of procedures and representative records, interviews with personnel, equipment status verification, and observations of program and process implementation. Based on the results of this inspection, no violations of NRC requirements were identified. In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS).

Page intentionally blank

TVA

ADAMS is accessible from the NRC Web site at <u>http://www.nrc.gov/reading-rm/adams.html</u> (the Public Electronic Reading Room).

Sincerely,

/RA/

Robert C. Haag, Chief Construction Projects Branch 3 Division of Construction Projects

Docket Nos. Construction Permit Nos.

50-438, 50-439 CPPR-122, CPPR-123

Enclosure: NRC Inspection Report 50-438/09-01 AND 50-439/09-01 w/Attachment - Supplemental Information

cc w/encl: (See page 3)

 PUELICLY AVAILABLE
 NON-FUBLICLY AVAILABLE
 SENSITIVE
 NON-SENSITIVE

 ADAMS:
 P(s)
 ACCESSION NUMBER: <u>ML693370383</u>
 ISUNSI REVIEW COMPLETE

OFFICE	RII:DCP	RII: DCP	RII:DCP	RIEDCP	RII:DCP	
SIGNATURE	JBB	Via Email	Va Email	Via En ail	Via Email	
NAME	JBaptist	W Fowler	CJulian	JBlake	MSheikh	
DATE	12/01/2009	11/30/2009	11/30/2009	11/30/2009	11/30/2009	
E-MAIL COPY?	YES NO	YES	NŨ	YES	NO	

OFFICIAL RECORD COPY DOCUMENT NAME: G1CCI/DCP/CPB3/BELLEFCNTEXXXXXXX.DOC

A-23

TVA

<u>cc w/encl:</u> Mr. Gordon P. Arent, Manager New Generation Licensing Nuclear Generation Development and Construction Watts Bar Nuclear Plant P.O. Box 2000 Spring City, Tennessee 37381

Mr. William R. Campbell Senior Vice President, Fleet Engineering Tennessee Valley Authority 6A Lookout Place 1101 Market Street Chattanooga, Tennessee 37402-2801

Mr. Preston D. Swafford Chief Nuclear Officer and Executive Vice President Tennessee Valley Authority 3R Lookout Place 1101 Market Place Chattanooga, Tennessee 37402-280

General Counsel Tennessee Valley Authority 6A West Tower 400 West Summit Hill Drive Knoxville, Tennessee 37902 Nashville, TN 37243-1532

Mr. Larry E. Nicholson, General Manager Performance Improvement Tennessee Valley Authority 4X Blue Ridge 1101 Market Street Chattanooga, Tennessee 37402-2801

Mr. Robert J. Whalen Vice President, Nuclear Engineering 3R Lookout Place Tennessee Valley Authority 1101 Market Street Chattanooga, Tennessee 37402-2801 3

Mr. Michael J. Lorek Vice President, Nuclear Engineering & Projects Tennessee Valley Authority 3R Lookout Place 1101 Market Street Chattanooga, Tennessee 37402-2801

Mr. Frederick C. Mashburn
Acting Manager, Corporate Nuclear
Licensing & Industry Affairs
Tennessee Valley Authority
4K Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

Mr. Michael A. Purcell Senior Licensing Manager Tennessee Valley Authority 4K Lookout Place 1101 Market Street Chattanooga, Tennessee 37402-2801

Chairman Jackson County Commission Courthouse Scottsboro, AL 35768

State Health Officer Alabama Dept. of Public Health RSA Tower- Administration Suite 1552 P.O. Box 303017 Montgomery, AL 36130-3017 TVA

cc email distribution w/encl: Andrea L. Sterdis Tennessee Valley Authority Electronic Mail Distribution 4

Letter to Ashok S. Bhatnagar from Robert Haag dated December 2, 2009.

SUBJECT: BELLEFONTE NUCLEAR PLANT UNITS 1 (CPPR-122) AND 2 (CPPR-123) -TRANSITION TO DEFERRED STATUS - NRC INSPECTION REPORT 05000438/2009601 AND 05000439/2009601

Distribution w/encl: L. Raghavan, NRR P. Milano, NRR C. Evans, RII L. Slack, RII EICS E. Guthrie, RII DRP J. Baptist, RII PUBLIC

A-26

U.S. NUCLEAR REGULATORY COMMISSION

REGION II

Docket Nos: Construction Permit Nos: 50-438 and 50-439 CPPR-122 and CPPR-123

Report Nos:

50-438/2009601 and 50-439/2009601

Licensee:

Facility:

Location:

Dates:

Inspectors:

Tennessee Valley Authority (TVA)

Bellefonte Nuclear Plant, Units 1 & 2

Bellefonte Road Hollywood, AL 35752

October 19 - 23, 2009

 J. Baptist, Senior Project Inspector, Division of Construction Projects (DCP), Construction Projects Branch (CPB) 3, Region II (RII)
 M. Sheikh, Senior Project Inspector, DCP, CPB 4, RII

 W. Fowler, Project Inspector, DCP, CPB 2, RII
 C. Julian, Senior Project Manager, Division of Construction Inspection (DCI), Construction Inspection Branch (CIB) 1, RII

J. Blake, Senior Program Inspector, DCI, CIB 3, RII

Robert C. Haag, Chief Construction Projects Branch 3 Division of Construction Projects

Approved by:

Enclosure

Single Nuclear Unit at the Bellefonte Site

EXECUTIVE SUMMARY

Bellefonte Nuclear Plant, Units 1 and 2 NRC Inspection Report 05000438,439/2009601

The inspection included aspects of engineering and construction activities, performed by Tennessee Valley Authority (TVA), associated with the Bellefonte Nuclear Plant (BLN), Units 1 and 2 project. This report covered a one-week period of inspections in the areas of quality assurance (QA); identification and resolution of problems; maintenance activities; engineering activities; access controls; and control of documents and records. The inspection guidance was primarily performed under NRC inspection procedure (IP) 92050, "Review of Quality Assurance for Extended Construction Delay."

The inspection evaluated if TVA had properly implemented the NRC-approved QA program, adequately addressed the status and quality of currently installed and stored equipment following investment recovery activities, and established associated processes and controls necessary to comply with regulatory requirements associated with its construction permits. The inspection evaluated the status of the applicable program areas, specified in Section III.A, "Deferred Plant", of the Commission Policy Statement on Deferred Plants through examination of procedures and representative records, interviews with personnel, equipment status verification, and observations of program and process. The inspection concluded that TVA has established the necessary programs to support transition to deferred status, consistent with the Commission Policy Statement for Deferred Plants. The inspection results are discussed in detail below.

Inspection Results:

- The QA organizational structure and functional relationships were clearly stated. The
 equipment that the TVA QA plan covers was properly identified and scoped. Work and
 inspection activities were performed by qualified personnel using approved procedures.
 (Section I.Q.1)
- Audit procedures were adequate and the audits and self-assessments conducted to assess readiness to transition to a deferred plant status were of good quality. (Section II.C.1)
- The corrective action program (CAP) procedures were established to support transition to deferred status. Licensee management was actively involved and emphasized the need for all employees to identify and report problems. (Section II.C.1)
- The licensee had a process established, governing site procedures applicable to determination of construction status and maintenance activities, to support transition to deferred status. (Sections III.E.1 and IV.M.1.1)
- Documentation was found to be properly prepared, reviewed, approved, and distributed. QA records were stored, maintained, and controlled in a manner to support transition to deferred status. (Section V.R.1)

Final Supplemental Environmental Impact Statement

REPORT DETAILS

Summary of Plant Status

During the inspection period, Bellefonte Nuclear Plant (BLN), Units 1 and 2 remained in a "terminated plant" status, as defined by the Commission Policy Statement on Deferred Plants (52 FR 38077)

I. Quality Assurance (QA) Program Structure and Implementing Procedures

Q.1 QA Organization and Procedures (IPs 92050, 35060, 35100, 36100)

a. Inspection Scope

The team reviewed programs and procedures, and interviewed personnel, to determine the adequacy of the Tennessee Valley Authority (TVA) QA program as it supports transition of BLN to deferred plant status. The QA program was specified in TVA Nuclear Quality Assurance Plan (NQAP), TVA-NQA-PLN89-A, Revision (Rev.) 21, with some requirements specific to the BLN delineated within paragraphs of the main body of the NQAP and the general description of how the NQAP was to be implemented at the site provided by Appendix G to the NQAP.

The adequacy of implemented procedures was evaluated on a sampling basis and actual procedural implementation was inspected to ensure that work was performed in accordance with procedural requirements.

The team reviewed the licensee's procedure, BLN Site Standard Practice (SSP)-2.3, "Administration of Site Procedures," Rev. 13, to identify if it had been revised to provide guidance to ensure that quality-related activities would be performed using documented procedures and instructions appropriate for a deferred plant.

The team assessed the adequacy of the QA program audit procedures. The team reviewed TVA procedure NAPD-2, "Audits", and the specific provisions for BLN contained in SSP-3.1, "Conduct of Quality Assurance." The team reviewed the results of internal and external audits and self-assessments conducted during 2009, as listed in the attachment to this report. The team evaluated the results of the audits to determine the type of audit findings and recommendations, as well as, what actions were taken to address the audit results.

The team reviewed BLN procedure SSP-2.9, "Records Management," Rev. 15. The review included evaluation of completeness of procedure instructions and guidance, assessment of staff's knowledge of the procedure, and evaluation of program implementation.

The team reviewed BLN procedures for the reporting of 10 CFR 50.55(e) construction deficiencies and 10 CFR 21.21 defects and non-compliances. This review included verification of effective program implementation and the completeness of guidance used to evaluate whether or not an item is reportable.

Additional documents reviewed are listed in the attachment.

2

b. Observations

The QA organizational structure and functional relationships were clearly stated. The qualifications, responsibilities, and duties of QA personnel, including independence from personnel having cost or scheduling responsibilities, were well defined. Methods were established to ensure that procedures were developed, approved before use, complete, and controlled, and those performing QA inspection activities had available to them the most recent approved version. The equipment covered by the QA plan was properly identified and scoped; work and inspection activities were performed by qualified personnel using approved procedures.

The team verified that the education and experience of the BLN Project Nuclear Assurance (NA) Manager met the minimum requirements specified in TVA NQAP Paragraph C of § 4.1.6, "Nuclear Assurance."

During interviews, the team noted that due to the low level of activity at BLN, the NA manager was the only QA staff permanently assigned to the site. Other supporting QA personnel were borrowed from the corporate NA offices as needed to support audit or assessment activities. Accordingly, until construction activities resume involving QA-related structures, systems, and components (SSCs), the licensee does not plan to permanently staff local QA/Quality Control (QC) personnel.

BLN procedure SSP-2.3, "Administration of Site Procedures," Rev. 13, had been revised to reflect activation of the procedure after reinstatement of BLN construction permits (CPs) and to reflect site organizational changes. This procedure provided direction for the administration and revision of procedures required for manipulations of, and performance of work on, plant equipment.

The team verified that procedures clearly outlined the process for identifying deficiencies and determining whether an item is reportable. These procedures included provisions for submitting initial reports, as well as interim reports, should meeting the final report due date become unachievable. In addition, procedural attachments provided step-by-step guidance on evaluating whether a substantial safety hazard (SSH) or deviation exists. Reporting timeframes and NRC contact information was provided and was accurate. The team also reviewed evaluations for reportability associated with a failed tendon coupling in the BLN Unit 1 tendon gallery and determined the licensee had properly implemented their procedural guidance. TVA informed the team that this reportability evaluation will be reviewed when additional information regarding the failure mechanism and applicability to other tendon couplings becomes available.

During 2009, several voluntary audits and self-assessments were conducted to determine BLN readiness to transition from a terminated plant status to a deferred plant status. The audits were found to have followed approved procedures while the findings and recommendations were appropriately critical.

The team examined BLN's records retention program. The implementing procedure, SSP-2.9, "Records Management," Rev. 15, included specific instructions for records creation, identification, and storage. The team observed that the procedure required sufficient records and documentation be prepared to provide evidence of the quality of items or activities affecting quality. In addition, the procedure provided guidance regarding records processing, indexing specifications for timely retrieval, maintenance,

and lifetime storage. The team observed that the procedure discussed replacing lost, damaged, or contaminated records, and access to QA records.

Conclusions

C.

The team concluded that deficiency and non-compliances procedures were adequate and provide ample direction to perform timely notification to the NRC with a report that includes all required information.

The team concluded that the audit procedures were adequate and the audits and selfassessments conducted to assess readiness to transition to a deferred plant status were of good quality.

The team concluded that the licensee has a QA plan in place that is commensurate with the level of activities during the expected construction activities and delay to support transition to deferred plant status, consistent with the Commission Policy Statement.

II. Corrective Action Program (CAP)

C.1 CAP Implementation (IPs 92050, 35100)

a. Inspection Scope

The team reviewed TVA NQAP § 10.0, "Adverse Conditions" and BLN procedure SSP-3.4, "Corrective Action Program," Rev. 13, for guidance on the identification and resolution of conditions adverse to quality. The team also reviewed numerous problem evaluation reports (PERs), interviewed personnel regarding their understanding of the CAP process and concerns resolution program (CRP), attended management review and screening meetings, and interviewed the CAP staff regarding their role in CAP implementation.

Specifically, the team reviewed several PERs to verify that initiation level was appropriate, condition classification criteria were followed, management review and action was appropriate, and resolution of the issue was sufficient. The team also conducted a detailed review to assess the adequacy of the root-cause and apparent-cause evaluations of the problems identified. The team reviewed these evaluations against the descriptions of the problem described in the PERs and the guidance in licensee procedures. The team assessed the licensee's ability to determine the cause(s) of identified problems and consideration of the following: issue reportability, common cause, generic concerns, extent-of condition, and extent-of-cause. The review also assessed if the licensee had appropriately identified and prioritized corrective actions to prevent recurrence.

The team also reviewed the findings and recommendations from four internal audits and self-assessments, one self-assessment follow-up, and one external assessment performed by industry consultants.

Additional documents reviewed are listed in the attachment.

.

b. Observations

The team determined that the procedures, for identification and correction of conditions adverse to quality, were adequately established and had sufficient detail regarding initiating threshold and classification criteria. Also, procedures were established to preclude repetition of activities adverse to quality and provisions were established for escalating, to higher management, those corrective actions that were not adequate and/or timely. Additionally, a management system was established for overview of trends in conditions adverse to quality. BLN personnel were familiar with the PER initiation process, understood the PER classification criteria, and displayed a willingness to identify conditions adverse to quality. The management review committee (MRC) membership and mission were sufficient to ensure that PER classification and resolution complied with written procedures.

The team found that the licensee has been effective in identifying, classifying, and resolving conditions adverse to quality and has incorporated lessons learned from the development and implementation of a CAP at BLN. Management involvement was adequate, issues were properly challenged, and timeliness goals were adequately established.

One item that was found unique to the BLN CAP was the classification of a PER component as "inactive." In the event a PER is written and an aspect of the PER would not be resolved until active construction begins (i.e. equipment is identified as degraded), the CAP allows the PER to be classified as "inactive". The team reviewed the criteria for making this determination, including the processes in place to bring these items to resolution, and found the controls to be adequate.

The audit reports were of good quality and the resulting issues and recommendations were pertinent and clearly presented. The team reviewed the PERs generated by TVA, in response to the audit issues and recommendations, and the corrective actions taken or planned. In instances where no new PER was initiated, the team determined that those conditions were previously identified in other corrective action documents. The team did identify two instances where PER documentation of corrective actions was not completely accurate. TVA initiated PERs to correct those conditions.

Based on the interviews conducted and the PERs reviewed, the team determined that licensee management emphasized the need for all employees to identify and report problems using the established methods of the CAP and CRP. These methods were readily accessible to all employees. Based on discussions conducted, with a sample of plant employees from various departments, the team determined that employees felt free to raise issues and that management encouraged employees to place issues into the CAP for resolution. The team did not identify any reluctance, on the part of the licensee staff, to report safety concerns.

c. <u>Conclusions</u>

The team concluded that the licensee had a CAP that was commensurate with the level of activities during the expected construction delay to support transition to deferred plant status.

III. Evaluation of Current Plant Status

E.1 Assessment of Current Plant Status (IP 92050)

a. Inspection Scope

In October 2005, TVA requested that the CPs be withdrawn and ceased all qualityrelated activities. At that time, BLN was maintaining current plant status in the Engineering, Construction, Maintenance, and Documentation (ECM&D) database. After the CPs were withdrawn in 2006, TVA terminated the BLN QA program and started investment recovery (salvage) activities. Because recovery activities took place without the controls of a QA program, the status and quality of currently installed and stored equipment is unknown. TVA also recognized that potential collateral effects/damage to plant equipment could have occurred during recovery activities. TVA ceased investment recovery activities when they decided BLN was a viable option for completion and subsequently implemented an NRC-approved QA program.

During this inspection, the team reviewed procedures, inspected plant hardware, and interviewed personnel to verify the implementation of TVA's program for the assessment of the plant status for the BLN. At the time of the inspection, TVA was in the process of attempting to re-establish configuration control of BLN through the "configuration recovery" efforts being conducted by contractor, Sargent & Lundy^{LLC} (S&L)

The team reviewed the S&L procedures for the determination of plant system status. The S&L procedures and a brief description of the program are as follows:

PI-TVAN-06, Rev. 1, 12/03/2008, *Bellefonte Nuclear Plant Configuration Recovery*. Phase 1 of the configuration recovery project involving the mark-up of piping and instrumentation drawings (P&ID) and electrical schematic drawings to clearly identify mechanical and electrical components that had been removed during investment recovery (salvage) operations.

PI-TVAN-07, Rev. 0, 02/02/2009, Bellefonte Nuclear Plant Configuration Control Assessment. This program was the method for conducting an assessment of the ECM&D configuration control process at BLN. The assessment was done by selecting a sample of various plant components and comparing the in-plant configuration with construction documents/records to check for agreement.

PI-TVAN-08, Rev. 1, 04/13/2009, *Bellefonte Nuclear Plant Configuration Recovery Record/Identification*. This procedure provided instruction for Phase 2 of the Sergeant and Lundy program for configuration recovery at BLN. This phase used the results of the phase 1 program to identify the construction records within ECM&D database which were impacted by the removal of equipment.

PI-TVAN-09, Rev. 0, 07/13/2009, *Bellefonte Nuclear Plant Configuration Recovery Record Update.* This procedure described Phase 3 of the program and involved the updating of the various construction documents/records that were impacted by equipment that was removed during the investment recovery effort at BLN. The Phase 3 effort was designed to generate a report defining the type of records that were updated and the outstanding items that must be processed during the BLN Detailed, Scoping, 6

Estimating, & Planning (DSEP) effort and/or items that must be processed during the construction effort.

PI TVAN 10, Rev. 0, 00/08/2009, *Bellefonte Nuclear Plant Configuration Recovery Phase 4 Record Update.* This phase of the program was in process at the time of this inspection and was intended to complete the documentation of investment recovery affected equipment and investment recovery collateral damage identified during Phase 3 walk-downs. It was also designed to update the site construction records to account for:

- Plant equipment shipped from the Bellefonte Site to other facilities. These items were tracked using shipping tickets.
- Identify the ECM&D records and update the ECM&D database for the following equipment that was not included in the Phase 2 & 3 scope:
 - System heat trace
 - Instrument sense lines
 - Removed instrument racks
 - Sample lines
 - Acid/Caustic Building
 - Uninstalled instruments in received status

The team reviewed the "Configuration Control Assessment Report" dated July 15, 2009, performed by S&L, in accordance with PI-TVAN-07, which reported the results of comparing construction records to actual component configuration. The assessment involved a total of 157 components; 128 components assessed using a method of selecting a record and then inspecting the component in the field and 29 components were assessed by randomly selecting the component in the field and verifying the records.

The team also reviewed the results of a TVA corporate NA observation concerning the BLN 1&2 Population of the ECM&D Database. During this assessment the NA observer also reviewed the results of the S&L configuration recovery project.

As an independent review of the status of configuration control, the team conducted walkdowns using the S&L updated "red-line" drawings where investment recovery activities had taken place and also in areas of the plant where it was presumed recovery activities did not occur. These walkdowns included the auxiliary feedwater, component cooling water, spent fuel pool cooling, decay heat removal, auxiliary building air conditioning, and high pressure fire protection systems for Unit 1 and Unit 2. While conducting the walk-downs, the team evaluated if the equipment removed for investment recovery had been properly identified. The team compared the condition of components in the field with the P&IDs and the isometric drawings, which had been marked up by S&L personnel during the phase 1 plant status reviews. During this independent review, the team also selected a number of components from each system to determine if the licensee's ECM&D database was in agreement with the observed field conditions for the selected components.

In addition, due to the designation of protecting the QA records vault, the team conducted independent walkdowns on the Raw Service Water (RSW) fire protection water storage tanks, diesel driven fire pumps, and the RSW pumps and power supplies. The walk-down reviewed instrumentation used to automatically start the RSW pumps on

Final Supplemental Environmental Impact Statement

A-34

low level, physical conditions of the diesel driven fire pumps, fuel oil levels and valve lineups for the RSW and diesel driven fire pumps.

Additional documents reviewed are listed in the attachment.

b. Observations

During the walkdowns the team observed the physical condition of the SSCs. The team identified that TVA had a clear understanding of the need to capture the details surrounding the investment recovery effort as an attempt to validate equipment status affected by the investment recovery effort and to also restore confidence in the ECM&D database. Additionally, TVA identified in the "Bellefonte Nuclear Plant Units 1 & 2 Deferred Status Assessment Report", dated August 4, 2009, that, if construction activities are resumed, multiple programs will be required to fully understand the plant's equipment status, pedigree, and condition necessary to fully evaluate the proper methods of equipment restoration.

During the walkdowns, the team observed the physical condition of the various system's pumps, valves, piping and electrical terminations. The team noted that investment recovery activities included some pump and pump motor removals and that the deliberate cutting of electrical connections, to aid in their removal, was not uncommon. Furthermore, the team's walkdowns identified examples where the investment recovery efforts had additional unknown and detrimental effects on surrounding plant equipment that was not captured by S&L's efforts. These items were placed in the CAP and will be resolved at the appropriate time if construction reactivation occurs.

As part of the walkdown activities, the team performed random samples of drawings referenced by the parent drawing used during the walkdown. The team verified that the references could be retrieved and were appropriately revised. Additionally, if any documents were superseded the team verified that document control had properly identified the referenced drawing as superseded. Individual components, identified during the walkdown, were also verified to ensure their conditions were accurately reflected in the site's ECM&D database.

The licensee's use of the electronic ECM&D database, to define current plant status, has historically been and remains an adequate method for defining project status. Additional methods and data tacking systems were being used in concert with the ECM&D database to attempt to restore confidence to BLN's evaluation of current plant status. BLN was aware that conditions exist within the plant that were not properly reflected in the approved databases and have confidence that, if construction activities resume, additional scoping walkdowns will more accurately reveal plant status. The team identified that the BLN efforts to understand the current plant status were effective but, due to the complexity of any construction project, BLN could not precisely capture the current plant status of the BLN construction status in the ECM&D database.

c. Conclusions

The team concluded that investment recovery activities were primarily isolated to certain areas of the plant and, while some recovery efforts resulted in significant collateral damage, programs are established to capture the overall impact of the salvage activities. In addition, documents used by BLN to identify and record items that were damaged

8

and/or removed, during the time period when the QA program was not in effect, appear to be detailed and accurate.

The team concluded that the licensee had a process in place, concerning site procedures applicable to determination of construction status during the expected construction delay, to support transition to deferred plant status, consistent with the Commission Policy Statement.

IV. Maintenance and Preservation (M&P)

M.1.1 M&P Controls (IP 92050)

a. Inspection Scope

Through discussions with licensee personnel and review of procedures and documentation, the team determined that as a result of investment recovery activities without proper QA control, the licensee considers that the condition of all SSCs on site is indeterminate. Therefore, the consideration of safety classification of each individual SSC does not apply. For that reason, preventive maintenance activities were restricted to those activities deemed to be necessary for investment protection. If construction resumes at a later date, TVA plans to individually assess each SSC for overall condition and safety classification. Those SSCs that can be qualified will be reviewed for required PMs, commensurate with the safety classification of the SSC.

The team reviewed the controls established to ensure maintenance activities performed while in a terminated or deferred plant status did not advance construction of the plants. Personnel were interviewed, plan of the day meetings were attended, weekly and daily work schedules were reviewed, and BLN procedures SSP-6.2, "Work Control," Rev. 8, and QCP-10.8, "Temporary Installations or Omissions," Rev. 20 were evaluated.

During the course of this portion of the inspection, the following documents were reviewed:

- Bellefonte DSEP Phase I Design Basis Reconstitution, Engineering Calculations, Unit 1 & 2, October 13, 2009.
- Bellefonte DSEP Phase I Design Basis Reconstitution Program Study, Design Basis
 Documents, Unit 1 & 2.

Additional documents reviewed are listed in the attachment.

b. Observations

Several thousand active PM activities currently exist at BLN. The PM database was recreated from the previously implemented PM schedule, prior to CP cancellation, and was revised with findings from the S&L investment recovery impact assessment. PM activities were implemented in April 2009 and have been performed weekly by BLN maintenance staff. As PMs were attempted, positive and negative feedback, regarding equipment status and PM performance feasibility, was incorporated into the PM and ECM&D databases to improve the assessment of current plant status. At an approximate performance of 500 PM activities per month, TVA plans to have performed the majority of the expected PM activities by April 2010. Team observation of PM activities indicated that proper controls were established to minimize further degradation of targeted equipment.

The team verified that BLN management approved work orders, daily work activities, and weekly schedules prior to implementation. Additionally, BLN site procedures established controls for work activities performed under a deferred plant status. Specific guidance is provided that prohibits any work that could be identified as furthering plant construction or completion. If the work is questionable, it shall be reviewed by BLN management prior to the start of the effort. If work requires temporary installation of equipment to facilitate operation or PM of equipment, the temporarily installed equipment is identified and tracked in an independent database that will ensure replacement by qualified equipment, if the BLN construction effort is resumed.

c. <u>Conclusions</u>

The team concluded that the licensee has a process in place, concerning site procedures applicable to maintenance and preservation of equipment during the expected construction delay, to support transition to deferred plant status, consistent with the Commission Policy Statement.

M.1.2 M&P Implementation (IP 92050)

a. Inspection Scope

The team reviewed procedures, observed licensee activities, performed facility walkdowns, and interviewed personnel to verify the implementation of TVA's QA program for the Bellefonte site in the area of maintenance and preservation of equipment. The team observed PM activities involving the rotation of EDG building fans, the inspection of the condition of the inert gas (Nitrogen) in the Containment System electrical penetrations, and corrective maintenance removal of groundwater in-leakage into the essential raw cooling water (ERCW) cable tunnel (pipe tunnel). The team reviewed the applicable procedures, documentation, and qualification of the workers conducting the PM and corrective maintenance.

Additionally, the team observed corrective maintenance activities, taken to return the diesel driven fire pumps and RSW pumps to an operational status, for fire protection of plant. This was done to verify the equipment's capability of providing fire protection for the sites lifetime vault. This inspection included a review of the original design basis of the high pressure fire protection system and the impacts of placing certain air operated valves (AOVs) in locked open positions. This also included walk-downs of the main control room to verify RSW pump automatic controls were in appropriate positions and that indications exist that provide pump start on low tank levels.

Employee qualifications were reviewed to determine if the necessary training had been provided to qualify licensee personnel for the conduct the PM activities observed. The training required employees conducting the PM to have read SSP- 9.9, "Preventive Maintenance Long Term Layup."

Additional documents reviewed are listed in the attachment.

10

Observations

Preventive maintenance and walkdown plans and procedures were adequate to identify and minimize degradation of safety related structures. The System Engineer Walkdown procedure called particular attention to those portions of the safety-related structures most susceptible to degradation due to environmental effects. These areas included the primary containment steel liner and portions of the facility prone to ground and rainwater in-leakage. The Bellefonte DSEP Phase I Groundwater In-leakage Assessment contained measures to identify possible degradation due to groundwater in-leakage which occurred after cancellation of the construction permits. PERs 174710 and 201868 had been initiated and contained adequate measures to track the evaluation, correction, and prevention of adverse conditions associated with groundwater in-leakage into the reactor building, auxiliary building, and ERCW pipe tunnel.

The team verified that the employees, who carried out the PM on reactor building electric penetration nitrogen fill, had successfully completed the required training.

The team determined that the current maintenance of the high pressure fire protection system was adequate and that the system could provide protection of plant equipment and assets at BLN.

c. Conclusions

The team concluded that the licensee has a process in place, concerning site procedures applicable to maintenance and preservation of equipment during the expected construction delay, to support transition to deferred plant status, consistent with the Commission Policy Statement.

M.1.3 M&P Storage Activities (IP 92050, 35065)

a. <u>Inspection Scope</u>

The team reviewed procedures and interviewed personnel to verify the implementation of TVA's QA program for the BLN in the areas of housekeeping and storage controls.

The licensee's procedure for housekeeping, SSP-12.7, "Housekeeping/Cleanliness Control," Rev. 7, was reviewed and compared with the commitment requirements of ANSI-N45.2.3-1973, "Housekeeping During the Construction Phase of Nuclear Power Plants." Additionally, to determine the extent in which the licensee conducts their housekeeping tasks, several PERS were reviewed.

To evaluate warehouse, in-place, and in-plant storage conditions and determine whether the requirements of the policy statement were being met, the team performed document reviews and walk-down inspections of warehouse and in-plant storage areas. The team reviewed SSP-10.3, "Material Storage and Handling," Rev. 9, and PER 168868, Warehouse Storage-Env. Controls. The team also conducted walk-down inspections of Storage Huts HR and HU, as well as various locations within the plant.

Additional documents reviewed are listed in the attachment.

b. Observations

Inventory and environmental controls were terminated following cancellation of the CPs. Level A and B storage area requirements were not met and all indoor storage areas were subsequently classified as Level C by the licensee. Many components and materials were either removed from the site or placed in alternate, integrated storage areas containing safety and non-safety related items, as well as items that were not ready for use. The licensee has classified all components as non-safety related due to its lack of inventory and environmental control. Storage areas were clearly marked indicating that all components within must be evaluated before use in safety-related applications.

The team verified, through walkdown inspections and discussions with licensee personnel, that because housekeeping controls had not been in place during the time the construction permits were cancelled, BLN does not have any areas more restrictive than Zone IV, as described in ANSI N45.2.3-1973. The team was informed that more restrictive housekeeping zones will be established as the licensee conducts individual "hand-over-hand" inspections of SSCs and re-establishes controlled warehousing.

The licensee had initiated PER 168868 to address the storage issues and restore compliance with its material storage and handling procedure SSP-10.3. This PER requires an inventory of all stored items, restoration of Level A and B storage conditions and controls, identification of the appropriate storage level for each item, and evaluation of items for use in safety-related applications. Inventory activities were already underway at the time of the inspection.

c. Conclusions

The team concluded that the licensee has a process in place concerning applicable housekeeping and storage controls during the expected construction delay to support transition to deferred plant status, consistent with the Commission Policy Statement.

V. QA Records

R.1 Procedural Guidance and Record Validation (IP 92050, 35100)

a. Inspection Scope

The team conducted walkdowns of QA record storage facilities and assessed retrieval, access control, quality, storage, and protection of records. The team evaluated BLN's program for retrieval of QA records by requesting copies of various construction and test records and observing staff retrieving records electronically using the enterprise document management (EDM) system.

The team reviewed assessments performed by outside organizations, conducted interviews with staff responsible for records management, and reviewed implementing procedures for document control and QA records to verify that the BLN was operating in accordance with the TVA NQAP. The team evaluated the completeness of procedural instructions and guidance, assessed the staff's knowledge of the procedures, procedure implementation, and TVA plans to improve plant records. The following procedures were reviewed for adequacy:

BLN Procedure SSP-2.9, "Records Management," Rev. 15, defines the requirements and processes for managing records including generation, approval, receipt, transmittal, retention, storage, retrieval, and disposition of records. The procedure also described indexing, and access controls to records.

BLN Procedure SSP-2.3, "Document Control," Rev. 9, included requirements for generation, review, approval, and distribution control of documents.

Additional documents reviewed are listed in the attachment.

Observations

b

The team found, during the records storage facilities walkdown, that the records were stored in one of two vaults located on site. These vaults were classified as the permanent storage facility (lifetime storage) or the construction storage vault. Both facilities had proper environmental controls (temperature and humidity) restored after the lapse in QA programs at BLN following CP withdrawal. The team verified operability and calibration of equipment used for climate control and determined that QA records were protected against damage from temperature and humidity.

Requested QA records were provided to the team in a timely manner. The team observed that access to QA records was controlled and records were adequately maintained in fire resistant structures with adequate smoke and fire suppression systems. The team noted that there was no PM on the fire damper for the permanent QA records vault. The HVAC system for this storage facility is supported by a temporary unit located outside the vault in a hallway. The team determined that the fire damper could be a communicating path should the fire damper fails to close if a fire was to occur in the hallway. PER# 205486 was initiated to evaluate this issue.

The team reviewed assessment # 47-9072951-000 performed by AREVA. One of the areas that was evaluated during this assessment was radiographic films records. This AREVA assessment identified that some degradation was found on a small percentage of the films. The cause of the degradation was attributed to inadequate film processing techniques by the vendor and not caused by the storage conditions in the records vaults. An additional item, from the AREVA assessment, was that items intended to preserve the radiographic films records were missing. During this inspection, the NRC team observed staff interleaving radiography films records with acid free paper, as corrective actions from this AREVA assessment, and determined that the method used to perform this task was in accordance with implementing procedures.

c. Conclusion

The team determined that documents were properly prepared, reviewed, approved, and distributed and that QA records were stored, maintained, and controlled in accordance with the TVA's requirements.

The team concluded that the licensee has a process in place, concerning QA records applicable to equipment during the expected construction activities and delay, to support transition to deferred plant status, consistent with the Commission Policy Statement.

Final Supplemental Environmental Impact Statement

12

VII. Access Controls

A.1 Procedural Guidance and Program Implementation (IP 92050)

a. Inspection Scope

The team reviewed BLN procedure SSP-11.50, "Bellefonte Security and Plant Access", Rev. 10, and interviewed personnel to verify the implementation of TVA's access control program. While not specifically required by the guidance in the Commission Policy Statement for Deferred Plants, the team recognized the potential effect on BLN "current plant status" if efforts were not in place to minimize unauthorized plant access.

b. Observations

The team verified through witnessing entrance and exit requirements of both personnel and vehicles that security measures were implemented in accordance with prescribed procedures. Additionally, the team witnessed proper implementation of plant access procedures as Security escorted un-badged contract maintenance personnel performing building maintenance at BLN.

c. Conclusions

The team concluded that the licensee has adequate controls established to minimize potential unwanted access to BLN that might adversely and unknowingly affect plant equipment status.

V. Management Meetings

X.1 Exit Meeting Summary

On October 23, 2009, the team presented the inspection results to Mr. Ashok Bhatnagar and other members of his staff. Although some proprietary information may have been reviewed during the inspection, no proprietary information was included in this inspection report.

A-41

Single Nuclear Unit at the Bellefonte Site

SUPPLEMENTAL INFORMATION

KEY POINTS OF CONTACT

Licensee personnel Ron Arsenault, Electrical Engineer Cheryl Auvinen, Doc / Records Management Glen Camper, Maintenance Foreman Jim Chardon, Construction, Maintenance and Modifications Manager Theresa Cheek, NGDC OE / CE Manager Bob Davis, Plant Support Alvin Hinson, Engineering Support Manager Christine Johnson, Corrective Actions Program Administrator Walter Justice Jr., Site Engineering Manager Joel Landers, Safety Consultant Vernon Lee, Maintenance Specialists - PM John Muir, Operations Tom Neissen, Nuclear Assurance Manager Mark Palmer, Project Controls / OPS Manager Larry Parvin, Corrective Action Program Coordinator Scott Patterson, Design Engineer Dan Pratt, Project Engineer Zack Rad, Bellefonte Licensing Project Manager Tom Ryan, NGDC Licensing Project Manager Dan Sanchez, NGDC Training Manager Andrea Sterdis, NGDC Licensing Manager Bill Wasylow, Facilities Supervisor Dale Whitecomb, Licensing Support Dennis Williams, Operations

Attachment

Final Supplemental Environmental Impact Statement

List of Documents Reviewed

Drawings

3BE1818-CA-01A, "Auxiliary Feedwater System," Rev. 0 35W0606-CS-01, "Condensate System," Rev. 0 3BE0854-NM-01A, "Spent Fuel Pool Cooling," Rev. 0 3BE1856-KC-01A, "Component Cooling System," Rev. 0 3BE1812-ND-01A, "Decay Heat Removal System," Rev. 0 3BE1843-VE-01A, "Auxiliary Building Trained Areas Air Conditioning System," Rev. 0

Procedures

SSP-1.50, "Bellefonte Organization and Responsibilities," Rev 10,

SSP-2.3, "Administration of Site Procedures," Rev 13,

SSP- 2.7, "Document Control", Rev. 9,

SSP- 2.9, "Records Management," Rev. 15,

SSP-3.1, "Conduct of Quality Assurance," Rev. 13, SSP-3.4, "Corrective Action Program," Rev. 6, SSP-4.5, "Regulatory Reporting Requirements," Rev. 13, SSP- 6.2, "Work Control," Rev. 8,

SSP-10.3, "Material Storage and Handling," Rev. 9,

SSP-12.7, "Housekeeping/Cleanliness Controls," Rev. 7,

SSP-11.50, "Bellefonte Security and Plant Access," Rev. 10,

BLTI-PREV-09, "System Engineer Walkdowns," Rev. 11,

PI-TVAN-06, Bellefonte Nuclear Plant Configuration Recovery, Rev. 1.

PI-TVAN-07, Bellefonte Nuclear Plant Configuration Control Assessment, Rev. 0.

PI-TVAN-08. Bellefonte Nuclear Plant Configuration Recovery Record/Identification, Rev. 1,

PI-TVAN-09, Bellefonte Nuclear Plant Configuration Recovery Record Update. Rev. 0,

PI-TVAN-10, Bellefonte Nuclear Plant Configuration Recovery Phase 4 Record Update. Rev. 0 NAPD-2, Audits, Rev. 0025, February 18, 2009.

Self-Assessments

BLN-CAP-09-01, "Review of BLN PERs for Trends"

Bellefonte Nuclear Plant Units 1 & 2 Deferred Status Assessment Report, Rev. 0, August 11, 2009

Bellefonte Nuclear Plant Units 1 and 2 Construction Permit and Plant Layup Activities - Audit BLA0901, July 15, 2009

BLN-CAP-09-01 Self Assessment Report - Review of BLN PERs for Trends, August 12, 2009

BLN-CAP-S-09-002 Self Assessment Report - Comparison of the Bellefonte Corrective Action Program to the NPG Corrective Action Process, September 9, 2009

BLN-Site-09-001 Self Assessment Report - BLN Units 1 and 2 Readiness to Return to Deferred Plant Status, June 11, 2009

BLN-Site-09-001A Self Assessment Report - Follow-up On BLN Units 1 and 2 Readiness to Return to Deferred Plant Status, September 28, 2009

PERs Reviewed

168868, Warehouse Storage-Env. Controls

170768, Lack of reportability process

171986, Lighting circuits not per drawings

173729, HP Fire Protection System

173755, Groundwater intrusion

173511, BLN Deferred Status Readiness - Internal Assessment AFI No 1

Single Nuclear Unit at the Bellefonte Site

3

173550, BLN Deferred Status Readiness - Internal Assessment AFI No 2 174748. Document control support of upcoming reviews 174750, Plant environment following withdrawal of construction permits 174325, Limited distribution of controlled procedures 174452, Bellefonte security practices 174457, BLN procedures referencing Operating Plant requirements documents 174459, Late approval of BLN corrective action plans 174431, BLN procedure discrepancies 174437, Bellefonte procedure discrepancies 174490. In process work requests documentation 174665, Affected employee clearance training 174674, Operation review of TIO forms 174675, ER specification admin errors 174710, Groundwater In-leakage into Auxiliary Building and Reactor Building 174715. Involvement of ISO in PER 169084 corrective action 174751, Compliance with records management procedure 174752, BLN work control/ service request procedure inconsistencies 174811, Corrective action program 174831, CMTR not yet reviewed 174836, COC typcgraphical error - Auxiliary Feedwater 174858, Record storage - Boyer underground facility 174875, NA audit BLA0901 recommendations 174894, Bellefonte tags plus 175091, Reporting requirements 177443, Fire extinguishers not secured 177446, FME program at BLN 177449, U1 containment roll-up door 177451, Document control environmental controls 177452, Recurrence controls for PER 171986 177453, Fire Protection System availability 177456, Plant security program at BLN 177458, Records vault isolation HVAC dampers 177460, Reg guide tabulation 177462, Permit status 177463, Open condition reports 177405, ECM and D software status 177468, Documentation presentation for deferral effort 177459, CP status communication 177474, Construction permit status 177476, Stellite reduction program 177478, S and L procedure details 200119, U1 V9 Tendon Coupler Failed 201357, Enhancements to SSP-3.4 201868, Water is in the ERCW cable tunnel (pipe tunnel) 202352, Open or breached systems not managed effectively 202411, Employee crossed protective burm in 125V battery room 203644. A safety issue was identified, there appears to be energized 480v conductors exposed

PERs initiated as a result of this inspection

205213, Tagging Practice Inconsistent With NPG Standards 205215, Control of Components

205218, NRC Provided Info With Missing Pages

205281, NRC Identified - Wrong proc ref in BLN project report for Imp of Nuclear QA Prog for BLN U1/U2

205351, Bellefonte has established a practice of using policies

205375. The corrective action plan for PER 173511 was inadequate

205376, Weld damaged on pipe connected to VLV 1-INM-VCAL-79-N

205387, PER 177453 was improperly closed to per action 173511-003 and did not address original problem

205389, NRC identified duplicate use of the term "Service Request".

205390, NRC identified a possible disconnect between responsibilities outlined in SSP-1.50 and SSP-3.1

205396, Cord found in bottom of file cabinet

205397, Cabinet Drawer Locked With No Key

205398, Blanks Found on Records Signature Log

205402, Improper closure of PER 177458

205454, MRC Observation

205458, Use of flagging for barricades is not IAW with the Health & Safety Manual Section 602.

205486, There are currently no PMs on the Fire Dampers for the Permanent QA Records Vault.

205585, NRC Identified difference in nomenclature between Hold Order tag and breaker

205586, NRC Recommendation to evaluate security procedures to address unauthorized intrusion into plant

205589, Inability to provide definitive answer regarding fire damper PM requirements

Miscellaneous

Sargent & Lundy Project No. 12054-006 Rpt. No. 3 of 4, "Bellefonte DSEP Phase I Design Basis Reconstitution Program Study Design Basis Documents Unit 1 & 2", October 13, 2009 Sargent & Lundy Project No. 12054-006 Rpt. No. 1 of 4, "Bellefonte DSEP Phase I Design

Configuration Control Engineering Databases and Applications Unit 1 & 2", October 13, 2009 Sargent & Lundy Project No. 12054-006 Rpt. No. 2 of 4, "Bellefonte DSEP Phase I Design Configuration Control Engineering Procedures Unit 1 & 2", October 13, 2009

Sargent & Lundy Project No. 12054-006 Rpt. No. 4 of 4, "Bellefonte DSEP Phase I Engineering Calculations Unit 1 & 2", October 13, 2009

Sargent & Lundy Project No. 12054-012 Rpt. No. 2 of 4, "Bellefonte DSEP Phase 1

Groundwater In-leakage Assessment Unit 1 & 2", October 13, 2009

DBD-RF, "High Pressure Fire Protection System", Revision 1

System Engineer Walkdowns, BLTI-PREV-09, 2/6/2009

Bellefonte DSEP Phase I Groundwater In-leakage Assessment

Final Supplemental Environmental Impact Statement

Page intentionally blank

APPENDIX C – RESPONSES TO AGENCY AND PUBLIC COMMENTS

Page intentionally blank

TABLE OF CONTENTS

RESPONSE TO PUBLIC COMMENTS	A-51
Analysis of Comments	A-51
Agency Letters	A-51
U.S. Environmental Protection Agency — Region IV Atlanta	A-52
U.S. Department of Interior	A-86
State of Alabama — Alabama Historical Commission	A-87
Georgia Department of Natural Resources — Historic Preservation Division	A-89
Public Comments	` A-91
General	A-91
The NEPA Process	A-93
For and Against the Alternatives	A-95
Air Quality	
Aquatic Ecology	A-97
Climatology & Meteorology	
Cost of New Generation	A-99
Delivered Cost of Power	
Demand-Side Management (DSM)	
Energy Alternatives	A-102
Floodplain and Flood Risk	A-108
Need for Power	
Nuclear Plant Safety and Security	
Nuclear Reactor Design	
Radiological Waste (RadWaste)	
Seismology	
Socioeconomics	
Spent Fuel	
Water Quality	
Water Supply	
Wetlands	
List of Individual Commenters and Associated Comment Statement Numbers	A-122

Page intentionally blank

RESPONSE TO PUBLIC COMMENTS

The draft supplemental environmental impact statement (DSEIS) was available for public review and comment from November 13, 2009 through December 28, 2009. The document was transmitted to state, federal, and local agencies and federally recognized tribes. It was also available on TVA's website for review. Thirty-nine agencies, businesses, organizations, and individuals commented on the DSEIS via mail, email, and verbal statements. In addition, a public meeting was held in Scottsboro, Alabama on December 8, 2010 where the public had the opportunity to ask questions about the DSEIS and submit comments. Forty-nine people registered for the public meeting. This appendix summarizes the public's comments on the DSEIS and TVA's responses to those comments.

Analysis of Comments

Commenters submitted a variety of comments on the DSEIS. The comments were reviewed and arranged into groups with similar concerns. Then, a primary comment statement was prepared for each group of comments. Finally, a response was generated for each comment statement. While many of the commenters supported nuclear power, others voiced general concerns about the use of nuclear power. Many comments focused on the age of existing structures, water quality, reactor design, the safety of nuclear power, air quality, spent fuel, radwaste, alternative sources of energy and conservation, and socioeconomic impacts. Some comments raised concerns about the need and cost of power and cumulative effects.

The individuals, businesses, organizations, and agencies that commented on the DSEIS are listed in Table 1. The table lists each commenter alphabetically and identifies the comment statement or statements attributed to the commenter.

The identifiers for the comment statements are associated with each comment statement in the section immediately preceding the table. The actual letters, e-mails, facsimiles, and transcripts of verbal statements have been included in the administrative record.

Agency Letters

TVA received four letters from state and federal agencies during the 45-day public comment period. The responses to agency comments on the DSEIS follow each letter.

U.S. Environmental Protection Agency — Region IV Atlanta



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY REGION 4 ATLANTA FEDERAL CENTER 61 FORSYTH STREET ATLANTA, GEORGIA 30303-8960

December 11, 2009

Ms. Linda B. Shipp Senior Manager NEPA Compliance Environmental Permitting and Compliance Office of Environmental Research Tennessee Valley Authority 400 West Summit Hill Drive Knoxville, TN 37902

Attn: Ms. Ruth Horton Senior NEPA Specialist

Subject: EPA's NEPA Review Comments on TVA's DSEIS for the "Single Nuclear Unit at the Bellefonte Plant Site" (November 2009); Jackson County, Alabama

Dear Ms. Shipp:

The U.S. Environmental Protection Agency (EPA) has reviewed the subject Tennessee Valley Authority (TVA) Draft Supplemental Environmental Impact Statement (DSEIS) in accordance with our responsibilities under Section 102(2)(C) of the National Environmental Policy Act (NEPA) and Section 309 of the Clean Air Act. TVA has identified an additional need for baseload capacity in the Tennessee Valley for the 2018-2020 timeframe. In response, TVA proposes to either complete or construct and operate one nuclear generating unit at the Bellefonte Nuclear Plant (BLN) brownfield site with a capacity of at least 1,100 MW and up to 1,200 MW, and an expected life cycle of 40 years. BLN is a 1,600-acre peninsular site located on TVA's Guntersville Reservoir in Jackson County Alabama near the town of Hollywood and city of Scottsboro. Three larger cities located within a 50-mile radius of the BLN site are Huntsville and Gadsden, Alabama, and Chattanooga, Tennessee.

EPA environmentally supports TVA's consideration of additional nuclear power in its power mix for the Tennessee Valley if impacts can be minimized and mitigated. Compared to conventional forms of fossil fuels such as pulverized coal, the use of nuclear power reduces overall air emissions – both criteria pollutants and emissions such as carbon dioxide associated with climate change effects. Although nuclear plants may have spent fuel disposal and safety concerns, we give deference to and assume facility safety compliance with the U.S. Nuclear Regulatory Commission (NRC) and TVA requirements and standards. We note that TVA currently operates three nuclear sites in the Valley with two or more reactor units each: Browns Ferry Nuclear Plant (BFN) on the nearby Wheeler Reservoir in Alabama, and the Watts Bar Nuclear Plant (WBN) and

Internet Address (URL) • http://www.epa.gov Recycled/Recyclable • Printed with Vegetable Oil Based Inks on Recycled Paper (Minimum 30% Postconsumer)

Final Supplemental Environmental Impact Statement

Sequoyah Nuclear Plant (SQN) on the Chicamauga Reservoir in Tennessee. We believe that renewables, clean fossil fuel options and nuclear power will become more and more prominent and eventually replace conventional fossil fuels for power generation.

Background

The TVA Bellefonte site has an extended history. The original TVA license application of 1973 to construct two nuclear reactors at BLN was made to the Atomic Energy Commission, pre-dating the NRC. Filing an application for an operational license followed in 1978. However, with construction for BLN Unit 1 (BLN 1) about 90% complete and for BLN Unit 2 (BLN 2) about 58% complete in the mid-1980s, TVA requested a deferred license status from NRC due to reduced growth forecasts. This deferred status was continued and NRC extended the construction permits to 2011 and 2014 for the two units. In the late 1990s, TVA also issued a "BLN Conversion EIS" to repower Bellefonte from a nuclear facility to a natural gas facility (i.e., combustion turbine plant). EPA provided comments on the DEIS and FEIS in 1997, although conversion construction did not go forward.¹ Subsequently in 2006, TVA submitted a site redress plan and NRC withdrew the construction permits. As part of the TVA redress plan and asset recovery program, unneeded portions of the Bellefonte site "were sold for reuse or abandoned in place" (pg. 4)² while others, such as a substation and training center, continued to operate. In response to more favorable power economics since 2005, TVA formally requested re-instatement of the construction permits for BLN 1&2 in 2009. Also, the earlier 2008 COLA ER proposed the Westinghouse AP1000 units BLN 3 and 4 at Bellefonte. On October 19, 2009, NRC conducted a site inspection for the requested deferred status and a response letter to TVA is pending.³ Of note is that there was a lapse in quality assurance oversight during the period of permit withdrawal through March 2009, a fact that was entered into the Corrective Action Program.

TVA has not determined whether to complete an existing structure or construct a new structure for the proposed single nuclear generating unit. That is, one of the existing partially completed units could be completed using a Babcock & Wilcox (B&W) pressurized light water reactor technology as BLN 1 or 2, or a new unit could be constructed using a Westinghouse AP1000 (AP1000) advanced pressurized light water reactor technology proposed as BLN 3 or 4 in 2008.

Existing plant structures at BLN include several buildings (two reactor containment, two diesel generator, control, turbine, auxiliary, service and office buildings), a condenser circulating water pumping station, a river intake pumping station, two natural draft cooling towers, a transformer yard, a 500-kV and a 161-kV switchyard,

¹ TVA's interim consideration to convert to a natural gas plant was not documented in the present DSEIS in Section 1.2, but should be noted in the Final SEIS (FSEIS). However, we note that the BLN Conversion EIS was referenced in Section 1.7. BLN 3 and 4 should also be referenced relative to the 2008 Combined <u>License</u> Application Environmental Report (COLA ER).

² The FSEIS should summarize the equipment and structures that were sold and discuss how this might change the Exclusion Area Boundary (EAB) from previous analyses referenced in the DSEIS and whether the previous X/Q and dose calculations are still appropriate or must be re-calculated.
³ NRC's findings regarding this site inspection should be disclosed in the FSEIS.

EPA03

EPA02

EPA01 cont

- 3

a spent nuclear fuel storage pool; sewage treatment facilities, a helicopter pad and railroad spurs. These facilities remain intact but some, such as one of the cooling towers, will need repair or upgrading. Potential work on existing BLN 1 or 2 is facilitated since neither were completed or irradiated when construction ceased.

Reactor Technologies

The DSEIS considers the older B&W and the modern AP1000 reactor technologies as its two nuclear reactor alternatives for the proposed unit at BLN. These alternatives were the Completion and Operation of a Single B&W Pressurized Light Water Reactor (Alt. B) of Construction and Operation of a Westinghouse AP1000 Advanced Pressurized Light Water Reactor (Alt. C). Alternative B would maximize re-use of the existing, partially-constructed structures at BLN to complete the B&W reactor, i.e., primarily the re-use of one of the two started reactors (BLN 1 or 2). Alternative C would start construction of a new nuclear generation facility using an AP1000 reactor technology (BLN 3 or 4), although some reactor support facilities such as one of the two existing cooling towers could still be re-used.

EPA typically supports the re-use of materials and sites (brownfields/grayfields over greenfields). For the present proposal, re-use would be maximized by Alternative B where BLN 1 or 2 would be completed with the intended B&W reactor design. In this case, however, EPA is concerned that over 20 years have elapsed since construction ceased on BLN 1&2 in the mid-1980s, and that construction designs and materials as well as new inspection standards have significantly changed – especially for development of a nuclear generation unit.

Beyond the uncertainty of the structural integrity of the partially-completed BLN 1&2, it should be noted that the B&W technology is not as efficient and safe as the AP1000 technology (or equivalent). Compared to the B&W design, the DSEIS documents that an AP1000 reactor uses less radioactive fuel (1,821 fuel assemblies vs. 2,285) over a 40-year life cycle (Table 2-2) and therefore produces less spent fuel for disposal; needs fewer components (Fig. 2-8); has inherent public health safety features in its new "passive" safety design (Sec. 2.3) with less potential radiological effects (Sec. 3.17) and designbased accidents (Sec. 3.19); and requires less water intake for cooling with less thermal discharge volumes.

Purpose & Need

The purpose of the present SEIS is to notify agencies and the public that TVA proposes a major federal action to complete or construct and operate a single nuclear generating unit at BLN, and to document the resultant potential environmental impacts for this unit (pg. S-1). Although TVA may wish to add additional future units at the BLN site, only TVA's NEPA responsibilities for the proposed single BLN nuclear generating unit are covered in the present SEIS. Accordingly, additional TVA NEPA documentation would be needed for additional units at the BNL site (however, if reasonably foreseeable, the cumulative impacts of such additional units should be included in this FSEIS).

EPA04

EPA05

4

Moreover, we understand from TVA that NRC will subsequently develop its own NEPA document on the licensing process for BLN once TVA determines its selected reactor technology in its Record of Decision (ROD) for the present BLN SEIS.

Alternatives

In addition to the above two nuclear generation alternatives (and the no action), power alternatives requiring or not requiring new generation, site selection alternatives, and transmission alternatives (with the no action) were presented in the DSEIS. Although these alternatives are further described in the enclosed *Detailed Comments*, we offer the following summary comments.

* Suitability of Existing BLN Structures: If Alternative B is selected for the FSEIS, the suitability for re-using existing structures associated with the B&W reactor should be discussed. While EPA typically supports the re-use of materials and sites (brownfields and grayfields over greenfields), we are concerned that over 20 years have elapsed since construction was suspended on BLN 1&2.⁴ While we defer nuclear plant safety to TVA and NRC, EPA has documented our re-use construction concerns in the enclosed *Detailed Comments*.

EPA07

EPA08

EPA09

EPA10

EPA11

* Reactor Technologies: The relative environmental and engineering merits of the B&W and AP1000 technologies are compared in the DSEIS. EPA finds that the modern AP1000 technology (or equivalent) is the preferred design for TVA's proposed nuclear generation unit at BLN. EPA prefers this type of AP1000 reactor (Alt. C) over the B&W design (Alt. B) despite the fact that more existing structures at BLN could be used (if found competent) by completing either BLN1 or BLN 2 with the B&W design.

* "Green" Alternatives: With or without the present nuclear generation project, EPA strongly believes that green alternatives should continue to be promoted by TVA and that the FSEIS should summarize ways in which TVA is promoting such green alternatives, particularly efficiency/conservation and the addition of renewable capacity to support clean conventional baseload options. The FSEIS should also discuss how the amount of energy that could be saved or generated by these green alternatives would compare to the identified need and projected 1,100-1,200 MW capacity of the proposed BLN unit.

* Alternate Sites: TVA screened several existing, brownfield and greenfield sites in its site selection process. We understand that co-location of the proposed nuclear unit at an existing TVA nuclear power station such as BFN may not be advisable due to cumulative thermal discharge issues at the same site and reservoir. Other potential co-locations at WBN and SQN apparently have onsite space conflicts. Former TVA plant sites (e.g., Hartsville Nuclear Plant site) are also not ideal since all or most of the

Presumably because of new construction standards and other upgrades, the 90% and 58% completion levels for BLN 1&2, respectively, may translate into only a 55% and 35% completion level according to the internet (Wikipedia). The FSEIS should discuss this.

5

lands have now been sold to private developers. Finally, development of the Murphy Hill (MH) greenfield site would likely have more environmental impacts than development of the BLN brownfield site, even though MH was already partially graded before a proposed TVA gasification plant at MH was cancelled. Although these site options might be revisited for verification in the FSEIS, we agree that the availability of the BLN brownfield site for development with either Alternative B or C has environmental merit.

* Transmission Upgrades: If Alternative B (B&W) or C (AP1000) is pursued by TVA, transmission lines and facilities would need to be upgraded through refurbishment (Option 1) or new construction (Option 2) to accommodate the 1,100-1,200 MW of additional electricity. We agree with the selection of Option 1 from an environmental perspective.

* FSEIS Conclusions: In the FSEIS, TVA should confirm or modify its DSEIS preferred alternatives and select a preferred reactor technology.

Environmental Impacts

Although additional EPA comments are provided in the *Detailed Comments* enclosure, we offer the following summary comments on the environmental impacts of the proposed nuclear generation unit at BLN.

* Air Quality – One of the advantages of a nuclear power plant is that the criteria pollutants and climate change air emissions associated fossil fuel plants are circumvented or significantly reduced. As discussed in the *Detailed Comments*, our BLN air quality comments are therefore more procedural, relating to meteorological data; dispersion modeling assumptions, procedures, and inputs; use of the new PM 2.5 standard; and further substantiation of some conclusions.

* Radiological Effects – As indicated previously, EPA prefers the AP1000 reactor design over the B&W technology. One of the reasons for this preference is that the AP1000 is inherently safer than the B&W design due to its advanced passive safety design. We have also provided additional comments on radiological effects in the enclosed Detailed Comments. These primarily focused on our requests for additional substantiation of provided dose calculations, tritium detection and the storage of spent nuclear fuel.

* Waters of the US – It appears from the DSEIS that avoidance and minimization of adverse impacts to aquatic resources under the federal Clean Water Act (CWA) Section 404 are being taken into consideration appropriately. That the project would utilize existing structures and transmission corridors, to varying degrees based on alternatives, is a good approach to mitigation as a baseline. Whereas Alternative B (B&W) would not result in the filling of wetlands and Alternative C (AP1000) would impact 12.2 acres, operational safety and modernization considerations associated with the AP1000 design provide adequate justification for pursuing Alternative C if it is otherwise appropriate. Once an alternative is selected and TVA is ready to proceed, a CWA Section 404 permit application should be submitted that characterizes any wetlands and/or stream impacts. EPA13

EPA11 cont.

EPA14

EPA15 cont.

along with a mitigation plan to address them. Also, since upgrading existing transmission line and facilities (Option 1) is preferred by TVA over new construction, we assume that there would not be any additional wetland impacts associated with project transmission upgrades.

6

* Surface Water – Surface water withdrawals ("make-up water") are needed to account for the proposed nuclear power unit's evaporative losses, cooling tower drift and discharges ("blowdown") to remove solids that accumulate in the cooling water. The Tennessee River (Guntersville Reservoir) would be both the source water for intake withdrawals and receiving waters for downstream discharges via a submerged diffuser (Figs. 3-2 to 3-5).

Although both the B&W and AP1000 technologies would operate in a closed-circuit mode and utilize one of the existing natural draft cooling towers to cool reactor cooling waters, thermal effluent would nevertheless be generated and discharged back into the Guntersville Reservoir receiving waters. Discharge of this heated blowdown is regulated by the State of Alahama National Pollutant Discharge Elimination System (NPDES) permit. This permit also prescribes thermal discharge limits, which are not to exceed a 92°F monthly average, 95°F daily maximum, and 5°F increase over ambient conditions. Hydrothermal modeling (pg. 94) appears to predict that the proposed nuclear unit would not exceed these limits for both Alternatives B and C outside the mixing zone, with the exception of infrequent and unusual hydrologic or meteorological conditions. The FSEIS should clarify and summarize if compliance with all three thermal limits is indeed predicted for both designs and what measures will be taken for compliance during unusual river flows and weather conditions (e.g., generation at less than nameplate capacity or temporary unit shutdown).

As suggested above, it is noteworthy that the AP1000 technology would require significantly less surface water than the B&W technology – 72% of the B&W withdrawal volume and 36% of the B&W discharge volume (pg. 95). The expected withdrawal rate for the B&W reactor is 34,000 gpm (75 cfs) and discharge rate is 22,650 gpm (50 cfs), while the withdrawal rate for the AP1000 reactor is 23,953 gpm (53 cfs) and discharge rate is 7,914 gpm (18 cfs).⁵ Overall, this would result in a lower level of thermal pollution for Guntersville Reservoir, even if both technologies are predicted to comply with NPDES thermal limitations. Such relative differences in efficiency should be considered in TVA's final selection of a preferred reactor technology, particularly if additional units would be added at BLN in the future causing cumulative effects.

In regard to chemical additives such as biocides and inhibitors added to the cooling waters to control fouling, EPA recommends that the minimum amount of chemical additives be used and that concentrations be monitored. We will defer to the State of Alabama's NPDES permit regarding compliance with water quality standards for discharge effluents, and retain our federal permit oversight.

³ Although a minor discrepancy, these "gpm" data suggest a difference of 71% and 35% as opposed to the 72% and 36% stated in the DSEIS.

EPA20

EPA19

EPA16

EPA17

· · ·	
* Environmental Justice (EJ) – U.S. Census data for 2000 for the block group incorporating BLN showed a minority level (percentage) higher than the county average but lower than the state and national averages. Estimates for 2008 showed increases in	EPA21
minorities but with probably similar trends. U.S. Census poverty levels for 2000 and 2007 estimates showed a poverty level percent for the BLN area that is below county, state and national levels. EJ evaluations were made in the BLN Conversion EIS (1997) and were referenced (pg. 146). The more recent COLA ER concluded "that any impacts would be minor and not disproportionate." Moreover, "more recent data" with the same conclusion were also referenced, but not cited. The FSEIS should briefly	EPA22
substantiate these conclusions, rather than only incorporating by reference, and provide citations/timeframes. Also, any potential concentrations ("pockets") of minority and/or low-income populations near the BLN site should be identified in the FSEIS. It should be noted that a potential EJ impact at BLN would make this site less environmentally preferable to EPA despite being an available brownfield site.	EPA23 EPA24
Regardless of the final EJ conclusion, TVA should provide public outreach on the project to all demographics living near the site during the SEIS process as well as periodic updates thereafter.	EPA25
* Induced/Secondary/Cumulative Impacts – Although TVA has identified a need for additional power by 2018-2020, supplying such power (1,100-1,200 MW) will likely accommodate or induce additional growth in the Tennessee Valley and result in developmental impacts. The FSEIS should acknowledge these expected secondary impacts as a project consequence.	EPA26
Regarding cumulative effects, NEPA documents should discuss the past, present and reasonably foresceable future projects (federal and non-federal) within the project area. This listing should focus on projects that impact the same resources as the proposal, with impacts being qualified and quantified to the extent feasible. In the case of the present BLN proposal, nearby projects with similar impacts (wetland, water quality and radiological impacts) should be emphasized.	EPA27
We note that Section 3.13.10 discusses cumulative impacts, albeit only for socioeconomics, while other environmental consequences do not have a cumulative impacts section. This document format is somewhat cumbersome and could be streamlined in the FSEIS by designating only one cumulative impacts section that covers all relevant parameters.	EPA28
EPA DSEIS Rating	
•	•

7

EPA rates this DSEIS an "EC-2" (Environmental Concerns, additional information requested). We primarily base this rating on the inherent uncertainties associated with a nuclear power unit.

Final Supplemental Environmental Impact Statement

Summary

EPA supports TVA's consideration of additional nuclear power for the Tennessee Valley due to its reduced air emissions compared to conventional fossil fuel technologies. However, we will defer nuclear plant safety issues to NRC and TVA. For the proposed nuclear generation unit at the Bellefonte site, EPA prefers the AP1000 technology (or equivalent). EPA therefore prefers Alternative C (AP1000) over Alternative B (B&W). However, we also support the use of green alternatives (renewables, efficiency and conservation) if it can be shown that they can provide the identified power need in lieu of the planned nuclear unit, or if not, as a growing supplement to TVA's baseload capacity. Moreover, EPA favors the use of brownfields, grayfields and co-located facilities when feasible and new impacts are not thereby generated. We therefore agree that the availability of the BLN brownfield site for development has environmental merit. Finally, we concur that refurbishing transmission lines and facilities (Option 1) if all current regulatory codes can be met rather than constructing new ones is environmentally appropriate if the BLN project is pursued by TVA. In the FSEIS, TVA should confirm or modify its DSEIS preferred alternatives and select a preferred reactor technology.

EPA30

Regarding project impacts for the proposed single nuclear unit, the FSEIS should provide additional background information for air quality impacts and radiological effects; discuss mitigation for BLN impacts to waters of the US (Alt. C); insure compliance with State NPDES thermal limits for heated effluent discharges by either reactor technology (Alts B or C); verify minor or no EJ impacts, and revise the cumulative impacts section.

EPA29

EPA32

EPA appreciates the opportunity to review this DSEIS. Should you have questions on our comments, please contact Chris Hoberg of my staff at 404/562-9619 or <u>hoberg.chris@cpu.gov</u> for NEPA issues, and Stanley Krivo of the Air, Pesticides and Toxics Management Division at 404/562-9123 or <u>krivo.stanley@cpa.gov</u> for air quality technical issues.

Sincerely,

Heinz J. Mueller, Chief NEPA Program Office Office of Policy and Management

Enclosure: Detailed Comments

-9

DETAILED COMMENTS

Environmental Impacts

o Air Quality - EPA's air quality comments for the DSEIS are as follows:

+ Section 3.16.1.2 Local Meteorology (pg. 160)

* Meteorological Data (2006-2008): The discussion of the updated 2006-2008 meteorological data period does not provide a complete summary of the meteorological conditions. This discussion should be supplemented with tables and figures that provide EPA33 applicable wind roses, frequency distributions, comparisons, etc. that would provide the reader with a better understanding of the current meteorological conditions. The tables and figures will also allow comparisons with previous observations and long-term records, and a basis for the evaluation of subsequent dispersion and transport analyses. * Comparison of Meteorological Data Records: The stability class frequency distribution is used to show agreement between different meteorological data records. FPA34 EPA believes that this is not sufficient to show agreement. The data record comparisons should include joint frequency distributions of stability, wind direction, and wind speed. + Section 3.16.2.1 Dispersion (pg. 162) * Section Contents/Title: This section is concerned with both the dispersion and EPA35 transport of cffluent releases. Therefore, we suggest changing the name to "Transport and Dispersion". * Transport and Dispersion Modeling Procedures: The atmospheric transport and dispersion modeling procedures, computer model, and input parameters used to EPA36 develop the provided dispersion estimates should be provided. Explanations may be needed for some of the input parameters (e.g., modeled receptors). An appendix could be used for this information. * Figure of Reactor Plant Layouts: A figure providing the plant layout, release vents, building heights, and receptor locations, for both the B&W and AP1000 reactor EPA37 units would be of value in understanding the information provided. We recommend inclusion of such a figure in the FSEIS. * Define Symbols: The definition and importance of calculated X/O, X/O no EPA38 decay undepleted, X/Q 2.26 day decay undepleted, X/Q 8.0 day decay depleted, and D/Q values provided in Tables 3-14, 15, and 16 should be explained. * Receptor Type and Locations: The receptors of interest in Tables 3-14 and 3-15 EPA39 (e.g., nearest cow, garden, goat, etc.) for the B&W reactor appear to be different

Appendix C

depending on the location of the release. Some of these locations appear to be inside EPA39 cont. the EAB. An explanation should be provided. Table 3-16 has four receptor types at the same location which appears to be within the EPA40 EAB. This table also has a new column "Maximum Receptor Type Value". The FSEIS should explain these items. The reason routine releases (i.e., Tables 3-14, 15 & 16) used the maximum modeled dispersion values while the accidental releases provided in Tables 3-17 and 18 use the EPA41 50% probability values should be explained. Because the accident releases are concerned with mostly short-term periods (i.e., less than 24 hours), the maximum values would appear to be appropriate. * Release Boundary: The "release boundary" used to determine the distance of EPA42 interest for the accidental release X/Q values should be explained. It appears that the release location used for the previous routine releases could be used. + Section 3.16.3 Affected Environment - Air Quality (pg. 164) * Auxiliary Equipment Emissions: This section does not address the anticipated emissions from the auxiliary equipment except by referencing the 1974 TVA Final EPA43 Environmental Statement (FES). The FSEIS should include/provide the appropriate emission values and impact assessments for these project emissions. * New PM 2.5 Standard: This section indicates that the new PM 2.5 24-hour National Ambient Air Quality Standards (NAAQS) was not addressed in previous EPA44 documents. This new standard should be addressed in evaluating the project PM 2.5 impact in the FSEIS. * PSD Class I Areas: Class I Areas beyond 100 km should not be eliminated EPA45 from impact consideration. The need to perform Class I area impact assessment depends on the magnitude of the emissions and the distance to the receptors of concern. • Radiological Effects - We offer the following comments. + Section 3.17 Radiological Effects of Normal Operations (pg. 167) - This section indicates recent dose calculations confirm the earlier 1974 assessment for the B&W EPA46 reactors so the 1974 impacts are applicable for the proposed project. The DSEIS contains no demonstration for this conclusion. The recent dose calculations should be provided along with comparison to the referenced 1974 assessment to demonstrate this conclusion, An appendix could be used to provide this needed documentation, + Section 3.17.3.2 Radiation Doses Due to Gaseous Effluents (pg. 173) - The stated purpose of this section is to revise the inputs and methodologies used in the 1974 FES to EPA47 use current values representing recent meteorological, population and agricultural data. It also provides gaseous effluent doses for the AP1000 unit. This section should provide

Single Nuclear Unit at the Bellefonte Site

11

the modeling procedures, computer model, and input parameters etc. used to develop the provided doses. An appendix could be used for this information.

EPA47 cont.

EPA48

+ Section 3.19.1 Design-Basis Accidents (pg. 197) - The purpose of this section is to update the accident dose consequences given in the previous BLN Units 1 and 2 Final Safety Analysis Report (FSAR) (TVA 1991) using atmospheric dispersion values based on current meteorological data and to present corresponding results for the AP1000 unit. The second paragraph on page 199 indicates this was not done directly through re-modeling but by using previously reported doses scaled by 50 percentile X/Q values using the more current meteorological data period. Confirmation is needed that all other parameters used in the dose assessments remain unchanged for the two reactors (e.g., EAD and LPZ distance for each reactor, the Q values, etc.).

+ <u>Tritium</u> – Undetected levels of tritium in the liquid pathway in the vicinity of some of the currently operating reactors has been an ongoing concern. The levels of tritium released via the liquid pathway annually for either the B&W or AP1000 reactors listed in Tables 3-23 and 3-24, respectively, should be monitored closely and actions levels put in place as these numbers are approached. As an example, for the AP1000, if 50% of the estimated annual release of 1010 C/yr is reached, more frequent environmental monitoring and/or sampling should be conducted. Additionally, if necessary, TVA may need to re-evaluate the operational parameters of the reactor and its associated liquid waste treatment systems. Guidelines for the need to increase the frequency of monitoring for tritium based on predetermined action levels should be addressed in the TVA Radiological Environmental Monitoring Program (REMP), if they are not already included.

+ <u>Spent Fuel Storage</u> – An ongoing, long-term issue is the projected storage of spent nuclear fuel onsite until late in the 21st century, addressed in Section 3.18.2. Although the NRC has determined that this can be done safely for an extended period of time with little risk to the public, it is desirable but not certain that a high-level waste repository will be licensed prior to the need for an onsite spent fuel storage facility in 2036.

+ <u>Other</u> – The basis and documentation for the dose calculations should be provided. An appendix could be used to provide this information.

o Noise - We offer the following noise comments:

+ <u>Cooling Towers</u>: Page 142 indicates that operational noise generated by the cooling tower is expected to be 48 dBA at the nearest residence (similar to ambient levels) and 54.6 dBA if the tower was operated 24 hours a day. The FSEIS should define the frequency of operation associated with the 48 dBA level and the basis of such an operational timeframe.

+ <u>Noise Metric</u>: The noise metric used in the DSEIS is unclear. That is, are the provided data in dBA instantaneous or averaged, such as the day-night level (DNL) descriptor? We assume the readings are in DNL but should be clarified in the FSEIS

EPA50

EPA49

EPA51

EPA52

EPA53

EPA54

Final Supplemental Environmental Impact Statement

A-62

(e.g., "48 dBA" could be designated as "48 DNL", "48 dBA DNL", Ldn = 48 dBA, or an introductory sentence indicating that all noise data are expressed in DNL).

+ <u>Blasting</u>: Blasting may be associated with construction of the AP1000 reactor. The FSEIS should provide additional information on the expected noise levels during blasting at the nearest residence and the frequency of such events.

+ <u>Residences</u>: Approximately how many residences are located in the proximity of the "nearest residence"? Are homes isolated or clustered?

Alternatives

In addition to the no action, two nuclear generation alternatives (completion of a B&W reactor or a new AP1000 reactor) were considered for BNL. Both technologies are predicted (pg. 15) to save the public user money in terms of cents perkilowatt (cents/kWh) by 2020 (B&W) or 2023 (AP1000). In addition, alternatives requiring or not requiring new generation, site selection alternatives, and transmission alternatives were considered in the DSEIS. We offer the following.

Nuclear Generation Alternatives: Three nuclear generation alternatives were presented.

+ <u>Alternative A (No Action</u>) - Under the No Action Alternative, TVA would continue to maintain construction permits for BLN 1&2 in deferred status and not initiate any further site construction at this time.

+ Alternative B (Completion and Operation of a Single B&W Pressurized Light Water Reactor) - Alternative B would maximize re-use of the existing, partially-constructed structures at BLN to complete the B&W reactor technology. These primarily include the re-use of one of the two started reactors (BLN 1 or 2), with BLN 1 construction intentionally being about two years further along than BLN 2. Some 400 acres of the 1,600-acre site were disturbed during the initial construction of BLN 1&2.

+ Alternative C (Construction and Operation of a Westinghouse AP1000 Advanced <u>Pressurized Light Water Reactor</u>) - Alternative C would start construction of a new nuclear generation facility using an AP1000 reactor technology. An additional 185 acres of the BLN site would need to be cleared. However, several existing structures at the site could still be re-used. These primarily include the re-use of one of the two existing cooling towers; however, they also include reactor supporting structures such as the intake channel and pumping station, blowdown discharge structure, transmission lines and switchyards, barge dock, railroad spur, and meteorological tower.

o Alternatives Requiring or Not Requiring New Generation: Other alternatives requiring or not requiring new generation capacity were also considered (pp. 46-47). Those alternatives requiring new generating capacity included power generation through coal-fired and natural gas plants as well as renewables. We agree that nuclear power

EPA54 cont.

EPA55

EPA56

13

would generate less emissions than coal and natural gas and that that renewables are still intermittent, and that such "green" power may need to be purchased by TVA. Moreover, those alternatives not requiring new generation included repowering of existing plants, increasing efficiency and demand side management (energy conservation), and reducing peak demand. TVA concluded that these options were already ongoing and that the addition of nuclear facility at BLN would continue to diversify TVA's energy resources and reduce energy source uncertainties, consistent with TVA's Energy Vision 2020 EIS.

o Site Selection Alternatives: Regarding the site selection process, several brownfield and greenfield sites were screened. These included co-location with existing TVA nuclear plant sites (BFN, WBN and SQN) which TVA generally found unacceptable because of reservoir thermal issues, the unavailability of some sites due to space or planned changes, and the availability of assets at BLN. In addition to BLN, several brownfield sites in Tennessee were also considered. These were the former Hartsville Nuclear Plant (HVN) site on Old Hickory Reservoir, the former Phipps Bend Nuclear Plant (PBN) site on the Holston River, and the former Yellow Creek Nuclear Plant (YCN) on the Pickwick Reservoir. Although these sites have highway access and prior site characterizations, they have been sold or partially sold and therefore would need to be re-acquired by TVA for power plant development. The considered Murphy Hill (MH) greenfield site on Guntersville Reservoir was a former selected site for a coal gasification plant (1981 TVA FEIS). Although some grading had been done before the project was cancelled, the DSEIS suggested that more impacts can be expected at a greenfield site such as MH than at a brownfield site such as BLN. Although we generally agree, given that the MH site was partially graded, the differences between MH and BLN may not be as significant. However, if BLN 1 or 2 were re-used, there could be a significant benefit to selecting BLN.

o Transmission Alternatives: With the addition of 1,100-1,200 MW of power, the existing transmission line and stations would need to be upgraded if Alternative B (B&W) or C (AP1000) were implemented. Two action options were screened: Option 1 would upgrade existing facilities while Option 2 would construct new facilities. Since the latter would cost twice the price of the former, only Option 1 was carried forward. Option 1 would re-energize the 500 kV transmission lines and switchyard and would be implemented over the no action if TVA decided to implement Alternative B or C.

EPA Re-Use Recommendations

While EPA typically supports the re-use of materials and sites (brownfields over greenfields), the fact that over 20 years have elapsed since construction ceased on BLN 1&2 in the mid-1980s may be of concern in terms of construction design and material upgrades as well as new inspection standards, especially for a nuclear plant facility. That is, if portions of the partially completed structures for BLN 1 or 2 are to be used for the present project, we offer the following areas of review to help insure construction competence for a nuclear generation unit at BLN:

• Building Codes & Inspections – The condition of the existing facilities at BLN 1&2 should be inspected. Existing utilities at the two unfinished facilities could include mechanical, plumbing, electrical, and telecommunications equipment and their respective distribution systems. The condition and capacity of existing boilers, chillers, air handlers, duct work, plumbing fixtures, piping, transformers, generators, power panels, and wiring are a few of the items that should be carefully examined to determine if they have any remaining usable life or if they should be replaced, and what costs might be involved. In this regard, it should be noted that NRC's standards for safety requirements may have changed since construction on BLN 1&2 was suspended.

Similarly, what is the status of Building Code compliance and what code(s) (e.g., International Building Code: IBC) is/are in effect? The existing facilities/structures may require upgrades to render them in full compliance with current building codes. Since building codes are constantly being revised to include more stringent requirements, this could result in significant additional construction costs. The assessment of any Bellefonte structure/facility being considered for re-use should include a complete building code analysis.

o Asbestos – EPA has identified numerous construction materials that may contain asbestos (<u>http://www.epa.gov/region4/air/asbestos</u>). Although the use of asbestos containing materials is currently illegal, such materials were used until about 1980. If asbestos is determined to be present in existing BLN 1&2 facilities, abatement may be required for re-use, which may be costly.

o Structural Condition – Given that a nuclear generating unit is being proposed, the structural condition of the existing facilities is probably the most important issue. Has a complete structural engineering and safety assessment of the major structures been done, especially for the two partially-built, pressurized water reactors? As suggested above, building codes are frequently upgraded to include more stringent requirements for the structural resistance to natural forces (tornados, earthquakes). NRC has apparently upgraded their seismic design for nuclear power plants (2000) since the Bellefonte plant was first started (http://www.riskeng.com/PDF/New_Seismic.pdf). In addition, are there complete construction materials and inspection records of the initial construction available for compliance reviews (compressive strengths, slump tests, reinforcing steel inspections, welding records, etc.)? Were "as-built drawings" prepared after construction? Has there been any measured subsidence or settlement of the structures/facilities?

Other structural-related considerations include infestations, roofing integrity and pavement structures. Regarding infestations, do the structures have a history of water infiltration, either through roof leaks or at window and door openings? Are any structures affected by mold and/or termites? Similarly, the structural integrity of roofs is also important. Although roofing integrity may be sound, it is critical to assess the weather-tight integrity of the finished roofing system and materials, including its age, repair history, and its replacement cost. Any needed roofing replacement or repair costs should be addressed as part of the project's development costs. Finally, regarding EPA57

EPA58

EPA59

EPA60

EPA61

EPA62

EPA63

15

pavements and hard stand areas, an analysis of all flexible, rigid and special pavement types should be performed, with remaining life determinations made.

Weather/Climate Events – As suggested above, tornados, earthquakes and other weather/climate events since the mid-1980s could be important in determining the re-use suitability of BNL 1&2. The BNL site is located in an F-3/F-4/F-5 tornado alley, according to <u>hup://upload.wikimedia.org/wikipedia/commons/3/35/Tornado_Alley.gif</u>.
 Moreover, in April of 2003, this area⁶ experienced an earthquake of a 4.9 Rickter Scale magnitude. Did this event result in any structural damage at the BLN facilities?
 Similarly, did the recent flooding events in the summer of 2009 cause Guntersville Reservoir to flood at Bellefonte and cause structural damages for the existing facilities?
 Also, does the current site design and layout meet requirements for capture and treatment of onsite storwmwater? We note (pg. 37) that structures on the "nuclear island" portion of the BLN site are designed to withstand "…hurricanes floods, tornados and earthquakes without loss of capability to perform safety functions."

o *Impact Analysis* – Were the existing facilities designed and constructed to survive the impacts of large commercial aircraft? Advances in power station designs have occurred since the 9-11 terrorism event. Will the partially-built facilities to contain the pressurized water reactor meet (or can they be modified to meet) the current standards for this? Also see: http://www.nrc.gov/reading-rm/doc-collections/news/2007/07-127.html.

Other Comments

• NEPA Process – Because of the new BLN site development plan, the large number of supporting documents containing important basic information/analyses, and the more than 3.5 decades over which these reference document have been developed, a stand-alone complete SEIS containing all pertinent information and backup analyses appears to be appropriate for this project. The present DSEIS for the current single nuclear reactor configuration does not provide the information and supporting documentation needed for a complete understanding and evaluation by licensing agencies and the general public. In lieu of a complete stand-alone SEIS, the FSEIS should provide the specific document, section, and page where referenced documentation/analyses can be obtained to support the information provided. If appropriate, the specific NRC docket website location should also be provided.

o *Benzene* – On page 97, the molluscicide entry includes this description: "a nitrogen atom with four attachments, some or all of which can be benzene-based, rather than hydrocarbon-based." Since benzene is a hydrocarbon, this statement should be revisited for the FSEIS.

o Terminology – The name of Alternative C is somewhat inconsistent in the DSEIS. Typically, it is listed (e.g., pg. 36) as Construction and Operation of a Westinghouse AP1000 Advanced Pressurized Light Water Reactor. However, the technology is also referred to (pg. 188) as the Westinghouse Advanced Passive pressurized water reactor

EPA71

⁶ The earthquake epicenter was located some 37 miles southwest of Chattanooga, TN (internet).

EPA63 cont.

EPA64 EPA65 EPA66

EPA67

EPA68

EPA69

EPA70

A-66

(AP1000). Although the FSEIS should clarify, we assume that the AP1000 design is an EPA71 cont. "advanced passive safety" system.

o Table 1-3 - The information provide in this table (Environmental Reviews and Documents Pertinent to Bellefonte Nuclear Plant Unit 1: pg. 19) is not limited to Unit 1. Therefore, "Unit 1"should be removed from the title.

o Figures - Assumed Figure 2-1 is not numbered in the DSEIS. Also, we suggest that Figures 3-2, 3-3, and 3-4 label the identified "submerged diffuser" area as the plant discharge site for clarity, as was done in Figure 3-5.

EPA72

EPA73

EPA01. On October 19, 2009, NRC conducted a site inspection for the requested deferred status and a response letter to TVA is pending. NRC's findings regarding this site inspection should be disclosed in the FSEIS.

Response: The December 2, 2009 NRC Inspection Report has been included as the Final Supplemental Environmental Impact Statement (FSEIS) Appendix B. The inspection concluded that TVA has established the necessary programs to support transition to deferred status, consistent with the Commission Policy Statement for Deferred Plants. By letter dated January 14, 2010, the U.S. Nuclear Regulatory Commission (NRC) authorized placement of BLN Units 1 and 2, into 'deferred plant' status (see Appendix A). FSEIS 1.2.2 has been revised to include additional information about the inspection and its findings as well as the NRC's authorization to place Bellefonte Units 1 and 2 into 'deferred plant' status.

EPA02. TVA's interim consideration to convert to a natural gas plant was not documented in the present DSEIS in Section 1.2, but should be noted in the Final SEIS (FSEIS). However, we note that the BLN Conversion EIS was referenced in Section 1.7. BLN 3 and 4 should also be referenced relative to the 2008 Combined License Application Environmental Report (COLA ER).

Response: TVA's 1997 FEIS for the Bellefonte conversion process was briefly described and incorporated by reference in DSEIS 1.7 and documented in Table 1-3. The FSEIS 1.2.2 has been revised to further document the consideration to convert Bellefonte to a natural gas plant in 1997. The 2008 COLA ER is discussed in FSEIS 1.2.3 and is listed in Table 1-3.

EPA03. The FSEIS should summarize the equipment and structures that were sold as part of the TVA redress plan and asset recovery program, and discuss how this might change the Exclusion Area Boundary (EAB) from previous analyses referenced in the DSEIS and whether the previous X/Q and dose calculations are still appropriate or must be recalculated.

Response: FSEIS 2.2.3 summarizes the equipment sold by TVA as part of the investment recovery program. The Unit 1 and 2 atmospheric dispersion (χ /Q) values have been revised based on current meteorological data (see FSEIS 3.16) and the current Exclusion Area Boundary. The dose calculations were revised based on these revised χ /Q values and releases from the Units 1 & 2 Final Safety Analysis Report (FSAR). Equipment and structures that were sold as part of the TVA redress plan and asset recovery program is to be replaced to maintain conformance with the original Unit 1 and 2 design. Replacement of any Unit 1 or 2 plant equipment, which was previously sold as part of the redress plan and asset recovery program, will not impact the EAB, χ /Q calculations, or dose calculations.

EPA04. EPA is concerned that over 20 years have elapsed since construction ceased on BLN 1&2 in the mid-1980s, and that construction designs and materials as well as new inspection standards have significantly changed - especially for development of a nuclear generation unit.

Response: FSEIS 2.2.2, 2.2.3, and 2.7.1 have been updated to include detailed information regarding the condition of existing structures, and facilities, including remaining usable life and compliance with NRC standards and consideration of building codes.

EPA05. Beyond the uncertainty of the structural integrity of the partially-completed BLN 1 &2, it should be noted that the B&W technology is not as efficient and safe as the AP1000 technology (or equivalent). Compared to the B&W design, the DSEIS documents that an AP 1000 reactor uses less radioactive fuel (1,821 fuel assemblies vs. 2,285) over a 40-year life cycle (Table 2-2) and therefore produces less spent fuel for disposal; needs fewer components (Fig. 2-8); has inherent public health safety features in its new "passive" safety design (Sec. 2.3) with less potential radiological effects (Sec. 3.17) and design based accidents (Sec. 3.19); and requires less water intake for cooling with less thermal discharge volumes.

Response: FSEIS 2.2, 2.3, 2.7, Tables 2-2, and 3-3 have been revised to clarify the differences between the two technologies.

EPA06. Although TVA may wish to add additional future units at the BLN site, only TVA's NEPA responsibilities for the proposed single BLN nuclear generation unit are covered in the present SEIS. Accordingly, additional TVA NEPA documentation would be needed for additional units at the BLN site (however, if reasonably foreseeable, the cumulative impacts of such additional units should be included in this FSEIS).

Response: TVA is not proposing to add nuclear units beyond Watts Bar Unit 2 and the proposed single unit at Bellefonte. The Integrated Resource Planning process currently underway will provide a roadmap for meeting future power needs beyond those addressed by the current proposal. While nuclear power is expected to be a component of TVAs future plans, it would be speculative at this time to say that TVA might build additional nuclear units at the Bellefonte site.

Two-unit construction and operation at the Bellefonte site is addressed in the original TVA/NRC environmental reports, the environmental assessment and the construction permit for the B&W plant, and also in the combined license application for the AP1000 plant. Based on these earlier reports, TVA can project that should one or more units be added in the future, additional site disturbance would be minimal outside of the 606 acre project area. Operational impacts would increase, but not double, as there are some shared systems, particularly with the B&W units. Because both units would use closed cycle cooling systems, additional surface water impacts would be small. In general surface water, air quality, radiological, and many other effects would be operated in compliance with permits to minimize environmental effects.

EPA07. If Alternative B is selected for the FSEIS, the suitability for re-using existing structures associated with the B&W reactor should be discussed. While EPA typically supports the re-use of materials and sites (brownfields and grayfields over greenfields), we are concerned that over 20 years have elapsed since construction was suspended on BLN 1&2. While we defer nuclear plant safety to TVA and NRC, EPA has documented our re-use construction concerns in the enclosed *Detailed Comments*.

Response: See response to EPA04.

EPA08. EPA finds that the modern AP1000 technology (or equivalent) is the preferred design for TVA's proposed nuclear generation unit at BLN. EPA prefers this type of AP1000 reactor (Alt. C) over the B&W design (Alt. B) despite the fact that more existing structures at BLN could be used (if found competent) by completing either BLN 1 or BLN 2 with the B&W design.

Response: Comment noted.

EPA09. With or without the present nuclear generation project, EPA strongly believes that green alternatives should continue to be promoted by TVA and that the FSEIS should summarize ways in which TVA is promoting such green alternatives, particularly efficiency/conservation and the addition of renewable capacity to support clean conventional baseload options.

Response: The contribution of energy efficiency and demand response (EEDR) programs and the generation of electricity from renewable resources are more fully addressed in FSEIS 1.4 and 2.4.

Currently TVA is actively pursuing renewable generation capacity through our Green Power Switch and Generation Partners programs and has recently added approximately 1,300 MWs of wind resources to its energy portfolio through several power purchase agreements. TVA currently provides incentives to customers through the Energy Right and Generation Partners programs.

TVA recognizes that EEDR programs play an important part in meeting our energy needs. The demand reduction and energy savings associated with EEDR programs have been included in our updated need for power analysis in FSEIS 1.4.

TVA anticipates using a mix of resources, including EEDR programs, renewable resources, natural gas-fired generation, and nuclear generation to provide the additional future needs. Given the magnitude of the capacity and energy need, and to avoid the risk of relying on only one fuel or technology, no single resource should be used to meet all of the future energy and capacity requirements. TVA has determined that adding a nuclear unit at the BLN site is the most cost effective alternative to meet a portion of these future needs.

EPA10. The FSEIS should discuss how the amount of energy that could be saved or generated by these green alternatives would compare to the identified need and projected 1,100-1,200 MW capacity of the proposed BLN unit.

Response: See response to EPA09.

EPA11. TVA screened several existing, brownfield and greenfield sites in its site selection process. We understand that co-location of the proposed nuclear unit at an existing TVA nuclear power station such as BFN may not be advisable due to cumulative thermal discharge issues at the same site and reservoir. Other potential co-locations at WBN and SQN apparently have onsite space conflicts. Former TVA plant sites (e.g., Hartsville Nuclear Plant site) are also not ideal since all or most of the lands have now been sold to private developers. Finally, development of the Murphy Hill (MH) greenfield site would likely have more environmental impacts than development of the BLN brownfield site, even though MH was already partially graded before a proposed TVA gasification plant at MH was cancelled. Although these site options might be revisited for verification in the FSEIS, we agree that the availability of the BLN brownfield site for development with either Alternative B or C has environmental merit.

Response: Comment noted.

EPA12. Presumably because of new construction standards and other upgrades, the 90% and 58% completion levels for BLN 1&2, respectively, may translate into only a 55% and 35% completion level according to the internet (Wikipedia). The FSEIS should discuss this.

Response: FSEIS 2.2.2 and 2.2.3 have been revised to address the completion status of Unit 1 and Unit 2 and the activities required to complete a unit.

EPA13. In the FSEIS, TVA should confirm or modify its DSEIS preferred alternatives and select a preferred reactor technology.

Response: FSEIS 2.9 identifies TVA's preferred alternative as the completion and operation of Bellefonte Unit 1, a B&W unit.

EPA14. As indicated previously, EPA prefers the AP1000 reactor design over the B&W technology. One of the reasons for this preference is that the AP1000 is inherently safer then the B&W design due to its advanced passive safety design.

Response: FSEIS 2.7.2 has been revised to clarify that both designs would meet all NRC safety requirements. The AP1000 design is different, but not safer.

EPA15. It appears from the DSEIS that avoidance and minimization of adverse impacts to aquatic resources under the federal Clean Water Act (CWA) Section 404 are being taken into consideration appropriately. That the project would utilize existing structures and transmission corridors, to varying degrees based on alternatives, is a good approach to mitigation as a baseline. Whereas Alternative B (B&W) would not result in the filling of wetlands and Alternative C (AP1000) would impact 12.2 acres, operational safety and modernization considerations associated with the AP1000 design provide adequate justification for pursuing Alternative C if it is otherwise appropriate. Once an alternative is selected and TVA is ready to proceed, a CWA Section 404 permit application should be submitted that characterizes any wetlands and/or stream impacts, along with a mitigation plan to address them.

Response: If the selected alternative involves any activity that results in the discharge of dredge or fill material into the waters of the U.S, TVA would apply for a Clean Water Act Section 404 permit from the U.S. Army Corps of Engineers. The

permit would address wetland and stream impacts by requiring mitigation measures to compensate for those impacts.

EPA16. Also, since upgrading existing transmission line and facilities (Option 1) is preferred by TVA over new construction, we assume that there would not be any additional wetland impacts associated with project transmission upgrades.

Response: Because the transmission line corridors proposed for upgrade are already existing and no new or wider rights-of-way are proposed, no additional impacts to wetlands are anticipated under any generation action alternative. The only impacts to wetlands would be those associated with reenergizing, refurbishing and upgrading the lines, and with regular right-of-way maintenance activities. Any wetland areas located within existing corridors may experience vegetation clearing and/or vehicular traffic. All best management practices (e.g. dry season work, pressure reducing tires, mats, aquatic approved herbicides) would be implemented to minimize wetland impacts in existing rights-of-way.

EPA17. Although both the B&W and AP1000 technologies would operate in a closedcircuit mode and utilize one of the existing natural draft cooling towers to cool reactor cooling waters, thermal effluent would nevertheless be generated and discharged back into the Guntersville Reservoir receiving waters. Discharge of this heated blowdown is regulated by the State of Alabama National Pollutant Discharge Elimination System (NPDES) permit. ThIs permit also prescribes thermal discharge limits, which are not to exceed a 92°F monthly average, 95°F daily maximum, and 5°F increase over ambient conditions. Hydrothermal modeling (pg. 94) appears to predict that the proposed nuclear unit would not exceed these limits for both Alternatives B and C outside the mixing zone, with the exception of infrequent and unusual hydrologic or meteorological conditions. The FSEIS should clarify and summarize if compliance with all three thermal limits is indeed predicted for both designs and what measures will be taken for compliance during unusual river flows and weather conditions (e.g., generation at less than nameplate capacity or temporary unit shutdown).

Response: If TVA selects and completes Alternative B (B&W reactor) or Alternative C (AP 1000 reactor), procedures for the operation and maintenance of the plant will include processes to monitor all National Pollutant Discharge Elimination System (NPDES) thermal limits and implement changes in the operation of the plant to maintain compliance with these limits. If required, curtailing power generation at the plant (i.e., derating) would be used to prevent a violation of the NPDES permit limits, as emphasized on page 92 and page 94 of DSEIS 3.1.3.1. Derating has been successfully implemented to maintain compliance at several TVA thermal plants in Alabama, including Widows Creek Fossil Plant, Colbert Fossil Plant, and Browns Ferry Nuclear Plant. TVA will implement processes to maintain compliance with the NPDES limits at Bellefonte for all possible operating conditions of the plant, including unusual river flows and weather conditions (FSEIS 3.1.3).

EPA18. As suggested above, it is noteworthy that the AP1000 technology would require significantly less surface water than the B&W technology – 72% of the B&W withdrawal volume and 36% of the B&W discharge volume (pg. 95). The expected withdrawal rate for the B&W reactor is 34,000 gpm (75 cfs) and discharge rate is 22,650 gpm (50 cfs), while the withdrawal rate for the AP1000 reactor is 23,953 gpm (53 cfs) and discharge rate is 7,914 gpm (18 cfs). Overall, this would result in a lower level of thermal pollution for Guntersville Reservoir, even if both technologies are predicted to comply with NPDES thermal limitations. Such relative differences in efficiency should be considered in TVA's final selection of a preferred reactor technology, particularly if additional units would be added at BLN in the future causing cumulative impacts.

Response: The use of closed-loop cooling system under both technologies would result in a water withdrawal rate that is a small percent (0.2 percent or less) of the annual average river flow of Guntersville Reservoir. For example, the minimum daily average flow out of Chickamauga Dam (located upstream) is 1,350,000 gallons per minute (gpm). The daily average flow through Guntersville Reservoir will be about the same. TVA has revised FSEIS 2.7.2 and 3.1.2, replaced DSEIS Tables 3-3 and 3-4 with FSEIS Table 3-3, and added Table 2-5 to clarify the comparison of both technologies. A comparison of thermal efficiencies for both technologies has been added to FSEIS 2.7.2 and Table 2-2.

EPA19. In regard to chemical additives such as biocides and inhibitors added to the cooling waters to control fouling, EPA recommends that the minimum amount of chemical additives be used and that concentrations be monitored. We will defer to the State of Alabama's NPDES permit regarding compliance with water quality standards for discharge effluents, and retain our federal permit oversight.

Response: As provided in the BLN site NPDES permit (AL0024635), should TVA select Alternative B or C, TVA would implement best industry practices to minimize the amount of chemical additives used. Concentrations of additives would be routinely monitored.

EPA20. Although a minor discrepancy, these "gpm" data suggest a difference of 71% and 35 % as proposed to the 72% and 36% stated in the DSEIS.

Response: See response to EPA18.

EPA21. U.S. Census data for 2000 for the block group incorporating BLN showed a minority level (percentage) higher than the county average but lower than the state and national averages. Estimates for 2008 showed increases in minorities but with probably similar trends.

Response: FSEIS 3.13.3.1 has been revised to include further discussion about impacts to minority and low-income populations based on additional information provided to NRC in 2008. The 'more recent data' mentioned in FSEIS 3.13.3.2 is discussed in FSEIS 3.13.3.1. This has been clarified in the FSEIS. These data may be cited as http://www.census.gov/hhes/www/poverty/poverty.html.

Final Supplemental Environmental Impact Statement

EPA22. U.S. Census poverty levels for 2000 and 2007 estimates showed a poverty level percent for the BLN area that is below county, state and national levels. EJ evaluations were made in the BLN Conversion EIS (1997) and were referenced (pg. 146). The more recent COLA ER concluded "...that any impacts would be minor and not disproportionate." Moreover, ",more recent data" with the same conclusions were also referenced, but not cited. The FSEIS should briefly substantiate these conclusions, rather than only incorporating by reference, and provide citations/timeframes.

Response: See response to EPA21.

EPA23. Also, any potential concentrations ("pockets") of minority and/or low-income populations near the BLN site should be identified in the FSEIS.

Response: FSEIS 3.13.3.1 has been updated to include concentrations of minority and/or low-income populations near the BLN site.

EPA24. It should be noted that a potential EJ impact at BLN would make this site less environmentally preferable to EPA despite being an available brownfield site.

Response: Comment noted.

EPA25. Regardless of the final EJ conclusion, TVA should provide public outreach on the project to all demographics living near the site during the SEIS process as well as periodic updates thereafter.

Response: FSEIS 1.6.2 describes the public outreach for the DSEIS including notice of availability, newspaper ads, TVA's webpage, and a public meeting. Should TVA select one of the action alternatives, ongoing communications would be established with those living in areas affected by plant construction to ensure the public is informed about the construction process and that TVA is aware of public guestions and concerns. Outreach will be designed to reach all demographics.

EPA26. Although TVA has identified a need for additional power by 2018-2020, supplying such power (1,100-1,200 MW) will likely accommodate or induce additional growth in the Tennessee Valley and result in developmental impacts. The FSEIS should acknowledge these expected secondary impacts as a project consequence.

Response: While not addressed in the Socioeconomics section, an overview of the growth in power needs that TVA anticipates and is planning for is discussed in FSEIS 1.4, in particular in 1.4.1. TVA is responding to the forecasted need for power and does not agree that it is "inducing" growth by doing do. TVA does agree that the reliability of the energy TVA's system provides and is known for can be a consideration when companies assess where to locate new facilities. Trying to assess the impacts from that would involve substantial speculation. Any cumulative effects from future proposals to use the BLN site can and would be assessed when such proposals occur.

Final Supplemental Environmental Impact Statement

A-74

EPA27. Regarding cumulative effects, NEPA documents should discuss the past, present, and reasonably forseeable future projects (federal and non-federal) within the project area. This listing should focus on projects that impact the same resources as the proposal, with impacts being qualified and quantified to the extent feasible. In the case of the present BLN proposal, nearby projects with similar impacts (wetland, water quality and radiological impacts) should be emphasized.

Response: The SEIS considers cumulative effects on a resource by resource basis. The analysis for each resource takes into account current background conditions, which reflect the effects of past and present projects. Where applicable, the resource-specific analysis considers the impact of reasonably foreseeable future projects. FSEIS 3.13.11 references information from Section 4.7 of the COLA ER (TVA 2008), which indentifies the Redstone Arsenal realignment project as the only major federal project in the 50-mile area that could contribute to cumulative socioeconomic effects. Redstone Arsenal is nearly 50 miles from Bellefonte and the construction period for that project is not expected to overlap with the proposed Bellefonte project. Both the Bellefonte and the Redstone projects would provide longterm economic benefit to the area. Updated information about nonfederal projects planned for the area has been added to FSEIS 3.13.11. Most of the projects identified would be completed before projected construction workforce buildup at the Bellefonte site and none were thought to contribute to cumulative effects during operation. Cumulative effects of TVA's Widows Creek fossil plant on water and air quality are discussed in FSEIS 3.1.3 and 3.16.2.

EPA28. We note that Section 3.13.10 discusses cumulative impacts, albeit only for socioeconomics, while other environmental consequences do not have a cumulative impacts section. This document format is somewhat cumbersome and could be streamlined in the FSEIS by designating only one cumulative impacts section that covers all relevant parameters.

Response: Comment noted. TVA has chosen to address cumulative effects on a resource by resource basis. A statement regarding how cumulative effects are addressed in the FSEIS has added to the introduction to FSEIS 3.0.

EPA29. ...the FSEIS should provide additional background information for air quality impacts and radiological effects;

Response: FSEIS 3.16.2 and 3.17 have been revised to include additional information about air quality impacts and radiological effects.

EPA30. ...discuss mitigation for BLN impacts to waters of the US (Alt C);

Response: FSEIS 3.4.2 discusses the potential purchase of credits from a wetland mitigation bank within the same watershed to compensate for wetland impacts resulting from selecting Alternative C. If Alternative C is selected, implementation of that alternative will generate more specific details regarding proposed mitigation methods and compensation ratios required by the U.S. Army Corps of Engineers under the Clean Water Act Section 404 permit for all wetland impacts associated with this alternative.

EPA31. ...insure compliance with State NPDES thermal limits for heated effluent discharges by either reactor technology (Alts B or C).

Response: TVA will comply with the thermal limit requirements of the applicable NPDES permit. As indicated in FSEIS 3.1.3.2, modeling results indicate that NPDES thermal limits (i.e., discharge temperatures not to exceed limits of 92°F monthly average, 95°F daily maximum, or 5°F increase over ambient conditions) will be met under most river flow and meteorological conditions. On rare and infrequent occasions, measures up to, and including, plant derates would be taken to prevent a violation of the NPDES permit. Monitoring would be conducted to confirm compliance with the NPDES thermal limits.

EPA32. ...verify minor or no EJ impacts, and revise the cumulative impacts section.

Response: See response to EPA21.

EPA33. The discussion of the updated 2006-2008 meteorological data period does not provide a complete summary of the meteorological conditions. This discussion should be supplemented with tables and figures that provide applicable wind roses, frequency distributions, comparisons, etc. that would provide the reader with a better understanding of the current meteorological conditions. The tables and figures will also allow comparisons with previous observations and long-term records, and a basis for the evaluation of subsequent dispersion and transport analyses.

Response: The 2006-2008 meteorological data has been added to the FSEIS. The following is included in Appendix I:

- Composite wind rose (all stability classes).
- Occurrence of stability classes (percent of total hours).
- Wind direction distribution (percent of total hours).
- Wind speed distribution (percent of total hours).
- Joint frequency distribution tables for each stability class (A-G) and all stability classes combined.

EPA34. The stability class frequency distribution is used to show agreement between different meteorological data records. EPA believes that this is not sufficient to show agreement. The data record comparisons should include joint frequency distributions of stability, wind direction, and wind speed.

Response: Appendix J, which compares the different data periods (1979-1982, 2006-2007 COLA, and 2006-2008 Full), has been added to the FSEIS. Tables list the percent of occurrence for wind direction, wind speed and, stability class during each data period. Graphs are provided to display the data for direct comparison. The differences between the three data periods are within the normal year-to-year variation for Bellefonte.

EPA35. Section 3.16.2.1 Dispersion (pg. 162). This section is concerned with both the dispersion and transport of effluent releases. Therefore, we suggest changing the name to "Transport and Dispersion".

Response: Section 3.16 has been reorganized in the FSEIS to better match the structure of other sections in Chapter 3. The discussion of atmospheric dispersion can now be found in subsection 3.16.1 Climatology and Meteorology, Environmental Consequences. This subsection includes both routine and accidental releases.

EPA36. The atmospheric transport and dispersion modeling procedures, computer model, and input parameters used to develop the provided dispersion estimates should be provided. Explanations may be needed for some of the input parameters (e.g., modeled receptors). An appendix could be used for this information.

Response: The requested information has been added to FSEIS 3.16.1.2, Routine Releases.

EPA37. A figure providing the plant layout, release vents, building heights, and receptor locations, for both the B&W and AP1000 reactor units would be of value in understanding the information provided. We recommend inclusion of such a figure in the FSEIS.

Response: The site layout for the B&W and AP1000 reactor units are shown in FSEIS Figures 2-1 and 2-12 respectively. Figures providing the release vents, building heights, and receptor locations, for both the B&W and AP1000 reactor units, have been added to FSEIS 3.16.1.2.

EPA38. The definition and importance of calculated X/Q, X/Q no decay undepleted, X/Q \Rightarrow 2.26 day decay undepleted, X/Q 8.0 day decay depleted, and D/Q values provided in Tables 3-14, 15, and 16 should be explained.

Response: This information has been added to FSEIS 3.16.1.2, Environmental Consequences, Routine Releases.

EPA39. The receptors of interest in Tables 3-14 and 3-15 (e.g., nearest cow, garden, goat, etc.) for the B&W reactor appear to be different depending on the location of the release. Some of these locations appear to be inside the EAB. An explanation should be provided.

Response: The distances and directions from the release point to the receptor location will be different for different release points. A discussion of the selection of receptor locations and Figure 3-21 showing the receptor locations for the B&W reactor has been added to FSEIS 3.16.1.2.

EPA40. Table 3-16 has receptor types at the same location which appears to be within the EAB. This table also has a new column "Maximum Receptor Type Value." The FSEIS should explain these items.

Response: Additional information has been provided in FSEIS 3.16.1.2, to clarify the receptor locations within the EAB.

EPA41. The reason routine releases (i.e., Tables 3-14, 15 & 16) used the maximum modeled dispersion values while the accidental releases provided in Tables 3-17 and 18 use the 50% probability values should be explained. Because the accident releases are concerned with mostly short-term periods (i.e., less than 24 hours), the maximum values would appear to be appropriate.

Response: As stated in FSEIS 3.16.1.2, 50 percent probability short-term accident χ/Q values were determined to provide more realistic doses in accordance with NRC Regulatory Guide 1.145. This means that the resulting χ/Q values could be exceeded half of the time. In contrast, the design basis analyses in the FSAR are required to use more conservative 95th percentile χ/Q values meaning that the values would be exceeded only 5 percent of the time. The normal effluent release χ/Qs given in FSEIS Tables 3-14, 3-15, and 3-16 are based on annual averages. Therefore, they do not represent any probability percentile. However, for normal effluent releases, the highest χ/Qs were determined from all of the offsite locations to provide conservative maximum individual doses.

EPA42. The "release boundary" used to determine the distance of interest for the accidental release χ/Q values should be explained. It appears that the release location used for the previous routine releases should be used.

Response: Additional information has been added to FSEIS 3.16.1.2 to explain the basis for the release boundary surrounding the potential release locations.

EPA43. Section 3.16.3 Affected Environment – Air Quality (pg. 164). This section does not address the anticipated emissions from the auxiliary equipment except by referencing the 1974 TVA Final Environmental Statement (FES). The FSEIS should include/provide the appropriate emission values and impact assessments for these project emissions.

Response: According to TVA's 1974 Final Environmental Statement (FES), the oilfired auxiliary steam generators would, at peak load, release sulfur oxides to the atmosphere from a 125-ft stack at a rate of almost 143 pounds per hour (lb/hr) or 18 grams per second (gm/sec). The maximum SO₂ concentration was calculated to be 0.12ppm. This peak would occur quite close to the plant stack and decrease quite rapidly with distance. At the time of the 1974 FES, the State of Alabama SO₂ standard was 0.15ppm for a 24-hour average. The current EPA National Ambient Air Quality Standards (NAAQS) for SO₂ is 0.14ppm for a 24-hour average. The 1974 FES concluded that the SO₂ releases from the oil-fired auxiliary steam generators were acceptable. Even with the slightly lower NAAQS, these releases are acceptable. The auxiliary boilers have since been sold and various options for their replacement are being considered, including an electric boiler which would have no emissions. The AP1000 utilizes an electric boiler in place of an oil fired boiler; therefore no emissions will occur from the auxiliary boiler with Alternative C. Operational activities, emissions and impacts related to Alternative C would be roughly equivalent to or less than those under Alternative B. FSEIS 3.16.3 has been revised to include this information.

Final Supplemental Environmental Impact Statement

EPA44. Section 3.16.3 Affected Environment – Air Quality (pg. 164). This section indicates that the new PM 2.5 24-hour National Ambient Air Quality Standards (NAAQS) was not addressed in previous documents. This new standard should be addressed in evaluating the project PM 2.5 impact in the FSEIS.

Response: TVA addressed the $PM_{2.5}$ NAAQS in the DSEIS on page 164. $PM_{2.5}$ non-attainment designations were also addressed in the COLA ER. Both the standard and the non-attainment designations were referenced and updated for this SEIS. This information can be found in FSEIS 3.16.2.1.

EPA45. Class I Areas beyond 100 km should not be eliminated from impact consideration. The need to perform Class I area impact assessments depends on the magnitude of the emissions and the distance to the receptors of concern.

Response: Typically, Class 1 areas are identified within a 100-km radius of the site; however, TVA identified and considered the two nearest Class 1 areas even though they fell outside this radius. TVA's analysis determined that emissions related to the action alternatives B or C would be controlled to meet current applicable regulatory requirements such that resulting impacts would be minor and would not adversely affect these Class 1 areas. Therefore, areas located further away than these Class 1 areas would also experience no adverse impact.

EPA46. Section 3.17 Radiological Effects of Normal Operations (pg. 167) – This section indicates recent dose calculations confirm the earlier 1974 assessment for the B&W reactors so the 1974 impacts are applicable for the proposed project. The DSEIS contains no demonstration for this conclusion. The recent dose calculations should be provided along with comparison to the referenced 1974 assessment to demonstrate this conclusion. An appendix could be used to provide this needed documentation.

Response: The conclusions of the 1974 assessment demonstrated that the doses are within the more recently established 10 CFR Part 50 Appendix I limits (1977a), and the new analyses calculated independently also confirms that the doses are within these limits. The 1974 assessment is discussed for informational and historical purposes only. All conclusions presented in this section are based on their respective analyses presented in FSEIS 3.17.

EPA47. Section 3.17.3.2 Radiation Doses Due to Gaseous Effluents (pg. 173) – the stated purpose of this section is to revise the inputs and methodologies used in the 1974 FES to use current values representing recent meteorological, population and agricultural data. It also provides gaseous effluent doses for the AP1000 unit. This section should provide the modeling procedures, computer model, input parameters etc. used to develop the provided doses. An appendix could be used for this information.

Response: The requested information has been added to FSEIS 3.17.2.

EPA48. Section 3.19.1 Design-Basis Accidents (pg. 197) - The purpose of this section is to update the accident dose consequences given in the previous BLN Units 1 and 2 Final Safety Analysis Report (FSAR) (TVA 1991) using atmospheric dispersion values based on current meteorological data and to present corresponding results for the AP 1000 unit. The second paragraph on page 199 indicates this was not done directly through re-modeling but by using previously reported doses scaled by 50 percentile X/Q values using the more current meteorological data period. Confirmation is needed that all other parameters used in the dose assessments remain unchanged for the two reactors (e.g., EAD and LPZ distance for each reactor, the Q values, etc.).

Response: The following statement has been added to FSEIS 3.19.1.1, evaluation methodology: 'All other input parameters and assumptions used for the accident analyses remain unchanged from the BLN Units 1&2 FSAR and BLN COLA FSAR.'

EPA49. Undetected levels of tritium in the liquid pathway in the vicinity of some of the currently operating reactors has been an ongoing concern. The levels of tritium released via the liquid pathway annually for either the B&W or AP1000 reactors listed in Tables 3-23 and 3-24, respectively, should be monitored closely and actions levels put in place as these numbers are approached. As an example, for the AP1000, if 50% of the estimated annual release of 1010 C/yr is reached, more frequent environmental monitoring and/or sampling should be conducted. Additionally, if necessary, TVA may need to re-evalutate the operational parameters of the reactor and its associated liquid waste treatment systems.

Response: The radiological environmental monitoring program (REMP) conducted for the BLN site will be designed based on the regulatory guidance from NRC Regulatory Guide 4.1 and NUREG 1301/1302. The sampling will include the collection of water samples from the Tennessee River downstream from the site at a minimum of two locations using automatic composite samplers. These samplers will be designed to collect a sample at least once every two hours. The resulting composite sample will be analyzed monthly. The process that is currently applied in the REMP monitoring conducted for TVA's existing nuclear sites is to collect and analyze samples for the composite samplers more frequently if elevated activity levels are identified or suspected in samples from any of the REMP monitoring locations. This process would be applied to the BLN REMP.

EPA50. Guidelines for the need to increase the frequency of monitoring for tritium based on predetermined action levels should be addressed in the TVA Radiological Environmental Monitoring Program (REMP), if they are not already included.

Response: See response to EPA49.

EPA51. An ongoing, long-term issue is the projected storage of spent fuel onsite until late in the 21st century, addressed in Section 3.18.2. Although the NRC has determined that this can be done safely for an extended period of time with little risk to the public, it is desirable but not certain that a high-level waste repository will be licensed prior to the need for an on-site spent fuel storage facility in 2036.

Response: The U.S. Department of Energy (DOE) is responsible for the disposal of all high-level radioactive waste generated from TVA's nuclear reactors, as well as the transportation of radioactive materials to the disposal facility. TVA plans to provide dry cask storage of radioactive materials in an on-site independent spent

Final Supplemental Environmental Impact Statement

A-80

fuel storage installation (ISFSI) at BLN, in addition to the storage capacity of the spent fuel pool for either a B&W reactor or an AP1000 reactor, until a licensed repository or interim offsite storage option becomes available (10 CFR 51.23). A discussion of spent fuel storage is contained in FSEIS 3.18.2.

EPA52. The basis and documentation for the dose calculations should be provided. An appendix could be used to provide this information.

Response: See response to EPA47.

EPA53. Page 142 indicates that operational noise generated by the cooling tower is ecpected to be 48 dBA at the nearest residence (similar to ambient levels) and 54.6 dBA if the tower was operated 24 hours a day. The FSEIS should define the frequency of operation associated with the 48 dBA level and the basis for such an operational timeframe.

Response: The cooling towers will operate 24 hours a day, 7 days a week. The only time that they will not operate is during refueling outages.

EPA54. The noise metric used in the DSEIS is unclear. That is, are the provided data in dBA instantaneous or averaged, such as the day-night level (BNL) descriptor? We assume the readings are in DNL but should be clarified in the FSEIS (e.g., "48 dBA" could be designated as "48 DNL", "48 dBA DNL", Ldn = 48 dBA, or an introductory sentence indicating that all noise data are expressed in DNL).

Response: The metric used is the day-night average noise level, which is abbreviated as either Ldn or DNL.

EPA55. Blasting may be associated with construction of the AP1000 reactor. The FSEIS should provide additional information on the expected noise levels during blasting at the nearest residence and the frequency of such events.

Response: Peak instantaneous A-weighted noise levels from blasting are predicted to be 75 dBA at the source and approximately 40 dBA at the nearest residence. Blasting is expected to occur intermittently over the course of one year, though there would likely be several weeks when blasting would occur daily. When blasting does occur, there would likely be two or three detonations per day, each lasting less than one second. FSEIS 3.12.2 has been updated to include this information.

EPA56. Approximately how many residences are located in the proximity of the "nearest residence"? Are homes isolated or clustered?

Response: There are approximately 50 cabins, second homes and primary residences located along the north shore of Town Creek embayment in the Creeks Edge Development. The homes most likely to be impacted by noise are clustered in the southwestern portion of the development (see Figure 3-15). This information has been added to FSEIS 3.12.2.

EPA57. The condition of the existing facilities at BLN 1&2 should be inspected. Existing utilities at the two unfinished facilities could include mechanical, plumbing, electrical, and telecommunications equipment and their respective distribution systems. The condition and capacity of existing boilers, chillers, air handlers, duct work, plumbing fixtures, piping, transformers, generators, power panels, and wiring are a few of the items that should be carefilly examined to determine if they have any remaining usable life or if they should be replaced, and what costs might be involved. In this regard, it should be noted that NRC's standards for safety requirements may have changed since construction on BLN 1 &2 was suspended.

Response: See response to EPA04.

EPA58. Similarly, what is the status of Building Code compliance and what code(s) (e.g., International Building Code: IBC) is/are in effect? The existing facilities/structures may require upgrades to render them in full compliance with current building codes. Since building codes are constantly being revised to include more stringent requirements, this could result in significant additional construction costs. The assessment of any Bellefonte structure/facility being considered for re-use should include a complete building code analysis.

Response: See response to EPA04. As a federal agency, TVA is not subject to building codes but it does consider them.

EPA59. EPA has identified numerous construction materials that may contain asbestos (http://www.epa.gov/region4/air/asbestos). Although the use of asbestos containing materials is currently illegal, such materials were used until about 1980. If asbestos is determined to be present in existing BLN 1&2 facilities, abatement may be required for reuse, which may be costly.

Response: DSEIS 3.14.1 stated that asbestos materials have been used in the construction of BLN Units 1&2 facilities. Several roll-offs of asbestos waste generated from the repair and upkeep of the plant buildings have been disposed of in the past three years. These materials were removed by appropriately certified personnel, and disposed of in an ADEM-approved landfill. Should TVA select one of the action alternatives, it is expected that this process will continue, as needed, during plant construction.

EPA60. Given that a nuclear generating unit is being proposed, the structural condition of the existing facilities is probably the most important issue. Has a complete structural engineering and safety assessment of the major structures been done, especially for the two partially-built, pressurized water reactors? As suggested above, building codes are frequently upgraded to include more stringent requirements for the structural resistance to natural forces (tornados, earthquakes). NRC has apparently upgraded their seismic design for nuclear power plants (2000) since the Bellefonte plant was first started (<<u>http://www.riskeng.com/PDF/New_Seismic.pdf</u>>).

Response: See response to EPA04.

EPA61. In addition, are there complete construction materials and inspection records of the initial construction available for compliance reviews (compressive strengths, slump tests, reinforcing steel inspections, welding records, etc.)? Were "as-built drawings" prepared after construction?

Response: FSEIS 2.2.3 has been revised to include information on the status of quality assurance records and as-constructed drawings.

EPA62. Has there been any measured subsidence or settlement of the structures/facilities?

Response: There has been no observed subsidence or settlement of the structures/facilities. FSEIS 2.2.3 has been updated to address the issue of subsidence or settlement of structures/facilities.

EPA63. Other structural-related considerations include infestations, roofing integrity and pavement structures. Regarding infestations, do the structures have a history of water infiltration, either through roof leaks or at window and door openings? Are any structures affected by mold and/or termites? Similarly, the structural integrity of roofs is also important. Although roofing integrity may be sound, it is critical to assess the weather-tight integrity of the finished roofing system and materials, includingeits age, repair history, and its replacement cost. Any needed roofing replacement or repair costs should be addressed as part of the project's development costs. Finally, regarding pavements and hard stand areas, an analysis of all flexible, rigid and special pavement types should be performed, with remaining life determinations made.

Response: See response to EPA04.

EPA64. As suggested above, tornados, earthquakes and other weather/climate events since the mid-1980s could be important in determining the re-use suitability of BLN 1&2. The BLN site is located in an F-3/F-4/F-5 tornado alley, according to http://upload.wikimedia.org/wikipedia/commons/3/35/Tornado_Alley.gif.

Response: FSEIS 3.16.1.1 has been updated to include weather events since 1980. The tornadoes listed on the Huntsville National Weather Service web site for 1980-2008 were identified and are listed in Appendix K. During 1980-2008, 17 tornadoes occurred in Jackson County, including 2 storms with a strength of F4(Fujita scale)/EF-4 (Enhanced Fujita scale). Of these tornadoes, 7 (including 1 EF-4 tornado) had tracks (all or part) within 10 miles of the BLN site. The F/EF Class for each tornado is listed and tornadoes with tracks within 10 miles of Bellefonte are identified. Numerous other significant weather events were identified for Jackson County during 1980-2008 on the National Climatic Data Center (NCDC) Storm Events web site. The quantity of each of these events is listed. No impacts to existing plant structures resulted from these events.

EPA65. Moreover, in April of 2003, this area experienced an earthquake of a 4.9 Rickter Scale magnitude. Did this event result in any structural damage at the BLN facilities?

Response: No, the April 29, 2003 earthquake that occurred near Fort Payne, Alabama did not cause any damage, structural or otherwise, to BLN facilities. According to the U.S. Geological Survey's community internet intensity map, the shaking intensity at BLN was in the IV (light) to V (moderate) range. At these

Final Supplemental Environmental Impact Statement

intensity levels the vibration, similar to the passing of heavy trucks, effects include the rattling of windows, dishes, and doors; small unstable objects displaced or upset; doors swing, close, open are typically noticed; and could be felt both indoors and outside enough to waken sleepers. No structural damage would be expected at these intensity levels.

EPA66. Similarly, did the recent flooding events in the summer of 2009 cause Guntersville Reservoir to flood at Bellefonte and cause structural damages for the existing facilities?

Response: Based on observed data at Guntersville Dam and the South Pittsburg gage at Tennessee River mile 418.1, the highest reservoir elevation between May and September 2009 occurred in early May and was less than a two-year flood at both locations. Therefore, there was no flood damage at the BLN site.

EPA67. Also, does the current site design and layout requirements for capture and treatment of onsite storm water? We note (pg. 37) that structures on the "nuclear island" portion of the BLN site are designed to withstand ". . .hurricanes floods, tornados and earthquakes without loss of capability to perform safety functions."

Response: The capture and treatment of stormwater for the current site design and layout is managed through NPDES permit, AL0024635. Any future construction will meet applicable NPDES requirements. The current permit is active from December 1, 2009 through November 30, 2014.

EPA68. Were the existing facilities designed and constructed to survive the impacts of large commercial aircraft? Advances in power station designs have occurred since the 9-11 terrorism event. Will the partially-built facilities to contain the pressurized water reactor meet (or can they be modified to meet) the current standards for this? Also see: http://www.nrc.gov/reading-rm/doc-collections/news/2007/07-127.html.

Response: The Category 1 structures that contain the pressurized water reactor are complete, with minor modifications necessary to meet new regulatory requirements. Security requirements for nuclear power plants have been significantly upgraded since September 11, 2001, including the development of contingency plans to address beyond design basis events. The B&W plant design will meet applicable licensing requirements and regulations including those regarding aircraft impact.

EPA69. Because of the new BLN site development plan, the large number of supporting documents containing important basic information/analyses, and the more than 3.5 decades over which these reference document have been developed, a stand-alone complete SEIS containing all pertinent information and backup analyses appears to by appropriate for this project. The present DSEIS for the current single nuclear reactor configuration does not provide the information and supporting documentation needed for a complete understanding and evaluation by licensing agencies and the general public. In lieu of a complete stand-alone SEIS, the FSEIS should provide the specific document, section, and page where referenced documentation/analyses can be obtained to support the information provided. If appropriate, the specific NRC docket website location should also be provided.

Response: The FSEIS strives to include specific citations for all reference documents. Many of the key documents are posted on TVA's web-site for easy

Final Supplemental Environmental Impact Statement

A-84

access by readers. In response to EPA's comment, we've reviewed the DSEIS for complete and accurate citations. Where they were missing, complete citations have been added to the FSEIS.

EPA70. On page 97, the molluscicide entry includes this description: "a nitrogen atom with four attachments, some or all of which can be benzene-based, rather than hydrocarbon-based." Since benzene is a hydrocarbon, this statement should be revisited for the FSEIS.

Response: The molluscicide entry has been corrected in FSEIS 3.1.4.1.

EPA71. The name of Alternative C is somewhat inconsistent in the DSEIS. Typically, it is listed (e.g., pg. 36) as "Construction and Operation of a Westinghouse AP1000 Advanced Pressurized Light Water Reactor." However, the technology is also referred to (pg. 188) as the "Westinghouse Advanced Passive Pressurized Water Reactor (AP1000)." Although the FEIS should clarify, we assume that the AP1000 design is an "advanced passive safety" system.

Response: This inconsistency has been corrected in the FSEIS.

EPA72. Table 1-3 - The information provided in this table ("Environmental Reviews and Documents Pertinent to Bellefonte Nuclear Plant Unit 1:" pg 19) is not limited to Unit 1. Therefore, "Unit 1" should be removed from the title.

Response: The title of Table 1-3 has been corrected in the FSEIS.

EPA73. Assumed Figure 2-1 is not numbered in the DSEIS. Also, we suggest that Figures 3-2, 3-3, and 3-4 label the identified "submerged diffuser" area as the plant discharge site for clarity, as was done in Figure 3-5.

Response: Figure 2-1 is labeled in the FSEIS and is listed in the Table of Contents. The suggested revision has been made to FSEIS Figures 3-3, 3-4 and 3-5.

U.S. Department of Interior

12/21/2009 11:44:32 AM TVA PAC site ID #64

The Department of the Interior has reviewed the draft EIS and have no comments to provide for your consideration. It can be reached at 404-331-4524 or by email at gregory_hogue@ios.doi.gov.

DOI01

Gregory Hogue Regional Environmental Officer Office of Environmental Policy and Compliance Office of the Secretary Department of the Interior 75 Spring Street SW, Room 1144 Atlanta GA 30303 404-331-4524 404-331-1736 fax gregory hogue@ios.doi.goy

Contact: email

DOI01. The Department of the Interior has reviewed the draft EIS and have no comments to provide for your consideration.

Response: Comment noted.

State of Alabama — Alabama Historical Commission

STATE OF ALABAMA ALABAMA HISTORICAL COMMISSION 468 South PENNY STILLE MONTGOMENT, ALABAMA 30130-0900

FRANK W, WHITE IZAISSINTER DIRECTOR

November 24, 2009

10, 533-242-3184 PAX 284-2403477

Ruth M, Horton TVA 400 West Summit Hill Drive

Knoxville, Tennessee 37902

AHC 09-1092 Re:

Supplemental Environmental Impact Statement **Bellefonte Facility** Jackson, Limestone, & Morgan Counties, Alabama

Dear Ms. Horton:

Upon review of the SEIS submitted by your office, we have determined that we agree with the findings in the report. Fort the facility, we agree that archaeological site []a311 should be SHPOALDI avoided. We also agree that the Bellefonte Cemetery and the African American Bellefonte Cemetery should be avoided and some vegetative screening should be utilized here. Furthermore, for the transmission lines, we agree with your consulting with our office on the scope of work when it becomes available to ensure cultural resources are identified and dealt with according to eligibility.

SHPOAL02

We appreciate your efforts on this project. Should you have any questions, please contact Greg Rhinehart at (334) 230-2662, Please have the AHC tracking number referenced above available and include it with any correspondence.

Truly yours,

Xizaullyswn. Brain

Elizabeth Ann Brown Deputy State Historic Preservation Officer

EAB/GCR/gcr

* RECEIVED DEC 1 4 2009

THE STATE HETORES PHESCHANDON DYFECE in the preservation of the

SHPOAL01. Fort [sic] the facility, we agree that archaeological site Ija311 should be avoided. We also agree that the Bellefonte Cemetery and the African American Bellefonte Cemetary should be avoided and some vegetative screening should be utilized here.

Response: Comment noted.

SHPOAL02. Futhermore, for the transmission lines, we agree with your consulting with our office on the scope of work when it becomes available to ensure cultural resources are identified and dealt with according to eligibility.

Response: Comment noted. TVA will continue to consult with the Alabama Historical Commission regarding the scope of work for the transmission lines associated with the Bellefonte Plant.

Georgia Department of Natural Resources — Historic Preservation Division



HISTORIC PRESERVATION DIVISION

CHRIS CLARK COMMISSIONER

DR. DAVID CRASS ACTING DIVISION DIRECTOR

December 9, 2009

Ruth M. Horton Senior NEPA Specialist Tennessee Valley Authority 400 West Summit Hill Drive, WT 11D Knoxville, Tennessee <u>mhorton@tva.gov</u>

RE: Upgrade Beliefonte Nuclear Transmission Lines Dade County, Georgia HP-090914-001

Dear Ms. Horton:

The Historic Preservation Division (HPD) has reviewed the Draft Supplemental Environmental Impact Statement, Single Nuclear Unit at the Bellefonte Plant Site, Jackson County, Alabama, dated November 2009 and prepared by the Tennessee Valley Authority (TVA). Our comments are offered to assist TVA in complying with the provisions of Section 106 of the National Historic Preservation Act of 1966, as amended (NHPA).

Based on the information provided, HPD understands that if the Transmission Action Alternative is selected, then TVA will consult with our office and conduct a cultural resource survey to identify historic properties in the project's area of potential effects.

SHPOGADI

For future submittels, please note our new address below. We look forward to reviewing the additional information as it becomes available. Please refer to project number HP-090914-001 in any future correspondence regarding this undertaking. If we may be of further assistance, please do not hesitate to contact me at (404) 651-6624.

Sincerely,

Elizabeth Shine

Elizabeth Shirk Environmental Review Coordinator

ES: jht

ce: Dan Latham, Jr., Northwest RC

254 WASHINGTON STREET, SW | GROUND LEVEL | ATLANTA, GEORGIA 30334 404.656.2840 | FAX 404.657.1368 | WWW.GASHPO.ORG

SHPOGA01. Based on the information provided, HPD understands that if the Transmission Action Alternative is selected, then TVA will consult with our office and conduct a cultural resource survey to identify historic properties in the project's area of potential effects.

Response: Comment noted. TVA will continue to consult with the Georgia Department of Natural Resources - Historic Preservation Division regarding the scope of work for the transmission lines associated with the Bellefonte Plant.

Final Supplemental Environmental Impact Statement

Public Comments

General

1. We incorporate by reference Blue Ridge Environmental Defense League's (BREDL) previous recommendations on TVA's Integrated Resource Management Plan.

Response: Comments relevant to this SEIS contained in BREDL's August 14, 2009 letter to TVA regarding the scoping of the IRP have been responded to in Appendix C.

2. TVA's main goal is to be guardians over the TVA Watershed area, which includes providing energy plus protecting our environment while protecting the welfare of its stakeholders.

Response: Comment noted.

3. TVA has neglected one of their primary missions, environmental stewardship.

Response: Comment noted. For more information about TVA's environmental stewardship programs, activities and goals, go to the TVA environmental stewardship webpage <<u>http://www.tva.gov/environment</u>>.

4. Since TVA got into the power generation business, its mission has been to increase use of electricity to spur economic development. Neither TVA nor its distributors have the ability to transform themselves into a modern electricity system that sees energy efficiency as an energy resource that will save money, create jobs, and benefit everyone.

Response: Comment noted. The FSEIS has been modified to include more information about energy efficiency (EE), including the addition of an Energy Efficiency/Demand Response (EEDR) program to the base case and all alternatives, and the analysis of an enhanced, more aggressive EE effort on the Bellefonte B&W alternative.

5. The dedication of water supply to nuclear power plants is wasteful and contrary to the principal purposes for which the Tennessee Valley Authority was created -- river navigability, flood control and agricultural and industrial development.

Response: The expected BLN withdrawal is about 35,000 gallons per minute (gpm; with 23,000 gpm being returned to the river) and 24,000 gpm (with 8,000 gpm being returned to the river), for the B&W and the AP1000 alternatives, respectively. These expected BLN withdrawals are approximately 0.2 percent and 0.1 percent, respectively, of the average flow through Guntersville Reservoir (see FSEIS Table 3-3). River navigability, flood control and agricultural and industrial development would not be impacted by these small water withdrawals.

6. TVA and its distributors make money strictly on how much power they sell and how much they can recover in increased rates from the capital investments of building new generation sources. The single largest barrier to unrolling energy efficiency in our region is how to ensure that the TVA and its distributors can cover their costs as power sales decline.

Response: Comment noted. FSEIS 1.4 shows the reduction in power sales due to energy efficiency programs, and the annual cost of power taking into account the cost of the programs as well as the power sales decline.

7. TVA deferred investment in base load generation, which increased the cost of electricity to many municipal and cooperative utilities by up to 75 percent, to prepare for competition that never came. With the restart of Browns Ferry Unit 1 and the completion of Watts Bar Unit 2, TVA is working to close the gap in base load generation that was caused by their tepid reaction to pending competition forecast by the industry during the mid-1990s.

Response: Comment noted.

8. The TVA has carried forth a community propaganda campaign which has not presented accurate risks of nuclear power or employment statistics.

Response: TVA provides information that is based on verifiable data when available or based on best available estimates when making forecasts. FSEIS 3.0 provides information on nuclear plant safety in FSEIS 3.19, 'Nuclear Plant Safety and Security' and on employment statistics in FSEIS 3.13, 'Socioeconomics.'

9. What has TVA spent totally on all costs (including insurance and interest) related to the failed attempt to build two nuclear reactors at the Bellefonte site? How much does TVA still owe on this debt?

Response: TVA has spent approximately \$4.6 billion on the partial construction of Bellefonte Units 1 and 2. TVA has been addressing these costs over the years. In July 2005, TVA's Board of Directors approved amortizing the remaining costs, \$3.9 billion, and collecting them in rates over ten years beginning with fiscal year 2006. While TVA seeks to maximize the use of existing assets and thereby avoid some of the capital costs associated with constructing an entirely new facility, TVA had already addressed the amortization and recovery of the Bellefonte sunk costs before the current consideration of completing one of the unfinished Bellefonte units. Costs such as insurance and interest on debt are part of the cost of doing business and generally are not allocated to individual projects. Investments in power production facilities are a liability only if left unfinished. Once a power plant is brought online, the resulting revenue stream will provide a return on the investment.

10. The mismanagement of the nuclear program has resulted in the TVA Debt.

Response: Some of TVA's current debt can be attributed to the past nuclear programs. TVA spent approximately \$4.6 billion on the partial construction of Bellefonte Units 1 and 2. Investments in power production facilities are a liability only if left unfinished. Once a power plant is brought online, the resulting revenue stream will provide a return on the investment.

11. TVA's lack of honesty to the public after the Kingston and Widows Creek Disasters does not give citizens a sense of security and trust.

Response: TVA works to ensure public trust by providing information to the public about any incident as quickly and accurately as possible, and information is updated as new information becomes available.

The NEPA Process

12. TVA's analysis of energy efficiency and renewable energy as potential alternatives to the proposed new nuclear reactor is inadequate to fulfill NEPA's requirements to vigorously explore and objectively evaluate all reasonable alternatives. TVA has not released any analysis that would support its contention that these resources do not merit full consideration. Energy efficiency and renewable energy alternatives should be given full consideration as reasonable alternatives under NEPA.

Response: FSEIS 2.4 has been revised to include a more robust discussion of the potential for EEDR and renewable resources either alone or in combination with energy storage technologies.

TVA has reviewed the most recently published studies on energy efficiency identified by comment providers (Brown, M and J A Laitner, et al, "Energy Efficiency in Appalachia: How Much More is Available and at What Cost, and by When?" Appalachian Regional Commission, March 2009; Chandler, S and M A Brown, "Meta-Review of Efficiency Potential Studies and Their Implications for the South." Georgia Tech Ivan Allen College School of Public Policy, Working Paper #51, August 2009) as well as reports published since the close of the comment period (Brown, M A et al, "Energy Efficiency in the South," Southeast Energy Efficiency Alliance, April 12, 2010). These studies estimate the potential of EE to effectively add capacity to power systems-through energy savings-to replace or delay the construction of new generating plants through 2020 and/or 2030. For comparative purposes, TVA also reviewed a study by the Electric Power Research Institute that forecasted energy efficiency potential in southern U.S. states ("Assessment of Achievable Potential from Energy Efficiency and Demand Response Programs in the U.S. (2010-2030)," Electric Power Research Institute, Technical Report 1016987, January 2009).

The FSEIS has been updated to include an EEDR program that reduces energy needs by about 5,200 GWhs in the 2018-2020 time period. The average annual reduction for this program is about 0.3 percent through 2020. This is about 55 percent of the moderate achievable estimate of 0.5 percent annual reduction through 2020 by the Meta-Review study and about the 70 percent of the realistic achievable estimate of 0.4 percent for southern states by EPRI. An Enhanced EEDR program which about doubles the reduction in energy use of the base case EEDR program in the 2018-2020 time period has also been developed and analyzed. The TVA Enhanced EEDR program averages 0.6 percent reduction per year through 2020. This is approximately 55-75 percent of the maximum achievable estimates of 1 percent by the Meta-Review study, 0.9 percent for southern states by EPRI, 0.7 percent for Appalachia by the ARC, and 0.9 percent by the Energy Efficiency in the South study (see FSEIS 2.4).

The Need for Power analysis in FSEIS 1.4 shows that in the base case EEDR program, the proposed nuclear unit plus additional gas and nuclear expansion units are needed to meet the forecasted demand for power. Analysis of the Enhanced EEDR program shows that even with substantial energy replacement through conservation measures, TVA must still add new generation in the 2018-2020 time frame to balance resources with the projected load requirements. TVA needs both EEDR and new base load generation to meet projected demand. If EEDR efforts are more successful than predicted, TVA will be able to consider this in future energy resource analyses, including consideration of new resources and the retirement of existing resources, such as older coal-fired generating units.

FSEIS 2.4 discusses in more detail the merits of renewable energy sources such as wind and solar. Both of these resources have significantly greater land footprints and associated environmental impacts compared to the proposed nuclear unit. Additionally, to provide generation profiles similar to a nuclear unit, they must be coupled with energy storage capacity which would increase the land requirement to compensate for additional efficiency losses or with fossil-fueled generation which would increase air quality impacts. Biomass as a renewable fuel can be used to provide high capacity factor power provided adequate fuel supply exists; however, the air quality impacts are higher than a nuclear unit. Hydroelectric power has been concluded to be less environmentally preferable given its low capacity factors, environmental impacts, and the limited availability of feasible new sites in the TVA territory.

13. TVA's analysis does not offer any substantive consideration of the significant risks associated with building a nuclear reactor, such as the uncertainty in the timeline to license and construct a new reactor and costs associated with construction.

Response: The cost and schedule risks associated with building a nuclear power plant are considered in FSEIS 1.2 and 2.7. These risks are considered in the cost and schedule estimates. TVA's experience with completing Watts Bar Unit 1, refurbishing and restarting Browns Ferry Unit 1, and the current efforts to complete Watts Bar Unit 2 provide confidence in the processes and practices TVA has established to complete a nuclear unit at BLN within cost and schedule estimates. For the B&W design, similar to the process at Watts Bar Unit 2, construction will not begin until engineering is substantially complete. This practice provides assurance that the full scope of activities required to support construction is clearly defined.

For the AP1000, the Part 52 'one step' licensing process is designed to minimize licensing schedule risks, and the standardized design is intended to provide a high degree of confidence in construction schedules and costs, especially for the units that follow the reference plant construction.

14. The Southeast U.S. could generate more than 15 percent of forecasted electricity demand by 2015 with renewable energy resources such as wind, solar, and biomass resources. The DEIS fails to consider biomass resources altogether in spite of clear potential within the TVA service territory.

Response: In FSEIS 2.4 TVA addresses the potential for wind, solar, biomass, and hydroelectric generation in the TVA region either alone or in combination with energy storage technologies. The results have been compared to those presented

Final Supplemental Environmental Impact Statement

in the 2009 Southern Alliance for Clean Energy's (SACE) "Yes We Can: Southern Solutions for a national Renewable Energy Standard."

Wind: The SACE report did not provide its underlying technical assumptions for determining potential wind energy capacity, which is higher than that calculated by TVA. In Tennessee, for example, the SACE report concludes that 2,089 MW of potential wind energy capacity exists. However, using the DOE Wind Powering America basis of 163.3 km² (40,352 acres) of available windy land area and a reasonable assumption of 1 MW of capacity per 60 acres of land, TVA calculates that the potential wind energy capacity is 672.5 MW. The SACE report estimates 1416.5 MW more wind capacity in Tennessee alone.

Solar: The SACE report extrapolates available capacity within each state in the Southeast from a calculation for the state of Florida for ground-mounted photovoltaic solar energy – the only technically feasible solar energy technology on a large scale in the TVA region. This results in capacity factors between 20 percent and 25 percent depending on the state, which is higher than the 17 percent calculated by TVA using the average direct solar radiation in the region. The result is a more optimistic calculation of the solar energy potential than what TVA believes is reasonable for the TVA power service area.

Biomass: The SACE report provides an estimate of potential power capacity to be generated from biomass fuels which is higher than that of the analysis conducted by TVA. The report appears to have either over-estimated the heat content of biomass fuels or assumed efficiencies for each conversion technology that are uncharacteristically high.

Hydro: The basis for the methodology used in the SACE report is similar to that used by TVA. Thus, the conclusions are reasonably similar on the basis of annual average power (MWa). The SACE report, however, cites a state-wide capacity factor for each state in the region to calculate the total feasible capacity (MW). TVA prefers to measure hydroelectric resources in terms of annual average power as it is closer to a base load equivalent.

15. TVA should look seriously at recycling waste energy (including steam, furnace gases, heat, and pressure).

Response: Recycling waste energy, combined heat and power, is an important resource alternative. TVA pursues opportunities for recycling waste energy projects with our large industrial users as they arise. These are evaluated on a case by case basis as potential purchased power agreements in our planning efforts. Concerning our existing steam generation facilities, continuous efforts are made to monitor and reduce any heat losses in our systems to make them as efficient as possible. This is typically the least cost additional power available.

For and Against the Alternatives

16. This is the best way to produce the amount of energy needed by the Tennessee Valley area with less harm to the environment.

Response: Comment noted.

17. I (we) am against implementation of Alternative C.

Response: Comment noted.

18. I (We) prefer or support the selection of Alternative A for implementation.

Response: Comment noted.

19. I (We) prefer or support the selection of Alternative B for implementation.

Response: Comment noted.

20. I (We) prefer or support the selection of Alternative C for implementation.

Response: Comment noted.

21. I (We) prefer or support the selection of Alternative B or C for implementation.

Response: Comment noted.

Air Quality

22. We need to move away from fossil fuels, and in particular, the Widows Creek steam plant should be taken out of service in order to remove the pollution that comes from it.

Response: Comment noted. The Need for Power analysis conducted for this FSEIS includes the reduction of TVA's dependence on fossil fuel (see FSEIS 1.4.3). The base case and all alternatives for this analysis includes a reduction in fossil fuel capacity of 1,000 to 2,000 MW by 2015.

23. Carbon dioxide emission from construction and operation of the plant (total carbon cost) are unacknowledged, but considerable. The greenhouse gas emissions associated with nuclear generation (including uranium mining, milling, processing, enrichment, fuel fabrication and radioactive waste storage) come close to those of natural gas generation and are far higher than renewable energy sources.

Response: Nuclear power plants do not emit carbon dioxide in large quantities during the normal course of operations. However, fossil fuels are often used as part of a nuclear power facility life-cycle, primarily for the manufacture of the fuel that is used in the facility. Nuclear energy life-cycle emissions include emissions associated with construction of the plant, mining and processing the fuel, routine operation of the plant, waste disposal and decommissioning. Numerous studies demonstrate that on a life-cycle based comparison, nuclear generated electricity emits about the same amount of carbon dioxide per kWh as renewable energy sources and far less than fossil fuel sources. One such study is from the University of Wisconsin, "Life-Cycle Assessment of Electricity Generation Systems and Applications for Climate Change Policy Analysis" (Meier 2002). A discussion of life-cycle carbon dioxide emissions from nuclear power plants has been added in FSEIS 3.16. 3.

24. Reducing demand for electricity with efficiency and renewables will reduce emissions from combustion of fossil fuels at utility power plants.

Response: See response to Comment 22. Energy efficiency and renewable contribute to lower emissions from TVA's existing coal plants.

25. Nuclear power is not the answer to the carbon-fueled climate change crisis. We should not exchange one environmentally damaging technology for another.

Response: Nuclear energy has a proven ability to safely generate large quantities of reliable, affordable base load power generation with very little greenhouse gas emissions and other environmentally damaging impacts. Because low-carbon nuclear energy (life cycle) can produce more electricity than other clean sources, it can help to reduce our dependence on fossil fuels for base load generation and lead the way for other clean energy sources. Radiation releases are governed by federal regulations that ensure the protection of public health and safety.

Aquatic Ecology

26. Methods to control aquatic plants in the Tennessee River are of concern.

Response: Comment noted

27. Has the environmental and energy impact statement considered the amount of coolant water needed for nuclear cooling and its impacts on aquatic ecosystems?

Response: Yes, see FSEIS 2.7.2, 3.1, 3.5 and 3.7.1. The BLN site would employ a closed-cycle cooling system. Closed-cycle systems have been demonstrated to have very low effects on aquatic biota and ecosystems in the source water body. Under Alternative B or C, plant water withdrawals are 0.2 percent or less than the annual average river flow. TVA would monitor these effects during the first NPDES permitting cycle to verify that impacts to the source waterbody (impingement/entrainment of aquatic organisms) are acceptable.

28. Many fish and mussel populations throughout the entire Tennessee River, including the Bellefonte site, are greatly reduced from their historical numbers.

Response: Guntersville Reservoir was impounded in 1939. Prior to impoundment, the reach of the Tennessee River that is now inundated by Guntersville Reservoir supported a more diverse fish and mussel community. Impoundment changed this reach from a free-flowing river, characterized by a diversity of habitats (shoals, etc.), into a reservoir. Many fish and mussel species could not adapt to these changes.

TVA fish data collected from 1949 until present was reviewed to assess changes in fish species composition shortly after impoundment until present. During 1949 to 1989, 70 species were collected in TVA fish surveys in Guntersville Reservoir. A total of 71 species have been collected in Guntersville Reservoir in TVA fish samples over the past 20 years. Two of the 71 species collected in recent surveys (Atlantic needlefish and inland silverside) invaded the Tennessee River system during the past 15 years; for comparison of recent data to historic data these species are excluded. Overall, there have been no major changes in fish community composition of Guntersville Reservoir from historic data (1949 to 1989,

A-97

70 species) to recent data (1990 to 2009, 69 species). A more detailed discussion of this analysis has been added to FSEIS 3.5.1.

Rare fish species in the Tennessee River system mostly occur in reservoir tributaries that are free-flowing. Inflow areas below dams of mainstem Tennessee River reservoirs are reaches that may contain some rare species occurrences, many of which are on a seasonal basis (such as use of these areas to spawn). Bellefonte Nuclear Plant is situated approximately 35 miles downstream from Nickajack Dam in a transitional area between the reservoir inflow and forebay of Guntersville Reservoir. Fish communities of transitional areas in Tennessee River reservoirs are characterized by reservoir tolerant species and operation of this plant should have no effect on rare fish species or their habitats.

In the comments on the DSEIS, nuclear power facilities were identified as a cause of decline of fish and mussel populations in the Tennessee River system. This is incorrect. TVA currently operates three nuclear power facilities which discharge a heated effluent into the Tennessee River. Thermal discharges from each of these facilities are regulated by Section 316(a) of the federal Clean Water Act. Annual fish and benthic macroinvertebrate monitoring is conducted upstream (reference site unaffected by the plant's thermal discharge) and immediately downstream of the thermal discharge to demonstrate that these facilities are not adversely affecting fish and benthic macroinvertebrate populations as a result of thermal discharges. These data are reported annually to state and federal regulators. Operation of these facilities in a manner that ensures that the maximum thermal discharge limits are not exceeded assures protection of aquatic resources from the thermal affects of the facilities' discharges. Facilities must reduce power production, if necessary, to ensure compliance with the thermal limits in the NPDES permits.

Mussels have declined significantly in the Tennessee River system and throughout North America. Impoundment of free-flowing rivers is the primary cause of this decline. Some species have been able to adapt to reservoir environments and can be locally abundant. Many species are still extant in tailwaters below dams but are present in low numbers due to a variety of factors. Cold water dam releases inhibit reproductive physiology, reproductive timing, and may eliminate specific host fish required for reproduction. Unnatural flow regimes also interrupt reproductive timing and may scour substrates necessary for juvenile development. Many of the species that are listed as threatened or endangered under the Endangered Species Act are extant as old individuals that have remained in tailwaters since the dam was constructed. In many cases, conditions are not suitable for successful reproduction and populations slowly disappear as these individuals die. Mussel surveys conducted around the BLN site yielded mostly common, reservoir tolerant species. One individual of the pink mucket, Lampsilis abrupta, was found in surveys conducted for this SEIS. This species is an example of a long lived mussel that is widespread in the Tennessee River system (but rare and occurs in low abundance) and that has had limited reproductive success in areas affected by impoundments. As stated above, the BLN site is situated in a mid-reservoir (transitional) area between the reservoir inflow and forebay of Guntersville Reservoir. Mussel habitats in transition zones of Tennessee River reservoirs are typically marginal and only support viable populations of species that are able to adapt to reservoir conditions.

29. Warm water that is discharged from nuclear power plants results in 'thermal plumes' that cause stress on aquatic life, lower dissolved oxygen levels, and affect the feeding and breeding patterns of various species. Dissolved oxygen levels downstream from the Sequoyah nuclear plant were even lower as it is downstream from the Watts Bar nuclear plant. What about the impacts at the Bellefonte location, which is even further down stream?

Response: Hydrothermal modeling of potential heat effects under either action alternative are discussed in FSEIS 3.1.3.1. Thermal effects of plant operations on aquatic species are addressed in FSEIS 3.5.2. TVA has modeled the potential effects of cooling water blowdown discharges on fish and shellfish communities at the BLN site and does not anticipate any significant effects to important fish or shellfish communities to occur. TVA will monitor these communities when the plant is operational to confirm the conclusion of the model.

TVA monitors dissolved oxygen levels in Guntersville Reservoir as part of its Reservoir Vital Signs monitoring program. Monitoring results demonstrate that, due to the physical makeup of the reservoir (relatively shallow and more riverine when compared to other reservoirs), relatively short retention times, and inflows from unimpounded rivers and streams, Guntersville Reservoir does not exhibit the low dissolved oxygen conditions that occur in some deeper reservoirs with longer retention times. Therefore, effluent from the BLN site is not expected to combine with effects from upstream or downstream industries to result in extraordinarily low dissolved oxygen levels.

Climatology & Meteorology

30. As climate change worsens, water shortages and heat waves will make nuclear power less reliable due to rising river water temperatures forcing reactors to be powered down.

Response: Additional analysis was performed on the possible effects of climate change, both for temperature and water resources, and this information is included in FSEIS 3.16.3.

31. The Draft EIS did not adequately address global climate change impacts.

Response: TVA has performed additional analysis of possible climate change impacts on a nuclear reactor at the Bellefonte site, as well as impacts from a Bellefonte reactor on global climate change. See FSEIS 3.16.3, Global Climate Change.

Cost of New Generation

32. Nuclear energy is the cheapest, cleanest means for producing reliable electrical energy for an ever growing power need in America.

Response: Cost and emissions are two important benefits for using nuclear energy for producing reliable electrical energy. FSEIS Table 1-2 shows that completion and operation of a B&W unit (Alternative B) is the least costly alternative by 2020 and overall the most cost effective alternative for providing base load energy. FSEIS Table 1-1 shows that emissions of SO₂, NO_x, and mercury are cut by over half from

2010 levels for alternatives that include a new nuclear unit. CO₂ emissions are reduced by 1.3 percent.

33. A study of the social costs of renewable energy technologies indicate that they provide a net social benefit from employment gains and resultants wage and tax benefits from the installation of wind and solar technologies.

Response: Comment noted. Renewable energy resources are addressed in FSEIS 2.4.

34. The estimated cost to construct a nuclear power plant has risen significantly in recent years; this contrasts with some renewable energy options like solar and wind, whose costs have declined.

Response: While it is true that the cost estimates for new nuclear power plants has risen and cost estimates for solar and wind options have declined in part due to increased maturity level in the technology, nuclear is still TVA's most economical option for new generation capacity. FSEIS 2.4 discusses the renewable energy alternatives considered. While economics were not addressed specifically, each of the primary renewable technologies (wind, solar, hydro, and biomass) was found to be less environmentally preferable when compared to a generating capacity equal to that of the proposed nuclear facility (See response to Comment 14). Additionally, in order to provide a generation profile similar to a nuclear facility, renewable technologies require coupling with energy storage systems or fossil-fuel powered generation, which increases the environmental impact and costs.

35. Nuclear power plants are a poor long range investment given their long and risky construction schedules. TVA's first attempt at constructing a nuclear power plant at the site was a financial disaster. This project presents a large financial risk to TVA.

Response: See FSEIS 2.2.3 and 2.2.4. As it did with WBN 2, TVA has conducted a detailed analysis of the BLN B&W units to determine constructability, costs and risks. This has substantially increased TVA's confidence that BLN 1 can be successfully completed. TVA also carefully considered similar risks for an AP1000 unit. See FSEIS 2.3.

36. Nuclear power is expensive and would not survive without federal subsidies.

Response: Nuclear, like many generation alternatives, has a high upfront capital cost which is offset by low operating cost. Nuclear is less sensitive to fuel costs than other technologies. However, all forms of electricity generation are subsidized through the various government programs and these subsidies are factored into the economic evaluation to determine the cost of energy. TVA evaluates the total cost when making decisions about the most cost effective forms of new generation. FSEIS 1.4.5 discusses the economic benefit of adding nuclear power to TVA's generation portfolio. TVA receives no direct funding or subsidies from the federal government for the operation of its power generation system.

37. Providing the lowest cost electricity as mandated by the TVA Act will not be accomplished if either Alternative B or C is selected.

Response: FSEIS 1.4.4 discusses the economic benefit of adding nuclear power to TVA's generation portfolio. While both Alternatives B and C have lower annual power costs than the base case, Alternative B (B&W) increases its cost advantage over time relative to the base case because of the lower operating cost and lower capital cost of this technology.

Delivered Cost of Power

38. Selection of Alternative B or C will reduce power costs for TVA customers and mitigate price fluctuations caused by off-system power purchases and the increased use of natural gas-fired generation to meet peak demands and meet reserve capacity requirements.

Response: FSEIS 1.4.4 discusses the savings provided by completing either action alternative. See response to Comment 37.

39. Because of TVA's reliance on natural gas-based generation to meet peak demands and reservation capacity requirements for most of the past decade, consumer electric bills have dramatically increased.

Response: Consumer bills for electricity have increased over the past decade for a number of reasons, including fuel cost volatility, higher cost of purchased power, and lower than expected hydro generation. With a diverse generation portfolio that includes nuclear generation, TVA is better able to control energy costs and the risk to customers of increased costs of any specific generation resource is lessened.

40. Nuclear generated electricity is the least expensive generating option, or is at least cost-effective.

Response: Nuclear generated electricity is one of the least expensive base load generating options to meet the growing demand for electricity in the Tennessee Valley.

41. Has an analysis been conducted comparing the cost of nuclear power compared to alternative, renewable energy sources?

Response: Cost estimates for new nuclear power plants have risen and cost estimates for solar and wind options have declined due in part to increased maturity level in the technology, but nuclear is still TVA's most economical option for new generation capacity. FSEIS 1.4.4 compares the cost of various generation options, including an enhanced EEDR program and concludes that completion of the nuclear unit at Bellefonte is the most economical way to meet the projected demand.

FSEIS 2.4 discusses renewable energy alternatives, while economics were not addressed specifically, each of the primary renewable technologies (wind, solar, hydro, and biomass) was found to be less environmentally preferable when compared to a generating capacity equal to that of the proposed nuclear facility. (See response to Comment 14) Additionally, in order to provide a generation profile similar to a nuclear facility, renewable technologies require coupling with energy

storage systems or fossil-fuel powered generation, which increases the environmental impact and costs.

Demand-Side Management (DSM)

42. TVA should invest money in an aggressive advertising campaign for conservation energy efficiency programs they are offering.

Response: Comment noted. TVA will continue to develop cost effective EEDR programs to help meet future load growth as well as prepare for the possible placement of aging fossil generation units in long term layup. Advertising campaigns are an important consideration that is incorporated into program design.

43. TVA recognizes the benefits of a well-diversified resource mix to address uncertainties associated with any one kind of energy resource, but dismisses demand response and energy efficiency programs because TVA considers these programs will take time to implement and could have uncertain results. Building a new nuclear reactor does not diversify TVA's energy mix since the utility is already heavily reliant on nuclear power.

Response: TVA recognizes that EEDR programs play an important part in meeting our energy needs. As discussed in the response to Comment 12, the demand reduction and energy savings associated with EEDR programs have been included in our updated need for power analysis in FSEIS 1.4. TVA will continue to develop cost effective EEDR programs to help meet future load growth as well as prepare for placement of aging fossil-generation units in long-term layup. Currently about one third of TVA's power mix is nuclear generation. Adding a single nuclear unit in 2019 will increase the contribution by a small amount (see FSEIS Figure 1-7).

44. TVA has not, to date, effectively addressed energy efficiency as a resource. Energy efficiency is the most cost-effective, near-term strategy to ensure future system reliability. TVA should focus on the implementation of energy efficiency programs or refute the studies that show energy efficiency to be a potentially significant resource in the TVA service territory.

Response: The FSEIS has been updated to include an EEDR program that reduces required energy needs by about 5,200 GWhs in the 2018-2020 time period. FSEIS 2.4 has been revised to include a comparison of TVA's EEDR program with recent studies that describe potential energy reductions in the TVA service territory due to energy efficiency. For additional information see FSEIS 1.4, 2.4 and the response to Comment 12.

Energy Alternatives

45. Nuclear power, clean coal, U.S. produced petroleum, geothermal, wind, and natural gas are all components to energy independence and will all be needed to meet increasing energy demand.

Response: TVA uses a diverse portfolio of EEDR and supply side resources to meet the electricity needs of our customers. This approach helps mitigate risks such as those associated with fuel dependence. As we develop our portfolio of base, intermediate and peaking generation resources to meet projected load requirements we consider all viable options in our planning efforts.

46. Since TVA has initiated a renewed integrated resource planning process that is not yet complete, making a final determination of the need for an additional nuclear reactor at the Bellefonte site means that up-to-date analysis of various alternatives will not be factored into the decision-making process, which does not live up to the purpose of NEPA to require a full and fair consideration of all reasonable options. TVA must delay deciding on whether to build the proposed nuclear reactor at the Bellefonte site until this resource planning process has resulted in a comprehensive plan that fairly considers all viable resource options.

Response: One of TVA's most important responsibilities is ensuring that it is able to meet the demand for electricity placed on its power system. Thousands of businesses, industries and public facilities, and millions of people depend on TVA each day to reliably supply their power needs. To meet this responsibility TVA forecasts the future demand and the need for additional generating resources in the region it serves. Because planning, permitting, and construction of new generating capacity and transmission requires a long lead time, TVA must make decisions to build new generating capacity well in advance of the actual need. Waiting until the Integrated Resource planning process is complete in 2011 would put TVA at risk of not being able to meet the capacity needs in the 2018-2020 time frame and could remove completion of one of the BLN units as a viable resource option for meeting this identified need. Similarly, TVA has proceeded to acquire additional wind resources while the integrated resource planning process is underway to make sure it secured these resources at an optimal time.

Commenters identified renewable energy resources and EEDR resources, specifically, as the resources that needed more consideration in the context of the proposed construction of a nuclear unit at the BLN site. In response, TVA has expanded the discussion of these resources in the FSEIS and comment responses, including analyzing an enhanced, more aggressive EE program. Based on this analysis, TVA has determined that one nuclear unit still was the low-cost option for meeting TVA's purpose and need. See FSEIS 2.4 for a discussion of alternative energy resources.

47. The FSEIS should discuss the contribution of energy efficiency/conservation programs and the generation of electricity from renewable resources in terms of the purpose and need of the proposed BLN unit. TVA should focus on an energy policy that invests in clean, renewable energy sources such as wind and solar, and that includes a comprehensive energy conservation and efficiency program. TVA should offer incentives to residential and commercial entities to offset the cost of installing renewable energy technologies.

Response: The contribution of EEDR programs and the generation of electricity from renewable resources are more fully addressed in FSEIS 1.4 and 2.4. Currently TVA is actively pursuing renewable generation capacity through our Green Power Switch and Generation Partners programs and has recently added 1,300 MWs of wind resources to its energy portfolio through several power purchase agreements. TVA currently provides incentives to customers through the Energy Right and Generation Partners programs.

TVA anticipates using a mix of resources, including EEDR programs, renewable resources, natural gas-fired generation, and nuclear generation to provide the additional future needs. Given the magnitude of the capacity and energy need, and

to avoid the risk of relying on only one fuel or technology, no single resource should be used to meet all of the future energy and capacity requirements. TVA has determined that adding a nuclear unit at the BLN site is the most cost effective alternative to meet a portion of these future needs.

48. TVA's current portfolio of nuclear and fossil fuel-fired electricity generation facilities presents real economic impacts in terms of public health in the region, particularly medical care costs and early death. TVA should adopt a carbon negative energy policy that invests in clean, renewable energy sources such as wind and solar, and that includes a comprehensive energy conservation and efficiency program. Such an energy policy will generate benefits to public health and the economy.

Response: TVA's current energy policy includes energy conservation and efficiency programs. Nuclear energy has a proven ability to safely generate large quantities of reliable, affordable base load power generation without greenhouse gas and other emissions. NRC regulations ensure that public health and safety are adequately protected from radiation exposure. Because low-carbon nuclear energy (life cycle) can produce more electricity than other clean sources, it can help to reduce our dependence on fossil fuels for base load generation and lead the way for other clean energy sources. FSEIS 1.4 shows that the base case and all alternatives reduce carbon emissions from present levels.

49. Energy storage technologies are becoming economically and practically viable as evidenced by information available from the US Department of Energy.

Response: Comment noted. TVA continues to evaluate energy storage technologies and how they can fit into its portfolio. Energy storage is primarily used to help manage peak demands by storing power generated off peak for use during times of peak demand or to mitigate the variability of renewable fuel supply such as wind and solar providing a more stable energy generation profile. FSEIS 2.4.2 discusses various energy storage alternatives.

50. TVA should make public any and all analysis that indicate the environmental impacts of solar and wind energy 'are equal to or greater than those of a nuclear plant.'

Response: FSEIS 2.4 has been revised to include a more robust discussion of the potential for renewable resources. Renewable energy sources such as wind and solar have significant land requirements to generate electricity comparable to that of a nuclear facility. Additionally, to provide generation profiles similar to a nuclear unit, they must be coupled with energy storage capacity which increases the land requirement to compensate for additional efficiency losses or with fossil-fueled generation which increases the impact on air quality. Biomass as a renewable fuel can be used to provide high capacity factor power provided adequate fuel supply exists; however, the air quality impacts are higher than a nuclear unit. Hydroelectric power has been concluded to be less environmentally preferable given its low capacity factors, environmental impacts, and the limited availability of feasible new sites in the TVA territory.

A-104

51. While the US might not need to build any coal or nuclear plants to meet the base load, as generation units age, the challenge will be to replace their capacity with the most forgiving electricity sources, which will be renewable energy sources.

Response: Renewable energy sources are one supply side option to meet TVA's energy needs. The need for power analysis in FSEIS 1.4 has been updated to include renewable resources and discusses their appropriate utilization for meeting power needs. Likewise, a discussion of renewable resources considered as an alternative to the nuclear plant is also included in FSEIS 2.4.

52. The region needs to move away from coal and adopt nuclear and non-polluting renewable resources. The region has too many coal burning units, which pose hazards. How many millions of tons of coal ash does TVA own?

Response: TVA continues to develop cost effective EEDR and renewable energy programs to help meet future load growth and provide the flexibility to retire older fossil generation. Nuclear energy has a proven ability to safely generate large quantities of reliable, affordable base load power generation without greenhouse or other gas emissions. TVA currently has 217 million tons of coal combustion products (CCP), including fly ash, bottom ash, slag, gypsum, char, and spent bed which is stored in ponds and landfills. TVA beneficially reuses 38 percent of its CCP.

53. The high temperatures used in incineration and gasification waste biomass, as well as the cooling process following burning, can produce toxic and acidic gases, metals, dioxins, and furans that are dangerous at extremely low levels. Some are persistent and bioaccumulative.

Response: Comment noted. Any fuel that TVA considers for combustion is thoroughly evaluated for environmental impacts including emissions. Any waste sources that are high in heavy metals, toxins, etc. are not accepted as fuel sources.

54. Biomass should not be considered a renewable energy, as waste is not a renewable resource.

Response: Comment noted. Broadly speaking there are two biomass energy feed stocks—biomass waste and biomass crops. The latter clearly is renewable because crops, such as switch grass, can be repeatedly grown and harvested to feed a biomass combustor. Biomass waste—such as wood wastes from industries using forest products—also is considered renewable because it is derived from a renewable resource initially. The sustainable availability of biomass waste is a factor that must be carefully considered when deciding to rely on biomass waste as an energy resource.

55. If increased generating capacity is necessary, TVA should build a natural gas generation plant at the site. Such a plant could be built more quickly with a lower installed cost and less technological risk, and would eliminate some of the waste generation and public and environmental health concerns of a nuclear generating facility.

Response: Natural gas generation was considered as an option to meet the purpose and need of TVA's current proposal in the FSEIS 2.4.2. Our need for

Final Supplemental Environmental Impact Statement

A-105

power analysis predicts a need for 7500 MW additional generation capacity from 2010 to 2019 (medium-load forecast). Due to the relatively high cost of natural gas as a fuel, natural gas plants were found to be most suitable for meeting intermediate and peaking needs. Additionally, the negative impact to air quality from gas-fired generation exceeds that of nuclear power. Nuclear energy has a proven ability to safely generate large quantities of reliable, affordable base load power generation. Nuclear waste is discussed in FSEIS 3.18. Constructing and operating natural gas generation at the BLN site was evaluated in detail in TVA's Final Environmental Statement, "Bellefonte Conversion Project" (TVA 1997).

56. A 800mgw natural gas combined cycle plant is a solution along with energy efficiency measures and updating hydroelectric generation and power distribution systems.

Response: FSEIS 2.4 discusses alternatives that do not require new generation, such as energy efficiency, and those that do, such as natural gas-fired technology and hydro power, as well as combinations. The discussion concludes these alternatives are less environmentally preferable to the nuclear facility.

57. It is unreasonable to expect all renewable technologies to produce full base load capacity. Solar peaking units should also be seriously considered.

Response: The load shape of our energy requirements dictates the type of resources that are considered as alternatives in the FSEIS, as well as how they are utilized to meet customer demand. Here the need is for base load generation, not peaking generation. Matching resources to the hourly demands requires a diverse portfolio of resource options.

FSEIS 2.4 shows that renewable energy sources such as wind and solar have significant land requirements to generate electricity comparable to that of a nuclear facility. Additionally, to provide generation profiles similar to a nuclear unit, they can be coupled with energy storage capacity which increases the land requirement to compensate for additional efficiency losses or with fossil-fueled generation which increases the impact on air quality.

58. The FSEIS should include an analysis of the significant direct solar conversion capability in the vicinity of the Bellefonte site.

Response: FSEIS 2.4.2 has been updated to further explain the feasibility of solarpowered generation in the TVA service area using direct normal insolation and diffuse horizontal radiation data provided by the National Renewable Energy Laboratory. Solar plants have significant land requirements to generate electricity comparable to that of a nuclear facility. Additionally, to provide generation profiles similar to a nuclear unit, they must be coupled with energy storage capacity which increases the land requirement to compensate for additional efficiency losses or with fossil-fueled generation which increases the impact on air quality.

59. New solar capacity can be closely tailored to rising demand due to short construction times.

Response: See the response to Comments 57 and 58. Despite shorter construction times, solar generation is not considered a suitable option for the base

load need identified in this FSEIS. FSEIS 2.4.2 has been updated to further explain the potential of renewable resources, including solar, in the TVA service area.

60. The Department of Energy projects that if solar energy capacity increase goals are achieved, it would put the U.S. industry on track to reduce the cost of electricity produced by PV from current levels to a price that is competitive in nationwide markets.

Response: TVA monitors the progress made in the development of various demand and supply side options to meet our future energy needs. As developmental goals are realized the new characteristics of the options are entered into our planning models for future decisions.

FSEIS 2.4.2 has been updated to further explain the feasibility of solar-powered generation in the TVA service area using direct normal insolation and diffuse horizontal radiation data provided by the National Renewable Energy Laboratory. PV solar generation is not considered a suitable option for the need identified in this FSEIS. In addition, as this comment suggests, solar energy currently is substantially more costly than other energy resource options

61. Wind energy produces three times the total U.S. electric power need annually. Wind power is becoming one of the lowest cost energy technologies with zero waste and should be among TVA's highest priorities.

Response: TVA is actively pursuing renewable generation capacity through our Green Power Switch and Generation Partners programs. In addition, TVA has recently acquired 1,300 MWs of wind energy through several power purchase agreements.

While an important part of our clean energy portfolio, the use of wind power to provide base load generation requires coupling with either fossil-fueled generation or energy storage. FSEIS 2.4.2 discusses this potential for wind power in the TVA region and concludes that it is less environmentally preferable to the proposed nuclear option, primarily due to the large land area requirement to provide a comparable source of base load generation.

62. Most thermoelectric power plants have an efficiency factor of about 33 percent (two thirds of the power released by the heat source is wasted and is released to the environment as hot water). To meet base load demand, thermoelectric plants build thermal capacity three times the desired electric power need. Similarly, base load power from wind turbines requires the construction of about three times to needed electric capacity to deliver reliable base load power.

Response: Some inefficiency is inherent in the process of thermoelectric generation. However, these thermoelectric plants provide electricity in a reliable manner.

Floodplain and Flood Risk

63. Of concern in terms of the site and the proposed facility is the possibility of flooding in the Guntersville Watershed.

Response: Completion or construction and operation of a nuclear plant at this location would not increase the flood risk in the Guntersville Reservoir watershed because the plant would not impact upstream flood elevations. Nor would there be unacceptable flooding risks at the site itself. See FESIS 3.3.

64. The DSEIS indicates that all safety related structures are located above the PMF levels or have been flood-proofed. When additional site hydrological studies completed, analysis could result in a PMF higher than assumed in the design, which could require additional construction not already assumed in the DSEIS. Without a completed hydrology analysis, the Draft SEIS cannot address the potential impact of any additional construction.

Response: FSEIS 3.3.1 has been updated based on the 2009 re-verification of the Probable Maximum Flood (PMF), the controlling PMF elevation at the BLN site. The PMF would be 625.7 feet msl with dam safety modifications that were made to Watts Bar and Nickajack dams. The maximum wind wave activity is estimated to be 1.3 feet high. Therefore, the PMF and coincident wind wave activity results in a flood elevation of 627.0 feet msl which is below the B&W plant flood design grade elevation of 629.1 and the AP1000 plant grade elevation of 628.6.

65. Possible issues with the location of safety systems in terms of the Probable Maximum Flood levels were not adequately addressed in the NEPA analysis.

Response: FSEIS 3.3.2 has been updated to clarify that, under both Alternatives B and C all safety-related structures are either located above or flood-proofed to the Tennessee River PMF and coincident wind wave elevation of 627.0 feet msl, and above the probable maximum precipitation (PMP) site drainage elevation of 627.53 feet msl.

Need for Power

66. TVA has not demonstrated realistic future projections of electrical needs nor financial reductions of debt.

Response: FSEIS 1.4 describes the methodology used to estimate our future energy needs. The methodology is comparable to that used by other large utilities. TVA's 2007 Strategic Plan calls for TVA to pay its financing obligations before the power generating assets supporting those obligations are fully depreciated. Also, any new debt will be supported by new assets. In following these principles, TVA ensures that it maintains a debt level that is supportable based on the size and scope of operations.

67. With the growth in the Tennessee Valley region and with electric vehicles on the horizon, TVA must invest in new base load supply. Otherwise, its base load fleet would be further strained and its peaking fleet would be operated more often, effectively increasing the cost of TVA power.

Response: Comment noted. If widespread use of electric vehicles becomes a reality, we anticipate that TVA's load shape will flatten somewhat, lessening the need for peaking resources and increasing the need for more base load resources.

68. The recession has reduced the consumption of electricity and many utility executives believe that this recession's recovery will not follow traditional patterns due to advances in energy efficiency.

Response: As stated in FSEIS 1.4.1, future growth is expected to be lower than historical averages, including the impact of the 2008-2009 recession.

69. TVA's projections for 2030 system energy and summer peak are inaccurate and cannot be used to determine the need for more generating capacity since they do not include the 1200MW peak reduction that TVA plans to deliver in 2012, the effects of the Time of Use pricing rate structure anticipated to occur in 2012, or the anticipated legislation that will put a price on carbon.

Response: The need for power analysis for Bellefonte is not based on 2030 projections for system energy and summer peak loads. FSEIS 1.4 discusses the methodology used to determine the need for power, which includes the load forecast, current system resources, and forecasted additions for all years of the forecast. FSEIS 1.4 has been updated to include a number of changes in planning assumptions that have been made as part of the normal business planning cycle, including adjustments to reserve requirements, forecasted hydro production, fuel and emissions allowance prices, an updated load forecast, power purchase agreements for wind energy, increased emissions control from coal plants, long term layups of coal capacity, and the addition of an EEDR program. The potential impacts of carbon legislation are included in the production cost model.

70. TVA needs to revise downward its projected need for additional capacity based on the EIA's updated projection (December 2009) of the growth in electricity.

Response: The need for power projection in the DSEIS matches that of the EIA'S updated projections of growth in electricity. In order to address the uncertainty of economic growth, TVA's forecast includes analysis of both higher and lower than expected economic growth. As stated in FSEIS 1.4.1, future growth is expected to be lower than historical averages including the impact of the 2008-2009 recession. An updated analysis of the need for power is provided in FSEIS 1.4.

Even though historically, net system requirements (NSR) grew at an average rate of 2.3 percent (1990-2008), in TVA's current forecast, NSR shows a reduction in demand through 2010, reflecting the weak economic conditions compounding over the last year. In TVA's forecast, the average annual growth rate recovers to 1.3 percent, which is higher than EIA's longer term projection (2012-2028) in the December 2009 forecast, but remains lower than the growth rate over the 18-year historical period. For comparison, the long-term net system requirements in the low

economic conditions case grow at an average annual rate of 0.3 percent (much lower than the 1.0 percent in EIA update); whereas, in the high economic conditions case, NSR forecast shows average annual growth of 2.0 percent, double that of the EIA update, but still lower than the 18-year historical period of the Tennessee Valley.

71. The hydro and steam plants are experiencing a lot of stress and it's straining the systems.

Response: TVA maintains and operates its coal fleet and hydro plant in a manner that optimizes generation. The success of meeting the January 2010 cold spell, which was a new peak for TVA, suggests the strengths of the TVA system. However, TVA is paying more attention to maintenance activities. The additional base load generation that a nuclear unit provides will ensure that TVA will be able to meet the increasing base load demand while maintaining system reliability.

72. It makes sense to use a site that has already experienced a great deal of development as a nuclear power plant, like Bellefonte, instead of developing another site to increase the electrical base load.

Response: Making use of the infrastructure at the Bellefonte site maximizes the use of existing assets, avoids larger capital outlays, and avoids the environmental impacts and extended project schedule of siting new power generating facilities elsewhere.

Nuclear Plant Safety and Security

73. There is no such thing as accident-free nuclear power; all reactors are susceptible to operator error or programming errors.

Response: Nuclear plant accidents are discussed in detail in FSEIS Section 3.19. Additionally, information pertaining to nuclear plant safety can be found at the following links:

<<u>http://www.nrc.gov/reading-rm/doc-collections/nuregs/brochures/br0164/r4/></u>

<http://www.nei.org/keyissues/safetyandsecurity/operationalsafety/>

<http://www.world-nuclear.org/info/inf06.html>

74. Nuclear power reactors release radioactive gases and liquids into the environment as a result of accidents, as well as normal operations.

Response: The FSEIS addresses both normal operations and accidents. See Sections 3.17, 3.19.1, and 3.19.2 regarding the radiological effects of normal operation, design-basis accidents, and severe accidents, respectively. All calculated doses are within the applicable NRC limits.

75. The incident at Browns Ferry nearly resulted in the loss of everything by everyone living downwind of the site.

Response: Safe operation of our nuclear plants is of utmost importance. The safety of nuclear plants is highly regulated by the NRC and TVA continues to comply with all applicable safety standards. Worker training and compliance with written procedures are used to prevent incidents such as the Browns Ferry event which happened in 1975, 35 years ago. See FSEIS 3.19 for analysis and further discussion of plant safety and security.

76. The uncertainties associated with new nuclear reactors continue to escalate, putting people and the environment at increasing risk.

Response: The new reactor licensing process is designed to reduce risk and uncertainty. The NRC safety and environmental reviews are extremely thorough and complete. The process ensures that the designs are substantially complete before the Design Certification and Combined Operating Licenses are issued, further reducing risk and uncertainty. The technology, design methods and analyses used in new reactor designs have reduced the uncertainty to levels that meet or exceed the published NRC safety goals.

A probabilistic risk assessment (PRA) has been submitted as a part of the AP1000 design certification application in accordance with 10 CFR Part 52. The PRA evaluation, provided in Chapter 19 of the AP1000 DCD, evaluates the AP1000 design, including plant, containment, and typical site analysis that consider both internal and external events. The AP1000 design process included a risk assessment of the design prior to being finalized to optimize the plant with respect to safety. The risk informed design process resulted in the selection of design alternatives which increased the overall level of safety and verified that the US NRC PRA safety goals have been satisfied.

The risks associated with operation of a new AP1000 plant at the Bellefonte site are addressed in Section 7.2 of the COLA ER (TVA 2008a). The reported early fatality risk resulting from a severe accident is zero and the latent (cancer) fatality risk is 1.83E-05 per reactor year. As discussed in Section 7.2, these risks meet the nuclear regulatory commission's safety goal policy statement. Therefore, the early and latent fatality risks from a severe accident at the BLN site are considered acceptable. The risks associated with operation of B&W and AP1000 reactors are addressed in FSEIS 3.19.

77. No fire-endurance tests have been conducted to qualify Hemyc as an NRC-approved one-hour or three-hour fire barrier for installation at nuclear power plants.

Response: TVA is aware of the issues with Hemyc. TVA construction will utilize an approved and qualified fire barrier design.

78. What will the impact be, if any, on the general aviation airport in Scottsboro given the proximity of the Bellefonte plant and towers to the approach and glide pattern?

Response: The Bellefonte Nuclear Plant should have no impact on the general aviation airport in Scottsboro. See response to Comment 79. In addition, the BLN Units 3 and 4 COLA, Section 3.5.1.6, analyzed the probability of an aircraft crash from the Scottsboro airport, including projected growth through 2060, and found "the aircraft hazards pose no undue risk to the health and safety of the public." Similarly, the BLN Units 1 and 2 FSAR evaluated the potential aircraft crash from the Scottsboro airport and found the results acceptable.

79. Will there be any security areas, off-limits areas, or any other restrictions that may impact local aviation?

Response: There will be no restrictions that would affect local aviation.

80. The nuclear option makes us more susceptible to danger from a variety of sources, including hazardous wastes and terrorism. Terrorism targeting the nuclear plant presents serious risks to our safety.

Response: TVA believes that the possibility of a terrorist attack affecting operation of one or more units at the BLN site is very remote and that postulating potential health and environmental impacts from a terrorist attack involves substantial speculation. Notwithstanding the very remote risk of a terrorist attack affecting operations, TVA increased the level of security readiness, improved physical security measures, and increased its security arrangements with local and federal law enforcement agencies at all of its nuclear generating facilities after the events of September 11, 2001. These additional security measures were taken in response to advisories issued by NRC.

Nuclear Reactor Design

81. Both of the proposed nuclear plant designs are problematic, untested in the U.S., and potentially costly and unsafe. An AP1000 reactor has never been constructed. In addition, the design of the AP1000 reactor is problematic and presents a financial (and potentially a safety) risk.

Response: The B&W design at Bellefonte is an enhancement of proven B&W plants that are successfully operating in this country. The B&W 205 reactor has improved operating margins and the Bellefonte plant design has incorporated many other safety and operational improvements. This design was built and operated well in Germany (the Muelheim-Kaerlich reactor) before it was shut down for reasons unrelated to its performance.

AP1000 units are currently under construction in China and are scheduled to be operational several years before any planned need at Bellefonte. Additionally, three US utilities are planning to begin construction on AP1000 units before TVA. These efforts will serve to confirm construction techniques and schedules, reduce cost and schedule risks, and provide valuable lessons learned before construction would begin at Bellefonte. The design of third (or later) generation reactors is specifically intended to provide safety enhancements and improved operability over the existing nuclear fleet which have demonstrated an impressive reliability and safety record.

Westinghouse, along with the AP1000 owners group, is working diligently to resolve the remaining NRC licensing issues and has proposed design changes to respond to the cited NRC concern. Recertification of the design is anticipated in 2011.

82. The Draft SEIS states that in 1988 when TVA abandoned plans to complete the reactors, Unit 1 was 90 percent complete and Unit 2 was 58 percent complete. However, due to new construction standards and other upgrades, the completion levels may translate into only 55 percent and 35 percent complete. This should be addressed in the FSEIS.

Response: FSEIS 2.2.2 and 2.2.3 have been revised to address the completion status of Unit 1 and Unit 2 and the activities required to complete a unit.

83. Existing assets should be utilized to maximize the use of existing disturbed lands and minimize new land disturbances.

Response: Use of existing assets to obtain new generation sources makes good business and environmental sense. As discussed in FSEIS 2.2 and 2.3, for either alternative TVA would utilize existing assets to maximize the use of existing disturbed lands and facilities, and to minimize new land disturbances.

84. So-called 'cookie cutter' reactors are not standard and require substantial site-specific design changes, adding to uncertainties about performance and reliability. Substantial site-specific design changes necessary during the construction of previous nuclear power plants have delayed construction and created uncertainty regarding performance and reliability.

Response: Substantial site-specific design changes have not been necessary for the AP1000 units. The AP1000 utilities and Westinghouse have worked closely together to achieve an extremely high degree of standardization in both plant design and operational programs. Further, design and engineering work will be substantially complete prior to construction minimizing the potential for design changes and schedule delays. This commitment to standardization will ensure that construction schedules and reliable performance have a high degree of certainty.

85. The building of new-design AP1000 reactors should not even be considered until the design problems, critiqued by the Nuclear Regulatory Commission, have been fully resolved.

Response: An AP1000 reactor can only be constructed after Westinghouse has received the approved design certification from the NRC.

Radiological Effects

86. Independent studies have shown increases in childhood leukemia near nuclear facilities in La Hague, France. TVA should study these findings.

Response: The Compagnie Générale des Matières Nucléaires (COGEMA) La Hague spent fuel reprocessing facility near Cherbourg, France is unlike any domestic nuclear facility because spent fuel is not currently reprocessed in the United States. The proposed BLN commercial nuclear power plant will not reprocess nuclear fuel, and there would not necessarily be any correlation between

the anticipated radiological impacts associated with the operation of the COGEMA facility and operation of an AP1000 or B&W reactor at BLN.

The NRC periodically investigates the cancer risks for populations that live near nuclear power facilities as part of its mission to protect the health and safety of the public. The NRC uses the results of these studies to provide assurance that current regulations provide adequate protection for the health and safety of the public. In fact, the NRC has recently asked the National Academy of Sciences to perform an updated study regarding these risks. If the NRC were to find that current regulations do not adequately protect the public, the regulations would be modified so as to do so. TVA is obligated to comply with all regulations applicable to each of its nuclear facilities. In addition to complying with applicable regulations, TVA keeps abreast of studies performed regarding the potential effects of nuclear facilities on the health and safety of the public through the Nuclear Energy Institute. There have been numerous studies performed in the United States, Canada, and Great Britain that found no correlation between nuclear power plants and cancers (see ">http://www.nei.org/keyissues/safetyandsecurity/factsheets/safetystudiespublicwork erspage2/>).

87. Can TVA ensure that nuclear power is safe given the potential effects on the environment and the quality of life of current and future generations of residents as a result of the generation of waste products?

Response: The handling, transportation and storage of spent fuel and irradiated waste are highly regulated and are safely managed. The NRC has independently determined that these waste forms can be safely stored until they are eventually disposed of permanently. TVA's plans for storing spent fuel and radwaste that would be generated during the operation of the B&W and AP1000 reactor units are described in FSEIS 3.18.2.

88. Radioactive pollution from nuclear power plants is invisible and a threat to public health.

Response: The FSEIS addresses the radiological effects of normal operation, design-basis accidents, and severe accidents in FSEIS 3.17, 3.19.1, and 3.19.2 respectively. All calculated doses are within the applicable NRC limits. The average annual dose within 50 miles of a nuclear power plant due to normal radioactive effluents is much less than the average annual background radiation dose.

Radiological Waste (RadWaste)

89. Groundwater and surface waters in France are reported to have been impacted by leaks from on- and off-site storage facilities. These events should be studied by TVA.

Response: The radioactive waste leaks from French nuclear facilities came from waste processing plants and not from power plants. As indicated in FSEIS 3.2.1, groundwater quality at BLN has been monitored over the years to obtain background concentration data. During operation, TVA will continue to monitor groundwater and surface waters to ensure that water quality standards are maintained. The radiological environmental monitoring program (REMP) conducted for the BLN site will be designed based on the regulatory guidance from NRC Regulatory Guide 4.1 and NUREG 1301/1302.

A-114

90. TVA nuclear power plants do not have a facility licensed to accept Class B, C, or greater-than-C radioactive waste.

Response: Congress enacted the Low-Level Radioactive Waste Policy Amendments Act (LLRWPAA) of 1985 to ensure that disposal capacity would be available for all types of LLRW generated by Atomic Energy Act (AEA) licensees. Although no facility licensed for the off-site disposal of all classes of LLRW is currently available to TVA, off-site long term storage options are in the process of being developed.

A Bellefonte unit is not scheduled to load fuel and begin operation for several years and will not be generating Class B and C waste until after initial operation. By that time, it is expected that a Class B and C disposal facility or a means of processing such waste in a manner that allows disposal in an existing facility will be available. Shipping waste at the earliest practicable time minimizes the need for waste reprocessing caused by potential changes in a disposal facility's requirements, reduces occupational and nonoccupational exposures from handling and maximizes the amount of onsite storage space available for use.

Seismology

91. The Bellefonte site is located about one mile from the Sequatchie Fault Line, implying an increased probability that it may experience earth tremors or possibly earthquakes. The site is also over Karst terrain which is a geological term for unstable Limestone formations characterized by fractured and shifting rock, sink-holes, ravines, and underground streams. Putting a nuclear reactor at such an unstable site might ultimately result in core meltdown.

Response: FSEIS 3.15 addresses Seismology. In additon, geology, seismology, and geotechnical information is provided in the COLA FSAR Section 2.5.

There is no new information to suggest that the thrust faults (including the Sequatchie Valley Fault) within the Appalachian foreland thrust belt are capable tectonic structures as defined by NRC Regulatory Guide 1.208 (Appendix A). Seismicity in the region occurs primarily within basement rocks below the regional detachment and first motion analyses indicate predominantly strike-slip focal mechanisms (see discussion in Subsection 2.5.1.1.4.2.4 of the NRC regulatory guide). Evidence for post-Cenozoic faulting or geomorphic evidence for Quaternary deformation in the region is not reported in the published literature.

Investigations at the BLN site by TVA have not identified large-scale karst features (Reference 201). No natural sinkholes have been identified and no enterable caves have been located. Thick, pure limestones like the Tuscumbia, Monteagle, and Bangor Limestones that host large caverns elsewhere in Jackson County, do not occur at the site. Nevertheless, the underlying impure limestones of the Stones River Group are found to weather primarily by dissolution, and small-scale karst features are present. Karst features at the BLN site are of a somewhat different character and smaller scale than highly karstified areas of northern Alabama. Factors such as relief, hydraulic gradient, and purity of the limestone beds have combined to produce a more subtle karst terrain.

The relief and hydraulic gradient at the BLN site are not favorable for the development of large cavern systems. In lowland areas like the BLN site, where

limestone units have little relief, are relatively close to groundwater levels, and groundwater has relatively low hydraulic gradients, cave systems that can be entered and explored are not known. A map of the distribution of caves in Jackson County shows hundreds of caves in the adjacent highlands, but none within the Sequatchie Valley (Figure 2.5-303; Reference 413). Cave locations shown immediately east of the site are associated with the northeast-trending escarpment of Sand Mountain, approximately 1.5 miles east of the BLN site where the Mississippian Bangor and Monteagle Limestones crop out beneath the Permian sandstone cap. Thick beds of pure limestones are not present at the BLN site. The limestone underlying the Units 3 and 4 power block construction zone belongs to the Ordovician Stones River Group and consists of beds of relatively pure limestones (30 to 80 percent carbonate). See Subsection 2.5.4.1.2 for detailed lithology and mineralogy. The presence of the impure limestone beds may inhibit development of larger conduits and favor smaller ones

Most of the cavities encountered are small, 0.1 to 0.5 ft. in height, and clustered near the top-of-rock, 62 percent within 10 ft. and 84 percent within 20 ft. of top-of-rock. At the Units 1 and 2 power block location, explored in the 1970s, 32 percent of borings encountered cavities (Table 2.5-225). Most cavities occurred in the upper ten feet of rock, and were removed during excavation. Photographs of the excavation (Figures 2.5-307 and 2.5-308) show competent rock without significant cavities at excavation grade.

Socioeconomics

92. Alternatives B or C would generate positive direct, indirect, and induced economic impacts in the immediate area and in other states in which products or services are procured.

Response: Comment noted. FSEIS 3.13.2.2 includes discussion of the beneficial effects of the construction and operation workforce for both action alternatives.

93. The current energy policy in the Tennessee Valley--in particular a lack of focus on renewable energy generation and energy efficiency programs, and the resultant waste of energy--places the region at a disadvantage in the global competition for economic development.

Response: Comment noted. TVA is committed to increasing its renewable energy and energy efficiency programs.

94. Jackson County is in need of the jobs that would be created by completion or construction and operation of a single nuclear unit at the BLN site. Training programs are being planned to help supply a qualified workforce.

Response: In addition to direct employment at the site, there would be some positive secondary impact on employment due to increased demand for goods and services by workers and their families.

95. TVA could generate a greater number of jobs in the service area by instituting aggressive energy efficiency and renewable energy programs. These labor-intensive programs could result in the creation of a greater number of jobs than would be created by pursuing the development of capital-intensive nuclear power plants.

Response: To meet future power needs, TVA will need a diverse power mix. TVA is committed to decreasing dependence on high carbon-emitting fossil fuel plants by increasing generation from renewable energy sources as well as focusing on energy efficiency and demand response. TVA welcomes the opportunity to help create "green jobs" by encouraging growth of these industries in the Valley. However, the need currently being addressed is for base load power, which is best met by generators which have relatively low operating costs and which are expected to be available and able to operate continuously throughout the day.

96. An analysis should be conducted to identify the potential positive and negative impacts on the city of Hollywood of each of the three Alternatives. The analysis should identify and evaluate the possible domestic and social impacts (including effects on economics and traffic) resulting from plant construction and operation. Such impacts may include economics, traffic, strains on the police and fire departments, and impacts to City infrastructure and its maintenance.

Response: FSEIS 3.13 has been expanded to provide additional information about the potential for socioeconomic impacts to the surrounding community. Although no study specific to Hollywood has been conducted, TVA plans to work with the local governments and/or community representatives during the preconstruction and throughout the construction period to identify specific problems and concerns and to assist the community in alleviating problems. This could also involve identification of positive impacts.

97. The county is prepared for the influx of construction workers and has the infrastructure in place to facilitate construction activities.

Response: Comment noted. As discussed elsewhere, TVA will work with the local communities to help manage issues that arise, such as traffic concerns.

Spent Fuel

98. There is no long-term storage available for the spent fuel that would be produced by the nuclear reactors. It is desirable that a high level waste repository be licensed before the need for an on-site spent fuel storage facility in 2036.

Response: The U.S. Department of Energy (DOE) is responsible for the disposal of all high-level radioactive waste generated from TVA's nuclear reactors, as well as the transportation of radioactive materials to the disposal facility. TVA plans to provide dry cask storage of radioactive materials in an on-site independent spent fuel storage installation (ISFSI) at BLN, in addition to the storage capacity of the spent fuel pool for either a B&W reactor or an AP1000 reactor, until a licensed repository or interim offsite storage option becomes available (10 CFR 51.23). A discussion of spent fuel storage is contained in FSEIS 3.18.2.

Water Quality

99. There will likely be significant negative impacts to the Tennessee River basin.

Response: State and federal pollution control regulations require that all effluent discharges from the plant have an NPDES permit from the Alabama Department of Environmental Management. These permits specify effluent discharge limits and monitoring requirements to ensure the plant has no significant harm on the receiving water body. TVA will operate the plant to comply with these requirements. A modeling assessment of potential impacts to reservoir water quality indicates that the plant will have essentially no effect on overall reservoir temperatures, dissolved oxygen concentrations, or algae biomass (see FSEIS 3.1.2 and 3.1.3).

100. Nuclear power operations degrade the water bodies from which they draw enormous amounts of fresh water.

Response: The impact of nuclear power plant operation on the water body from which they draw water is regulated under the Clean Water Act, including hydrothermal, entrainment and impingement impacts. Potential water quality impacts to Guntersville Reservoir were examined using two models, one to evaluate 'near-field' impacts in the discharge mixing zone of the plant (CORMIX), and one to evaluate 'far-field' impacts throughout the entire Guntersville reservoir (CE-QUAL-W2). These evaluations are summarized in FSEIS 3.1.3. The CORMIX analyses showed that in the most extreme events, the plant will need to curtail operation to maintain the mixing zone temperature within current regulatory limits. TVA operating procedures will include a process to continuously monitor the plant discharge temperature and provide adequate notification to curtail the plant operation in such events. The CE-QUAL-W2 analyses included a two-dimensional representation of the entire Guntersville Reservoir. Two years were simulated with CE-QUAL-W2 to assess the range of potential range of reservoir-wide impacts: 1) 1999 a year representative of typical or near average (annual) river flow, and 2) 2007 the driest year in over 100 years of record in the Tennessee Valley. The results indicated only small to no changes in reservoir water quality. As to the entrainment and impingement impacts, the closed-cycle cooling system is considered the "best technology available" to minimize these adverse environmental impacts.

101. Special attention is needed to minimize the effects of higher water temperatures to the (Tennessee) river.

Response: Both Alternative B (B&W reactor) and Alternative C (AP1000 reactor) utilize a closed loop cooling system, which minimizes impacts of the plant thermal discharge on the receiving waters. TVA is required under the provisions of the Clean Water Act to ensure that the impact of the plant discharge to the Tennessee River does not exceed state standards for water temperature that are specified in the plant NPDES Permit. These standards are summarized in FSEIS 3.1.3.1. To document compliance with these standards, the plant will include real-time instrumentation to measure the temperature of the water exiting the plant into the river, and procedures to implement changes in plant operation should the water temperature begin to approach the level of the temperature standards.

102. Nuclear power plants release radioactive contaminants and hazardous chemicals into surrounding waters resources, contribute to thermal pollution, and impact aquatic life.

Response: See FSEIS 3.17.3 for radiation doses due to liquid effluents including doses to aquatic plants, invertebrates, and fish. All doses are within the applicable NRC limits.

See FSEIS 3.1.4 for identification and discussion of environmental effects of chemical additives required for plant operation. The BLN site NPDES permit establishes criteria to protect Guntersville reservoir water quality for its designated uses as a drinking water source, recreation, and industrial use such as cooling. For each discharge point, the NPDES permit establishes limits for the types and quantities of effluents, monitoring and reporting requirements, and required sampling locations. Therefore, the effects of chemical discharges would be minor. See FSEIS 3.1.3 for information and an analysis of the hydrothermal effects of plant operation. Construction and operation of either a B&W or AP1000 reactor unit would meet all effluent requirements.

103. Based on observations from other nuclear power plants in Tennessee and Alabama, TVA will do an outstanding job of monitoring discharge from a new power plant at the Bellefonte site.

Response: State and federal pollution control regulations require that all effluent discharges from the plant have an NPDES permit. These permits will specify effluent discharge limits and monitoring requirements. TVA will operate the plant to comply with these requirements. TVA may also conduct additional monitoring to assist in regulatory compliance, environmental protection, and efficient plant operation, especially during the initial startup of the plant.

Water Supply

104. Monitoring is necessary at downstream water intakes. Monitoring stations should be established upstream of each of the downstream water intakes; stations should be established on both sides of the river. These monitoring stations should be established in addition to those generally required of a nuclear power plant.

Response: Effluent limits and monitoring requirements for discharges from the plant are established by state and federal regulations. The quality of intake water that is withdrawn by water utilities is routinely monitored by the utility as a necessary step in treating the water. Should any of these monitoring activities indicate a potential water supply concern related to the operation of Bellefonte, additional targeted monitoring may be initiated to address the concern and protect the water supply.

105. Has an analysis been conducted to evaluate the feasibility and potential impacts of water withdrawals during a global warming-induced drought?

Response: The expected BLN withdrawal (makeup) is 35,000 gpm and 24,000 gpm respectively, for the B&W and the AP1000 alternatives. FSEIS 2.7.2 has been revised to clarify these data including the addition of FSEIS Table 2-5, which provides a comparison of plant water use. Also, DSEIS Tables 3-3 and 3-4 have been replaced with a new FSEIS Table 3-3. These withdrawals are approximately 0.2 percent and 0.1 percent, respectively, of the average flow at the BLN site and

approximately 2.5 percent and 1.8 percent, respectively, of the minimum expected drought flow (i.e., the minimum daily average flow of 3000 cfs from Chickamauga Dam). Potential water quality impacts to Guntersville Reservoir were examined using a two-dimensional reservoir model (i.e., CE-QUAL-W2). Two years were simulated to assess the range of potential impacts: 1) 1999 a year representative of typical or near average (annual) river flow, and 2) 2007 the driest year in over 100 years of record in the Tennessee Valley. The results indicated only small to no changes in reservoir water quality. Because plant withdrawals are small relative to average and minimum river flows (and the volume of reservoir water), and because the established minimum flows and reservoir volume are expected to be maintained even during a drought more severe than 2007, results of the modeling analysis are believed to cover reasonably foreseeable drought conditions. The discussion of global warming/climate change has been expanded. See FSEIS 3.16.

106. Has an analysis been conducted to evaluate the feasibility and potential impacts of plant water usage in light of increasing population in the region and increasing residential, commercial, and industrial water consumption?

Response: Projected 2030 water use in the area is shown in FSEIS Table 3-2, including a single BLN unit. TVA examined the potential impacts of these and other projected 2030 water supply withdrawals throughout the Tennessee Valley as part of its 2004 river operations assessment (TVA 2004). The analysis indicated that projected 2030 water supply withdrawals would be protected with the possible need for short-term mitigation measures at several locations during an extreme and prolonged drought.

107. Selection of either Alternative B or C would result in a Bellefonte plant that uses more water than conventional or renewable energy sources and more than is consumed by energy efficiency measures. The plant would be the largest water consumer in the area, and would compete with other important water users in the region. Despite this, water supply issues are not considered significant in the DSEIS.

Response: Typically, nuclear generation requires more water than solar or wind generation, but less water than bio-fuels. Solar and wind generation have other economic and environmental disadvantages. FSEIS 3.1.2 addresses surface water use and trends. FESIS Table 3-2 lists all of the surface water withdrawals in the Guntersville watershed for the years 2005 and 2030. The table shows that a single nuclear reactor at Bellefonte would be the second largest water user in 2030, with the largest being TVA's Widows Creek Fossil Plant which withdraws 1,476 MGD. However, because Bellefonte water withdrawals are small relative to the average and minimum river flows (and the volume of reservoir water), and because the established minimum flows and reservoir volume are expected to be maintained even during severe drought conditions, potential adverse impacts to Guntersville Reservoir and regional water supplies are expected to be insignificant. For example, the expected BLN withdrawal is about 35,000 gpm (with 23,000 gpm being returned to the river) and 24,000 gpm (with 8,000 gpm being returned to the river), respectively, for the B&W and the AP1000 alternatives. These expected BLN withdrawals are approximately 0.2 percent and 0.1 percent, respectively, of the average flow through Guntersville Reservoir and approximately 2.5 percent and 1.8 percent, respectively, of the minimum expected drought flow (i.e., the minimum daily average flow of 3000 cfs from Chickamauga Dam). FSEIS 2.7.2 has been revised to

clarify these data including the addition of Table 2-6, which provides a comparison of plant water use. Also, DSEIS Tables 3-3 and 3-4 have been replaced with a new FSEIS Table 3-3.

108. The DSEIS does not address the cumulative impacts presented by the possibility of having eight nuclear reactors operating in the Tennessee River basin along with other facilities.

Response: Currently there are six nuclear units operating in the Tennessee River Basin. Proposed additional units include one unit at Bellefonte and one additional unit at Watts Bar. Both of these units would have closed cycle cooling systems that involve small hydrothermal discharges relative to the adjacent river flow and reservoir volumes. As explained in the FSEIS 3.1.3.1, the hydrothermal analysis encompasses worst-case conditions based on potential ranges for river flow, river temperature, meteorology, and plant operations, using more than 30 years of historical data. The range of river flow was based on historical hydrology and the expected future operating policy of the TVA river system. As indicated in the FSEIS 3.1.3.2, Environmental Consequences, the CE-QUAL-W2 model assessed potential cumulative effects on Guntersville Reservoir and concluded that far-field effects would not be significant. Given these findings and with design and operation in compliance with regulatory requirements, single nuclear unit operations at Bellefonte are not expected to have adverse cumulative impacts on surface waters.

109. The FSEIS should present data on the volume of water consumed and evaporated at each of TVA's currently operating nuclear reactors and coal fired power plants.

Response: Total water withdrawal from TVA nuclear and coal-fired power plants in 2005 was approximately 15,539 MGD. Return flow totaled approximately 15,463 MGD resulting in a consumptive use of 76 MGD. In contrast, the average annual flow in the Tennessee River out of Chickamauga Dam is about 20,680 MGD. Information on individual plants in the Tennessee Valley can be found in the following FSEIS reference.

Bohac, C. E. and M.J. McCall. 2008. *Water Use in the Tennessee Valley for 2005 and Projected Use in 2030*. Retrieved from <<u>http://www.tva.gov/river/watersupply/watersupply/watersupply/report_to_2030.pdf</u>>

Wetlands

110. TVA should avoid impacts to the wetlands located at the AP1000 site.

Response: This wetland complex would be impacted (filled) if the AP 1000 alternative is selected. FSEIS 3.4.2 documents this impact. TVA took this environmental impact into consideration in selecting the B&W reactor as its preferred alternative. Should TVA decide to build the AP1000 reactor, the loss of wetland functions would be compensated for via wetland mitigation (purchase of wetland credits from a wetland mitigation bank within the watershed).

Name Business or Organization	Associated Comment Statement Numbers
Akridge, Charles	21
Bailey, Ron	78, 79
Barczak, Sarah Southern Alliance for Clean Energy	12, 13, 14, 18, 28, 29, 31, 34, 43, 44, 46, 50, 63, 64, 76, 81, 82, 102, 105, 107, 108
Bradley, Heather	87
Bundy, Laura	15, 18, 36, 37, 44, 70, 98
Bynum, Faye & Wayne	21, 94
Cannon, Henry	21
Cummins, Wayne Sand Mountain Concerned Citizens	20, 103, 104
DePinto, Frank	27, 41, 105, 106
Dutton, Phil Hollywood City Council	16
Gay, John	21, 22
Gibson, Tom Valley Radiology	21
Gorenflo, Louise Sierra Club-Tennessee Chapter	4, 6, 11, 12, 18, 24, 37, 44, 46, 47, 51, 68, 69, 70, 93, 95
Guthrie, James	21
Horn, Stewart	9, 11, 12, 18, 23, 30, 35, 37, 42, 44, 47, 55, 68, 69, 70, 74, 75, 86, 89, 91, 93, 95, 98, 107, 109, 110
Johnson, Norman	21, 40
Jones, Charles	19, 83, 101
Kennamer, Donald	19, 21, 94
Lamberts, Frances	18, 23, 37, 44, 80, 85, 88, 100
Livingston, Jack	21
Martin, Harley	21
McCluney, Ross	12, 18, 35, 49, 57, 58, 80, 84
Morgan, Garry BEST/BREDL/SCE/AEC	3, 9, 8,10, 11, 12, 18, 24, 31, 41, 43, 47, 56, 65, 66, 99
Reed, Elijah	17, 26
Rogers, Goodrich Jackson County Economic Development Authority	21, 72, 94, 97
Safer, Don Tennessee Environmental Council	18, 25, 37, 44, 47
Sandin, James Scottsboro Electric Power Board	7, 19, 38, 39, 67
Schaum, Fred L 'Pete' Alabama Development Office	32, 40, 45, 92
Stiles, William	2, 21
Trenkle, David	21, 52

List of Individual Commenters and Associated Comment Statement Numbers

Name Business or Organization	Associated Comment Statement Numbers
Warr, Richard Hollywood City Council	96
Wilkinson, Duncan	19
Woodall, John	21, 71, 94
York, George	21, 92, 94
Zeller, Louis A Blue Ridge Environmental Defense League	1, 5, 18, 23, 25, 33, 36, 47, 48, 53, 54, 59, 60, 61, 62, 73, 77, 88, 90, 98, 102, 107

Page intentionally blank

)

APPENDIX D – SENSITIVE AREA REVIEW PROCESS

Ì

Page intentionally blank

Sensitive Area Review (SAR) Process

This attachment briefly summarizes the environmental compliance review process TVA uses for maintenance and modifications of transmission lines and presents the results of this process, by subject matter area.

Overview of Environmental Compliance Process for Transmission Line Maintenance and Modifications

The TVA Transmission and Power Supply – Transmission Operations and Maintenance (TPS-TOM) organization routinely conducts maintenance activities on transmission lines in the TVA system (TVA Power Service Area). These activities include, but are not restricted to, right-of-way reclearing (removal of vegetation), pole replacements, installation of lightning arrestors and counterpoise, and upgrading of existing equipment. Regular maintenance activities are conducted on a cycle of 3-5 years.

Prior to these activities, the transmission line area (including the right-of-way) is reviewed by technical specialists in the TVA Regional Natural Heritage Project, and TVA Cultural Resources group, to identify any resource issues that may occur along that transmission line. These reviews are conducted on a recurring basis that coincides with the maintenance cycle, to ensure that the most current information is provided to the organizations conducting maintenance on these transmission lines.

The TVA Regional Natural Heritage Project maintains a database of some 30,000+ occurrence records for protected plants, animals, caves, heronries, eagle nests, and natural areas for the entire TVA Power Service Area, including all 201 counties. All records that are present, or are potentially present, in transmission line right-of-ways are taken into consideration when conducting these transmission line reviews. Wetland information is maintained by TVA Resource Services and includes NWI wetland maps for the entire TVA Power Service Area. Soil survey maps are also used to identify potential wetland areas. The TVA Cultural Resources group maintains records of known archaeological sites, and routinely gathers information from the seven-state TVA Power Service Area.

Also included in this document is the explanation of Sensitive Area Review (SAR) Class Definitions and associated table of mapping polygon colors, and the restrictions indicated by those designations.

(Managed Areas) - Managed Areas, Ecologically Significant Sites, and National Rivers Inventory for Maintenance Activities in TVA Transmission Line Rights-of-Way

Managed Areas (MA) are lands held in public ownership that are managed to protect and maintain certain ecological features. Ecologically Significant Sites (ESS) are tracts

of privately owned land that are identified by resource biologists as containing significant environmental resources. National River Inventory (NRI) streams are free-flowing river segments that are recognized by the National Park Service as possessing remarkable natural or cultural values. The TVA Natural Heritage Project maintains a database of all such lands and streams occurring within the seven state TVA power service area.

Sensitive area reviews for MA's, ESS's, and NRI streams are completed by utilizing computerized mapping graphics software known as ArcMap. If a MA, ESS, and/or NRI stream is located within the 0.5-mile buffer of the subject transmission line, a polygon is drawn that represents the area's boundaries within the buffer. A description of the area that includes contact information, restrictions, and the subject transmission line name is listed in the corresponding attribute table.

Right-of-way (ROW) maintenance and/or clearing and pole replacement activities are the two areas that are reviewed for the presence of sensitive resources in SARs. If all or any portion of a MA, ESS, and/or NRI stream lies within the buffer of the subject transmission line, a polygon is drawn depicting the boundary of such areas. Restrictions on proposed activities (Class 0, 1 2, or 3 below) are determined by the type and location of the MA, ESS, and/or NRI streams as well as consultation with the area manager or resource specialist. The class and contact restrictions, definitions, and polygon color for both activities are listed in the included table.

After determining the particular class restriction associated with the area, special instructions or comments are added to indicate the importance of the restriction and why it was assigned. For example, when a portion of a national forest is within the 0.5-mile buffer or crossed by the subject transmission line, a Class 3 restriction is assigned and a comment is added indicating the area manager must be contacted and herbicide use is restricted.

Under Categorical Exclusions, transmission line projects such as lightning mitigation, counterpoise activities, conveyances, line relocations for state highway department work, and providing delivery points and switches for substations are reviewed for potential impacts to MA's, ESS's, and NRI streams. A three mile radius of the project site(s) is reviewed for MA's, ESS's, and NRI streams that might be affected by the proposed activity.

(Botany) - State and Federal listed plant restrictions for Maintenance Activities in TVA Transmission Line Rights-of-Way

Botanical assessments are completed for Sensitive Area Reviews (SARs) in order to identify state and federally listed plants that occur within a five mile radius of the transmission line. Identifying the occurrences gives us the ability to identify habitats within a proposed project area that are sensitive and potentially require restrictions from activities. To identify rare plant and sensitive habitat locations we utilize the TVA Natural Heritage database, aerial photographs and USGS topographical maps.

Transmission line SAR activities include right-of-way (ROW) maintenance/reclearing and pole replacements. The review process for the two activities is different since they potentially impact vegetation in different ways. ROW maintenance consists of vegetation clearing with herbicides unless otherwise specified. Herbicides kill all vegetation that is sprayed. Mechanical clearing has less of an impact since many plants can tolerate being cut. Pole replacements potentially impact vegetation when vehicles and equipment drive on and in the vicinity of the ROW and the soil and the vegetation are disturbed. If there are sensitive plants in the vicinity we recommend different access routes to be taken and we notify individuals of sensitive areas to avoid. Restrictions are determined by our knowledge of the habitat requirements for rare plants and rare plant communities that occur within the vicinity of the ROW. Once a sensitive area is located a polygon designating the known or likely extent of that occurrence is drawn on an ArcMap electronic topographic map, and appropriate class restrictions are applied (see table of Class Definitions and Associated Polygon Colors of Sensitive Areas).

(Terrestrial Animals) - State and Federal Protected Terrestrial Animal restrictions for Sensitive Area Reviews (SARs) conducted in support of Maintenance Activities in TVA Transmission Line Rights-of-Way

The TVA Regional Natural Heritage Program keeps track of state and federal protected species reported from the seven-state region. The terrestrial animal portion of the data base includes all listed birds (breeding and large wintering aggregations), mammals, reptiles, and amphibians. In addition to specific species of animals, the terrestrial portion of the database also includes records of heronries and caves as they often are used by multiple species.

Each SAR project is reviewed for the presence of protected terrestrial animals. A 1-mile radius of the project site(s) is typically reviewed for each proposed activity along transmission lines. Once an occurrence is located a polygon designating the known or likely extent of that occurrence is drawn on an ArcMap electronic topographic map (see included maps), and appropriate class restrictions are applied (see included table of Class Definitions and Associated Polygon Colors of Sensitive Areas). Special comments or instructions accompany each entry as appropriate. For instance, if a cave is located along a powerline corridor schedule for vegetative maintenance, a 200-foot buffer is indicated around the opening of the cave and a "Hand Clearing Only" restriction is applied within the buffer. If the cave is used by a summer or hibernating colony of bats, appropriate time restrictions, as designated in specific recovery plans for each species, are also applied.

(Aquatic Animals) - State and Federal Protected Aquatic Animal restrictions for Maintenance Activities in TVA Transmission Line Rights-of-Way

The TVA Regional Natural Heritage Program keeps track of state and federal protected species reported from the seven-state region. Aquatic animal occurrence records are maintained and updated by TVA Heritage staff on a regular basis.

Each SAR project is reviewed for the known or likely occurrence of protected aquatic animals in streams in or adjacent to the transmission line right-of-way. A 10 mile buffer around the transmission line being reviewed is examined to determine the likely occurrence of protected aquatic animals. Once an occurrence is located, appropriate class restrictions are applied and the appropriate colored polygon is drawn around the resource area on an ArcMap electronic topographic map (see included maps and table of Class Definitions and Associated Polygon Colors of Sensitive Areas). All transmission line maintenance activities are currently conducted using Best Management Practices as outlined in Muncy (1999). Special comments or instructions (including designation of specific Streamside Management Zones) accompany each entry as appropriate.

(Wetlands) - Wetlands Review for Maintenance Activities in TVA Transmission Line Rights-of-Way

Prior to the performance of any maintenance activities in TVA transmission line ROWs, office-level reviews are conducted by Natural Heritage wetland biologists. This review includes review of the National Wetland Inventory (NWI) map, county soil surveys, and TVA photos of transmission line structures. Potential wetland areas, not indicated on the NWI map, are identified based on interpretation of topographic features, water bodies, soils information, TVA photos and proximity to NWI features. All NWI wetlands or potential wetland areas are superimposed as layers on an ArcMap electronic topographic map (see included maps). These ArcMap images are sent to the client accompanied by the Wetlands ROW and Pole Replacement Guidelines and an Excel spread sheet which lists areas that have been included with the NWI data as areas of potential wetlands and what guidelines are to be used.

The NWI wetlands are indicated (in dark blue outline) on the ArcMap drawings for both the ROW and a 1-mile diameter buffer area around the ROW. Potential wetland areas are identified (in dark pink outline) in the ROW, but are not identified in the buffer area, parts of which may be used for ROW access. If the access route follows an existing road that does not require any repair or upgrading, no further wetland reviews are needed. Repair and upgrading includes, but is not limited to grading, fill addition, new or upgraded stream crossings, and vegetation removal. If a new or upgraded access route is necessary, environmental reviews of those particular access areas are conducted as required by the National Environmental Policy Act (NEPA).

The National Wetland Inventory (NWI) data was compiled using high-altitude aerial photography, some of which is now over 15 years old, with very limited field verification.

Because of this, some of the NWI data may be inaccurate. The limitations of the NWI data are considered in the performance of ROW maintenance and pole replacement to avoid accidental wetland impacts. Since there could be wetlands present for which no map evidence or other data currently exists, maintenance crews remain alert to such things as water on the surface of the ground, soil saturation, the type of vegetation growing in an area, and evidence of present, seasonal or temporary flooding.

In the absence of a ground survey by a wetlands specialist to determine wetland presence and location for ROW reclearing or pole replacements, Best Management Practices, as described in Muncy (1999), and TPS Environmental Quality Specifications for ROW Construction and Maintenance are implemented to avoid and minimize potential impacts (see attached Wetlands Guidelines for ROW and Pole Replacement). These techniques would be implemented in all locations where NWI wetlands and potential wetland areas are indicated on the project maps submitted by the TVA Natural Heritage staff.

Site-specific recommendations for ROW reclearing include the following:

- Depending on site conditions, Level B tree-cutting guidelines, or methods CM-2, CM-3, CM-4, or CM-5 may be used for tree clearing (Muncy 1999). These methods specify techniques for tree clearing and removal that are selected based on wetland hydrology and condition in order to avoid and minimize wetland impacts.
- According to method CM-6 (Muncy 1999), if the wetland is a scrub-shrub, emergent, or grazed wetland, there should be no equipment entry, and minimal intrusion by all mechanized equipment.
- For aerial or ground herbicide application, use is restricted to those herbicides that are EPA-approved for use in aquatic areas.
- If possible, mechanical clearing should be conducted when the ground is dry or minimally saturated. Ruts should be minimized to avoid altered hydrologic patterns, soil compaction, and disruptions in vegetation regeneration.

Specific recommendations for pole replacement activities include the following:

- Entry of vehicles or heavy equipment in wetlands should be avoided when possible.
- If entry is unavoidable, appropriate measures such as mats and lowground pressure equipment should be used.
- Impacts to vegetation should be avoided or minimized.

In addition, certain activities that may occur during pole replacement in wetlands are regulated under Sections 404 and 401 of the Clean Water Act. U.S. Army Corps of

Final Supplemental Environmental Impact Statement

A-131

Engineers (USACE) Nationwide General Permit (NWP) #12 authorizes certain activities related to utility line construction and contains conditions to ensure that impacts to wetlands are minimal. Section 401 gives states the authority to certify whether activities permitted under Section 404 are in accordance with state water quality standards (Strand, 1997). A qualified TVA or TVA contract wetlands specialist would be required to delineate the wetland(s) and provide the wetland determination data forms which are required for inclusion in the permit application. TVA also follows Executive Order 11990 which requires all federal agencies to minimize the destruction, loss, or degradation of wetlands, and to preserve and enhance the natural and beneficial values of wetlands, in carrying out the agency's responsibilities.

Potential impacts to wetlands resulting from right-of-way maintenance activities include vegetation damage, soil compaction and erosion, sedimentation, and hydrologic alterations. These impacts are avoided or minimized during TVA maintenance operations by following the recommendations of the guidelines presented above and implementing all relevant Best Management Practices. In addition, the appropriate permits are obtained if required for the specific activity.

(Cultural) - Cultural Resource Reviews Related to Operations and Maintenance Activities in TVA Transmission Line Rights-of-Way

Regulatory Background

The National Historic Preservation Act of 1979 (NHPA) made historic preservation a statutory and regulatory responsibility of federal government agencies and established procedures to be followed for historic preservation. Generally speaking, any TVA action involving construction and/or ground disturbing activity is subject to NHPA. The concepts "historic property" and "undertaking" are critical underpinnings of the Act. The NHPA defines historic property as "any prehistoric or historic district, site, building, structure, or object included in, or eligible for inclusion in, the National Register of Historic Places." The Secretary of the Interior is the Keeper of the National Register of Historic Places ("the National Register"), which is maintained by the National Park Service. Much of the regulatory language of the Act describes the processes by which districts, sites, buildings, or structures are assessed for listing in the National Register. An undertaking is "a project, activity, or program funded in whole or in part under the direst or indirect jurisdiction of a Federal Agency."

Section 106 of the NHPA requires TVA to 1) consider the effect of its actions on historic properties and 2) allow the Advisory Council on Historic Preservation an opportunity to comment on the action. Section 106 involves four steps: 1) initiate the process; 2) identify historic properties; 3) assess adverse effects; and 4) resolve adverse effects. One of the main responsibilities of TVA Cultural Resources is to carry out these four steps. The process involves documentary research and field reconnaissance for identifying cultural resources (such as artifacts, sites, or historic structures); determining whether any identified cultural resources are eligible for listing on the National Register, and therefore should be considered "historic properties"; assessing whether a proposed

undertaking will cause adverse affects to any historic properties; and recommending ways to resolve adverse effects, namely avoidance or mitigation. This process is carried out in consultation with the State Historic Preservation Officer of the state in which the undertaking takes place and with any other interested consulting parties including federally recognized Indian tribes.

The construction, maintenance, and operation of TVA transmission lines all constitute undertakings and as such are subject to the NHPA and its implementing regulations at 36CFR800. Examples of maintenance activities associated with transmission lines are spraying herbicides and replacing individual poles. Such activities are reviewed by TVA Cultural Resources staff on a case-by-case basis using the Sensitive Area Review (SAR) procedure. The purpose of an SAR Cultural Resources review is to identify whether the undertaking has any potential for adverse effects on cultural resources such as historic structures or buried prehistoric sites. If the undertaking does have potential for adverse effects, then procedures for avoidance or mitigation of the effects are put into place.

How TVA Cultural Resources Conducts SARs for Transmission Operations and Maintenance Projects

TVA Cultural Resources staff examine topographic maps of the project site for (a) previously recorded archaeological sites in the vicinity of the transmission line corridor; and (b) conditions that suggest high potential for archaeological sites including low slope (< 10%), proximity to major water sources, and lack of modern disturbance. ArcView GIS is used to identify areas with potential for cultural resources. The decision to do a field review is based on such information along with any information the staff can glean from videos of the transmission line corridors and from still photographs of the project site.

Field reviews are conducted by Cultural Resources staff or by consulting archaeologists, who look for signs of intact, buried prehistoric deposits using surface survey and sub-surface probes (when appropriate). The project is cleared if no artifacts or features identified and if the project site appears to have a low potential for cultural resources. If intact buried deposits containing cultural resources are discovered, an attempt is made to discern whether the site may be potentially eligible for the National Register. A formal assessment of eligibility would not be undertaken during a field review, however. If the site may be eligible, then a Phase I investigation is called for. A Phase I might also be called for there is a high potential for intact buried deposits, even if no artifacts or features were identified during field review. The purposes of a Phase I investigation are to delimit the boundaries of a site, gather additional information relating to the site's eligibility (such as integrity), and assess possible effects to the site from the undertaking.

Avoidance is generally feasible for transmission line maintenance projects when cultural resources are present. ArcView GIS is used to generate a map showing polygons

around those cultural resources, representing sensitive areas. Areas that are sensitive from the standpoint of cultural resources are coded Level 2, which indicates restrictions on methods of clearing (no mechanized equipment). These maps are provided to TPS prior to any maintenance activities on the line, so that crew supervisors will be aware of the necessary restrictions. Restrictions are typically called for when a previously recorded cemetery, prehistoric mound, or earthwork occurs within 0.25 miles of the transmission line.

Class Definitions and Associated Polygon Colors of Sensitive Areas for RIGHT-OF-WAY RECLEARING Sensitive Area Reviews

· · ·	Terrestrial Plants (A), Terrestrial A	nimals (D), and Aquatic Animals (E)	
Class	Restriction if Sensitive area in ROW	Restriction for Sensitive Areas Potentially Affected when <u>Accessing</u> ROW	Polygon Color
1	No broadcast spraying. Use one of the three following alternatives: 1) Hand or mechanical clearing, 2) Request field surveys by TVA Heritage staff to determine if suitable habitat for these species exists in the subject area, 3) Selective spraying of herbicides to shrubs or tree saplings less than 12 feet in height.	Not Applicable	Yellow
2	Hand-clearing only. Vehicles and equipment restricted from area unless confined to existing access road. Special circumstance. Must contact Heritage Botanist prior to entering or conducting maintenance in subject area.	Vehicles and equipment restricted from area unless confined to existing access road.	Red
0	Special circumstance. Terrestrial Animals - Indiana Bat Summer Root between November 15 and March 31. If cutting restriction, a bat mist-net survey is necessary.		Green
	Wetlar	ìd\$* (€)	
-	Wetlands obtained from National Wetland Inve Pole Replacement Guidelines" for restrictions.	ntory data. Refer to "Wetlands ROW and	Blue Outline
1	Potential wetlands identified by Natural Heritag interpretation of topographic features, water bo features. Refer to "Wetlands ROW and Pole Re	dies, soil surveys and proximity to NWI	Pink Outline

		Natural :	Areâs (B)						
Class	Call**	De	finition.	Color					
1	No	Same as Class 1 definition above.		Yellow					
2	No	Same as Class 2 definition above.		Red					
1	Yes	Same as Class 1 definition above, and entering or conducting maintenance is	I must contact area manager prior to n subject area	Yellow hatching					
2	Yes	Same as Class 2 definition above, and entering or conducting maintenance in	I must contact area manager prior to n subject area.	Red hatching					
3	Yes	Must contact area manager prior to subject area.	Neon Green						
0		Special circumstance.		Green					
		Airchaec	llogy (F)						
Clášš 2	Rest	riction if Sensitive area in ROW.	Restriction for Sensitive Areas Rotentially Affected when <u>Accessing</u> ROW	Color					
1	Mechanical clearing must be conducted when the ground is dry and firm. If bulldozer is used, blade must be kept above ground surface to avoid ground disturbance. Material from clearing (timber, brush, and large debris) must be removed from sensitive area.								
2	(chainsay equipme hand-car	anical clearing. Hand-clearing only ws may be used but not heavy nt). Debris from clearing must be ried out of sensitive area. Vetlands Statement included in this pac	All vehicles must be low-pressured tire equipment and must be confined to existing access road.	Red					

* Refer to Wetlands Statement included in this package.

** The "Call" column on the accompanying datasheets is used by Natural Area specialists only. A blank in the column indicates no call is necessary.

Class Definitions and Associated Polygon Colors of Sensitive Areas for POLE REPLACEMENT Sensitive Area Reviews

All	Resources Areas (Plants, Natural Areas, Wetlands, Terrestrial Animals, and Aquatic	Animals)
Class	Restriction	Color
	 Botany: Sensitive Botanical resources are known from the area. Details of proposed activities should be submitted to TVA Heritage staff to determine if the proposed activities require restrictions. Natural Areas: Refer to table accompanying project for restrictions. Wetlands: Potential wetlands identified by Natural Heritage wetland biologists based on interpretation of topographic features, water bodies, soil surveys and proximity to NWI features. Refer to "Wetlands ROW and Pole Replacement Guidelines" for restrictions. Terrestrial Animals: Refer to table accompanying project for restrictions. 	Pink
	Wetlands	
-	Wetlands obtained from National Wetland Inventory data. Refer to "Wetlands ROW and Pole Replacement Guidelines" for restrictions.	Blue Outline
	Archaeology	Color
Class	Restriction	
1	Presence of significant below-ground cultural resources is highly likely. Work must be scheduled when ground is dry and firm. Only vehicles with low-pressured tires may be used within sensitive area. If structure is a pole, new poles must be placed in existing holes; if structure is a tower, existing footings must be used for new tower. If guy wires are used, existing guy wire anchors must be used for new structure. If any of these conditions can not be met, then details of proposed activities (nature of work, date work is to take place) must be submitted to TVA Cultural Resources staff so that a field review can be scheduled.	Yellow
2	Presence of significant cultural resources is known. Work schedule must be submitted to TVA Cultural Resources staff so that a field review can be scheduled.	Red

Page intentionally blank

.

APPENDIX E – CORMIX MODELING RESULTS

Page intentionally blank

	IDIE E-1. Summary of CORMIX Model Results												
x 6			Ambient Rive	r Conditions	Blowdown	Conditions	Conditions at Edge of Mixing Zone						
Plant	Case	Month	Flow	Temp	Discharge	Temp	Temp	Temp Rise	Plume Width	Plume Thickness			
			(cfs)	(°F)	(cfs)	(°F)	(°F)	(°F)	(feet)	(feet)			
36-inch Diameter, 45-foot Long Diffuser Pipe													
B&W	1	March	3130	41.0	50	86.4	43.2	2.2	246	8			
B&W	2	April	190	52.0	50	90.4	53.9	1.9	249	8			
B&W	3	July	3760	89.5	50	97.7	89.9	0.4	193	10			
B&W	4	March	-9160 ¹	41.0	50	86.4	44.4	3.4	343	9			
AP 1000	1	March	3130	41.0	18	86.4	43.1	2.1	444	4			
AP 1000	2	April	190	52.0	18	90.4	53.9	1.9	424	5			
AP 1000	3	July	3760	89.5	18	97.7	89.9	0.4	337	5			
AP 1000	4	March	-9160 ¹	41.0	18	86.4	42.4	1.4	348	7.			
			42-ind	ch Diameter, 7	5-foot Long D	iffuser Pipe	1						
B&W	1	March	3130	41.0	50	86.4	43.6	2.6	368	6			
B&W	2	April	190	52.0	50	90.4	54.3	2.3	356	7			
B&W	3	July	3760	89.5	50	97.7	90.0	0.5	286	8			
B&W	4	March	-9160 ¹	41.0	50	86.4	43.3	2.3	442	10			
AP 1000	1	March	3130	41.0	18	86.4	43.5	2.5	758	3			
AP 1000	2	April	190	52.0	18	90.4	54.3	2.3	625	.4			
AP 1000	3	July	3760	89.5	18	97.7	89.8	0.3	632	7			
AP 1000	4	March	-9160 ¹	41.0	18	86.4	42.0	1.0	375	10			

Table E-1. Summary of CORMIX Model Results

Notes: ¹Reverse river flow with diffuser ports pointing vertically upward

cfs = cubic feet per second °F = degrees fahrenheit

Appendix E

Parameter (Units)	•	am of Widov Intake RM 409.5 - 4			Upstream of Bellefonte Intake TRM 393.0 - 393.9			nstream of Be Discharge FRM 389.0 - 3	•	Guntersville Forebay TRM 349.8 - 350.5			
Temperature (°F) ²	Max. Day ³	April-Sept. Mean⁴	July-Aug. Mean⁴	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	
Reference	85.4	76.6	83.0	86.5	77.0	83.4	86.5	77.1	83.5	89.4	77.9	85.3	
Base	85.4	76.6	83.0	87.9	78.5	84.4	87.6	78.5	84.5	89.5	78.1	85.6	
B&W	85.4	76.6	83.0	88.0	78.5	84.4	87.6	78.5	84.5	89.6	78.1	85.6	
AP 1000	85.4	76.6	83.0	88.0	78.5	· 84.4	87.6	78.5	84.5	89.6	78.1	85.6	
Dissolved Oxygen (mg/L) ²	Min. Day⁵	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	
Reference	5.3	6.8	6.0	5.2	6.7	5.9	5.2	6.7	5.9	6.5	8.8	8.2	
Base	5.3	6.8	6.0	5.2	6.6	5.9	5.2	6.6	5.9	6.5	8.8	8.0	
B&W	5.3	6.8	6.0	5.2	6.6	5.9	5.2	6.6	5.9	6.5	8.8	8.0	
AP 1000	5.3	6.8	6.0	5.2	6.6	5.9	5.2	6.6	5.9	6.4	8.8	8.0	
Algae Biomass (mg/L) ²	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	
Reference	0.1	0.0	0.0	0.6	0.1	0.1	0.6	0.1	0.1	3.5	2.2	2.1	
Base	0.1	0.0	0.0	0.6	0.1	0.1	0.5	0.1	0.1	3.6	2.1	2.0	
B&W	0.1	0.0	0.0	0.6	0.1	0.1	0.5	0.1	0.1	3.6	2.1	2.0	
AP 1000	0.1	0.0	0.0	0.6	0.1	0.1	0.5	0.1	0.1	3.6	2.1	2.0	

Table E-2.	Summary of 1999 Guntersville Reservoir Model Results ¹

²All values are based on model results at the 5-foot depth

³Max day is the maximum daily value for the entire year

⁴Mean is the average of the 6-hour model outputs over the designated time period

 $^5\ensuremath{\mathsf{Min.}}$ day is the minimum daily value for the entire year

Parameter (Units)	Upstream of Widow's Creek Intake TRM 409.5 - 410.7			Upstream of Bellefonte Intake TRM 393.0 - 393.9				nstream of Be Discharge FRM 389.0 - 3		Guntersville Forebay TRM 349.8 - 350.5			
Temperature (°C) ²	Max. Day ³	April-Sept. Mean ⁴	July-Aug. Mean ⁴	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Dāy	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	
Reference	86.5	77.0	83.8	86.9	77.4	84.2	87.2	77.5	84.4	88.5	78.4	85.5	
Base	86.5	77.0	83.8	88.4	79.0	85.6	88.3	79.0	85.7	88.6	78.5	85.7	
B&W	86.5	77.0	83.8	88.4	79.0	85.6	88.3	79.1	85.7	88.7	78.5	85.7	
AP 1000	86.5	77.0	83.8	88.4	79.0	85.6	88.3	79.0	85.7	88.7	78.5	85.7	
Dissolved Oxygen (mg/L) ²	Min. Day⁵	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	
Reference	5.2	6.6	5.8	5.1	6.4	5.6	5.0	6.5	5.6	7.1	8.9	8.5	
Base	5.2	6.6	5.8	5.1	6.4	5.6	5.0	6.4	5.5	6.9	8.9	8.5	
B&W	5.2	6.6	5.8	5.1	6.4	5.6	5.0	6.4	5.5	6.9	8.9	8.5	
AP 1000	5.2	6.6	5.8	5.1	6.4	5.6	5.0	6.4	5.5	6.9	8.9	8.5	
Algae Biomass (mg/L) ²	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	
Reference	0.1	0.0	0.0	0.4	0.2	0.1	0.5	0.2	0.2	3.8	2.8	3.1	
Base	0.1	0.0	0.0	0.3	0.1	0.1	0.4	0.2	0.2	3.9	2.9	3.1	
B&W	0.1	0.0	0.0	0.3	0.1	0.1	0.4	0.2	0.2	3.9	2.9	3.1	
AP 1000	0.1	0.0	0.0	0.3	0.1	0.1	0.4	0.2	0.2	3.9	2.9	3.1	

Table E-3. Summary of 2007 Guntersville Reservoir Model Results¹

¹All values in table are from model simulation results and are based on the 6-hour model output for the parameter indicated.

²All values are based on model results at the 5-foot depth

³Max day is the maximum daily value for the period April through September

⁴Mean is the average of the 6-hour model outputs over the designated time period

⁵Min. day is the minimum daily value for the period April through September

Appendix E

Parameter (Units)	-	am of Widov Intake RM 409.5 - 4			um of Bellefo RM 393.0 - 3			nstream of Be Discharge IRM 389.0 - 3)	Guntersville Forebay TRM 349.8 - 350.5			
Temperature (°F) ²	Max. Day ³	April-Sept. Mean ⁴	July-Aug. Mean ⁴	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	
Reference	85.4	76.6	83.0	86.5	77.0	83.4	86.5	77.1	83.5	89.4	77.9	85.3	
Base	85.4	76.6	83.0	87.9	78.5	84.4	87.6	78.5	84.5	89.5	78.1	85.6	
B&W	85.4	76.6	83.0	88.0	78.5	84.4	87.6	78.5	84.5	89.6	78.1	85.6	
AP 1000	85.4	76.6	83.0	. 88.0	78.5	84.4	87.6	78.5	84.5	89.6	78.1	85.6	
Dissolved Oxygen (mg/L) ²	Min. Day⁵	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	
Reference	5.3	6.8	6.0	5.2	6.7	5.9	5.2	6.7	5.9	6.5	8.8	8.2	
Base	5.3	6.8	6.0	5.2	6.6	5.9	5.2	6.6	5.9	6.5	8.8	8.0	
B&W	5.3	6.8	6.0	5.2	6.6	5.9	·5.2	6.6	5.9	6.5	8.8	8.0	
AP 1000	5.3	6.8	6.0	5.2	6.6	5.9	5.2	6.6	5.9	6.4	8.8	8.0	
Algae Biomass (mg/L) ²	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	
Reference	0.1	0.0	0.0	0.6	0.1	0.1	0.6	0.1	0.1	3.5	2.2	2.1	
Base	0.1	0.0	0.0	0.6	0.1	0.1	0.5	0.1	0.1	3.6	2.1	2.0	
B&W	0.1	0.0	0.0	0.6	0.1	0.1	0.5	0.1	0.1	3.6	2.1	2.0	
AP 1000	0.1	0.0	0.0	0.6	0.1	0.1	0.5	0.1	0.1	3.6	2.1	2.0	

¹All values in table are from model simulation results and are based on the 6-hour model output for the parameter indicated.

²All values are based on model results at the 5-foot depth

³Max day is the maximum daily value for the entire year

⁴Mean is the average of the 6-hour model outputs over the designated time period

⁵Min. day is the minimum daily value for the entire year

Parameter (Units)	Upstream of Widow's Creek Intake TRM 409.5 - 410.7			Upstream of Bellefonte Intake TRM 393.0 - 393.9			_	nstream of Be Discharge FRM 389.0 - 3	•	Guntersville Forebay TRM 349.8 - 350.5			
Temperature (°F) ²	Max. Day ³	April-Sept. Mean ⁴	July-Aug. Mean ⁴	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	July-Aug. Mean		
Reference	85.4	76.6	83.0	86.5	77.0	83.4	86.5	77.1	83.5	89.4	77.9	85.3	
Base	85.4	76.6	83.0	87.9	78.5	84.4	87.6	78.5	84.5	89.5	78.1	85.6	
B&W ·	85.4	76.6	83.0	88.0	78.5	84.4	87.6	78.5	84.5	89.6	78.1	85.6	
AP 1000	85.4	76.6	83.0	88.0	78.5	84.4	87.6	78.5	84.5	89.6	78.1	85.6	
Dissolved Oxygen (mg/L) ²	Min. Day ⁵	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	
Reference	5.3	6.8	6.0	5.2	6.7	5.9	5.2	6.7	5.9	6.5	8.8	8.2	
Base	5.3	6.8	6.0	5.2	6.6	5.9	5.2	6.6	5.9	6.5	8.8	8.0	
B&W	5.3	6.8	6.0	5.2	6.6	5:9	5.2	6.6	5.9	6.5	8.8	8.0	
AP 1000	5.3	6.8	6.0	5.2	6.6	5.9	5.2	6.6	5.9	6.4	8.8	8.0	
Algae Biomass (mg/L) ²	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	
Reference	0.1	0.0	0.0	0.6	0.1	0.1	0.6	0.1	0.1	3.5	2.2	2.1	
Base	0.1	0.0	0.0	0.6	0.1	0.1	. 0.5	0.1	0.1	3.6	2.1	2.0	
B&W	0.1	0.0	0.0	0.6	0.1	0.1	0.5	0.1	0.1	3.6	2.1.	2.0	
AP 1000	0.1	0.0	0.0	0.6	0.1	0.1	0.5	0.1	0.1	3.6	2.1	2.0	

²All values are based on model results at the 5-foot depth

³Max day is the maximum daily value for the entire year

⁴Mean is the average of the 6-hour model outputs over the designated time period

⁵Min. day is the minimum daily value for the entire year

A-145

Appendix E

Parameter (Units)	-	am of Widov Intake RM 409.5 - 4		•	m of Bellefo RM 393.0 - 3			nstream of Be Discharge FRM 389.0 - 3	•	Guntersville Forebay TRM 349.8 - 350.5			
Temperature (°F) ²	Max. Day ³	April-Sept. Mean ⁴	July-Aug. Mean ⁴	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	
Reference	85.4	76.6	83.0	86.5	77.0	. 83.4	86.5	77.1	83.5	89.4	77.9	85.3	
Base	85.4	76.6	83.0	87.9	78.5	84.4	87.6	78.5	84.5	89.5	78.1	. 85.6	
B&W	85.4	76.6	83.0	88.0	78.5	84.4	87.6	78.5	84.5	89.6	78.1	85.6	
AP 1000	85.4	76.6	83.0	88.0	78.5	84.4	87.6	78.5	84.5	89.6	78.1	85.6	
Dissolved Oxygen (mg/L) ²	Min. Day⁵	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	
Reference	5.3	6.8	6.0	5.2	6.7	5.9	5.2	6.7	5.9	6.5	8.8	8.2	
Base	5.3	6.8	6.0	5.2	6.6	5.9	5.2	6.6	5.9	6.5	8.8	8.0	
B&W	5.3	6.8	6.0	5.2	6.6	5.9	5.2	6.6	5.9	6.5	8.8	8.0	
AP 1000	5.3	6.8	6.0	5.2	6.6	5.9	5.2	6.6	5.9	6.4	8.8	8.0	
Algae Biomass (mg/L) ²	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	
Reference	0.1	0.0	0.0	0.6	0.1	0.1	0.6	0.1	0.1	· 3.5	2.2	2.1	
Base	0.1	0.0	0.0	0.6	0.1	0.1	0.5	0.1	0.1	3.6	2.1	2.0	
B&W	0.1	0.0	0.0	0.6	0.1	0.1	0.5	0.1	0.1	3.6	2.1	2.0	
AP 1000	0.1	0.0	0.0	0.6	0.1	0.1	0.5	0.1	0.1	3.6	2.1	2.0	

²All values are based on model results at the 5-foot depth

³Max day is the maximum daily value for the entire year

⁴Mean is the average of the 6-hour model outputs over the designated time period

⁵Min. day is the minimum daily value for the entire year

Parameter (Units)		am of Widov Intake RM 409.5 - 4			am of Bellefo IRM 393.0 - 3			nstream of Be Discharge IRM 389.0 - 3	•	Guntersville Forebay TRM 349.8 - 350.5			
Temperature (°F) ²	Max. Day ³	April-Sept. Mean ⁴	July-Aug. Mean ⁴	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	
Reference	85.4	76.6	83.0	86.5	77.0	83.4	86.5	77.1	83.5	89.4	77.9	85.3	
Base	85.4	76.6	83.0	87.9	78.5	84.4	87.6	78.5	84.5	89.5	78.1	85.6	
B&W	85.4	76.6	83.0	88.0	78.5	84.4	87.6	78.5	84.5	89.6	78.1	85.6	
AP 1000	85.4	76.6	83.0	88.0	78.5	84.4	87.6	78.5	84.5	89.6	78.1	85.6	
Dissolved Oxygen (mg/L) ²	Min. Day⁵	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	Min. Day	April-Sept. Mean	July-Aug. Mean	
Reference	5.3	6.8	6.0	5.2	6.7	5.9	5.2	6.7	5.9 ′	6.5	8.8	8.2	
Base	5.3	6.8	6.0	5.2	6.6	5.9	5.2	6.6	5.9	6.5	8.8	8.0	
B&W	5.3	6.8	6.0	5.2	6.6	5.9	5.2	6.6	5.9	6.5	8.8	8.0	
AP 1000	5.3	6.8	6.0	5.2	6.6	5.9	5.2	6.6	5.9	6.4	8.8	8.0	
Algae Biomass (mg/L) ²	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day	April-Sept. Mean	July-Aug. Mean	Max. Day			
Reference	0.1	0.0	0.0	0.6	0.1	0.1	0.6	0.1	0.1	3.5	2.2	2.1	
Base	0.1	0.0	0.0	0.6	0.1	0.1	0.5	0.1	0.1	3.6	2.1	2.0	
B&W	0.1	0.0	0.0	0.6	0.1	0.1	0.5	0.1	0.1	3.6	2.1	2.0	
AP 1000	0.1	0.0	0.0	0.6	0.1	0.1	0.5	0.1	. 0.1	3.6	2.1	2.0	

²All values are based on model results at the 5-foot depth

³Max day is the maximum daily value for the entire year

⁴Mean is the average of the 6-hour model outputs over the designated time period

⁵Min. day is the minimum daily value for the entire year

Page intentionally blank

APPENDIX F – WETLANDS FIELD DELINEATION AND HABITAT ASSESSMENT FORMS

, •

Page intentionally blank

	ect: Bellefonte NP 0 10389	Investigator: J. Grotor	n, Ĥ. Hart	Normal Circumstances:					Sample ID:	wioo	.1	
Čọu	nty: Jackson				Atypic	al Situat	ion:	n	Station or Structure Number(s)			
State	è: AL	Date: April 6, 2006			Proble	em Arèa:		'n	Cowardin Code:	PFO	1E	
	getation											
veţ		Species	Stratum	n India	cator			F	Tant Species	,s	tratum.	Indicator
1.	Quércus phéllos		Tr	Fa	CW-	9.	Toxicode	indron	radicans	- <u> </u> -	w	Fac
2.	Quercus nigra		Tr	F	ac	10.	Carex tri	buloid	95		н	Facw
3.	Quercus pagoda		Tr	Ęa	acț	11.	Ulmus ai	merica	na		Tr	Facw
4.	Pinus taeda		Tr	F	ac	12.	Ulmus th	omasi	i	-	Tr, Sh	Fac
5.	Acer rubrum	· · · · · · · · · · · · · · · · · · ·	Tr	F	ac	13.	Impatien			́н	Facw	
6.	Liquidambar styraci	fiua .	Tr, Sh	Fa	104	14.						·
7.	llex decidua		Sh	Fa	C#-	15.			·······			
8.	Berchemia scanden	IS-	w	Fa	ICW	16.			J			
Perc	cent of Dominant Spe	cies That are OBL, FAC	: 100%					· · ·				
	· · ·											
	drology											
Field	d Observations:		Wetland Hy	drology ir	ndicator	rs:						
De	pth of Surface Water:	0-6 (in.) f	Primary Inc	licators						Secon	dary Inc	licators
De	pth to Free Water in P	it: '11 (in.)	y I	nundated			ſ	Drift Li	nes y	Oxidize	d Root C	Channels,
De	pth to Saturated Soil:	8 (in.)	y s	Saturated in	n Upper	12 in:	· \	Water	Marks y	Water S	stained L	.eaves
	•			Sediment D	eposits		y i	Draina	ge Patterns			
Řem	arke: wet weather do	ainage to Town Creek err	havment o	o Gunteres	ille Res	ennir				.		· · · ·
									· .			
Soi	ils	,						,				
	Unit:	·	Draina	ge class:					Listed hydric soil?	Yes	Τ	No
Prof	file Description:				1							
De	epth (Inches) A	Vatrix Color (Munsell M	oist)	Mottle C	olors (N	Vlunsell I	Moist)	P	fottle Abundance		Texte	ure
·	0-2	10 YR 6/2		,	-		<u> </u>				Loa	m
	2-8	10 YR 6/4							-	<i></i>	Silt to	am
	8-12	10/YR 6/4			10 YF	6/2			Common		Silty clay	loam.
Hyd	ric Soil Indicators:	<u>.</u>	l						·····		•	
	Gleyed or Low Chr	oma Colors		Histic	Épipedo				Aquic Mois	ture Re	dime	······
	Sulfidic Odor						rf. Layer S	andy S				
;ÿ	Concretions			<u>`</u>			andy Soils		Other (Exp) .
	arks: Soil color not qu	ite hydric (chroma is too	high); lots (of evidence	of exte	nsive soi	l dislurban	ce in p	**************************************			
İetla	and Determinatio											
_	rophytic Vegetation Pr		Ŷ	Ņo	ls	this Sar	pling Poin	t Withi	n a USACE Wetland?	Yes	Ŷ	No
Wetland Hýdrölogy Present? Yes Y							Is this Sampling Point Within a USACE Wetland? Does area only meet USEWS wetland definition?			Yes		No N
Hydr	ric Solls Present?		No N	 Is	wetland	mapped o	n NWI	? ·	Yes –	i 	No N	
Eétir	nated size: 2 95 acres											

TVA Natural Heritage Project Routine Wetland Determination Form

Sample ID: W001	Photo ID(s);	WD1-1VV, WD	1-2W, WC	01-3W						
Ragging Description: 1-29 cou	Interdockwise fro	om NW come	r near cub	vert around	to east; 30-	70 da	okwise from #1	arou	nd north side bad	(to;#29
Drawing										
. •	oject Centerline,	Surveý Corrio	ior Bound:	aries, Leng	th of Wetland	d Fear	ure, Distances	form	Centerline, Photo	Locations
Ward Not T Wood Not T NT Accurated Junour	und (F.	a contraction			fom	Çenterline, Photo	Locations
								<u> </u>	· · ·	
	· · · ·		aterbodv/	Watershed	Uppermod	draina	ige (NMC) to	Foun	Ureek (Tennéssé	e River.
Obvious Connections to Waters of the US/State?	ý Yes			Reservoir						e inver-
	y Yes Cap. Frir			Reservoir		3	Groundwater	4	Precipitation	
Waters of the US/State? Primary Water Source	Cap. Frir		<u>intersville</u> Dverbankii	Reservoir	Sheet Flow	3		1 70		Öther
Waters of the US/State? Primary Water Source (If other, note in comments)	63.5 TV	nge 1 G	<u>intersville</u> Dverbanki GORY:	Reservoir ng 2 Category	Sheet Flow	11	Groundwater	4	Precipitation	Öther

	d: Bellefonte NP 10389	Invest	igator:	J. Groton	H. Hart		Norma	al Circun	nstances:	'У	Sample ID:	٧	V002		
.Count	y: Jackson						Atypic	al Situat	ion:	n	Station or Structure Number(s);				
State:	AL	Date:	April 6	2006			Proble	m Area:		n	Cowardin Code:	P	FOIE		
Vede	etation			<u></u>		<u>.</u>					• • • • • • • • • • • • • • • • • • •				-
		nt Species	5		Stratum	India	cator			F	Pant Species	1	Stratum	Indicate	pr,
1,	Carpinus carolinia	na			Tr, Sh	Fi	ac	9.	Τοχίσος	lendron	radicans		w	Fac	-
-2.	Quercus nigra				Tr	Fi	ac	10.	Ulmus	america	ina		۲ŕ	Facw	
3.	Quercus pagoda				Tr	Fi	ac	11	Ulmus	thomas	U .		Tr, Sh	Fac	
4.	Pinus taoda				Tr	Ę,	ac	12.	Impatie	ns sp.		·	н	Facw	
5.	Acer rubrum				Tr	Fi	ac	13.							
6.	Liquidambar styra	ciflua			Tr, Sh	Fa	iČ+	14.		_					
7.	llex decidua				Sh	Fa	ac	15.							
8.	Berchemia scande	ens			w	Fa	icw.	,16.							
Perce	nt of Dominant S	pecies Th	atare C	OBL, FAC	W, or FAC	: 100%									
Hydi	rology														
	Observations:		Naniany pagagain	v	Vetland Hy	drology in	ndicator	s:			······				
	h of Surface Wate	r:	0-4	(in.) P	rimary Ind	icators						Sec	condary Indi	cators	
Dept						nundated				Drift Li	nes y	Öxid	lized Root C	hannels	
· · .	h to Free Water in	.Pit:	÷ .	(in.)	y In	unuarcu									
Dept		*****		(in. <u>)</u> (in.)		aturated in	n Upperi	12 iñ.		Water	*****	Wal	er Stäined Lo	eaves	
Dept	h to Free Water in	*****			<u>y</u> s			12 iñ.	 y.	Waler	*****	Wal		eaves	
Dept Dept	h to Free Water in	lt	8	(in.)	y s	aturated in ediment D	eposits		<u> </u>	Waler	Marks y	Wal		eaves	
Dept Dept	h to Free Water in Ih to Saturated Soi	lt	8	(in.)	y s	aturated in ediment D	eposits		<u>y</u> .	Waler	Marks y	Wat		eaves	
Dept Dept	ih to Free Water in Ih to Saturated Soi Irks: wet weather o	lt	8	(in.)	y s	aturated in ediment D	eposits		<u> </u>	Waler	Marks y	Wal		2ave,s	
Dept Dept Rema	ih to Free Water in Ih to Saturated Soi Inks: wet weather o S	lt	8	(in.)	y S s	aturated in ediment D	eposits		<u>y</u> .	Waler	Marks y			No:	
Dept Dept Rema Soils Soil U	ih to Free Water in Ih to Saturated Soi Inks: wet weather o S	lt	8	(in.)	y S s	iaturated in Iediment D n Guntersv	eposits		<u>у.</u>	Waler	Marks y ge Patterns		er Stäined Le		
Dept Dept Rema Soils Soil U Profil	h to Free Water in h to Saturated Soi rks: wet weather o S Jnit:	l: drainage to	8 D Town ((in.)	y S subayment or Drainag	iaturated in Iediment D n Guntersv	ille Res	ervoir		Waler Draina	Marks y ge Patterns		er Stäined Le	No:	
Dept Dept Rema Soils Soil U Profil	ih to Free Water in Ih to Saturated Soi Inks: wet weather o S Juit: e Description;	l: drainage to	8 D Town ((in.) Creek em	y S subayment or Drainag	iaturated in Rediment D In Guntersv ge class:	ille Res	ervoir		Waler Draina	Marks y ge Patterns Listod hydric soil?		er Stained Le	No	
Dept Dept Rema Soils Soil U Profil	Ih to Free Water in Ih to Saturated Soi Inks: wel weather of S Junit: The Description: Sth (Inches)	l: drainage to	8 5 Town (olor (Ma	(in.) Creek em lunsell Ma	y S subayment or Drainag	iaturated in Rediment D In Guntersv ge class:	ille Res	ervoir		Waler Draina	Marks y ge Patterns Listod hydric soil?		er Stained Le os Textu	No.	
Dept Dept Rema Soils Soil U Profil	In to Free Water in In to Saturated Soi Inks: wet weather of S Junit: In Description: oth (Inches) 0-2	l: drainage to	8 o Town (olor (M 10 YR	(in.) Čreek em lunseli Ma 4/2 5/2	y S subayment or Drainag	iaturated in Rediment D In Guntersv ge class:	ille Res ille Res colors (fl	ervoir flunsell l		Waler Draina	Marks y ge Patterns Listod hydric soil?		er Stained Le os Textu Silt loz	Nò. re m	
Dept Dept Rema Soils Soil U Profil	th to Free Water in th to Saturated Soli urks: wet weather of S Juit: e Description: oth (Inches) 0-2 2-5	l: drainage to	8 5 Town (olor (M 10 YR 10 YR	(in.) Creek em lunseli Ma 4/2 5/2 7/3	y S subayment or Drainag	iaturated in Rediment D In Guntersv ge class:	eposits Alle Res Colors (f	ervoir Aunsell I 7/2		Waler Draina	Marks y ge Patterns Listed hydric soil? Mottle Abundance		er Stained Le os Textu Sill los Silt los	Nò. rei im ay	
Dépi Dépi Rema Soil U Profil	In to Free Water in In to Saturated Soi Inks: wel weather of S Juit: e Description: oth (Inches) 0-2 2-5 5-9	I:	8 o Town (olor (Min 10 YR 10 YR	(in.) Creek em lunseli Ma 4/2 5/2 7/3	y S subayment or Drainag	iaturated in Rediment D In Guntersv ge class:	Colors (N	ervoir Aunsell I 7/2		Waler Draina	Marks y ge Patierns Listed hydric soil? Mottle Abundance		er Stälned Le es Textu Silt los Silt los	Nò. rei im ay	
Dépi Dépi Rema Soil U Profil	In to Free Water in In to Saturated Soit Inks: wel weather of S Junit: e Description: oth (Inches) 0-2 2-5 5-9 9-12	l: drainage to Matrix C	8 olor (M 10 YR 10 YR 10 YR	(in.) Creek em lunseli Ma 4/2 5/2 7/3	y S subayment or Drainag	aturated ir iediment D n Guntersv ge class: Mottle C	Colors (N	ervoir funsell 7/2 7/2		Waler Draina	Marks y ge Patierns Listed hydric soil? Mottle Abundance	Y	er Stälned Le os Textu Silt los Silt los Silty ol Clay	Nò. rei im ay	
Dept Dept Rema Soil Dep Soil Dep Hydrii	th to Free Water in th to Saturated Soi urks: wet weather of s Juit: e Description: oth (Inches) 0-2 2-5 5-9 9-12 c Soil Indicators:	l: drainage to Matrix C	8 olor (M 10 YR 10 YR 10 YR	(in.) Creek em lunseli Ma 4/2 5/2 7/3	y S subayment or Drainag	aturated ir iediment D n Guntersv ge class: Mottle C Histic	ille Reso ille Reso colors (fi - - - - - - - - - - - - - - - - - - -	ervoir Aunsell 7/2 7/2		Water	Marks y ge Patterns Listed hydric soil? Mottle Abundance Common Common Aquic Mo	Y	er Stälned Le os Textu Silt los Silty of Clay Regime	Nò. rei im ay	
Dept Dept Rema Soil Dep Soil Dep Hydrii	th to Free Water in th to Saturated Soli urks: wel weather of S Juit: e Description: oth (Inches) 0-2 2-5 5-9 9-12 c Soil Indicators: Gleyed or Low Ci	l: drainage to Matrix C	8 olor (M 10 YR 10 YR 10 YR	(in.) Creek em lunseli Ma 4/2 5/2 7/3	y S subayment or Drainag	aturated ir iediment D n Guntersv ge class: Mottle C Histic Histic	eposits ille Ress colors (I 0 YR 10 YR Epipedo	ervoir flunsell 7/2 7/2 cont. Su	Moist)	Water Draina	Marks y ge Patterns Listed hydric soil? Mottle Abundance Common Common Solls y Réducing	Y isture	er Stälned Le os Textu Silt los Silty of Clay Regime	Nò. rei im ay	
Dept Dept Rema Soil: Soil U Profil Dep Hydrin Y Y	In to Free Water in In to Saturated Soi Inks: wel weather of S Jinit: e Description: oth (Inches) 0-2 2-5 5-9 9-12 c Soil Indicators: Gleyed or Low Ch Suffidle Odor Concretions	l: drainage to Matrix C	8 olor (M 10 YR 10 YR 10 YR	(in.) Creek em lunseli Ma 4/2 5/2 7/3	y S subayment or Drainag	aturated ir iediment D n Guntersv ge class: Mottle C Histic Histic	eposits ille Ress colors (I 0 YR 10 YR Epipedo	ervoir flunsell 7/2 7/2 cont. Su	Moist)	Water Draina	Marks y ge Patterns Listed hydric soil? Mottle Abundance Common Common Solls y Réducing	Y isture	er Stälned Le es Textu Silt los Silty d .Clay Regime Iftions	Nò. rei im ay	
Dept Dept Rema Soil: Profil Profil Profil Py y y y y Rema	In to Free Water in In to Saturated Soi Inks: wel weather of S Jinit: e Description: oth (Inches) 0-2 2-5 5-9 9-12 c Soil Indicators: Gleyed or Low Ch Suffidle Odor Concretions	I: drainage to Matrix Co hroma Colo	8 olor (M 10 YR 10 YR 10 YR	(in.) Creek em lunseli Ma 4/2 5/2 7/3	y S subayment or Drainag	aturated ir iediment D n Guntersv ge class: Mottle C Histic Histic	eposits ille Ress colors (I 0 YR 10 YR Epipedo	ervoir flunsell 7/2 7/2 cont. Su	Moist)	Water Draina	Marks y ge Patterns Listed hydric soil? Mottle Abundance Common Common Solls y Réducing	Y isture	er Stälned Le es Textu Silt los Silty d .Clay Regime Iftions	Nò. rei im ay	
Depi Depi Rema Soil Soil Profil Profil Hydrid y y y X Rema	In to Free Water in In to Saturated Soil Inks: wel weather of S Juit: e Description: oth (Inches) 0-2 2-5 5-9 9-12 c Soil Indicators: Gleyed or Low Ch Sulfidic Odor Concretions	I: drainage to Matrix Co hroma Colo	8 olor (M 10 YR 10 YR 10 YR	(in.) Creek em lunseli Ma 4/2 5/2 7/3	y S sibayment or Drainag	aturated ir iediment D n Guntersv ge class: Mottle C Histic Histic	eposits Aille Ress colors (II - - - - - - - - - - - - - - - - - -	ervoir flunsell 7/2 7/2. n Cont. Su ding in S	Moist) rf. Layer andy Soil	Water Draina	Marks y ge Patterns Listed hydric soil? Mottle Abundance Common Common Solls y Réducing	Y isture	er Stälned Le os Textu Silt los Silt los Silt los Silt los Silt los in Remarks)	Nò. rei im ay	
Depi Depi Rema Soil Soil Profil Dep Profil Hydri y y y Rema Rema	In to Free Water in In to Saturated Soi Inks: wel weather of S Juit: e Description: oth (Inches) 0-2 2-5 5-9 9-12 c Soil Indicators: Gleyed or Low Ch Sulfidic Odor Concretions Irks:	I: drainage to Matrix Co hroma Colo tion Present?	8 olor (M 10 YR 10 YR 10 YR	(in.) Creek em lunseli Mi 4/2 5/2 7/3 7/3	y S sibayment or Drainag	eturated ir iediment D n Guntersv ge class: Mottle C Histic Histic Organ	eposits Aile Ress colors (1 - - 10 YR 10 YR Epipedo Drganic (ic Streal Is	arvoir flunsell 7/2 7/2 7/2 Cont. Su ding in S this Sam	Moist) rf. Layer andy Soil	Water Draina	Marks y ge Patterns Listed hydric soil? Mottle Abundance 	j Y	er Stälned Le es Textu Silt los Silt los Silt y cl Clay Regime filions in Remarks)	Nò. re im ay	

TVA Natural Heritage Project Routine Wetland Determination Form

Sample ID: W002	Pho	țo ID((s): WO2	2-1,W, V	۸O2-2WV, ۱	MD2-3V	V, WO	2-4W, V	₩02-5	5W, V	V02-6/\	(, W02	7W, V	V02-	8W, W	/02-9//		
Flagging Description: W2-1 to corner back to W2-1	Ŵ2-16	clockv	Arse from	m south	nern edge	äround	to ne	prthives	st cóm	ier, M	/2A-1 to	W2A	43 do	ockw	ise froi	m north	easter	'n
Drawing																		
Please Include: North Arrow, Pl	roject Ce	enterlir	ne, Surv	vey Cor	ridor.Bour	ndaries.	Lenc	th of W	/etland	d Fea	ture.D	istance	s from	n Ce	nterline	e. Photo	Loca	tions
																-(
NUUS			صر ما															
NICE 2 NOT	-100 5	SLA	C									• •						
NT			in et	م الم	and)													
		- dec	an ce U	2.1 0.														
		k	7								\sim	2						
- A	,	K.								(~	1						
No. 1	k	/				1.4	13		. t	\ Y)	5				2		
	H		ned	in the	Amerike	: E S 12	1. <u>1</u>	. de	J.la	istil	مرانا	\sim	ini					
(H)	<u>A</u> -				LA		MAL	10 -	مان مان تعنق	sela Second		$\!$		**				
in the second se	X				65	Q	1	T. T.	petres.	1	X	lu c	\geq					
ľ –	\mathbf{X}			×c	- 1	2 ×	<u> </u> _,	WAL Jares	(21)N	;			ŲÇ.					
	\mathbb{X}	\sim	DV/	1 all of	$\langle \phi \rangle$	≥ 0	9	dr.s.l	Letv.	£.								
	X	X	J.Z	$\sim \chi$	C			12	i rel cocis									
- 17		/ (
J. 1	$\sum_{i=1}^{N}$	57	1	1	No.			1										
V (and	Ľ		$\mathbf{\tilde{x}}$	L.		-0	UA.	4										
aller-di	L X Unic		X	No.				Hrb) ivert	Ite						,			
Willing .	Unie		N U	Ner				ntrb) ivert	n fler	1-	15 10 10	WZ X	read	2	~			
Willing to the	•		R S	No.				ntrb) ivert	n lkn	1-	BEN	N2 Aller	roid		~			
Wellow It	•	e#+++				1-1420	110 + 110 +	How) N cat Indun S inter D	5.4.(4 1)	/- suri	pro					,		
Obvious Connections to Waters of the US/State?	nj strice	Yes		No 1	Weterbod	y/Water	rshed	110/11/10/10	5.4.(4 1)	/- suri					zek (Te	enness	e Riv	ər-
Obvious Connections to Waters of the US/State? Primary Water Source	nj strice	Yes	Fringe	vo 1	Waterbod Güntersvil	yWater le Rese	rshed	110/11/10/10	med (/- Statt	age (W		o Tow	n Ĉri	zek (Te		e Riv	
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments)	nj strice	Yes Cap:	Fringe		Güntersvil	y/Water king	rshed	Unna Sheet	med (/- Statt	age (W	MC)∶ti	o Tow	n Ĉri			ee Riv	
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE: Description of Wetland and Ot	<u>кј</u> ,јтúć У 6 her Cor	Yes Cap: 9	Fringe TVARA	1 M CAT	Güntersvil Overban EGORY: geclass; h	yWates king Cate	rshed ervoir 3 egory	Unna Sheet	Flow	/- Statu drain 2	age (/// Grour	WC) to	-4	n Cri	recipit	ation	T	Other
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments)	<u>кј</u> ,јтúć У 6 her Cor	Yes Cap: 9	Fringe TVARA	1 M CAT	Güntersvil Overban EGORY: geclass; h	yWates king Cate	rshed ervoir 3 egory	Unna Sheet	Flow	/- Statu drain 2	age (/// Grour	WC) to	-4	n Cri	recipit	ation	T	Other
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE: Description of Wetland and Of to ROW; erosion potential, existing Flatwood forested wetland	Ny ,Hrût Y 6 her Cor ng distur	Yes Cap. 1 39 1 thance	Fringe TVÄRA ts: (i.e. s, adjace	1 M CAT forest a ent land	Güntersvil Overban EGORY: geclas; h I we wild	yWates king Cate	rshed ervoir 3 egory	Unna Sheet	Flow	/- Statu drain 2	age (/// Grour	WC) to	-4	n Cri	recipit	ation	T	Other
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE: Description of Wetland and Of to ROW; existing o tendal, existing Flatwood forested wetland Wetland will receive is torm water Obvious signs of soil disturbance	Af , it is a y y her Cor ng distur runoff fr a and es	Yes Cap: 9 1 mmen dance	Fringe TVARA ts: (i.e. s, adjace nstructio	M CAT forest a ent land	Güntersvil Overban EGORY: geclas; h I wa wiki	yWate le Ress king Cate	rshed ervoir 3 egory	Unna Sheet	Flow	/- Statu drain 2	age (/// Grour	WC) to	-4	n Cri	recipit	ation	T	Other
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE: Description of Wetland and Ot to ROW; existing o tendal, existi Flatwood forested wetland Wetland will receive storm water Obvious signs of soil disturbano Several perched wetlands/verna Numerous large trees (18-24+ in Sumerous large trees (18-24+ in	Ny Janue y 6 her Con ng distur nunoff fr a and es j pools s ches DE	Yes Cap: 39 11 10 ance to ance om co arth-mo scatten BH) thr	Fringe TVARAI ts: (i.e. s, adjace nstruction oving in ed abou roughou	1 forest a ent land on area past ut north ut vetia	Güntersvil Overban EGORY: Beclass; h I way wild eastern lõ ind but est	yAVater le Rese king Cate abitat f	rshed rshed ervoir 3 egory teatury teatury teatury teatury	Hrb) IV CAS I (JULIII) Hold I (JULIII) Sheet 3 Sheet 3 as; hydr	Flow Flow	drain 2 regin	age (W Grour ne; dis s, lat k	WC) to notwate	r 4	P P	land o	ation utside o	forad	Other
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE: Description of Wetland and Ot to ROW; existing o tendal, existi Flatwood forested wetland Wetland will receive storm water Obvious signs of soil disturbano Several perched wetlands/verna Numerous large trees (18-24+ in Sumerous large trees (18-24+ in	Ny Janue y 6 her Con ng distur nunoff fr a and es j pools s ches DE	Yes Cap: 39 11 10 ance to ance om co arth-mo scatten BH) thr	Fringe TVARAI ts: (i.e. s, adjace nstruction oving in ed abou roughou	1 forest a ent land on area past ut north ut vetia	Güntersvil Overban EGORY: Beclass; h I way wild eastern lõ ind but est	yAVater le Rese king Cate abitat f	rshed rshed ervoir 3 egory teatury teatury teatury teatury	Hrb) IV CAS I (JULIII) Hold I (JULIII) Sheet 3 Sheet 3 as; hydr	Flow Flow	drain 2 regin	age (W Grour ne; dis s, lat k	WC) to notwate	r 4	P P	land o	ation utside o	forad	Other
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE: Description of Wetland and Ot to ROW; existing o tendal, existi Flatwood forested wetland Wetland will receive storm water Obvious signs of soil disturbano Several perched wetlands/verna Numerous large trees (18-24+ in Sumerous large trees (18-24+ in	Ny Janue y 6 her Con ng distur nunoff fr a and es j pools s ches DE	Yes Cap: 39 11 10 ance to ance om co arth-mo scatten BH) thr	Fringe TVARAI ts: (i.e. s, adjace nstruction oving in ed abou roughou	1 forest a ent land on area past ut north ut vetia	Güntersvil Overban EGORY: Beclass; h I way wild eastern lõ ind but est	yAVater le Rese king Cate abitat f	rshed rshed ervoir 3 egory teatury teatury teatury teatury	Hrb) IV CAS I (JULIII) Hold I (JULIII) Sheet 3 Sheet 3 as; hydr	Flow Flow	drain 2 regin	age (W Grour ne; dis s, lat k	WC) to notwate	r 4	P P	land o	ation utside o	forad	Other
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE: Description of Wetland and Ot to ROW; erostingo tendal, existi Flatwood forested wetland Wetland will receive storm water Obvious signs of soil disturbano Several, perched wetlands/verna Num erous large trees (18-24+ in Several, perched wetlands/verna Num erous large trees (18-24+ in	Ny Janue y 6 her Con ng distur nunoff fr a and es j pools s ches DE	Yes Cap: 39 11 10 ance to ance om co arth-mo scatten BH) thr	Fringe TVARAI ts: (i.e. s, adjace nstruction oving in ed abou roughou	1 forest a ent land on area past ut north ut vetia	Güntersvil Overban EGORY: Beclass; h I way wild eastern lõ ind but est	yAVater le Rese king Cate abitat f	rshed rshed ervoir 3 egory teatury teatury teatury teatury	Hrb) IV CAS I (JULIII) Hold I (JULIII) Sheet 3 Sheet 3 as; hydr	Flow Flow	drain 2 regin	age (W Grour ne; dis s, lat k	WC) to notwate	r 4	P P	land o	ation utside o	forad	Other
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE: Description of Wetland and Ot to ROW; existing o tendal, existi Flatwood forested wetland Wetland will receive storm water Obvious signs of soil disturbano Several perched wetlands/verna Numerous large trees (18-24+ in Sumerous large trees (18-24+ in	Ny Janue y 6 her Con ng distur nunoff fr a and es j pools s ches DE	Yes Cap: 39 11 10 ance to ance om co arth-mo scatten BH) thr	Fringe TVARAI ts: (i.e. s, adjace nstruction oving in ed abou roughou	1 forest a ent land on area past ut north ut vetia	Güntersvil Overban EGORY: Beclass; h I way wild eastern lõ ind but est	yAVater le Rese king Cate abitat f	rshed rshed ervoir 3 egory teatury avair	Hrb) IV CAS I (JULIII) Hold I (JULIII) Sheet 3 Sheet 3 as; hydr	Flow Flow	drain 2 regin	age (W Grour ne; dis s, lat k	WC) to notwate	r 4	P P	land o	ation utside o	forad	Other
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE: Description of Wetland and Of to ROW; excession potential, existin	Ny Janue y 6 her Con ng distur nunoff fr a and es j pools s ches DE	Yes Cap: 39 11 10 ance to ance om co arth-mo scatten BH) thr	Fringe TVARAI ts: (i.e. s, adjace nstruction oving in ed abou roughou	1 forest a ent land on area past ut north ut vetia	Güntersvil Overban EGORY: Beclass; h I way wild eastern lõ ind but est	yAVater le Rese king Cate abitat f	rshed rshed ervoir 3 egory teatury avair	Hrb) IV CAS I (JULIII) Hold I (JULIII) Sheet 3 Sheet 3 as; hydr	Flow Flow	drain 2 regin	age (W Grour ne; dis s, lat k	WC) to notwate	r 4	P P	land o	ation utside o	forad	Other
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE: Description of Wetland and Ot to ROW; erostingo tendal, existi Flatwood forested wetland Wetland will receive storm water Obvious signs of soil disturbano Several, perched wetlands/verna Num erous large trees (18-24+ in Several, perched wetlands/verna Num erous large trees (18-24+ in	Ny Janue y 6 her Con ng distur nunoff fr a and es j pools s ches DE	Yes Cap: 39 11 10 ance to ance om co arth-mo scatten BH) thr	Fringe TVARAI ts: (i.e. s, adjace nstruction oving in ed abou roughou	1 forest a ent land on area past ut north ut vetia	Güntersvil Overban EGORY: Beclass; h I way wild eastern lõ ind but est	yAVater le Rese king Cate abitat f	rshed rshed ervoir 3 egory teatury avair	Hrb) IV CAS I (JULIII) Hold I (JULIII) Sheet 3 Sheet 3 as; hydr	Flow Flow	drain 2 regin	age (W Grour ne; dis s, lat k	WC) to notwate	r 4	P P	land o	ation utside o	forad	Other
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE: Description of Wetland and Ot to ROW; erostingo tendal, existi Flatwood forested wetland Wetland will receive storm water Obvious signs of soil disturbano Several, perched wetlands/verna Num erous large trees (18-24+ in Several, perched wetlands/verna Num erous large trees (18-24+ in	Ny Janue y 6 her Con ng distur nunoff fr a and es j pools s ches DE	Yes Cap: 39 11 10 ance to ance om co arth-mo scatten BH) thr	Fringe TVARAI ts: (i.e. s, adjace nstruction oving in ed abou roughou	1 forest a ent land on area past ut north ut vetia	Güntersvil Overban EGORY: Beclass; h I way wild eastern lõ ind but est	yAVater le Rese king Cate abitat f	rshed rshed ervoir 3 egory teatury avair	Hrb) IV CAS I (JULIII) Hold I (JULIII) Sheet 3 Sheet 3 as; hydr	Flow Flow	drain 2 regin	age (W Grour ne; dis s, lat k	WC) to notwate	r 4	P P	land o	ation utside o	forad	Other
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE: Description of Wetland and Ot to ROW; erostingo tendal, existi Flatwood forested wetland Wetland will receive storm water Obvious signs of soil disturbano Several, perched wetlands/verna Num erous large trees (18-24+ in Several, perched wetlands/verna Num erous large trees (18-24+ in	Ny Janue y 6 her Con ng distur nunoff fr a and es j pools s ches DE	Yes Cap: 39 11 10 ance to ance om co arth-mo scatten BH) thr	Fringe TVARAI ts: (i.e. s, adjace nstruction oving in ed abou roughou	1 forest a ent land on area past ut north ut vetia	Güntersvil Overban EGORY: Beclass; h I way wild eastern lõ ind but est	yAVater le Rese king Cate abitat f	rshed rshed ervoir 3 egory teatury avair	Hrb) IV CAS I (JULIII) Hold I (JULIII) Sheet 3 Sheet 3 as; hydr	Flow Flow	drain 2 regin	age (W Grour ne; dis s, lat k	WC) to notwate	r 4	P P	land o	ation utside o	forad	Other

Sample ID: W003

Сонг	nty: Jackson				Atypic	al Situat	ion:	'y	Station or Structure Number(s);			
State	e: AL	Date: April 6, 2006			Proble	em Area:		n	Cowardin Code:	PF	01B	
Veo	etation							<u>.</u>		-	<u></u>	
		t Species	Stratum	Indi	cator				Plant Species	Τ	Stratum	Indicator
1.	Ligustrum sinense		Sh	- F	ac	9.	Glyceria	striat	a		н	Obi
.2.	Celtis laovigata		Tr	Fa	icw	10.	Ulmus th	omas	iii	\neg	Tr, Sh	Fac
3,	Fraxinus pennsylva	nica	Sh, Sap	Fa	acw	11.	Quercus	mich	auxii		Tr	Facw-
4.	Berchemia scander	75	wv	Fa	acw	12.						1
5 . `	Ulmus alata		Tr	Fa	cu+	13.						· ·
6.	Carex cherokeensi:	5	н	Fa	icw-	14.						
7.	Nothoscordum biva	lve	н	F	ac	15.						
8.	Sanicula sp.		Ĥ	Fac	Facu	16.						
Perc	ent of Dominant Sp	ecies That are OBL, FA	ĆW, or FAC:	82%								
Hyd	irology	· · ·										
The second se	Observations:		Wetland Hyd	irology li	ndicator	rs:				int in the		
Dep	oth of Surface Water:	0-1 (in.)	Primary Indi	cators						Seco	ondary ing	dicators
Dep	oth to Free Water in F	Pit: - (in.)	y In	undated			i	Drift Li	ines	Oxidiz	zed Root (Channels
Dep	oth to Saturated Soil:	7 (in.)	ÿ Sa	aturated in	n Upper	12 in,	, I	Water	Marks	Water	r Stalned I	Leaves
			Se	ediment C	eposits)		<u>y</u> I	Draina	ige Patterns			
Rem	aiks: Headwater of	unnamed drainage (W	WC) to Tow	n Creek	(Tenne:	ssee Riv	ver-Gunter	rsville	Reservoir); connects b	y drain	age chan	nel to W02
Soi	ls		-									-
Soil	Unit:		Drainag	e class:					Listed hydric soil?	Ye	s	No
Prof	ile Description:											
De	epth (Inches)	Matrix Color (Munsell N	loist)	Mottle C	Colors (N	Aunsell	Moist)		Mottle Abundance		Text	ure
	0-3	10 YR 3/2			-				-		Silt Ic	am
	3-6	10 YR 5/3		-	10 YR	8 6/2			Common		Silt Ic	am
	6-12	10 YR 6/2	1		10 YR	6/6			Common		Silty	clay
							•					••• ·. · · · · ·
Hydi	ric Soil Indicators:		· ·					1				
	Gleyed or Low Chr	oma Colors		Histic	Epipedo	<u>л</u>			Aquic Mo	isture F	legime	
	Suffidic Odor			 High (Organic	Cont. Su	rf. Layer S	andy	Soils Reducing	Condit	lions	
,y	Concretions			Organ	nic Strea	king in S	andy Soils		Other (Ex	plain in	n Remarks	i)
Rem	arks: Soil color not q	uite hydric (chroma in sec	cond horizon	too high):	lots of e	vidence	of extensi	ve soi	i disturbance in past;			
Wetla	nd Determinatio	on			•							
Hydr	ophytic Vegetation P	resent? Yes	Y N	10	ls	this San	pling Poin	t With	in a USACE Wetland?	Yes	<u> </u>	No
Wetl	and Hydrology Prese	nt? Yes	<u> </u>	lo	D	oes area	only meet	USF\	WS wetland definition?	Yes		No N
Hydr	ic Soils Present?	Yes	Ņ	lo N	ls	wetland	mapped o	n NW	ļ?	Yés		No N
Estin	nated size: 0.28 acre	· · · · · · · · · · · · · · · · · · ·										

TVA Natural Heritage Project Routine Wetland Determination Form

Normal Circumstances:

У

Project: Bellefonte NP REO 10389

Investigator: J. Groton, H. Hart

Drawing Viewe Include: North Arrow, Project Centerline; Survey Considor Boundaries, Length of Wetland Feature, Dictances from Centerline, Photo Locations Viewe Construction	Please Include: North Anow, Project Centerline; Survey Corridor Boundaries, Length of Wetland Feature, Distances from Centerline, Photo Locations WULLS WED NOT TO SCHILT WICH AND	Sample ID: W003	Ph	noto II	0(s): V	ND3-11	N, W03-2W							•	
Please Include North Arrow, Projed Centedine; Surgey Caridor Boundaries, Length of Wetland Feature, Distances from Centerline, Photo Locations WUL25 WLC25 WLC25 WLC25 N1 AUDIT THO SCHILET N1 Auror chur Mored Auror chur Mored Auror chur Mored N1 Auror chur Mored Auror chur Mored Auror chur Mored N1 Auror chur Mored Auror chur Mored Auror chur Mored N1 Auror chur Mored Auror chur Mored Auror chur Mored N1 Auror chur Mored Auror chur Mored Auror chur Mored N1 Auror chur Mored Auror chur Mored Auror chur Mored Auror chur Mored Auror chur Mored Auror chur Mored Auror chur Mored N1 Auror chur Mored Auror chur Mored Auror chur Mored Multiture Auror chur Mored Multure Auror chur Mored	Prese Include: North Arrow, Project Centerline; Survey Corrisor Bounderies, Length of Weithand Feature, Distances from Centerline, Physic Locations Projects: AUST: Tro: SurVey: Divide: Survey: August: August: <t< th=""><th>-</th><th>Interc</th><th>dockw</th><th>ise from</th><th>m norti</th><th>hviest</th><th></th><th></th><th></th><th></th><th></th><th></th><th></th><th></th></t<>	-	Interc	dockw	ise from	m norti	hviest								
WUGES NOT NOT TO SLEPTE AUCOR NT Auto-cki flord NO Waterbody/Watershed Headwater of unnamed drainage (WWC) to Town Creek: (Tennessee River-Ourtersvile Reservoir) Otwices Connections to waters of the US/State? Yes No Waterbody/Watershed Headwater of unnamed drainage (WWC) to Town Creek: (Tennessee River-Ourtersvile Reservoir) Thomay Water Source Cap. Fringe Overbanking 2 Thomay Water Source Cap. Fringe Overbanking 2 TowaiAM SCORE: 35 TVARAM CATEGORY: Category 2	Wilds finder The Surkture NY All of the Surkture NY NY <th>Drawing</th> <th></th>	Drawing													
NOT TO SLATE NT	Devices Connections to your and the stand where the connections to your and the stand of th		oject i	Cente	dine; S	Survey	Corridor Bound	laries, Le	ength of Wetland	Feat	ure, Distances f	rom	Centerline, Photo	Locatio	şΠş
NY Aussister Hand Minimum Line Hand Minimum Line Hand	Obvious Connections to	WULS	_		· .						• •		•		
NY Aussister Hand Minimum Line Hand Minimum Line Hand	Obvious Connections to	WOB	<u>ه</u> د	i L IFT	しい										
Obvious Connections to Maters of the US/State? Yes No Waterbody/Watershed: Headwater of unnamed drainage (WWC) to Town Creek: (Tennessee River-Curtersvile Reservoir) Obvious Connections to Maters of the US/State? Yes No Waterbody/Watershed: Headwater of unnamed drainage (WWC) to Town Creek: (Tennessee River-Curtersvile Reservoir) Other Source Interference Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater Other Waters of the US/State? Other Source Interference 3 TVARAM CATE GORY: Category 2	Advises Connections to Vesting of the US State Vertices Connections to Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State Vesting of the US State <td>NY</td> <td></td> <td></td> <td></td> <td>er K</td> <td>and</td> <td>_</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>	NY				er K	and	_							
Obvious Connections to Hull I. H. Interfet I. I. Ves No Weterbody/Watershed; Headwater of umamed drainage (WWC) to Town Creek: (Interfet Ghells/State? Obvious Connections to Hull I. H. Interfet I. I. Ves No Weterbody/Watershed; Headwater of umamed drainage (WWC) to Town Creek: (Tennessee River-Guntersville Reservoir) Official Scatter Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Interfet of Wetland and Other Comments; (i.e. Sprest are class; labbiat feature; indrake; precipitation of the wetland outside of or adjaced Other 3 Precipitation Other	Obvious Cannections to water of the US State? Yes No Waterbody/Watershed. Headwater of urnamed. drainage (WWC) to Town Creek. (Tennessee River-Curtersville Reservoir) Primary Water Source (Induer, note in comments) Yes No Waterbody/Watershed. Headwater of urnamed. drainage (WWC) to Town Creek. (Tennessee River-Curtersville Reservoir) Primary Water Source (Induer, note in comments) 3 TVARAM CATE GORY: Category 2 Description of Welland and Other Comments (See Service) and waterbody area (See Service) 3 TVARAM CATE GORY: Category 2 3 TVARAM CATE GORY: Category 2 Description of Welland and Other Comments (See Service) and waterbody area (See Service) are inside construction footprint): It will also be affected by another and to stellar of the set and incuble assembly area (See Service) area (See Service). Strail area of forested welland, partially interseds poterful construction area (See Service) area inside construction footprint): It will also be affected by another (See Service). Strail area of forested welland, partially interseds poterful construction area (See Service). Strail area of forested welland, partially interseds poterful construction area (See Service). Strail area of insetted welland, partially interseds poterful construction area (See Service). Strail area of insetted welland, partially intersed poterful construction area (See Service). Strail area of insetted welland, partially intersed poter			15	1										
Obvious Connections to Hull I. H. Interfet I. I. Ves No Weterbody/Watershed; Headwater of umamed drainage (WWC) to Town Creek: (Interfet Ghells/State? Obvious Connections to Hull I. H. Interfet I. I. Ves No Weterbody/Watershed; Headwater of umamed drainage (WWC) to Town Creek: (Tennessee River-Guntersville Reservoir) Official Scatter Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Interfet of Wetland and Other Comments; (i.e. forest are class; labitat feature; indrake; precipitation of the wetland outside of or adjaced 0 Other 0	Obvious Cannections to water of the US State? Yes No Waterbody/Watershed. Headwater of urnamed. drainage (WWC) to Town Creek. (Tennessee River-Curtersville Reservoir) Primary Water Source (Induer, note in comments) Yes No Waterbody/Watershed. Headwater of urnamed. drainage (WWC) to Town Creek. (Tennessee River-Curtersville Reservoir) Primary Water Source (Induer, note in comments) 3 TVARAM CATE GORY: Category 2 Description of Welland and Other Comments (See Service) and waterbody area (See Service) 3 TVARAM CATE GORY: Category 2 3 TVARAM CATE GORY: Category 2 Description of Welland and Other Comments (See Service) and waterbody area (See Service) are inside construction footprint): It will also be affected by another and to stellar of the set and incuble assembly area (See Service) area (See Service). Strail area of forested welland, partially interseds poterful construction area (See Service) area inside construction footprint): It will also be affected by another (See Service). Strail area of forested welland, partially interseds poterful construction area (See Service). Strail area of forested welland, partially interseds poterful construction area (See Service). Strail area of insetted welland, partially interseds poterful construction area (See Service). Strail area of insetted welland, partially intersed poterful construction area (See Service). Strail area of insetted welland, partially intersed poter		i	M						·	A I				
Obvious Connections to Hull I. H. Interfet I. I. Ves No Weterbody/Watershed; Headwater of umamed drainage (WWC) to Town Creek: (Interfet Ghells/State? Obvious Connections to Hull I. H. Interfet I. I. Ves No Weterbody/Watershed; Headwater of umamed drainage (WWC) to Town Creek: (Tennessee River-Guntersville Reservoir) Official Scatter Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Interfet of Wetland and Other Comments; (i.e. forest are class; labitat feature; indrake; precipitation of the wetland outside of or adjaced 0 Other 0	Obvious Cannections to water of the US State? Yes No Waterbody/Watershed. Headwater of urnamed. drainage (WWC) to Town Creek. (Tennessee River-Curtersville Reservoir) Primary Water Source (Induer, note in comments) Yes No Waterbody/Watershed. Headwater of urnamed. drainage (WWC) to Town Creek. (Tennessee River-Curtersville Reservoir) Primary Water Source (Induer, note in comments) 3 TVARAM CATE GORY: Category 2 Description of Welland and Other Comments (See Service) and waterbody area (See Service) 3 TVARAM CATE GORY: Category 2 3 TVARAM CATE GORY: Category 2 Description of Welland and Other Comments (See Service) and waterbody area (See Service) are inside construction footprint): It will also be affected by another and to stellar of the set and incuble assembly area (See Service) area (See Service). Strail area of forested welland, partially interseds poterful construction area (See Service) area inside construction footprint): It will also be affected by another (See Service). Strail area of forested welland, partially interseds poterful construction area (See Service). Strail area of forested welland, partially interseds poterful construction area (See Service). Strail area of insetted welland, partially interseds poterful construction area (See Service). Strail area of insetted welland, partially intersed poterful construction area (See Service). Strail area of insetted welland, partially intersed poter	3/H	Ľ	Ý					,	١.	\geq				
Obvious Connections to Hull I. H. Interfet I. I. Ves No Weterbody/Watershed; Headwater of umamed drainage (WWC) to Town Creek: (Interfet Ghells/State? Obvious Connections to Hull I. H. Interfet I. I. Ves No Weterbody/Watershed; Headwater of umamed drainage (WWC) to Town Creek: (Tennessee River-Guntersville Reservoir) Official Scatter Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other IVARAM SCORE: 35 TVARAM CATEGORY: Cetagory 2 Cetagory 2	Obvious Cannections to water of the US State? Yes No Waterbody/Watershed. Headwater of urnamed. drainage (WWC) to Town Creek. (Tennessee River-Curtersville Reservoir) Primary Water Source (Induer, note in comments) Yes No Waterbody/Watershed. Headwater of urnamed. drainage (WWC) to Town Creek. (Tennessee River-Curtersville Reservoir) Primary Water Source (Induer, note in comments) 3 TVARAM CATE GORY: Category 2 Description of Welland and Other Comments (See Service) and waterbody area (See Service) 3 TVARAM CATE GORY: Category 2 3 TVARAM CATE GORY: Category 2 Description of Welland and Other Comments (See Service) and waterbody area (See Service) are inside construction footprint): It will also be affected by another and to stellar of the set and incuble assembly area (See Service) area (See Service). Strail area of forested welland, partially interseds poterful construction area (See Service) area inside construction footprint): It will also be affected by another (See Service). Strail area of forested welland, partially interseds poterful construction area (See Service). Strail area of forested welland, partially interseds poterful construction area (See Service). Strail area of insetted welland, partially interseds poterful construction area (See Service). Strail area of insetted welland, partially intersed poterful construction area (See Service). Strail area of insetted welland, partially intersed poter	1 AN	ß			1.55	here is	1.00	1. Alchy	6.	\geq				
Obvious Connections to Yes No Waterbody/Watershed! Headwater of urnamed drainage (WWC) to Town Creek: Obvious Connections to Yes No Waterbody/Watershed! Headwater of urnamed drainage (WWC) to Town Creek: Officient structure Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Interse of the US/State? Yes No Waterbody/Watershed! Headwater of urnamed drainage (WWC) to Town Creek: Officient State? Yes No Waterbody/Watershed! Headwater of urnamed drainage (WWC) to Town Creek: Officient State? Yes No Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Interse of Wetland and Other Comments: Size for stage class: hobitat features: hydrologic regime: description of the webaid outside of or adjaces Size for stage class: hobitat features: hydrologic regime: description of the webaid outside of or adjaces	Onvious Connections to units, when the second se		¥		ALU.	NY AL	A	134-1	+ UNSURLING		$\langle \rangle$	-			
Obvious Connections to Naters of the US /State? Yes No Waterbody/Watershed: Headwater of urnamed drainage (VWC) to Town Creek: (Tennessee River-Guntersville Reservoir) Obvious Connections to Naters of the US /State? Yes No Waterbody/Watershed: Headwater of urnamed drainage (VWC) to Town Creek: (Tennessee River-Guntersville Reservoir) Onimary Water Source If other, note in comments) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other	Onvious Connections to waters of the US/State? Yes No Watershody/Watershed: Headweter of urnamed drainage (WWC) to Town Creek: (Irinnessee River-Gurtersville Reservoir) Onvious Connections to waters of the US/State? Yes No Watershody/Watershed: Headweter of urnamed drainage (WWC) to Town Creek: (Irinnessee River-Gurtersville Reservoir) Primary Water Source (Iritere, note in commerts) Cap. Fringe Overbanking 2 Sheet Flow 1 Croundwater 3 Precipitation Other Other TVARAM SCORE: 35 TVARAM CATE GORY; Cetegory 2 Cetegory 2 Description of Wetland and Other Commerts: (La: Spreet Rage Law;) habitat faature; i hydrologic regime; description of the wetland outdate of or adjacer to ROW; exvising obmidal, existing disturbances, adjacert age Law; habitat faature; i hydrologic regime; description of the wetland outdate of or adjacer to ROW; exvising obmidal, existing disturbances, adjacert age claw; habitat faature; i hydrologic regime; description of the wetland outdate of or adjacer to ROW; exvising obmidal, existing disturbances, adjacert age claw; habitat faature; i hydrologic regime; description of the wetland outdate of or adjacer to ROW; exvising obmidal, existing disturbances, adjacert age claw; habitat faature; i hydrologic regime; description of the wetland outdate of or adjacer to ROW; exvising obmidal, existing disturbances, adjacert age claw; habitat faature; i hydrologic regime; description of the wetland outdate of or adjacer to ROW; exvising obmidal, existing disturbances, adjacer in wetershed Simal area of forestid voltand v002 by					1	$(\times 5)$	$\langle y \rangle$	TEACTURE	ieriity	\sim				
Obvious Connections to Naters of the US /State? Yes No Waterbody/Watershed: Headwater of urnamed drainage (VWC) to Town Creek: (Tennessee River-Guntersville Reservoir) Obvious Connections to Naters of the US /State? Yes No Waterbody/Watershed: Headwater of urnamed drainage (VWC) to Town Creek: (Tennessee River-Guntersville Reservoir) Onimary Water Source If other, note in comments) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other	Onvious Connections to waters of the US/State? Yes No Watershody/Watershed: Headweter of urnamed drainage (WWC) to Town Creek: (Irinnessee River-Gurtersville Reservoir) Onvious Connections to waters of the US/State? Yes No Watershody/Watershed: Headweter of urnamed drainage (WWC) to Town Creek: (Irinnessee River-Gurtersville Reservoir) Primary Water Source (Iritere, note in commerts) Cap. Fringe Overbanking 2 Sheet Flow 1 Croundwater 3 Precipitation Other Other TVARAM SCORE: 35 TVARAM CATE GORY; Cetegory 2 Cetegory 2 Description of Wetland and Other Commerts: (La: Spreet Rage Law;) habitat faature; i hydrologic regime; description of the wetland outdate of or adjacer to ROW; exvising obmidal, existing disturbances, adjacert age Law; habitat faature; i hydrologic regime; description of the wetland outdate of or adjacer to ROW; exvising obmidal, existing disturbances, adjacert age claw; habitat faature; i hydrologic regime; description of the wetland outdate of or adjacer to ROW; exvising obmidal, existing disturbances, adjacert age claw; habitat faature; i hydrologic regime; description of the wetland outdate of or adjacer to ROW; exvising obmidal, existing disturbances, adjacert age claw; habitat faature; i hydrologic regime; description of the wetland outdate of or adjacer to ROW; exvising obmidal, existing disturbances, adjacert age claw; habitat faature; i hydrologic regime; description of the wetland outdate of or adjacer to ROW; exvising obmidal, existing disturbances, adjacer in wetershed Simal area of forestid voltand v002 by	KU.	l		/	S.		3-1-	21,1-22,03-0		war				
With and the state of the US /State? Yes No Waterbody/Watershed: Headwater of urnamed drainage (WWC) to Town Creek: US with and the state? Obvious Connections to Not state? Yes No Waterbody/Watershed: Headwater of urnamed drainage (WWC) to Town Creek: US with and the state? Obvious Connections to Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Other of Wetland and Other Comments: 35 TVARAM CATE GORY: Category 2 Category 2	Within the second se		\leq	بر ابتر	104	بر درمین مردمین	×03	- i - i	Mrs.LI Vacillein		~				
Willing	With with the start is the		\mathbb{S}	X	12	Ž	The second se		Vector						
Image: And States Yes No Waterbody/Watershed: Headwater of urnamed drainage (WWC) to Town Creek: (Tennessee River-Guntersville Reservoir) Primary Water Source (I other, note in comments) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other (IVARAM SCORE: 35 TVARAM CATE GORY: Category 2 Description of Wetland and Other Comments: (i.e. Sprest are class; habitat features; hydrologic regime; description of the wetland outside of or adjaced	Christer of the US State? Yes No Waterbody/Watershed; Headwater of urnamed drainage (WWC) to Town Creek: Maters of the US State? Primary Water Source (In the commerties) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Other Source Primary Water Source (In the r, note in commerties) 35 TVARAM CATE GORY: Category 2 Description of Wetland and Other Commerts: (Le. Spreet age class; labitat features; hydrologic regime; description of the wetland outside of or a djacer or ROW; servis mpioential, existing disturbance; adjacert age class; labitat features; hydrologic regime; description of the wetland outside of or a djacer or ROW; servis mpioential, existing disturbance; adjacert age (-0.25 acre inside construction footprint): It will also be affected by arroposed haul road to site and module assembly areas: Atelland is connected to Wetland W02 by wet weather conveyance but higher in watershed 2possible smill seep near southern edge	5. 14	imes	۲ <u>چ</u> ۲	N. N.	/	in the second		per -						
Image: And States Yes No Waterbody/Watershed: Headwater of urnamed drainage (WWC) to Town Creek: (Tennessee River-Guntersville Reservoir) Primary Water Source (I other, note in comments) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other (IVARAM SCORE: 35 TVARAM CATE GORY: Category 2 Description of Wetland and Other Comments: (i.e. Sprest are class; habitat features; hydrologic regime; description of the wetland outside of or adjaced	Christer of the US State? Yes No Waterbody/Watershed; Headwater of urnamed drainage (WWC) to Town Creek: Maters of the US State? Primary Water Source (In the commerties) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Other Source Primary Water Source (In the r, note in commerties) 35 TVARAM CATE GORY: Category 2 Description of Wetland and Other Commerts: (Le. Spreet age class; labitat features; hydrologic regime; description of the wetland outside of or a djacer or ROW; servis mpioential, existing disturbance; adjacert age class; labitat features; hydrologic regime; description of the wetland outside of or a djacer or ROW; servis mpioential, existing disturbance; adjacert age (-0.25 acre inside construction footprint): It will also be affected by arroposed haul road to site and module assembly areas: Atelland is connected to Wetland W02 by wet weather conveyance but higher in watershed 2possible smill seep near southern edge	willing y		A.	_Χ	Nr.	/ -	U UPLI	174) 1111				*		
Image: And States Yes No Waterbody/Watershed: Headwater of urnamed drainage (WWC) to Town Creek: (Tennessee River-Guntersville Reservoir) Primary Water Source (I other, note in comments) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other (IVARAM SCORE: 35 TVARAM CATE GORY: Category 2 Description of Wetland and Other Comments: (i.e. Sprest are class; habitat features; hydrologic regime; description of the wetland outside of or adjaced	Christer of the US State? Yes No Waterbody/Watershed; Headwater of urnamed drainage (WWC) to Town Creek: Maters of the US State? Primary Water Source (In the commerties) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other Other Source Primary Water Source (In the r, note in commerties) 35 TVARAM CATE GORY: Category 2 Description of Wetland and Other Commerts: (Le. Spreet age class; labitat features; hydrologic regime; description of the wetland outside of or a djacer or ROW; servis mpioential, existing disturbance; adjacert age class; labitat features; hydrologic regime; description of the wetland outside of or a djacer or ROW; servis mpioential, existing disturbance; adjacert age (-0.25 acre inside construction footprint): It will also be affected by arroposed haul road to site and module assembly areas: Atelland is connected to Wetland W02 by wet weather conveyance but higher in watershed 2possible smill seep near southern edge	faction and			A.S.	Å	·	,			Б		1		
Obvious Connections to Maters of the US/State? Yes No Waterbody/Watershed: Headwater of urnamed drainage (WWC) to Town Creek: (Tennessee River-Guntersville Reservoir) Primary Water Source (If other, note in comments) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other (VARAM SCORE: 35 TVARAM CATE GORY: Category 2 Category 2 <td< td=""><td>Obvious Connections to Yes No Waterbody/Watershed; Headwater of urnamed drainage (WWC) to Town Creek: (Tennessee River-Guntersville Reservoir) Primary Water Source (I other, note in comments) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other IVARAM SCORE: 35 TVARAM CATEGORY: Category 2 Category 2 Description of Wetland and Other Comments: (Se. Sarest age class; habitat faatures; hydrologic regime; description of the wetland outside of or adjacer to ROW; environgetendial, existing disturbance, adjacer hard us, widthe observations, station numbers, lat long etc) Simal area of forested wetland; partially intersects potential construction area (-0.25 acre inside construction footprint): It will also be affected by aroposed haul road to site and module assembly areas: Wetland is connected to Wetland Wull by wet weather conveyance but higher in watershed Possible small seep near southern edge Sature Sa</td><td>U</td><td></td><td></td><td>~</td><td>للمست</td><td>NA -</td><td>\sim</td><td>a change</td><td>លទស</td><td>(NA) FURE</td><td>i</td><td>r</td><td></td><td></td></td<>	Obvious Connections to Yes No Waterbody/Watershed; Headwater of urnamed drainage (WWC) to Town Creek: (Tennessee River-Guntersville Reservoir) Primary Water Source (I other, note in comments) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other IVARAM SCORE: 35 TVARAM CATEGORY: Category 2 Category 2 Description of Wetland and Other Comments: (Se. Sarest age class; habitat faatures; hydrologic regime; description of the wetland outside of or adjacer to ROW; environgetendial, existing disturbance, adjacer hard us, widthe observations, station numbers, lat long etc) Simal area of forested wetland; partially intersects potential construction area (-0.25 acre inside construction footprint): It will also be affected by aroposed haul road to site and module assembly areas: Wetland is connected to Wetland Wull by wet weather conveyance but higher in watershed Possible small seep near southern edge Sature Sa	U			~	للمست	NA -	\sim	a change	លទស	(NA) FURE	i	r		
Waters of the US/State? Yes No (Tennessee River-Guntersville Reservoir) Primary Water Source (If other, note in comments) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other (VARAM SCORE: 35 TVARAM CATE GORY: Category 2 Category 2 Category 2	Wateris of the US/State? Yes NO (Tennessee River-Guntersville Reservoir) Primary Water Source (1 other, note in cominents) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other IVARAM SCORE: 35 TVARAM CATEGORY: Cetegory 2 Cetegory 2 Description of Wetland and Other Comments: (Le. Sprest age class; Jub/itst faatures; Judrologic regime; description of the wetland outside of or adjacer to ROW; evolve objected wetland; partially intersects potential construction area (÷0.25 acre inside construction footprint): It will also be affected by decorposed hau road to site and module assembly areas: Simall area of forested wetland; partially intersects potential construction area (÷0.25 acre inside construction footprint): It will also be affected by decorposed hau road to site and module assembly areas: Vettand is connected to Wetland WO2 by wet weather conveyance but higher in watershed Precipitation of the wetland word by wetwatter conveyance but higher in watershed	s - Jalistet et	inten	16.6			10	<u>w ; r</u>	X)	<u>9</u> }	N In				
Waters of the US/State? Yes No (Tennessee River-Guntersville Reservoir) Primary Water Source (If other, note in comments) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other (VARAM SCORE: 35 TVARAM CATE GORY: Category 2 Category 2 Category 2	Wateris of the US/State? Yes NO (Tennessee River-Guntersville Reservoir) Primary Water Source (1 other, note in cominents) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other IVARAM SCORE: 35 TVARAM CATEGORY: Cetegory 2 Cetegory 2 Description of Wetland and Other Comments: (Le. Sprest age class; Jub/itst faatures; Judrologic regime; description of the wetland outside of or adjacer to ROW; evolve objected wetland; partially intersects potential construction area (÷0.25 acre inside construction footprint): It will also be affected by decorposed hau road to site and module assembly areas: Simall area of forested wetland; partially intersects potential construction area (÷0.25 acre inside construction footprint): It will also be affected by decorposed hau road to site and module assembly areas: Vettand is connected to Wetland WO2 by wet weather conveyance but higher in watershed Precipitation of the wetland word by wetwatter conveyance but higher in watershed														
Primary Water Source (If other, note in comments) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other (VARAM SCORE: 35 TVARAM CATE GORY: Category 2 C	Primary Water Source (1 other, note in comments) Cap. Fringe Overbanking 2 Sheet Flow 1 Groundwater 3 Precipitation Other TVARAM SCORE: 35 TVARAM CATEGORY: Category 2 Category 2 Description of Wetland and Other Comments: (i.e. farest age class; habitat features; hydrologic regime; description of the wetland outside of or adjacer to ROW; exciton potential, existing disturbances, adjacent land use, wildlife observations, station numbers, lat long, etc) Simall area of forested wetland; partially intersects potential construction area (÷0.25 acre inside construction footprint): It will also be affected by areas Avettand is connected to Vetland W02 by wet weather conveyance but higher in watershed Precipiter in watershed Possible small seep near southern edge. Simal seep near southern edge. Simal seep near southern edge.	Obvious Connections to Waters of the US (State?	Г	Yes	; 	No						(vw	VC) to Town Cre	ek'	
IVARAM SCORE: 35 TVARAM CATEGORY: Category 2 Description of Wetland and Other Comments: (i.e. forest age class : habitat features : hydrologic regime: description of the wetland outside of or adjace	TVARAM SCORE: 35 TVARAM CATEGORY: Cetegory 2 Description of Wetland and Other Commerts: (i.e. forest age class; habitat features; hydrologic regime; description of the wetland outside of or adjacer to ROW; exclosion potential, existing disturbances, adjacent land use, wildlife observations, station numbers, lat long, etc) Sinall area of forested wetland; partially intersects potential construction area (+0.25 acre inside construction footprint): It will also be affected by areas Apetland is connected to Wetland W02 by wet weather conveyance but higher in watershed Possible small seep near southern edge.	Primary Water Source (If other, note in comments)	Π	Ċa	p. Fring	ge			L .	1		3	Precipitation	0	ther
escription of Wetland and Other Comments: (i.e. forest age class; habitat features; hydrologic regime; description of the wetland outside of or adjacer	Description of Wetland and Other Commerts: (i.e. forest age class; habitat features; hydrologic regime; description of the wetland outside of or adjacer to ROW; exotony of antial, existing disturbances, adjacent land use wildlife observations, station numbers, lat long etc) Small area of forested wetland; partially intersects potential construction area (÷0.25 acre inside construction footprint): It will also be affected by proposed heul road to site and module assembly areas Metland is connected to Wetland W02 by wet weather conveyance but higher in watershed Possible small seep near southern edge.	A	\vdash	25				T '		<u> </u>		L .	•		
なっていまいがいないができる「「「「「「「「」」」」、「「」」、「」」、「」」「「「「「」」」」、「「」」、「「」」、「」」、「」」「」」	to ROW; exclong otential, existing disturbancer, adjacent land use, wildlife observations, station numbers, lat long, etc) Small area of forested wetland; partially intersects potential construction area (÷0.25 acre inside construction footprint): It will also be affected by proposed haul road to site and in odule assembly areas Wetland is connected to Wetland VV02 by wet weather conveyance but higher in watershed possible small seep near southern edge.	IVARAM SCORE:		33	I IVA	RAMO	CATEGORY:	Catego	iry 2						
	^z össible small seep néar southém edge.	Description of Wetland and Oth to ROW; crosion potential, existin	ıg dist	iurban	ents: (ices, ad	ie for jacent	estage class; ha land use, wildli	bitat feat fe observ	aries; hydrologic ations, station nu	mber	s, lat long, etc)				cer
proposed haul road to site and module assembly areas		Description of Wetland and Oth to ROW; exclosion potential, existin Small area of forested wetland; p proposed haul road to site and m	n g dist Dartiall	turban Iyinter	ents:(nces, ad; rsects mbly a	ie for jacent potenti reas	estage class; ha land use, wildli ial construction	binatfean feobserv area (∻C	ures; hydrologic adors, station nu 1.25 acre inside c	mber	s, lat long, etc)				٢ēī
proposed haul road to site and module assembly areas Netland is connected to Wetland W02 by wet weather conveyance but higher in watershed		Description of Wetland and Oth to ROW; evolvango endial, evision Sinall, area of forested wetland; p. proposed haul road to site and m. Wetland is connected to Wetland	ig dist partiall odulé I VV02	turban Iyinter asse 2 by we	ents:(nces, ad; rsects mbly a	ie for jacent potenti reas	estage class; ha land use, wildli ial construction	binatfean feobserv area (∻C	ures; hydrologic adors, station nu 1.25 acre inside c	mber	s, lat long, etc)				céi
proposed haul road to site and module assembly areas Netland is connected to Wetland W02 by wet weather conveyance but higher in watershed		Description of Wetland and Oth to ROW; evolopiotential, evident Sinall area of forested wetland; p proposed haul road to site and m Wetland is connected to Wetland	ig dist partiall odulé I VV02	turban Iyinter asse 2 by we	ents:(nces, ad; rsects mbly a	ie for jacent potenti reas	estage class; ha land use, wildli ial construction	binatfean feobserv area (∻C	ures; hydrologic adors, station nu 1.25 acre inside c	mber	s, lat long, etc)				ren
proposed haul road to site and module assembly areas Netland is connected to Wetland W02 by wet weather conveyance but higher in watershed		to ROW; evolution potential, existing Small area of forested vetland; p proposed hau road to site and m Wetland is connected to Wetland	ig dist partiall odulé I VV02	turban Iyinter asse 2 by we	ents:(nces, ad; rsects mbly a	ie for jacent potenti reas	estage class; ha land use, wildli ial construction	binatfean feobserv area (∻C	ures; hydrologic adors, station nu 1.25 acre inside c	mber	s, lat long, etc)				cen
proposed haul road to site and module assembly areas Wetland is connected to Wetland W02 by wet weather conveyance but higher in watershed possible small seep near southern edge.		Description of Wetland and Ott to ROW; evolopionential, evident Small area of forested wetland; p proposed haul road to site and m Wetland is connected to Wetland	ig dist partiall odulé I VV02	turban Iyinter asse 2 by we	ents:(nces, ad; rsects mbly a	ie for jacent potenti reas	estage class; ha land use, wildli ial construction	bilat fear feolserv area (+0	uneși hydrologic ations, station nu 1.25 acre inside c watershed	mber	s, lat long, etc) uction footprint)	elt v			rën
proposed haul road to site and module assembly areas Wetland is connected to Wetland W02 by wet weather conveyance but higher in watershed possible small seep near southern edge.		Description of Wetland and Ott to ROW; evolopionential, evident Small area of forested wetland; p proposed haul road to site and m Wetland is connected to Wetland	ig dist partiall odulé I VV02	turban Iyinter asse 2 by we	ents:(nces, ad; rsects mbly a	ie for jacent potenti reas	estage class; ha land use, wildli ial construction	bilat fear feolserv area (+0	uneși hydrologic ations, station nu 1.25 acre inside c watershed	mber	s, lat long, etc) uction footprint)	elt v			cen
rroposed haul road to site and incidulé assembly areas Wetland is connected to Wetland W02 by wet weather conveyance but higher in watershed ossible small seep néar southern edge.		Description of Wetland and Ott to ROW; exciso no ential, existin Small area of forested wetland; p proposed haul road to site and in Wetland is connected to Wetland Possible small seep near souther	eg dist odulé I VV02 m ed <u>o</u>	turban liyintei asse by we ge	ents: () res, ad mbly a et weat	jacent potenti reas ther co	est age class ; ha land use, wildli al construction onveyance but i	bilat fear feolserv area (+0	uneși hydrologic ations, station nu 1.25 acre inside c watershed	mber	s, lat long, etc) uction footprint)	elt v			rën
rroposed haul road to site and incidulé assembly areas Wetland is connected to Wetland W02 by wet weather conveyance but higher in watershed ossible small seep néar southern edge.		Description of Wetland and Ott to ROW; exciso no ential, existin Small area of forested wetland; p proposed haul road to site and in Wetland is connected to Wetland Possible small seep near souther	eg dist odulé I VV02 m ed <u>o</u>	turban liyintei asse by we ge	ents: () res, ad mbly a et weat	jacent potenti reas ther co	est age class ; ha land use, wildli al construction onveyance but i	bilat fear feolserv area (+0	uneși hydrologic ations, station nu 1.25 acre inside c watershed	mber	s, lat long, etc) uction footprint)	elt v			cên
vertand is connected to Ste and module assembly areas Wetland is connected to Wetland W02 by wet weather conveyance but higher in watershed possible small seep near southern edge.		Description of Wetland and Ott to ROW; exciso no ential, existin Small area of forested wetland; p proposed haul road to site and in Wetland is connected to Wetland Possible small seep near souther	eg dist odulé I VV02 m ed <u>o</u>	turban liyintei asse by we ge	ents: () res, ad mbly a et weat	jacent potenti reas ther co	est age class ; ha land use, wildli al construction onveyance but i	bilat fear feolserv area (+0	uneși hydrologic ations, station nu 1.25 acre inside c watershed	mbier constr	s, lat long, etc) ruction footprint)	elt v			cê,
vertand is connected to Ste and module assembly areas Wetland is connected to Wetland W02 by wet weather conveyance but higher in watershed possible small seep near southern edge.		Description of Wetland and Ott to ROW; evolution provential, existin Small area of forested wetland; pr proposed haul road to site and in Wetland is connected to Wetland Possible small seep near souther	eg dist odulé I VV02 m ed <u>o</u>	turban liyintei asse by we ge	ents: () res, ad mbly a et weat	jacent potenti reas ther co	est age class ; ha land use, wildli al construction onveyance but i	bilat fear feolserv area (+0	uneși hydrologic ations, station nu 1.25 acre inside c watershed	mbier constr	s, lat long, etc) ruction footprint)	elt v			€. Ŝ

Project: Bellefonte NP REO 10389	Investigator: J. Groton, B. Dimick	Normal Circumstances:	у	Sample ID:	W004
County: Jackson		Atypical Situation:	n	Station or Structure Number(s):	
State: AL	Date: April 26, 2006	Problem Area:	n	Cowardin Code:	PFO1E

t

,	Plant Species	Stratum	Indicator		Plant Species	Stratum	Indicator
1.	Fraxinus pennsylvanica	Tr, Sh, 'Sap	Facw	9.	Nothoscordum bivalve	н	Fac
2.	Quercus phellos	Tr, , Sap	Facw-	10,	Galium aparine	н	Facu
3.	Ulmus emericane	Tr, Sh	Facw	11.	Diospyros virginiana	Sap	Fac
4.	Campsis radicans	Sap	Fac	12.	Toxicodendron radicans	WV, Sap	Fac
5.	Berchemia scandens	w	Facw	13.	Lycopus sp	н	Obl
6.	Ampelopsis arborea	Sap	Fac+	14.	Glyceria striata	н	Obl
· 7 :	liex decidua	Sh	Facŵ	15.	Several unidentified Carex species	н	
8.	Pinus laeda	Tr	Fac	16.	moss	н	-
Perc	ent of Dominant Species That are OBL, FAC	W, or FAC:	93%				

Hydrology

Field Observations:			Wetland Hydrology Indicators:			
Depth of Surface Water:	0-12	(in.)	Primary Indicators			Secondary Indicators
Depth to Free Water in Pit:	3	(in.)	y Inundated		Drift Lines	Oxidized Root Channels
Depth to Saturated Soil:	0	(in.)	y Saturated in Upper 12 in.		Water Marks	Water Stained Leaves
		•	Sediment Deposits	×	Drainage Patterns	

		· · · · · · · · · · · · · · · · · · ·	
Drain	age class:	Listed hydric soil?	Yes No
Matrix Color (Munsell Moist)	Mottle Colors (Munsell Moist)	Mottle Abundance	Texturé
10 YR 5/3	10 YR 5/6	Common	Silty clay loam
10.YR 6/2	10 YR 5/6	Common	Silty clay loam
10 YR 6/1	10 YR 5/6	Common	Silty clay loam
3:			
Chroma Colors	Histic Epipedon	Aquic Mo	ísture Regime
•	High Organic Cont. Surf. Layer Sa	andy Soils Y Reducing	Conditions
	Organic Streaking in Sandy Soils	Other (Ex	plain in Remarks)
	Matrix Color (Munsell Moist) 10 YR 5/3 10 YR 6/2 10 YR 6/1	10 YR 5/3 10 YR 5/6 10 YR 6/2 10 YR 5/6 10 YR 6/1 10 YR 5/6 5:	Matrix Color (Munsell Moist) Mottle Colors (Munsell Moist) Mottle Abundance 10 YR 5/3 10 YR 5/8 Common 10 YR 6/2 10 YR 5/6 Common 10 YR 6/1 10 YR 5/6 Common 10 YR 6/1 10 YR 5/6 Common St

neuanu Determination	,								
Hydrophylic Vegetation Present?	Yes	, Y	No	<u> </u>	Is this Sampling Point Within a USACE Wetland?	Yes	Y	No	
Wetland Hydrology Present?	Yes	Y	No		Does area only meet USFWS wetland definition?	Yes		No	Ň
Hydric Soils Present?	Yes	Y	No		Is wetland mapped on NWI?	Yes		No	N
Estimated size: 1.81 acres									

Wetland Descriptors	1.01	D(_)_ (***)							4
Sample ID, V/004	Photo I	U(8): V(0)-	TW (nonthern er	36), WEU-2M	(center of well	Haref), VVQ14-3/V	(southern)	ean)	
Flagging Description: 1-48 clo	cloviso inor	n norsteast (corner		·				
Drawing			· · · · · · · · · · · · · · · · · · ·					····	
Please Include: North Arrow, Pr	riject Centr	erine, Surve	y Comidar Boun	daries, Lenj	th of Watland i	Feature, Distan	ces from Ç	entenine, Photo	Localions
Λ				12.00				•	
		مستعصية فالمستحرين	Ter-	LENG Rand	vole drawing	an a sure a sure of the sure o	**************************************	n	
N.	-	هية بمرجم الماجين	وسیب اردامین او		alle starry	he clide h			·
1 4	د. المجمع من المعلم المجمع من	*		•					Tomas and the
and the second sec	and the second se				,		1	Sel.	
and the second second		18	*		orthe		1		
and the second second		т т т		1) 1		/	
and the second					(110)	1	11		
1			11	772			1		
•			, r,	ا مندر ماروموزی	- V				ŧ
	•		1 2-						. •
			- al s	+ e \$4 9 \$		/		à	
		1	· · · ·		-1-1-		***		
		1	- and	har -	A	2		م الألية	
		i.	- 34 G	1		2			
		۲۰	<u> </u>	-1.				e 📲	
			· ·				ند		
							· ·		
	Ferr	1		میں اور منبع	 2.			•	
	FER	<u>त</u>	مسیعر	- W					
Obvious Connections to Waters of the US/State?	Y You	<u> </u>			. Unnamed d	Irainape (VWVC	.) <u>to Tow</u>	n Craw: (Tennes	ssee River-
Obvious Connections to	Y Y01	a filo		//Watershed le Reservoir	. Unnamed d	trainapa (WWC	<u> </u>	n Creek (Tennes Precipitation	isee River- Other
Obvious Connections to Waters of the US/State? Primary Water Source	Y Y01	a filo ap Fauxpa	Guntersv#	//Watershed le Reservoir	Unnamed of Sheet Flow		<u> </u>	<u> </u>	<u>r</u>
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE; Description of Wetland and Ot	Y Yen Či S5 her, Comm	i filo ip Filoge TVARAM	2 Overbani 2 Overbani CATEGORY:	Wätershed le Reservetr uty 1 Category abbast featur	Unnamed of Sileet Flow 2 s; hydrollegic r	Giðunikyð	iệi 3 mì of the ŵ	Precipitation	Othéi
Obvious Connections to Waters of the US/State? Primary Water Source (If Other, note in comments)	Y Yos Ci S5 her Comm g disturbit	ip Fartie TVARAM enter (Ln. Fo ices, adjacen	2 Overbent 2 Overbent CATEGORY: nest age class; he hand use, wild it	Wätershed le Reservetr uty 1 Category abbast featur	Unnamed of Sileet Flow 2 s; hydrollegic r	Giðunikyð	iệi 3 mì of the ŵ	Precipitation	Othéi
Obvious Connections to Waters of the US/State? Primary Water Source (if other, note in comments) TVARAM SCORE; Description of Wetland and Ott is ROW; restan parential, existin Young tensized wetland tomedia No evidence of benear	Y Yeş Čt S5 her Comm g disturbat n tioodad ç	Farvie IP Farvie TVARAM opta: (Lr. Fo inces, adjacen trainageway	2 Overban 2 Overban CATEGORY: rest age class; he r land use, wild it	Wätershed le Reservetr uty 1 Category abbast featur	Unnamed of Sileet Flow 2 s; hydrollegic r	Giðunikyð	iệi 3 mì of the ŵ	Precipitation	Othéi
Obvious Connections to Waters of the US/State? Primary Water Source (if other, note in comments) TVARAM SCORE; Description of Welland and Ot to ROW: prostar patential, existin Young tarssted welland tormed in No evidence of borror Welland chans into droinage date Uninage is impeded where wella	Y You Ci 55 her Comm g disturbut n tioodad ci h beside p hisd W04 w	i fic ip Furyja TVARAM ienta: (Lr. fo ikies, adjacen trainageway ermistor roa dorogets with	Overban Overban Overban CATEGORY: rest age class; his land use, wildb	AWatershed le Reservats arty 1 Category abinst featur ife observation	Sineel Flow Sineel Flow 2 rs: hydrobysk, r ms, statten num	Greundwa regime: descripti idens: lat-lung, e n ol pluccost cut	iệj 3 mi of the w te) vậnt	Prèciphalaon echina jours la cara	Othey or udjakmit
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in commanis) TVARAM SCORE; Description of Wetland and Oti to ROW; restin parential, existin Young torosted wetland formed it No evidence of boarsor Wetland chans into drainage date Drainage is impeded where well There are several shallow, linear result of a past attempt to drain o	Y You Či S5 heri Comm g disturbat n floodad ç hibeside p nicd W04 in ditchès în	p Finap p Finap TVARAM prite: (Lr. for kes, adjacentralinageway cransfor non domodis with line upper er	Overban Overban Overban CATEGORY: rest age class; his land use, wildb	AWatershed le Reservats arty 1 Category abinst featur ife observation	Sineel Flow Sineel Flow 2 rs: hydrobysk, r ms, statten num	Greundwa regime: descripti idens: lat-lung, e n ol pluccost cut	iệj 3 mi of the w te) vậnt	Prèciphalaon echina jours la cara	Othey or udjakmit
Obvious Connections to Waters of the US/State? Primary Water Source (if other, note in comments) TVARAM SCORE; Description of Wetland and Oth to ROW: prosting parential, existin young torsis diversity with a tormed by No evidence of beriver Wetland thems tree drollage date Drainage is impedied where with	Y You Či S5 heri Comm g disturbat n floodad ç hibeside p nicd W04 in ditchès în	p Finap p Finap TVARAM prite: (Lr. for kes, adjacentralinageway cransfor non domodis with line upper er	Overban Overban Overban CATEGORY: rest age class; his land use, wildb	AWatershed le Reservats arty 1 Category abinst featur ife observation	Sineel Flow Sineel Flow 2 rs: hydrobysk, r ms, statten num	Greundwa regime: descripti idens: lat-lung, e n ol pluccost cut	iệj 3 mi of the w te) vậnt	Prèciphalaon echina jours la cara	Othey or udjakmit
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE; Description of Wetland and Oti to ROW; restin parential, existin Young torssted wetland tomed if No evidence of boarse Wetland chans into drainage date Drainage is impaded where well There are several shallow, linear result of a past attempt to drain o	Y You Či S5 heri Comm g disturbat n floodad ç hibeside p nicd W04 in ditchès în	p Finap p Finap TVARAM prite: (Lr. for kes, adjacentralinageway cransfor non domodis with line upper er	Overban Overban Overban CATEGORY: rest age class; his land use, wildb	AWatershed le Reservats arty 1 Category abinst featur ife observation	Sineel Flow Sineel Flow 2 rs: hydrobysk, r ms, statten num	Greundwa regime: descripti idens: lat-lung, e n ol pluccost cut	iệj 3 mi of the w te) vậnt	Prèciphalaon echina jours la cara	Othey or udjakmit
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE; Description of Wetland and Oti to ROW; restin parential, existin Young torssted wetland tomed if No evidence of boarse Wetland chans into drainage date Drainage is impaded where well There are several shallow, linear result of a past attempt to drain o	Y You Či S5 heri Comm g disturbat n floodad ç hibeside p nicd W04 in ditchès în	p Finap p Finap TVARAM prite: (Lr. for kes, adjacentralinageway cransfor non domodis with line upper er	Overban Overban Overban CATEGORY: rest age class; his land use, wildb	AWatershed le Reservats arty 1 Category abinst featur ife observation	Sineel Flow Sineel Flow 2 rs: hydrobysk, r ms, statten num	Greundwa regime: descripti idens: lat-lung, e n ol pluccost cut	iệj 3 mi of the w te) vậnt	Prèciphalaon echina jours la cara	Othey or udjakmit
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE; Description of Wetland and Oti to ROW; proston parential, existin Young torssted wetland formed if No evidence of boarsor Wetland chains into drolinage date Drainage is impeded where well There are several shallow, linear result of a past attempt to drain o	Y You Či S5 heri Comm g disturbat n floodad ç hibeside p nicd W04 in ditchès în	p Finap p Finap TVARAM prite: (Lr. for kes, adjacentralinageway cransfor non domodis with line upper er	Overban Overban Overban CATEGORY: rest age class; his land use, wildb	AWatershed le Reservats arty 1 Category abinst featur ife observation	Sineel Flow Sineel Flow 2 rs: hydrobysk, r ms, statten num	Greundwa regime: descripti idens: lat-lung, e n ol pluccost cut	iệj 3 mi of the w te) vậnt	Prèciphalaon echina jours la cara	Othey or udjakmit
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE; Description of Wetland and Oti to ROW; restin parential, existin Young torssted wetland tomed if No evidence of boarse Wetland chans into drainage date Drainage is impaded where well There are several shallow, linear result of a past attempt to drain o	Y You Či S5 heri Comm g disturbat n floodad ç hibeside p nicd W04 in ditchès în	p Finap p Finap TVARAM prite: (Lr. for kes, adjacentralinageway cransfor non domodis with line upper er	Overban Overban Overban CATEGORY: rest age class; his land use, wildb	AWatershed le Reservats arty 1 Category abinst featur ife observation	Sineel Flow Sineel Flow 2 rs: hydrobysk, r ms, statten num	Greundwa regime: descripti idens: lat-lung, e n ol pluccost cut	iệj 3 mi of the w te) vậnt	Prèciphalaon echina jours la cara	Othey or udjakmit
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE; Description of Wetland and Oti to ROW; proston parential, existin Young torssted wetland formed if No evidence of boarsor Wetland chains into drolinage date Drainage is impeded where well There are several shallow, linear result of a past attempt to drain o	Y You Či S5 heri Comm g disturbat n floodad ç hibeside p nicd W04 in ditchès în	p Finap p Finap TVARAM prite: (Lr. for kes, adjacentralinageway cransfor non domodis with line upper er	Overban Overban Overban CATEGORY: rest age class; his land use, wildb	AWatershed le Reservats arty 1 Category abinst featur ife observation	Sineel Flow Sineel Flow 2 rs: hydrobysk, r ms, statten num	Greundwa regime: descripti idens: lat-lung, e n ol pluccost cut	iệj 3 mi of the w te) vậnt	Prèciphalaon echina jours la cara	Othey or udjakmit
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE; Description of Wetland and Oti to ROW; proston parential, existin Young torssted wetland formed if No evidence of boarsor Wetland chains into drolinage date Drainage is impeded where well There are several shallow, linear result of a past attempt to drain o	Y You Či S5 heri Comm g disturbat n floodad ç hibeside p nicd W04 in ditchès în	p Finap p Finap TVARAM prite: (Lr. for kes, adjacentralinageway cransfor non domodis with line upper er	Overban Overban Overban CATEGORY: rest age class; his land use, wildb	AWatershed le Reservats arty 1 Category abinst featur ife observation	Sineel Flow Sineel Flow 2 rs: hydrobysk, r ms, statten num	Greundwa regime: descripti idens: lat-lung, e n ol pluccost cut	iệj 3 mi of the w te) vậnt	Prèciphalaon echina jours la cara	Othey or udjakmit
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE; Description of Wetland and Oti to ROW; proston parential, existin Young torssted wetland formed if No evidence of boarsor Wetland chains into drolinage date Drainage is impeded where well There are several shallow, linear result of a past attempt to drain o	Y You Či S5 heri Comm g disturbat n floodad ç hibeside p nicd W04 in ditchès în	p Finap p Finap TVARAM prite: (Lr. for kes, adjacentralinageway cransfor non domodis with line upper er	Overban Overban Overban CATEGORY: rest age class; his land use, wildb	AWatershed le Reservats arty 1 Category abinst featur ife observation	Sineel Flow Sineel Flow 2 rs: hydrobysk, r ms, statten num	Greundwa regime: descripti idens: lat-lung, e	iệj 3 mi of the w te) vậnt	Prèciphalaon echina jours la cara	Othey or udjakmit
Obvious Connections to Waters of the US/State? Primary Water Source (If other, note in comments) TVARAM SCORE; Description of Wetland and Oti to ROW; restin parential, existin Young torssted wetland tomed if No evidence of boarse Wetland chans into drainage date Drainage is impaded where well There are several shallow, linear result of a past attempt to drain o	Y You Či S5 heri Comm g disturbat n floodad ç hibeside p nicd W04 in ditchès în	p Finap p Finap TVARAM prite: (Lr. for kes, adjacentralinageway cransfor non domodes with line upper er	Overban Overban Overban CATEGORY: rest age class; his land use, wildb	AWatershed le Reservats arty 1 Category abinst featur ife observation	Sineel Flow Sineel Flow 2 rs: hydrobysk, r ms, statten num	Greundwa regime: descripti idens: lat-lung, e	iệj 3 mi of the w te) vậnt	Prèciphalaon echina jours la cara	Othey or udjakmit

			-	a a companya a secondar da	
Project: Bellefonte NP REO 10389	Investigator: J. Groton, B. Dimick	Normal Circumstances:	у	Sample ID:	W005
County: Jackson		Atypical Situation:	n	Station or Structure Number(s):	
State: AL	Date: April 26, 2006	Problem Area:	n	Cowardin Code:	PFO1E

	Plant Species	Stratum	Indicator		Plant Species	Stratum	Indicator
1.	Fraxinus pennsylvanica	Tr, Sh, Sap	Facw	9.	Ulmus alata	Tr, Sh	Facu+
2.	Microstegium vimineum	н	Fac+	10.	Rumex crispus	н	Fac
3.	Toxicodendron radicans	WV, Sap	Fac	11.	llex decidua	Sh	Facw
4.	Ulmus thomasii	Tr, Sh	Fac	12.	Populus deltoides	Tr	Fac+
5.	Carex cherokeensis	н	Facw-	13.	Berchemia scandens	Sap	Facw
6.	Senecio sp.	н	-	14.			
7.	Salix	Tr, Sh	Obl	15.			
8.	Lonicera japonica	WV, Sap	Fac-	16.			
Perc	ent of Dominant Species That are OBL, FAC	W, or FAC:	77%				

Hÿdrology

		Wetland Hydrology Indicators:	~	
Q-4	(in.)	Primary Indicators		Secondary Indicators
>12	(in.)	y Inundated	Drift Lines	Oxidized Root Channels
0	(in.)	y Saturated in Upper 12 in.	Water Marks	Water Stained Leaves
		Sediment Deposits	Drainage Patterns	
etiand on	terrace	of VWVC draining W02; ~25 feet from cha	nnel but no obvious connection to st	iream channel
	>12	>12 (in.) 0 (in.)	Q-4 (in.) Primary Indicators >12 (in.) y Inundated 0 (in.) y Saturated in Upper 12 in. Sediment Deposits	Q-4 (in.) Primary Indicators >12 (in.) y Inundated Drift Lines 0 (in.) y Saturated in Upper 12 in. Water Marks

Soil Unit:	Drai	inage class:	Listed hydric soil?	Yes No			
Profile Description		<u> </u>					
Depth (Inches)	Matrix Color (Munsell Moist)	Mottle Colors (Munsell Moist)	Mottle Abundance	Texture			
0-12+	10 YR 4/2	7.5 YR 5/8	Common	Sitty clay loam			
lydric Soil Indicat	ors:						
Gleyed or Lo	w Chroma Colors	Histic Epipedon	Aquic Mo	isture Regime			
Sulfidic Odor		High Organic Cont. Surf. Layer Sa	andy Soils y Reducing	Conditions			
Concretions		Organic Streaking in Sandy Soils	Other (Ex	plain in Remarks)			
Remarks:	. <u> </u>						

Hydrophytic Vegetation Present?	Yes	Y	No	 Is this Sampling Point Within a USACE Wetland?	Yes	Y	No	
Wetland Hydrology Present?	Yes	Y	No,	Does area only meet USFWS wetland definition?	Yes		Ňo	N
Hydric Soils Present?	Yes	Y,	No	 Is wetland mapped on NWI?	Yes		No	Ņ
Estimated size: 0.26 acre								an online work to

Vetland Descriptors	P	hòto I	D(s): V	/05-1\	/V, W05-2W, V	/05-3/V, V	∕05-4\/				
Flagging Description: 1-17 c	ľočkwi	se fron	n sóuthe	em tip	of wetland						
Drawing										· · · · · ·	
Please Include: North Arrow	Proiect	Cente	nine. S	urvev	Carridor Boun	daries. Le	noth of Wetland	Feature Distance	s from	Centerline Photo	1 ocations:
WUES WEGS NOT - WIUS NT		i Lift									
Hand I want			1			Jun - A	With a White and the all all and the all all and the all all and the all all all and the all all all all all all all all all al	and man			•
i - Jádliðe	A-Wê	ガンレ			A A A A A A A A A A A A A A A A A A A		Dinillisub	MAN PARAL POR		ontenin viewa ;	
Obvious Connections to Waters of the US/State?		Yes	×	No	Waterbody	ŴVątershe	d:			• •	
Primary Water Source (If other, note in comments)		, Ĉa	p. Ering	e .	⁴ Överbanl	ing 2	Sheet Flow	Groundwater	1	Precipitation	Öthe
ÍVARÁM SCORE:		60	TVA	RAM C	CATEGORY:	Catego	ýβ				
Description of Wetland and (to ROW; eroson polential, exis Shallow, perched, vietland or vi Metland WD5 is about 25 feet. Lows	ting di s sinal p	nturibai ooloon	ces, adj terrace	acent of we	land use wildli t weather conv	feobserva evance dr	tions, station num aining Wetland V	nbers, lat long etc NO2):	1 - A - A - C - C	
			·			·					
								, • .			

Project: Bellefonte NP REQ 10389	Investigator: J. Groton, B. Dimick.	Normal Circumstances:	ý	Sample ID:	VV006
County: Jackson		Atypical Situation:	n.	Station or Structure Number(s);	
 State: AL	Date: April 26, 2006	Problem Area:	n	Cowardin Code:	PFO1E

	Plant Species	Stratum	Indicator		Plant Species	Stratum	Indicator
1.	Fraxinus pennsylvanica	Tr	Facw	9.	Glyceria striata	н	Obl
2.	Liquidambar styraciflua	Ţr	Fac+	10.	Polýgonum sp.	н	•
3.	Quercus phellos	Tr	Facw-	11.	Gratiola neglecta	н	Obl
4.	llex decidua .	Sh	Facw	12.	Ligustrum sinense	Sh	Fac
5.	Berchomia scandens	w	Facw	13,	Impatiens sp.	н	Facw
6.	Smilax glauca	w	Fac	14.	Carpinus caroliniana	Tr, Sh	Fac
7.	Gallum aparine	н	Facu	15.	Campsis radicans	Sap	Fac
8.	Cellis laevigata	Tr	Facw	16,	Moss	Ĥ	•
							••••••

Percent of Dominant Species That are OBL, FACW, or FAC: 88%

Hydrology						
Field Observations:			Wetland Hydrology Indicators:			
Depth of Surface Water:	0-12	(in.)	Primary Indicators			Secondary Indicators
Depth to Free Water in Pit:	3	- (in.)	y inundated		Drift Lines	Oxidized Root Channels
Depth to Saturated Soil:	<u>o</u>	(in.)	y Saturated in Upper 12 in.		Water Marks	 Water Stained Leaves
1		_	Sediment Deposits	ý	Drainage Patterns	
Remarks:						

									_	_	_	
nit:			Drain	inagé class:			Listed hydric soil?	Yes		No		
Description:								_				
th (Inches)	Matrix Color (N	Aunsell Mo	ist)	Mottle Cr	olors (Munsell Moist)	Mic	ottle Abundance		Text	ure		
0-4	10 YR	₹ 3/2					-	!	Silty clay	y loam		
.4-12+	10 YR	₹ 5/2			10 YR 5.6		Common	1	Silty clay	y loam		
-												
Soil Indicato	rs:						· · ·					
Gleyed or Low	/ Chroma Colors			Histic F	Epipedon		Aquic Moi:	sture Re	gime			
Sulfidic Odor			-	High Organic Cont. Surf. Layer Sandy Soils y Reducing Conditions								
Concretions				Organic Streaking in Sandy Soils Other (Explain in Remarks)								
rks:												
d Determir	nation											
		Yes	Y	No	Is this Sampling Point	Within'	a USACE Wetland?	Yes	Y	No		
d Hydrology P	resent?	Yes	Y	No	Does area only meet	USFWS	wetland definition?	Yes		No	Ń	
Solis Present?	į	Yes	Y	No .	 Is wetland mapped or 	n NŴİ?		Yes		No .	N	
	Description: h (Inches) 0-4 4-12+ Soil Indicator Gleyed or Low Sulfidic Odor Concretions ke: <u>d Determin</u> hytic Vegetatic d Hydrology Pr	Description: h (Inches) Matrix Color (M 0-4 10 YR 4-12+ 10 YR 50il Indicators: Gleyed or Low Chroma Colors Sulfidic Odor Concretions ke: d Determination hydic Vegetation Present? d Hydrology Present?	Description: h (Inches) Matrix Color (Munsell Moi 0-4 10 YR 3/2 4-12+ 10 YR 5/2 Soil Indicators: Gleyed or Low Chroma Colors Sulfidic Odor Concretions ks: d Determination hytic Vegetation Present? Yes d Hydrology Present? Yes	Description: h (Inches) Matrix Color (Munsell Moist) 0-4 10 YR 3/2 4-12+ 10 YR 5/2 50il Indicators:	Description: h (Inches) Matrix Color (Munsell Moist) Mottle Color 0-4 10 YR 3/2 4.12 4-12+ 10 YR 5/2 4.12 Soil Indicators: 5000000000000000000000000000000000000	Description: h (Inches) Matrix Color (Munsell Moist) Mottle Colors (Munsell Moist) 0-4 10 YR 3/2 - 4-12+ 10 YR 5/2 10 YR 5.6 50il Indicators:	Description: h (Inches) Matrix Color (Munsell Moist) Mottle Colors (Munsell Moist) Mo 0-4 10 YR 3/2 - - 4-12+ 10 YR 5/2 10 YR 5.6 - 4-12+ 10 YR 5/2 10 YR 5.6 - Soil Indicators: - - - Gleyed or Low Chroma Colors Histic Epipedon - Sulfidic Odor - High Organic Cont. Surf. Layer Sandy Soil Concretions Organic Streaking in Sandy Soils ks: - - d Determination - - hytic Vegetation Present? Yes Y No Lis this Sampling Point Within 1 d Hydrology Present? Yes Y No Does area only meet USFWS	Description: h (Inches) Matrix Color (Munsell Moist) Mottle Colors (Munsell Moist) Mottle Abundance 0-4 10 YR 3/2 - - - 4-12+ 10 YR 5/2 10 YR 5.6 Common - 4-12+ 10 YR 5/2 10 YR 5.6 Common - Soil Indicators: - - - - Gleyed or Low Chroma Colors Histic Epipedon Aquic Mols Sulfidic Odor - Histic Epipedon Aquic Mols Concretions Organic Cont. Surf. Layer Sandy Soils y Reducing 0 Concretions Organic Streaking in Sandy Soils Y Reducing 0 Mytic Vegetation Present? Yes Y No Lis this Sampling Point Within a USACE Wetland? d Hydrology Present? Yes Y No Does area only meet USFWS wetland definition?	Description: h (Inches) Matrix Color (Munsell Moist) Mottle Colors (Munsell Moist) Mottle Abundance 0-4 10 YR 3/2 -	Description: h (Inches) Matrix Color (Munsell Moist) Mottle Colors (Munsell Moist) Mottle Abundance Text 0-4 10 YR 3/2 - Silty cla - Silty cla 4-12+ 10 YR 5/2 10 YR 5/6 Common Silty cla 4-12+ 10 YR 5/2 10 YR 5/6 Common Silty cla 5oil Indicators: - - Aquic Moisture Regime Suffidic Odor - Histic Epipedon Aquic Moisture Regime Suffidic Odor - High Organic Cont. Surf. Layer Sandy Soils Y Concretions Organic Streaking in Sandy Soils Other (Explain in Remarks Ke: - - No	Description: h (Inches) Matrix Color (Munsell Moist) Mottle Colors (Munsell Moist) Mottle Abundance Texture 0-4 10 YR 3/2 - Silty clay loam 4-12+ 10 YR 5/2 10 YR 5/6 Common Silty clay loam 4-12+ 10 YR 5/2 10 YR 5/6 Common Silty clay loam 5oil Indicators: - - Aquic Moisture Regime Suffidic Odor - Histic Epipedon Aquic Moisture Regime Suffidic Odor - High Organic Cont. Surf. Layer Sandy Soils Y Reducing Conditions Concretions Organic Streaking in Sandy Soils Y Reducing Conditions Other (Explain In Remarks) ks: - - No	

Wetland Descriptors												
Sample ID W035	P	hata II	D(s): W(08-1%	(Inodheasten	1 ens)	, WÜ	6-2VV (Center i	ol vreilland), VV06-3V	V (nai	(Inwestern end)	
Flagging Description: 1-75 dec	l. Rvá:	ie Irón	h thế nột	IW/05	l cònter			·			•	
Drawing												
Plesse Include: Horin Arrow, Pro	ioct.	Cente Cente Cente	rine, Su , R.	<u>wey</u> (Finglet	lenes,	Len		Tealure, Destances	from	Certenine, Photo Contaction Photo Contac	Localions Mandalans
- 				F.16	A		。 (* * * (* * *	1 2	Freder 71	1]- 1	Provy A 	
	(Wa	6)		1). 1)				The s		Mary	و مع
All Albertone Albertone to	1	1183	- <u> </u>	No	Waterporty	14/1 ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	イ く *		ea aminages (VMA	5) 10	€T >reso Tavin Cringk (Ter	
Waters of the US/State? Primary Water Source	3				River-Gunt	1	Re					
(If einer, note in commonis)	╞	La	p. Finge	L.	Overbank	<u>99</u> [Sheel Flow	2. Graundwajer		Precipitation	Other
TVARAM SCORE: Description of Wetland and Oth to ROW; crosten pircritial, existing There is a dictribution of the northeas Welland VV08 is too by a wal wear second that flows northwest. Bath	g dis 1 Co thor	ninan mer th convo	i ents: (Ly kes, adja at looks vence in	, fure cent 1 like Bi at ant	and use, wikili Schoole Billom ors the wollar	le abse øted (i iai sten	niad Urii:U 1 Ina	ons, cailos nu ccessiully) () (scuin 2010 sol	antiers, lat-lang, etc) connect W08 to W0 its isto two channels	2, abo	but 100-150 (eet t	the south
hp at both clinenc could of ine po	rim	oter rei	6d									
Ther≑ appears to be some tocal g Grey trop trop, encket trop, erayas				ee tus	hii uinrat ret≰é	19:00	កណីប	ווא באבאס או פ	ทางเรือ-พลเล 0559ไกล์	.		
		<u>.</u>										

Project: Bellefonte NP REO 10389	Investigator: B. Dimick, K. Pilarski, L.Burton	Normal Circumstances:	у	Sample ID:	W007
County: Jackson		Atypical Situation;	n	Station or Structure Number(s):	
State: AL	Date: September 1,2009	Problem Area:	ň	Cowardin Code:	PFO1E

	Plant Species	Stratum	Indicator		Plant Species	Stratum.	Indicator
1:	Fraxinus pennsylvanica	Tr	Facw	9.			
2.	Cetis laevigata	Tr	Facw	10.			
3.	Berchemia scandens	ş	Facw	11.			
4.	Populus deltoides	Tr	Fac	12.			
5.	Ligustrum sinense	Sh	Fac	13.			
6.			•	14.			
7.				15.			
8.				16.			
Perc	ent of Dominant Species That are OBL, FAC	W, or FAC:	100%		· · · · · · · · · · · · · · · · · · ·	•	· · ·

Hydrològy

Field Observations:			Wetland	Hydrology Indicators:				
Depth of Surface Water:	0.	(in.)	Primary I	ndicators				Secondary Indicators.
Depth to Free Water in Pit:	0	(in.)	n	Inundated		Drift Lines	ÿ	Oxidized Root Channels
Depth to Saturated Soil:	0	- (in.)	n	Saturated in Upper 12 in.		Water Marks		Water Stained Leaves
		-		Sediment Deposits	y	Drainage Patterns		
Remarks: small drainage feat	ire betwe	en 2 cub	verts					

Soils										•	<u> </u>
Soil Ur	nit:			Drai	nage class;		Listed hy	dric soil?	Yes	Nô	F -
Profile	Description:										
Depi	th (Inches)	Matrix Color (MunselÌ Mo	rist)	Mottle Col	lors (Munsell Moist)	Mottle Abund	dance		Texture	
	0-4	10 Y	/R 3/2			-	-		s	m	
	4-12+ 10 Y		10 YR 5/2			10 YR 5/6	Common		S	m	
Hydric	e Soil Indicato	rs:									
у	Gleyed or Low	Chroma Colors			Histic Ep	pipedon		Aquic Mois	ture Reg	ime	
	Sulfidic Odor				High Or	ganic Cont. Suif. Layer Sa	andy Soils y	Reducing C	Condition	5	
	Concretions				Organic	Streaking in Sandy Soils		Other (Exp	İain in Re	emarks)	
Remark	ks:							·			
Vetlan	d Determin	ation									
Hydrop	phytic Vegetation	on Present?	Yes	Y	No	Is this Sampling Point	Within a USACE V	Netland?	Yes	Y No	
Wetlan	nd Hydrology P	resent?	Yes	Y	No	Does area only meet	USFWS wetland d	efinition?	Yes	No	N
Hudrio	Soils Present?	,	Yes	Ý	No	- Is wetland mapped on	inned		Yes	No	N

Estimated size: 0.02 acres

	ľ	hoto II	D(s): 60;	64			-				
Ragging Description: 4 lags	I				· · · · · ·						
Drawing					,						
Please Include: North Arrow, Pro	ject	Cente	rline; Su	rvey C	orridor Bound	taries, L	ength of Wetland	Feature, Distances	form,	Centerline, Photo	Locations
W004 110T 11		Sr.	مصر بسان	· ·							
wool Not th			r 6~								
NT	R	11.0	<u> /</u>				······	······		and the second second	
Please Indude: North Arrow, Pro WOO 4 WOO 1 NOT 71 WOO 7 NT Accust and						- f-	+1	/M			
			~	.			st.				
Contraction of the second	a	<u>.</u>	(4		woult	-7/		A			
(447)			¥4	41	ZT	/		A AND A AND			
- foul	μĹ	U.F.	ľ	K	_/		S	<i>.</i>			
1 P. P. P. P. P. P. P. P. P. P. P. P. P.	~		Ņ	<u> </u>	>		T				
-reversion	X		· .		**	(Joint	A Land and a service of the service	s.K			
3 14	,					P	14414	Ī			
1 1 X		\nearrow	· ~{ ``	7	75	5	N M C	r at .			
33 MX	Ż	γ^{3}	$\sqrt{2}$	\leftarrow	500	1	UNUN	q			
51 121	1	Ý			M		Lova A	4			
21 11/							71				
71 4					J		70				
7					J		7 //				
بالمراجع المراجع	r				J		, .				
من بر الم المرابع Obvious Connections to Waters of the US/State?	×		· ·	No	J Waterbody	AWätersh	, .	inaige to Towns Or	eek		
Obvious Connections to Waters of the US/State? Primary Water Source	×		p. Fřinge	1	Överbank		, .		eek 3	Precipitation	Other
Obvious Connections to Waters of the US/State? Primary Water Source (Ifother, note in comments) TVARA M SCORE:		Car 34	p. Fringe TVAR/	1 A.M. C	Överbank ATEGÖRY:	ing 2	ied: cúlverted dra	inageto Towns Cr Groundwater	3		1
Obvicus Connections to Waters of the US/State? Primary Water Source (Ifother, note in comments) TVARA M SCORE:		Car 34	p. Fringe TVAR/	1 A.M. C	Överbank ATEGÖRY:	ing 2	ied: cúlverted dra	inageto Towns Cr Groundwater	3		1
Obvicus Connections to Waters of the US/State? Primary Water Source (Ifother, note in comments)		Car 34	p. Fringe TVAR/	1 A.M. C	Överbank ATEGÖRY:	ing 2	ied: cúlverted dra	inageto Towns Cr Groundwater	3		1
Obvious Connections to Waters of the US/State? Primary Water Source (Ifother, note in comments) TVARA M SCORE: Description of Wetland and Oth to ROW; eccion potential, existing	ier (Car 34 Comme	p. Fringe TVAR/ ents: (Le ces, adja	AM.C. Am.C.	Överbank ATEGÖRY: tage dass; ha nd use, will bi	ing 2 hilat fea ie observ	ed: culverted dra Sheet Flow urres Jydrologic r ations, station rum	inage to Towns Cr Groundwater egime; description ideas, lat-long etQ	3		1
Obvious Connections to Waters of the US/State? Primary Water Source (Ifother, note in comments) TVARA M SCORE: Description of Wetland and Oth to ROW; erosion potential, existing Craw ish burrows.	ier (Car 34 Comme	p. Fringe TVAR/ ents: (Le ces, adja	AM.C. Am.C.	Överbank ATEGÖRY: tage dass; ha nd use, will bi	ing 2 hilat fea ie observ	ed: culverted dra Sheet Flow urres Jydrologic r ations, station rum	inage to Towns Cr Groundwater egime; description ideas, lat-long etQ	3		1
Obvious Connections to Waters of the US/State? Primary Water Source (Ifother, note in comments) TVARA M SCORE: Description of Wetland and Oth to ROW; erosion potential, existing Craw ish burrows.	ier (Car 34 Comme	p. Fringe TVAR/ ents: (Le ces, adja	AM.C. Am.C.	Överbank ATEGÖRY: tage dass; ha nd use, will bi	ing 2 hilat fea ie observ	ed: culverted dra Sheet Flow urres Jydrologic r ations, station rum	inage to Towns Cr Groundwater egime; description ideas, lat-long etQ	3		1
Obvious Connections to Waters of the US/State? Primary Water Source (Ifother, note in comments) TVARA M SCORE: Description of Wetland and Oth to ROW; erosion potential, existing Craw ish burrows.	ier (Car 34 Comme	p. Fringe TVAR/ ents: (Le ces, adja	AM.C. Am.C.	Överbank ATEGÖRY: tage dass; ha nd use, will bi	ing 2 hilat fea ie observ	ed: culverted dra Sheet Flow urres Jydrologic r ations, station rum	inage to Towns Cr Groundwater egime; description ideas, lat-long etQ	3		1
Obvious Connections to Waters of the US/State? Primary Water Source (Ifother, note in comments) TVARA M SCORE: Description of Wetland and Oth to ROW; erosion potential, existing Craw ish burrows.	ier (Car 34 Comme	p. Fringe TVAR/ ents: (Le ces, adja	AM.C. Am.C.	Överbank ATEGÖRY: tage dass; ha nd use, will bi	ing 2 hilat fea ie observ	ed: culverted dra Sheet Flow urres Jydrologic r ations, station rum	inage to Towns Cr Groundwater egime; description ideas, lat-long etQ	3		1
Obvious Connections to Waters of the US/State? Primary Water Source (Ifother, note in comments) TVARA M SCORE: Description of Wetland and Oth to ROW; erosion potential, existing Craw ish burrows.	ier (Car 34 Comme	p. Fringe TVAR/ ents: (Le ces, adja	AM.C. Am.C.	Överbank ATEGÖRY: tage dass; ha nd use, will bi	ing 2 hilat fea ie observ	ed: culverted dra Sheet Flow urres Jydrologic r ations, station rum	inage to Towns Cr Groundwater egime; description ideas, lat-long etQ	3		1
Obvious Connections to Waters of the US/State? Primary Water Source (Ifother, note in comments) TVARA M SCORE: Description of Wetland and Oth to ROW; erosion potential, existing Craw ish burrows.	ier (Car 34 Comme	p. Fringe TVAR/ ents: (Le ces, adja	AM.C. Am.C.	Överbank ATEGÖRY: tage dass; ha nd use, will bi	ing 2 hilat fea ie observ	ed: culverted dra Sheet Flow urres Jydrologic r ations, station rum	inage to Towns Cr Groundwater egime; description ideas, lat-long etQ	3		1
Obvious Connections to Waters of the US/State? Primary Water Source (Ifother, note in comments) TVARA M SCORE: Description of Wetland and Oth to ROW; erosion potential, existing Craw ish burrows.	ier (Car 34 Comme	p. Fringe TVAR/ ents: (Le ces, adja	AM.C. Am.C.	Överbank ATEGÖRY: tage dass; ha nd use, will bi	ing 2 hilat fea ie observ	ed: culverted dra Sheet Flow urres Jydrologic r ations, station rum	inage to Towns Cr Groundwater egime; description ideas, lat-long etQ	3		1
Obvious Connections to Waters of the US/State? Primary Water Source (Ifother, note in comments) TVARA M SCORE: Description of Wetland and Oth to ROW; erosion potential, existing Craw ish burrows.	ier (Car 34 Comme	p. Fringe TVAR/ ents: (Le ces, adja	AM.C. Am.C.	Överbank ATEGÖRY: tage dass; ha nd use, will bi	ing 2 hilat fea ie observ	ed: culverted dra Sheet Flow urres Jydrologic r ations, station rum	inage to Towns Cr Groundwater egime; description ideas, lat-long etQ	3		1
Obvious Connections to Waters of the US/State? Primary Water Source (Ifother, note in comments) TVARA M SCORE: Description of Wetland and Oth to ROW; erosion potential, existing Craw ish burrows.	ier (Car 34 Comme	p. Fringe TVAR/ ents: (Le ces, adja	AM.C. Am.C.	Överbank ATEGÖRY: tage dass; ha nd use, will bi	ing 2 hilat fea ie observ	ed: culverted dra Sheet Flow urres Jydrologic r ations, station rum	inage to Towns Cr Groundwater egime; description ideas, lat-long etQ	3		1

Project: Bellefonte NP	Investigator: B. Dimick, K.Pilarski, L.Burton	Normal Circumstances:	у	Sample ID:	W008
County: Jackson		Atypical Situation:	n	Station or Structure Number(s)	
State: AL	Date: Sept. 1 2009	Problem Area:	n	Cowardin Code:	PSSIE

	Plant Species	Stratum	Indicator		Plant Species	Stratum	Indicator
1.	Salix nigra	Sapling	OBL	9.			
2 .	Juncus effusus	Herb	FACW	10.			
3.	Festuca arundinacea	Herb	FAC	11.			
4.	Eupatorium serolinum	Herb	FAC	12.			
5.				13.			
6,				14.			
7.				15.			
8.				16.			
Perc	ent of Dominant Species That are OBL, FAC	W, or FAC:	100%				

Hydrology

Hydric Soils Present?

Estimated size: 0.43

Yes

No, N

Field Observations:			Wetland Hydrology Indicators:			
Depth of Surface Water:	0	(in.)	Primary Indicators			Secondary Indicators
Depth to Free Water in Pit:		(in.)	inundated		Drift Lines	Oxidized Root Channels
Depth to Saturated Soil:	0	(in.)	Saturated in Upper 12 in.		Water Marks	Water Stained Leaves
			Sediment Deposits	у	Drainage Patterns	· · · · · · · · · · · · · · · · · · ·
Remarks:						

Soil Unit:	T		Drainad	o class:	A dischart of the discussion of the second	T	Listed hydric soil?	Yes		No
	<u></u>		Drainag	u unas.			cisco nyone soni	103		
Profile Des	cription:	·				_				
Depth (In	ches) Matrix Colo	r (Munsell Mo	ist)	Mottle Co	lors (Munsell Moist)	Mott	le Abundance	۰.	Text	ure
0-4	10	YR 4/4			-		-	Silt loam		
4-12-	+ 10) YR 4/3							Silt Lo	am
				,						
Hydric Soil	Indicators:			·····			······································			
N Gley	ed or Low Chroma Colors			Histic E	pipedan		Aquic Mòis	sture Reg	ime	
Sulfic	tic Odór			High Or	ganic Cont. Surf. Layer Sa	andy Solis	Reducing	Condition	15	
Cond	retions			Organic	Streaking in Sandy Soils		Other (Exp	lain in R	emarks	Ĵ.
	ydric soils not present									

Is wetland mapped on NWI?

Yes

No

Ņ

	Phato i	D(s): 38,	,39								
Sample ID: MDD8 Flagging Description:											
Drawing Please Include: North Arrow, Proj	ect Cente	dine Sur	nev Con	idor Boundari	es lei	orth of Wetland Fe	ature Distance	form (Centerline Phot	0 1007	tione
Recieve and China				and the state	E ()	Hill and		י נשיד י	5c <i>d</i> 7+		
			1	1		g=					
/ Obvious Connections to	v Voie	. 1 1) No. 1 ((Terche	ر میں در میں ط: Enhomouri our			Pacipania		
Obvious Connections to Waters.of the US/State? Primary Water Source	X Yes					d: Ephemeral cor	-	<u> </u>	`````		0#6
Waters of the US/State?		p. Fringe) Waterbody Wa Overbanking EGORY: 2		d: Ephemeral.cor	ivejance to Gur Groundwater	<u> </u>	e Reservoir Precipitation		Othe

Project: Bellefonte NP	Investigator: B. Dimick, K.Pilarski, L.Burton	Normal Circumstances:	у	Sample ID:	W009
County: Jackson		Atypical Situation;	n	Station or Structure Number(s):	
State: AL	Date: Sept. 1,2009	Problem Area:	n	Cowardin Code:	PSS1E

	Plant Species	Stratum	Indicator		Plant Species	Stratum	Indicator
1,	Salix nigra	Sapling	OBL	9.			
2.	Júneus effusus	Herb	FACW	10,			
3.	Festuca arundinacea	Herb	FAC	11.			·
4.	Cephalanthus occidentalis	Shrub	OBL	12.			
5.	Eupatorium serotinum	Herb	FAC	13.			
6.				14.			
7.				15.	-		
8.	-			16.			
Perc	ent of Dominant Species That are OBL, FAC	W, or FAC:	100%				

Hydrology

Field Observations:			Wetland Hydrology Indicators:				
Depth of Surface Water:	0	(in.)	Primary Indicators			•	Secondary Indicators
Depth to Free Water in Pit:		(in.)	Inundated		Drift Lines		Oxidized Root Channels
Depth to Saturated Soil:	0	(in.)	Saturated in Upper 12 in.		Water Marks		Water Stained Leaves
			Sediment Deposits	ý	Drainage Patterns		
Remarks:			,				•

Soil L			T T			The second second second second second second second second second second second second second second second s		I I	T
	Jnit:		Dra	inage class:		Listed hydric soil?	Yes	No	
Profil	e Description:								
Dep	pth (Inches)	Matrix Color (Mun	sell Moist)	Mottle Col	ors (Munsell Moist)	Mottle Abundance		Texture	
	0-4	'10 YR 4/	4	1	-	-		Silt Ioam	
4-12+		'10 YR 4/	3			. •		Silt Loam	
lydri	ć Soil Indicato	rs:							
1	Gleyed of Low	Chroma Colors		Histic Ep	ipedon	Aquic Mc	isture Regir	ne	
	Sulfidic Odor			High Org	anic Cont. Surf. Layer Sa	ndy Soils Reducing	Conditions		
	Concretions			Organic	Streaking in Sandy Soils	Other (E)	oplain in Rer	narks)	
Rema	Concretions arks: Hydric soil	s not pr es ent		Organic	Streaking in Sandy Soils	Other (E)	oplain in Rer	narks)	
·····	arks: Hydric soil			Organic	Streaking in Sandy Soils	Oiher (E)	kplain in Rer	narks)	
etlar		ation	Yes Y	Organic		Other (E) Within a USACE Wetland?	oplain in Rer Yes I		
e tlar Hydro	arks: Hydric soll n d Determi r	on Present?	Yes Y Yes Y		Is this Sampling Point				

Sample ID: VI009	PH	icto II](s):n	o photo)ș					·	·
Flagging Description:											
										- <u></u>	
Drawing	miect	Conter	dine S	unexí	Corridor Bound	Izriàc Io	ngth of Wetland	Feature Distance	s from	Centedine Phot	o Locations
Please Include: North Arrow: Pl The Control of the	العدية ومحق العربي		nine; s	Lux A	Conidor Bound		Ingth of Wetland	NA		Centerline, Phot	o Locations
							м. П		•		
Obvious Connections to	X	Yes	Т	No	Waterbody	Ŵatersh	ed: Ephemeral c	ónveyance to Gu	itersvil	le Reservoir	
Waters of the US/State? Primary Water Source	-	.Cai	p. Fring	le [.]	Övérbank		Sheet Flow	*Groundwäte		Precipitation	Öthe
(If other, note in comments)	╉	31			A TEGORY:	2:	the part of stars of	and the state of the			3 2
	ther C	1.6	Ĺ	2	x	hilat feat té observe	mes, hydrologic r diens, station rom	égime; descriptio	of the	wefland outside (far adjacer
Description of Wetland and O o ROW, crosico potential, cristi Does not have soils to meet juri occurred. It meest USFWS we	sdictio tland c	nal we Jefinitio	tiand (on and	riteria : 'should	as defined by: be considere	the USA	E. Thiswedland	likelv developed	∘ inalou	i spot le t over a 990	tergrading
Joes not have soils to meet juri:	sdictic tland t	nal we definitio	tland (on and	riteria : 'should	as defined by be considere	the USA	E. Thiswedland	likelv developed	∘ inalou	ı spotlet over a 990:	ter,grading
Does not have soils to meet juri:	sdictio tland (nal we	tland (on and	nteria : 'should	as defined byt be considere	the USA	E. Thiswedland	likely developed and Executive' O	∘ inalou	u spotletovera 990:	ter grading

Project: Bellefonte	Investigator: B. Dimick, K.Piłarski, L.Burton	Normal Circumstances:	у	Sample ID:	W010
County: Jackson		Atypical Situation;	n	Station or Structure Number(s);	
State: AL	Date: September 1, 2009	Problem Area:	n	Cowardin Code:	PFO1E


	Plant Species	Stratum	Indicator		Plant Species	Stratum	Indicator
1.	Fraxinus pennsylvanica	Tr	Facw	9.	Glyceria striata	н	Obi
2.	Liquidambar styraciflua	τŢ	Fac+	10.	Polygonum sp.	н	-
3,	Quercus phellos	Tr	Facw-	11.	Salix nigra	Tr	OBL
4.	Ìlex decidua	Sh	Facw	12.	Ligustrum sinense	Sh	Fac
5.	Berchemia scandens	w	Facw	13.	Saururus cernuum	Herb	OBL
6.	Smilax glauca	w	Fac	14.	Carpinus caroliniana	Tr, Sh	Fac
7.	Populus deltoides	Tr	Fac	15.	Campsis radicans	Sap	Fac
8.	Cellis laevigata	Tr	Facw	16.			
Perc	ent of Dominant Species That are OBL, FAC	W, or FAC:	100				

Hydrology


Field Observations:			Wetland Hydrology Indicators:				
Depth of Surface Water:	O,	(in.)	Primary Indicators				Secondary indicators
Depth to Free Water in Pit:	0	(in.)	inundated		Drift Lines	Y	Oxidized Root Channels
Depth to Saturated Soil:	0	(in.)	y Saturated in Upper 12 in.		Water Marks		Water Stained Leaves
			Sediment Deposits	<u>у</u> .	Drainage Patterns		
Remarks:							


			T	·····				-1		T
Soil Unit: Dr			Drair	nagė class;		Listed hydric s	oil? Ye	9	No	
Profile Descrip	tion:									
Depth (Inche	s) Matrix Color ((Munsell Mo	rist)	Mottle Co	lors (Munsell Moist)	Mottle Abundance		Text	ure	
0-4 10 YR 3/1			· · · · · · · · · · · · · · · · · · ·	-	-		Silty clay loam			
4-12+ 10 YR 5/2		(R 5/2			10 YR 5/6	Common		Silty clay loam		
					-					
Hydric Soil Indi	icators:			•						
ý Glevjed o	r Low Chroma Colors			Histic Ep	olpedon	Aqui	Molsture F	legime		
Sulfidic C	Ddor		-	High Or	ganic Cont. Surf. Layer Sa	andy Šolis y Redu	cing Condit	ionis		
Concretio	ons		-	Örganic	Streaking in Sandy Soils	Othe	(Explain in	Remarks)	
Remarks:						•				
/etland Deter	rmination									
	getation Present?	Yes	Y	No	Is this Sampling Point	Within a USACE Wetlan	I? Yes	Ý	No	
	ogy Present?	Yes	Y	No	Does area only meet	USFWS wetland definition	? Yes	<u>. </u>	No	N
Wetland Hydrold	Hydric Soils Present? Yes Y		-		Is wetland mapped on NWI?					

Netland Descriptors	P	hoto ID(s): 1	6:18-2	24,26,153-165
Sample ID; W010		101010(3).	0-10,2	
Flagging Description:				
Drawing				
Please Include: North Arrow, Pro	ect	Centerline; 5	Survey	Corridor Boundaries, Length of Wetland Feature, Distances from Centerline, Photo Locations
Ast Ast Ast Ast Ast Ast Ast Ast				
			 	Bunder and Frederice in -
Divious Connections to Naters of the US/State?	x	Yes	No	
Primary Water Source If other, note in comments)	F	Сар, Глії	ge 1	1 Overbanking Sheet Flow 2 Groundwater 3 Precipitation Othe
VARAMSCORE:		-50 TVA	RÁMIC	CATEGÓRY: 2
to ROW; erosion potential, existing	;idiis ttoл	turbances, ad n. natural rav	jacentri in e with	rest age class; habitat features; hydrologic regime; description of the wetland outside of or adjacent I had use, wild life observations, station numbers, hit-long, etc) Ith large wetland trees and wetland soils (although some places are rocky). The majority of the empties into Guntersville Resevoir via a culvert near the shoreline.
·			,	




Last revised 2005-04-29







Last revised 2005-04-29


Final Supplemental Environmental Impact Statement







Last revised 2005-04-29














Final Supplemental Environmental Impact Statement

















Final Supplemental Environmental Impact Statement







Last revised 2005-04-29

Final Supplemental Environmental Impact Statement







APPENDIX G – RESERVOIR FISH ASSEMBLAGE INDEX (RFAI), RESERVOIR BENTHIC INDEX (RBI) SCORES, AND HISTORICAL FISH SPECIES OCCURRENCES

Page intentionally blank

Table G-1.Individual Metric Scores and the Overall RFAI Scores Downstream (TRM 390.0)
and Upstream (TRM 393.0) of Bellefonte Nuclear Plant, Spring 2009

Spring 2009		TRM 390.0		TRM 393.0	
Metric	Gear Type	Observed	Score		Score
A. Species richness and composition					
1. Number of species		21 Species	3	26 Species	3
2. Number of centrarchid species (less micropterus)		6 Species Black Crappie Bluegill Green Sunfish Redbreast Sunfish Redear Sunfish Warmouth	5	6 Species Black Crappie Bluegill Longear Sunfish Redbreast Sunfish Redear Sunfish Warmouth	5
3. Number of benthic invertivore species		2 Species Freshwater drum Logperch	1	1 Species Freshwater drum	1
4. Number of intolerant species		0 Species	1	2 Species Skipjack Herring Longear Sunfish	1
5. Percent tolerant individuals	Electrofishing	72.7% Bluegill 51.5% Largemouth Bass 13.3% Spotfin Shiner 2.2% Gizzard Shad 2.0% Redbreast Sunfish 2.0% Bluntnose Minnow 1.1% Common Carp 0.4% Green Sunfish 0.2%	0.5	73.6 % Bluegill 54.5% Largemouth Bass 8.9% Gizzard Shad 3.4% Common Carp 3.2% Spotfin Shiner 2.8% Redbreast Sunfish 0.3% Western Mosquitofish 0.3% Bluntnose Minnow 0.1% Yellow Bullhead 0.1%	0.5
	Gill Netting	41.0% Longnose Gar 19.4% Common Carp 11.2% Largemouth Bass 5.2% Bluegill 4.5% Gizzard Shad 0.7%	0.5	17.2% Gizzard Shad 7.0% Longnose Gar 5.7% Common Carp 1.9% Largemouth Bass 1.4% Bluegill 0.6% Brown Bullhead 0.6%	1.5
 Percent dominance by one species 	Electrofishing	51.5% Bluegill	1.5	54.5% Bluegill	1.5
	Gill Netting	22.4% Yellow Bass	1.5	49.0% Yellow Bass	0.5
7. Percent nonnative species	Electrofishing	12.4% Inland Silverside 11.6% Common Carp 0.4% Yellow Perch 0.4%	0.5	3.5% Common Carp 3.2% Yellow Perch 0.3%	0.5
	Gill Netting	11.2% Common Carp 11.2%	0.5	2.5% Common Carp 1.9% Grass Carp 0.6%	0.5

Single Nuclear Unit at the Bellefonte Site Table G-1 (Continued)

Spring 2009		TRM 390.0	D	TRM 393.0	
Metric	Gear Type	Observed	Score	Observed	Score
8. Number of top carnivore species		8 Species Black Crappie Flathead Catfish Largemouth Bass Longnose Gar Spotted Bass Spotted Gar White Bass Yellow Bass	5	9 Species Black Crappie Flathead Catfish Largemouth Bass Longnose Gar Skipjack Herring Spotted Bass Spotted Gar White Bass Yellow Bass	5
B. Trophic composition					· .
9. Percent top carnivores	Electrofishing	15.7% Largemouth Bass 13.2% Yellow Bass 1.5% Spotted Gar 0.6% Spotted Bass 0.4%	2.5	11.7% Largemouth Bass 8.9% Spotted Bass 1.4% Yellow Bass 1.0% White Bass 0.3% Black Crappie 0.1%	2.5
· · ·	Gill Netting	64.2% Yellow Bass 22.5% Longnose Gar 19.3% White Bass 6.1% Largemouth Bass 5.2% Spotted Bass 4.5% Black Crappie 3.6% Flathead Catfish 3.0%	2.5	73.9% Yellow Bass 49.0% Spotted Bass 8.4% Longnose Gar 5.7% White Bass 4.5% Flathead Catfish 2.5% Black Crappie 1.3% Largemouth Bass 1.3% Skipjack Herring 0.6%	2.5
10. Percent omnivores	Electrofishing	9.0% Channel Catfish 5.5% Gizzard Shad 2.0% Bluntnose Minnow 1.1% Common Carp 0.4%	2.5	12.3% Channel Catfish 5.4% Gizzard Shad 3.3% Common Carp 3.2% Bluntnose Minnow 0.1% Yellow Bullhead 0.1%	2.5
		23.9% Common Carp 11.2% Blue Catfish 7.5% Channel Catfish 4.5% Gizzard Shad 0.7%	1.5	20.4% Blue Catfish 7.6% Gizzard Shad 7.0% Channel Catfish 3.2% Common Carp 1.9% Brown Bullhead 0.6%	1.5
C. Fish abundance and health					
11. Average number per run	Electrofishing	1	0.5	47.8	0.5
10 5	Gill Netting	13.4	1.5	15.7	1.5
12. Percent anomalies	Electrofishing		1.5	8.1%	0.5
Overall RFAI Score	Gill Netting	0.0%	2.5 35	1.3%	2.5 34
			Fair		Fair

Table G-2.Individual Metric Scores and the Overall RFAI Scores Downstream (TRM 390.0)
and Upstream (TRM 393.0) of Bellefonte Nuclear Plant, Summer 2009

Summer 2009	1	TRM 390.0		TRM 393.0	×
Metric	Gear Type	Observed	Score	Observed	Score
A. Species richness and composition				,	
1. Number of species	····	20 Species	. 3	23 Species	3
2. Number of centrarchid species (less micropterus)		7 Species Black Crappie Bluegill Longear Sunfish Redbreast Sunfish Redear Sunfish Warmouth White Crappie	5	7 Species Black Crappie Bluegill Green Sunfish Longear Sunfish Redbreast Sunfish Redear Sunfish Warmouth	5
3. Number of benthic invertivore species		1 Species Freshwater drum	1	1 Species Freshwater drum	1
4. Number of intolerant species		1 Species Longear Sunfish	1	2 Species Skipjack Herring Longear Sunfish	1
5. Percent tolerant individuals	Electrofishing	59.7% Largemouth Bass 20.6% Bluegill 14.7% Western mosquitofish 10.0% Gizzard Shad 5.7% Spotfin Shiner 4.1% Golden Shiner 2.3% Common Carp 1.4% Redbreast Sunfish 0.6% White Crappie 0.3%	0.5	63.3 % Bluegill 22.2% Largemouth Bass 11.8% Gizzard Shad 11.7% Spotfin Shiner 8.9% Golden Shiner 7.4% Longnose Gar 0.7% Yellow bullhead 0.2% Redbreast Sunfish 0.2% Green Sunfish 0.2%	0.5
	Gill Netting	41.0% Longnose gar 14.0% Common Carp 13.0% Gizzard Shad 9.0% Largemouth Bass 3.0% Bluegill 2.0%	0.5	38.4% Longnose Gar 17.4% Gizzard Shad 10.5% Largemouth Bass 8.1% Common Carp 2.3%	0.5
6. Percent dominance by one species	Electrofishing	20.5% Largemouth Bass	2.5	25.4% Spotted Gar	2.5
	Gill Netting	17.0% Channel Catfish	1.5	26.7% Channel Catfish	1.5
7. Percent nonnative species	Electrofishing	3.1% Inland Silverside 1.7% Common Carp 1.4%	0.5	2.0% Inland Silverside 2.0%	1.5
	Gill Netting	13.0% Common Carp 13.0%	0.5	3.5% Common Carp 2.3% Yellow Perch 1.2%	0.5

Final Supplemental Environmental Impact Statement

Table G-2 (Continued)

Summer 2009		TRM 390.0	D	TRM 393.0		
Metric	Gear Type	Observed	Score	Observed	Score	
3. Number of top carnivore species		7 Species Black Crappie Flathead Catfish Largemouth Bass Longnose Gar Spotted Bass Spotted Gar White Crappie	3	8 Species Black Crappie Flathead Catfish Largemouth Bass Longnose Gar Spotted bass Skipjack Herring Spotted Gar Yellow Bass	5	
B. Trophic composition						
9. Percent top carnivores	Electrofishing	42.0% Largemouth Bass 20.9% Spotted Gar 19.5% Black Crappie 0.8% Flathead Catfish 0.4% White Crappie 0.4%	2.5	38.5% Spotted Gar 25.4% Largemouth Bass 11.8% Longnose Gar 0.7% Black Crappie 0.4% Flathead Catfish 0.2%	2.5	
	Gill Netting	45.0% Flathead Catfish 15.0% Longnose Gar 14.0% Spotted Bass 7.0% Spotted Gar 4.0% Largemouth Bass 3.0% Black Crappie 2.0%	2.5	48.8% Longnose Gar 17.4% Flathead Catfish 10.4% Spotted Bass 9.3% Largemouth Bass 8.1% Black Crappie 1.2% Skipjack Herring 1.2% Yellow Bass 1.2%		
10. Percent omnivores	Electrofishing	12.6% Gizzard Shad 5.8% Channel Catfish 3.1% Golden Shiner 2.3% Common Carp 1.4%	2.5	20.5% Gizzard Shad 11.6% Golden Shiner 7.4% Channel Catfish 1.3% Yellow Bullhead 0.2%	2.5	
	Gill Netting	41.0% Channel Catfish 17.0% Common Carp 13.0% Gizzard Shad 9.0% Blue Catfish 2.0%	0.5	41.9% Channel Catfish 26.7% Gizzard Shad 10.6% Blue Catfish 2.3% Common Carp 2.3%	0.5	
C. Fish abundance and health		10.5	0.5	20.0	05	
11. Average number per run	Electrofishing	19.5	0.5	29.9	0.5	
	Gill Netting	10.0	0.5	8.6	0.5	
12. Percent anomalies	Electrofishing	2.4%	1.5	1.3%	2.5	
	Gill Netting	6.0%	0.5	3.5%	1.5	
Overall RFAI Score		· · · · · · · · · · · · · · · · · · ·	30	<u> </u>	35	
			Poor		Fair	

Final Supplemental Environmental Impact Statement

Table G-3.Individual Metric Scores and the Overall RFAI Scores Downstream (TRM
390.0) and Upstream (TRM 393.0) of Bellefonte Nuclear Plant, Autumn
2009

Autumn 2009		TRM 390.0		TRM 393.0		
Metric	Gear Type	Observed	Score	Observed	Score	
A. Species richness and composition						
1. Number of species		26 Species	3	30 Species	3	
2. Number of centrarchid species (less micropterus)		7 Species Black crappie Bluegill Green sunfish Longear sunfish Redbreast sunfish Redear sunfish Warmouth	5	5 Species Black crappie Bluegill Longear sunfish Redear sunfish Warmouth	5	
3. Number of benthic invertivore species		1 Species Freshwater drum	1	2 Species Freshwater drum Spotted sucker	1	
4. Number of intolerant species		2 Species Brook silverside Longear sunfish	1	5 Species Brook silverside Longear sunfish Skipjack herring Smallmouth bass Spotted sucker	5	
5. Percent tolerant individuals	Electrofishing	67.8% Bluegill 31.26% Bluntnose minnow 1.93% Common carp 1.59% Gizzard shad 18.36% Golden shiner 0.55% Green sunfish 0.07% Largemouth bass 12.70% Redbreast sunfish 0.48% Spotfin shiner 0.90%	0.5	74% Bluegill 36.53% Bluntnose minnow 0.45% Common carp 0.98% Gizzard shad 14.11% Golden shiner 6.04% Largemouth bass 9.06% Spotfin shiner 6.64% W. mosquitofish 0.15%	0.5	
	Gill Netting	5.7% Common carp 2.86% Largemouth bass 2.86%	2.5	26% Common carp 0.81% Gizzard shad 17.89% Golden shiner 1.63% Largemouth bass 5.69%	1.5	
6. Percent dominance by one species	Electrofishing	31.3% Bluegill	1.5	36.5% Bluegill	1.5	
	Gill Netting	22.9% Blue catfish	1.5	17.9% Gizzard shad	1.5	

Single Nuclear Unit at the Bellefonte Site

Table G-3 (Continued)

Gear Type	TRM 390.0 Observed	Score	TRM 393.0 Observed	Score
			• 17 m 1	
	· · · · · · · · · · · · · · · · · · ·			
Electrofishing	96.6	0.5	88.3	0.5
Gill Netting	3.5	0.5	12.3	1.5
Electrofishing	3.6%	1.5	4.7%	1.5
Gill Netting	0.0%	2.5	0.0%	2.5
		34		40
		Fair		Fair
	Gill Netting	Gill Netting 3.5 Electrofishing 3.6% Gill Netting 0.0%	Gill Netting 3.5 0.5 Electrofishing 3.6% 1.5 Gill Netting 0.0% 2.5 34 Fair	Gill Netting 3.5 0.5 12.3 Electrofishing 3.6% 1.5 4.7% Gill Netting 0.0% 2.5 0.0% 34 Fair Fair Fair

Table G-4.Comparison of RFAI Scores From Autumn Sampling Conducted During 1993-2009 as Part of the Vital Signs
(VS) Monitoring Program* in Guntersville Reservoir. Sites at Tennessee River Mile (TRM) 410 and 405 are
upstream and downstream monitoring sites for Widows Creek Fossil Plant and are not part of the VS
monitoring Program.

Location	Site	1993	1994	1996	1998	2000	2001	2002	2004	2005	2006	2007	2008	2009	Average
Inflow	TRM 424*	36	46	42	34	28		46	42		38		34	44	39
Inflow	TRM 410					34	32	34	·	32	38	30	28	34	33
Inflow	TRM 405					. 38	40	32		36	34	32	24	34	34
Transition	TRM 375.2*	42	. 35	38	32	41		34	33		36		37	40	37
Forebay	TRM 350*	45	38	48	41	42		36	41		44		35	38	41
Downstrea	m of BLN					1	I	•			<u>[</u>	. <u> </u> ,			
Transition	TRM 390	Spring	2009		Su	mmer 20	009		Autum	n 2009		Ave	rage		
		3	5			30			3	4		. 3	33		
Upstream o	of BLN								· · · · · · · · · · · · · · · · · · ·						
Transition	TRM 393	Spring	, 2009		Su	mmer 20	009		Autum	n 2009		Ave	rage	×.	
		. 3	4			35			4	0		3	86		

Note: Spring, summer, and autumn 2009 RFAI scores from sites located upstream and downstream of BLN are also included for comparison.

RFAI Scores: 12-21 (Very Poor); 22-31 (Poor); 32-40 (Fair); 41-50 (Good); or 51-60 (Excellent)

A-199

Appendix G

A-200

Table G-5. A Comparison of Overall Species Occurrences From Current and Historical Data From TVA Fish Samples in Guntersville
Reservoir During Electro-fishing, Gill Netting, Hoop Netting, and Cove Rotenone Surveys, As Well As Data From Fish
Impingement Studies Conducted at Widows Creek Fossil Plant (WCF)

* 7 	Common Name	Scientific Name	RFAI 1993-2009	Historic EF/GN/HN 1974-1984	Cove Rotenone 1949-1993	WCF Impingement 1974-1975	WCF Impingement 2005-2007	2009 Qualitative Species Sampling
		Annuille meduate :	· ·					
1	American eel Atlantic needlefish	Anguilla rostrata	 X	X				
2		Strongylura marina	1					
3	Bigeye chub	Hybopsis amblops		 	<u> </u>		'	
4	Bigmouth buffalo	Ictiobus cyprinellus	X	<u> </u>	X			
5	Black buffalo	Ictiobus niger	X	<u> </u>	X		Х	X
6	Black bullhead	Ameiurus melas	X		<u>X</u> .	<u>x</u>		
7	Black crappie	Pomoxis nigromaculatus	X	X	X		X	X
8	Black redhorse	Moxostoma duquesnei	X		Х		Х	X
9	Blackspotted topminnow	Fundulus olivaceus	X		X			X
10	Blackstripe topminnow	Fundulus notatus	X		X			Χ -
11	Blacktail shiner*	Cyprinella venusta			X			
12	Blue catfish	Ictalurus furcatus	X	X	X .		Х	
13	Bluegill	Lepomis macrochirus	X	· X	Х	Х	Х	X
14	Bluntnose darter*	Etheostoma chlorosomum			Х			
15	Bluntnose minnow	Pimephales notatus	X					X
16	Bowfin	Amia calva	X	Х	Х			X
17	Brook silverside	Labidesthes sicculus	X	Х	X			X
18	Brown bullhead	Ameiurus nebulosus	X	Х	Х			X
19	Bullhead minnow	Pimephales vigilax	X		Х			X
20	Channel catfish	Ictalurus punctatus	Х	Х	Х	X	Х	X
21	Channel shiner	Notropis wickliffi	X					
22	Chestnut lamprey	Ichthyomyzon castaneus	X		Х	Х		
23	Common carp	Cyprinus carpio	X	Х	Х	Х		X
24	Creek chub	Semotilus atromaculatus		·	Х			
25	Dusky darter	Percina sciera	Х	·			Х	
26	Emerald shiner	Notropis atherinoides	X	X	X	X	Х	
27	Fantail darter*	Etheostoma flabellare			Х			
28	Fathead minnow	Pimephales promelas	X		X			
29	Flathead catfish	Pylodictis olivaris	X	Х	X		Х	X
30	Freshwater drum	Aplodinotus grunniens	X	<u> </u>	X	X	X	X

	Common Name	Scientific Name	RFAI 1993-2009	Historic EF/GN/HN 1974-1984	Cove Rotenone 1949-1993	WCF Impingement - 1974-1975	WCF Impingement 2005-2007-	2009 Qualitative Species Sampling
						•		
31	Ghost shiner	Notropis buchanani			X			
32	Gizzard shad	Dorosoma cepedianum	X	X	Х	Х	Х	Х
33	Golden redhorse	Moxostoma erythrurum	Х	X	Х			X
34	Golden shiner	Notemigonus crysoleucas	X	Х	X		Х	Х
35	Goldfish	Carassius auratus	Х		Х			
36	Grass carp	Ctenopharyngodon idella	Х		Х			Х
37	Green sunfish	Lepomis cyanellus	Х	Х	Х	Х	Х	X ·
38	Highfin carpsucker	Carpiodes velifer		·	Х			
39	Inland silverside	Menidia beryllina	X ·				· X	
40	Largemouth bass	Micropterus salmoides	Х	Х	X	X	Х	X
41	Largescale stoneroller	Campostoma oligolepis	Х		X			Х
42	Logperch	Percina caprodes	Х	Х	Х	Х	Х	X
43	Longear sunfish	Lepomis megalotis	X	X	X	X	X	X
44	Longnose gar	Lepisosteus osseus	X	X	X		X	X
45	Mimic shiner	Notropis volucellus	X		X		X.	
46	Mooneye	Hiodon tergisus	X	X	X	Х		
47	Northern hogsucker	Hypentelium nigricans	X		X			Х
48	Orangespotted sunfish	Lepomis humilis			X	Х	Х	
49	Pugnose minnow	Opsopoeodus emiliae		·	X		<u> </u>	
50	Paddlefish	Polyodon spathula		X		Х		
51	Quillback	Carpiodes cyprinus			х			
52	Rainbow darter	Etheostoma caeruleum				·		X
53	Redbreast sunfish	Lepomis auritus	Х		X		X	× · · · ·
54	Redear sunfish	Lepomis microlophus	X		X	X	X	X
55	Redline darter*	Etheostoma rufilineatum			X			<u> </u>
56	River carpsucker	Carpiodes carpio		X	X			
57	River darter	Percina shumardi					X	
58	River redhorse	Moxostoma carinatum	X				^	
59	Rock bass	Ambloplites rupestris	X		X	 X	X	
60	Sauger	Sander canadensis	X		^X	<u> </u>		
61	Sauger Shortnose gar*				X		Х	
62		Lepisosteus platostomus					·	
	Silver chub	Macrhybopsis storeriana	 X	X	X			
63	Silver Redhorse	Moxostoma anisurum						
64	Skipjack herring	Alosa chrysochloris	<u> </u>	X	X	<u> </u>	<u> </u>	X
65	Smallmouth bass	Micropterus dolomieu	<u> </u>	X	<u> </u>	<u>X</u>	X	
66	Smallmouth buffalo	Ictiobus bubalus	X	Х	Х	Х		

Table G-5. (Continued)

Appendix G

A-202

Table C-5. (Continued)

8 9 9 4	Common Name	Scientific Name	RFAI 1993-2009	Historic EF/GN/HN 1974-1984	Cove Rotenone 1949-1993	WCF Impingement 1974-1975	WCF Impingement 2005-2007	2009 Qualitative Species Sampling
67	Smallmouth redhorse	Moxostoma breviceps			x			· · ·
68	Snubnose darter	Etheostoma simoterum	Х			·		
69	Spotfin shiner	Cyprinella spiloptera	X	X	X		Х	X
70	Spotted bass	Micropterus punctulatus	X	X	X		X	X
71	Spotted gar	Lepisosteus oculatus	Х	X	X			X
72	Spotted sucker	Minytrema melanops	X	Х	Х	Х	X	X
73	Steelcolor shiner	Cyprinella whipplei	Х	Х	Х			X
74	Stripetail darter	Etheostoma kennicotti			Х			
75	Striped bass	Morone saxatilis	Х	X			X	
76	Suckermouth minnow*	Phenacobius mirabilis			Х			·
77	Threadfin shad	Dorosoma petenense	Х	· X	Х	Х	Х	Х
78	Walleye	Sander vitreus	Х	X		Х		
79	Warmouth	Lepomis gulosus	Х	Х	Х	Х		Х
80	Western mosquitofish	Gambusia affinis	Х		Х	·	Х	Х
81	White bass	Morone chrysops	Х	Х	Х	Х	Х	Х
82	White crappie	Pomoxis annularis	Х	Х	X	Х	X	
83	Whitetail shiner	Cyprinella galactura			Х			Х
84	White sucker	Catostomus commersoni				Х		
85	Yellow bass	Morone mississippiensis	Х	Х	Х	Х	Х	Х
86	Yellow bullhead	Ameiurus natalis	Х	. X	X	Х	Х	Х
87	Yellow perch	Perca flavescens	Х	Х	Х		Х	Х
		Total number of species:	64	43	72	30	38	43

Note: Species are listed alphabetically by common name. Asterisks denote questionable species records. Historic electro-fishing (EF), gill net (GN), and hoop net (HN) data are from TVA 1974b; TVA 1983c; and TVA 1985b. WCF impingement data collected during 1974-1975 are from TVA 1975b. WCF impingement data collected during 2005-2007 are from TVA 2007b.

Table G-6.Individual Metric Ratings and Overall Reservoir Benthic Index (RBI) Scores
for Upstream and Downstream Sampling Sites Near Bellefonte Nuclear
Plant, Guntersville Reservoir, Spring 2009

Spring 2009		stream // 389	Upstream TRM 393.7		
Metric	Obs	Rating	Obs	Rating	
1. Average number of taxa	10.4	5	8,3	3	
2. Proportion of samples with long-lived organisms	1	5	0.9	- 5	
3. Average number of EPT taxa	1	3	0.9	3	
4. Average proportion of oligochaete individuals	12.7	3,	9.1	5	
Average proportion of total abundance comprised by the two most abundant taxa	76.5	3	76	3	
6. Average density excluding chironomids and oligochaetes	250.9	1	214.1	1	
7. Zero-samples - proportion of samples containing no organisms	0	5	0	5	
Reservoir Benthic Index Score		25 Good		25 Good	

Table G-7.	Average Mean Density per Square Meter of Benthic
	Taxa Collected at Upstream and Downstream
	Sampling Sites Near Bellefonte Nuclear Plant,
	Guntersville Reservoir, Spring 2009

Таха	Downstream TRM 389	Upstream TRM 393.7		
	Mean Density	Mean Density		
Turbellaria				
Tricladida				
Planariidae				
Dugesia tigrina	2	2		
Annelida				
Oligocheata				
Lumbriculidae	1			
Naididae	2			
Ophidonais serpentina		1		
Tubificidae	· 112	111 ′		
Limnodrilus hoffmeisteri	14	2		
Branchiura sowerbyi	. ·	1		
Hirudinea				
Rhynchobdellida				
Glossiphoniidae				
Helobdella stagnalis	2			
Crustacea				
Amphipoda				
Corophiidae				
Apocorophium lacustre		5		
Crangonyctidae				
Crangonyx sp.	5	· 8		
Gammaridae				
Gammarus sp.	31	63		
Talitridae				
Hyalella azteca	 .	2		
Insecta	. · · ·	•		
Odonata				
Anisoptera				
Gomphidae				
Gomphus sp.		1 ·		
Libellulidae		1		
Ephemeroptera	· · ·			
Caenidae				
Caenis sp.		5		
Ephemeridae				
<i>Hexagenia limbata</i> <10mm	8	1 1		
<i>Hexagenia limbata</i> >10mm	_, 101	47		
Trichoptera				
Leptoceridae	3	1 <i>′</i>		
Oecetis sp.		3		

Table G-7. (Continued)

Таха	Downstream TRM 389	Upstream TRM 393.7			
	Mean Density	Mean Density			
Diptera					
Chironomidae					
Ablabesmyia annulata	9	3			
Ablabesmyia rhamphe		1			
Axarus sp.		3			
Chironomus sp.	15	. 9			
Coelotanypus sp.	233	64			
Cricotopus sp.		⁻ 1			
Cryptochironomus sp.	3	5 ·			
Dicrotendipes neomodestus	2	1			
Epoicocladius sp.	4	2			
Paracladopelma sp.	4	2			
Polypedilum halterale sp.	27	28			
Procladius sp.	5	3			
Stictochironomus caffrarius	124	77			
,Tanytarsus sp.	2 [.]				
Coleoptera					
Elmidae					
Dubiraphia sp.		1			
Hydrophilidae					
Berosus sp.	1				
Mollusca					
Gastropoda					
Lymnophila					
Ancylidae	· · ·				
Ferrissia rivularis	• 1				
Mesogastropoda					
Hydrobiidae					
Amnicola sp.		1			
Birgella subglobosa	2	1			
Pleuroceridae	<u> </u>				
Pleurocera canaliculata	3	16			
Viviparidae	4				
Campeloma decisum	4				
Bivalvia					
Veneroida					
Corbiculidae	·				
<i>Corbicula fluminea</i> <10 mm	15	29			
<i>Corbicula fluminea</i> >10 mm	72	25			
Sphaeriidae					
Pisidium sp.	·	2			
Unionoida		· ·			
Unionidae					
Potamilus alatus	1				
Density of organisms per m ²	804	525			
Number of samples	10	10			
Total area sampled (m²)	1.05	1.1			

Location	Site	1994	1996	1998	2000	2001	2002	2004	2005	2006	2007	2008	Average
Inflow	TRM 420	21	27	23	25		25	21		23		29	24
Inflow	TRM 408				23	21	21		19	29	25	27	24
Inflow	TRM 406.7				23	23	23		27	27	27	2,7	25
Transition	TRM 375.2	33	33	33	31		31	29		29		25	31
Forebay	TRM 350	27	35	35	23		25	35		23	 -	17	28
Downstream	n of BLN												
Transition	TRM 389	Spring	2009										
		2	25										
Upstream o	f BLN	·											
Transition	TRM 393.7	Spring	g 2009										
		2	25										

 Table G-8.
 Comparison of RBI Scores from Autumn Sampling Conducted During 1994-2008 as Part of the Vital

 Signs Monitoring Program in Guntersville Reservoir

Note: Spring 2009 RBI scores from sites located upstream and downstream of BLN are also included for comparison. RBI Scores: 7-12 (Very Poor); 13-18 (Poor); 19-23 (Fair); 24-29 (Good); or 30-35 (Excellent)

APPENDIX H – AGENCY CONSULTATION

A-207

Page intentionally blank

United States Fish and Wildlife Consultation (Alabama, Georgia, and Tennessee)

Page intentionally blank

.

·



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, Tennessee 37902-1499

November 4, 2009

Mr. Bill Pearson, Supervisor U.S. Fish & Wildlife Service Alabama Ecological Services Field Office 1208-B Main Street Daphne, AL 36526

Dear Mr. Pearson:

The Tennessee Valley Authority (TVA) is proposing to construct and operate a single nuclear unit at the Bellefonte Nuclear Plant (BLNP) site in Jackson County, Alabama, This would be accomplished either by completing one of the existing partially built Babcock & Wilcox (B&W) nuclear units or by constructing a Westinghouse AP1000 nuclear unit. The Draft Supplemental Environmental Impact Statement (DSEIS) describing the environmental impacts of these two alternatives in detail will soon be mailed to your office for use in reviewing this project.

Existing TVA transmission lines in Bedford, Coffee, Sequatchie, Hamilton, and Marion Counties, Tennessee; Limestone, Jackson, and Morgan Counties, Alabama; and Catoosa, Walker, and Dade Counties, Georgia, would need upgrading in order to transmit the power generated at the nuclear plant. The enclosed Biological Assessment (BA) analyzes the impacts of single nuclear unit generation at BLNP site, including the associated transmission line upgrades. Some of the transmission lines originating on the BLNP site are presently de-energized. ROWs for these lines would be brought back to current TVA standards for energized lines. Associated right-of-way maintenance the other affected lines would not change based on this proposed project. Therefore, activities related to vegetation maintenance were not assessed in the enclosed BA.

Based on previous conversations with various offices of the U.S. Fish and Wildlife Service (F&WS), TVA will initiate a formal, programmatic Section 7 Endangered Species Act consultation on its right-of-way maintenance. This consultation would be completed before any transmission line upgrades associated with the generation of electricity at BLNP would be needed, and commitments resulting from the programmatic consultation would be incorporated in that work.

The DSEIS will not identify a preferred alternative. There is little difference in operation between the B&W and AP1000 nuclear units. Therefore, the enclosed BA assumes the most inclusive impacts of construction and operation to potentially-affected species.

Mr. Bill Pearson, Supervisor Page 2 November 4, 2009

TVA has determined that completion or construction and operation of a single nuclear unit at BLNP site in Jackson County, Alabama, would not affect Hine's emerald dragonfly, Sequatchie caddisfly, orangefoot pimpleback, armored snail, royal marstonia, Alabama lampmussel, Alabama moccasinshell, birdwing pearlymussel, cracking pearlymussel, Cumberland monkeyface, Cumberland bean, Cumberland pigtoe, dromedary pearlymussel, fine-lined pocketbook, ring pink, spectaclecase, southern pigtoe, tan riffleshell, boulder darter, palezone shiner, and red-cockaded woodpecker. TVA has determined that the project is not likely to affect Anthony's riversnail, slender campeloma, pale lilliput, slabside pearlymussel, American hart's tongue fern, fleshy-fruit gladecress, green pitcher plant, large-flowered skullcap, leafy prairie-clover, Morefield's leather flower, Price's potato-bean, small whorled pogonia, Virginia spiraea, white fringeless orchid, slackwater darter, snail darter, gray bat, or bald eagle. TVA respectfully requests concurrence for these determinations.

TVA has determined that the project could adversely affect pink mucket and sheepnose (candidate for listing). The enclosed BA provides the details of impacts to these two mussel species from the proposed Bellefonte project. TVA requests that F&WS initiate formal Section 7 consultation for impacts to the pink mucket from this project. TVA requests initiation of formal conference for impacts to the sheepnose.

Sincerely,

Original signed by

Peggy W. Shute, Manager Biological Permitting and Compliance Office of Environment and Research

Enclosures

cc: Ms. Mary Jennings, Supervisor U.S. Fish & Wildlife Service Tennessee Field Office 446 Neal Street Cookeville, TN 38501

Ms. Sandy Tucker, Field Supervisor U.S. Fish & Wildlife Service 105 Westpark Drive, Suite D Athens, GA 30606 Ms. Karen Marlow Science Center, Room 229 Samford University 800 Lakeshore Drive Birmingham, AL 35229-2234

Final Supplemental Environmental Impact Statement

A-212



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, TN 37902-1499

November 4, 2009

Mr. Bill Pearson, Supervisor U.S. Fish & Wildlife Service Alabama Ecological Services Field Office 1208-B Main Street Daphne, AL 36526

Dear Mr. Pearson:

DRAFT SUPPLEMENTAL ENVIRONMENTAL IMPACT STATEMENT (SEIS) FOR A SINGLE NUCLEAR UNIT AT THE BELLEFONTE SITE— JACKSON COUNTY, ALABAMA

Enclosed are two draft copies of the draft SEIS, which evaluates Tennessee Valley Authority's (TVA) proposal to complete or construct and operate a single nuclear generating unit at the Bellefonte Nuclear Plant (BLN) site located in Jackson County, Alabama. TVA is requesting your review of the draft SEIS and is accepting comments between November 13 and December 28, 2009.

TVA is considering a No Action Alternative and two Action Alternatives: completion and operation of a Babcock and Wilcox pressurized light water reactor or construction and operation of a Westinghouse AP1000 advanced pressurized light water reactor. Either of the two Action. Alternatives would use licensing processes that are already underway. The draft SEIS also evaluates the impact of refurbishing, reenergizing, and upgrading existing electrical transmission infrastructure necessary to accommodate new power generation.

TVA has identified the need for additional base load generation in the 2018 to 2020 time frame. Completion or construction of one additional nuclear unit capable of generating between approximately 1,100 and 1,200 megawatt (MW) of power within this time frame would help address the need for additional base load generation in the TVA power service area and help meet TVA's goal to have at least 50 percent of its generation portfolio comprised of low or zero carbon-emitting sources by the year 2020. Both Action Alternatives proposed would also make beneficial use of existing assets at the BLN site.

This draft SEIS supplements TVA's original 1974 Final Environmental Statement – Bellefonte Nuclear Plant Units 1 and 2 for the BLN project and updates other related environmental documents including a 2008 environmental report for the AP1000 for BLN Units 3 and 4. TVA will identify its preferred alternative in the final SEIS after receiving input from the reviewing agencies and the public.

Mr. Bill Pearson, Supervisor November 4, 2009 Page 2

The draft SEIS may be viewed at <u>www.tva.gov/environment/reports/blnp</u>, and comments may be provided to us online. Please note that any comments received, including names and addresses, will become part of the administrative record and will be available for public inspection. To provide written comments or request a printed copy of the draft SEIS, please contact:

Ruth M. Horton Senior NEPA Specialist Tennessee Valley Authority 400 West Summit Hill Drive, WT 11D Knoxville, TN 37902 Phone: (865) 632-3719 E-mail: <u>imhorton@tva.gov</u>.

Also, for general project information, contact:

Andrea L. Sterdis Nuclear Project Manager Tennessee Valley Authority 1101 Market Street, LP 5A Chattanooga, TN 37402 Phone: (423) 751-7119 E-mail: <u>alsterdis@tva.gov</u>

Sincerely,

Original signed by

Peggy W. Shute, Manager Biological Permitting and Compliance Office of Environment and Research

Enclosures

Final Supplemental Environmental Impact Statement



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, TN 37902-1499

November 4, 2009

Ms. Mary E. Jennings, Supervisor U.S. Fish & Wildlife Service Tennessee Field Office 446 Neal Street Cookeville, TN 38501

Dear Ms. Jennings:

DRAFT SUPPLEMENTAL ENVIRONMENTAL IMPACT STATEMENT (SEIS) FOR A SINGLE NUCLEAR UNIT AT THE BELLEFONTE SITE— JACKSON COUNTY, ALABAMA

Enclosed are two draft copies of the draft SEIS, which evaluates Tennessee Valley Authority's (TVA) proposal to complete or construct and operate a single nuclear generating unit at the Bellefonte Nuclear Plant (BLN) site located in Jackson County, Alabama. TVA is requesting your review of the draft SEIS and is accepting comments between November 13 and December 28, 2009.

TVA is considering a No Action Alternative and two Action Alternatives: completion and operation of a Babcock and Wilcox pressurized light water reactor or construction and operation of a Westinghouse AP1000 advanced pressurized light water reactor. Either of the two Action Alternatives would use licensing processes that are already underway. The draft SEIS also evaluates the impact of refurbishing, reenergizing, and upgrading existing electrical transmission infrastructure necessary to accommodate new power generation.

TVA has identified the need for additional base load generation in the 2018 to 2020 time frame. Completion or construction of one additional nuclear unit capable of generating between approximately 1,100 and 1,200 megawatt (MW) of power within this time frame would help address the need for additional base load generation in the TVA power service area and help meet TVA's goal to have at least 50 percent of its generation portfolio comprised of low or zero carbon-emitting sources by the year 2020. Both Action Alternatives proposed would also make beneficial use of existing assets at the BLN site.

This draft SEIS supplements TVA's original 1974 *Final Environmental Statement – Bellefonte Nuclear Plant Units 1 and 2* for the BLN project and updates other related environmental documents including a 2008 environmental report for the AP1000 for BLN Units 3 and 4. TVA will identify its preferred alternative in the final SEIS after receiving input from the reviewing agencies and the public.

Ms. Mary E. Jennings, Supervisor November 4, 2009 Page 2

The draft SEIS may be viewed at <u>www.tva.gov/environment/reports/blnp</u>, and comments may be provided to us online. Please note that any comments received, including names and addresses, will become part of the administrative record and will be available for public inspection. To provide written comments or request a printed copy of the draft SEIS, please contact:

Ruth M. Horton Senior NEPA Specialist Tennessee Valley Authority 400 West Summit Hill Drive, WT 11D Knoxville, TN 37902 Phone: (865) 632-3719 E-mail: rmhorton@tva.gov.

Also, for general project information, contact:

Andrea L. Sterdis Nuclear Project Manager Tennessee Valley Authority 1101 Market Street, LP 5A Chattanooga, TN 37402 Phone: (423) 751-7119 E-mail: alsterdis@tva.gov

Sincerely,

Original signed by

Peggy W. Shute, Manager Biological Permitting and Compliance Office of Environment and Research

Enclosures



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, TN 37902-1499

November 4, 2009

Ms. Sandy Tucker, Field Supervisor U.S. Fish & Wildlife Service 105 Westpark Drive, Suite D Athens, GA 30606

Dear Ms. Tucker:

DRAFT SUPPLEMENTAL ENVIRONMENTAL IMPACT STATEMENT (SEIS) FOR A SINGLE NUCLEAR UNIT AT THE BELLEFONTE SITE – JACKSON COUNTY, ALABAMA

Enclosed is a copy of the draft SEIS, which evaluates Tennessee Valley Authority's (TVA) proposal to complete or construct and operate a single nuclear generating unit at the Bellefonte Nuclear Plant (BLN) site located in Jackson County, Alabama. TVA is requesting your review of the draft SEIS and is accepting comments between November 13 and December 28, 2009.

TVA is considering a No Action Alternative and two Action Alternatives; completion and operation of a Babcock and Wilcox pressurized light water reactor or construction and operation of a Westinghouse AP1000 advanced pressurized light water reactor. Either of the two Action Alternatives would use licensing processes that are already underway. The draft SEIS also evaluates the impact of refurbishing, reenergizing, and upgrading existing electrical transmission infrastructure necessary to accommodate new power generation.

TVA has identified the need for additional base load generation in the 2018 to 2020 time frame. Completion or construction of one additional nuclear unit capable of generating between approximately 1,100 and 1,200 megawatt (MW) of power within this time frame would help address the need for additional base load generation in the TVA power service area and help meet TVA's goal to have at least 50 percent of its generation portfolio comprised of low or zero carbon-emitting sources by the year 2020. Both Action Alternatives proposed would also make beneficial use of existing assets at the BLN site.

This draft SEIS supplements TVA's original 1974 *Final Environmental Statement – Bellefonte Nuclear Plant Units 1 and 2* for the BLN project and updates other related environmental documents including a 2008 environmental report for the AP1000 for BLN Units 3 and 4. TVA will identify its preferred alternative in the final SEIS after receiving input from the reviewing agencies and the public.

Ms. Sandy Tucker, Field Supervisor November 4, 2009 Page 2

The draft SEIS may be viewed at <u>www.tva.gov/environment/reports/blnp</u>, and comments may be provided to us online. Please note that any comments received, including names and addresses, will become part of the administrative record and will be available for public inspection. To provide written comments or request a printed copy of the draft SEIS, please contact:

Ruth M. Horton Senior NEPA Specialist Tennessee Valley Authority 400 West Summit Hill Drive, WT 11D Knoxville, TN 37902 Phone: (865) 632-3719 E-mail: rmhorton@tva.gov.

Also, for general project information, contact:

Andrea L. Sterdis Nuclear Project Manager Tennessee Valley Authority 1101 Market Street, LP 5A Chattanooga, TN 37402 Phone: (423) 751-7119 E-mail: <u>alsterdis@tva.gov</u>

Sincerely,

Original signed by

Peggy W. Shute, Manager Biological Permitting and Compliance Office of Environment and Research

Enclosures

TVA

Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, TN 37902-1499

November 4, 2009

Ms. Karen Marlow U.S. Fish and Wildlife Service Science Center, Room 229 Samford University 800 Lakeshore Drive Birmingham, AL 35229-2234

Dear Ms. Marlow:

DRAFT SUPPLEMENTAL ENVIRONMENTAL IMPACT STATEMENT (SEIS) FOR A SINGLE NUCLEAR UNIT AT THE BELLEFONTE SITE—JACKSON COUNTY, ALABAMA

Enclosed is a copy of the draft SEIS, which evaluates Tennessee Valley Authority's (TVA) proposal to complete or construct and operate a single nuclear generating unit at the Bellefonte Nuclear Plant (BLN) site located in Jackson County, Alabama. TVA is requesting your review of the draft SEIS and is accepting comments between November 13 and December 28, 2009.

TVA is considering a No Action Alternative and two Action Alternatives: completion and operation of a Babcock and Wilcox pressurized light water reactor or construction and operation of a Westinghouse AP1000 advanced pressurized light water reactor. Either of the two Action Alternatives would use licensing processes that are already underway. The draft SEIS also evaluates the impact of refurbishing, reenergizing, and upgrading existing electrical transmission infrastructure necessary to accommodate new power generation.

TVA has identified the need for additional base load generation in the 2018 to 2020 time frame. Completion or construction of one additional nuclear unit capable of generating between approximately 1,100 and 1,200 megawatt (MW) of power within this time frame would help address the need for additional base load generation in the TVA power service area and help meet TVA's goal to have at least 50 percent of its generation portfolio comprised of low or zero carbon-emitting sources by the year 2020. Both Action Alternatives proposed would also make beneficial use of existing assets at the BLN site.

This draft SEIS supplements TVA's original 1974 Final Environmental Statement – Bellefonte Nuclear Plant Units 1 and 2 for the BLN project and updates other related environmental documents including a 2008 environmental report for the AP1000 for BLN Units 3 and 4. TVA will identify its preferred alternative in the final SEIS after receiving input from the reviewing agencies and the public.

Ms. Karen Marlow November 4, 2009 Page 2

The draft SEIS may be viewed at <u>www.tva.gov/environment/reports/blnp</u>, and comments may be provided to us online. Please note that any comments received, including names and addresses, will become part of the administrative record and will be available for public inspection. To provide written comments or request a printed copy of the draft SEIS, please contact:

Ruth M. Horton Senior NEPA Specialist Tennessee Valley Authority 400 West Summit Hill Drive, WT 11D Knoxville, TN 37902 Phone: (865) 632-3719 E-mail: rmhorton@tva.gov.

Also, for general project information, contact:

Andrea L. Sterdis Nuclear Project Manager Tennessee Valley Authority 1101 Market Street, LP 5A Chattanooga, TN 37402 Phone: (423) 751-7119 E-mail: <u>alsterdis@tva.gov</u>

Sincerely,

Original signed by

Peggy W. Shute, Manager Biological Permitting and Compliance Office of Environment and Research

Enclosures

Final Supplemental Environmental Impact Statement



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, TN 37902-1499

November 4, 2009

Ms. Cynthia Dohner Southeast Regional Director U.S. Fish and Wildlife Service 1875 Century Boulevard, Suite 400 Atlanta, GA 30345

Dear Ms. Dohner:

DRAFT SUPPLEMENTAL ENVIRONMENTAL IMPACT STATEMENT (SEIS) FOR A SINGLE NUCLEAR UNIT AT THE BELLEFONTE SITE— JACKSON COUNTY, ALABAMA

Enclosed is a copy of the draft SEIS, which evaluates Tennessee Valley Authority's (TVA) proposal to complete or construct and operate a single nuclear generating unit at the Bellefonte Nuclear Plant (BLN) site located in Jackson County, Alabama. TVA is requesting your review of the draft SEIS and is accepting comments between November 13 and December 28, 2009.

TVA is considering a No Action Alternative and two Action Alternatives: completion and operation of a Babcock and Wilcox pressurized light water reactor or construction and operation of a Westinghouse AP1000 advanced pressurized light water reactor. Either of the two Action Alternatives would use licensing processes that are already underway. The draft SEIS also evaluates the impact of refurbishing, reenergizing, and upgrading existing electrical transmission infrastructure necessary to accommodate new power generation.

TVA has identified the need for additional base load generation in the 2018 to 2020 time frame. Completion or construction of one additional nuclear unit capable of generating between approximately 1,100 and 1,200 megawatt (MW) of power within this time frame would help address the need for additional base load generation in the TVA power service area and help meet TVA's goal to have at least 50 percent of its generation portfolio comprised of low or zero carbon-emitting sources by the year 2020. Both Action Alternatives proposed would also make beneficial use of existing assets at the BLN site.

This draft SEIS supplements TVA's original 1974 Final Environmental Statement – Bellefonte Nuclear Plant Units 1 and 2 for the BLN project and updates other related environmental documents including a 2008 environmental report for the AP1000 for BLN Units 3 and 4. TVA will identify its preferred alternative in the final SEIS after receiving input from the reviewing agencies and the public.

Ms. Cynthia Dohner November 4, 2009 Page 2

The draft SEIS may be viewed at <u>www.tva.gov/environment/reports/blnp</u>, and comments may be provided to us online. Please note that any comments received, including names and addresses, will become part of the administrative record and will be available for public inspection. To provide written comments or request a printed copy of the draft SEIS, please contact:

Ruth M, Horton Senior NEPA Specialist Tennessee Valley Authority 400 West Summit Hill Drive, WT 11D Knoxville, TN 37902 Phone: (865) 632-3719 E-mail: mhorton@tva.gov.

Also, for general project information, contact:

Andrea L. Sterdis Nuclear Project Manager Tennessee Valley Authority 1101 Market Street, LP 5A Chattanooga, TN 37402 Phone: (423) 751-7119 E-mail: alsterdis@tva.gov

Sincerely,

Original signed by

Peggy W. Shute, Manager Biological Permitting and Compliance Office of Environment and Research

Enclosures

Final Supplemental Environmental Impact Statement



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, TN 37902-1499

November 4, 2009

Mr. Dwight Cooley, Field Supervisor U.S. Fish and Wildlife Service 2700 Refuge Headquarters Road Decatur, AL 35603

Dear Mr. Cooley:

DRAFT SUPPLEMENTAL ENVIRONMENTAL IMPACT STATEMENT (SEIS) FOR A SINGLE NUCLEAR UNIT AT THE BELLEFONTE SITE— JACKSON COUNTY, ALABAMA

Enclosed is a copy of the draft SEIS, which evaluates Tennessee Valley Authority's (TVA) proposal to complete or construct and operate a single nuclear generating unit at the Bellefonte Nuclear Plant (BLN) site located in Jackson County, Alabama. TVA is requesting your review of the draft SEIS and is accepting comments between November 13 and December 28, 2009.

TVA is considering a No Action Alternative and two Action Alternatives: completion and operation of a Babcock and Wilcox pressurized light water reactor or construction and operation of a Westinghouse AP1000 advanced pressurized light water reactor. Either of the two Action Alternatives would use licensing processes that are already underway. The draft SEIS also evaluates the impact of refurbishing, reenergizing, and upgrading existing electrical transmission infrastructure necessary to accommodate new power generation.

TVA has identified the need for additional base load generation in the 2018 to 2020 time frame. Completion or construction of one additional nuclear unit capable of generating between approximately 1,100 and 1,200 megawatt (MW) of power within this time frame would help address the need for additional base load generation in the TVA power service area and help meet TVA's goal to have at least 50 percent of its generation portfolio comprised of low or zero carbon-emitting sources by the year 2020. Both Action Alternatives proposed would also make beneficial use of existing assets at the BLN site.

This draft SEIS supplements TVA's original 1974 Final Environmental Statement – Bellefonte Nuclear Plant Units 1 and 2 for the BLN project and updates other related environmental documents including a 2008 environmental report for the AP1000 for BLN Units 3 and 4. TVA will identify its preferred alternative in the final SEIS after receiving input from the reviewing agencies and the public.

Mr. Dwight Cooley, Field Supervisor November 4, 2009 Page 2

The draft SEIS may be viewed at <u>www.tva.gov/environment/reports/blnp</u>, and comments may be provided to us online. Please note that any comments received, including names and addresses, will become part of the administrative record and will be available for public inspection. To provide written comments or request a printed copy of the draft SEIS, please contact:

Ruth M. Horton Senior NEPA Specialist Tennessee Valley Authority 400 West Summit Hill Drive, WT 11D Knoxville, TN 37902

Phone: (865) 632-3719 E-mail: <u>rmhorton@tva.gov</u>.

Also, for general project information, contact:

Andrea L. Sterdis Nuclear Project Manager Tennessee Valley Authority 1101 Market Street, LP 5A Chattanooga, TN 37402 Phone: (423) 751-7119 E-mail: <u>alsterdis@tva.gov</u>

Sincerely,

Original signed by

Peggy W. Shute, Manager Biological Permitting and Compliance Office of Environment and Research

Enclosures



IN REPLY REFER TO: 2006-F-1022(a)

United States Department of the Interior

FISH AND WILDLIFE SERVICE 1208-B Main Street Daphne, Alabama 36526

DEC 0 7 2009

Peggy W. Shute Biological Permitting and Compliance Office of Environment and Research 400 West Summit Hill Drive, WT 11C Knoxville, TN 37901-1401

Dear Ms. Shute:

This letter acknowledges the U.S. Fish and Wildlife Service's (Service) November 6, 2009, receipt of your November 4, 2009, biological assessment and letter requesting initiation of formal section 7 consultation under the Endangered Species Act (Act). The consultation concerns the possible effects of the Tennessee Valley Authority's (TVA) proposed construction and operation of a single nuclear unit at the Bellefonte Nuclear Plant site in Jackson County, Alabama, on the endangered pink mucket pearlymussel (*Lampsilis ubrupta*) and the sheepnose mussel (*Plethobasus cyphyus*), a candidate for listing under the Act.

TVA is considering either the completion of an existing, partially built Babcock & Wilcox nuclear unit, or the construction of a new Westinghouse AP1000 nuclear unit and has not yet identified a preferred alternative in the biological assessment and draft supplemental environmental impact statement (SEIS). We understand that TVA will identify its preferred alternative in the final SEIS after receiving input from the reviewing agencies and the public. As discussed and agreed upon in our November 24, 2009, conference call, the Service will address the possible effects of each of the proposed alternatives in our consultation with TVA.

We concur with your determination that the proposed project will not affect the following endangered (E) threatened (T), and candidate (C) species:

Alabama lampmussel (Lampsilis virescens) - E Alabama moccasinshell (Medionidus acutissimus) - T Aumored statii (Marstonia (~Fyrgulopsis) pachyta) - E Birdwing pearlymussel (Lemiox rimosus (= Conradilla caelata)) - E Boulder darter (Etheostoma wapiti) - E Cracking pearlymussel (Hemistena lata) - E Cumberland bean pearlymussel (Villosa trabalis) - E Cumberland monkeyface pearlymussel (Quadrula intermedia) - E Cumberland pigtoe (Pleurobema gibberum) - E

PHONE: 251-441-5181



FAX: 251-441-6222

A-225

Ms. Peggy W. Shute

Dromedary pearlymussel (Dromus dromas) - E Fine-lined pocketbook (Hamiota altilis) - T Hine's emerald dragonfly (Somatochlora hineana) - E Orangefoot pimpleback pearlymussel (Plethobasus coopertanus) - E Palezone shiner (Notropis albizonatus) -E Red-cockaded woodpecker (Picoides borealis) - E Ring pink (Obovaria retusa) - E Royal (obese) marstonia snail (Marstonia ogmoraphe) - E Sequatchie caddisfly (Glyphopsyche sequalchie) - C Southern pigtoe (Pleurobema georgianum) - E Spectaclecase (Cumberlandia monodonta) - C Tan riffleshell (Epioblasma florentina walkeri (=E, walkeri)) - E

Likewise, we concur with your finding that the proposed project may affect, but is not likely to adversely affect, the following species:

2

American hart's tongue fern (Asplenium scolopendrium var. americanum) - T Anthony's riversnail (Athearnia anthonyi) - E Gray bat (Myotis grisescens) E Green pitcher-plant (Sarracenia oreophila) - E Large-flowered skullcap (Scutellaria montana) - E Leafy prairie-clover (Dalea (=Petalostemum) foliosa) - E Morefield's leather-flower (Clematis morefieldii) - E Pale lilliput pearlymussel (Toxolasma cylindrellus) - E Price's potato-bean (Apios priceana) - T Slabside pearlymussel (Lexingtonia dolabelloides) - C Slackwater darter (Etheostoma boschungi) - T Slender campeloma (Campeloma decampi) - E Small whorled pogonia (Isotria medeoloides) - T Snail darter (Percina tanasi) - T Unnamed gladecress (Leavenworthia crassa) - C Virginia spiraea (Spriraea virginiana) - T White fringeless orchid (Platanthera integrilabia) - C

All information required of you to initiate consultation on the possible effects of the proposed construction and operation of a single nuclear unit at the Bellefonte Nuclear Plant site in Jackson County, Alabama, on the endangered pink mucket pearlymussel (*Lampsilis abrupta*) and the sheepnose mussel (*Plethobasus cyphyus*) was either included with your letter or is otherwise accessible for our consideration and reference. We have assigned log number 2006-F-1022(a) to this consultation. Please refer to that number in future correspondence on this consultation.

Section 7 allows the Service up to 90 days to conclude formal consultation with your agency and an additional 45 days to prepare our biological opinion (unless we mutually agree to an extension). Therefore, we anticipate completing the consultation by February 4, 2010, and the biological opinion by March 22, 2010.

A-226

As a reminder, the Endangered Species Act requires that after initiation of formal consultation, the Federal action agency make no irreversible or irretrievable commitment of resources that limits future options. This practice insures agency actions do not preclude the formulation or implementation of reasonable and prudent alternatives that avoid jeopardizing the continued existence of endangered or threatened species or destroying or modifying their critical habitats.

If you have any questions or need additional information, please contact Ms. Karen Marlowe of my staff at (205) 726-2667. Please use the reference number located at the top of this letter in future phone calls or written correspondence.

Sincerely, Mun Heuson

William J. Pearson Field Supervisor Alabama Ecological Services Field Office

cc: USFWS, Ecological Services, Asheville, NC USFWS, Ecological Services, Cookeville, TN USFWS, Ecological Services, Jackson, MS USFWS, Ecological Services, Frankfort, KY USFWS, Ecological Services, Clemson, SC USFWS, Ecological Services, Chicago, IL



United States Department of the Interior

FISH AND WILDLIFE SERVICE 1208-B Main Street Daphne, Alabama 36526

JAN 2 1 2010

2006-F-1022

Peggy W. Shute Biological Permitting and Compliance Office of Environment and Research 400 West Summit Hill Drive, WT 11C Knoxville, TN 37901-1401

Dear Ms. Shute:

This letter follows up our December 7, 2009, acknowledgement of receipt of your November 4, 2009, biological assessment and letter requesting initiation of formal section 7 consultation under the Endangered Species Act of 1973, as amended (Act). In the course of our review of the Tennessee Valley Authority's (TVA) proposed construction and operation of a single nuclear unit at the Bellefonte Nuclear Plant site in Jackson County, Alabama, with associated transmission line upgrades and the proposed project's effects on the endangered pink mucket pearlymussel (*Lampsilis abrupta*) and candidate sheepnose mussel (*Plethobasus cyphyus*), we have concluded that there will be no effect to the sheepnose mussel.

The only record of a sheepnose in recent history anywhere near the Bellefonte site is the discovery of a single, old, weathered shell near the plant during the mussel and snail surveys that were conducted for the biological assessment (Charles Howard, pers. comm. 2010; Gerry Dinkins, pers. comm. 2009) and there are no records of the sheepnose upstream of Interstate 65 at Decatur, Alabama (Jeff Garner, pers. comm. 2010). We, therefore, intend to consult only on the effects of the proposed Bellefonte Nuclear Plant project on the endangered pink mucket pearlymussel. We continue to anticipate completing the consultation by February 4, 2010, and the biological opinion by March 22, 2010.

If you have any questions or need additional information, please contact Ms. Karen Marlowe of my staff at (205) 726-2667. Please use the reference number located at the top of this letter in future phone calls or written correspondence.

Sincerely.

William J. Pearson Field Supervisor Alabama Ecological Services Field Office

PHONE: 251-441-5181

FAX: 251-441-6222

Final Supplemental Environmental Impact Statement



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, TN 37902-1499

March 18, 2010

Mr. William J. Pearson, Field Supervisor Alabama Ecological Services Field Office U.S. Fish and Wildlife Service 1208-B Main Street Daphne, AL 36526

Dear Mr. Pearson:

On November 4, 2009, the Tennessee Valley Authority (TVA) submitted a Biological Assessment (BA) and request for formal consultation (according to Section 7 of the Endangered Species Act) to your office for the TVA project entitled "Proposed Single Unit Nuclear Plant Development at Bellefonte Nuclear Site and Associated Transmission line upgrades, in Alabama, Tennessee, and Georgia" (USFWS ID: 2006-F-1022). As a result of the BA, TVA determined that the project was likely to adversely affect the federally-listed-as-endangered pink mucket pearlymussel (*Lampsilis abrupta*). After consultation with your office and further evaluation of the project's impacts to pink mucket, TVA has committed to additional protective measures that would help minimize the project's adverse impacts to pink mucket, which are in addition to measures and best management practices previously described in the BA.

Our evaluation of impacts determined that the project would directly affect 25,455 m² of mussel habitat and indirectly affect 89,876 m² of habitat in the Tennessee River within the intake channel, overbank area near the intake channel, barge slip area, and effluent mixing zone (areas combined). Based on relative densities of mussels found within the action area and assumptions about the frequency of pink mucket, TVA determined that a total of five adult pink mucket could be directly taken via harm or kill and that 63 adult pink mucket could be indirectly taken via harm.

The effort and cost associated with translocating these mussels from the project area (even if restricted to areas of direct impacts only) to a suitable location within the Tennessee River and monitoring their health would be extraordinary, especially when considering the relative benefit to the species and generally poor or marginal habitat for pink mucket (and most other unionid mussel species) within the proposed action area. Therefore, in lieu of translocation as a protective measure, TVA would commit to funding other conservation actions aimed to recover pink mucket and its habitat.

To determine an appropriate amount of funding for this proposed Bellefonte project, we compared the potential adverse impacts of the proposed project with impacts from a recently permitted project for a barge loading facility at Tennessee River mile 424 upstream from the Bellefonte Nuclear Plant site at the head of Guntersville Reservoir (Biological Assessment: Proposed Fabrication and Loading Facility by Chicago Bridge

Final Supplemental Environmental Impact Statement

Mr. William J. Pearson, Field Supervisor Page 2 March 18, 2010

and Iron [CBI] Company [Marion County, Tennessee], TVA 2008). For the CBI project, the applicant committed to \$25,000 that would be used for pink mucket recovery. The applicants also committed to two years of post-construction mussel monitoring and reporting to identify project impacts within and adjacent to the CBI action area.

The proposed Bellefonte project would directly take fewer pink mucket than the CBI project (5 vs. 17 individuals, respectively), and indirectly take slightly fewer pink mucket (62 vs. 66 individuals, respectively). The proposed Bellefonte project would directly affect substantially more habitat than the CBI project (25,455 m² vs. 3,300 m²). However, mussel habitat quality at the Bellefonte site, particularly in areas to be directly affected by dredging impacts, is relatively poor compared to habitat present at the CBI site. At the Bellefonte site, mussel density is 0.12 - 0.81 mussels/m² vs. 4.76 mussels/m² at the CBI site. TVA has taken into consideration both the area affected and the quality of the mussel habitat in developing its proposed mitigation.

TVA would commit a total of \$30,000 to be used for research and recovery of pink mucket to mitigate impacts to the species that would result from constructing and operating a single nuclear unit at the Bellefonte Nuclear site. However, TVA does not stipulate the use of these monies for specific projects. If funding more general research evaluating impacts of water-based facilities (like the Bellefonte Nuclear site) to mussel habitats in the mainstem Tennessee River were of interest to the U.S. Fish and Wildlife Service, TVA would not object to this use of funds.

If you have questions about these additional commitments, please contact me or Chuck Howard at (865) 632-2092.

Sincerely,

Original signed by

Peggy W. Shute, Manager Biological Permitting and Compliance Endangered Species Act Compliance Officer Office of Environment and Technology

Emailed copy provided to Karen Marlow, U.S.F&WS, Birmingham, AL



IN REPLY REFER TO

United States Department of the Interior

FISH AND WILDLIFE SERVICE 1208-B Main Street Daphne, Alabama 36526

APR 1 5 2013

2006-F-1022

Peggy W. Shute Tennessee Valley Authority Biological Permitting and Compliance Office of Environment and Research 400 West Summit Hill Drive, WT 11C Knoxille, TN 37901-1401

Dear Ms. Shute:

This document transmits the Fish and Wildlife Service's (Service) biological opinion based on the Service's review of the Tennessee Valley Authority's (TVA) proposed construction and operation of a single nuclear unit at the Bellefonte Nuclear Plant (BLN) site in Jackson County, Alabama, and its effects on the endangered pink mucket (pearlymussel) (*Lampsilis abrupta*) in accordance with section 7 of the Endangered Species Act (ESA) of 1973, as amended (16 U.S.C. 1531 *et seg.*). The proposed project includes associated transmission line upgrades in Bedford, Coffee, Sequatchie, Hamilton and Marion Counties, Tennessee; Limestone, Jackson and Morgan Counties, Alabama; and Catoosa, Walker and Dade Counties, Georgia. The November 4, 2009, request for formal consultation was received on November 6, 2009.

This biological opinion is based on information provided in the November 4, 2009, biological assessment (BA) titled *Biological Assessment: Proposed Single Unit Nuclear Plant Development at Bellefonte Nuclear Site and Associated Transmission Line Upgrades, Alabama, Tennessee, and Georgia;* the November 2009 draft Supplemental Environmental Impact Statement (SEIS); survey reports; available literature; and other sources of information. A complete administrative record of this consultation is on file in the Alabama Field Office located in Daphne, Alabama.

Consultation History

- July 17, 2006: NuStart Energy Development, LLC, (NuStart) wrote a letter to the Service's Daphne, Alabama, field office (Alabama FO) seeking information on threatened, endangered, and candidate species and habitats in and around the 1,600acre Bellefonte site being considered for an advanced technology nuclear power plant.
- August 17, 2006: The Alabama FO wrote a response to NuStart providing a species list, recommending surveys, and requesting additional information on the proposed project.

PHONE: 251-441-5181



FAX: 251-441-6222

Ms. Peggy W. Shute

- September 6, 2006: TVA wrote a letter to the Alabama FO, clarifying NuStart's role in the Nuclear Regulatory Commission (NRC) combined construction and operating license process for the Bellefonte plant site.
- November 6, 2006: Enercon Services, Inc., (Enercon) the environmental contractor for NuStart, called the Alabama FO requesting information on the State of Alabama's thermal limits and clarification on the surveys needed for the pink mucket and Anthony's riversnail (*Athearnia anthonyi*).
- January 21, 2007: Enercon acknowledged the Service's August 17, 2006, letter, to NuStart and provided further information in response to some of the Service's recommendations and concerns.
- February 1, 2007: A meeting at Wheeler National Wildlife Refuge between the Service, Enercon, and TVA was held to further discuss the Service's issues and concerns and Enercon's responses and data gathered to date.
- June 18, 2007: The Alabama FO received the aquatic mussel survey report from Mainstream Commercial Divers, Inc, the consultant hired by Enercon. Survey efforts found no threatened or endangered mussel species along any of the 22 transects.
- February 12, 2008: Enercon transmitted a winter plant habitat survey report to the Alabama FO, stating there was no habitat present within the project footprint for listed plants.
- February 26, 2008: In a telephone conversation with Enercon, the Alabama FO recommends surveys during the flowering/fruiting period for the threatened Price's potato-bean (*Apios priceana*) and endangered Morefield's leather flower (*Clematis morefieldit*).
- February 26, 2008: The NRC sent a letter to the Service's Regional Director in Atlanta, Georgia, requesting a list of protected species within the area under evaluation for the Bellefonte Nuclear Plant, Units 3 and 4 combined license application. The letter was received by the Alabama FO on November 18, 2008.
- December 22, 2008: The Alabama FO responded to the NRC, summarizing the past survey recommendations and results, and recommending surveys for the Price's potato-bean and Moorefield's leather flower during the flowering/fruiting period.
- August 27, 2009: A meeting between TVA and the Service was held in the Service's Cookeville, Tennessee, field office to discuss an appropriate process and timeline for conducting the endangered species section 7 consultation for the proposed Bellefonte Nuclear Plant project.
- October 1, 2009: A meeting between TVA and the Service was held in Birmingham, Alabama. The meeting was called by TVA to provide the Service with a summary of the proposed construction and operation of a nuclear unit at the Bellefonte Nuclear Power Plant and to discuss the upcoming release of the draft SEIS and submission of the BA.
- November 6, 2009: The Alabama FO receives TVA's BA and letter requesting initiation of formal consultation for the construction and operation of a single nuclear unit at Bellefonte Nuclear Plant and its effects on the endangered pink mucket (pearlymussel) and the candidate sheepnose mussel (*Plethobasus cyphyus*).

- November 23, 2009: The Alabama FO received the draft SEIS for a single nuclear unit at Bellefonte Nuclear Plant.
- November 24, 2009: A conference call between TVA and the Service was held to clarify the project alternative(s) to be addressed in the formal consultation.
- December 7, 2009: The Alabama FO sent a letter to TVA acknowledging receipt of the BA and initiating formal consultation.
- January 21, 2010: The Alabama FO sent a letter to TVA stating that, given the fact that there were no current records of the sheepnose within the project area, the proposed project would have no effect on this candidate species.
- March 1, 2010: The Alabama FO sent the draft biological opinion (BO) to TVA for review.
- March 18, 2010: TVA sent comments on the draft BO and revised the project description to include a commitment to provide \$30,000 for research and recovery of pink mucket.
- April 1, 2010: Alabama FO staff met with TVA to discuss and flesh out the pink mucket recovery project to be included as part of the project description in the BO.

Table 1. Species and critical habitat evaluated for effects and those where the Service has concurred with a "not likely to be adversely affected" determination.

ENDANGERED (E),	PRESENT IN ACTION	PRESENT IN ACTION
THREATENED (T), OR CANDIDATE (C)	AREA	AREA BUT "NOT LIKELY TO BE
SPECIES or CRITICAL HABITAT		ADVERSELY AFFECTED"
American hart's-tongue fern (Asplenium scolopendrium) var. americanum) - T	Yes	Yes
Anthony's riversnail (Athearnia anthonyi) - E	Yes	Yes
Gray bat (Myotis grisescens) E	Yes	Yes
Green pitcher-plant (Sarracenia oreophila) - E	Yes	Yes .
Large-flowered skullcap (Scutellaria montana) - E	Yes	Yes
Leafy prairie-clover (Dalea (=Petalostemum) foliosa) - E	Yes	Yes
Morefield's leather-flower (Clematis morefieldii) - E	Yes	Yes
Pale lilliput pearlymussel (Toxolasma cylindrellus) - E	Yes	Yes
Price's potato-bean (Aplos priceana) - T	Yes	Yes
Slabsido pearlymussel (Lexingtonia dolabelloides) -	Yes	Yes

Ms. Peggy W. Shute

С	-	
Slackwater darter (Etheostoma boschungi) - T	Yes	Yes
Slender campeloma (Campeloma decampi) - E	Yes	Yes
Small whorled pogonia (Isotria medeoloides) - T	Yes	Yes
Snail darter (Percina tanasi) - T	Yes	Yes
Unnamed gladecress (Leavenworthia crassa) - C	Yes	Yes
Virginia spiraea (Spriraea virginiana) - T	Yes	Yes
White fringeless orchid (Platanthera integrilabia) - C	Yes	Yes .

BIOLOGICAL OPINION

DESCRIPTION OF PROPOSED ACTION

This project description is taken from the BA and draft SEIS. The action evaluated in this consultation is TVA's proposed construction and operation of a single nuclear unit at the Bellefonte Nuclear Plant site in Jackson County, Alabama, with associated transmission line upgrades. TVA intends to either complete and operate one of the partially constructed Babcock & Wilcox (B&W) pressurized light water reactor units on the BLN site (BLN unit 1 or 2) or construct and operate a new Westinghouse AP1000 advanced pressurized light water reactor at the site. A preferred alternative has not yet been identified. TVA intends to identify its preferred alternative in the final SEIS for the proposed project. This consultation, therefore, addresses the possible effects of each of the proposed alternatives on the endangered pink mucket.

The Action Area (Figures 1 and 2) extends from approximately Tennessee River mile (TRM) 392.4 to TRM 390.8, and includes the 1,200-foot (ft) (366-meter (m)) long, 330-ft (101 m) wide intake channel connecting Guntersville Reservoir with the BLN intake pumping station; the mainstem river portion, or intake channel overbank, for which the effects of dredging will extend approximately 580 ft (177 m) out from the riverward boundary of the intake channel proper; the barge terminal, which is located in a small embayment along the right bank of the river at the downstream margin of the BLN site; and, the area (i.e., the mixing zone) within the Tennessee River that is expected to be directly and indirectly impacted by effluent (thermal and chemical) discharges from an existing two-pipe multiport diffuser located at the downstream margin of the barge terminal embayment and extending approximately 430 ft (131 m) into the river. The action area also includes the BLN site itself, located on the peninsula bounded by the Tennessee River and Town Creek at TRM 391.5, and the sites in

5

Ms. Peggy W. Shute





Figure 1. Intake channel and intake channel overbank.



6

Figure 2. The mixing zone and barge terminal.

Final Supplemental Environmental Impact Statement

A-236

which transmission line upgrades are planned in association with the BLN construction and operation; however, as summarized in Table 1 (above), no endangered, threatened, or proposed species are likely to be adversely affected by the proposed construction activities on land at the BLN site and by the transmission line upgrades.

Dredging

Intake Channel

For both alternatives, dredging of the cooling water intake channel, which is located at the upstream boundary of the BLN site, will be necessary to remove fine sediments prior to the facility operation, along with maintenance dredging every 5-10 years. Approximately 10,000 cubic yards of dredged material will be removed from a 240,000 square foot (5.5 acre) area, from the pumping station to the trash boom (ca. 1,200 ft. or 366 m).

Intake Channel Overbank

For the B&W reactor, an additional 11,100 cubic yards of material will be removed from the trash boom to the main river channel (i.e., the intake channel overbank) (ca. 760 ft (232 m) long and 25 ft (7.62 m) wide), extending 580 ft (177 m) into the Tennessee River from the intake channel proper. Direct and indirect impacts from the intake channel and intake channel overbank dredging are expected to encompass an area extending from slightly upstream of the intake channel overbank to 330 ft (101 m) downstream.

Barge Unloading Dock

For both the B&W reactor and the AP1000 reactor, the unloading dock will be refurbished. No additional dredging at the barge unloading dock will be required for the B&W reactor; however, approximately 240 cubic yards of material will need to be dredged from an area in the embayment measuring approximately 150 ft (46 m) long and 100 ft wide (30.5 m) (=15,000 square ft or .34 acres) for the AP1000 reactor. Direct and indirect impacts from the dredging of the embayment for the AP1000 reactor are expected to extend from slightly upstream of the embayment to 330 ft (101 m) downstream.

All dredged material will be disposed of on-site in an approved area above the 500-year flood elevation.

Barge Traffic

Under both alternatives, barges will be used to transport heavy equipment, large reactor components, construction modules too large to ship by train, and removal of construction debris and other waste from the site.

Thermal and Chemical Discharges

7

The type of thermal and chemical discharges from the two-pipe multiport diffuser located at the downstream margin of the barge terminal embayment and extending approximately 430 ft (131 m) into the river channel will be similar for both the B&W reactor and the AP1000 reactor, although slightly reduced for the AP1000 reactor (i.e., the AP1000 discharge would be 36 percent of that associated with a B&W reactor). As permitted under BLN's NPDES permit number AL0024635, the discharges consist of cooling tower blowdown and other wastewater resulting from electric power generation. The discharge temperature limitations (92°/95° F or 33°/35°C) ensure that the temperature at the edge of the mixing zone will not exceed 90°F (32°C), the temperature considered protective of maintaining a balanced indigenous population of fish, shellfish, and aquatic life (ADEM 1998; TVA 1982). The mixing zone (i.e., the limits of where thermal and chemical effects from the diffuser would be felt) encompasses a 250-ft (76 m) radius from the diffuser in all directions (Figure 3).




Figure 3. Diffuser and mixing zone

Conservation Measure Proposed as Part of the Action

In accordance with the Service's draft 5-year review (Service 2009) and recommendations for reintroduction and augmentation outlined in the draft "Plan for the Controlled Propagation, Augmentation and Reintroduction of Freshwater Mollusks of the Cumberlandian Region" prepared by the Cumberlandian Region Mollusk Restoration Committee (2009), TVA will provide \$30,000 to the Alabama Aquatic Biodiversity Center (AABC) for the reintroduction and/or augmentation of pink mucket and other high priority mollusks within their historic ranges. The reintroduction/augmentation project will be funded by TVA prior to the initiation of dredging activities described above.

STATUS OF THE SPECIES/CRITICAL HABITAT

Listed species/critical habitat description

The pink mucket was listed as endangered without critical habitat on June 14, 1976 (41 FR 24062-24067). The preferred habitat of this species is in medium to large rivers in habitat ranging from silt to boulders, rubble, gravel, and sand substrates (Hickman 1937; Yokley 1972; Buchanan 1980; Clarke 1982, as cited in Service 1985). It is generally found in larger streams and rivers in moderate to fast-flowing water, at depths ranging from 1.5 to 26 ft (0.5 to 8.0 m) (Service 1985). Historically, it was known from the Tennessee, Cumberland, and Ohio River systems with occasional records from the Mississippi River system (Service 1985). Recent sampling efforts and a more thorough search of historical records documents historic populations in at least 48 streams (Service 2009). The species has become extirpated in at least 19 streams, and is currently known from only 29 streams within the Ohio, Cumberland, Tennessee, Missouri, Mississippi, White, and Red River systems (Service 2009). Over one-third of these populations are represented by only one or two individuals found over the past 25 years, and 16 populations (55%) are restricted to less than 16 river miles (Service 2009).

Life history

Like most naiads, male pink muckets release sperm into the water, where females downstream obtain the sperm through siphoning. Fertilization of the eggs occurs within the gills of the female. The female retains the fertilized eggs in the posterior section of the outer gills until they partially develop into a young life stage called glochidia. The glochidia are discharged into the water by the female either singly or in groups, depending on the species. Within three or four days, they must attach to a suitable fish host, encysting on gill filaments, opercles, or fins. If the glochidium is unsuccessful in attaching to the appropriate fish host, it will die. During the period of attachment to the host fish, which may last for several days or weeks depending on the species, the encapsulated glochidium develops into a juvenile mussel and drops from the host to begin growth on the stream bottom. Appropriate stream bottom habitat conditions must be present for the mussel to develop into an adult.

9

The pink mucket has been reported as gravid in August, September, October, November, and January (Gordon and Layzer 1989 and citations therein), with the glochidia overwintering and being released the following June (Service 1985). Host fish include largemouth bass (*Micropterus salmoides*), smallmouth bass (*Micropterus dolomieu*), spotted bass (*Micropterus punctulatus*), and walleye (*Sander vitreus*) (Barnhart *et al.* 1997), as well as white crappie (*Pomoxis annularis*) and sauger (*Sander canadense*) (J.B. Layzer and L.M. Madison, USGS, pers. comm., in Williams *et al.* 2008).

Like most mussel species, the pink mucket is believed to be long-lived – up to 50 years (Service 1985). A pond propagation study that took place in 2006 in the Tennessee River, Tennessee, indicates that female pink muckets reach sexual maturity at 2+ years of age (D.W. Hubbs, Tennessee Wildlife Resources Agency, pers. comm. 2009, in Service 2009).

Population dynamics

The pink mucket populations that remain are, with few exceptions, extremely small and occur in relatively short river reaches. Over one-third of the populations are represented by only one or two individuals found over the past ~25 years and 16 populations (55%) are restricted to ≤ 16 river miles (Service 2009).

Within the Ohio River in Ohio, West Virginia, Kentucky, and Illinois, the pink mucket occupies its largest stretch of river but individual records may be several hundred miles apart (Service 2009). The pink mucket in the Ohio River has been severely impacted by the invasive zebra mussel (*Dreissena polymorpha*), navigational activities, industrial pollution, and stochastic events, and appears to be in decline (Service 2009).

In the Kanawha River in West Virginia, the pink mucket occupies only ~5 RM, and appears to be stable (B. Douglas, Service, pers. comm. 2004 in Service 2009), with recruitment documented in 1999 (Douglas ca. 1999). In the Elk River, West Virginia, the population is considered to be non-recruiting (H.L. Dunn, Ecological Specialists Inc. (ESI), pers. comm. 2009 in Service 2009), and the status of this population is currently unknown (Service 2009).

In Kentucky, the pink mucket inhabits Licking River, Green River, and Barren River. Its status is unknown in Licking and Barren Rivers, and is declining in the Green River (Service 2009). In the Cumberland River of Tennessee, the pink mucket population is considered stable, although recruitment has not yet been verified (Service 2009).

The pink mucket population in the Tennessee River of Alabama, Tennessee, and Kentucky represents the best pink mucket population east of the Mississippi and is one of the top two rangewide (Service 2009). The species was historically distributed throughout the ~650 river mile (RM) main stem of the Tennessee River. It now occupies ~250 RMs of Tennessee River tailwaters downstream of Wilson and Guntersville Dams (Mirarchi *et al.*, 2004; Service 2009). There is evidence of recruitment and the population continues to improve in status in Guntersville (J.T. Garner, DCNR, pers. comm. 2009, in Service 2009). The current status of

pink mucket populations elsewhere in Tennessee (Holston River, French Broad River, Clinch River) and Alabama (Paint Rock River and Bear Creek) is unknown (Service 2009).

In the Black and Spring Rivers of Arkansas and Missouri, recruitment is occurring (Hutson and Barnhart 2004; J.L. Harris, Arkansas Highway and Transport Department (AHTD), pers. comm. 2004, 2009 in Service 2009) and the populations are considered stable (Harris *et al.* 1997. In Missouri, populations are declining in the Osage, Sac, Gasconade, Meramec, Bourbeuse, and Big Rivers, and the status of the St. Francis River population is currently unknown (Service 2009). In Arkansas, the Ouachita and Saline River populations appear to be recruiting and are considered stable (Harris *et al.* 1997; J.L. Harris, AHTD, pers. comm. 2009 in Service 2009), while the status of the White River, Current River, Eleven Point River, and Little Missouri River populations is unknown (Service 2009).

The pink mucket is sporadically distributed and rare in Bayou Bartholomew (Service 2009), which drains portions of Arkansas and Louisiana and is one of the longest rivers in the U.S. that is unchannelized and undammed its entire length (Brooks *et al.* 2008). The status of this population is currently unknown.

Status and distribution

The pink mucket was historically widespread, but rare throughout its range (Service 1985). This species currently exists in 29 streams, with a total occupied linear range estimated at approximately 1,300 RMs. Historically, the pink mucket occupied approximately 6,700 RMs in at least 48 streams in the lower half of the Mississippi River basin. Thus, there has been an 80% loss of the historical distribution of the pink mucket over the past century (Service 2009).

A variety of threats contributed to the historical decline of the pink mucket, including the development of impoundments for recreation, navigation, flood control, water supply, and electricity, siltation from other human activities, and pollution (Service 1985). In addition to these ongoing threats, extant populations are primarily impacted by reservoir releases, mining practices, industrial discharges, stochastic events, and factors associated with small disjunct populations (Service 2009). Impoundments may adversely impact riverine mussels by killing them during project construction and dredging, suffocating them with accumulated sediments, reducing food and oxygen availability by the reduction of water flow, and extirpating host fish, at least on a local basis. In addition, the impoundments have isolated surviving populations of these mussel species and their associated fish hosts, which may result in decreased genetic diversity and also reduce species' reproductive and recruitment potential.

Other forms of habitat modification include channelization, channel clearing, and desnagging, which may result in streambed scour and erosion, increased turbidity, reduction of groundwater levels, sedimentation, and changes in aquatic community structure. Human activities that historically and currently introduce large quantities of sediment into streams in the Tennessee River drainage include channel modification, agriculture, forestry, mining, and industrial and residential development.

Other types of water quality degradation resulting from point and non-point pollution sources may also affect listed species. Discharges into streams from both these sources may result in decreased dissolved oxygen concentration, increased acidity or conductivity, and other changes in water chemistry that may affect mussels and/or their host fishes.

I able 2. Biologic	al Opmions within	n the Alabama	Field Office	e boundaries that ha	ve been
issued for advers	e impact to the pir	ak mucket.	•		
ODDITONO	CIDECITIC	DINTE ADDID	2	THE A DESIGN A PROP	

OPINIONS ¹	SPECIES	NUMBERS ²	HABITAT ³	
			Critical Habitat	Habitat
1994/2	Pink mucket	Not able to determine	NA	~1,800 cubic yards
1995/1	Pink mucket	1	NA	NA
1996/1	Pink mucket	5% of pop.	NA	NA
1997/1	Pink mucket	Not able to determine		~1,800 cubic yards
2000/1	Pink mucket	17	NA	NA
2002/1	Pink mucket	1	NA	1.4 acre

Year/Number of Opinions.

² The number of individuals of the species that will be lost

³ Acres, cubic yards, miles of stream or shoreline of critical habitat and non-critical habitat that would be lost or modified.

ENVIRONMENTAL BASELINE

Status of the species within the action area

Pink mucket is rare within the action area. The most recent records of pink mucket in and near the action area were in 2008, when it was found above the action area, just below Nickajack Dam at Tennessee RM 424 and estimated to comprise 0.11% of the mussel community (Lewis 2008), and in 2009, when one live individual was found immediately adjacent to the BLN site at a depth of 25 ft (7.6 m) in a substrate composed of 50% cobble, 40% gravel, and 10% sand (Dinkins 2009). Dinkins (2009) also collected one dead shell in the main channel.

Factors affecting species' environment within the action area

Impoundment of the Tennessee River and its tributaries has likely had the most extensive adverse impacts on populations of the pink mucket within the action area. Construction of dams converted large reaches of free-flowing riverine habitat to lake-like conditions. Along with alteration of the physical habitat, this change also resulted in changes in the fish fauna. Fish species adapted to lake habitats replaced native riverine fishes that served as fish hosts for the mussels. Streambank erosion, poor land use practices, dredging, municipal and industrial discharges, and development along the river have disturbed, altered, or destroyed habitat used by the pink mucket (Service 2004).

13

However, as detailed in the Service's 2004 biological opinion for TVA's proposed Reservoir Operations Study (ROS) located in the Tennessee River Valley in Alabama, Georgia, Kentucky, Mississippi, North Carolina, Tennessee, and Virginia, TVA has implemented a variety of programs to improve conditions for aquatic resources. Specifically, TVA maintains established minimum flows and minimum dissolved oxygen levels in tailwaters and conducts substantial monitoring of environmental parameters, evaluation of ongoing environmental impacts, and systematic mitigation for large-scale impacts. An example is the Reservoir Release Improvement Program (RRI Program). The RRI Program was initiated to improve water quality and aquatic habitat in tributary tailwaters by providing minimum flows and increasing dissolved oxygen content. Under this program, TVA has restored levels of dissolved oxygen in over 300 miles downstream of 16 projects. Another TVA activity attempts to stabilize reservoir levels for a 2week period when water temperatures reach $65^{\circ}F(18^{\circ}C)$ at a depth of 5 ft (1.5 m). This fish spawning operation minimizes water level fluctuations during the peak spawning period to avoid more than a 1-foot-per-week (.3-meters-per week) change (either lowering or rising) in pool levels. Stabilizing reservoir levels aids fish spawning success. These and other programs, such as the Vital Signs Monitoring Program, which rates environmental conditions in reservoirs using a reservoir specific fish and benthic Index of Biotic Integrity (IBI), may benefit mussel resources in the Tennessee River, including federally listed species, because fish play a vital role in the life cycles of mussels (Service 2004).

EFFECTS OF THE ACTION

Factors to be considered

The primary effects of the proposed construction and operation of a single nuclear unit at BLN are direct and indirect impacts associated with the dredging of the intake channel, intake channel overbank, and barge unloading terminal, and the direct and indirect impacts of the thermal and chemical releases from the coolant water effluent.

Analysis for the effects of the action

Dredging will directly harm or kill mussels inhabiting the sediment within the intake channel (for both B&W and AP1000 reactors), the intake channel overbank (B&W), and the barge unloading terminal (AP1000) areas. The resulting mobilization of sediments, such as silt and sand, may harm or kill mussels downstream, where such sediments may smother mussels or otherwise compromise respiration, feeding, and reproduction. Dredging in the barge terminal area is anticipated to be necessary only once, while dredging in the intake channel and overbank areas will need to be done every 5 to 10 years.

The operation of barges for the transportation of heavy equipment, large reactor components, construction modules too large to ship by train, and removal of construction debris and other waste from the site will result in brief periods of extreme turbulence, increased suspended sediments, scouring of substrate (and possibly mussels) from the riverbed, and accumulation of fine sediments in surrounding areas as a result of tow propeller wash. These impacts could

result in direct harm or killing of mussels (i.e., scouring of substrate) and interference with respiration, feeding, and reproduction.

Species' response to the proposed action

Given the pink mucket's rarity in the action area, its disparate occurrences throughout the Tennessee River, and its low resilience to changes in its habitat, it is unlikely that this species would recolonize areas that have been dredged or areas that have otherwise been rendered unsuitable as a result of this proposed project in the foresceable future.

CUMULATIVE EFFECTS

Cumulative effects include the effects of future State, tribal, local, or private actions that are reasonably certain to occur in the action area considered in this biological opinion. Future Federal actions that are unrelated to the proposed action are not considered in this section because they require separate consultation pursuant to section 7 of the Act.

Large recreational boats and barge traffic that move upriver and downriver through the action area likely have some effect on aquatic species and habitats. Propeller wash creates waves that erode the riverbanks, resulting in sediment deposit on the river bottom. Runoff from adjacent agricultural fields may contain fertilizers and/or pesticides that can affect aquatic organisms. Residential, commercial, and industrial development around Guntersville Reservoir is likely to continue, resulting in destruction or alteration of aquatic and terrestrial habitats. These effects have occurred over many years and are likely to continue.

CONCLUSION

After reviewing the current status of the pink mucket, the environmental baseline for the action area, the effects of the proposed construction of a single nuclear unit at BLN, and the cumulative effects, it is the Service's biological opinion that the proposed completion and operation of one of the partially constructed Babcock & Wilcox (B&W) pressurized light water reactor units on (BLN unit 1 or 2) or construction and operation of a new Westinghouse AP1000 advanced pressurized light water reactor at the BLN site, as proposed, is not likely to jeopardize the continued existence of the pink mucket. No critical habitat has been designated for the species; therefore, none will be affected.

INCIDENTAL TAKE STATEMENT

Section 9 of the Act and Federal regulations pursuant to section 4(d) of the Act prohibit the take of endangered and threatened species, respectively, without special exemption. Take is defined as to harass, harm, pursue, hunt, shoot, wound, kill, trap, capture, or collect; or to attempt to engage in any such conduct. Harm is further defined by the Service to include significant habitat modification or degradation that results in death or injury to listed species by significantly impairing essential behavioral patterns, including breeding, feeding, or sheltering. Harass is defined by the Service as intentional or negligent actions that create the likelihood of injury to

listed species to such an extent as to significantly disrupt normal behavior patterns which include, but are not limited to, breeding, feeding, or sheltering. Incidental take is defined as take that is incidental to, and not the purpose of, the carrying out of an otherwise lawful activity. Under the terms of section 7(b)(4) and section 7(o)(2), taking that is incidental to and not intended as part of the agency action is not considered to be prohibited taking under the Act provided that such taking is in compliance with the terms and conditions of this Incidental Take Statement.

The measures described below are non-discretionary for listed species and must be undertaken by TVA for the exemption in section 7(0)(2) to apply. TVA has a continuing duty to regulate the activity covered by this incidental take statement. If TVA fails to assume and implement the terms and conditions of the incidental take statement, the protective coverage of section 7(0)(2)may lapse. In order to monitor the impact of incidental take, TVA must report the progress of the action and its impact on the species to the Service as specified in the incidental take statement. [50 CFR §402.14(i)(3)]

AMOUNT OR EXTENT OF TAKE ANTICIPATED

If the B&W alternative is chosen by TVA, the Service expects that 68 pink muckets and an unknown number of larvae could be taken. If the AP1000 alternative is chosen, 33 pink mucket and an unknown number of larvae could be taken (Table 3). The incidental take is expected to be in the form of harm and kill.

Dredging of the intake channel proper, a 240,000 ft² (22,297 m²) area where the total mussel density is estimated by Dinkins (2009) as 0.12 mussels/m², 0.1% of which is estimated to be pink mucket (Lewis 2008), could result in direct killing or harm of 3 pink muckets. Dredging the overbank portion of the intake channel, a 19,000 ft² (1,765 m²) area where the total mussel density is estimated as 0.81 mussels/m² (Dinkins 2009), 0.1% of which is estimated to be pink mucket (Lewis 2008), could result in direct killing or harm of 2 pink muckets. Dredging will result in the temporary suspension and deposition of sediments, flow pattern alteration, and tow propeller wash, as well. Within the intake channel proper, these indirect effects are expected to occur over an estimated 156,000 ft² (14,493 m²), and affect an estimated 2 pink muckets. Within the overbank portion, indirect effects are expected to occur over an estimated 456,200 ft² (42,382 m²) and affect an estimated 34 pink muckets. Dredging will occur every 5 to 10 years, and it is unlikely that pink muckets will re-colonize the intake channel and overbank areas between these maintenance dredging activities.

For the AP1000 alternative, the barge terminal area will be dredged one-time only. Approximately 15,000 ft^2 (1,394 m²) will be dredged, which may result in the direct killing or harm of one pink mucket. Indirect effects from the dredging will be similar to those described above for the intake channel. In addition, the pink mucket could be impacted by tow propeller wash caused by the barges that will need to be used for both the B&W and AP1000 construction alternatives. The indirect effects associated with tow propeller wash include extreme turbulence, increased suspended sediments, scouring of substrate, and accumulation of fine sediment in

surrounding areas. An estimated $86,250 \text{ ft}^2 (8,013 \text{ m}^2)$ will be affected, which in turn will affect 7 pink muckets.

The thermal and chemical mixing zone (i.e., the limits of where thermal and chemical effects from the diffuser would be felt) encompasses a 250-ft (76 m) radius from the diffuser in all directions for both the B&W and AP1000 alternatives. According to the CORMIX modeling provided in Appendix A of the Biological Assessment, live mussels on the river bottom will not be directly impacted by the coolant water effluent within the mixing zone. However, indirectly these mussels may be unable to reproduce successfully due to the stressing of host fish that pass through the mixing zone, the inability of mussel larvae to attach, or remain attached to host fish in the mixing zone or affected by the mixing zone, death or disabling of larvae attached to host fish that past through the mixing zone, etc. An unknown number of larvae and an estimated 20 adult pink muckets may be harmed within the 269,000 ft² (20,242 m²) area associated with the mixing zone.

Impact Area/Action	Type of Take	Area (ft ² /m ²)	Total mussel density ^a (no/m ²)/Total mussels	No. of adult/juvenile pink mucket taken ^b
Intake Channel/ Dredging – Direct (B&W and AP1000)	Harm and Kill	240,000/22,297	2,676	3
Intake Channel/Dredging – Indirect (B&W and AP1000)	Harm	156,000/14,493	1,739	2
Overbank/Dredging – Direct (B&W)	Harm and Kill	19,000/1,765	1,430	2
Overbank/Dredging- Indirect (B&W)	Harm	456,200/42,382	34,329	34
Barge Terminal/Dredging Direct (AP1000)	Harm and Kill	15,000/1,394	1,129	. 1
Barge Terminal/Dredging and Barge Use – Indirect (B&W and AP1000)	Harm	86,250/8,013	6,491	7
Effluent Mixing Zone (B&W and AP1000) ^b	Harm	269,000/24,900	20,242	20

Table 3. Types and amount of take for the proposed action.

^aDensities based on Dinkins (2009) with a 3X multiplier correction factor to account for sampling type error (surface searches).

^bThe number of larvae that may be affected by the Effluent Mixing Zone is unknown.

EFFECT OF THE TAKE

In the accompanying biological opinion, the Service determined that this level of expected take is not likely to result in jeopardy to the pink mucket or destruction or adverse modification of critical habitat.

REASONABLE AND PRUDENT MEASURES.

The Service believes the following reasonable and prudent measure(s) are necessary and appropriate to minimize impacts of incidental take of the pink mucket.

- 1. Reduce the area and amount of sediment deposition downstream of the dredging activities.
- 2. Work with the Service, State fish and wildlife agencies, and non-governmental groups to promote recovery of the pink mucket and other listed mussel species from the Tennessee/Cumberland River basins.

TERMS AND CONDITIONS

In order to be exempt from the prohibitions of section 9 of the Act, TVA must comply with the following terms and conditions, which carry out the reasonable and prudent measures described above and outline required reporting/monitoring requirements. These terms and conditions are non-discretionary.

- 1. Implement Best Management Practices (BMPs) during the proposed dredging activities.
- 2. To the maximum extent possible, TVA should restrict all dredging activities to periods during low river discharges when the potential for downstream movement of dredged and suspended material is reduced.
- 3. As per the commitment made in TVA's March 18, 2010, letter to the Service's Alabama Field Office, and follow-up meeting on April 1, 2010, TVA will provide \$30,000 to the Alabama Department of Conservation and Natural Resources'Alabama Aquatic Biodiversity Center (AABC) for the reintroduction and/or augmentation of pink mucket and other high priority mollusks within their historic ranges. The reintroduction/augmentation project will be funded by TVA prior to the initiation of dredging activities associated with the construction and operation of a single nuclear unit at the BLN site.

Upon locating a dead, injured, or sick individual of an endangered or threatened species, initial notification must be made to the Fish and Wildlife Service Law Enforcement Office (Special Agent Donnie Grace, 1208-B Main Street, Daphne, AL 36526 (251/441-5787). Additional notification must be made to the Fish and Wildlife Service Ecological Services

Field Office (251/441-5181). Care should be taken in handling sick or injured individuals and in the preservation of specimens in the best possible state for later analysis of cause of death or injury.

The reasonable and prudent measures, with their implementing terms and conditions, are designed to minimize the impact of incidental take that might otherwise result from the proposed action. The Service believes that no more than 68 adult/juvenile and an unknown number of larval-stage pink mucket will be incidentally taken if the B&W alternative is chosen, and that no more than 33 adult/juvenile and an unknown number of larvae will be taken if the AP1000 alternative is chosen. If, during the course of the action, this level of incidental take is exceeded, such incidental take represents new information requiring reinitiation of consultation and review of the reasonable and prudent measures provided. TVA must immediately provide an explanation of the reasonable and prudent measures.

CONSERVATION RECOMMENDATIONS

Section 7(a)(1) of the Act directs Federal agencies to use their authorities to further the purposes of the Act by carrying out conservation programs for the benefit of endangered and threatened species. Conservation recommendations are discretionary agency activities to minimize or avoid adverse effects of a proposed action on listed species or critical habitat, to help carry out recovery plans, or to develop information.

- Continue to work with the Service and other partners in modifying dam discharges to improve habitat conditions in tailwaters for the pink mucket and other endangered and threatened mollusks.
- Determine the status of pink mucket populations in areas impacted by TVA actions on the Tennessee River through periodic monitoring that includes a quantitative component that provides basic population size estimates and a sampling design specifically for searching for juveniles, thus facilitating the assessment of recruitment into a population.
- Conduct studies to determine if hydraulic or other factors associated with TVA's
 operations can affect pink mucket patchiness and rareness in large river habitats and
 conduct threat assessments from particular stressors.

In order for the Service to be kept informed of actions minimizing or avoiding adverse effects or benefiting listed species or their habitats, the Service requests notification of the implementation of conservation recommendations.

REINITIATION NOTICE

This concludes formal consultation on the actions outlined in the November 4, 2009, request. As written in 50 CFR §402.16, reinitiation of formal consultation is required where discretionary TVA involvement or control over the action has been retained (or is authorized by law) and if: (1) the amount or extent of incidental take is exceeded; (2) new information

reveals effects of the TVA action that may affect listed species or critical habitat in a manner or to an extent not considered in this opinion; (3) the TVA action is later modified in a manner that causes an effect to the listed species or critical habitat not considered in this opinion; or (4) a new species is listed or critical habitat designated that may be affected by the action. In instances where the amount or extent of incidental take is exceeded, any operations causing such take must cease until reinitiation.

For this biological opinion the incidental take would be exceeded when the take exceeds 68 pink muckets for the B&W alternative or 33 pink muckets for the AP1000 alternative, which is what has been exempted from the prohibitions of section 9 by this opinion. The Service appreciates the cooperation of TVA during this consultation. We would like to continue working with you and your staff regarding the Bellefonte Nuclear Plant project. For further coordination please contact Karen Marlowe at (205) 726-2667.

Sincerely,

William J. Pearson Field Supervisor Alabama Ecological Services Field Office

cc:

Bob Butler, USFWS, Ecological Services, Asheville, NC USFWS, Ecological Services, Cookeville, TN ADCNR, Montgomery, AL GSA, Tuscaloosa, AL

Ms. Peggy W. Shute

LITERATURE CITED

Alabama Department of Environmental Management. 1998. Alabama Department of Environmental Management permit rationale, Tennessee Valley Authority Bellefonte Nuclear Plant. Prepared by David Butts, September 9, 1998.

- Barnhart, M.C., F.A. Riusech, and A.D. Roberts. 1997. Fish hosts of the federally endangered pink mucket, *Lampsilis abrupta*. Triannual Unionid Report 13:35.
- Brooks, J.A., R.L. Minton, S.G. George, D.M. Hayes, R. Ulmer, and F. Pezold. 2008. Diversity and distribution of native freshwater mussels in Bayou Bartholomew, Arkansas. Southeastern Fishes Council No. 50:8-17.
- Buchanan, A.C. 1980. Mussels (Naiades) of the Meramec River basin. Missouri Department of Conservation, Aquatic Series. No. 17, 68 pp.
- Clarke, A.H. 1982. Survey of the freshwater mussels of the upper Kanawha River (RM 91-95), Fayette County, West Virginia, with special reference to *Epioblasma toulosa* (Rafinesque) and *Lampsilis abrupta* (Say) (=*Lampsilis orbiculata* (Hildreth), of authors). Final Report. U.S. Fish and Wildlife Service, Newton Corner, MA. Order No. 50181-0546-2. 45 pp.
- Cumberlandian Region Mollusk Restoration Committee. 2009. Draft plan for the controlled propagation, augmentation and reintroduction of freshwater mollusks of the Cumberlandian Region. V + 143 pp.
- Dinkins, G.R. 2009. Survey for Anthony's rivershail (*Athearnia anthonyi*) in the Tennessee River in vicinity of Bellefonte Nuclear Power Plant, Jackson County, Alabama. Report prepared for Tennessee Valley Authority, November 2009. 30 pp.
- Douglas, B. ca. 1999. A [1999] survey of the mussel fauna of the upper Kanawha River, West Virginia (RM 95.5-91.0) and a review of mussel species currently known to be present in the Kanawha River (RM 95.5-0.0) Unpublished report, U.S. Fish and Wildlife Service, Elkins, West Virginia. 13 pp.
- Gordon, M.E., and J.B. Layzer. 1989. Mussels (Bivalvia: Unionoidea) of the Cumberland River: review of life histories and ecological relationships. U.S. Department of the Interior, Fish and Wildlife Service Biological Report 89(15). 87 pp. + appendices.
- Harris, J.L., P.J. Rust, A.C. Christian, W.R. Posey, II, C.L. Davidson, and G.L. Harp. 1997. Revised status of rare and endangered Unionacea (Mollusca: Margaritiferidae, Unionidae) in Arkansas. Proceedings of the Arkansas Academy of Science 51:66-89.
- Hickman, M.E. 1937. A contribution to mollusca of east Tennessee. Unpublished master's thesis, Department of Zoology, University of Tennessee, Knoxville. 165 pp., 104 pl.

 Hutson, C., and M.C. Barnhart. 2004. Survey of endangered and special concern mussel species in the Sac, Pomme de Terre, St. Francis, and Black River systems of Missouri, 2001-2003. Unpublished report, Missouri Department of Conservation, Jefferson City. 379 pp.

- Lewis Environmental Consulting, LLC. 2008. Mussel survey at Tennessee River Mile 423.6-423.9 along the left descending bank in Marion County, Tennessee. Report prepared for Thompson Engineering, Inc. 27 pp.
- Mirarchi, R.E., J.T. Garner, M.F. Mettee, and P.E. O'Neil. 2004. Alabama wildlife, volume 2, imperiled aquatic mollusks and fishes. The University of Alabama Press, Tuscaloosa, Alabama. 255 pp.
- Tennessee Valley Authority. 1982. Predicted effects for mixed temperatures exceeding 30°C (86°F) in Guntersville Reservoir, Alabama, in the vicinity of the diffuser discharge, Bellefonte Nuclear Plant. TVA Report No. TVA/ONR/WRF 82/5, February 1982.
- Tennessee Valley Authority. 2009a. Biological assessment: proposed single unit nuclear plant development at Bellefonte nuclear site and associated transmission line upgrades, Alabama, Tennessee, and Georgia. 151 pp.
- Tennessee Valley Authority. 2009b. Draft supplemental environmental impact statement; single nuclear unit at the Bellefonte plant site, Jackson County, Alabama. 407 pp.
- U.S. Fish and Wildlife Service. 1976. Endangered and threatened wildlife and plants; endangered status for 159 taxa of animals. Federal Register 41(115): 24062-24067.
- U.S. Fish and Wildlife Service. 1985. Recovery plan for the pink mucket pearly mussel Lampsilis orbiculata (Hildreth, 1828). U.S. Fish and Wildlife Service. Atlanta, GA. 47 pp.
- U.S. Fish and Wildlife Service. 2004. Biological opinion on the proposed Reservoir Operations Study (ROS) located in the Tennessee River Valley in Alabama, Georgia, Kentucky, Mississippi, North Carolina, Tennessee, and Virginia. U.S. Fish and Wildlife Service. Cookeville, TN. 39 pp.
- U.S. Fish and Wildlife Service. 2009. Pink mucket Lampsilis abrupta; Draft 5-year review: summary and evaluation. U.S. Fish and Wildlife Service. Asheville, NC. 68 pp.
- Williams, J.D., A.E. Bogan, and J.T. Garner. 2008. Freshwater mussels of Alabama and the Mobile Basin in Georgia, Mississippi and Tennessee. The University of Alabama Press, Tuscaloosa. 908 pp.

Ms. Peggy W. Shute

Yokley, P., Jr. 1972. Freshwater mussel ecology, Kentucky Lake, Tennessee. Tennessee Game and Fish Commission Project 4-46R. 133 pp.

State Historic Preservation Officer Consultation (Alabama, Georgia, and Tennessee)

A-253

Page intentionally blank

TVA

Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, Tennessee 37902-1499

August 25, 2009

Ms. Stacye Hathorn Alabama Historical Commission 468 South Perry Street Montgomery, Alabama 36130-0900

Dear Ms. Hathorn:

TVA, BELLEFONTE NUCLEAR PLANT COMPLETION OF ONE UNIT, JACKSON COUNTY, ALABAMA

The Tennessee Valley Authority (TVA) previously consulted with your office regarding the construction of two new reactor units at the Bellefonte Nuclear Plant site in Jackson County, Alabama (BLN) (NuStart Combined Operating License Application for Units 3 and 4; AHC 2006-1211). TVA is now preparing a Supplemental Environmental Impact Statement (SEIS) that will update existing information about the potential environmental impacts associated with its proposal to operate a single nuclear unit on the same site. The SEIS will evaluate three alternatives – compléting and operating one of the partially completed units, constructing and operating a new Westinghouse AP1000 nuclear unit, and taking no action to operate a nuclear unit at the site.

TVA originally applied for a license for the construction and operation of two Babcock & Wilcox pressurized water reactors, BLN Units 1 and 2 in 1974. In 1988, TVA formally notified the Nuclear Regulatory Commission of construction deferral and at that time, Unit 1 was approximately 90 percent complete and Unit 2 was approximately 58 percent complete. The plant was maintained in deferred status until 2005. Since then, several buildings have been removed.

TVA has determined the area of potential effects (APE) for the construction of a single unit to be the approximate 606 acres surrounding the proposed construction and its associated infrastructure as well as a 1-mile viewshed for historic structures. Due to the similarity of areas needed for construction and operational purposes, this same APE was earlier considered and coordinated with the Alabama State Historic Preservation Office (AL SHPO) regarding Units 3 & 4.

Two surveys were conducted within the APE to identify archaeological sites or historic structures that may be impacted by the construction of Units 3 & 4 (Deter-Wolfe 2007 and Jenkins 2008). Results of the archaeological survey concluded that sites 1JA300 and 1JA301 were completely destroyed by the intake construction. Site 1JA113 was determined, in consultation with AL SHPO and federally recognized Indian tribes to be ineligible for listing in the National Register of Historic Places (NRHP) along with one newly recorded historic archaeological site (1JA1103). Site 1JA111 was recommended

Ms. Stacye Hathorn Page 2 August 25, 2009

as potentially eligible for listing in NRHP. TVA has committed to fence off and mark 1JA111 on the BLN site drawings to avoid impacts by any future planned construction. Any future modification to current project plans which have a potential to affect this site, would require TVA to conduct further testing of 1JA111 to determine its NRHP eligibility status.

Two historic sites (Bellefonte Cemetery and the African American Bellefonte Cemetery) were identified in the visual APE that was determined to meet the criteria of eligibility for the NRHP. It was determined by TVA, in consultation with your office, that these eligible resources were protected by existing dense vegetative buffers and will not be adversely affected by any new construction at the Bellefonte Plant site.

TVA is providing a copy of this report to the Eastern Band of Cherokee Indians, United Keetoowah Band, Cherokee Nation, The Chickasaw Nation, Muscogee (Creek) Nation of Oklahoma, Thiopthlocco Tribal Town, Kialegee Tribal Town, Alabama-Quassarte Tribal Town, Alabama-Coushatta Tribe of Texas, Eastern Shawnee Tribe of Oklahoma, Shawnee Tribe, Absentee Shawnee Tribe of Oklahoma, Seminole Tribe of Florida, Jena Band of Choctaw Indians, the Poarch Band of Creek Indians, and the Choctaw Nation of Oklahoma and requesting their comments on our findings.

Based on these findings and the commitment to protect site 1JA111, TVA has determined that the proposed undertaking will have no effect on historic properties. Pursuant to Section 106 of the National Historic Preservation Act and its implementing regulations at 36 CFR § 800, TVA is seeking your concurrence with this determination.

If you have any questions or comments, please contact me or Erin Pritchard at <u>eepritchard@tva.gov</u> or 865-632-2463.

Sincerely,

A. Eric Howard Manager (Interim) Cultural Resources

EEP:IKS cc: Ruth Horton, WT 11D-K Bruce Yeager, WT 11D-K EDMS, WT 11D-K



STATE OF ALABAMA ALABAMA HISTORICAL COMMISSION 468 South Perry Street Montgomery, Alabama 36130-0900

FRANK W. WHITE EXECUTIVE DIRECTOR

September 9, 2009

TEL: 334-242-3184 FAX: 334-240-3477

Eric Howard TVA 400 West Summit Hill Drive Knoxville, Tennessee 37902-1499

Re: AHC 06-1211 Unit One Bellefonte Nuclear Plant Jackson County, Alabama

Dear Mr. Howard:

Upon review of the information forwarded by your office, we have determined that we agree with your findings. We agree with the proposals to avoid archaeological site IJaIII as it is potentially eligible for the National Register of Historic Places (NRHP). We further agree that should future modifications to the development plan include an impact to this site, Phase II testing proposals will have to be developed and carried out in consultation with our office. Finally, we agree that the two NRHP eligible cemeteries will not be adversely affected by the proposed activities due to the existing dense vegetation buffers.

We appreciate your efforts on this project. Should you have any questions, please contact Greg Rhinehart at (334) 230-2662. Please have the AHC tracking number referenced above available and include it with any correspondence.

Truly yours,

Elizabeth Ann Brown Deputy State Historic Preservation Officer

EAB/GCR/gcr

THE STATE HISTORIC PRESERVATION OFFICE www.preservcala.org



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, Tennessee 37802-1489

September 9, 2009

Ms. Stacye Hathorn Alabama Historical Commission 468 South Perry Street Montgomery, Alabama 36130-0900

Dear Ms. Hathorn:

TVA, BELLEFONTE NUCLEAR TRANSMISSION LINE UPGRADES: LIMESTONE, JACKSON, AND MORGAN COUNTIES, ALABAMA; BEDFORD, COFFEE, SEQUATCHIE, HAMILTON, AND MARION COUNTIES, TENNESSEE, AND WALKER AND DADE COUNTIES, GEORGIA

By this letter, the Tennessee Valley Authority (TVA) is initiating consultation for the proposed upgrading of TVA transmission lines (TL) and TL right-of-ways (ROWs) associated with the Bellefonte Nuclear Plan Completion Project (PROJECT). TVA is in the planning stages of the PROJECT and the proposed upgrading of the TLs would begin around 2016.

Currently, TVA is in the process of preparing a Supplemental Environmental Impact Statement that would update existing information about the potential environmental impacts associated with its proposal to operate a single nuclear generation unit at the Bellefonte Nuclear Plant (BLN) site. TVA may choose to 1) complete and operate either one of two partially constructed units (Babcock and Wilcox pressurized water reactor) or 2) construct and operate one new technology unit (Westinghouse AP1000 advanced boiling water reactor). The No Action Alternative would also be considered.

As currently proposed under both Action Alternatives, the existing 161-kilovolt (kV) and 500-kV switchyards constructed on the BLN site would be refurbished and reenergized; four 500-kV TL that terminate in the BLN switchyard would be reestablished; the ROW would be brought back to current TVA standards; the capacity of nine existing TLs would be increased; and two 161-kV transmission lines that supply a 161-kV switchyard to provide site power would be reestablished (Figure 1); all of these TLs and ROWs are existing.

TVA has determined the area of potential effects (APE) to be the ROW and TLs that are slated for upgrades and the footprint of all infrastructures (e.g., access roads, staging areas). The architectural APE would be a .5-mile wide area linearly centered along the proposed TL ROW.

A review of the Alabama, Tennessee, and Georgia site files identified twenty-five sites have been previously recorded within the APE. One of these sites (1MG785) is no longer extant. Seven sites (1MG116, 1MG115, 1MG667, 1MG758, 1MG757, 1JA304, 1JA694) were previously determined not eligible for the National Record of Historical Places (NRHP). Two sites, 1MG735 and 9WA164, have been previously determined potentially eligible for the NRHP, The remaining 15 sites (1JA637, 1JA650, 40MI246, 40MI247, 40HA0089, 40MI248, 1JA453, 1JA452, 1JA304, 1JA377, 1JA518, 1JA532, 1JA524, 1JA617, and 1JA558) have not been assessed for NRHP eligibility. In Alabama, one previously recorded historic district (the City of

Final Supplemental Environmental Impact Statement

A-258

Ms. Stacye Hathorn Page 2 September 9, 2009

Bridgeport) falls within the architectural APE. In Georgia, one eligible Historic District (Happy Valley Farms in Walker County, Georgia) and two eligible historic structures (WA-WA-114 and WA-WA-642) falls within the .5 mile architectural APE. All of these properties and other yet-tobe-identified properties would be assessed in consultation with your office and other interested parties.

At this time TVA is simply providing notification of the proposed undertaking. By 2014, TVA cultural resources would consult with your offices regarding the Scope of Work for the evaluation and identification of any cultural resources that would be affected by the proposed undertaking.

Should you have any questions or comments, please contact Richard Yarnell at 865/632-3463 or wryarnell@tva.gov.

Sincerely,

A. Eric Howard Manager (Interim) Cultural Resources

MH:IKS Enclosure cc: EDMS, WT 11D-K



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, Tennessee 37902-1499

September 9, 2009

Mr. E. Patrick McIntyre, Jr. Executive Director Tennessee Historical Commission Clover Bottom Mansion 2941 Lebanon Road Nashville, Tennessee 37243-0442

Dear Mr. McIntyre:

TVA, BELLEFONTE NUCLEAR TRANSMISSION LINE UPGRADES: LIMESTONE, JACKSON, AND MORGAN COUNTIES, ALABAMA; BEDFORD, COFFEE, SEQUATCHIE, HAMILTON, AND MARION COUNTIES, TENNESSEE, AND WALKER AND DADE COUNTIES, GEORGIA

By this letter, the Tennessee Valley Authority (TVA) is initiating consultation for the proposed upgrading of TVA transmission lines (TL) and TL right-of- ways (ROWs) associated with the Bellefonte Nuclear Plan Completion Project (PROJECT). TVA is in the planning stages of the PROJECT and the proposed upgrading of the TLs would begin around 2016.

Currently, TVA is in the process of preparing a Supplemental Environmental Impact Statement that would update existing information about the potential environmental impacts associated with its proposal to operate a single nuclear generation unit at the Bellefonte Nuclear Plant (BLN) site. TVA may choose to 1) complete and operate either one of two partially constructed units (Babcock and Wicox pressurized water reactor) or 2) construct and operate one new technology unit (Westinghouse AP1000 advanced boiling water reactor). The No Action Alternative would also be considered.

As currently proposed under both Action Alternatives, the existing 161-kilovolt (kV) and 500-kV switchyards constructed on the BLN site would be refurbished and reenergized; four 500-kV TL that terminate in the BLN switchyard would be reestablished; the ROW would be brought back to current TVA standards; the capacity of nine existing TLs would be increased; and two 161-kV transmission lines that supply a 161-kV switchyard to provide site power would be reestablished (Figure 1); all of these TLs and ROWs are existing.

TVA has determined the area of potential effects (APE) to be the ROW and TL's that are slated for upgrades and the footprint of all infrastructures (e.g., access roads, staging areas). The architectural APE would be a .5 mile wide area linearly centered along the proposed TL ROW.

A review of the Alabama, Tennessee, and Georgia site files identified twenty-five sites have been previously recorded within the APE. One of these sites (1MG785) is no longer extant. Seven sites (1MG116, 1MG115, 1MG667, 1MG758, 1MG757, 1JA304, 1JA694) were previously determined not eligible for the National Record of Historical Places (NRHP): Two sites 1MG735 and 9WA164 have been previously determined potentially eligible for the NRHP. The remaining 15 sites (1JA637, 1JA650, 40MI246, 40MI247, 40HA0089, 40MI248, 1JA453, Mr. E. Patrick McIntyre, Jr. Page 2 September 9, 2009

1JA452, 1JA304, 1JA377, 1JA518, 1JA532, 1JA524, 1JA617, 1JA558) have not been assessed for NRHP eligibility. In Alabama, one previously recorded historic district (the City of Bridgeport) falls within the architectural APE. In Georgia, one eligible Historic District (Happy Valley Farms in Walker County, Georgia) and two eligible historic structures (WA-WA-114 and WA-WA-642) falls within the .5-mile architectural APE. All of these properties and other yet-to-be-identified properties would be assessed in consultation with your office and other interested parties.

At this time, TVA is simply providing notification of the proposed undertaking. By 2014, TVA cultural resources would consult with your offices regarding the Scope of Work for the evaluation and identification of any cultural resources that would be affected by the proposed undertaking.

Should you have any questions or comments, please contact Richard Yarnell at 865/632-3463 or wryarnell@tva.gov.

Sincerely,

A. Eric Howard Manager (Interim) Cultural Resources

MH:IKS Enclosure cc: EDMS, WT 11D-K



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, Tennessee 37902-1499

September 10, 2009

Mr. Ray Luce State Historic Preservation Officer 34 Peachtree Street, NW, Suite 1600 Atlanta, Georgia 30303-2316

Déar Mr. Luce:

TVA, BELLEFONTE NUCLEAR TRANSMISSION LINE UPGRADES: LIMESTONE, JACKSON, AND MORGAN COUNTIES, ALABAMA: BEDFORD, COFFEE, SEQUATCHIE, HAMILTON, AND MARION COUNTIES, TENNESSEE, AND WALKER AND DADE COUNTIES, GEORGIA

By this letter, the Tennessee Valley Authority (TVA) is initiating consultation for the proposed upgrading of TVA transmission lines (TL) and TL right-of-ways (ROW) associated with the Bellefonte Nuclear Plan Completion Project (PROJECT). TVA is in the planning stages of the PROJECT and the proposed upgrading of the TLs would begin around 2016.

Currently, TVA is in the process of preparing a Supplemental Environmental Impact Statement that would update existing information about the potential environmental impacts associated with its proposal to operate a single nuclear generation unit at the Bellefonte Nuclear Plant (BLN) site. TVA may choose to 1) complete and operate either one of two partially constructed units (Babcock and Wilcox pressurized water reactor) or 2) construct and operate one new technology unit (Westinghouse AP1000 advanced boiling water reactor). The No Action Alternative would also be considered.

As currently proposed under both Action Alternatives, the existing 161-kilovolt (kV) and 500-kV switchyards constructed on the BLN site would be refurbished and reenergized; four 500-kV TL that terminate in the BLN switchyard would be reestablished; the ROW would be brought back to current TVA standards; the capacity of nine existing TLs would be increased; and two 161-kV transmission lines that supply a 161-kV switchyard to provide site power would be reestablished (Figure 1); all of these TLs and ROWs are existing.

TVA has determined the area of potential effects (APE) to be the ROW and TLs that are slated for upgrades and the footprint of all infrastructures (e.g., access roads, staging areas). The architectural APE would be a .5 mile wide area linearly centered along the proposed TL ROW.

A review of the Alabama, Tennessee, and Georgia site files identified twenty-five sites have been previously recorded within the APE. One of these sites (1MG785) is no longer extant. Seven sites (1MG116, 1MG115, 1MG667, 1MG758, 1MG757, 1JA304, 1JA694) were previously determined not eligible for the National Register of Historical Places (NRHP). Two sites, 1MG735 and 9WA164, have been previously determined potentially eligible for the NRHP. The remaining 15 sites (1JA637, 1JA650, 40MI246, 40MI247, 40HA0089, 40MI248, 1JA453, 1JA452; 1JA304, 1JA377, 1JA518, 1JA532, 1JA524, 1JA617, 1JA558) have not been assessed for NRHP eligibility. In Alabama, one previously recorded historic district (the City of Bridgeport) Mr. Ray Luce Page 2 September 10, 2009

falls within the architectural APE. In Georgia, one eligible Historic District (Happy Valley Farms in Walker County, Georgia) and two eligible historic structures (WA-WA-114 and WA-WA-642) falls within the 5 mile architectural APE. All of these properties and other yet-to-be-identified properties would be assessed in consultation with your office and other interested parties.

At this time, TVA is simply providing notification of the proposed undertaking. By 2014, TVA Cultural Resources would consult with your offices regarding the Scope of Work for the evaluation and identification of any cultural resources that would be affected by the proposed undertaking.

Should you have any questions or comments, please contact Richard Yarnell at 865/632-3463 or wryarnell@tva.gov.

Sincerely,

A. Eric Howard Manager (Interim) Cultural Resources

MH:IKS Enclosure cc: EDMS, WT 11D-K



ALABAMA-COUSHATTA TRIBE OF TEXAS 571 Stale Park Rd 56 • Livingston, Texas 77351 • (936) 563-1100

September 18, 2009

Tennessee Valley Authority Attn: Pat Bernard Ezzell 400 West Summit Hill Drive Knoxville, TN 37902-1499

Dear Mrs. Ezzell:

On behalf of Chief Oscola Clayton Sylestine and the Alabama-Coushatta Tribe, our appreciation is expressed on your efforts to consult us regarding the Bellefonte Nuclear Plant proposal in Jackson County.

Our Tribe maintains ancestral associations within the state of Mississippi despite the absence of written records to completely identify Tribal activities, villages, trails, or grave sites. However, it is our objective to ensure significances of Native American ancestry including the Alabama-Coushatta Tribe are administered with the utmost regard.

Upon review of your August 26, 2009 documents submitted to our office, no known impacts to religious, cultural, or historical assets of the Alabama-Coushatta Tribe of Texas should occur in conjunction with this activity. Based upon the provisions to be incorporated during implementation, we have no objections to the proceeding of this proposal.

In the event of inadvertent discovery of human remains and/or archaeological artifacts, activity in proximity to the location must cease and appropriate authorities, including this office, notified without delay. Should you require additional assistance, please do not hesitate to contact us.

Respectfully submitted,

Bryant J. Celestine Historic Preservation Officer

Telephone: 936 - 563 - 1181

celestine.bryant@actribe.org

Fax: 936 - 563 - 1183



STATE OF ALABAMA ALABAMA HISTORICAL COMMISSION 468 South Perry Street Montgomery, Alabama 361300900

FRANK W. WHITE EXECUTIVE DIRECTOR

September 25, 2009

TEL: 334-242-3184 FAX: 334-240-3477

A. Eric Howard TVA 400 West Summit Hill Drive Knoxville, Tennessee 37902-1499

Re: AHC 09-1092

Transmission Line Upgrades Bellefonte Nuclear Facility Multiple Counties, Alabama

Dear Mr. Howard:

Thank you for forwarding the information regarding the development of a Supplemental Environmental Impact Statement for the above referenced project. We look forward to working with you as this process proceeds.

Should you have any questions, please contact Greg Rhinehart at (334) 230-2662. Please have the AHC tracking number referenced above available and include it with any correspondence.

Sincerely,

Frank White State Historic Preservation Officer

FW/LAW/AMH/gcr

THE STATE HISTORIC PRESERVATION OFFICE www.preserveala.org

Final Supplemental Environmental Impact Statement

A-265



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, Tennessee 37902-1499

October 28, 2009

Ms. Stacye Hathorn Alabama Historical Commission 468 South Perry Street Montgomery, Alabama 36130-0900

Dear Ms. Hathorn:

AHC 09-1092 TRANSMISSION LINE (TL) UPGRADES BELLEFONTE NUCLEAR FACILITY MULTIPLE COUNTIES, ALABAMA

In a letter dated September 9, 2009, TVA initiated consultation regarding the proposed upgrading of TVA TLs and right-of-ways (ROWs) which would result from the Bellefonte Nuclear Plant Completion Project (Project). Following further review, TVA finds that in order to proceed with Project planning an agreement document developed in consultation with your office and other interested parties would be required. This document would facilitate the phased identification and evaluation of historic properties that may be affected by the proposed TL and ROW upgrades planned in 2016. Therefore, TVA's Archeological and Historic staff are in the process of drafting an agreement document for your review and comment and will submit this document to you in the forthcoming month.

Should you have any questions or comments, please contact Richard Yamell at 865/632-3463 or wryarnell@tva.gov.

Sincerely,

A. Eric Howard Federal Preservation Officer WT 11D-K

MH:IKS cc: EDMS, WT 11D-K



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, Tennessee 37902-1499

October 28, 2009

Mr. Ray Luce State Historic Preservation Officer Department of Natural Resources 34 Peachtree Street, NW, Suite 1600 Atlanta, Georgia 30303-2316

Dear Mr. Luce:

TENNESSEE VALLEY AUTHORITY (TVA), BELLEFONTE NUCLEAR PLANT, PROPOSED UPGRADES TO TVA TRANSMISSION LINES (TL), DADE AND WALKER COUNTIES, GEORGIA HP-090914-01

In a letter dated September 9, 2009, TVA initiated consultation regarding the proposed upgrading of TVA TLs and right-of-ways (ROWs) which would result from the Bellefonte Nuclear Plant Completion Project (Project). Following further review, TVA finds that in order to proceed with Project planning an agreement document developed in consultation with your office and other interested parties would be required. This document would facilitate the phased identification and evaluation of historic properties that may be affected by the proposed TL and ROW upgrades planned in 2016. Therefore, TVA's Archeological and Historic staff are in the process of drafting an agreement document for your review and comment and will submit this document to you in the forthcoming month.

Should you have any questions or comments, please contact Richard Yarnell at 865/632-3463 or wryarnell@tva.gov.

Sincerely,

A. Eric Howard Federal Preservation Officer WT 11D-K

MH:IKS cc: EDMS, WT 11D-K



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, Tennessee 37902-1499

October 28, 2009

Mr. E. Patrick McIntyre, Jr. Executive Director Tennessee Historical Commission Clover Bottom Mansion 2941 Lebanon Road Nashville, Tennessee 37243-0442

Dear Mr. McIntyre:

TENNEESSEE VALLEY AUTHORITY (TVA), BELLEFONTE NUCLEAR TRANSMISSION LINE (TL) UPGRADES, LIMESTONE, JACKSON, AND MORGAN COUNTIES, ALABAMA; BEDFORD, COFFEE, SEQUATCHIE, HAMILTON, AND MARION COUNTIES, TENNESSEE; AND WALKER AND DADE COUNTIES, GEORGIA

In a letter dated September 9, 2009, TVA initiated consultation regarding the proposed upgrading of TVA TLs and right-of-ways (ROWs) which would result from the Bellefonte Nuclear Plant Completion Project (Project). Following further review, TVA finds that in order to proceed with Project planning an agreement document developed in consultation with your office and other interested parties would be required. This document would facilitate the phased identification and evaluation of historic properties that may be affected by the proposed TL and ROW upgrades planned in 2016. Therefore, TVA's Archeological and Historic staff are in the process of drafting an agreement document for your review and comment and will submit this document to you in the forthcoming month.

Should you have any questions or comments, please contact Richard Yarnell at 865/632-3463 or wryarnell@tva.gov.

Sincerely,

A. Eric Howard Federal Preservation Officer WT 11D-K

MH:IKS cc: EDMS, WT 11D-K



Tennessee Valley Authority, 400 West Summit Hill Drive, Knowille, Tennessee 37902-1499

November 4, 2009

Mr. Frank White State Historic Preservation Officer Alabama Historical Commission 468 South Perry Street Montgomery, Alabama 36130-0900

Dear Mr, White:

DRAFT SUPPLEMENTAL ENVIRONMENTAL IMPACT STATEMENT (SEIS) FOR A SINGLE NUCLEAR UNIT AT THE BELLEFONTE SITE AND ASSOCIATED TRANSMISSION UPGRADES IN JACKSON COUNTY, LIMESTONE COUNTY, AND MORGAN COUNTY, ALABAMA

Please find enclosed two copies of the draft SEIS, which evaluates Tennessee Valley Authority's (TVA) proposal to complete or construct and operate a single nuclear generating unit at the Bellefonte Nuclear Plant (BLN) site located in Jackson County, Alabama. TVA is requesting your review of the draft SEIS and is accepting comments between November 13 and December 28, 2009.

TVA is considering a No Action Alternative and two Action Alternatives: completion and operation of a Babcock and Wilcox pressurized light water reactor or construction and operation of a Westinghouse AP1000 advanced pressurized light water reactor. Either of the two Action Alternatives would use licensing processes that are already underway. The draft SEIS also evaluates the impact of refurbishing, reenergizing, and upgrading existing electrical transmission infrastructure necessary to accommodate new power generation.

TVA has identified the need for additional base load generation in the 2018 to 2020 time frame. Completion or construction of one additional nuclear unit capable of generating between approximately 1,100 and 1,200 megawatt (MW) of power within this time frame would help address the need for additional base load generation in the TVA power service area and help meet TVA's goal to have at least 50 percent of its generation portfolio comprised of low or zero carbon-emitting sources by the year 2020. Both Action Alternatives proposed would also make beneficial use of existing assets at the BLN site.

This draft SEIS supplements TVA's original 1974 *Final Environmental Statement – Bellefonte Nuclear Plant Units 1 and 2* for the BLN project and updates other related environmental documents including a 2008 environmental report for the AP1000 for BLN Units 3 and 4. TVA will identify its preferred alternative in the final SEIS after receiving input from the reviewing agencies and the public.

The draft SEIS may be viewed at <u>www.tva.gov/environment/reports/blnp</u>, and comments may be provided to us online. Please note that any comments received, including names and addresses, will become part of the administrative record and will be available for public

Final Supplemental Environmental Impact Statement

A-269

inspection. To provide written comments or request a printed copy of the draft SEIS, please contact:

Ruth M. Horton Senior NEPA Specialist Tennessee Valley Authority 400 West Summit Hill Drive, WT 11D Knoxville, Tennessee 37902 Phone: (865) 632-3719 E-mail: mhorton@tva.gov.

Also, for general project information, contact:

Andrea L. Sterdis Nuclear Project Manager Tennessee Valley Authority 1101 Market Street, LP 5A Chattanooga, Tennessee 37402 Phone: (423) 751-7119 E-mail: <u>alsterdis@tva.gov</u>

Sincerely,

A. Eric Howard Federal Preservation Officer Office of Environment and Research WT 11D-K

Enclosure



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, Tennessee 37902-1499

November 4, 2009

Mr. Ray Luce State Historic Preservation Officer 34 Peachtree Street, NW, Suite 1600 Atlanta, Georgia 30303-2316

Dear Mr. Luce:

DRAFT SUPPLEMENTAL ENVIRONMENTAL IMPACT STATEMENT (SEIS) FOR A SINGLE NUCLEAR UNIT AT THE BELLEFONTE SITE AND ASSOCIATED TRANSMISSION UPGRADES IN DADE COUNTY AND WALKER COUNTY, GEORGIA

Please find enclosed two copies of the draft SEIS, which evaluates Tennessee Valley Authority's (TVA) proposal to complete or construct and operate a single nuclear generating unit at the Bellefonte Nuclear Plant (BLN) site located in Jackson County, Alabama. TVA is requesting your review of the draft SEIS and is accepting comments between November 13 and December 28, 2009.

TVA is considering a No Action Alternative and two Action Alternatives: completion and operation of a Babcock and Wilcox pressurized light water reactor or construction and operation of a Westinghouse AP1000 advanced pressurized light water reactor. Either of the two Action Alternatives would use licensing processes that are already underway. The draft SEIS also evaluates the impact of refurbishing, reenergizing, and upgrading existing electrical transmission infrastructure necessary to accommodate new power generation.

TVA has identified the need for additional base load generation in the 2018 to 2020 time frame. Completion or construction of one additional nuclear unit capable of generating between approximately 1,100 and 1,200 megawatt (MW) of power within this time frame would help address the need for additional base load generation in the TVA power service area and help meet TVA's goal to have at least 50 percent of its generation portfolio comprised of low or zero carbon-emitting sources by the year 2020. Both Action Alternatives proposed would also make beneficial use of existing assets at the BLN site.

This draft SEIS supplements TVA's original 1974 Final Environmental Statement – Bellefonte. Nuclear Plant Units 1 and 2 for the BLN project and updates other related environmental documents including a 2008 environmental report for the AP1000 for BLN Units 3 and 4. TVA will identify its preferred alternative in the final SEIS after receiving input from the reviewing agencies and the public.

The draft SEIS may be viewed at <u>www.tva.gov/environment/reports/blnp</u>, and comments may be provided to us online. Please note that any comments received, including names and addresses, will become part of the administrative record and will be available for public

Final Supplemental Environmental Impact Statement

A-271

inspection. To provide written comments or request a printed copy of the draft SEIS, please contact:

Ruth M. Horton Senior NEPA Specialist Tennessee Valley Authority 400 West Summit Hill Drive, WT 11D Knoxville, Tennessee 37902 Phone: (865) 632-3719 E-mail: mhorton@tva.gov.

Also, for general project information, contact:

Andrea L. Sterdis Nuclear Project Manager Tennessee Valley Authority 1101 Market Street, LP 5A Chattanooga, Tennessee 37402 Phone: (423) 751-7119 E-mail: <u>alsterdis@tva.gov</u>

Sincerely,

Ho

A. Eric Howard Federal Preservation Officer Office of Environment and Research WT 11D-K

Enclosure



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, Tennessee 37902-1499

November 4, 2009

Mr. E. Patrick McIntyre, Jr. Executive Director Tennessee Historical Commission 2941 Lebanon Pike Nashville, Tennessee 37243-0442

Dear Mr. McIntyre:

DRAFT SUPPLEMENTAL ENVIRONMENTAL IMPACT STATEMENT (SEIS) FOR A SINGLE NUCLEAR UNIT AT THE BELLEFONTE SITE AND ASSOCIATED TRANSMISSION UPGRADES IN BEDFORD COUNTY, COFFEE COUNTY, HAMILTON COUNTY, MARION COUNTY, AND SEQUATCHIE COUNTY, TENNESSEE

Please find enclosed two copies of the draft SEIS, which evaluates Tennessee Valley Authority's (TVA) proposal to complete or construct and operate a single nuclear generating unit at the Bellefonte Nuclear Plant (BLN) site located in Jackson County, Alabama. TVA is requesting your review of the draft SEIS and is accepting comments between November 13 and December 28, 2009.

TVA is considering a No Action Alternative and two Action Alternatives: completion and operation of a Babcock and Wilcox pressurized light water reactor or construction and operation of a Westinghouse AP1000 advanced pressurized light water reactor. Either of the two Action Alternatives would use licensing processes that are already underway. The draft SEIS also evaluates the impact of refurbishing, reenergizing, and upgrading existing electrical transmission infrastructure necessary to accommodate new power generation.

TVA has identified the need for additional base load generation in the 2018 to 2020 time frame. Completion or construction of one additional nuclear unit capable of generating between approximately 1,100 and 1,200 megawatt (MW) of power within this time frame would help address the need for additional base load generation in the TVA power service area and help meet TVA's goal to have at least 50 percent of its generation portfolio comprised of low or zero carbon-emitting sources by the year 2020. Both Action Alternatives proposed would also make beneficial use of existing assets at the BLN site.

This draft SEIS supplements TVA's original 1974 Final Environmental Statement – Bellefonte Nuclear Plant Units 1 and 2 for the BLN project and updates other related environmental documents including a 2008 environmental report for the AP1000 for BLN Units 3 and 4. TVA will identify its preferred alternative in the final SEIS after receiving input from the reviewing agencies and the public.

The draft SEIS may be viewed at <u>www.tva.gov/environment/reports/blnp</u>, and comments may be provided to us online. Please note that any comments received, including names and

addresses, will become part of the administrative record and will be available for public inspection. To provide written comments or request a printed copy of the draft SEIS, please contact:

Ruth M. Horton Senior NEPA Specialist Tennessee Valley Authority 400 West Summit Hill Drive, WT 11D Knoxville, Tennessee 37902 Phone: (865) 632-3719 E-mail: <u>rmhorton@tva.gov</u>.

Also, for general project information, contact:

Andrea L. Sterdis Nuclear Project Manager Tennessee Valley Authority 1101 Market Street, LP 5A Chattanooga, Tennessee 37402

Phóne: (423) 751-7119 E-mail: <u>alsterdis@tva.góv</u>

Sincerely,

A. Eric Howard Federal Preservation Officer Office of Environment and Research WT 11D-K

Enclosure



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, Tennessee 37902-1499

March 24, 2010

To Those Listed:

TVA, BELLEFONTE NUCLEAR TRANSMISSION LINE UPGRADES, LIMESTONE, JACKSON, AND MORGAN COUNTIES, ALABAMA; BEDFORD, COFFEE, SEQUATCHIE, HAMILTON, AND MARION COUNTIES, TENNESSEE; AND WALKER AND DADE COUNTIES, GEORGIA

TVA previously consulted with you on August 26, 2009, regarding the Bellefonte Nuclear Completion Project. By this letter, the Tennessee Valley Authority (TVA) is providing preliminary documentation for the proposed upgrading of TVA transmission lines (TLs) and TL right-of-ways (ROW) associated with the Bellefonte Nuclear Plant Completion Project (PROJECT). TVA is in the planning stages of the PROJECT and the proposed upgrading of the TLs would begin around 2016.

Currently, TVA is in the process of preparing a Supplemental Environmental Impact Statement that would update existing information about the potential environmental impacts associated with its proposal to operate a single nuclear generation unit at the Bellefonte Nuclear Plant (BLN) site: TVA may choose to 1) complete and operate either one of two partially constructed units (Babcock and Wilcox pressurized water reactor) or 2) construct and operate one new technology unit (Westinghouse AP1000 advanced boiling water reactor). The No Action Alternative would also be considered.

As currently proposed under both Action Alternatives, the existing 161-kilovolt (kV) and 500-kV switchyards constructed on the BLN site would be refurbished and reenergized; four 500-kV TL that terminate in the BLN switchyard would be reestablished; the ROW would be brought back to current TVA standards; the capacity of nine existing TLs would be increased; and two 161-kV transmission lines that supply a 161-kV switchyard to provide site power would be reestablished (Figure 1); all of these TLs and ROWs are existing.

TVA has determined the area of potential effects (APE) to be the ROW and TLs that are slated for upgrades and the footprint of all infrastructures (e.g., access roads, staging areas). The architectural APE would be a .5 mile wide area linearly centered along the proposed TL ROW.

A review of the Alabama, Tennessee, and Georgia site files identified twenty-five sites previously recorded within the APE. One of these sites (1MG785) is no longer extant. Seven sites (1MG116, 1MG115, 1MG667, 1MG758, 1MG757, 1JA304, 1JA694) were previously determined not eligible for the National Register of Historic Places (NRHP). Two sites, 1MG735 and 9WA164, has been previously determined potentially eligible for the NRHP. The remaining 15 sites (1JA637, 1JA650, 40MI246, 40MI247, 40HA0089, 40MI248, 1JA453, 1JA452, 1JA304, 1JA377, 1JA518, 1JA532, 1JA524, 1JA617, 1JA558) have not been assessed for NRHP eligibility. In Alabama, one previously recorded historic district (the City of Bridgeport) falls within the architectural APE. TVA would seek comments regarding these properties and other yet to be identified properties,

Page 2 March 24, 2010

TVA is preparing three Memoranda of Agreement (MOA) for the phased identification and evaluation of cultural resources within the APE. Because three states are involved in the APE, a separate MOA for phased identification and evaluation will be executed between TVA and each State Historic Preservation Officer (Alabama, Tennessee, and Georgia).

At this time TVA is providing notification of the proposed undertaking to the following tribes: Cherokee Nation, Eastern Band of Cherokee Indians, United Keetoowah Band of Cherokee Indians in Oklahoma, The Chickasaw Nation, Muscogee (Creek) Nation of Oklahoma, Alabama-Coushatta Tribe of Texas, Alabama-Quassarte Tribal Town, Kialegee Tribal Town, Thlopthlocco Tribal Town, Seminole Tribe of Florida, Absentee-Shawnee Tribe of Oklahoma, Eastern Shawnee Tribe of Oklahoma, Shawnee Tribe, Jena Band of Choctaw Indians, and the Poarch Band of Creek Indians. No upgrading or reconductoring for the proposed undertaking is scheduled to begin until 2016.

At this time, TVA is inviting you to participate as a concurring party to the MOA for a phased identification and evaluation of historic properties. Please let me know if you would like to participate as a concurring party; and, if so, for which states. Whether you choose to be a concurring party to this agreement document or not, TVA will consult with you regarding any National Register of Historic Places eligibility evaluations, determinations, and/or historic property treatment plans, should such measures be required.

Should you have any questions, please contact me via phone at 865/632-6461 or via e-mail at pbezzell@tva.gov. Please respond within 30 days of receipt of this letter, if you have any comments on the proposed undertaking.

Sincerely,

anaed Egypell Tat L

Pat Bernard Ezzell Native American Liaison and Historian

MH:PBE:IKS Enclosure cc: Kimberly Hodges (EDMS), LP 2V-C



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, Tennessee 37902-1499

April 8, 2010

Mr. E. Patrick McIntyre, Jr. Executive Director Tennessee Historical Commission Clover Bottom Mansion 2941 Lebanon Road Nashville, Tennessee 37243-0442

Dear Mr. McIntyre:

MEMORANDUM OF AGREEMENT BETWEEN THE TENNESSEE VALLEY AUTHORITY AND THE TENNESSEE STATE HISTORIC PRESERVATION OFFICER FOR THE TRANSMISSION LINE UPGRADES RELATING TO THE BELLEFONTE NUCLEAR PROJECT

Enclosed for your signature, is one copy of the Memorandum of Agreement (MOA) and three additional signatory pages regarding the proposed Bellefonte Nuclear Project transmission line (TL) upgrades. TVA has consulted with your office and other consulting parties during the development of the MOA. The MOA was prepared for the Bellefonte Nuclear Project Supplemental Environmental Impacts Statement. The MOA is for the phased identification and evaluation of historic properties that may be affected by the proposed TL upgrades to begin in 2016.

Please sign the three additional enclosed signatory pages and return to me. If you have questions, please feel free to contact me at (865) 632-2457.

Sincerely,

A. Eric Howard Federal Preservation Officer

MH:IKS Enclosures cc: Files, HAPC, WT 11D-K



HISTORIC PRESERVATION DIVISION

CHRIS CLARK COMMISSIONER

DR. DAVID CRASS DIVISION DIRECTOR

April 29, 2010

Mr. A. Eric Howard Federal Preservation Officer Historic and Archaeological Permitting and Compliance Tennessee Valley Authority 400 West Summit Hill Drive Knoxville, Tennessee 37902-1499

Re: Memorandum of Agreement Upgrade Belfonte Nuclear Transmission lines Dade and Walker Counties, Georgia HP-090914-001

Dear Mr. Howard:

The Historic Preservation Division (HPD) has received the Memorandum of Agreement (MOA) for the above referenced project in Dade and Walker Counties, Georgia. Our comments are offered to assist federal agencies in complying with the provisions of Section 106 of the National Historic Preservation Act of 1966, as amended.

As previously stated, HPD concurs that the MOA is adequate to address adverse effects that may be associated with undertaking. Therefore, I have signed this agreement and am returning three (3) additional original signature pages to you for further processing.

If you have any questions, please contact Elizabeth (Betsy) Shirk, Environmental Review Coordinator, at (404) 651-6624.

Sincerely,

Dr. David Crass Division Director Deputy State Historic Preservation Officer

DC/ECS

Enclosure

cc: Richard Yarnell, TVA, wryarnell@tva.gov Dan Latham, Jr., Northwest Georgia RC PA File


> 254 Washington Street, SW | Ground Level | Atlanta, Georgia 30334 404.656.2840 | Fax 404.657.1368 | www.gashpo.org

Final Supplemental Environmental Impact Statement


A-278

Appendix I

APPENDIX I – BLN METEOROLOGICAL TOWER DATA, APRIL 1, 2006, TO SEPTEMBER 24, 2008



Composite Wind Rose (All Stability Classes)



Appendix I

Occurrence of Stability Classes

Stability	Percent of
Class	Total Hours
A	0.915
B	1.985
C	4.725
D	44.107
E	27.465
F	11.917
G	8.886

Wind Direction Distribution

Min al Dine etia	Develop 1
Wind Direction	Percent of
(blowing from)	Total Hours
Ν	7.944
NNE	12.454
NE	13.147
ENE	4.908
E	2.812
ESE	2.568
SE	3.328
SSE	4.240
S	6.802
SSW	12.547
SW	10.029
WSW	4.944
W	3.459
WNW	2.757
NW	3.242
NNW	4.819

Wind Speed Distribution

Percent of
Total Hours
0.397
17.334
30.630
24.271
14.767
11.755
0.827
0.019
0.000

Joint Frequency Distributions by Stability Class

Stability Class A

WIND			WIND SPE	ED (MPH)						
DIRECTION	CALM	0.6-1.4	<u>1.5-3.4</u>	3.5-5.4	<u>5.5-7.4</u>	7.5-12.4	<u>12.5-18.4</u>	<u>18.5-24.4</u>	>=24.5	<u>TOTAL</u>
N	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.000	0.000	0.005
NNE	0.000	0.000	0.000	0.000	0.015	0.010	0.000	0.000	0.000	0.024
NE	0.000	0.000	0.005	0.005	0.010	0.015	0.000	0.000	0.000	0.034
ENE	0.000	0.000	0.010	0.000	0.000	0.000	0.000	0.000	0.000	0.010
E	0.000	0.000	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.005
ESE	0.000	0.000	. 0.000	0.010	0.010	0.005	0.000	0.000	0.000	0.024
SE	0.000	0.000	0.000	0.000	0.039	0.010	0.005	0.000	0.000	0.054
SSE	0.000	0.000	0.000	0.005	0.049	0.019	0.000	0.000	0.000	0.073
S	0.000	0.000	0.000	0.019	0.073	0.049	0.000	0.000	0.000	0.141
SSW	0.000	0.005	0.000	0.005	0.015	0.058	0.000	0.000	0.000	0.083
SW	0.000	0.000	0.000	0.029	0.029	0.073	0.005	0.000	0.000	0.136
WSW	0.000	0.000	0.000	0.000	0.005	0.049	0.005	0.000	0.000	0.058
W	0.000	0.000	0.000	0.000	0.029	0.044	0.010	0.000	0.000	0.083
WNW	0.000	0.000	0.010	0.005	0.024	0.015	0.000	0.000	0.000	0.054
NW	0.000	0.000	0.010	0.000	0.015	0.015	0.000	0.000	0.000	0.039
NNW	0.000	0.000	0.005	0.000	0.019	0.068	0.000	0.000	0.000	0.092
SUBTOTAL	0.000	0.005	0.044	0.078	0.336	0.428	0.024	0.000	0.000	0.915

Stability Class B

WIND			WIND SPEE	D (MPH)						
DIRECTION	CALM	<u>0.6-1.4</u>	<u>1.5-3.4</u>	<u>3.5-5.4</u>	<u>5.5-7.4</u>	<u>7.5-12.4</u>	12.5-18.4	<u>18.5-24.4</u>	>=24.5	<u>TOTAL</u>
N	0.000	0.000	0.000	0.024	0.068	0.083	0.000	0.000	0.000	0.175
NNE	0.000	0.000	0.005	0.000	0.054	0.005	0.000	0.000	0.000	0.073
NE	0.000	0.000	0.000	0.005	0.034	0.044	0.000	0.000	0.000	0.088
									0.000	
ENE	0.000	0.000	0.005	0.000	0.010	0.010	0.000	0.000		0.024
E	0.000	0.000	0.000	0.000	0.010	0.005	0.000	0.000	0.000	0.015
ESE	0.000	0.000	0.000	0.000	0.029	0.005	0.000	0.000	0.000	0.034
SE	0.000	0.000	0.000	0.005	0.034	0.005	0.000	0.000	0.000	0.044
SSE	0.000	0.000	0.000	0.054	0.054	0.010	0.000	0.000	0.000	0.117
S	0.000	0.000	0.005	0.044	0.136	0.054	0.000	0.000	0.000	0.238
SSW	0.000	0.000 .	0.000	0.015	0.083	0.136	0.005	0.000	0.000	0.238
SW	0.000	0.000	0.005	0.019	0.073	0.141	0.019	0.000	0.000	0.258
WSW	0.000	0.000	0.000	0.024	0.024	0.112	0.019	0.000	0.000	0.180
W	0.000	0.000	0.000	0.029	0.054	0.078	0.000	0.000	0.000	0.161
WNW	0.000	0.000	0.000	0.015	0.034	0.039	0.005	0.000	0.000	0.092
NW	0.000	0.000	0.000	0.010	0.005	0.073	0.000	0.000	0.000	0.088
NNW	0.000	0.000	0.005	0.010	0.044	0.097	0.005	0.000	0.000	0.161
SUBTOTAL	0.000	0.000	0.024	0.253	0.749	0.905	0.054	0.000	0.000	1.985

Appendix I

Joint Frequency Distributions by Stability Class (continued)

Stability Class C

WIND			WIND SPEE	ED (MPH)						
DIRECTION	CALM	0.6-1.4	<u>1.5-3.4</u>	<u>3.5-5.4</u>	<u>5.5-7.4</u>	7.5-12.4	<u>12.5-18.4</u>	<u>18.5-24.4</u>	>=24.5	<u>TOTAL</u>
• ·		0.005	0.040	0.000	0.407	0.400	0.000	0.000	0.000	0.050
N	0.000	0.005	0.010	0.088	0.127	0.122	0.000	0.000	0.000	0.350
NNE	0.000	0.000	0.010	0.156	0.248	0.073	0.000	0.000	0.000	0.487
NE	0.000	0.000	0.005	0.102	0.161	0.097	0.005	0.000	0.000	0.370
ENE	0.000	0.000	0.000	0.063	0.058	0.005	0.000	0.000	0.000	0.127
E	~ 0.000	0.000	0.000	0.019	0.029	0.005	0.000	0.000	0.000	0.054
ESE	0.000	0.000	0.000	0.034	0.019	0.029	0.000	0.000	0.000	0.083
· SE	0.000	0.000	0.005	0.058	0.068	0.000	0.000	0.000	0.000	0,131
SSE	0.000	0.000	0.000	0.102	0.097	0.044	0.000	0.000	0.000	0.243
S	0.000	0.000	0.005	0.078	0.151	0.083	0.010	0.000	0.000	0.326
SSW	0.000	0.000	0.005	0.127	0.195	0.263	0.000	0.000	0.000	0.589
SW	0.000	0.000	0.005	0.092	0.195	0.302	0.024	0.000	0.000	0.618
WSW	0.000	0.000	0.010	0.073	0.102	0.161	0.029	0.010	0.000	0.384
W	0.000	0.000	0.005	0.058	0.097	0.097	0.005	0.000	0.000	0.263
WNW	0.000	0.000	0.019	0.063	0.058	0.097	0.000	0.000	0.000	0.238
NW	0.000	0.000	0.015	0.039	0.054	0.073	0.000	0.000	0.000	0.180
NNW	0.000	0.000	0.000	0.063	0.097	0.122	0.000	0.000	0.000	0.282
SUBTOTAL	0.000	0.005	0.092	1.217	1.757	1.572	0.073	0.010	0.000	4.725

Stability Class D

WI	ND			WIND SPEE	D (MPH)						
DIREC	CTION	CALM	0.6-1.4	<u>1.5-3.4</u>	<u>3.5-5.4</u>	<u>5.5-7.4</u>	7.5-12.4	<u>12.5-18.4</u>	<u>18.5-24.4</u>	<u>>=24.5</u>	<u>TOTAL</u>
N		0.000	0.068	1.387	1.494	1.100	0.929	0.010	0.000	0.000	4.988
N	NE	0.000	0.054	1.961	2.822	1.022	0.292	0.005	0.000	0.000	6.156
N	E	0.000	0.039	1.499	2.555	1.075	0.443	0.005	0.000	0.000	5.616
È	NE ·	0.000	0.024	0.453	0.735	0.214	0.088	0.000	0.000	0.000	1.513
E		- 0.000	0.034	0.238	0.331	0.107	0.049	0.000	0.000	0.000	0.759
E	SE	0.000	0.010	0.209	0.355	0.136	0.039	0.000	0.000	0.000	0.749
s		0.000	0.000	0.219	0.584	0.345	0.200	0.049	0.000	0.000	1.397
S	SE	0.000	0.000	0.282	0.696	0.380	0.273	0.015	0.000	0.000	1.645
S		0.000	0.024	0.360	0.852	0.633	0.569	0.127	0.010	0.000	2.574
S	sw	0.000	0.005	0.448	1.095	1.139	1.431	0.097	0.000	0.000	4.214
S	W	0.000	0.015	0.477	1.187	0.983	0.895	0.058	0.000	0.000	3.616
	/SW	0.000	0.029	0.438	0.749	0.428	0.423	0.107	0.000	0.000	2.175
Ŵ	1	0.000	0.039	0.516	0.521	0.384	0.336	0.039	0.000	0.000	1.835
· W	/NW	0.000	0.019	0.472	0.433	0.321	0.380	0.015	0.000	0.000	1.640
N	W	0.000	0.063	0.589	0.491	0.404	0.409	0.024	0.000	0.000	1.981
	NW	0.000	0.058	0.954	0.822	0.608	0.779	0.029	0.000	0.000	3.251
SUBT	OTAL	0.000	0.482	10.501	15.723	9.280	7.533	0.579	0.010	0.000	44.107

A-284

Single Nuclear Unit at the Bellefonte Site

Joint Frequency Distributions by Stability Class (continued)

Stability Class E

WIND			WIND SPEE	D (MPH)						
DIRECTION	CALM	<u>0.6-1.4</u>	<u>1.5-3.4</u>	3.5-5.4	<u>5.5-7.4</u>	7.5-12.4	<u>12.5-18.4</u>	18.5-24.4	<u>>=24.5</u>	<u>TOTAL</u>
N	0.003	0.268	1.027	0.365	0.112	0.019	0.000	0.000	0.000	1,793
NNE	0.006	0.628	2.569	1.221	0.214	0.024	0.000	0.000	0.000	4.663
NE	0.007	0.676	2.915	1.041	0.234	0.039	0.005	0.000	0.000	4.917
ENE	0.002	0.389	0.662	0.204	0.024	0.029	0.000	0.000	0.000	1.311
E	0.001	0.156	0.224	0.097	0.010	0.005	0.000	0.000	0.000	0.492
ESE	0.001	0.156	0.195	0.092	0.034	0.015	0.000	0.000	0.000	0.492
SE	0.001	0.097	0.219	0.200	0.049	0.029	0.000	0.000	0.000	0.594
SSE	0.001	0.112	0.414	0.156	0.068	0.044	0.005	0.000	0.000	0.799
S	0.002	0.141	0.676	0.360	0.161	0.117	0.024	0.000	0.000	1.481
SSW	0.003	0.311	1.187 ·	1.231	0.788	0.642	0.044	0.000	0.000	4.207
SW	0.003	0.282	1.168	0.861	0.521	0.190	0.010	0.000	0.000	3.035
WSW	0.002	0.165	0.618	0.307	0.131	0.029	0.005	0.000	0.000	1.257
W	0.001	0.122	0.355	0.102	0.044	0.015	0.000	0.000	0.000	0.638
WNW	0.001	0.083	0.268	0.078	0.029	0.010	0.000	0.000	0.000	0.468
NW	0.001	0.102	0.389	0.083	0.034	0.019	0.000	0.000	0.000	0.629
NNW	0.001	0.122	0.350	0.165	0.039	0.010	0.000	0.000	0.000	0.687
SUBTOTAL	0.034	3.810	13.236	6.564	2.491	1.236	0.092	0.000	0.000	27.465

Stability Class F

WIND			WIND SPEE	ED (MPH)						
DIRECTION	CALM	<u>0.6-1.4</u>	1.5-3.4	<u>3.5-5.4</u>	<u>5.5-7.4</u>	7.5-12.4	<u>12.5-18.4</u>	<u>18.5-24.4</u>	>=24.5	<u>TOTAL</u>
N	0.005	0.214	0.170	0.005	0.000	0.000	0.000	0.000	0.000	0.394
NNE	0.010	0.438	0.380	0.019	0.015	0.000	0.000	0.000	0.000	0.862
NE	0.017	0.681	0.706	0.054	0.005	0.000	0.000	0.000	0.000	1.463
ENE	0.014	0.672	0.453	0.019	0.010	0.000	0.000	0.000	0.000	1.167
E	0.010	0.662	0.175	0.015	0.000	0.000	0.000	0.000	0.000	0.862
ESE .	0.007	0.418	0.165	0.000	0.000	0.000	0.000	0.000	0.000	0.591
SE	0.007	0.394	0.151	0.019	0.010	0.000	0.000	0.000	0.000	0.581
SSE	0.007	0.428	0.141	0.000	0.005	0.000	0.000	0.000	0.000	0.581
S	0.014	0.745	0.365	0.010	0.000	0.000	0.000	0.000	0.000	1.133
SSW	0.021	0.900	0.764	0.107	0.015	0.000	0.000	0.000	0.000	1.807
SW	0.015	0.477	0.706	0.117	0.015	0.005	0.000	0.000	0.000	1.334
WSW	0.005	0.204	0.209	0.029	0.005	0.000	0.000	0.000	0.000	0.453
W	0.003	0.088	0.112	0.010	0.000	0.000	0.000	0.000	0.000	0.212
WNW	0.001	0.044	0.068	0.005	0.000	0.005	0.000	0.000	0.000	0.123
NW	0.002	0.063	0.122	0.005	0.000	0.000	0.000	0.000	0.000	0.192
NNW	0.002	0.083	0.058	0.015	0.005	0.000	0.000	0.000	0.000	0.162
SUBTOTAL	0.141	6.511	4.745	0.428	0.083	0.010	0.000	0.000	0.000	11.917

Appendix I

Joint Frequency Distributions by Stability Class (continued)

Stability Class G

WIND			WIND SPEE	ED (MPH)						
DIRECTION	CALM	<u>0.6-1.4</u>	<u>1.5-3.4</u>	<u>3.5-5.4</u>	5.5-7.4	<u>7.5-12.4</u>	<u>12.5-18.4</u>	<u>18.5-24.4</u>	<u>>=24.5</u>	<u>TOTAL</u>
Ν	0.007	0.238	0.039	0.000	0.000	. 0.000	0.000	0.000	0.000	0.285
NNE	0.009	0.248	0.097	0.000	0.000	0.000	0.000	· 0.000	0.000	0.354
NE	0.016	0.384	0.238	0.000	0.000	0.000	0.000	0.000	0.000	0.639
ENE	0.018	0.535	0.170	0.005	0.000	0.000	0.000	0.000	0.000	0.729
Е	0.016	0.545	0.073	0.000	0.000	0.000	0.000	0.000	0.000	0.634
ESE	0.015	0.555	0.034	0.000	0.000	0.000	0.000	0.000	0.000	0.604
SE	0.014	0.482	0.054	0.000	0.000	0.000	0.000	0.000	0.000	0.549
SSE	0.019	0.618	0.097	0.005	0.000	0.000	0.000	0.000	. 0.000	0.739
S	0.022	0.701	0.161	0.000	0.000	0.000	0.000	0.000	0.000	0.884
SSW	0.031	0.822	0.375	0.015	0.000	0.000	0.000	0.000	0.000	1.243
SW	0.024	0.530	0.409	0.010	0.000	0.000	0.000	0.000	0.000	0.973
WSW	0.011	0.311	0.097	0.010	0.000	0.000	0.000	0.000	0.000	0.429
W	0.006	0.136	0.102	0.000	0.000	0.000	0.000	0.000	0.000	0.245
· WNW	0.004	0.097	0.063	0.005	0.000	0.000	0.000	0.000	0.000	0.170
NW	0.005	0.127	0.073	. 0.000	0.000	0.000	0.000	0.000	0.000	0.205
NNW	0.005	0.136	0.063	0.000	0.000	0.000	0.000	0.000	0.000	0.205
SUBTOTAL	0.224	6.467	2.146	0.049	0.000	0.000	0.000	0.000	0.000	8.886

All Stability Classes

WIND			WIND SPEE	D (MPH)						
DIRECTION	CALM	<u>0.6-1.4</u>	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	<u>12.5-18.4</u>	<u>18.5-24.4</u>	<u>>=24.5</u>	<u>TOTAL</u>
Ν	0.028	0.780	2.643	1.939	1.385	1.158	0.009	0.000	0.000	7.944
NNE	0.052	1.333	4.941	4.166	1.546	0.411	0.005	0.000	0.000	12.454
NE	0.059	1.768	5.343	3.787	1.523	0.648	0.019	. 0.000	0.000	13.147
ENE	0.028	1.631	1.768	1.026	0.326	0.128	0.000	0.000	0.000	4.908
E	0.018	1.409	0.714	0.454	0.156	0.061	0.000	0.000	0.000	2.812
ESE	0.014	1.163	0.586	0.487	0.227	0.090	0.000	0.000	0.000	2.568
SE	0.013	0.983	0.643	0.846	0.544	0.246	0.052	0.000	0.000	3.328
SSE	0.018	1.168	0.946	1.036	0.662	0.392	0.019	0.000	0.000	4.240
S	0.026	1.617	1.556	1.381	1.173	0.884	0.156	0.009	0.000	6.802
SSW	0.040	2.085	2.747	2.620	2.331	2.577	0.147	0.000	0.000	12.547
SW	0.034	1.300	2.761	2.341	1.825	1.641	0.128	0.000	0.000	10.029
WSW	0.017	0.714	1.371	1.201	0.700	0.771	0.161	0.009	0.000	4.944
W	0.012	0.378	1.083	0.733	0.624	0.577	0.052	0.000	0.000	3.459
WNW	0.010	0.241	0.908	0.586	0.454	0.539	0.019	0.000	0.000	2.757
NW	0.013	0.355	1.173	0.610	0.496	0.572	0.024	0.000	0.000	3.242
NNW	0.015	0.407	1.447	1.059	0.794	1.059	0.038	0.000	0.000	4.819
SUBTOTAL	0.397	17.334	30.630	24.271	14.767	11.755	0.827	0.019	0.000	100.000

Appendix J


APPENDIX J – BLN METEOROLOGICAL TOWER DATA, COMPARISON OF DATA FROM DIFFERENT PERIODS

Final Supplemental Environmental Impact Statement

Bellefonte Nuclear Plant Meteorological Data (Comparison of Data From Different Periods)

Wind Direction (blowing from)	1979-1982	2006-2007 (COLA)	2006-2008 (full)
N	8.516	8.778	7.944
NNE	13.384	12.899	12.454
NE	14.362	13.133	13.147
ENE	5.047	4.354	4.908
E	2.179	2.000	2.812
ESE	1.370	2.045	2.568
SE	4.223	2.662	3.328
SSE	3.596	4.080	4.240
S	8.644	6.765	6.802
SSW	9.763	12.956	12.547
SW	7.969	9.873	10.029
WSW	4.927	5.137	4.944
W	2.825	3.928	3.459
WNW	2.662	2.958	2.757
NW	3.863	3.411	3.242
NNW	6.669	5.020	4.819

Wind Direction (Percent Occurrence)




Single Nuclear Unit at the Bellefonte Site

Bellefonte Nuclear Plant Meteorological Data (Comparison of Data From Different Periods)

Wind Speed (Percent Occurrence)

Wind Speed Range (mph)	<u>1979-1982</u>	2006-2007 (COLA)	<u>2006-2008 (full)</u>
Calm	0.928	0.459	0.397
0.6-1.4	9.713	16.542	17.334
1.5-3.4	28.719	31.387	30.630
3.5-5.4	23.654	23.804	24.271
5.5-7.4	16.247	14.971	14.767
7.5-12.4	17.682	11.954	11.755
12.5-18.4	2.893	0.860	0.827
18.5-24.4	0.152	0.023	0.019
>=24.5	0.011	0.000	0.000




Final Supplemental Environmental Impact Statement

Bellefonte Nuclear Plant Meteorological Data (Comparison of Data From Different Periods)

Stability Class	<u>1979-1982</u>	2006-2007 (COLA)	2006-2008 (full)
Α	1.040	0.750	0.915
B	2.252	1.774	1.985
С	5.628	5.154	4.725
D	48.490	44.102	44.107
E	29.970	27.580	27.465
	8.702	11.927	11.917
G	3.919	8.713	8.886

Stability Class (Percent Occurrence)



APPENDIX K – TORNADOES IN JACKSON COUNTY, ALABAMA, 1980 TO 2008

Tornadoes in Jackson County, Alabama during 1980-2008:

Date	Location	F-Class	Within 10 miles of Bellefonte (Y/N)?
July 22, 1982	Just NE of Holly Tree	F0	Ν
August 16, 1985	Section	F0	Ŷ
May 8, 1988	3 [mile] SW Stevenson to near Cartersville	F2	N
November 15, 1989	Stevenson community	F1	N
May 18, 1995	Near Athens to near Scottsboro	F4	N
March 16, 1996	Between Pisgah and Rosalie	F1	N
January 5, 1997	Flat Rock	F0	N
May 24, 2001	0.5 NW Aspel to 0.5 NE of Aspel	F1	N
March 19, 2003	Section to Rosalie	F1	Y
March 19, 2003	2 NE Dutton to 3 NE Dutton	F1	Y
March 19, 2003	2 SW Flat Rock to 2 NE Flat Rock	F1	N
May 6, 2003	Hollywood to 3 NE Hollywood	F0	Y
May 6, 2003	5 NE of Hollywood to 6 NE Hollywood	F0	Y
August 20, 2004	1 W Skyline to Skyline	F0	N
April 3, 2007	3 miles E of Langston to Macedonia	EF1*	N
February 6, 2008	1.0 SSE Pisgah to 1.1SE Flat Rock	EF4	Y
December 10, 2008	1.0 SE Tupelo to 2.1 ENE Pikeville	EF2	Y

Source: Huntsville NWS web site (http://www.srh.noaa.gov/hun/?n=jacksontor)

*NWS introduced the Enhanced Fujita (EF) Scale on February 1, 2007 to better estimate tornado wind speeds based on a more objective assessment of storm damage. The wind speed values for each class are provided below. Source: http://www.spc.noaa.gov/efscale/ef-scale.html).

•	Wind Speed (3-sec gust, mph)		
<u>F/EF-Class</u>	F-Scale	EF-Scale (operational)	
0	45-78	65-85	
. 1	79-117	86-110	
2	118-161	111-135	
3	162-209	136-165	
4	210-261	166-200	
5	262-317	>200	

f

Appendix L

APPENDIX L – POWER SYSTEM OPERATIONS ENVIRONMENTAL PROTECTION PROCEDURES RIGHT-OF-WAY VEGETATION MANAGEMENT GUIDELINES

Final Supplemental Environmental Impact Statement

Tennessee Valley Authority Environmental Protection Procedures Right-of-Way Vegetation Management Guidelines

1.0 Overview

- A. The Tennessee Valley Authority (TVA) must manage the vegetation on its rights-of-way and easements to ensure emergency maintenance access and routine access to structures, switches, conductors, and communications equipment. In addition, TVA must maintain adequate clearance, as specified by the National Electrical Safety Code, between conductors and tall-growing vegetation and other objects. This requirement applies to vegetation within the right-of-way as well as to trees located off the right-ofway.
- B. Each year TVA assesses the conditions of the vegetation on and along its rights-of-way. This is accomplished by aerial inspections, periodic field inspections, aerial photography, and information from TVA personnel, property owners, and the general public. Important information gathered during these assessments includes the coverage by various vegetation types, the mix of plant species, the observed growth, the seasonal growing conditions, and the density of the tall vegetation. TVA also evaluates the proximity, height, and growth rate of trees adjacent to the right-of-way that may be a danger to the line or structures.
- C. TVA right-of-way specialists develop a vegetation reclearing plan that is specific to each line segment and is based on terrain conditions, species mix, growth, and density.

2.0 Right-of-Way Management Options

- A. TVA uses an integrated vegetation management approach. In farming areas, TVA encourages property owner management of the right-of-way using low-growing crops. In dissected terrain with rolling hills and interspersed woodlands, TVA uses mechanical moving to a large extent.
- B. When slopes become hazardous to farm tractors and rotary mowers, TVA may use a variety of herbicides specific to the species present with a variety of possible application techniques. When scattered small stands of tall-growing vegetation are present and access along the right-of-way is difficult or the path to such stands is very long, herbicides may be used.
- C. In very steep terrain, in sensitive environmental areas, in extensive wetlands, at stream banks, and in sensitive property owner land use areas, hand clearing may be utilized. Hand clearing is recognized as one of the most hazardous occupations documented by the Occupational Safety and Health Administration. For that reason, TVA is actively looking at better control methods, including use of low-volume herbicide applications, occasional single tree injections, and tree growth regulators (TGRs).
- D. TVA does not encourage tree reclearing by individual property owners because of the high hazard potential of hand clearing, possible interruptions of the line, and electrical safety considerations for untrained personnel that might do the work. Private property owners may reclear the right-of-way with trained reclearing professionals.

- E. Mechanical mowers not only cut the tall saplings and seedlings on the right-of-way, they also shatter the stump and the supporting near-surface root crown. The tendency of resistant species is to resprout from the root crown, and shattered stumps can produce a multistem dense stand in the immediate area. Repeated use of mowers on short cycle reclearing with many original stumps regrowing in the above manner can create a single species thicket or monoculture. With the original large root system and multiple stems, the resistant species can produce regrowth at the rate of 5-10 feet in a year. In years with high rainfall, the growth can reach 12-15 feet in a single year. These dense, monoculture stands can become nearly impenetrable for even large tractors. Such stands have low diversity and little wildlife food or nesting potential and become a property owner's concern. Selective herbicide application may be used to control monoculture stands.
- F. TVA encourages property owners to sign an agreement to manage rights-of-way on their land for wildlife under the auspices of "Project Habitat," a joint project by TVA, BASF, and wildlife organizations, e.g., National Wild Turkey Federation, Quail Unlimited, and Buckmasters. The property owner maintains the right-of-way in wildlife food and cover with emphasis on quail, turkey, deer, or other wildlife. A variation used in or adjacent to developing suburban areas is to sign agreements with the developer and residents to plant and maintain wildflowers on the right-of-way.
- G. TVA places strong emphasis on managing rights-of-way in the above manner. When the property owners do not agree to these opportunities, TVA must maintain the right-of-way in the most environmentally acceptable, cost-effective, and efficient manner possible.

3.0 Herbicide Program

A. TVA has worked with universities (such as Mississippi State University, University of Tennessee, Purdue University, and others), chemical manufacturers, other utilities, U.S. Department of Transportation, U.S. Fish and Wildlife Service (USFWS), and U.S. Forest Service (USFS) personnel to explore options for vegetation control. The results have been strong recommendations to use species-specific, low-volume herbicide applications in more situations. Research, demonstrations, and other right-of-way programs show a definite improvement of rights-of-way treated with selective lowvolume applications of new herbicides using a variety of application techniques and timing. Table 1 below identifies herbicides currently used on bare ground areas on TVA rights-of-way and in substations. Table 3 identifies TGRs that may be used on tall trees that have special circumstances that require trimming on a regular cycle. The rates of application utilized are those listed on the USEPA-approved label and consistent with utility standard practice throughout the Southeast.

Table 1 - Herbicides Currently Used on TVA Rights-of-Way

Trade Name	Active Ingredients	Label Signal Word
Accord	Glyphosate/Liquid	Caution
Arsenal	Imazapyr/Liquid/Granule	Caution
Chopper	Imazapyr/RTU	Caution
Escort	Metsulfuron Methyl/Dry Flowable	Caution
Garlon	Triclopyr/Liquid	Caution
Garlon 3A	Triclopyr/Liquid	Danger
Krenite S	Fosamine Ammonium	Caution
Pathfinder II	Triclopyr/RTU	Caution
Roundup	Glyphosate/Liquid	Caution
Roundup Pro	Glyphosate	Caution
Spike 20P	Tebuthiuron	Caution
Transline	Clopyralid/Liquid	Caution

Table 2 - Preemergent Herbicides Currently Used for Bare Ground Areas on TVA Rights-of-Way and Substations

<u>Trade Name</u>	Active Ingredients	Label Signal Word
Sahara	Diuron/Imazapyr	Caution
SpraKil SK-26	Tebuthiuron and Diuron	Caution
Topsite	Diuron/Imazapyr	Caution

Table 3 - Tree Growth Regulators (TGRs) Currently Used on TVA Rights-of-Way

<u>Trade Name</u>	Active Ingredients	Label Signal Word
Profile 2SC	TGR-paclobutrazol	Caution
TGR	Flurprimidol	Caution

- B. The herbicides listed in Tables 1 and 2 and TGRs listed in Table 3 have been evaluated in extensive studies in support of registration applications and label requirements. Many have been reviewed in the USFS vegetation management environmental impact statements (EISs), and those evaluations are incorporated here by reference (USFS 1989a, 1989b, 2002a, and 2002b). Electronic copies can be accessed at http://www.fs.fed.us/r8/planning/documents/vegmgmt/. The result of these reviews has been a consistent finding of limited environmental impact beyond that of control of the target vegetation. All the listed herbicides have been found to be of low environmental toxicity when applied by trained applicators following the label and registration procedures, including prescribed measures, such as buffer zones, to protect threatened and endangered species.
- C. Low-volume herbicide applications are recommended since research demonstrates much wider plant diversity after such applications. There is better ground erosion protection, and more wildlife food plants and cover plants develop. In most situations, there is increased development of wild flowering plants and shrubs. In conjunction with

Single Nuclear Unit at the Bellefonte Site

herbicides, the diversity and density of low-growing plants provide control of tall-growing species through competition.

- D. Wildlife managers often request the use of herbicides in place of rotary mowing in order to avoid damage to nesting and tunneling wildlife. This method retains ground cover year-round with a better mix of food species and associated high-protein insect populations for birds in the right seasons. Most also report less damage to soils (even when compared with rubber-tired equipment).
- E. Property owners interested in tree production often request the use of low-volume applications rather than hand- or mechanical clearing because of the insect and fungus problems in damaged vegetation and debris left on the right-of-way. The insect and fungus invasions, such as pine tip moth, oak leaf blight, sycamore and dogwood blight, etc., are becoming widespread across the nation.
- F. Best management practices (BMPs) governing application of herbicides are contained within A Guide for Environmental Protection and Best Management Practices for Tennessee Valley Authority Transmission Construction and Maintenance Activities (Muncy 1999), which is incorporated by reference. Herbicides can be liquid, granular, or powder and can be applied aerially or by ground equipment and may be selectively applied or broadcast, depending on the site requirements, species present, and condition of the vegetation. Water quality considerations include measures taken to keep herbicides from reaching streams whether by direct application or through runoff of or flooding by surface water. "Applicators" must be trained, licensed, and follow manufacturers' label instructions, U.S. Environmental Protection Agency (USEPA) guidelines, and respective state regulations and laws.
- G. When herbicides are used, their potential adverse impacts are considered in selecting the compound, formulation, and application method. Herbicides that are designated "Restricted Use" by USEPA require application by or under the supervision of applicators certified by the respective state control board. Aerial and ground applications are either done by TVA or by contractors in accordance with the following guidelines identified in TVA's BMPs manual (Muncy 1999):
 - 1. The sites to be treated are selected and application directed by the appropriate TVA official.
 - 2. A preflight walking or flying inspection is made within 72 hours prior to applying herbicides aerially. This inspection ensures that no land use changes have occurred, that sensitive areas are clearly identified to the pilot, and that buffer zones are maintained.
 - 3. Aerial application of liquid herbicides will normally not be made when surface wind speeds exceed 5 miles per hour, in areas of fog, or during periods of temperature inversion.
 - 4. Pellet application will normally not be made when the surface wind speeds exceed 10 miles per hour or on frozen or water-saturated soils.
 - 5. Liquid application is not performed when the temperature reaches 95 degrees Fahrenheit or above.

Final Supplemental Environmental Impact Statement

- 6. Application during unstable, unpredictable, or changing weather patterns is avoided.
- 7. Equipment and techniques are used that are designed to ensure maximum control of the spray swath with minimum drift.
- 8. Herbicides are not applied to surface water or wetlands unless specifically labeled for aquatic use. Filter and buffer strips will conform at least to federal and state regulations and any label requirements. The use of aerial or broadcast application of herbicides is not allowed within a streamside management zone (SMZs) (200 feet minimum width) adjacent to perennial streams, ponds, and other water sources. Hand application of certain herbicides labeled for use within SMZs is used only selectively.
- 9. Buffers and filter strips (200 feet minimum width) are maintained next to agricultural crops, gardens, farm animals, orchards, apiaries, horticultural crops, and other valuable vegetation.
- 10. Herbicides are not applied in the following areas or times: (a) in city, state, and national parks or forests or other special areas without written permission and/or required permits, (b) off the right-of-way, and (c) during rainy periods or during the 48-hour interval prior to rainfall predicted with a 20 percent or greater probability by local forecasters, when soil active herbicides are used.
- H TVA currently utilizes Activate Plus, manufactured by Terra, as an adjuvant to herbicides to improve the performance of the spray mixture. Application rates are consistent with the USEPA-approved label. The USFWS has expressed some concern on toxicity effects of surfactants on aquatic species. TVA is working in coordination with Mississippi State University and chemical companies to evaluate efficacy of additional low-toxicity surfactants, including LI700 as manufactured by Loveland Industries, through side-byside test plots in the SMZs of area transmission lines.
- TVA currently uses primarily low-volume applications of foliar and basal applications of Accord (glyphosate) and Accord- (glyphosate) Arsenal (imazapyr) tank mixes.
 Glyphosate is one of the most widely used herbicidal active ingredients in the world and has been continuously the subject of numerous exhaustive studies and scrutiny to determine its potential impacts on humans, animals, and the environment.

Single Nuclear Unit at the Bellefonte Site

4.0 References

- Muncy, J. A. 1999. A Guide for Environmental Protection and Best Management Practices for Tennessee Valley Authority Transmission Construction and Maintenance Activities, revised edition. Edited by C. Austin, C. Brewster, A. Lewis, K. Smithson, T. Broyles, and T. Wojtalik. Norris: Tennessee Valley Authority, Technical Note TVA/LR/NRM 92/1.
- U.S. Forest Service. 1989a. Vegetation Management in the Coastal Plain/Piedmont Final Environmental Impact Statement, Volumes I and II. Southern Region Management Bulletin R8-MB-23, January 1989. Atlanta, Ga.: USDA Forest Service.
 - —. 1989b. Vegetation Management in the Appalachian Mountains Final Environmental Impact Statement, Volumes I and II. Southern Region Management Bulletin R8-MB-38, July 1989. Atlanta, Ga.: USDA Forest Service.
 - —. 2002a. Vegetation Management in the Appalachian Mountains Final Environmental Impact Statement Supplement. Southern Region Management Bulletin R8-MB-97A, October 2002. Atlanta, Ga.: USDA Forest Service.
 - —. 2002b. Vegetation Management in the Coastal Plain/Piedmont Final Environmental Impact Statement Supplement. Southern Region Management Bulletin R8-MB-98A, October 2002. Atlanta, Ga.: USDA Forest Service.

Revision April 2008

Appendix M

APPENDIX M – TENNESSEE VALLEY AUTHORITY ENVIRONMENTAL QUALITY PROTECTION SPECIFICATIONS FOR TRANSMISSION LINE CONSTRUCTION

Tennessee Valley Authority Environmental Quality Protection Specifications for Transmission Line Construction

- <u>General</u> Tennessee Valley Authority (TVA) and/or the assigned contractor shall plan, coordinate, and conduct operations in a manner that protects the quality of the environment and complies with TVA's environmental expectations discussed in the preconstruction meeting. This specification contains provisions that shall be considered in all TVA and contract construction operations. If the contractor fails to operate within the intent of these requirements, TVA will direct changes to operating procedures. Continued violation will result in a work suspension until correction or remedial action is taken by the contractor. Penalties and contract termination will be used as appropriate. The costs of complying with the Environmental Quality Protection Specifications are incidental to the contract work, and no additional compensation will be allowed. At all structure and conductor pulling sites, protective measures to prevent erosion will be taken immediately upon the end of each step in a construction sequence, and those protective measures will be inspected and maintained throughout the construction and right-of-way rehabilitation period.
- <u>Regulations</u> TVA and/or the assigned contractor shall comply with all applicable federal, state, and local environmental and antipollution laws, regulations, and ordinances related to environmental protection and prevention, control, and abatement of all forms of pollution.
- 3. <u>Use Areas</u> TVA and/or the assigned contractor's use areas include but are not limited to site office, shop, maintenance, parking, storage, staging, assembly areas, utility services, and access roads to the use areas. The construction contractor shall submit plans and drawings for their location and development to the TVA engineer and project manager for approval. Secondary containment will be provided for fuel and petroleum product storage pursuant to 29CFR1910.106(D)(6)(iii)(OSHA).
- 4. Equipment All major equipment and proposed methods of operation shall be subject to the approval of TVA. The use or operation of heavy equipment in areas outside the right-of-way, access routes, or structure, pole, or tower sites will not be permitted without permission of the TVA inspector or field engineer. Heavy equipment use on steep slopes (greater than 20 percent) and in wet areas will be held to the minimum necessary to construct the transmission line. Steps will be taken to limit ground disturbance caused by heavy equipment usage, and erosion and sediment controls will be instituted on disturbed areas in accordance with state requirements.

No subsurface ground-disturbing equipment or stump-removal equipment will be used by construction forces except on access roads or at the actual structure, pole, or tower sites, where only footing locations and controlled runoff diversions shall be created that disturb the soil. All other areas of ground cover or in-place stumps and roots shall remain in place. (Note: Tracked vehicles disturb surface layer of the ground due to size and function.) Some disking of the right-of-way may occur for proper seedbed preparation.

Unless ponding previously occurred (i.e., existing low-lying areas), water should not be allowed to pond on the structure sites except around foundation holes; the water must be directed away from the site in as dispersed a manner as possible. At tower or structure sites, some means of upslope interruption of potential overland flow and diversion around the footings should be provided as the first step in construction-site preparation. If leveling is necessary, it must be implemented by means that provide for continuous gentle, controlled, overland flow or percolation. A good grass cover, straw, gravel, or other protection of the surface must be maintained. Steps taken to prevent increases in the moisture content of the in-situ soils will be beneficial both during construction and over the service life of any structure.

- 5. <u>Sanitation</u> A designated TVA or contractor representative shall contact a sanitary contractor who will provide sanitary chemical toilets convenient to all principal points of operation for every working party. The facilities shall comply with applicable federal, state, or local health laws and regulations. They shall not be located closer than 100 feet to any stream or tributary or to any wetland. The facilities shall be required to have proper servicing and maintenance, and the waste disposal contractor shall verify in writing that the waste disposal will be in state-approved facilities. Employees shall be notified of sanitation regulations and shall be required to use the toilet facilities.
- 6. <u>Refuse Disposal</u> Designated TVA and/or contractor personnel shall be responsible for daily inspection, cleanup, and proper labeling, storage, and disposal of all refuse and debris produced by his operations and by his employees. Suitable refuse collecting facilities will be required. Only state-approved disposal areas shall be used. Disposal containers such as dumpsters or roll-off containers shall be obtained from a proper waste disposal contractor. Solid, special, construction/demolition, and hazardous wastes as well as scrap are part of the potential refuse generated and must be properly managed with emphasis on reuse, recycle, or possible give away, as appropriate, before they are handled as waste. Contractors must meet similar provisions on any project contracted by TVA.
- 7. <u>Landscape Preservation</u> TVA and its contractors shall exercise care to preserve the natural landscape in the entire construction area as well as use areas, in or outside the right-of-way, and on or adjacent to access roads. Construction operations shall be conducted to prevent any unnecessary destruction, scarring, or defacing of the natural vegetation and surroundings in the vicinity of the work.
- 8. Sensitive Areas Preservation Certain areas on site and along the right-of-way may be designated by the specifications or the TVA engineer as environmentally sensitive. These areas include but are not limited to areas classified as erodible, geologically sensitive, scenic, historical and archaeological, fish and wildlife refuges, water supply watersheds, and public recreational areas such as parks and monuments. Contractors and TVA construction crews shall take all necessary actions to avoid adverse impacts to these sensitive areas and their adjacent buffer zones. These actions may include suspension of work or change of operations during periods of rain or heavy public use; hours may be restricted or concentrations of noisy equipment may have to be dispersed. If prehistoric or historic artifacts or features are encountered during clearing or construction operations, the operations shall immediately cease for at least 100 feet in each direction, and TVA's right-of-way inspector or construction superintendent and Cultural Resources Program shall be notified. The site shall be left as found until a significance determination is made. Work may continue elsewhere beyond the 100-foot perimeter.

 <u>Water Quality Control</u> - TVA and contractor construction activities shall be performed by methods that will prevent entrance or accidental spillage of solid matter, contaminants, debris, and other objectionable pollutants and wastes into flowing caves, sinkholes, streams, dry watercourses, lakes, ponds, and underground water sources.

The clearing contractor will erect and (when TVA or contract construction personnel are unable) maintain best management practices (BMPs) such as silt fences on steep slopes and adjacent to any stream, wetland, or other water body. Additional BMPs may be required for areas of disturbance created by construction activities. BMPs will be inspected by the TVA field engineer or other designated TVA or contractor personnel routinely and during periods of high runoff, and any necessary repairs will be made as soon as practicable. BMP inspections will be conducted in accordance with permit requirements. Records of all inspections will be maintained on site, and copies of inspection forms will be forwarded to the TVA construction environmental engineer.

Acceptable measures for disposal of waste oil from vehicles and equipment shall be followed. No waste oil shall be disposed of within the right-of-way, on a construction site, or on access roads.

10. <u>Turbidity and Blocking of Streams</u> - Construction activities in or near SMZs or other bodies of water shall be controlled to prevent the water turbidity from exceeding state or local water quality standards for that stream. All conditions of a general storm water permit, aquatic resource alteration permit, or a site-specific permit shall be met including monitoring of turbidity in receiving streams and/or storm water discharges and implementation of appropriate erosion and sediment control measures.

Appropriate drainage facilities for temporary construction activities interrupting natural site drainage shall be provided to avoid erosion. Watercourses shall not be blocked or diverted unless required by the specifications or the TVA engineer. Diversions shall be made in accordance with TVA's *A Guide for Environmental Protection and Best Management Practices for Tennessee Valley Authority Transmission Construction and Maintenance Activities.*

Mechanized equipment shall not be operated in flowing water except when approved and, then, only to construct crossings or to perform required construction under direct guidance of TVA. Construction of stream fords or other crossings will only be permitted at approved locations and to current TVA construction access road standards. Material shall not be deposited in watercourses or within stream bank areas where it could be washed away by high stream flows. Appropriate U.S. Army Corps of Engineers and state permits shall be obtained.

Wastewater from construction or dewatering operations shall be controlled to prevent excessive erosion or turbidity in a stream, wetland, lake, or pond. Any work or placing of equipment within a flowing or dry watercourse requires the prior approval of TVA.

11. <u>Clearing</u> - No construction activities may clear additional site or right-of-way vegetation or disturb remaining retained vegetation, stumps, or regrowth at locations other than the structure sites and conductor setup areas. TVA and the construction contractor(s) must provide appropriate erosion or sediment controls for areas they have disturbed that have previously been restabilized after clearing operations. Control measures shall be Single Nuclear Unit at the Bellefonte Site

implemented as soon as practicable after disturbance in accordance with applicable federal, state, and/or local storm water regulations.

- 12. <u>Restoration of Site</u> All construction disturbed areas, with the exception of farmland under cultivation and any other areas as may be designated by TVA's specifications, shall be stabilized in the following manner unless the property owner and TVA's engineer specify a different method:
 - A. The subsoil shall be loosened to a minimum depth of 6 inches if possible and worked to remove unnatural ridges and depressions.
 - B. If needed, appropriate soil amendments will be added.
 - C. All disturbed areas will initially be seeded with a temporary ground cover such as winter wheat, rye, or millet, depending on the season. Perennials may also be planted during initial seeding if proper growing conditions exist. Final restoration and final seeding will be performed as line construction is completed. Final seeding will consist of permanent perennial grasses such as those outlined in TVA's *A Guide for Environmental Protection and Best Management Practices for Tennessee Valley Authority Transmission Construction and Maintenance Activities.* Exceptions would include those areas designated as native grass planting areas. Initial and final restoration will be performed by the clearing contractor.
 - D. TVA holds the option, depending upon the time of year and weather condition, to delay or withdraw the requirement of seeding until more favorable planting conditions are certain. In the meantime, other stabilization techniques must be applied.
- 13. <u>Air Quality Control</u> Construction crews shall take appropriate actions to minimize the amount of air pollution created by their construction operations. All operations must be conducted in a manner that avoids creating a nuisance and prevents damage to lands, crops, dwellings, or persons.
- 14. <u>Burning</u> Before conducting any open burning operations, the contractor shall obtain permits or provide notifications as required to state forestry offices and/or local fire departments. Burning operations must comply with the requirements of state and local air pollution control and fire authorities and will only be allowed in approved locations and during appropriate hours and weather conditions. If weather conditions such as wind direction or speed change rapidly, the contractor's burning operations may be temporarily stopped by the TVA field engineer. The debris for burning shall be piled and shall be kept as clean and as dry as possible, then burned in such a manner as to reduce smoke. No materials other than dry wood shall be open burned. The ash and debris shall be buried away from streams or other water sources and shall be in areas coordinated with the property owner.
- 15. <u>Dust and Mud Control</u> Construction activities shall be conducted to minimize the creation of dust. This may require limitations as to types of equipment, allowable speeds, and routes utilized. Water, straw, wood chips, dust palliative, gravel, combinations of these, or similar control measures may be used subject to TVA's approval. On new construction sites and easements, the last 100 feet before an access

road approaches a county road or highway shall be graveled to prevent transfer of mud onto the public road.

- 16. <u>Vehicle Exhaust Emissions</u> TVA and/or the contractors shall maintain and operate equipment to limit vehicle exhaust emissions. Equipment and vehicles that show excessive emissions of exhaust gasses and particulates due to poor engine adjustments or other inefficient operating conditions shall not be operated until corrective repairs or adjustments are made.
- 17. <u>Vehicle Servicing</u> Routine maintenance of personal vehicles will not be performed on the right-of-way. However, if emergency or "have to" situations arise, minimal/temporary maintenance to personal vehicles will occur in order to mobilize the vehicle to an off-site maintenance shop. Heavy equipment will be serviced on the right-of-way except in designated sensitive areas. The Heavy Equipment Department within TVA or the construction contractor will properly maintain these vehicles with approved spill prevention controls and countermeasures. If emergency maintenance in a sensitive or questionable area arises, the area environmental coordinator or construction environmental engineer will be consulted. All wastes and used oils will be properly recovered, handled, and disposed/recycled. Equipment shall not be temporarily stored in stream floodplains, whether overnight or on weekends or holidays.
- 18. <u>Smoke and Odors</u> TVA and/or the contractors shall properly store and handle combustible material that could create objectionable smoke, odors, or fumes. The contractor shall not burn refuse such as trash, rags, tires, plastics, or other debris.
- 19. <u>Noise Control</u> TVA and/or the contractor shall take measures to avoid the creation of noise levels that are considered nuisances, safety, or health hazards. Critical areas including but not limited to residential areas, parks, public use areas, and some ranching operations will require special considerations. TVA's criteria for determining corrective measures shall be determined by comparing the noise level of the construction operation to the background noise levels. In addition, especially noisy equipment such as helicopters, pile drivers, air hammers, chippers, chain saws, or areas for machine shops, staging, assembly, or blasting may require corrective actions when required by TVA.
- 20. <u>Noise Suppression</u> All internal combustion engines shall be properly equipped with mufflers as required by the Department of Labor's *Safety and Health Regulations for Construction*. TVA may require spark arresters in addition to mufflers on some engines. Air compressors and other noisy equipment may require sound-reducing enclosures in some circumstances.
- 21. <u>Damages</u> The movement of construction crews and equipment shall be conducted in a manner that causes as little intrusion and damage as possible to crops, orchards, woods, wetlands, and other property features and vegetation. The contractor will be responsible for erosion damage caused by his actions and especially for creating conditions that would threaten the stability of the right-of-way or site soil, the structures, or access to either. When property owners prefer the correction of ground cover condition or soil and subsoil problems themselves, the section of the contract dealing with damages will apply.

Revision April 2007

Supplemental Environmental Impact Statement

Page intentionally by

Page intentionally blank

. . .

APPENDIX N – TENNESSEE VALLEY AUTHORITY TRANSMISSION CONSTRUCTION GUIDELINES NEAR STREAMS

Page intentionally blank

·

k .

Tennessee Valley Authority Transmission Construction Guidelines Near Streams

Even the most carefully designed transmission line project eventually will affect one or more creeks, rivers, or other type of water body. These streams and other water areas are protected by state and federal law, generally support some amount of fishing and recreation, and, occasionally, are homes for important and/or endangered species. These habitats occur in the stream and on strips of land along both sides (the streamside management zone [SMZ]) where disturbance of the water, land, or vegetation could have an adverse effect on the water or stream life. The following guidelines have been prepared to help Tennessee Valley Authority (TVA) Transmission Construction staff and their contractors avoid impacts to streams and stream life as they work in and near SMZs. These guidelines expand on information presented in *A Guide for Environmental Protection and Best Management Practices for TVA Construction and Maintenance Activities.*

Three Levels of Protection

During the preconstruction review of a proposed transmission line, TVA Environmental Stewardship and Policy staff will have studied each possible stream impact site and will have identified it as falling into one of three categories: (A) standard stream protection, (B) protection of important permanent streams, or (C) protection of unique habitats. These category designations are based on the variety of species and habitats that exist in the stream as well as state and federal requirements to avoid harming certain species. The category designation for each site will be marked on the plan and profile sheets. Construction crews are required to protect streams and other identified water habitats using the following pertinent set(s) of guidelines:

(A) Standard Stream Protection

This is the standard (basic) level of protection for streams and the habitats around them. The purpose of the following guidelines is to minimize the amount and length of disturbance to the water bodies without causing adverse impacts on the construction work.

Guidelines:

- 1. All construction work around streams will be done using pertinent best management practices (BMPs) such as those described in A Guide for Environmental Protection and Best Management Practices for TVA Construction and Maintenance Activities, especially Chapter 6, "Standards and Specifications."
- 2. All equipment crossings of streams must comply with appropriate state permitting requirements. Crossings of all drainage channels, intermittent streams, and permanent streams must be done in ways that avoid erosion problems and long-term changes in water flow. Crossings of any permanent streams must allow for natural movement of fish and other aquatic life.
- 3. Cutting of trees within SMZs must be accomplished by using either hand-held equipment or other appropriate clearing equipment (e.g., a feller-buncher) that would result in minimal soil disturbance and damage to low-lying vegetation. The method will be selected based on site-specific conditions and topography to

minimize soil disturbance and impacts to the SMZ and surrounding area. Stumps can be cut close to ground level but must not be removed or uprooted.

4. Other vegetation near streams must be disturbed as little as possible during construction. Soil displacement by the actions of plowing, disking, blading, or other tillage or grading equipment will not be allowed in SMZs; however, a minimal amount of soil disturbance may occur as a result of clearing operations. Shorelines that have to be disturbed must be stabilized as soon as feasible.

(B) Protection of Important Permanent Streams

This category will be used when there is one or more specific reason(s) why a permanent (always-flowing) stream requires protection beyond that provided by standard BMPs. Reasons for requiring this additional protection include the presence of important sports fish (trout, for example) and habitats for federal endangered species. The purpose of the following guidelines is to minimize the disturbance of the banks and water in the flowing stream(s) where this level of protection is required.

Guidelines:

- 1. Except as modified by guidelines 2-4 below, all construction work around streams will be done using pertinent BMPs such as those described in A Guide for *Environmental Protection and Best Management Practices for TVA Construction and Maintenance Activities*, especially Chapter 6, "Standards and Specifications."
- 2. All equipment crossings of streams must comply with appropriate state (and, at times, federal) permitting requirements. Crossings of drainage channels and intermittent streams must be done in ways that avoid erosion problems and long-term changes in water flow. Proposed crossings of permanent streams must be discussed in advance with Environmental Stewardship and Policy staff and may require an on-site planning session before any work begins. The purpose of these discussions will be to minimize the number of crossings and their impact on the important resources in the streams.
- 3. Cutting of trees within SMZs must be accomplished by using either hand-held equipment or other appropriate clearing equipment (e.g., a feller-buncher) that would result in minimal soil disturbance and damage to low-lying vegetation. The method will be selected based on site-specific conditions and topography to minimize soil disturbance and impacts to the SMZ and surrounding area. Cutting of trees near permanent streams must be limited to those required to meet National Electric Safety Code and danger tree requirements. Stumps can be cut close to ground level but must not be removed or uprooted.
- 4. Other vegetation near streams must be disturbed as little as possible during construction. Soil displacement by the actions of plowing, disking, blading, or other tillage or grading equipment will not be allowed in SMZs; however, a minimal amount of soil disturbance may occur as a result of clearing operations. Shorelines that have to be disturbed must be stabilized as soon as possible and revegetated as soon as feasible.

(C) **Protection of Unique Habitats**

This category will be used when, for one or more specific reasons, a temporary or permanent aquatic habitat requires special protection. This relatively uncommon level of protection will be appropriate and required when a unique habitat (for example, a particular spring run) or protected species (for example, one that breeds in a wet-weather ditch) is known to occur on or adjacent to the construction corridor. The purpose of the following guidelines is to avoid or minimize any disturbance of the unique aquatic habitat.

Guidelines:

- Except as modified by Guidelines 2-4 below, all construction work around the unique habitat will be done using pertinent BMPs such as those described in A Guide for Environmental Protection and Best Management Practices for TVA Construction and Maintenance Activities, especially Chapter 6, "Standards and Specifications."
- 2. All construction activity in and within 30 meters (100 feet) of the unique habitat must be approved in advance by Environmental Stewardship and Policy staff, preferably as a result of an on-site planning session. The purpose of this review and approval will be to minimize impacts on the unique habitat. All crossings of streams also must comply with appropriate state (and, at times, federal) permitting requirements.
- 3. Cutting of trees within 30 meters (100 feet) of the unique habitat must be discussed in advance with Environmental Stewardship and Policy staff, preferably during the on-site planning session. Cutting of trees near the unique habitat must be kept to an absolute minimum. Stumps must not be removed, uprooted, or cut shorter than 0.30 meter (1 foot) above the ground line.
- 4. Other vegetation near the unique habitat must be disturbed as little as possible during construction. The soil must not be disturbed by plowing, disking, blading, or grading. Areas that have to be disturbed must be stabilized as soon as possible and revegetated as soon as feasible, in some cases with specific kinds of native plants. These and other vegetative requirements will be coordinated with Environmental Stewardship and Policy staff.

Additional Help

If you have questions about the purpose or application of these guidelines, please contact your supervisor or the environmental coordinator in the local Transmission Service Center.

Revision April 2007

Comparison of Guidelines Under the Three Stream and Water Body Protection Categories (page 1)

Guidelines	A: Standard	B: Important Permanent Streams	C: Unique Water Habitats
1. Reference	All TVA construction work around streams will be done using pertinent BMPs such as those described in A Guide for Environmental Protection and Best Management Practices for TVA Construction and Maintenance Activities, especially Chapter 6, BMP "Standards and Specifications."	Except as modified by guidelines 2-4 below, all construction work around streams will be done using pertinent BMPs such as those described in A Guide for Environmental Protection and Best Management Practices for TVA Construction and Maintenance Activities, especially Chapter 6, BMP "Standards and Specifications."	Except as modified by guidelines 2-4 below, all construction work around the unique habitat will be done using pertinent BMPs such as those described in A Guide for Environmental Protection and Best Management Practices for TVA Construction and Maintenance Activities, especially Chapter 6, BMP "Standards and Specifications."
2. Equipment Crossings	All crossings of streams must comply with appropriate state and federal permitting requirements. Crossings of all drainage channels, intermittent streams, and permanent streams must be done in ways that avoid erosion problems and long-term changes in water flow. Crossings of any permanent streams must allow for natural movement of fish and other aquatic life.	All crossings of streams must comply with appropriate state and federal permitting requirements. Crossings of drainage channels and intermittent streams must be done in ways that avoid erosion problems and long-term changes in water flow. Proposed crossings of permanent streams must be discussed in advance with Environmental Stewardship and Policy staff and may require an on-site planning session before any work begins. The purpose of these discussions will be to minimize the number of crossings and their impact on the important resources in the streams.	All crossings of streams also must comply with appropriate state and federal permitting requirements. All construction activity in and within 30 meters (100 feet) of the unique habitat must be approved in advance by Environmental Stewardship and Policy staff, preferably as a result of an on-site planning session. The purpose of this review and approval will be to minimize impacts on the unique habitat.

Guidelines	A: Standard	B: Important Permanent Streams	C: Unique Water Habitats
3.	Cutting of trees within SMZs must be accomplished by using either hand-held equipment or other appropriate clearing equipment (e.g., a feller-buncher) that	Cutting of trees with SMZs must be accomplished by using either hand-held equipment or other appropriate clearing equipment (e.g., a feller-buncher) that	Cutting of trees within 30 meters (100 feet) of the unique habitat must be discussed in advance with Environmental Stewardship and Policy staff, preferably during the on-site
Cutting Trees	would result in minimal soil disturbance and damage to low-lying vegetation. The method will be selected based on site-specific conditions and topography to minimize soil disturbance and impacts to the SMZ and surrounding area. Stumps can be cut close to ground level but must not be removed or uprooted.	 would result in minimal soil disturbance and damage to low-lying vegetation. The method will be selected based on site-specific conditions and topography to minimize soil disturbance and impacts to the SMZ and surrounding area. Cutting of trees near permanent streams must be limited to those meeting National Electric Safety Code and danger tree requirements. Stumps can be cut close to ground level but must not be removed or uprooted. 	planning session. Cutting of trees near the unique habitat must be kept to an absolute minimum. Stumps must not be removed, uprooted, or cut shorter than 1 foot above the ground line.
4.	Other vegetation near streams must be disturbed as little as possible during construction. Soil displacement by the actions of	Other vegetation near streams must be disturbed as little as possible during construction. Soil displacement by the actions of	Other vegetation near the unique habitat must be disturbed as little as possible during construction. The soil must not be disturbed by plowing,
Other Vegetation	plowing, disking, blading, or other tillage or grading equipment will not be allowed in SMZs; however, a minimal amount of soil disturbance may occur as a result of clearing operations. Shorelines that have to be disturbed must be stabilized as soon as feasible.	plowing, disking, blading, or other tillage or grading equipment will not be allowed in SMZs; however, a minimal amount of soil disturbance may occur as a result of clearing operations. Shorelines that have to be disturbed must be stabilized as soon as possible and revegetated as soon as feasible.	disking, blading, or grading. Areas that have to be disturbed must be stabilized as soon as possible and revegetated as soon as feasible, in some cases with specific kinds of native plants. These and other vegetative requirements will be coordinated with Environmental Stewardship and Policy staff.

Comparison of Guidelines Under the Three Stream and Water Body Protection Categories (page 2)

Page intentionally blank

APPENDIX O – STATE-LISTED ANIMAL AND PLANT SPECIES PRESENT IN AREAS AFFECTED BY TRANSMISSION LINE WORK

Page intentionally blank

	Outout Contract	Alabama	Georgia	Tennessee	
Common Name	Scientific Name	State Status, Rank	State Status, Rank	State Status, Rank	
Insects				·	
A caddisfly	Hydropsyche rotosa	RARE, S1	-	-	
A caddisfly	Hydropsyche simulans	RARE, S1	-	-	
A caddisfly	Rhyacophila alabama	POTL, S1	-	-	
A caddisfly	Rhyacophila fenestra	RARE, S1	-	_	
A glossosomatid caddisfly	Agapetus hessi	TRKD, S1	-	-	
Tennessee clubtail dragonfly	Gomphus sandrius	-	- •	TRKD, S1	
Snails		L	L		
Anthony's river snail*#	Athearnia anthonyi	PROT, S1	- "	END, S1	
Armored rocksnail*	Lithasia armigera	-	-	TRKD, S1S2	
Armored snail	Pyrgulopsis pachyta	PROT, S1	-	-	
Corpulent hornsnail*	Pleurocera corpulenta	TRKD, S1	-	TRKD, S1	
Helmet rock snail*	Lithasia duttoniana	-	-	TRKD, S2	
Ornate rocksnail*	Lithasia geniculata	-	-	TRKD, S3	
Owen spring limnephilid caddisfly	Glyphopsyche sequatchie	-	-	POTL, -	
Royal marstonia	Pyrgulopsis ogmorhaphe	-	-	END, S1	
Rugose rocksnail	Lithasia jayana	-	-	TRKD, S2	
Skirted hornsnail*	Pleurocera pyrenella	TRKD, S2	-	-	
Slabside pearlymussel	Lexingtonia dolabelloides	PROT, S1	. –	TRKD, S2	
Slender campeloma*	Campeloma decampi	PROT, S1	-	-	
Smooth mudalia*	Leptoxis virgata	-	-	TRKD, S1	
Spiny riversnail*	lo fluvialis	EXTI, SX	-	TRKD, S2	
Spiral hornsnail	Pleurocera brumbyi	TRKD, S2	-	-	
Umbilicate river snail	Leptoxis subglobosa umbilicata	-	-	TRKD, S1	
Varicose rocksnail*	Lithasia verrucosa	TRKD, S3		-	
Warty rocksnail*	Lithasia lima	HIST, SH	-	TRKD, S2	
Mussels					
Acornshell	Epioblasma haysiana	EXTI?, SH	-	-	
Alabama lampmussel#	Lampsilis virescens	PROT, S1	-	-	
Alabama moccasinshell	Medionidus acutissimus	-	THR, S1	-	
Angled riffleshell	Epioblasma biemarginata	EXTI?, SX	-	-	
Birdwing pearlymussel	Lemiox rimosus	PROT, SX	-	-	
Butterfly*	Ellipsaria lineolata	TRKD, S3	-	· _	
Cracking pearlymussel	Hemistena lata	PROT, SX	-	-	
Cumberland bean	Villosa trabalis	PROT, SX	HIST, SH	-	

Table O-1. State-Listed Aquatic Animal Species Present in Counties Affected Transmission Line Upgrades

Supplemental Environmental Impact Statement

Single Nuclear Unit at the Bellefonte Site

Common Name	Scientific Name	Alabama State Status, Rank	Georgia State Status, Rank	Tennessee State Status, Rank
Cumberland combshell	Epioblasma brevidens	PROT, S1	-	-
Cumberland moccasinshell	Medionidus conradicus	PROT, S1	-	-
Cumberland monkeyface	Quadrula intermedia	PROT, S1	-	END, S1
Cumberland pigtoe	Pleurobema gibberum	-	-	END, S1
Deertoe	Truncilla truncata	TRKD, S1	-,	-
Dromedary pearlymussel	Dromus dromas	PROT, S1	- ·	END, S1
Elktoe	Alasmidonta marginata	EXTI, SX	-'	
Fine-lined Pocketbook	Lampsilis altilis	-	THR, S2	-
Fine-rayed Pigtoe#	Fusconaia cuneolus	PROT, S1	-	-
Fluted kidneyshell	Ptychobranchus subtentum	PROT, SX		TRKD, S2S3
Hickorynut	Obovaria olivaria	EXTI, SX	-	-
Kidneyshell	Ptychobranchus fasciolaris	. TRKD, S1		-
Monkeyface*	Quadrula metanevra	TRKD, S3	-	-
Mucket*	Actinonaias ligamentina	TRKD, S2	-	- '
Narrow catspaw	Epioblasma lenior	EXTI?, SX	-	· -
Ohio pigtoe	Pleurobema cordatum	TRKD, S2	-	-
Orange-foot Pimpleback	Plethobasus cooperianus	PROT, S1	-	END, S1
Painted creekshell	Villosa taeniata	TRKD, S3	-	
Pale lilliput#	Toxolasma cylindrellus	PROT, S1	-	END, S1
Pheasantshell	Actinonaias pectorosa	TRKD, S1	-	-
Pink mucket*#	Lampsilis abrupta	PROT, S1	. –	END, S2
Pink papershell*	Potamilus ohiensis	TRKD, S3	-	-
Purple lilliput	Toxolasma lividus	TRKD, S2	-	-
Rabbitsfoot	Quadrula cylindrica cylindrica	PROT, S1	-	TRKD, S3
Rainbow	Villosa iris	TRKD, S3	-	-
Ring pink	Obovaria retusa	PROT, S1	-	-
Rough pigtoe*	Pleurobema plenum	PROT, S1	. –	END, S1
Round hickorynut	Obovaria subrotunda	TRKD, S2	-	TRKD, S3
Sheepnose	Plethobasus cyphyus	PROT, S1		-
Shiny pigtoe pearlymussel#	Fusconaia cor	PROT, S1	-	-
Slabside pearlymussel*	Lexingtonia dolabelloides	PROT, S1	-	TRKD, S1
Slippershell mussel	Alasmidonta viridis	PROT, S1	_	-
Snuffbox	Epioblasma triquetra	TRKD, S1		-
Southern pigtoe	Pleurobema georgianum	-	END, S1	-
Spectaclecase	Cumberlandia monodonta	PROT, S1	-	TRKD, S2S3
Spike	Elliptio dilatata	TRKD, S1	-	-

A-324

i.

Final Supplemental Environmental Impact Statement

Appendix O

Common Name	Scientific Name	Alabama State Status, Rank	Georgia State Status, Rank	Tennessee State Status, Rank
Tan riffleshell	Epioblasma florentina walkeri	PROT, SX	-	END, S1
Tennessee clubshell	Pleurobema oviforme	TRKD, S1	-	TRKD, S2S3
Tennessee heelsplitter	Lasmigona holstonia	TRKD, S1S2	-	TRKD, S2
Tennessee pigtoe*	Fusconaia barnesiana	TRKD, S1	-	-
Tuberculed blossom pearlymussel	Epioblasma torulosa torulosa	PROT, SX		EXTI, SX
Turgid blossom pearlymussel	Epioblasma turgidula	-	-	EXTI, SX
Wavy-rayed Lampmussel	Lampsilis fasciola	TRKD, S1S2	-	-
White heelsplitter	Lasmigona complanata	TRKD, S2S3	-	. -
Crayfish				
A troglobitic crayfish*	Cambarus veitchorum	TRKD, S1	-	-
Chickamauga crayfish	Cambarus extraneus	-	-	THR, S1;S2
Troglobitic crayfish*	Cambarus jonesi	SPCO, S2	-	-
Troglobitic crayfish	Procambarus pecki	TRKD, S2?	-	-
Fish	•	•	•	
Ashy darter	Etheostoma cinereum	-	TRKD, S1	THR, S2S3
Barrens darter	Etheostoma forbesi	-	-	END, S1
Barrens topminnow	Fundulus julisia	-	-	END, S1
Bedrock shiner	Notropis rupestris	-	-	NMGT, S2
Bigeye chub	Hybopsis amblops	TRKD, S3	RARE, S1S2	-
Blotched chub	Erimystax insignis	TRKD, S2	-	-
Blotchside logperch	Percina burtoni	TRKD, S1		NMGT, S2
Bluebreast darter	Etheostoma camurum	TRKD, S1	-	-
Blueside darter	Etheostoma jessiae	TRKD, S3	-	-
Boulder darter	Etheostoma wapiti	PROT, S1	-	-
Chestnut lamprey	Ichthyomyzon castaneus	TRKD, S2	-	-
Coppercheek darter	Etheostoma aquali	-	-	THR, S2S3
Dusky darter	Percina sciera	-	RARE, S1	-
Fantail darter	Etheostoma flabellare	TRKD, S3	-	-
Flame chub	Hemitremia flammea	TRKD, S3	END, S1	NMGT, S3
Gilt darter	Percina evides	TRKD, S2	-	-
Golden darter	Etheostoma denoncourti	-	_	NMGT, S2
Highfin carpsucker	Carpiodes velifer		-	NMGT, S2S3
Longhead darter	Percina macrocephala	- ·	-	THR, S2
Mountain madtom	Noturus eleutherus	TRKD, S1	-	-
Northern studfish	Fundulus catenatus	-	THR, S1	-
Ohio lamprey	Ichthyomyzon bdellium	-	RARE, S3?	-
Paddlefish	Polyodon spathula	PROT, S3	-	-

Supplemental Environmental Impact Statement

!

Single Nuclear Unit at the Bellefonte Site

Common Name	Scientific Name	Alabama State Status, Rank	Georgia State Status, Rank	Tennessee State Status, Rank
Palezone shiner#	Notropis albizonatus	PROT, S1	-	
Popeye shiner	Notropis ariommus	-	THR, S1	-
Redband darter	Etheostoma luteovinctum	-	-	NMGT, S4
Redline darter	Etheostoma rufilineatum	TRKD, S3	_	-
River carpsucker	Carpiodes carpio	TRKD, S2	-	_
River darter	Percina shumardi	TRKD, S3	-	-
Rosyface shiner	Notropis micropteryx	TRKD, S2	-	-
Saddled madtom	Noturus fasciatus	-	-	THR, S2
Silver redhorse	Moxostoma anisurum	TRKD, S2	-	-
Silver shiner	Notropis photogenis	TRKD, S1	-	-
Slackwater darter	Etheostoma boschungi	PROT, S1	-	-
Slender madtom	Noturus exilis	TRKD, S3	-	-
Slenderhead darter	Percina phoxocephala	-	-	NMGT, S3
Snail darter	Percina tanasi	-	THR, S1	THR, S2S3
Snubnose darter	Etheostoma simoterum	TRKD, S3	-	-
Southern cavefish	Typhlichthys subterraneus	PROT, S3	RARE, S1	NMGT, S3
Southern redbelly dace	Phoxinus erythrogaster	TRKD, S3	-	-
Spotfin chub	Cyprinella monacha	. –	EXTI, SH	-
Spring pygmy sunfish	Elassoma alabamae	PROT, S1	-	-
Stargazing minnow	Phenacobius uranops	TRKD, S1	THR, S1	-
Stonecat	Noturus flavus	TRKD, S1	-	-
Striated darter	Etheostoma striatulum	-		THR, S1
Stripetail darter	Etheostoma kennicotti	TRKD, S3	-	
Tennessee dace	Phoxinus tennesseensis	-	-	NMGT, S3
Tuscumbia darter	Etheostoma tuscumbia	PROT, S2		-
Yellowfin madtom	Noturus flavipinnis	-	EXTI, SH	-

Species that are known to occur in watersheds directly affected by construction activities are indicated by (*). Species reported from Jackson County, Alabama are indicated by (#)

Status Codes: **THR** = Threatened; **TRKD** = Tracked by state Natural Heritage program; **RARE** = Listed Rare by the state; **NMGT** = In Need of Management; **PROT** = State Protected; **SPCO** = Listed Special Concern; **EXTI** = Listed Extirpated or Extinct

State Ranks: S1 = Critically Imperiled; S2 = Imperiled; S3 = Vulnerable; SH = Historic; ? = Inexact or Uncertain; SX = Presumed Extirpated

Table O-2. State-Listed Terrestrial Plant Species Known From Within a 5-Mile Vicinity of the Transmission Line Upgrades

ŀ

		Alabama	Georgia	Tennessee
Common Name	Scientific Name	State Status (Rank)	State Status (Rank)	State Status (Rank)
Chalk Maple	Acer leucoderme	-	-	SPCO(S3)
Sweetflag	Acorus calamus	SLNS(S1)	-	-
Yellow Giant-hyssop ¹	Agastache nepetoides	SLNS(S1)	SPCO(S1)	-
Roundleaf Serviceberry	Amelanchier sanguinea	THR(S2)	-	· _ ·
Price's Potato-bean	Apios priceana	SLNS(S2)	-	END(S2)
Spreading Rockcress	Arabis patens	-	-	END(S1)
American Spikenard	Aralia racemosa	SLNS(S1)	-	-
Bradley's Spleenwort	Asplenium bradleyi	SLNS(S2)	-	· _
Wall-rue Spleenwort	Asplenium ruta-muraria	SLNS(S2)		-
American Hart's-tongue	Asplenium scolopendrium	1		
Fern ²	var. americanum	SLNS(S1)	-	END(S1)
Maidenhair Spleenwort	Asplenium trichomanes	SLNS(S2S3)		-
Spreading False-foxglove	Aureolaria patula		_	SPCO(S3)
Nuttall's Rayless Golden- rod	Bigelowia nuttallii	SLNS(S3)	-	-
Mountain Bitter Cress	Cardamine clematitis		_	THR(S2)
Sedge	Carex hirtifolia	-	-	SPCO(S1S2)
Sedge	Carex purpurifera	SLNS(S2)	-	
Alabama Lipfern	Cheilanthes alabamensis	SLNS(S3)	-	_
Pink Turtlehead	Chelone Iyonii	SLNS(S1)	· _	-
Yellowwood	Cladrastis kentukea	SLNS(S3)	_	_
Leather-flower	Clematis glaucophylla	-	_	END(S1)
Morefield's Leather-flower ²	Clematis morefieldii	SLNS(S1)	_	
Wister Coral-root	Corallorhiza wisteriana	SLNS(S2)		_
Woodland Tickseed	Coreopsis pulchra	SLNS(S2)	-	_
American Smoke-tree	Cotinus obovatus	SLNS(S2)	_	SPCO(S2)
Harper's Dodder	Cuscuta harperi	SLNS(S2)	_	-
Pink Lady-slipper	Cypripedium acaule	SLNS(S3)	·_ ·	S-CE(S4)
Large Yellow Lady's-slipper	Cypripedium pubescens	SLNS(S3)	_	
Tennessee Bladderfern	Cystopteris tennesseensis	SLNS(S2)		
Leafy Prairie-clover ²	Dalea foliosa	SLNS(S1)		END(S2S3)
Bog Oat-grass	Danthonia epilis	-	_	SPCO(S1S2)
Tall Larkspur	Delphinium exaltatum	· · · ·	-	END(S2)
Dwarf Larkspur ¹	Delphinium tricorne	-	SPCO(S2?)	
Small's Stonecrop ¹	Diamorpha smallii	SLNS(S3)	-	END(S1S2)
American Beakgrain	Diarrhena americana	SLNS(S2)	-	
Dutchman's Breeches ¹	Dicentra cucullaria	SLNS(S2)	-	
	Dichanthelium acuminatum		-	
Panic-grass	ssp leucothrix	-	-	SPCO(S1)
Northern Bush-honeysuckle	Diervilla lonicera		-	THR(S2)
Mountain Bush-honeysuckle	Diervilla sessilifolia var. rivularis	-	-	THR(S2)
Spotted Mandarin	Disporum maculatum	SLNS(S1)	-	
Wolf Spikerush	Eleocharis wolfii	<u> </u>	-	END(S1)
Common Horsetail	Equisetum arvense	SLNS(S2)	-	-
Wahoo	Euonymus atropurpureus	SLNS(S3)	-	- ·
Creeping Aster	Eurybia surculosa	SLNS(S1)	-	-

Supplemental Environmental Impact Statement

A-327

Single Nuclear Unit at the Bellefonte Site

		Alabama	Georgia State	Tennessee
Common Name	Scientific Name	State Status	Status	State Status
		(Rank)	(Rank)	(Rank)
American Columbo ¹	Frasera caroliniensis	SLNS(S2)	-	-
Fragrant Bedstraw	Galium uniflorum	- ``	-	SPCO(S1)
Dwarf Huckleberry	Gaylussacia dumosa	· -	-	THR(S3)
Yellow Jessamine	Gelsemium sempervirens	-	-	SPCO(S1S2)
Pale Avens	Geum virginianum	SLNS(S1)	-	-
Manna-grass	Glyceria acutiflora	-	-	SPCO(S2)
Florida Hedge-hyssop	Gratiola floridana	-	-	END(S1)
Carolina Silverbell	Halesia carolina	SLNS(S2)	-	-
Eggert's:Sunflower	Helianthus eggertii	-	-	SPCO(S3)
White-leaved Sunflower	Helianthus glaucophyllus	SLNS(SH)	-	-
Featherfoil	Hottonia inflata	-	-	SPCO(S2)
Goldenseal	Hydrastis canadensis	SLNS(S2)	-	S-CE(S3)
Creeping St. John's-wort	Hypericum adpressum	-	-	END(S1)
Barrens St. Johnswort ¹	Hypericum sphaerocarpum	-	SPCO(S1)	-
Narrow Blue Flag	Iris prismatica			THR(S2S3)
Butler's Quillwort	Isoetes butleri	SLNS(S2)	-	-
Appalachian Quillwort	Isoetes engelmannii	SLNS(S3)	-	-
Small Whorled Pogonia	Isotria medeoloides	-	=	END(S1)
Large Whorled Pogonia	Isotria verticillata	SLNS(S2)	-	-
Twinleaf	Jeffersonia diphylla	SLNS(S2)		· -
Butternut	Juglans cinerea	-	-	THR(S3)
Fleshy-fruit Gladecress ²	Leavenworthia crassa	SLNS(S1)	-	-
Glade Cress	Leavenworthia exigua var. exigua	-	THR(S2)	SPCO(S3)
Michaux Leavenworthia	Leavenworthia uniflora	SLNS(S2)	_	
Slender Blazing-star	Liatris cylindracea	0LN0(02)	-	THR(S2)
Canada Lily	Lilium canadense			THR(S2)
Michigan Lily	Lilium michiganense	-		THR(S3)
Wood Lily	Lilium philadelphicum			END(S1)
Mountain Honeysuckle	Lonicera dioica	-		SPCO(S2)
Yellow Honeysuckle	Lonicera flava	_		THR(S1)
Fraser Loosestrife	Lysimachia fraseri	-		END(S2)
Mohr's Barbara's Buttons	Marshallia mohrii	_	THR(S2)	
Broadleaf Barbara's-buttons	Marshallia trinervia		-	THR(S2S3)
Broadleaf Bunchflower	Melanthium latifolium	-	_	END(S1S2)
False Helleborne	Melanthium parviflorum	SLNS(S1S2)		
American Pinesap	Monotropa hypopithys	SLNS(S2)		
Nestronia	Nestronia umbellula			END(S1)
Alabama Snow-wreath	Neviusia alabamensis	SLNS(S2)		
Hairy False Gromwell	Onosmodium hispidissimum	3LN3(32)		END(S1)
One-flowered Broomrape	Orobanche uniflora	SLNS(S2)	· · · · · · · · · · · · · · · · · · ·	
Great Yellow Wood-sorrel	Oxalis grandis	SLNS(S1)	-	-
American Ginseng	Panax quinquefolius		<u> </u>	- S-CE(S3S4)
Large-leaved Grass-of-	Parnassia grandifolia	-		SPCO(S3)
parnassus Mankau face Orchid			• • • • • • • • • • • • • • • • • • • •	
Monkey-face Orchid	Platanthera integrilabia	SLNS(S2)	-	END(S2S3)
Greek Valerian	Polemonium reptans	-	SPCO(S1)	-
Tennessee Leafcup	Polymnia laevigata	SLNS(S2S3)	-	-
Carolina Rhododendron	Rhododendron minus	SLNS(S2)	-	-

A-328

Final Supplemental Environmental Impact Statement

Common Name	Scientific Name	Alabama State Status (Rank)	Georgia State Status (Rank)	Tennessee State Status (Rank)
Granite Gooseberry	Ribes curvatum	SLNS(S2)	-	THR(S1)
Prickly Gooseberry	Ribes cynosbati	SLNS(S1S2)	-	-
Rose-gentian ¹	Sabatia capitata	END(S2)	-	-
Gibbous Panic-grass	Sacciolepis striata	SPCO(S1)	·-	-
Pussy Willow	Salix humilis	SLNS(S2S3)	-	-
Green Pitcher Plant ²	Sarracenia oreophila	SLNS(S2)	-	-
Sunnybell	Schoenolirion croceum	SLNS(S2)	-	-
Large-flowered Skullcap ¹	Scutellaria montana	THR(S2)	THR(S2)	-
Chaffseed ²	Schwalbea americana	-	-	E-P(SX)
Nevius' Stonecrop	Sedum nevii	SLNS(S3)	-	END(S1)
Ovate Catchfly	Silene ovata	END(S2)	-	-
Cumberland Rosinweed	Silphium brachiatum	SLNS(S2)	-	-
Compass-plant	Silphium laciniatum	THR(S2)	_	-
Bog Goldenrod	Solidago uliginosa	SLNS(SH)	-	-
Virginia Spiraea	Spiraea virginiana	END(S2)	THR(S1)	-
Great Plains Ladies'-tresses	Spiranthes magnicamporum	-	END(S1)	SPCO(S1)
Mountain Camellia	Stewartia ovata	SLNS(S2S3)	-	-
Southern Morning-glory	.Stylisma humistrata	-	-	THR(S1)
Smooth Blue Aster	Symphyotrichum laeve var. concinnum	SLNS(S1)	-	-
Limestone Fame-flower	Talinum calcaricum	-	-	SPCO(S3)
Fame-flower ¹	Talinum mengesii		-	THR(S2)
Appalachian Bristle Fern	Trichomanes boschianum		-	THR(S1S2)
Lance-leaf Trillium	Trillium lancifolium		-	END(S1)
Southern Red Trillium	Trillium`sulcatum	SLNS(S1)	-	-
Horse-gentian	Triosteum angustifolium	SLNS(S1)	-	-
Canada Violet	Viola canadensis	SLNS(S2)	-	-
Eggleston's Violet ¹	Viola egglestonii	-	SPCO(S2)	-
Three-parted Violet	Viola tripartita var. tripartita	-	-	SPCO(S2S3)
Virginia Chainfern	Woodwardia virginica	. – .	-	SPCO(S2)
Death-camas	Zigadenus leimanthoides	-	-	THR(S2)

Status Codes: END = Endangered; E-P = Endangered – Possibly Extirpated; THR = Threatened; RARE = Rare; SLNS = Listed by the state of Alabama, but not assigned a status; SPCO = Special Concern; S-CE = Special Concern-Commercially Exploited

Rank Codes: **S1** = Extremely rare and critically imperiled in the state with 5 or fewer occurrences, or very few remaining individuals, or because of some special condition where the species is particularly vulnerable to extirpation; $\mathbf{S2}$ = Very rare and imperiled within the state, 6 to 20 occurrences; $\mathbf{S3}$ = Rare or uncommon with 21 to 100 occurrences; $\mathbf{S4}$ = Apparently secure; \mathbf{SX} = Presumed extirpated; $\mathbf{S45}$ = Denotes a range of ranks because the exact rarity of the element is uncertain (e.g., S1S2); **?** = Denotes uncertainty in exact rarity of the element.

Table O-3. State-Listed Terrestrial Animal Species Reported From Jackson,
Limestone, and Morgan Counties, Alabama; Dade, Catoosa, and Walker
Counties, Georgia; and Bedford, Coffee, Hamilton, Marion, and
Sequatchie Counties, Tennessee

Ocquatome	Counties, rennessee			1
Common Name	Scientific Name	Alabama State Status (Rank)	Georgia State Status (Rank)	Tennessee State Status (Rank)
Amphibians				
Barking treefrog	Hyla gratiosa	. -	-	NMGT ¹ (S3) ²
Green salamander	Aneides aeneus	PROT (S3)	RARE (S2)	
Hellbender	Cryptobranchus alleganiensis	PROT (S2)	RARE (S2)	NMGT (S3)
Tennessee cave salamander	Gyrinophilus palleucus	PROT (S2)	TRKD(S1)	THR (S2)
Reptiles	·	-		L
Eastern milk snake	Lampropeltis triangulum triangulum	TRKD (S2)	TRKD (S2)	-
Birds		· · · · · · · · · · · · · · · · · · ·		
Bachman's sparrow	Aimophila aestivalis	TRKD (S3)	RARE(S3)	END (S2)
Bald eagle	Haliaeetus Ieucocephalus	PROT (S3)		NMGT (S3)
Cerulean warbler	Dendroica cerulea	TRKD(S1)	TRKD(S3)	NMGT (S3)
Osprey	Pandion haliaetus	PROT (S5)	-	-
Peregrine falcon	Falco peregrinus	PROT(SH)	END (S1)	END(S1)
Red-cockaded woodpecker	Picoides borealis	PROT (S2)	END (S2)	-
Swainson's warbler	Limnothlypis swainsonii	TRKD (S3)	TRKD (S3)	NMGT (S3)
Mammals			• • • • • • • • • • • • • • • • • • • •	······································
Allegheny woodrat	Neotoma magister	TRKD (S3)	-	NMGT (S3)
Common shrew	Sorex cinereus	-	TRKD(S2)	NMGT (S4)
Eastern big-eared bat	Corynorhinus rafinesquii	PROT(S2)	RARE(S3)	NMGT (S3)
Eastern small-footed bat	Myotis leibii	TRKD(S1)	TRKD(S2)	NMGT (S2S3)
Gray bat	Myotis grisescens	PROT (S2)	END (S1)	END (S2)
Indiana bat	Myotis sodalis	PROT (S2)	END (S1)	END (S1)
Invertebrates		,		
Beetle	Batriasymmodes spelaeus	-	-	TRKD (S3)
Blowing cave beetle	Pseudanophthalmus ventus	-	-	TRKD (S1)
Nickajack cave beetle	Pseudanophthalmus nickajackensis	-	-	TRKD (S1)
Duck River cave beetle	Pseudanophthalmus tullahoma	-	-	TRKD (S1)
Nickajack cave isopod	Caecidotea nickajackensis	-	-	TRKD (S1)
Spider, a cave-obligate	Nesticus barri	TRKD (S3)	-	-
	ered: THR = Threatened: TRK		i koto Natural Llarii	

State status: **END** = Endangered; **THR** = Threatened; **TRKD** = Tracked by state Natural Heritage program; **RARE** = Listed Rare by the state; **NMGT** = In Need of Management; **PROT** = State Protected

²State ranks: **S1** - critically imperiled; **S2** - imperiled; **S3** - rare or uncommon; **S4** - widespread, abundant and apparently secure; and **S5** - demonstrably widespread, abundant, and secure. **SH**=of historical occurrence, i.e., known to occur in the past, with the expectation that it may be rediscovered.

Final Supplemental Environmental Impact Statement

Class Definitions and Associated Polygon Colors of Sensitive Areas for Right-of-Way Reclearing Sensitive Area Reviews

Terrestri	ial Plants	s (A), Terrestrial Animals (D), a	and Aquatic Animals (E)	
Class		tion if Sensitive area in ROW	Restriction for Sensitive Areas Potentially Affected when <u>Accessing</u> ROW	Polygon Color
.1	the thre Hand of Reques Heritage habitat subject	adcast spraying. Use one of e following alternatives: 1) r mechanical clearing, 2) it field surveys by TVA e staff to determine if suitable for these species exists in the area, 3) Selective spraying of les to shrubs or tree saplings	Not Applicable	Yellow
		in 12 feet in height.		
2	equipm	learing only. Vehicles and ent restricted from area unless d to existing access road.	Vehicles and equipment restricted from area unless confined to existing access road.	Red
0		circumstance.		Green
Wetland				
-	Pole Re	placement Guidelines" for restrie		Blue Outline
1 ·.	interpre features	tation of topographic features, w s. Refer to "Wetlands ROW and	Heritage wetland biologists based on ater bodies, soil surveys and proximity to NWI Pole Replacement Guidelines" for restrictions.	Pink Outline
Natural /				
Class	Call**	Definition		Color
1	No	Same as Class 1 definition abo		Yellow
2	No	Same as Class 2 definition abo		Red
1	Yes	entering or conducting mainten		Yellow hatching
2	Yes	entering or conducting mainten		Red hatching
3	Yes	Must contact area manager p subject area.	prior to entering or conducting maintenance in	Neon Green
none		Special circumstance.		Green
Archaeo			· · · · · · · · · · · · · · · · · · ·	
Class	Restric	tion if Sensitive area in ROW	Restriction for Sensitive Areas Potentially	Color
4	BA		Affected when Accessing ROW	
1	conduct firm. If be kept ground clearing	nical clearing must be ted when the ground is dry and bulldozer is used, blade must above ground surface to avoid disturbance. Material from g (timber, brush, and large must be removed from	Vehicles and equipment must be confined to existing access road.	Yellow
2 ι	sensitiv		All vehicles must be low-pressured tire	Red
۷ ۴	clearing but not clearing	a only (chainsaws may be used heavy equipment). Debris from must be hand-carried out of e area.	All vehicles must be low-pressured tire equipment and must be confined to existing access road.	

* Refer to Wetlands Statement included in this package.
** The "Call" column on the accompanying datasheets is used by Natural Area specialists only. A blank in the column indicates no call is necessary.

Class Definitions and Associated Polygon Colors of Sensitive Areas for POLE REPLACEMENT Sensitive Area Reviews

All Reso	ources Areas (Plants, Natural Areas, Wetlands, Terrestrial Animals, and Aquatic Anima	als)
Class	Restriction	Color
1	 Botany: Sensitive Botanical resources are known from the area. Details of proposed activities should be submitted to TVA Heritage staff to determine if the proposed activities require restrictions. Natural Areas: Refer to table accompanying project for restrictions. Wetlands: Potential wetlands identified by Natural Heritage wetland biologists based on interpretation of topographic features, water bodies, soil surveys and proximity to NWI features. Refer to "Wetlands ROW and Pole Replacement Guidelines" for restrictions. Terrestrial Animals: Refer to table accompanying project for restrictions. 	Pink
Wetland		
-	Wetlands obtained from National Wetland Inventory data. Refer to "Wetlands ROW and Pole Replacement Guidelines" for restrictions.	Blue Outline
Archaed	ology	Color
Class	Restriction	
1	Presence of significant below-ground cultural resources is highly likely. Work must be scheduled when ground is dry and firm. Only vehicles with low-pressured tires may be used within sensitive area. If structure is a pole, new poles must be placed in existing holes; if structure is a tower, existing footings must be used for new tower. If guy wires are used, existing guy wire anchors must be used for new structure. If any of these conditions cannot be met, then details of proposed activities (nature of work, date work is to take place) must be submitted to TVA Cultural Resources staff so that a field review can be scheduled.	Yellow
2	Presence of significant cultural resources is known. Work schedule must be submitted to TVA Cultural Resources staff so that a field review can be scheduled.	Red