



| | | | | | |
|--|-----------------------------|--|-----------------------------|---|------------|
| TENNESSEE VALLEY AUTHORITY | | EXAMINATION SUMMARY AND RESOLUTION SHEET | | REPORT NUMBER: R-P0107 | |
| PROJECT: WBN UNIT: 2 CYCLE 00 | | | COMPONENT ID: RCW-01 | | |
| EXAMINATION METHOD | | | SYSTEM: RCS | ISI DWG NO: ISI-2068-W-02 <i>Rev 0</i> | |
| MT <input type="checkbox"/> | PT <input type="checkbox"/> | UT <input checked="" type="checkbox"/> | VT <input type="checkbox"/> | CONFIGURATION: | CATEGORY |
| PROCEDURE: N-UT-64 | | REV 11 | TC: N/A | BRCN TO P | B-J |
| EXAMINER: JASON NISSEN | | EXAMINER: N/A | | EXAMINER: N/A | |
| LEVEL: II | | LEVEL: N/A | | LEVEL: N/A | |
| <p>Total coverage calculated to be approximately 48.1 %</p> <p>An Ultrasonic examination was performed to meet the preservice requirements of ASME Section XI.</p> <p>A 45° shear and 60° refracted longitudinal wave was calibrated and used for this examination.</p> <p>The examination was limited due to branch connection configuration.</p> <p>No indications were observed recordable.</p> <p>48.1% examination volume coverage achieved.</p> | | | | | |
| RESOLUTION BY: JASON NISSEN <i>[Signature]</i> | | REVIEWED BY: <i>[Signature]</i> | | ANI: W | |
| LEVEL II DATE: 12/11/08 | | LEVEL: III DATE: 12/23/08 | | DATE: 2/4/09 | |
| | | | | Page: 1 OF 6 | |

TENNESSEE VALLEY
AUTHORITY


DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER

R-P0107

PROJECT WBN UNIT/CYCLE 2100
 PROCEDURE: N-UT-64 REV: 11 TC: N/A
 MANUFAC KBA MODEL: COMP G
 # ELEMENTS: 1 SHAPE: ROUND
 S/N 00W40H SIZE: .375 * FREQ: 2.25 MHz
 CONTOUR: N/A FOCUS: N/A
 CABLE TYPE RG-174 LENGTH: 6 # CNT: N/A
 MODE: SHEAR LONG RL

CALIBRATION DATE: 12/10/08
 CALIBRATION BLOCK NO. WB 83 TEMP: 76 °F
 SIMULATOR BLOCK: ROMPAS
 THERMOMETER S/N: 562773 DUE DATE: 06/20/09
 COUPLANT: ULTRAGEL II BATCH: 06225F
 ANGLE VERIFICATION
 BLOCK TYPE ROMPAS S/N: 790390
 NOMINAL ANGLE: 45° ACTUAL ANGLE 44°
 INSTRUMENT
 MANUFACTURER: KRAUTKRAMER DUE DATE: 08/18/09
 MODEL NO.: USN-60 S/N: E37690



| REFLECTOR | | | REFERENCE SENSITIVITY | MEMORY NUMBER |
|-------------------------------|-------------------------------------|--|-----------------------|---------------|
| SCAN DIRECT. | NTC | SDH | | |
| AXIAL | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 25.8 dB | 45 225 |
| CIRC. | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 25.8 dB | 45 225 |
| RANGE: <u>5.000</u> inches | | * FREQ: <u>2.25</u> MHz | | |
| PROBE DELA <u>5.0238</u> msec | | * RECTIFY: <u>FULLWAVE</u> | | |
| VELOCITY <u>0.1225</u> msec | | DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF | | |
| DISP DELAY: <u>0.000</u> | | * REJECT: <u>0</u> % | | |
| * ENERGY: <u>HIGH</u> | | * DISP. START: <u>TP</u> | | |
| * DAMPING: <u>1K</u> ohms | | DET: <input type="checkbox"/> Peak <input checked="" type="checkbox"/> Flank | | |
| * PRR/PRF: <u>AUTOHIGH</u> | | TCG: <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF | | |
| ANGLE: <u>44</u> deg | | * PULSER: <u>SINGLE</u> | | |
| ZERO: <u>N/A</u> msec | | | | |

REF. REFLECTOR: ROMPAS SDH GAIN: 39.6 dB
 AMPLITUDE: 80 % METAL PATH: 1.026"
 VERIFICATION TIMES 1) N/A 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

CALIBRATION TIMES
 INITIAL TIME: 1322 FINAL TIME: 1530

*PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

| VERTICAL | SIGNAL 1 | | 100 | 90 | 80 | 70 | 60 | 50 | 40 | 30 | 20 | |
|------------|----------|-----|----------|----|----------|----|-----|----|----------|----|-----|----------|
| | SIGNAL 2 | | 50 | 45 | 40 | 35 | 30 | 25 | 20 | 15 | 10 | |
| ATTENUATOR | GAIN | SET | -6 dB | | -12dB | | SET | | +12 | | SET | +6 |
| | AMP | 80% | 32 TO 48 | | 16 TO 24 | | 20% | | 64 TO 96 | | 40% | 64 TO 96 |
| | | | 40 | | 20 | | | | 80 | | | 80 |

| COMMENTS | WELD / ITEMS EXAMINED |
|---|-----------------------|
| * 4" nominal diameter of pipe The branch connection diameter is \approx 1.5" therefore .375" transducer was utilized | RCW-01 |
| Verification check 1417 and 1431 | |

EXAMINER: JASON NISSEN LVL: II
 EXAMINER: Jose Alejandro LVL: II
 REVIEWER: _____ LVL: III DATE: 12/23/09
 ANII: JD
 DATE: 2/4/09
 PAGE 2 OF 6

TENNESSEE VALLEY
AUTHORITY

DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER


R-P0107

PROJECT WBN UNIT/CYCLE 2100
PROCEDURE: N-UT-64 REV: 11 TC: N/A

MANUFAC: RTD TRANSDUCER MODEL: TRLA
ELEMENTS: 2 SHAPE: RECTANGLE
S/N 95-853 SIZE: 2.68x1.4 FREQ: 2.0 MHz
CONTOUR: N/A FOCUS: N/A
CABLE TYPE RG-174 LENGTH: 6 # CNT: N/A

MODE: SHEAR LONG RL

DAC



DISPLAY WIDTH 8.000 inches

CALIBRATION DATE: 12/16/08
CALIBRATION BLOCK NO. WB 83 TEMP: 76 °F
SIMULATOR BLOCK: ROMPAS

THERMOMETER S/N: 562773 DUE DATE: 06/20/09
COUPLANT: ULTRAGEL II BATCH: 06225F

ANGLE VERIFICATION
BLOCK TYPE ROMPAS S/N: 790390
NOMINAL ANGLE: 60 RL ACTUAL ANGLE 60 RL
INSTRUMENT

MANUFACTURER: KRAUTKRAMER DUE DATE: 08/18/09
MODEL NO.: USN-60 S/N: E37690

| REFLECTOR | | | REFERENCE SENSITIVITY | MEMORY NUMBER |
|--------------|-------------------------------------|--------------------------|-----------------------|---------------|
| SCAN DIRECT. | NTC | SDH | | |
| AXIAL | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <u>57.4</u> dB | <u>95-853</u> |
| CIRC. | <input type="checkbox"/> | <input type="checkbox"/> | <u>N/A</u> dB | <u>N/A</u> |

RANGE: 8.000 inches *FREQ: 2.0 MHz
PROBE DELA 1.4754 msec *RECTIFY: FULLWAVE
VELOCITY 2329 msec DUAL ON OFF
DISP DELAY: 0.000 *REJECT: 0 %
*ENERGY: HIGH *DISP. START: IP
*DAMPING: 1k ohms DET: Peak Flank
*PRR/PRF: AUTOHIGH TCG: ON OFF
ANGLE: 60 RL deg *PULSER: DUAL
ZERO: N/A msec

CALIBRATION TIMES

REF. REFLECTOR: ROMPAS SDH GAIN: 59 dB
AMPLITUDE: 50 % METAL PATH: 1.386

INITIAL TIME: 1337 FINAL TIME: 1533

VERIFICATION TIMES 1) N/A 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

*PDI QUALIFIED INSTRUMENT SETTINGS:

VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

| VERTICAL | SIGNALS | | | | | | | | | | |
|------------|----------|-----|----------|----------|-----|----------|-----|----------|----|----|--|
| | SIGNAL 1 | 100 | 90 | 80 | 70 | 60 | 50 | 40 | 30 | 20 | |
| | SIGNAL 2 | 50 | 45 | 40 | 35 | 30 | 25 | 20 | 15 | 10 | |
| ATTENUATOR | GAIN | SET | -6 dB | -12dB | SET | +12 | SET | +6 | | | |
| | AMP | 80% | 32 TO 48 | 16 TO 24 | 20% | 64 TO 96 | 40% | 64 TO 96 | | | |
| | | | 40 | 20 | | 80 | | 80 | | | |

COMMENTS

WELD / ITEMS EXAMINED

*verification check 1417 and 1431

RCW-01

EXAMINER: JASON NUSSEN LVL: II

ANII: JD

EXAMINER: Jose Alejandra LVL: II

DATE: 2/4/09

REVIEWER: [Signature] LVL: III DATE: 12/23/08

PAGE 3 OF 6

TENNESSEE VALLEY
AUTHORITY

MANUAL ULTRASONIC
PIPING EXAMINATION
DATA SHEET

REPORT NUMBER

R-PO107

PROJECT: WBN UNIT/CYCLE 2100

EXAMINATION DATE 12/10/08

SYSTEM: RCS

START TIME: 1418 END TIME: 1430

WELD I.D.: RCW-02 ^{SP} 12/11/08 RCW-01

EXAM SURFACE ID OD

CONFIG.: BRCN TO P

MATERIAL TYPE: CS SS CSCL CCSS

FLOW →

SURFACE TEMP.: 74.5 PYRO NO. 562773

PROCEDURE: N-UT-64 REV: 11 TC: N/A

EXAMINATION ANGLE 45 DEG. 60 RL DEG.

W₀ REFERENCE: EDGE OF BOSS

AXIAL SCAN SENSITIVITY 50 dB 72 dB

L₀ REFERENCE: UPSTREAM inline Main run PIPE

CIRC. SCAN SENSITIVITY 50 dB N/A dB

| IND NO. | L (in) FROM REF. | | | AT MAX AMP | | | MAX AMP % DAC | EXAM NO. 3-14 | NOM. ANG. | NRI | INDICATION INFORMATION: TYPE, DAMPING, ETC. |
|---------|------------------|-------|----|------------|--------|-------|---------------|---------------|-----------|-------------------------------------|---|
| | L1 | L Max | L2 | W MAX | MP MAX | D MAX | | | | | |
| | | | | | | | | 3 | 60° RL | <input checked="" type="checkbox"/> | |
| | | | | | | | | 3 | 45° | <input checked="" type="checkbox"/> | |
| | | | | | | | | 5 | 45° | <input checked="" type="checkbox"/> | |
| | | | | | | | | 6 | 45° | <input checked="" type="checkbox"/> | |
| | | | | | | | | | | <input type="checkbox"/> | |
| | | | | | | | | | | <input type="checkbox"/> | |

REMARKS/LIMITATIONS

EXAM LIMITED DUE TO BRANCH CONNECTION CONFIGURATION. NO EXAM SCANS FROM MAIN RUN OF PIPE. MAINTAINED 5% - 20% TO ROLL.

EXAMINER: JASON NISSEN Jordan LEVEL: II

ANII: JD

EXAMINER: Jose Alejandro Juarez LEVEL: II

DATE: 2/4/09

REVIEWED BY: [Signature] LEVEL: III DATE: 12/23/08

PAGE 4 OF 6

TVA

WALL THICKNESS
PROFILE SHEET

REPORT NO:


R-P0107

PROJECT: WBN
UNIT: 2


WELD NO: RCW-01
SYSTEM: RCS

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

| Position | 0° | 90° | 180° | 270° |
|----------|-------|-------|-------|-------|
| 1 | | | | |
| 2 | | | | |
| 3 | 2.0" | 1.85" | 2.1" | 2.0" |
| 4 | 2.0" | 2.0" | 1.97" | 1.99" |
| 5 | 1.96" | 2.0" | 2.1" | 2.0" |



CROWN HEIGHT: FLUSH DIAMETER: 4"
CROWN WIDTH: 2.0" WELD LENGTH: 40"



* 90°, 180° and 270° SIMILAR PROFILE

EXAMINER: JASON NISSEN
LEVEL: II
DATE: 10-08-08

REVIEWED BY: [Signature]
LEVEL: LTS DATE: 12/23/08

ANII: [Signature]
DATE: 2/4/09
PAGE: 5 OF 6

TVA

Office of Nuclear Power

PROJECT: WBN


SYSTEM: RCS

REPORT NO.:

UNIT: 2

WELD NO: RCW-01

R-P0107



BY: Jason Nissen

LEVEL: II

DATE: 12/11/08

PAGE

6 OF 6

| | | |
|---|--|--|
| NPG Nondestructive Examination Procedure | CALCULATION OF ASME CODE COVERAGE FOR SECTION XI, APPENDIX VIII ULTRASONIC EXAMINATIONS | N-GP-31 Rev. 0002 Page 16 of 24 |
|---|--|--|

Attachment 4
(Page 1 of 1)



AUSTENITIC PIPING WELDS SINGLE SIDE ACCESS - SUPPLEMENT 2

Required and obtained examination volume coverage work sheet

Below is a typical example of examination coverage plots although are not to be considered inclusive of all situations.

Typical example of a single sided access examination of an austenitic piping weld, examination credit can not be taken beyond the weld centerline when the beam is directed through the weld material. Although examinations are required to be performed with the ultrasonic beam directed through the weld material, however they can not be considered totally effective or creditable.

Note: Typically a one-sided austenitic weld examination with no circumferential restrictions would be indicated as 75% examination coverage or 50% if circumferential scans were limited to one side.



Weld # RCW-01 W = 1.36" H = .65" L = 40"

| Item | Description | Value |
|------------------------------------|---|--------------|
| REQUIRED EXAMINATION VOLUME | | |
| 1 | Required examination volume in sq in. (width x height) for single scan stroke | .884 |
| 2 | Number of scan directions (normally 4; i.e. upst,dnst, cw, & ccw)) | 4 |
| 3 | Total scan volume in sq inches (Item 1 * Item 2) | 3.54 |
| 4 | Total length of weld | 40 |
| 5 | Total required examination volume in cubic inches (Item 3 * Item 4) | 141.44 |
| OBTAINED EXAMINATION VOLUME | | |
| 6 | Examination volume achieved (sq in for single scan stroke) in 1 axial scanning direction (i.e. upst) multiplied by the length of weld examined | 0 |
| 7 | Examination volume achieved (sq in for single scan stroke) in 1 axial scanning direction (i.e. dnst) multiplied by the length of weld examined | 25.2 |
| 8 | Examination volume achieved (sq in for single scan stroke) in 1 circumferential scanning direction (i.e. cw) multiplied by the length of weld examined | 19.6 |
| 9 | Examination volume achieved (sq in for single scan stroke) in 1 circumferential scanning direction (i.e. ccw) multiplied by the length of weld examined | 19.6 |
| 10 | Determine the achieved examination volume by adding Items 6, 7, 8, and 9 | 64.4 |
| 11 | Examination volume percentage [(Item 10 / item 5) X 100] | (.455) = 46% |

INFORMATION ONLY