

TENNESSEE VALLEY AUTHORITY	EXAMINATION SUMMARY AND RESOLUTION SHEET	REPORT NUMBER: <i>R. P. 0226</i>
-------------------------------	--	---

PROJECT: <i>WBN</i> UNIT: <i>2</i> CYCLE <i>00</i>	COMPONENT ID: <i>RCF-D145-08</i>
--	----------------------------------

EXAMINATION METHOD	SYSTEM: <i>RCS</i> ISI DWG NO: <i>ISI-2068-W-05</i> <i>Rev. 0</i>
--------------------	---

MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CONFIGURATION:	CATEGORY
-----------------------------	-----------------------------	--	-----------------------------	----------------	----------

PROCEDURE: <i>N-UT-64</i>	REV <i>11</i>	TC: <i>N/A</i>	VLV TO EL	<i>B-J</i>
---------------------------	---------------	----------------	-----------	------------

EXAMINER: <i>Jose Alejandro</i> LEVEL: <i>II</i>	EXAMINER: <i>N</i> LEVEL: <i>A</i>	EXAMINER: <i>N</i> LEVEL: <i>A</i>	EXAMINER: <i>N</i> LEVEL: <i>A</i>
--	--	--	--

Total coverage calculated to be approximately 50 %

An ultrasonic examination was performed to meet the requirements of ASME Section XI preservice inspection.

A 45° shear wave and a 60° ^{JH0509-01} refracted longitudinal wave were calibrated and used for this examination.

Examination was limited due to valve geometry. Examination was performed from the elbow side.

No recordable indications observed.

50% examination volume coverage achieved.

RESOLUTION BY: <i>Jose Alejandro</i> LEVEL: <i>II</i> DATE: <i>03-09-09</i>	REVIEWED BY: <i>Darlene Duesey</i> LEVEL: <i>III</i> DATE: <i>3-10-09</i>	ANII: <i>[Signature]</i> DATE: <i>3/10/09</i> Page: <i>1</i> OF <i>6</i>
---	---	--

**TENNESSEE VALLEY
AUTHORITY**

**DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET**

REPORT NUMBER


R-P0226

PROJECT WBN UNIT/CYCLE 2100
PROCEDURE: N-UT-64 REV: 11 TC: N/A

TRANSDUCER
MANUFAC RTD MODEL: TRL2
ELEMENTS: 2 SHAPE: Rectangle
S/N 95-853 SIZE: 2(8x14) FREQ: 2.0 MHz
CONTOUR: N/A FOCUS: N/A
CABLE TYPE RG174 LENGTH: 72.0 # CNT: N/A

MODE: SHEAR LONG RL

DAC



A
M
P
L
I
T
U
D
E

CALIBRATION DATE: 03-09-09
CALIBRATION BLOCK NO. WB83 TEMP: 72.9 °F
SIMULATOR BLOCK: Rompas
THERMOMETER S/N: 558271 DUE DATE: 06-24-09
COUPLANT: Ultra Gel II BATCH: 07225E

ANGLE VERIFICATION
BLOCK TYPE Rompas S/N: 790390
NOMINAL ANGLE: 60RL ACTUAL ANGLE 60RL

INSTRUMENT
MANUFACTURER: KrautKramer DUE DATE: 06-23-09
MODEL NO.: USN 60 S/N: E36304

REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH		
AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	66.5 dB	60RL-4.in
CIRC.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	66.5 dB	60RL-4.in

RANGE: 4.0 inches *FREQ: 2.25 MHz
PROBE DELA 8.1322 msec *RECTIFY: Fullwave
VELOCITY 0.2295 msec DUAL ON OFF
DISP DELAY: 0.00 *REJECT: 0 %
*ENERGY: High *DISP. START: IF
*DAMPING: 1k ohms DET: Peak Flank
*PRR/PRF: Auto High TCG: ON OFF
ANGLE: 60RL deg *PULSER: Dual
ZERO: N/A msec

REF. REFLECTOR: Rompas Radius GAIN: 39.5 dB
AMPLITUDE: 50 % METAL PATH: 1.065

CALIBRATION TIMES
INITIAL TIME: 0921 FINAL TIME: 1251

VERIFICATION TIMES 1) 1055 2) 1100 3) 1146 4) 1151 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

***PDI QUALIFIED INSTRUMENT SETTINGS:**
VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL									
	SIGNAL 1	100	90	80	70	60	50	40	30	20
	SIGNAL 2	50	45	40	35	30	25	20	15	10
ATTENUATOR	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
			40	20		80		80		

COMMENTS

WELD / ITEMS EXAMINED

RCF-D145-05C
RCF-D145-08

EXAMINER: José Alejandro de la Cruz LVL.: II

ANII: J. J. 2/16/09

EXAMINER: Eddie Reed LVL.: I

DATE: 3/16/09

REVIEWER: Darlene Dudley LVL.: III DATE: 3/16/09

PAGE 2 OF 4

TENNESSEE VALLEY
AUTHORITY

DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER

R. P0226

PROJECT WBN UNIT/CYCLE 21 00
PROCEDURE: N-UT-64 REV: 11 TC: N/A

CALIBRATION DATE: 03-09-09
CALIBRATION BLOCK NO. WB 83 TEMP: 72.9 °F
SIMULATOR BLOCK: Rompas

TRANSDUCER
MANUFAC KBA MODEL: COMP-G
ELEMENTS: 1 SHAPE: Round
S/N 00DPPM SIZE: .250 FREQ: 2.25 MHz
CONTOUR: N/A FOCUS: N/A
CABLE TYPE RG-174 LENGTH: 72.0 # CNT: N/A


THERMOMETER S/N: 558271 DUE DATE: 06-24-09
COUPLANT: Ultra Gel II BATCH: 07225 E
ANGLE VERIFICATION

BLOCK TYPE Rompas S/N: 790390
NOMINAL ANGLE: 45° ACTUAL ANGLE 45°

MODE: SHEAR LONG RL

INSTRUMENT
MANUFACTURER: Krautkramer DUE DATE: 06-23-09
MODEL NO.: USN 60 S/N: E36304

DAC



A
M
P
L
I
T
U
D
E

DISPLAY WIDTH 2.5 inches

REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH		
AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	36.4 dB	45° 4in-SS
CIRC.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	36.4 dB	45° 4in-SS

RANGE: 2.5 inches * FREQ: 2.25 MHz
PROBE DELA 4.7150 msec * RECTIFY: Full WAVE
VELOCITY 0.1309 msec DUAL ON OFF
DISP DELAY: 0.00 * REJECT: 0 %
* ENERGY: High * DISP. START: IP
* DAMPING: 1k ohms DET: Peak Flank
* PRR/PRF: Auto High TCG: ON OFF
ANGLE: 45 deg * PULSER: Single
ZERO: 0 msec

REF. REFLECTOR: Rompas SDH GAIN: 44.2 dB
AMPLITUDE: 50 % METAL PATH: 1.066

CALIBRATION TIMES

INITIAL TIME: 0930 FINAL TIME: 1255
VERIFICATION TIMES 1) 1027 2) 1035 3) 1111 4) 1143 5) 1152 6) 1202 7) N/A 8) N/A 9) N/A

*PDI QUALIFIED INSTRUMENT SETTINGS:

VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL									
	SIGNAL 1	100	90	80	70	60	50	40	30	20
	SIGNAL 2	50	45	40	35	30	25	20	15	10
ATTENUATOR	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
			40	20		80		80		

COMMENTS

WELD / ITEMS EXAMINED

RCF-D145-08
RCF-D145-05C
RCF-D145-05
RCF-D145-04
RCF-D145-02B

EXAMINER: Jose Alejandro Quijano LVL.: II

ANII: J. Quijano

EXAMINER: Ellie Reed LVL.: I

DATE: 3/16/09

REVIEWER: Daiane Duley LVL.: UT DATE: 3-10-09

PAGE 3 OF 6

TENNESSEE VALLEY
AUTHORITY

MANUAL ULTRASONIC
PIPING EXAMINATION
DATA SHEET

REPORT NUMBER

R-P0026

PROJECT: WBN UNIT/CYCLE 2100

SYSTEM: RCS

WELD I.D.: RCF-D145-08

CONFIG.: VLV TO EL

FLOW 

PROCEDURE: N-UT-64 REV: 11 TC: N/A

W₀ REFERENCE: E of weld

L₀ REFERENCE: TDC

EXAMINATION DATE 03-09-09

START TIME: 1153 END TIME: 1201

EXAM SURFACE ID OD

MATERIAL TYPE: CS SS CSCL CCSS

SURFACE TEMP.: 70.6 PYRO NO. 558271

EXAMINATION ANGLE 45 DEG. 60RL DEG.

AXIAL SCAN SENSITIVITY 44.3 dB 59.5 dB

CIRC. SCAN SENSITIVITY 47.3 dB N/A dB

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP % DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	D MAX					
								4	45°	<input checked="" type="checkbox"/>	
								5	45°	<input checked="" type="checkbox"/>	
								6	45°	<input checked="" type="checkbox"/>	
								4	60RL	<input checked="" type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

REMARKS/LIMITATIONS No exam scans up stream side due to valve. Examination scans from elbow side maintaining 5-20% ID roll was performed. Scanned across the weld up to valve taper.

EXAMINER: Jose Alejandro M. Lopez LEVEL: II

EXAMINER: Ellie Rev. E. Rev. E. Rev. E. LEVEL: I

REVIEWED BY: Doreen Duley LEVEL: III DATE: 3-10-09

ANII: J. Lopez

DATE: 3/10/09

PAGE 4 OF 6

TVA

**WALL THICKNESS
PROFILE SHEET**

REPORT NO:


R-P0326

PROJECT: WATS BAR NUCLEAR
UNIT: 2


WELD NO: RCF-D145-08
SYSTEM: 068 (RCS)

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	*	*	*	*
2	*	*	*	*
3	.572	.526	.544	.519
4	.543	.543	.551	.667
5	.602	.539	.576	.649



CROWN HEIGHT: FLUSH DIAMETER: 4 INCH
CROWN WIDTH: .750 INCH WELD LENGTH: 14.5 INCH



* - NO READINGS TAKEN ON VALVE SIDE

EXAMINER: Jose Alejandro Juel
LEVEL: II
DATE: 03-03-09

REVIEWED BY: De la Cruz
LEVEL: IV DATE: 3-10-09

ANII: [Signature]
DATE: 3/10/09
PAGE 5 OF 6

TVA

Office of Nuclear Power

PROJECT: WBN SYSTEM: RCS


UNIT: 2 WELD NO: RCF-D145-08

REPORT NO.:

R-P0226

ELBOW

VALVE



BY: Jose Alejandro [Signature] LEVEL: II DATE: 03-03-09 PAGE 6 OF 6

NPG Nondestructive Examination Procedure	CALCULATION OF ASME CODE COVERAGE FOR SECTION XI, APPENDIX VIII ULTRASONIC EXAMINATIONS	N-GP-31 Rev. 0002 Page 16 of 24
---	--	--

Attachment 4
(Page 1 of 1)



AUSTENITIC PIPING WELDS SINGLE SIDE ACCESS - SUPPLEMENT 2

Required and obtained examination volume coverage work sheet

Below is a typical example of examination coverage plots although are not to be considered inclusive of all situations.

Typical example of a single sided access examination of an austenitic piping weld, examination credit can not be taken beyond the weld centerline when the beam is directed through the weld material. Although examinations are required to be performed with the ultrasonic beam directed through the weld material, however they can not be considered totally effective or creditable.

Note: Typically a one-sided austenitic weld examination with no circumferential restrictions would be indicated as 75% examination coverage or 50% if circumferential scans were limited to one side.



Weld # RCF-D145-08

W = 1.3 H = .2

L = 14.5

Item	Description	Value
REQUIRED EXAMINATION VOLUME		
1	Required examination volume in sq in. (width x height) for single scan stroke	.26
2	Number of scan directions (normally 4; i.e. upst, dnst, cw, & ccw))	4
3	Total scan volume in sq inches (Item 1 * Item 2)	1.04
4	Total length of weld	14.5
5	Total required examination volume in cubic inches (Item 3 * Item 4)	15.08
OBTAINED EXAMINATION VOLUME		
6	Examination volume achieved (sq in for single scan stroke) in 1 axial scanning direction (i.e. upst) multiplied by the length of weld examined	Ø
7	Examination volume achieved (sq in for single scan stroke) in 1 axial scanning direction (i.e. dnst) multiplied by the length of weld examined	3.77
8	Examination volume achieved (sq in for single scan stroke) in 1 circumferential scanning direction (i.e. cw) multiplied by the length of weld examined	1.885
9	Examination volume achieved (sq in for single scan stroke) in 1 circumferential scanning direction (i.e. ccw) multiplied by the length of weld examined	1.885
10	Determine the achieved examination volume by adding Items 6, 7, 8, and 9	7.54
11	Examination volume percentage [(Item 10 / item 5) X 100]	(.50) = 50%

JA

INFORMATION ONLY