

TENNESSEE VALLEY AUTHORITY	EXAMINATION SUMMARY AND RESOLUTION SHEET	REPORT NUMBER: R-PO370
-------------------------------	--	----------------------------------

PROJECT: WBN UNIT: 2 CYCLE 00		COMPONENT ID: SIF-D199-06	
EXAMINATION METHOD		SYSTEM: SIS	ISI DWG NO: ISI-2063-W-08^{REV 2}
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>
PROCEDURE: N-UT-84		REV 0	TC: NA
		CONFIGURATION: VLV TO TEE	CATEGORY: B-J

EXAMINER: <i>Jason Nissen</i>	EXAMINER: <i>N</i>	EXAMINER: <i>N</i>	EXAMINER: <i>N</i>
<i>Jason Nissen</i>	<i>A</i>	<i>A</i>	<i>A</i>
LEVEL: II	LEVEL: A	LEVEL: A	LEVEL: A

Total coverage calculated to be approximately **74.6%**

A single sided phased array ultrasonic examination was performed to meet the requirements of ASME Section XI preservice inspection.

A phased array 1.5 MHz, 16 element probe with a 25°-70° shear wave sector scan display was utilized to perform the examination

A phased array 1.5 MHz, dual 15 element probe with a 40°-70 refracted longitudinal wave sector scan display was also utilized to perform the examination

74.6% examination volume achieved due to Valve.

A recordable indication was observed due to weld root geometry. Seen at varying amplitude 360° around the weld.

RESOLUTION BY: <i>Jason Nissen</i>	REVIEWED BY: <i>Darlene DeLong</i>	ANII: <i>[Signature]</i>
LEVEL: II DATE: 5-21-08	LEVEL: II DATE: 5-29-09	DATE: 6/8/09
		Page: 1 OF 2

TENNESSEE VALLEY AUTHORITY		PHASED ARRAY ULTRASONIC CALIBRATION DATA SHEET				REPORT NUMBER: R.P0370					
PROJECT: WBN UNIT 2		CYCLE: 0		CALIBRATION DATE: 5-21-09							
PROC.: N-WT-84		REV: 0		TC: N/A		CALIBRATION BLOCK NO.: WB-83 TEMP: 73.6F					
INSTR. MFG: GEIT		DUE DATE: 8-6-09		SIMULATOR BLOCK NO: N/A							
MODEL/TYPE: PHASOR XS M & TE ID: E41821		THERMOMETER S/N: 562773						DUE DATE: 6-20-09			
SOFTWARE REVISION: 1.2		COUPLANT: Ultragel II						BATCH: 06225 F			
EXAM TYPE: SHEAR <input checked="" type="checkbox"/> LONG <input type="checkbox"/> RL <input type="checkbox"/>		EXAM: ISI <input type="checkbox"/> PSI <input checked="" type="checkbox"/>		LIMITATIONS: Y <input checked="" type="checkbox"/> N <input type="checkbox"/>							
CABLE TYPE: 1D		LENGTH: 2M		#CNT: 0							
ANGLE VERIFICATION											
BLOCK TYPE: ROMPAS		S/N: 790390		NOMINAL ANGLE			ACTUAL ANGLE				
REFLECTOR				LOW: 25° HIGH: 70°			LOW: 25° HIGH: 70°				
SCAN DIRECTION		NOTCH DEPTH	SDH. DEPTH		REF. SENS/AMPL	ANGLE / METAL PATH		EXAM SENS.			
AXIAL		1.500	N / A		4.0 / 80%	50° / 2.366		25.0			
CIRCUMFERENTIAL		1.500	N / A		4.0 / 80%	50° / 2.366		30.0			
INSTRUMENT SETTINGS											
GAIN TOGGLE:		dBd: 0	dBA: 25.0		SCAN DATA						
PROBE DATA				ELECTRONIC			SCAN PATTERN				
PROBE MFG: GEIT		MODEL: 115-000-441		TYPE: Sector		ANGLE START: 25°					
S/N: 01RLFK		APERTURE SIZE: .630		FOCAL POINT: Unfocused		ANGLE STOP: 70°					
ELEMENTS: 16		PITCH: .040		WAVE TYPE: Shear		ANGLE STEP: 1°					
FREQ: 1.5		ELEVATION: .472		RL FOCAL LAW: N/A							
CONFIGURATION: ARRAY		SHAPE: RECTANGLE		LEG: 1.0		MATERIAL THICKNESS: 1.00					
WEDGE DATA				APERTURE							
PROBE CHECK: <input checked="" type="checkbox"/> PRE-EXAM		<input checked="" type="checkbox"/> POST EXAM		NUMBER OF STEPS: 1		FIRST ELEMENT: 1					
WEDGE MFG: GEIT		VELOCITY: .0920		APERTURE SIZE: 16		APERTURE STEP: 1					
MODEL: 360-141-161		X OFFSET: .827		DISPLAY DATA		ANGLE CORRECTION		<input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF			
WEDGE ANGLE: 38°		Z OFFSET: .512		UT DATA							
CONTOUR: FLAT		ELEMENT 1 POSITION: END		BASE		PULSER	RECIEVER	NRM/TCG			
MATERIAL: STAINLESS STEEL		VELOCITY: .1220		DELAY: 0.0	VOLT: 150	FREQ: 880.6-6.5	CYC GAIN CNTL				
CALIBRATION TIMES				WIDTH: 330		ASCAN RECT:		0.0			
INITIAL TIME: 0825		FINAL TIME: 1135		MATERIAL: STAINLESS STEEL		PRF VALUE: Fullwave					
VERF. TIMES	1000	1040	N / A / N / A		AH						
LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB		-12 dB		SET	+12		SET	+6
	AMP	80	32-48		16-24		20	64-96		40	64-96
			40		20		80		80		
COMMENTS:					WELDS/ITEMS EXAMINED: SEF-D199-05						
					SEF-D199-06						
EXAMINER:		EXAMINER: N		REVIEWER:		ANII:		DATE: 6/8/09			
LEVEL: II		LEVEL: A		LEVEL: III		DATE: 5-29-09		PG. 2 OF 7			

PROJECT: WBN UNIT 2	CYCLE: Ø	CALIBRATION DATE: 5-21-08 ^{JPN} 5-21-09
PROC.: N-WT-84 REV: Ø	TC: N/A	CALIBRATION BLOCK NO.: WB 83 TEMP: 73.6°F
INSTR. MFG: GEIT	DUE DATE: 8-6-09	SIMULATOR BLOCK NO.: N/A
MODEL/TYPE: PHASOR XSM & TE ID: E41821	THERMOMETER S/N: 562773 DUE DATE: 6-20-09	
SOFTWARE REVISION: 1.2	COUPLANT Ultragel II BATCH: 06225F	
EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>	EXAM: ISI <input type="checkbox"/> PSI <input checked="" type="checkbox"/>	LIMITATIONS: Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
CABLE TYPE: 2 D LENGTH: 2 M #CNT: Ø		

ANGLE VERIFICATION					
BLOCK TYPE: ROMPAS	S/N: 790390	NOMINAL ANGLE		ACTUAL ANGLE	
REFLECTOR			LOW: 40°	HIGH: 70°	LOW: 40° HIGH: 70°
SCAN DIRECTION	NOTCH DEPTH	SDH. DEPTH	REF. SENS/AMPL	ANGLE / METAL PATH	EXAM SENS.
AXIAL	1.500	N / A	22.0 dB / 80%	50° / 2363	28.0 dB
CIRCUMFERENTIAL	N / A	N / A	N/A	N/A	N / A




INSTRUMENT SETTINGS					
GAIN TOGGLE: dBD: Ø	dBA: 28.0	SCAN DATA			
PROBE DATA			<u>ELECTRONIC</u>	<u>SCAN PATTERN</u>	
PROBE MFG: GEIT	MODEL: 115-000-481	TYPE: Sector	ANGLE START: 40°		
S/N: 01TCT6	APERTURE SIZE: .748	FOCAL POINT: 1.000	ANGLE STOP: 70°		
ELEMENTS: 2 (3x5)	PITCH: 4 x .150	WAVE TYPE: Longitudinal	ANGLE STEP: 1°		
FREQ: 1.5	ELEVATION: 2 x .472	RL FOCAL LAW: D07F100			
CONFIGURATION: ARRAY	SHAPE: RECTANGLE	LEG: 1.2	MATERIAL THICKNESS: 1.000		

WEDGE DATA			APERTURE		
PROBE CHECK: <input checked="" type="checkbox"/> PRE-EXAM	<input checked="" type="checkbox"/> POST EXAM				
WEDGE MFG: GEIT	VELOCITY: .0920	NUMBER OF STEPS: 1	FIRST ELEMENT: 1		
MODEL: 360-151-028	X OFFSET: .591	APERTURE SIZE: 10	APERTURE STEP: 1		
WEDGE ANGLE: 18°	Z OFFSET: .472	DISPLAY DATA	ANGLE CORRECTION	<input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF	
CONTOUR: FLAT	ELEMENT 1 POSITION: LOW END	UT DATA			

PART DATA		<u>BASE</u>	<u>PULSER</u>	<u>RECIEVER</u>	<u>NRM/TCG</u>
MATERIAL: Custom	VELOCITY: .2283	DELAY: 0.0	VOLT: 150	FREQ: 0.6-6.5	CYC GAIN CNTL: 0.0
CALIBRATION TIMES		WIDTH: 330		ASCAN RECT:	
INITIAL TIME: 0840	FINAL TIME: 1140	MATERIAL: Custom	PRF VALUE: AH	Fullwave	
VERF. TIMES	1013 / 1104 / N / A / N / A				

LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32-48	16-24	20	64-96	40	64-96			
			40	20		80		80			

COMMENTS:	WELDS/ITEMS EXAMINED:
	SIF - D199-05
	SIF - D199-06
	SIF - D197-03

EXAMINER: 	EXAMINER: N	REVIEWER: 	ANII: 
LEVEL: II	LEVEL: A	LEVEL: III	DATE: 6/19/09
		DATE: 5-29-09	PG. OF 3 7

TENNESSEE VALLEY
AUTHORITY

MANUAL ULTRASONIC
PIPING EXAMINATION
DATA SHEET

REPORT NUMBER

R. P0370

PROJECT: WBN UNIT/CYCLE 2100

EXAMINATION DATE 5-21-09

SYSTEM: SIS

START TIME: 1034 END TIME: 1056

WELD I.D.: SIF-D199-06

EXAM SURFACE ID OD

CONFIG.: VLV TO TEE

MATERIAL TYPE: CS SS CSCL CCSS

FLOW →

SURFACE TEMP.: 81.3 PYRO NO. 562773

PROCEDURE: N-UT-84 REV: Ø TC: N/A

EXAMINATION ANGLE 25/70 DEG. 40/70 RL DEG.

W_o REFERENCE: WELD 4

AXIAL SCAN SENSITIVITY 35/70 25.0dB 28.0 dB

L_o REFERENCE: TDC

CIRC. SCAN SENSITIVITY 25/70 30.0dB N/A dB

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP % DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	D MAX					
1	+1.0"	-1.0"	-3.0"	+ .85	1.705	1.080	130%	4	50°*	<input type="checkbox"/>	RL Probe / Root Geometry
								4	35°/70°	<input checked="" type="checkbox"/>	
								5	25°/70°	<input checked="" type="checkbox"/>	
								6	25°/70°	<input checked="" type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

REMARKS/LIMITATIONS Examination scans performed maintaining 5-20% ID ROLL. Exam was one sided due to valve.

* 50° Angle displayed the maximum amplitude with in the 40°/70° RL ARRAY.

EXAMINER: [Signature] LEVEL: II
 EXAMINER: N/A LEVEL: N/A
 REVIEWED BY: [Signature] LEVEL: III DATE: 5-22-09

ANII: [Signature]
 DATE: 6/1/09
 PAGE 4 OF 7

TVA

**WALL THICKNESS
PROFILE SHEET**

REPORT NO:

R.00370

PROJECT: WATTS BAR NUCLEAR


WELD NO: SIF-D199-06

UNIT: 2

SYSTEM: SIS

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	NA	NA	NA	NA
2	1.25	1.43	1.18	1.44
3	1.21	1.18	1.16	1.14
4	1.08	1.05	1.04	1.04
5	1.27	1.22	1.15	1.19



CROWN HEIGHT: Flush

DIAMETER: 10.0


CROWN WIDTH: .875

WELD LENGTH: 35.50

TEE SIDE

← FLOW

VALVE SIDE



EXAMINER:

John Alexander

REVIEWED BY:

Debra Deady

ANII:

J. M. M. Jr.

LEVEL:

II

LEVEL:

III

DATE:

5/20/09

DATE:

6/18/09

DATE:

05-18-09

PAGE

5 OF 7

TVA

Office of Nuclear Power

PROJECT: WBN

SYSTEM: SIS


REPORT NO.:

UNIT: 2

WELD NO: SIF-D199-06

R. Posto

Tee



Indication #1 is a reflector from the weld root. This reflector can be seen intermittently around the weld at lower amplitudes

BY: [Signature]

LEVEL: II

DATE: 5-28-09

PAGE 6 OF 7

TVA

Office of Nuclear Power


PROJECT: WATTS BAR NUCLEAR SYSTEM: SIS

UNIT: 2

WELD NO: SIF-D199-06

REPORT NO.:

R.00370



Plot shown represent primary angle of 45°, phased array angles used 25°-70°, RL angles used 40°-70°

BY: Jose Alejandro [Signature] LEVEL: II DATE: 05-18-09 PAGE 7 OF 7

TVA Procedure
N-GP-31

WEID # SIF-D199-06

Attachment 3

Item 1	Required examination Volume in sq. in. (width x height)	1.4	0.45	0.63
Item 2	Number of scan directions			4
Item 3	Total Scan volume in sq. in.			2.52
Item 4	Total length of weld			35.5
Item 5	Total required exam volume in cubic inches			89.46
Item 6	Exam volume achieved (sq. in.) in direction 1 X length of weld achieved	0	35.5	0
Item 7	Exam volume achieved (sq. in.) in direction 2 X length of weld achieved	0.62	35.5	22.01
Item 8	Exam volume achieved (sq. in.) in direction 3 X length of weld achieved	0.63	35.5	22.365
Item 9	Exam volume achieved (sq. in.) in direction 4 X length of weld achieved	0.63	35.5	22.365
Item 10	Determined the achivied exam volume add 6, 7, 8 & 9			66.74
Item 11	Exam volume percentage item 10/item 5 x 100			74.60317

One sized due to value

INFORMATION ONLY

John M. II

5-21-09