

OHara, Timothy

From: Giles, Edley [Edley.Giles@pseg.com]
Sent: Monday, May 24, 2010 5:15 PM
To: OHara, Timothy
Cc: Colville, Kerry A.; Berrick, Howard G.
Subject: RE: Salem ISI Program Dates

Requested information;

(1) Beginning and ending dates for Salem Unit 1 second interval?
2/27/1988 - 5/19/2001

(2) Beginning and ending dates for Salem Unit 2 second interval?
5/10/1992 - 11/27/2003

(3) Which periods within the Salem Unit 1 second interval were the IWA-5244 tests missed? Also, can you provide the dates of each period within the interval?

Unit 1 2nd Interval period dates

1st Period [2/27/1988 - 4/26/1991] Outages 1R8 (3/28/1989 - 6/18/1989) & 1R9 (2/2/1991 - 4/26/1991) No IWA-5422 testing on buried piping performed

2nd Period [4/27/1991 - 4/17/1998] Outages 1R10 (4/4/1992 - 8/17/1992), 1R11 (10/2/1993 - 2/2/1994) & 1R12 (4/7/1995 - 4/17/1998)* No IWA-5422 testing on buried piping performed**

3rd Period [4/18/1998 - 5/19/2001] Outages 1R13 (9/17/1999 - 10/26/1999) & 1R14 (4/6/2001 - 5/19/2001) No IWA-5422 testing on buried piping performed

***** extended shutdown**

(4) Which periods within the Salem Unit 2 second interval were the IWA-5244 tests missed? Also, can you provide the dates of each period within the interval?

Unit 2 2nd Interval period dates

1st Period [5/10/1992 - 5/10/1995] Outages 2R7 (3/17/1993 - 7/3/1993) & 2R8 (10/15/1994 - 2/16/1995) No IWA-5422 testing on buried piping performed

2nd Period [5/11/1995 - 11/15/2000] Outages 2R9 (6/8/1995 - 8/29/1997)*, 2R10 (4/3/1999 - 5/28/1999) & 2R11 (10/6/2000 - 11/15/2000) No IWA-5422 testing on buried piping performed**

3rd Period [11/16/2000 - 11/27/2003] Outages 2R12 (4/5/2002 - 5/17/2002) & 2R13 (10/9/2003 - 11/27/2003) No IWA-5422 testing on buried piping performed

***** extended shutdown**

(5) Were the required tests performed on Unit 2 during the first interval?

***Yes; The ten-year hydro Pressure Drop Test technique used on Unit 1 during the 1st Interval was also used for Unit 2 1st interval ten-year hydro, Have Pressure Test datasheet dated 3/9/1992 for Line to 22SG only (*have not found datasheet for line to 24SG yet).**

***Have not found evidence that the required periodic pressure test were performed during the 1st intervals 1st and 2nd periods as required by 74' edition 75' summer addenda, IWA-5440, IWD-2400 & IWD-2600(b), still looking.**

(6) What are the interval and period dates for interval 3? Have the tests been missed for interval 3 for Salem Unit 1 or 2?

3rd Intervals

Unit 1 5/19/2001 - 5/19/2011

1st Period [5/19/2001 - 6/3/2004] Outages 1R15 (10/10/2002 - 11/06/2002) & 1R16 (3/26/2004 - 6/3/2004) No IWA-5422 testing on buried piping performed

Information in this record was deleted in
accordance with the Freedom of Information Act.
Exemptions: FOIA(b)(7)(D)
FOIA(b)(7)(D) 2010-0334

F-8

2nd Period [6/4/2004 – 5/20/2008] Outages 1R17 (10/11/2005 – 11/6/2005) & 1R18 (3/27/2007 – 4/20/2007) No IWA-5422 testing on buried piping performed
3rd Period [5/21/2008 – 5/19/2011] Outages 1R19 (10/14/2008 – 11/11/2008) & 1R20 (4/3/2010 – 4/23/2010) Pressure test on buried piping during replacement activities 1R20

Unit 2 11/27/2003 – 11/27/2013

1st Period [11/27/2003 – 11/26/2006] Outages 2R14 (5/4/2005 – 5/11/2005) & 2R15 (10/10/2006 – 11/1/2006) No IWA-5422 testing on buried piping performed

2nd Period [11/27/2006 – 11/26/2010] Outages 2R16 (3/11/2008 – 5/8/2008) & 2R17 (10/13/2009 – 11/11/2009) No IWA-5422 testing on buried piping performed YET!

3rd Period [11/27/2010 – 11/27/2013] Outages 2R18 (scheduled spring 2011) & 2R19 (scheduled fall 2012)

Regards,
Tim Giles

From: OHara, Timothy [mailto:Timothy.OHara@nrc.gov]
Sent: Monday, May 24, 2010 2:19 PM
To: Giles, Edley
Cc: Colville, Kerry A.; Berrick, Howard G.
Subject: Salem ISI Program Dates

Hello Tim,

Can you please provide the following information:

- (1) Beginning and ending dates for Salem Unit 1 second interval?
- (2) Beginning and ending dates for Salem Unit 2 second interval?
- (3) Which periods within the Salem Unit 1 second interval were the IWA-5244 tests missed? Also, can you provide the dates of each period within the interval?
- (4) Which periods within the Salem Unit 2 second interval were the IWA-5244 tests missed? Also, can you provide the dates of each period within the interval?
- (5) Were the required tests performed on Unit 2 during the first interval?
- (6) What are the interval and period dates for interval 3? Have the tests been missed for interval 3 for Salem Unit 1 or 2?

A reply via email is fine. If a phone call would be better let me know and we can do that also. Thanks.

Tim OHara

20459686

1111

copyright