

DiabloCanyonNPEm Resource

From: Ferrer, Nathaniel
Sent: Friday, October 22, 2010 9:02 AM
To: Grebel, Terence
Cc: DiabloCanyonNPEm Resource
Subject: Draft Telecon Summary for Septmeber 30, 2010
Attachments: Telecon Summary 09-30-10 Scoping and Screening.doc

Terry & Philippe,

Attached is a draft of the Teleconference Call Summary for the September 30, 2010, conference call. Please review and let me know if there are any corrections/changes needed.

Please let me know if you have any questions.

Nathaniel Ferrer
Project Manager
Division of License Renewal
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
(301)415-1045

Hearing Identifier: DiabloCanyon_LicenseRenewal_NonPublic
Email Number: 2014

Mail Envelope Properties (26E42474DB238C408C94990815A02F091362B7C339)

Subject: Draft Telecon Summary for Septmeber 30, 2010
Sent Date: 10/22/2010 9:02:01 AM
Received Date: 10/22/2010 9:02:04 AM
From: Ferrer, Nathaniel

Created By: Nathaniel.Ferrer@nrc.gov

Recipients:

"DiabloCanyonNPEm Resource" <DiabloCanyonNPEm.Resource@nrc.gov>
Tracking Status: None
"Grebel, Terence" <TLG1@PGE.COM>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	437	10/22/2010 9:02:04 AM
Telecon Summary 09-30-10 Scoping and Screening.doc		80378

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

LICENSEE: Pacific Gas and Electric Company

FACILITY: Diablo Canyon Nuclear Power Plant, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
SEPTEMBER 30, 2010, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND PACIFIC GAS AND ELECTRIC COMPANY CONCERNING
REQUEST FOR ADDITIONAL INFORMATION RELATED TO THE DIABLO
CANYON NUCLEAR POWER PLANT, UNITS 1 AND 2, LICENSE RENEWAL
APPLICATION – SCOPING AND SCREENING

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Pacific Gas and Electric Company (PG&E) held a telephone conference call on September 30, 2010, to obtain clarification on the staff's request for additional information (DRAI) regarding the Diablo Canyon Nuclear Power Plant license renewal application (LRA).

By letters dated July 20 and August 9, 2010, the staff issued RAIs to PG&E regarding scoping and screening. By letters dated August 17 and September 7, 2010, PG&E provided responses to the RAIs. A previous conference call was held on August 31, 2010, in which the staff requested clarification on PG&E's response letter dated August 17, 2010. PG&E requested a telephone conference call for clarification on the staff's concerns related to the previous conference call. In addition, the staff requested a teleconference call for clarification on RAI response letter dated September 7, 2010. The telephone conference call was useful in clarifying the intent of the staff's RAIs and PG&E's responses. Enclosure 1 provides a listing of the participants. Enclosure 2 provides discussions on RAIs and responses for which clarification was requested. No changes to DRAIs were necessary as a result of this telephone conference call.

The applicant had an opportunity to comment on this summary.

Nathaniel Ferrer, Safety Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-275 and 50-323

Enclosures:

As stated

cc w/encls: Distribution via Listserv

LICENSEE: Pacific Gas and Electric Company

FACILITY: Diablo Canyon Nuclear Power Plant, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
SEPTEMBER 30, 2010, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND PACIFIC GAS AND ELECTRIC COMPANY CONCERNING
REQUEST FOR ADDITIONAL INFORMATION RELATED TO THE DIABLO
CANYON NUCLEAR POWER PLANT, UNITS 1 AND 2, LICENSE RENEWAL
APPLICATION – SCOPING AND SCREENING

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Pacific Gas and Electric Company (PG&E) held a telephone conference call on September 30, 2010, to obtain clarification on the staff's request for additional information (DRAI) regarding the Diablo Canyon Nuclear Power Plant license renewal application (LRA).

By letters dated July 20 and August 9, 2010, the staff issued RAIs to PG&E regarding scoping and screening. By letters dated August 17 and September 7, 2010, PG&E provided responses to the RAIs. A previous conference call was held on August 31, 2010, in which the staff requested clarification on PG&E's response letter dated August 17, 2010. PG&E requested a telephone conference call for clarification on the staff's concerns related to the previous conference call. In addition, the staff requested a teleconference call for clarification on RAI response letter dated September 7, 2010. The telephone conference call was useful in clarifying the intent of the staff's RAIs and PG&E's responses. Enclosure 1 provides a listing of the participants. Enclosure 2 provides discussions on RAIs and responses for which clarification was requested. No changes to DRAIs were necessary as a result of this telephone conference call.

The applicant had an opportunity to comment on this summary.

Nathaniel Ferrer, Safety Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-275 and 50-323

Enclosures:

As stated

cc w/encls: Distribution via Listserv

DISTRIBUTION:

ADAMS Accession No.:

OFFICE	LA:DLR	PM:RPB2:DLR	BC:RPB2:DLR	PM:RPB2:DLR
NAME		NFerrer	DWrona	NFerrer
DATE	/ /10	/ /10	/ /10	/ /10

OFFICIAL RECORD COPY

**TELEPHONE CONFERENCE CALL
DIABLO CANYON NUCLEAR POWER PLANT, UNITS 1 AND 2
LICENSE RENEWAL APPLICATION**

**LIST OF PARTICIPANTS
SEPTEMBER 30, 2010**

PARTICIPANTS

Nate Ferrer
Garry Armstron
Greg Casto
Terry Grebel
Philippe Soenen
Dan Gibbons
Brandy Sizemor
David Kunsemiller
Chalmer Myer
Al Saunders
Rye Davis

AFFILIATIONS

U.S. Nuclear Regulatory Commission (NRC)
NRC
NRC
Pacific Gas & Electric (PG&E)
PG&E
PG&E
PG&E
Strategic Teaming And Resource Sharing (STARS)
STARS
STARS
STARS

Diablo Canyon Nuclear Power Plant, Units 1 and 2
License Renewal Application
Request for Additional Information (13 and 18)
Scoping and Screening

RAI 2.3.3.6-2 and 2.3.3.18-2

By letters dated August 17 and September 7, 2010, the applicant responded to RAIs 2.3.3.6-2 and 2.3.3.18-2, and provided a description of how seismic endpoints were established at various panels. The staff was unclear how the applicant designated the endpoints as base-mounted equipment.

Discussion:

PG&E agreed to supplement its responses to RAIs 2.3.3.6-2 and 2.3.3.18-2 to address how endpoints at base-mounted equipment were established.

RAI 2.3.3.7-3

By letter dated September 7, 2010, the applicant responded to RAI 2.3.3.7-3, and provided a description of the water traps, and indicated that there are not oil filters located in the turbine building. However, the staff was unclear about a component indicated as an oil filter on license renewal boundary drawing LR-DCPP-25-106725-50. The staff was also unclear if a failure of the described water traps could affect safety-related equipment.

Discussion:

PG&E agreed to supplement its response to RAI 2.3.3.7-3 to clarify the oil filter on the above license renewal boundary drawing and provide clarification on whether failure of the water traps described above could affect safety-related equipment.