

Burritt, Arthur

From: Kaufman, Paul *RV*
Sent: Thursday, April 15, 2010 6:57 PM
To: Conte, Richard
Cc: OHara, Timothy; Burritt, Arthur
Subject: RE: Unit 1 Containment liner photos

Status Update Salem Unit 1 – AFW Buried Piping

PSEG has cut out approximately 60 ft-70ft. of AFW piping that is relatively shallow (< 5 feet) that was determined to be degraded or required to much preparation work to obtain UT readings. The finite element analysis evaluating the structural integrity of the rest of the AFW piping is expected to be completed by Monday April 19.

Outside of Scope

Outside of Scope

Information in this record was deleted in
accordance with the Freedom of Information Act.
Exemptions: outside of scope
FOIA/PA 2010-0334

D-44

Outside of Scope