

Schroeder, Daniel

From: Balian, Harry
Sent: Thursday, April 08, 2010 11:35 PM
To: Schroeder, Daniel
Cc: OHara, Timothy
Subject: Thursday Night

Outside of Scope

out of scope

Continued walking down Unit 1 AFW piping for additional degradation issues - taking credit for a partial alignment (04Q)

Outside of Scope

out of scope

Degraded AFW Pipe - I walked down the Unit 1 inner pen and found nothing remarkable. There is still a pipe section that I can't account for that is pissin' me off. I'll look for it in the Mechanical Pen tomorrow. Once done, that will only leave the portion buried beneath the door to nowhere area that I haven't gone hand-over-hand.

Outside of Scope

out of scope

Harry Balian
(856) 339 - 1041 - office

(b)(6) cell
home

6