

Schroeder, Daniel

From: Conte, Richard *CS*
Sent: Monday, April 19, 2010 2:46 PM
To: Schmidt, Wayne; Schroeder, Daniel; Balian, Harry; Burritt, Arthur; Cline, Leonard
Cc: Cook, William; Cahill, Christopher; OHara, Timothy; Gray, Harold
Subject: RE: Salem AFW

expanding to Harold and Tim

From: Schmidt, Wayne *W*
Sent: Monday, April 19, 2010 1:44 PM
To: Conte, Richard; Schroeder, Daniel; Balian, Harry; Burritt, Arthur; Cline, Leonard
Cc: Cook, William; Cahill, Christopher
Subject: Salem AFW

It looks like the driver for any issues where AFW cannot supply flow to all four SG or at least 3 of 4 SGs is ATWS. This also is perhaps where SG pressure may be the highest.

Wayne Schmidt
Senior Reactor Analyst, US NRC Region I
Alt E-mail: waynelschmidt@tmo.blackberry.net
Office - 610-337-5315
Cell (b)(6)
Fax - 610-337-5320

D-51