Ziev, Tracey

From:	OHara, Timothy
Sent:	Friday, April 23, 2010 5:53 PM
То:	Burritt, Arthur; Conte, Richard; Gray, Harold; Schroeder, Daniel; Balian, Harry; Cahill, Christopher
Cc:	Cline, Leonard; Douglas, Christopher; Lew, David; Clifford, James
Subject:	RE: Salem AFW Priorities/Next Steps

Art,

The long term concern should also include PSEG determining the design life of the new coating for completeness.

Tim OHara

From: Burritt, Arthur Sent: Friday, April 23, 2010 4:27 PM To: Conte, Richard; OHara, Timothy; Gray, Harold; Schroeder, Daniel; Balian, Harry; Cahill, Christopher Cc: Cline, Leonard; Douglas, Christopher; Lew, David; Clifford, James Subject: Salem AFW Priorities/Next Steps

Why is Unit 2 Ok

<u>Testing</u>

- Confirm the PSEG risk assessment to delay AFW testing is reasonable Cahill
- Evaluate pressure drop testing resolution
- Operability
- Evaluate the Unit 2 AFW extent of condition operability assessment (focus on the differences between Unit 1 & 2) Schroeder/O'Hara
- Confirm the finite element analysis for the Unit 1 as found condition is acceptable including the use of appropriate methods and assumptions – O'Hara/HQ
- Confirm the technical evaluation that supports 1275 psig is bounding (including a faulted S/G scenario) complete no concerns

What Needs to be Done Prior to Unit Startup

- Verify hydro/pressure test is code compliant O'Hara
- Evaluate the 50.59 for AFW modifications O'Hara
- · Verify the ANI reviews and accepts repairs including testing O'Hara
- Smart samples
 - Verify repairs to the control air system elbow that was replaced (how will PSEG certify the repair) O'Hara
 - Verify control air pipe coating are repaired including at the support clamps (visual check of the as left condition) – O'Hara

Long Term Concerns

AFW coating cure time acceptability