



SUPPORT MARK NO.	No. OF SUPPORTS REQ'D.	No. OF FRAMES REQ'D.	"A"	"B"	EL. "C"
14 AFWS - 6	1	1	3/8" MIN.	5'-0"	95'-11 5/16"
12 AFWS - 6	1	1		3'-0"	95'-11 5/16"
14 AFWS - 7	1	1		2'-9"	95'-11 5/16"
12 AFWS - 7	1	1		2'-11"	95'-10 7/8"
14 AFWS - 8	1	1		2'-9"	95'-10 3/4"
12 AFWS - 8	1	1		2'-9"	95'-10 3/4"
14 AFWS - 9	1	1		2'-9"	95'-9 13/16"
12 AFWS - 9	1	1		2'-9"	95'-9 13/16"
14 AFWS - 10	1	1		2'-9"	95'-9 13/16"
12 AFWS - 10	1	1		2'-9"	95'-9 13/16"
14 AFWS - 12	1	1		2'-11"	95'-10 7/8"
12 AFWS - 12	1	1		2'-11"	95'-10 7/8"
14 AFWS - 13	1	1		2'-11"	95'-10 7/8"
12 AFWS - 13	1	1		2'-7"	95'-10 7/8"
14 AFWS - 14	1	1		2'-9"	95'-9 13/16"
12 AFWS - 14	1	1		2'-9"	95'-9 13/16"
14 AFWS - 15	1	1		3'-1"	95'-9 13/16"
12 AFWS - 15	1	1		3'-5"	95'-9 7/8"
14 AFWS - 16	1	1		4'-3"	95'-9 7/8"
12 AFWS - 16	1	1		4'-6"	95'-9 3/8"
14 AFWS - 17	1	1			
12 AFWS - 17	1	1			
14 AFWS - 18	1	1			
12 AFWS - 18	1	1			
14 AFWS - 19	1	1			
12 AFWS - 19	1	1			

NOTES:
 1. DRILL 1/16" DIA HOLE FOR 1/2" U-BOLTS (TYP)
 2. COAT U-BOLTS AND BASEPLATE WITH CERAMALLOY CL+AC COATING

ORIGINAL FIELD NOTE: ADD PER FCR 60089561-1110
 (2) HEAVY COATS AS05 BITUMASTIC MATERIAL TO BE APPLIED TO ALL HANGER PARTS AFTER ERECTION

14 AFWS - 6 THRU 10 & 12 THRU 19
 12 AFWS - 6 THRU 10 & 12 THRU 19

NOTE: FOR LOCATION OF SUPPORTS SEE PLAN SHEET 3

REF: 207483 A 8923

2	REVISED 3" DIA. FOR 14AFWS-6 & 12AFWS-6 PER AS BUILT DWG.	1	2	3	4	80101381R0 H01R1 REVISE PER FCR 60089561-1110	Salem Nuclear Generating Station No. 1 Unit - Reactor Containment Auxiliary Feedwater El. 78'0" & El. 100'0"	226129D41000
No	DESCRIPTION	DATE	BY	CHKD	APP'D	REV	Hangers	SHEET 4 OF 24