




# ECCS Suction Strainers Debris Characteristics Issue No. 10

Tony Borger  
ECCS Suction Strainers Committee  
Source Term Vice Chairman

NRC / BWROG Resolution Plans  
October 20 - 21, 2010  
Rockville, MD



# Topics

---

Issue Overview

Problem Statement

BWROG Objective

URG Assessment

GSI-191 Approach

Proposed Resolution

Relationships to Other Issues

Next Steps and Milestones

# Issue Overview

---

The NRC stated the following regarding “Debris Characteristics” from the November 2007 presentation by Ralph Architzel (NRC) to the BWROG:

- “Blockage potential of calcium silicate insulation and other problematic materials such as microporous insulation may not have been treated conservatively”
- “Recent testing for PWRs has identified potential for significant head loss increases”

# Problem Statement

---

The modeling of Cal-Sil and microporous insulation (Min-K and microtherm) as particulates in head loss correlations does not fully account for their head loss impact at concentrations greater than 20%

# Additional Topics

---

OG will also address debris characteristics related to other issues

- Fiber
- Coatings
- Sources of other drywell debris, such as dirt, dust, and rust

# BWROG Objective

---

Develop document that identifies acceptable debris characteristics for use in BWR strainer qualification analysis and testing

Plants will compare their analysis to the guidance document and address gaps

Expectations:

- Most debris characteristics used by BWRs were appropriate
- Some materials may need special treatment

# URG Assessment

---

## Microporous and Cal-Sil

- No specific debris characteristics guidance

## Fiber Insulation Debris

- The URG adopted a three category size distribution for the fiberglass debris in the ZOI: fines, large pieces, and blankets
- Large pieces at upper elevations were judged to be held up in gratings in the drywell and not transported to the suppression pool
- The size distribution of fiber in the suppression pool consists of fines (23%) and large pieces (77%)

# URG Assessment

---

## Non-Insulation Debris

Dirt/Dust: This issue is under detailed resolution under Issue No. 6, *Latent Debris (Dirt/Dust)*

Rust from Unpainted Steel Surfaces: The URG recommended 50 lbm on the basis of engineering judgment. This source term considers unpainted steel surfaces in the drywell, the main vents/downcomers and that portion of the suppression chamber above the pool. Rust was considered to be in the form of “flakes”

Paints/Coatings in the ZOI: The URG recommends a maximum of 85 lbm for ablated coatings within the ZOI

Unqualified/Indeterminate Paint/Coatings: The URG does not provide any specific guidance. However, most evaluations have used either “spheres” or “flakes” as the size classification



# GSI-191 Approach

---

## Microporous / Cal-Sil

- Microporous transport utilized 10 micron particulate
- Cal-Sil transport utilized OPG data for size distribution
- Headloss testing was based on pulverized material

## Fiber Insulation Debris

- Section 3.0 (Baseline Analysis) of NEI-04-07 presents a size distribution of 60% fines and small pieces and 40% large pieces
- The SER to NEI-04-07 provides updated guidance identifying four size classification of fines, small pieces, large pieces and intact pieces

# GSI-191 Approach

---

## Non-insulation Debris

- All particulates are classified as 10 micron spheres for high fiber loads headloss testing
- Coatings transport allowed for treatment of non-spherical debris

# Resolution Strategy

---

A guidance document will be developed that describes what debris characteristics are appropriate for both transport and headloss. The following major steps will be used to develop the guidance:

- Review the current knowledge base of size distribution of debris for BWRs
- Prepare a report that provides recommended BWR debris characteristics
- Provide the report to the NRC for review and comment
- Issue revised report addressing NRC concerns

Document will be sent to utilities for utility comparison

Utilities will individually address any gaps

# Resolution Strategy (cont.)

---

## Expectations:

- Most URG-defined debris characteristics used by BWRs are appropriate
- Cal-Sil and microporous insulation debris characteristics may not have been estimated conservatively for certain debris bed compositions
- Fibrous debris characteristics used for thin-bed testing may have been non-conservative

# Key Relationships to Other Issues

---

## Issues 1 & 2: *Downstream Effects*

- The debris characteristics of the debris that reaches the strainer will impact the quantity and characteristics that bypasses the strainer and transported downstream of it.

## Issue 3: *Debris Bed Head Loss Predictions*

- Different debris characteristics could impact the debris bed and debris head loss predictions.

## Issue 9: *Debris Transport and Erosion*

- Different debris size distributions could impact the quantity of debris transported to the suppression pool.

# Next Steps and Milestones

---

Review the current knowledge base of size distribution of fibrous debris for BWRs	4Q 2010
Prepare a report that provides recommended BWR debris characteristics	2Q 2011
Provide report to NRC for review and comment	2Q 2011
Issue revised report addressing NRC concerns	3Q 2011